No-TPCODL/**5663** Date: **14.08.2026**

To

1.) Mr. Milind Deore,
Director, Bureau of Energy Efficiency, GoI, Ministry of Power.
4th Floor, Sewa Bhawan, R.K. Puram, New Delhi-110066
Email Id: - mdeore@beeindia.gov.in, suryay@beeindia.gov.in

2.) The Engineer-In-Chief (Electricity) -cum- Principal Chief Electrical Inspector (State Designated Agency, Odisha) Unit-5, Power House Square, Vidyut Marg, Bhubaneswar, 751001
Email Id: - eic-epcei@nic.in, sdaorissa@nic.in

Sub: Submission of 20th Periodic Energy Accounting Report of TPCODL for 1st Quarter of FY 2026-27 in pursuant to Regulation-4 (2) (b) of the BEE (Manner and intervals for conduct of Energy Audit in Electricity Distribution Companies) Regulation 2021 under EC Act-2001.

Sir/Madam,

With reference to the above cited subject, the 20th Periodic Energy Accounting Report of TPCODL for 1st Quarter of FY 2026-27 is submitted herewith in pursuant to Regulation-4(2) (b) of the Bureau of Energy Efficiency (Manner and intervals for conduct of Energy Audit in Electricity Distribution Companies) Regulation 2021 under EC Act-2001 in the specified format of BEE.

This is for favour of kind information & necessary action please.

Yours faithfully,

Chief (RCM, Enforcement & Energy Audit)
Nodal Officer, Energy Audit Cell, TPCODL

Encl: -

1.) Periodic Energy Accounting Report for Q-1 FY 2026-27 of TPCODL in Excel & PDF
2.) Notes for Periodic Energy Auditing Report of TPCODL for Q-1 FY 2026-27
3.) Power Procurement by GRIDCO approved by the commission for FY 2026-27

NOTES FOR PERIODIC ENERGY ACCOUNTING REPORT OF TPCODL

(FOR QUARTER-1 OF FY 2026-27)

Point -1:

Sheet No	Name	Particulars
3	Details of Input Infrastructure	• Line, AB and U/G cable length is not segregated voltage wise. • Input energy is shown at >66kv only, which is not matching with the injection voltages mentioned (0.4 kV,11 kV,33 kV & 132kV) in the form of Meter reading of Input Energy at injection points. • In Energy Accounting Summary OA input is 213.665MU and sales is 213.665MU which is matching with the form of input energy where Open access sale is mentioned as 213.665 MU. • In Loss Estimation for DISCOM, % D loss should be 18.2086 % in place of 0.182086.

Remarks-1:

a.) The format provided by the BEE, India is predefined One and it doesn't allow us to provide the line, AB & UG Cable length voltage wise. However, these data are as follows for your reference.

Sl. No.	Particulars	33kV	11kV	LT	Total
1	Line length (ckt. km)	4563	30498	41891	76952
2	Length of Aerial Bunched Cables	7	1241	37794	39042
3	Length of Underground Cables	629	653	75	1357

b.) The energy drawl or the interface point between TPCODL as a DISCOM and OPTCL as Transmission entity is essentially at the secondary of the Power Transformer. Hence, the total input energy to the DISCOM is 3869.86 MU and this has been segregated as 521.06 MU for >66kV Only & balance as 3348.8 MU for 33kV & below which is matching with the sum of the injection voltages mentioned at (0.4 kV,11 kV,33 kV & 132kV) in the form of Meter reading of Input Energy at injection points .

c.) The conventional generating station, including captive generating plant and consumer which has been granted connectivity to the distribution system as Open Access Consumer have the following drawls for this quarter

Sl.No.	Open Access Particulars	MU
1	Schedule (BSP) Open Access	139.4016
2	Actual Drawal from the System	353.0669
3	Netting Billing (Net KWh from TPCODL)	213.6652

Hence, basing on the above, the total Open access Input & Open Access Sales have been mentioned as 213.6652 MUs only.

d.) The format provided by the BEE, India is predefined One and it doesn't allow us to change the formula into % or doesn't allow us to multiply 100 in the Distribution Loss % and Hence, though % D loss is 18.2086 %, it has been arrived as 0.182086 being the non-editable format.

Point -2:

Sheet No	Name	Particulars
5	Form- Input Energy	Under Part-B: Some of the details such as Status of Communication, CT/PT Ratio, Sales Energy are not provided in the report

Remarks-2:

a.) Status of Communication has been left blank, as we don't have AMR/AMI Compliant meters in these input points.

b.) CT/PT Ratios have been filled with the MF of the T&D Interface meter.

c.) Sales Energy against each input points of DISCOM periphery is unavailable since TPCODL is having so many ring main networks and many 33 KV feeder emerges from one to many secondary sides of the Power Transformer of the OPTCL Grids. Hence, it was left blank but, as a whole 3165.216 MU is the Sales Energy of the TPCODL as filled in Division Wise Losses in this quarter.

Point-3:

Sheet No	Name	Particulars
6	Details of Received Sources	Details related to Generation at Transmission Periphery and Embedded Generation in DISCOM area not provided.

Remarks-3:

TPCODL as a Distribution licensee is carrying out the function of distribution and retail supply of electricity covering 5 distribution circles in its license area. The requirement of power for TPCODL is fully managed and met by GRIDCO. GRIDCO being a Bulk Supplier of Power in line with the 'Single Buyer Model' for the whole state of Odisha and as such the details pertaining to Generation at Transmission periphery and embedded generation for a particular DISCOM is not distinctly available. However, the same as a State is available in Honourable OERC`s order for GRIDCO`s ARR approval for FY 2026-27, relevant portion attached herewith.

The energy drawl or the interface point between TPCODL as a DISCOM and OPTCL as Transmission entity is essentially at the secondary of the Power Transformer or at 33 kV Side and therefore the DISCOM as such does not have any visibility of the Generation and Transmission Periphery. Hence, the sheet is left blank. However, the energy drawl by the TPCODL is 3869.86 MU.

Point-4:

Sheet No	Name	Particulars
8	Details of Feeder wise losses	Details of 955 nos of 11kV feeders shared out of total 1434 nos of metered 11kV feeders.

Remarks-4:

a.) TPCODL is having 1408 nos of Active OK smart meters out of the total 1434 nos of metered 11 kV feeders. We are working for completion of 100% feeder metering with smart meters.

b.) Moreover, the feeder-wise loss depends mainly on the consumer tagging and TPCODL is in the process of completion of GIS based consumer mapping. Since, all

the consumers were not mapped, there was huge gaps in the feeder-wise Energy Audit report and hence, we were able to submit 955 nos of feeders only having losses between 0% to 80% out of 1434 nos. of total metered feeders.

c.) The available data for the feeder wise loss details have been provided as follows:

i. Received at Feeder (Final in MU)= Feeder Meter Units Advanced in MU

ii. Feeder Consumption (in MU)= Feeder Meter Units Advanced in MU

iii. Final Net Export at Feeder Level (In MU)= Units Billed in MU in case of 11 kV Feeder Audit

Point-5:

Sheet No	Name	Particulars
10	Subsidy Details	Please provide the details of subsidy as per the enclosed format at Annexure-I

Remarks-5:

a.) There is no provision for subsidy for any category of consumers in the state of Odisha as per the Regulations and Tariff Orders of the Hon'ble Odisha Electricity Regulatory Commission. Thus, subsidy payable per unit in each consumer category by the state Govt. is not applicable for TPCODL.

b.) Moreover, TPCODL is not yet funded under the Revamped Distribution Sector Scheme (RDSS) rolled out by Ministry of Power. Hence, this sheet is left blank.

Chief (RCM, Enforcement & Energy Audit)
Nodal Officer, Energy Audit Cell, TPCODL

General Information

1	**Name of the DISCOM**	TP CENTRAL ODISHA DISTRIBUTION LIMITED (TPCODL)			
2	**i) Year of Establishment**	1ST JUNE 2020			
	ii) Government/Public/Private	JOINT VENTURE			
3	**DISCOM's Contact details & Address**				
i	City/Town/Village	BHUBANESWAR			
ii	District	KHURDA			
iii	State	ODISHA		Pin	751012
iv	Telephone	0674-2533726		Fax	
4	**Registered Office**				
i	Company's Chief Executive Name	MR. GAJANAN KALE			
ii	Designation	CHIEF EXECUTIVE OFFICER			
iii	Address	POWER HOUSE SQUARE, UNIT-8			
iv	City/Town/Village	BHUBANESWAR		P.O.	NAYAPALLI
v	District	KHURDA			
vi	State	ODISHA		Pin	751012
vii	Telephone	0674-2533726		Fax	
5	**Nodal Officer Details***				
i	Nodal Officer Name (Designated at DISCOM's)	MR. PRAVEEN KUMAR SHARMA			
ii	Designation	CHIEF (RCM, ENFORCEMENT & ENERGY AUDIT)			
iii	Address	2ND FLOOR, IDCO TOWER, JANPATH			
iv	City/Town/Village	BHUBANESWAR		P.O.	BHOINAGAR
v	District	KHURDA			
vi	State	ODISHA		Pin	751022
vii	Telephone	9971555148		Fax	
6	**Energy Manager Details***				
i	Name	MR. SHANKARSHAN PANIGRAHI			
ii	Designation	EXECUTIVE ENGINEER		Whether EA or EM	EM
iii	EA/EM Registration No.	EA-27961			
iv	Telephone	7978384770		Fax	
v	Mobile	7978384770	E-mail ID	s.panigrahi@tpecentralodisha.com	
7	**Period of Information**				
	Year of (FY) information including Date and Month (Start & End)	1st April 2026 to 30th Jun 2026			

Performance Summary of Electricity Distribution Companies			
1	Period of Information Year of (FY) information including Date and Month (Start & End)	1st April 2026 to 30th Jun 2026	
2	**Technical Details**		
(a)	**Energy Input Details**		
(i)	Input Energy Purchase (From Generation Source)	Million kwh	3869.86
(ii)	Net input energy (at DISCOM Periphery after adjusting the transmission losses and energy traded)	Million kwh	3869.86
(iii)	Total Energy billed (is the Net energy billed, adjusted for energy traded))	Million kwh	3165.22
(b)	Transmission and Distribution (T&D) loss Details	Million kwh	704.65
		%	18.21%
	Collection Efficiency	%	84.53%
(c)	Aggregate Technical & Commercial Loss	%	30.86%

I/We undertake that the information supplied in this Document and Pro-forma is accurate to the best of my knowledge and if any of the information supplied is found to be incorrect and such information result into loss to the Central Government or State Government or any of the authority under them or any other person affected, I/we undertake to indemnify such loss.

Authorised Signatory and Seal

Name of Authorised Signatory
Name of the DISCOM:
Full Address:-

Praveen Sharma
Chief RCM
TPCODL

TP Central Odisha Distribution Limited Bhubaneswar

Seal

Signature:-
Name of AEA*:
Registration Number:

SHANKARSHAN PANIGRAHI
Certified Energy Manager
Regd. No : EA-27961, TPCODL

Form-Details of Input Infrastructure

1	Parameters	Total	Covered during in audit	Verified by Auditor in Sample Check	Remarks (Source of data)
i	Number of circles	5			
ii	Number of divisions	20			
iii	Number of sub-divisions	65			
iv	Number of feeders	1751			
v	Number of DTs	95274			
vi	Number of consumers	3409145			
2	**Parameters**	**66kV and above**	**33kV**	**11/22kV**	**LT**
a. i.	Number of conventional metered consumers	42	13	2700	2459279
ii	Number of consumers with 'smart' meters	0	354	15606	926502
iii	Number of consumers with 'smart prepaid' meters	0	2	7079	80822
iv	Number of consumers with 'AMR' meters	0	0	0	0
v	Number of consumers with 'non-smart prepaid' meters	0	0	0	0
vi	Number of unmetered consumers	0	0	0	4649
vii	**Number of total consumers**	42	367	18306	3390430
b.i.	Number of conventionally metered Distribution Transformers				
ii	Number of DTs with communicable meters			19208	
iii	Number of unmetered DTs			76066	
iv	**Number of total Transformers**			95274	
c.i.	Number of metered feeders		295	1434	
ii	Number of feeders with communicable meters		294	1434	
iii	Number of unmetered feeders		0	22	
iv	**Number of total feeders**		295	1456	
d.	Line length (ct km)		76952		
e.	Length of Aerial Bunched Cables		39042		
f.	Length of Underground Cables		1357		

3	Voltage level	Particulars	MU	Reference	Remarks (Source of data)
i	66kV and above	Long-Term Conventional	521	Includes input energy for franchisees	
		Medium Conventional			
		Short Term Conventional			
		Banking			
		Long-Term Renewable energy			
		Medium and Short-Term RE		Includes power from bilateral/ PX/ DEEP	
		Captive, open access input		Any power wheeled for any purchase other than sale to DISCOM. Does not include input for franchisee.	
		Sale of surplus power			
		Quantum of inter-state transmission loss		As confirmed by SLDC, RLDC etc	
		Power procured from inter-state sources	521	Based on data from Form 5	
		Power at state transmission boundary	521		
		Long-Term Conventional	3,349		
		Medium Conventional			
		Short Term Conventional			
		Banking			

ii	33kV	Long-Term Renewable energy			
		Medium and Short-Term RE			
		Captive, open access input			
		Sale of surplus power			
		Quantum of intra-state transmission loss	0		
		Power procured from intra-state sources	3,349		
iii		**Input in DISCOM wires network**	3,870		
iv	33 kV	Renewable Energy Procurement			
		Small capacity conventional/ biomass/ hydro plants Procurement			
		Captive, open access input			
v	11 kV	Renewable Energy Procurement			
		Small capacity conventional/ biomass/ hydro plants Procurement			
		Sales Migration Input			
vi	LT	Renewable Energy Procurement			
		Sales Migration Input			
vii		**Energy Embedded within DISCOM wires network**	0		
viii		**Total Energy Available/ Input**	3,870		
4	**Voltage level**	**Energy Sales Particulars**	**MU**	**Reference**	
i	LT Level	DISCOM' consumers	1,931	Include sales to consumers in franchisee areas, unmetered consumers	
		Demand from open access, captive		Non DISCOM's sales	
		Embedded generation used at LT level		Demand from embedded generation at LT level	
		Sale at LT level	1,931		
		Quantum of LT level losses	677		
		Energy Input at LT level	2,608		
ii	11 kV Level	DISCOM' consumers	395	Include sales to consumers in franchisee areas, unmetered consumers	
		Demand from open access, captive		Non DISCOM's sales	
		Embedded generation at 11 kV level used		Demand from embedded generation at 11kV level	
		Sales at 11 kV level	395		
		Quantum of Losses at 11 kV	20		
		Energy input at 11 kV level	415		
iii	33 kV Level	DISCOM' consumers	318	Include sales to consumers in franchisee areas, unmetered consumers	
		Demand from open access, captive		Non DISCOM's sales	
		Embedded generation at 33 kV or below level		This is DISCOM and OA demand met via energy generated at same voltage level	
		Sales at 33 kV level	318		
		Quantum of Losses at 33 kV	8		
		Energy input at 33kV Level	326		
iv	> 33 kV	DISCOM' consumers	521	Include sales to consumers in franchisee areas, unmetered consumers	
		Demand from open access, captive		Non DISCOM's sales	
		Cross border sale of energy			
		Sale to other DISCOMs			
		Banking			
		Energy input at > 33kV Level	521		
		Sales at 66kV and above (EHV)	521		
		Total Energy Requirement	**3,870**		
		Total Energy Sales	**3,165**		

Energy Accounting Summary					
5	**DISCOM**	**Input (in MU)**	**Sale (in MU)**	**Loss (in MU)**	**Loss %**
i	LT	2,608	1,931	677	25.96%
ii	11 Kv	415	395	20	4.74%
iii	33 kv	326	318	8	2.37%
iv	> 33 kv	521	521	0	0%
6	**Open Access, Captive**	**Input (in MU)**	**Sale (in MU)**	**Loss (in MU)**	**Loss %**
i	LT				
ii	11 Kv				
iii	33 kv				
iv	> 33 kv	213.66515	213.66515	0	0%

Loss Estimation for DISCOM	
T&D loss	705
D loss	705
T&D loss (%)	0.182085638
D loss (%)	0.182085638

Details of Division Wise Losses (See note below**)

Division Wise Losses

Period From 1st Apr, 2026 to 30th June 2026

S.No	Name of circle	Circle code	Name of Division	Consumer profile								Energy parameters					Losses		Commercial Parameter			AT & C loss (%)
													Billed energy (MU)									
				Consumer category	No of connection metered (Nos)	No of connection Un-metered (Nos)	Total Number of connections (Nos)	% of number of connections	Connected Load metered (MW)	Connected Load Un-metered (MW)	Total Connected Load (MW)	% of connected load	Input energy (MU)	Metered energy	Unmetered/assessment energy	Total energy	% of energy consumption	T&D loss (MU)	T&D loss (%)	Billed Amount in Rs. Crore	Collected Amount in Rs. Crore	Collection Efficiency	
1	Electrical Circle - I , Bhubaneswar	1000	BCDD-01 , BHUBANESWAR	Residential	51739	0	51739	77%	158.8634	0	158.86337	48%	156.62	61.84368	0	61.84368119	42%	9.985251	6%	33.990	28.255	83.13%	
				Agricultural	0	0	0	0%	0	0	0	0%		0	0	0	0%			0	0	0.00%	
				Commercial/Industrial-LT	14856	0	14856	22%	73.97342	0	73.97342	23%		30.26553	0	30.26552793	21%			22.761	21.252	93.37%	
				Commercial/Industrial-HT	353	0	353	1%	79.70798	0	79.70798	24%		45.79758	0	45.79757739	31%			32.909	29.682	90.20%	
				Others	622	8	630	1%	15.1753	0.6275	15.8028	5%		8.094517	0.634969	8.729486235	6%			6.027	5.337	88.55%	
Sub-total					**67570**	**8**	**67578**	**100%**	**327.72007**	**0.6275**	**328.34757**	**100%**	**156.6215**	**146.0013**	**0.634969**	**146.6362728**	**100%**	**9.985251**	**6%**	**95.6868586**	**84.5253607**	**88.34%**	**17%**
2	Electrical Circle - I , Bhubaneswar	1000	BCDD-02 , BHUBANESWAR	Residential	201957	2	201959	86%	631.8086	0.0045	631.813147	63%	477.22	213.3844	0.001058	213.3854398	48%	37.01085	8%	113.231	91.023	80.39%	
				Agricultural	175	0	175	0%	1.97847	0	1.97847	0%		0.521798	0	0.521798026	0%			0.168	0.155	92.06%	
				Commercial/Industrial-LT	29528	0	29528	13%	126.284	0	126.28403	13%		56.43556	0	56.43555906	13%			42.676	38.989	91.36%	
				Commercial/Industrial-HT	666	0	666	0%	203.5473	0	203.54729	20%		141.3862	0	141.3862107	32%			98.111	89.256	90.97%	
				Others	1492	182	1674	1%	39.48679	0.95945	40.44624	4%		27.53395	0.945849	28.479796	6%			20.083	19.182	95.51%	
Sub-total					**233818**	**184**	**234002**	**100%**	**1003.1052**	**0.96395**	**1004.069177**	**100%**	**477.2197**	**439.2619**	**0.946907**	**440.2088036**	**100%**	**37.01085**	**8%**	**274.269924**	**238.604887**	**87.00%**	**20%**
3	Electrical Circle - I , Bhubaneswar	1000	BED , BHUBANESWAR	Residential	155289	9	155298	85%	499.8321	0.0185	499.85061	71%	302.67	171.6056	0.011519	171.6170707	63%	29.97205	10%	92.035	75.220	81.73%	
				Agricultural	466	0	466	0%	2.52669	0	2.52669	0%		0.904662	0	0.904662447	0%			0.266	0.260	97.76%	
				Commercial/Industrial-LT	26378	1	26379	14%	111.8332	0.0005	111.83367	16%		43.55009	0.00026	43.55035478	16%			32.683	29.972	91.70%	
				Commercial/Industrial-HT	431	0	431	0%	76.8641	0	76.8641	11%		45.06289	0	45.06289185	17%			33.167	30.455	91.82%	
				Others	964	41	1005	1%	16.85845	0.8725	17.73095	3%		10.62576	0.941701	11.56746406	4%			8.493	8.052	94.80%	
Sub-total					**183528**	**51**	**183579**	**100%**	**707.91452**	**0.8915**	**708.80602**	**100%**	**302.6745**	**271.749**	**0.95348**	**272.7024439**	**100%**	**29.97205**	**10%**	**166.643214**	**143.958068**	**86.39%**	**22%**
4	Electrical Circle - I , Bhubaneswar	1000	NED , NIMAPARA	Residential	183580	75	183655	87%	223.9836	0.0935	224.077113	70%	171.74	66.89133	0.030101	66.92142661	66%	70.4542	41%	30.826	21.588	70.03%	
				Agricultural	6651	52	6703	3%	25.56401	0.1625	25.726507	8%		6.856357	0.030579	6.886935852	7%			1.346	1.118	83.04%	
				Commercial/Industrial-LT	16003	1	16004	8%	47.63922	0.0005	47.63972	15%		14.72588	0	14.72587795	15%			10.866	9.510	87.52%	
				Commercial/Industrial-HT	120	0	120	0%	11.6766	0	11.6766	4%		7.332963	0	7.332962543	7%			5.209	4.501	86.40%	
				Others	3238	243	3481	2%	8.97735	1.2801	10.25745	3%		4.216073	1.198359	5.41443191	5%			3.848	1.432	37.22%	
Sub-total					**209592**	**371**	**209963**	**100%**	**317.84079**	**1.5366**	**319.37739**	**100%**	**171.7358**	**100.0226**	**1.259039**	**101.2816349**	**100%**	**70.4542**	**41%**	**52.095189**	**38.1483082**	**73.23%**	**57%**
5	Electrical Circle - II , Bhubaneswar	2000	KED , KHURDA	Residential	200080	416	200496	89%	256.5347	0.4685	257.00322	46%	313.84	87.25961	0.195508	87.45511657	34%	57.52355	18%	41.388	29.641	71.62%	
				Agricultural	3423	1	3424	2%	19.27641	0.003	19.27941	3%		4.357266	0.000346	4.357612026	2%			0.884	0.728	82.42%	
				Commercial/Industrial-LT	18145	8	18153	8%	64.36435	0.007	64.37135	12%		20.05626	0.004764	20.06102393	8%			14.874	13.044	87.70%	
				Commercial/Industrial-HT	648	0	648	0%	167.3688	0	167.36883	30%		101.7584	0	101.7584283	40%			71.893	62.705	87.22%	
				Others	2675	181	2856	1%	46.86414	0.8318	47.69594	9%		41.85006	0.829343	42.67940082	17%			29.024	24.980	86.07%	
Sub-total					**224971**	**606**	**225577**	**100%**	**554.40845**	**1.3103**	**555.71875**	**100%**	**313.8351**	**255.2816**	**1.029961**	**256.3115817**	**100%**	**57.52355**	**18%**	**158.063491**	**131.098869**	**82.94%**	**32%**
6	Electrical Circle - II , Bhubaneswar	2000	NED, NAYAGARH	Residential	213713	377	214090	91%	220.5921	0.5595	221.15161	71%	104.68	60.21632	0.240179	60.45649958	73%	22.02096	21%	27.388	21.952	80.15%	
				Agricultural	3583	15	3598	2%	15.08062	0.03463	15.11525	5%		1.68746	0.006445	1.693905081	2%			0.353	0.251	71.24%	
				Commercial/Industrial-LT	14156	5	14161	6%	43.91513	0.004	43.91913	14%		12.0115	0.002499	12.01399812	15%			8.802	7.924	90.02%	
				Commercial/Industrial-HT	112	0	112	0%	14.87727	0	14.87727	5%		2.912743	0	2.912743461	4%			2.593	2.239	86.33%	
				Others	2798	297	3095	1%	15.88063	1.29355	17.17418	6%		4.31061	1.26935	5.579959935	7%			4.245	2.357	55.52%	
Sub-total					**234362**	**694**	**235056**	**100%**	**310.34576**	**1.89168**	**312.23744**	**100%**	**104.6781**	**81.13863**	**1.518473**	**82.65710617**	**100%**	**22.02096**	**21%**	**43.3817561**	**34.7237174**	**80.04%**	**37%**
7	Electrical Circle - II , Bhubaneswar	2000	BED, BALUGAON	Residential	120149	16	120165	91%	132.2569	0.0185	132.275432	68%	89.77	42.03024	0.007777	42.03801297	58%	17.61501	20%	18.961	14.238	75.09%	
				Agricultural	1643	1	1644	1%	9.318338	0.003	9.321338	5%		2.367534	0	2.367534273	3%			0.473	0.392	82.89%	
				Commercial/Industrial-LT	8674	0	8674	7%	23.11617	0	23.11617	12%		7.623384	0	7.623384068	11%			5.592	4.943	88.39%	
				Commercial/Industrial-HT	91	0	91	0%	13.84294	0	13.84294	7%		8.623625	0	8.623624649	12%			6.201	5.276	85.09%	
				Others	1652	244	1896	1%	15.0366	0.51789	15.55449	8%		10.98165	0.524216	11.50586507	16%			7.932	6.864	86.53%	
Sub-total					**132209**	**261**	**132470**	**100%**	**193.57098**	**0.53939**	**194.11037**	**100%**	**89.77343**	**71.62643**	**0.531993**	**72.15842103**	**100%**	**17.61501**	**20%**	**39.1593415**	**31.7131347**	**80.98%**	**35%**
8	Electrical Circle - II , Bhubaneswar	2000	PED,PURI	Residential	199651	189	199840	88%	250.1457	0.202	250.347704	61%	213.92	84.56301	0.004701	84.56770903	54%	57.18482	27%	41.225	27.404	66.47%	
				Agricultural	3271	1	3272	1%	16.28939	0.00373	16.29312	4%		1.632841	0.000698	1.633538832	1%			0.300	0.168	56.19%	
				Commercial/Industrial-LT	21978	2	21980	10%	79.43862	0.0125	79.45112	19%		33.81058	0.007632	33.81821091	22%			25.379	21.701	85.51%	
				Commercial/Industrial-HT	302	0	302	0%	40.19386	0	40.193856	10%		22.47282	0	22.47282055	14%			16.164	13.408	82.95%	
				Others	2675	176	2851	1%	23.9154	1.2855	25.2009	6%		12.97965	1.267658	14.24731082	9%			9.696	8.043	82.95%	
Sub-total					**227877**	**368**	**228245**	**100%**	**409.98297**	**1.50373**	**411.4867**	**100%**	**213.9244**	**155.4589**	**1.280689**	**156.7395902**	**100%**	**57.18482**	**27%**	**92.7628796**	**70.7240667**	**76.24%**	**44%**
9	Electrical Circle, Cuttack	3000	CDD-01, CUTTACK	Residential	81493	0	81493	85%	221.9099	0	221.90986	65%	172.07	89.41401	0	89.41401144	60%	23.1722	13%	48.370	41.859	86.54%	
				Agricultural	1	0	1	0%	0.006	0	0.006	0%		0.000102	0	0.000102	0%			0.000	0.000	0.00%	
				Commercial/Industrial-LT	13993	0	13993	15%	56.32632	0	56.32632	16%		21.34114	0	21.34113594	14%			16.077	15.035	93.52%	
				Commercial/Industrial-HT	179	0	179	0%	34.97793	0	34.97793	10%		20.5724	0	20.57239645	14%			14.664	13.271	90.50%	
				Others	721	7	728	1%	28.60599	1.17094	29.77693	9%		16.3802	1.184992	17.56519077	12%			12.207	9.645	79.01%	
Sub-total					**96387**	**7**	**96394**	**100%**	**341.8261**	**1.17094**	**342.99704**	**100%**	**172.065**	**147.7078**	**1.184992**	**148.8928366**	**100%**	**23.1722**	**13%**	**91.3171404**	**79.8098993**	**87.40%**	**24%**
10	Electrical Circle, Cuttack	3000	CDD-02, CUTTACK	Residential	81950	0	81950	84%	164.9434	0	164.94341	54%	165.96	72.64817	0	72.64816567	49%	18.29934	11%	38.372	31.568	82.27%	
				Agricultural	549	0	549	1%	2.51169	0	2.51169	1%		0.983193	0	0.983192512	1%			0.235	0.190	80.59%	
				Commercial/Industrial-LT	14021	0	14021	14%	60.42388	0	60.42388	20%		21.90803	0	21.908032	15%			15.847	14.823	93.54%	
				Commercial/Industrial-HT	304	0	304	0%	50.07681	0	50.07681	16%		25.96335	0	25.96334938	18%			18.864	16.586	87.92%	
				Others	744	63	807	1%	27.71045	0.792	28.50245	9%		25.35823	0.801512	26.15974283	18%			17.368	16.199	93.27%	
Sub-total					**97568**	**63**	**97631**	**100%**	**305.66624**	**0.792**	**306.45824**	**100%**	**165.9618**	**146.861**	**0.801512**	**147.6624824**	**100%**	**18.29934**	**11%**	**90.6865453**	**79.3662516**	**87.52%**	**22%**

S.No	Name of circle	Circle code	Name of Division	Period From 1st Apr, 2026 to 30th June 2026																			AT & C loss (%)
				Consumer profile										Energy parameters						Losses		Commercial Parameter			
															Billed energy (MU)									
				Consumer category	No of connection metered (Nos)	No of connection Un-metered (Nos)	Total Number of connections (Nos)	% of number of connections	Connected Load metered (MW)	Connected Load Un-metered (MW)	Total Connected Load (MW)	% of connected load	Input energy (MU)	Metered energy	Unmetered/assessment energy	Total energy	% of energy consumption	T&D loss (MU)	T&D loss (%)	Billed Amount in Rs. Crore	Collected Amount in Rs. Crore	Collection Efficiency	
11	Electrical Circle, Cuttack	3000	CED, CUTTACK	Residential	162102	75	162177	89%	216.9452	0.119	217.06422	54%	222.27	63.23713	0.044796	63.28192242	40%	64.31376	29%	30.540	21.830	71.48%	
				Agricultural	3138	2	3140	2%	15.93773	0.014	15.95173	4%		6.248941	0.002421	6.25136235	4%			1.324	1.280	96.69%	
				Commercial/Industrial-LT	14035	2	14037	8%	51.96853	0.004	51.97253	13%		16.29973	0.00262	16.30234579	10%			12.022	10.857	90.31%	
				Commercial/Industrial-HT	322	0	322	0%	64.82149	0	64.82149	16%		41.9758	0	41.97580484	27%			29.141	26.009	89.25%	
				Others	1977	159	2136	1%	48.40636	0.8008	49.20716	12%		29.33957	0.81006	30.14963436	19%			20.477	19.241	93.97%	
Sub-total					**181574**	**238**	**181812**	**100%**	**398.07933**	**0.9378**	**399.01713**	**100%**	**222.2748**	**157.1012**	**0.859897**	**157.9610698**	**100%**	**64.31376**	**29%**	**93.5037814**	**79.2168169**	**84.72%**	**40%**
12	Electrical Circle, Cuttack	3000	AED, ATHAGADA	Residential	130562	19	130581	92%	147.4992	0.027	147.52616	53%	168.61	38.45226	0.011713	38.46397456	31%	45.7954	27%	17.383	14.146	81.38%	
				Agricultural	1346	0	1346	1%	6.6784	0	6.6784	2%		1.803198	0	1.803198487	1%			0.322	0.262	81.27%	
				Commercial/Industrial-LT	7227	2	7229	5%	23.10317	0.001	23.10417	8%		7.039081	0.000659	7.039740487	6%			5.178	4.699	90.75%	
				Commercial/Industrial-HT	111	0	111	0%	36.03935	0	36.03935	13%		12.78806	0	12.78806256	10%			9.212	8.406	91.25%	
				Others	1994	202	2196	2%	64.13969	0.484	64.62369	23%		62.22617	0.48985	62.71602225	51%			38.147	35.614	93.36%	
Sub-total					**141240**	**223**	**141463**	**100%**	**277.45977**	**0.512**	**277.97177**	**100%**	**168.6064**	**122.3088**	**0.502222**	**122.8109983**	**100%**	**45.7954**	**27%**	**70.2421401**	**63.1266896**	**89.87%**	**35%**
13	Electrical Circle, Cuttack	3000	SED, SALIPUR	Residential	116756	1	116757	90%	150.2988	0.001	150.2998	78%	82.70	44.14779	0.000451	44.14823767	78%	26.03606	31%	20.213	14.460	71.54%	
				Agricultural	1599	0	1599	1%	6.9807	0	6.9807	4%		1.62297	0	1.622969538	3%			0.332	0.233	70.04%	
				Commercial/Industrial-LT	9285	2	9287	7%	24.6122	0.002	24.6142	13%		7.408439	0.001289	7.409728427	13%			5.426	4.833	89.08%	
				Commercial/Industrial-HT	69	0	69	0%	5.32086	0	5.32086	3%		1.771173	0	1.771173425	3%			1.402	1.269	90.55%	
				Others	1540	331	1871	1%	4.0522	0.431	4.4832	2%		1.277123	0.431434	1.708557173	3%			1.293	0.236	18.26%	
Sub-total					**129249**	**334**	**129583**	**100%**	**191.26476**	**0.434**	**191.69876**	**100%**	**82.69673**	**56.22749**	**0.433174**	**56.66066623**	**100%**	**26.03606**	**31%**	**28.6661308**	**21.0320288**	**73.37%**	**50%**
14	Electrical Circle, Dhenkanal	4000	DED, DHENKANAL	Residential	213577	151	213728	91%	244.147	0.1745	244.32152	60%	196.47	74.7668	0.073935	74.84073473	54%	57.13502	29%	34.714	24.845	71.57%	
				Agricultural	3658	0	3658	2%	21.59349	0	21.59349	5%		4.952071	0	4.952071182	4%			0.897	0.764	85.12%	
				Commercial/Industrial-LT	13763	3	13766	6%	48.13406	0.002	48.13606	12%		15.19267	0.000916	15.19358514	11%			11.225	9.490	84.54%	
				Commercial/Industrial-HT	407	0	407	0%	65.04432	0	65.04432	16%		33.24468	0	33.24467966	24%			24.991	21.190	84.79%	
				Others	3934	179	4113	2%	28.79734	1.057	29.85434	7%		10.03941	1.063312	11.10272582	8%			8.055	4.380	54.37%	
Sub-total					**235339**	**333**	**235672**	**100%**	**407.71623**	**1.2335**	**408.94973**	**100%**	**196.4688**	**138.1956**	**1.138163**	**139.3337965**	**100%**	**57.13502**	**29%**	**79.882934**	**60.6686373**	**75.95%**	**46%**
15	Electrical Circle, Dhenkanal	4000	AED, ANGUL	Residential	176775	1	176776	88%	197.9963	0.002	197.998334	49%	153.10	68.16854	0.000885	68.16942249	55%	29.98288	20%	32.770	22.660	69.15%	
				Agricultural	5063	0	5063	3%	19.47866	0	19.478656	5%		2.154724	0	2.154723708	2%			0.418	0.352	84.29%	
				Commercial/Industrial-LT	14540	0	14540	7%	47.06629	0	47.06629	12%		17.24341	0	17.24341015	14%			12.776	11.381	89.08%	
				Commercial/Industrial-HT	171	0	171	0%	27.58795	0	27.58795	7%		11.11268	0	11.11268352	9%			8.402	7.867	93.63%	
				Others	3298	73	3371	2%	107.5154	0.483	107.99835	27%		23.95188	0.486796	24.43867681	20%			25.280	25.443	100.65%	
Sub-total					**199847**	**74**	**199921**	**100%**	**399.64458**	**0.485**	**400.12958**	**100%**	**153.1018**	**122.6312**	**0.487681**	**123.1189167**	**100%**	**29.98288**	**20%**	**79.6457394**	**67.7028398**	**85.00%**	**32%**
16	Electrical Circle, Dhenkanal	4000	TED , TALCHER	Residential	165588	69	165657	91%	197.0459	0.0775	197.12341	37%	312.25	66.24763	0.031278	66.27891056	26%	55.51109	18%	31.685	24.073	75.98%	
				Agricultural	1999	4	2003	1%	7.51565	0.008	7.52365	1%		0.903901	0.001945	0.905845711	0%			0.249	0.139	55.90%	
				Commercial/Industrial-LT	10768	2	10770	6%	39.57459	0.002	39.57659	7%		13.20712	0.000896	13.20801654	5%			9.818	8.488	86.45%	
				Commercial/Industrial-HT	186	0	186	0%	29.32616	0	29.32616	5%		14.41683	0	14.41682639	6%			11.112	10.566	95.09%	
				Others	2917	184	3101	2%	263.9821	0.5385	264.52061	49%		161.3735	0.558331	161.9317918	63%			119.338	109.460	91.72%	
Sub-total					**181458**	**259**	**181717**	**100%**	**537.44442**	**0.626**	**538.07042**	**100%**	**312.2525**	**256.1489**	**0.59245**	**256.741391**	**100%**	**55.51109**	**18%**	**172.202191**	**152.726614**	**88.69%**	**27%**
17	Electrical Circle, Paradeep	5000	PED, PARADEEP	Residential	119471	0	119471	91%	149.6486	0	149.64863	40%	287.05	44.73465	0	44.73464821	17%	22.20237	8%	20.476	16.254	79.38%	
				Agricultural	935	0	935	1%	12.8899	0	12.8899	3%		4.525062	0	4.525062178	2%			1.024	0.757	73.87%	
				Commercial/Industrial-LT	8184	0	8184	6%	24.35892	0	24.35892	7%		8.434292	0	8.434292065	3%			6.240	5.568	89.24%	
				Commercial/Industrial-HT	94	0	94	0%	17.1186	0	17.1186	5%		9.264563	0	9.264563335	3%			6.935	5.916	85.31%	
				Others	1867	88	1955	1%	167.5874	0.3475	167.9349	45%		197.5355	0.350997	197.8865457	75%			127.544	118.530	92.93%	
Sub-total					**130551**	**88**	**130639**	**100%**	**371.60345**	**0.3475**	**371.95095**	**100%**	**287.0475**	**264.4941**	**0.350997**	**264.8451115**	**100%**	**22.20237**	**8%**	**162.219449**	**147.02539**	**90.63%**	**16%**
18	Electrical Circle, Paradeep	5000	KED-01, KENDRAPARA	Residential	213740	2	213742	91%	236.5653	0.002	236.56728	71%	147.79	77.31879	0.00082	77.31961407	67%	32.91964	22%	34.678	24.302	70.08%	
				Agricultural	2427	1	2428	1%	19.41511	0.00746	19.42257	6%		5.918184	0	5.918184227	5%			1.396	1.166	83.50%	
				Commercial/Industrial-LT	15640	1	15641	7%	42.25278	0.0005	42.25328	13%		13.81161	0.000254	13.81186734	12%			10.134	8.584	84.71%	
				Commercial/Industrial-HT	135	0	135	0%	13.55636	0	13.55636	4%		5.016687	0	5.016687074	4%			4.128	3.108	75.28%	
				Others	2999	214	3213	1%	17.75779	1.4891	19.24689	6%		11.03575	1.768246	12.80399766	11%			8.701	6.298	72.39%	
Sub-total					**234941**	**218**	**235159**	**100%**	**329.54732**	**1.49906**	**331.04638**	**100%**	**147.79**	**113.101**	**1.76932**	**114.8703504**	**100%**	**32.91964**	**22%**	**59.0365632**	**43.4577611**	**73.61%**	**43%**
19	Electrical Circle, Paradeep	5000	KED-02, MARSHAGHAI	Residential	97685	0	97685	92%	103.0173	0	103.01732	78%	47.83	29.85017	0	29.85017474	80%	10.65362	22%	12.917	9.495	73.51%	
				Agricultural	1406	0	1406	1%	7.16216	0	7.16216	5%		0.554722	0	0.554722124	1%			0.130	0.099	76.34%	
				Commercial/Industrial-LT	5971	0	5971	6%	14.89115	0	14.89115	11%		4.30206	0	4.302059843	12%			3.177	2.708	85.23%	
				Commercial/Industrial-HT	20	0	20	0%	2.133	0	2.133	2%		0.800441	0	0.800440964	2%			0.695	0.537	77.26%	
				Others	1473	142	1615	2%	3.89105	0.4571	4.34815	3%		1.217956	0.452865	1.670820654	4%			1.245	0.173	13.93%	
Sub-total					**106555**	**142**	**106697**	**100%**	**131.09468**	**0.4571**	**131.55178**	**100%**	**47.83184**	**36.72535**	**0.452865**	**37.17821833**	**100%**	**10.65362**	**22%**	**18.1638839**	**13.0125355**	**71.64%**	**44%**
20	Electrical Circle, Paradeep	5000	JED, JAGATSINGPUR	Residential	141157	0	141157	90%	149.1419	0	149.14191	76%	83.30	50.7943	0	50.79429862	76%	16.8583	20%	22.764	17.666	77.61%	
				Agricultural	2578	0	2578	2%	9.85368	0	9.85368	5%		2.220639	0	2.220639106	3%			0.575	0.516	89.59%	
				Commercial/Industrial-LT	9977	0	9977	6%	24.89507	0	24.89507	13%		8.347735	0	8.34773477	13%			6.145	5.422	88.23%	
				Commercial/Industrial-HT	48	0	48	0%	4.7472	0	4.7472	2%		1.82033	0	1.82033021	3%			1.472	1.352	91.84%	
				Others	2100	127	2227	1%	8.02629	0.7305	8.75679	4%		2.522023	0.739325	3.261347555	5%			2.445	1.422	58.17%	
Sub-total					**155860**	**127**	**155987**	**100%**	**196.66415**	**0.7305**	**197.39465**	**100%**	**83.30265**	**65.70503**	**0.739325**	**66.44435026**	**100%**	**16.8583**	**20%**	**33.4016273**	**26.3782164**	**78.97%**	**37%**
21				Residential	0	0	0	#DIV/0!	0	0	0	#DIV/0!	0	0	0	0	#DIV/0!	0	0%	0	0	0.00%	
				Agricultural	0	0	0	#DIV/0!	0	0	0	#DIV/0!		0	0	0	#DIV/0!			0	0	0.00%	
				Commercial/Industrial-LT	0	0	0	#DIV/0!	0	0	0	#DIV/0!		0	0	0	#DIV/0!			0	0	0.00%	
				Commercial/Industrial-HT	0	0	0	#DIV/0!	0	0	0	#DIV/0!		0	0	0	#DIV/0!			0	0	0.00%	
				Others	0	0	0	#DIV/0!	0	0	0	#DIV/0!		0	0	0	#DIV/0!			0	0	0.00%	
Sub-total					**0**	**0**	**0**	**100%**	**0**	**0**	**0**	**100%**	**0**	**0**	**0**	**0**	**100%**	**0**	**0%**	**0**	**0**	**0.00%**	**100%**
				Residential	0	0	0	#DIV/0!	0	0	0	#DIV/0!		0	0	0	#DIV/0!			0	0	0.00%	

S.No	Name of circle	Circle code	Name of Division	Period From 1st Apr, 2026 to 30th June 2026																			
				Consumer profile									Energy parameters					Losses		Commercial Parameter			AT & C loss (%)
				Consumer category	No of connection metered (Nos)	No of connection Un-metered (Nos)	Total Number of connections (Nos)	% of number of connections	Connected Load metered (MW)	Connected Load Un-metered (MW)	Total Connected Load (MW)	% of connected load	Input energy (MU)	Billed energy (MU)			% of energy consumption	T&D loss (MU)	T&D loss (%)	Billed Amount in Rs. Crore	Collected Amount in Rs. Crore	Collection Efficiency	
														Metered energy	Unmetered/assessment energy	Total energy							
76	Total			Residential	3027014	1402	3028416	89%	4553.1761	1.768	4554.94406	59%	3869.862	1507.574	0.654721	1508.229072	48%	704.6464	18%	743.925464	572.479247	76.95%	
				Agricultural	43911	77	43988	1%	220.05709	0.23632	220.293411	3%		50.21563	0.042434	50.25805966	2%			10.6930957	8.82900036	82.57%	
				Commercial/Industrial-LT	287122	29	287151	8%	1028.1711	0.036	1028.20707	13%		373.0141	0.021789	373.0358852	12%			277.696172	249.222132	89.75%	
				Commercial/Industrial-HT	4769	0	4769	0%	958.8289	0	958.828896	12%		554.0943	0	554.0942572	18%			397.266589	353.600705	89.01%	
				Others	41680	3141	44821	1%	952.66668	16.44973	969.11641	13%		662.8496	16.749165	679.5987683	21%			471.449458	422.889008	89.70%	
77	At company level				3404496	4649	3409145	100%	7712.8998	18.49005	7731.389847	100%	3869.862	3147.748	17.468109	3165.216042	100%	704.6464	18%	1901.03078	1607.02009	84.53%	31%

**** Note - It shall be mandatory to record the energy supplied separately for each category of consumers which is being provided a separate rate of subsidy in the tariff, by the state government, so that the subsidy due for the electricity distribution company is quarterly calculated by multiplying the energy supplied to each of such category of consumers by the applicable rate of subsidy notified by the state government.**

Color code	Parameter
	Please enter name of circle
	Please enter circle code
0	Please enter numeric value or 0
	Formula protected

I/We undertake that the information supplied in this Document and Pro-forma is accurate to the best of my knowledge and if any of the information supplied is found to be incorrect and such information result into loss to the Central Government or State Government or any of the authority under them or any other person affected, I/we undertake to indemnify such loss.

Authorised Signatory and Seal

Name of Authorised Signatory:

Name of the DISCOM:

Full Address:-

Seal

Praveen Sharma
Chief RCM
TPCODL

TP Central Odisha Distribution Limited
Bhubaneswar

Signature:-

Name of Energy Manager:

Registration Number:

SHANKARSHAN PANIGRAHI
Certified Energy Manager
Regd. No : EA-27961, TPCODL

Form-Input energy(Details of Input energy & Infrastructure)

A. Summary of energy input & Infrastructure

S.No	Parameters	Period From Apr 2026 to Jun,2026	Remarks (Source of data)
A.1	Input Energy purchased (MU)	3869.86	
A.2	Transmission loss (%)	0%	
A.3	Transmission loss (MU)	0	
A.4	Energy sold outside the periphery(MU)	0.822168	
A.5	Open access sale (MU)	213.66515	
A.6	EHT sale	521	
A.7	Net input energy (received at DISCOM periphery or at distribution point)-(MU)	3869.86	
A.8	Is 100% metering available at 66/33 kV (Select yes or no from list)	Yes	
A.9	Is 100% metering available at 11 kV (Select yes or no from list)	No	
A.10	% of metering available at DT	0%	
A.11	% of metering available at consumer end	100%	
A.12	No of feeders at 66kV voltage level	0	
A.13	No of feeders at 33kV voltage level	295	
A.14	No of feeders at 11kV voltage level	1456	
A.15	No of LT feeders level	0	
A.16	Line length (ckt. km) at 66kV voltage level	0	
A.17	Line length (ckt. km) at 33kV voltage level	4563	
A.18	Line length (ckt. km) at 11kV voltage level	30498	
A.19	Line length (km) at LT level	41891	
A.20	Length of Aerial Bunched Cables	39042	
A.21	Length of Underground Cables	1357	
A.22	HT/LT ratio	0.836957819	

B. Meter reading of Input energy at injection points

S.No	Zone	Circle	Voltge Level (KVA)	Division (KVA)	Sub-Division (KVA)	Feeder ID	Feeder Name	Feeder Metering Status (Metered/ unmetered/ AMI/AMR)	Status of Meter (Functional/Non-functional)	Metering Date	Feeder Type (Agri/ Industrial/Mixed)	Status of Communication			Period from...to...				Sales	Remarks (Source of data)	
										Date of last actual meter reading/ communication		% data received through automatically if	Number of hours when meter was unable to	Total Number of hours in the period	Meter S.No	CT/PT ratio	Import (MU)	Export (MU)			
B.1	APEX	ESWAR/MANCHE	33 kV			17001AP01	TRF1	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	OPT03681	1	50.080442				
B.2	APEX	ESWAR/MANCHE	33 kV			17001AP02	TRF2	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	OPT03682	1	50.219933				
B.3	APEX	ESWAR/MANCHE	33 kV			17001AP03	TRF3	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	OPT03683	1	50.290156				
B.4	STATION	ESWAR/MANCHE	0.4 kV			17001STN01	STATION	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	AC3202502	1		0.024029			
B.5	STATION	ESWAR/MANCHE	0.4 kV			17001STN02	STATION	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	AC3202126	2		0.02818			
B.6	APEX	CHANDAKA	33 kV			17002AP01	TRF1	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	OPT03584	1	53.744431				
B.7	APEX	CHANDAKA	33 kV			17002AP02	TRF2	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	OPT03585	1	54.185357				
B.8	APEX	CHANDAKA	33 kV			17002AP03	TRF3	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	OPT02465	1	53.812295				
B.9	STATION	CHANDAKA	0.4 kV			17002STN01	STATION	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	AC3202260	2		0.060782			
B.10	STATION	CHANDAKA	0.4 kV			17002STN02	STATION	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	AC320075	4		0.041148			
B.11	STATION	CHANDAKA	0.4 kV			17002STN04	STATION	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	AC3109982	4		0.12845			
B.12	APEX	RANASINGHPUR	33 kV			17003AP01	TRF1	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	OPT03689	1	49.669086				
B.13	APEX	RANASINGHPUR	33 kV			17003AP02	TRF2	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	OPT03690	1	49.691737				
B.14	APEX	RANASINGHPUR	33 kV			17003AP03	TRF3	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	OPT02407	1	49.581956				
B.15	STATION	RANASINGHPUR	0.4 kV			17003STN01	STATION	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	AC3203028	1		0.034721			
B.16	APEX	ADAGADA/KESUF	33 kV			17004AP01	TRF1	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	OPT03685	1	45.653691				
B.17	APEX	ADAGADA/KESUF	33 kV			17004AP02	TRF2	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	OPT03687	1	44.509378				
B.18	STATION	ADAGADA/KESUF	0.4 kV			17004STN01	STATION	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	AC3202286	1		0.039441			
B.19	APEX	IMAPADA / DIGHA	33 kV			17005AP01	TRF1	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	OPT03646	1	24.424271				
B.20	APEX	IMAPADA / DIGHA	33 kV			17005AP02	TRF2	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	OPT02277	1	26.231738				
B.21	APEX	IMAPADA / DIGHA	33 kV			17005AP03	TRF3	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	OPT02279	1	22.821055				
B.22	STATION	IMAPADA / DIGHA	0.4 kV			17005STN01	STATION	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	AC3202422	2		0.02258			
B.23	APEX	KONARK	33 kV			17006AP01	TRF1	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	OPT03673	1	15.189246				
B.24	APEX	KONARK	33 kV			17006AP02	TRF2	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	OPT03675	1	15.230964				
B.25	STATION	KONARK	0.4 kV			17006STN01	STATION	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	AC3112228	3		0.037632			
B.26	APEX	KHURDA	132 kV			17007701	KAIPADARTRACTIO	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	OPT03615	1	24.267741				
B.27	APEX	KHURDA	33 kV			17007AP02	TRF2	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	OPT03608	1	15.930381				
B.28	APEX	KHURDA	33 kV			17007AP02	TRF2	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	OPT03609	1	31.683519				
B.29	APEX	KHURDA	33 kV			17007AP03	TRF3	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	OPT02186	1	46.933053				
B.30	APEX	KHURDA	33 kV			17007AP04	TRF4	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	OPT03611	1	48.63821				
B.31	STATION	KHURDA	0.4 kV			17007STN01	STATION	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	AC3200810	1		0.052966			
B.32	STATION	KHURDA	0.4 kV			17007STN02	STATION	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	AC3203583	1		0.003324			
B.33	APEX	MEDHASALA	33 kV			17008AP01	TRF1	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	OPT03573	1	10.776222				
B.34	APEX	MEDHASALA	33 kV			17008AP02	TRF2	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	OPT03575	1	6.706438				
B.35	STATION	MEDHASALA	0.4 kV			17008STN02	STATION	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	AC3105512	8		0.073856			
B.36	STATION	MEDHASALA	0.4 kV			17008STN03	STATION	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	AC3106483	8		0.065472			
B.37	STATION	MEDHASALA	0.4 kV			17008STN04	STATION	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	AC3131683	8		0.043112			
B.38	APEX	ARGUL	33 kV			17009AP01	TRF1	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	OPT03617	1	25.382552				
B.39	APEX	ARGUL	33 kV			17009AP02	TRF2	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	OPT03619	1	25.172238				
B.40	STATION	ARGUL	0.4 kV			17009STN01	STATION	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	AC3202962	1		0.023397			
B.41	APEX	BANKI	33 kV			17010AP01	TRF1	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	OPT03644	1	10.00997				
B.42	APEX	BANKI	33 kV			17010AP02	TRF2	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	OPT03647	1	10.006243				
B.43	STATION	BANKI	0.4 kV			17010STN01	STATION	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	AC3202804	1		0.026842			
B.44	APEX	NAYAGARH	220 kV			17011801	NAYAGARH RTSS 22	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	OPT02545	1	0.785792				
B.45	APEX	NAYAGARH	33 kV			17011AP01	TRF1	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	OPT03691	1	35.718465				
B.46	APEX	NAYAGARH	33 kV			17011AP02	TRF2	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	OPT03692	1	35.673768				
B.47	APEX	NAYAGARH	33 kV			17011AP03	TRF3	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	OPT04632	1	35.148827				
B.48	STATION	NAYAGARH	0.4 kV			17011STN01	STATION	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	AC3200105	1		0.04351			
B.49	APEX	PURI	33 kV			17012AP01	TRF1	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	OPT03649	1	23.127301				
B.50	APEX	PURI	33 kV			17012AP02	TRF2	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	OPT03650	1	22.90974				
B.51	APEX	PURI	33 kV			17012AP03	TRF3	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	OPT02127	1	22.896575				
B.52	STATION	PURI	0.4 kV			17012STN02	STATION	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	AC3110059	2		0.055298			
B.53	APEX	SHAMUKA	33 kV			17013AP01	TRF1	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	OPT03669	1	18.133009				
B.54	APEX	SHAMUKA	33 kV			17013AP02	TRF2	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	OPT03671	1	21.171785				
B.55	APEX	SHAMUKA	33 kV			17013AP03	TRF3	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	OPT02554	1	33.498818				
B.56	STATION	SHAMUKA	0.4 kV			17013STN01	STATION	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	AC3112875	2		0.035666			
B.57	STATION	SHAMUKA	0.4 kV			17013STN02	STATION	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	A13107076	2		0.002824			
B.58	APEX	SAMAGARA	132 kV			17014701	MALATIPATAPUR(R	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	OPT02229	1	1.753017				
B.59	APEX	SAMAGARA	132 kV			17014701	MALATIPATAPUR(R	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	OPT04637	1	3.53859				
B.60	APEX	SAMAGARA	33 kV			17014AP01	TRF1	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	OPT03677	1	13.539931				
B.61	APEX	SAMAGARA	33 kV			17014AP02	TRF2	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	OPT03679	1	13.634675				
B.62	STATION	SAMAGARA	0.4 kV			17014STN01	STATION	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	AC3109455	2		0.019068			
B.63	STATION	SAMAGARA	0.4 kV			17014STN02	STATION	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	AC3109458	2		0.0364			
B.64	APEX	BALUGAON	132 kV			17015701	SOLARI TRACTION	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	OPT00769	1	9.33432				
B.65	APEX	BALUGAON	33 kV			17015407	KESHPUR FDR	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	OPT02396	1		13.628927			

B.66	APEX	BALUGAON	33 kV			17015409	KHALIKOTE FDR	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	OPT00747	1		12.637173			
B.67	APEX	BALUGAON	33 kV			17015AP01	TRF1	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	OPT00611	1	30.98877				
B.68	APEX	BALUGAON	33 kV			17015AP02	TRF2	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	APM12642	1	20.841508				
B.69	APEX	BALUGAON	33 kV			17015AP03	TRF3	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	OPT02159	1	12.213999				
B.70	STATION	BALUGAON	0.4 kV			17015STN01	STATION	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	AC3202254	1		0.026949			
B.71	APEX	CHANDPUR	11 kV			17016201	MGM SOLAR	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	ORBP8178	1	0.327869				
B.72	APEX	CHANDPUR	11 kV			17016202	VIVACITY/PAN TIME	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	OPT03695	1	0.361808				
B.73	APEX	CHANDPUR	33 kV			17016401	MGM SOLAR 33KV, 5	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	ORA00427	1	2.217818				
B.74	APEX	CHANDPUR	33 kV			17016AP01	TRF1	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	OPT02515	1	0.006967				
B.75	APEX	CHANDPUR	33 kV			17016AP02	TRF2	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	OPT02517	1	28.261481				
B.76	APEX	CHANDPUR	33 kV			17016AP03	TRF3	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	OPT03693	1	17.78284				
B.77	STATION	CHANDPUR	0.4 kV			17016STN01	STATION	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	AC3103972	4		0.020228			
B.78	STATION	CHANDPUR	0.4 kV			17016STN01	STATION	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	AC3112182	4		0.000012			
B.79	APEX	CHANDIKHOLE	132 kV			17017AP03	MTPCL(IPP) CKT-1 1	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	ORA00222	1	0.007414				
B.80	APEX	CHANDIKHOLE	132 kV			17017AP04	MTPCL(IPP) CKT-2 1	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	ORA00220	1	0.062514				
B.81	APEX	CHANDIKHOLE	33 kV			17017AP01	BADCHANA FDR	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	OPT02063	1	23.581899				
B.82	APEX	CHANDIKHOLE	33 kV			17017AP02	KUNDALA FEEDER	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	Q0266923	1	4.47647				
B.83	APEX	CHOUDWAR	132 kV			17018701	CHOUDWAR RTSS F	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	OPT01177	1	14.48747				
B.84	APEX	CHOUDWAR	132 kV			17018701	CHOUDWAR RTSS F	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	OPT02230	1	7.214008				
B.85	APEX	CHOUDWAR	132 kV			17018702	ULTRA TECH FEEDE	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	OPT02445	1	13.904711				
B.86	APEX	CHOUDWAR	132 kV			17018702	ULTRA TECH FEEDE	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	ORA00130	1	16.61849				
B.87	APEX	CHOUDWAR	33 kV			17018AP02	TRF2	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	OPT02266	1	21.694761				
B.88	APEX	CHOUDWAR	33 kV			17018AP03	TRF3	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	OPT01126	1	14.77153				
B.89	APEX	CHOUDWAR	33 kV			17018AP03	TRF3	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	OPT02231	1	7.042411				
B.90	APEX	CHOUDWAR	33 kV			17018AP04	TRF4	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	OPT01053	1	22.51373				
B.91	STATION	CHOUDWAR	0.4 kV			17018STN01	STATION	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	621206	20		-0.010512			
B.92	STATION	CHOUDWAR	0.4 kV			17018STN02	STATION	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	AC3115160	2		0.03393			
B.93	APEX	BIDANASI	33 kV			17019AP01	TRF1	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	OPT02399	1	45.979415				
B.94	APEX	BIDANASI	33 kV			17019AP02	TRF2	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	OPT02697	1	46.489852				
B.95	APEX	BIDANASI	33 kV			17019AP03	TRF3	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	OPT02398	1	28.543802				
B.96	STATION	BIDANASI	0.4 kV			17019STN01	STATION	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	AC3202409	1		0.025884			
B.97	STATION	BIDANASI	0.4 kV			17019STN02	STATION	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	AC3202410	1		0.04756			
B.98	APEX	CUTTACK	33 kV			17020AP01	TRF1	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	OPT02138	1	39.270353				
B.99	APEX	CUTTACK	33 kV			17020AP02	TRF2	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	OPT02934	1	63.774397				
B.100	APEX	CUTTACK	33 kV			17020AP03	TRF3	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	OPT02935	1	39.889305				
B.101	STATION	CUTTACK	0.4 kV			17020STN01	STATION	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	AC3115246	4		0.037252			
B.102	STATION	CUTTACK	0.4 kV			17020STN02	STATION	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	AC3115245	4		0.016236			
B.103	APEX	SALIPUR	132 kV			17021701	OCL FDR	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	OPT02171	1	7.405054				
B.104	APEX	SALIPUR	132 kV			17021701	OCL FDR	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	OPT02372	1	4.173668				
B.105	APEX	SALIPUR	33 kV			17021AP01	TRF1	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	OPT02297	1	17.561046				
B.106	APEX	SALIPUR	33 kV			17021AP02	TRF2	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	OPT02937	1	20.090415				
B.107	APEX	SALIPUR	33 kV			17021AP03	TRF3	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	OPT02298	1	13.254098				
B.108	STATION	SALIPUR	0.4 kV			17021STN02	STATION	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	AC3105866_	2		0.03478			
B.109	APEX	PHULNAKAHARA	33 kV			17022AP01	TRF1	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	OPT02693	1	29.893249				
B.110	APEX	PHULNAKAHARA	33 kV			17022AP02	TRF2	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	OPT02694	1	18.600592				
B.111	APEX	PHULNAKAHARA	33 kV			17022AP03	TRF3	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	OPT02695	1	29.759504				
B.112	STATION	PHULNAKAHARA	0.4 kV			17022STN01	STATION	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	AC3115269	2		0.037212			
B.113	APEX	NUAPATANA	33 kV			17023AP01	TRF1	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	OPT03734	1	13.407897				
B.114	APEX	NUAPATANA	33 kV			17023AP02	TRF2	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	OPT04007	1	20.222306				
B.115	APEX	NUAPATANA	33 kV			17023AP03	TRF3	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	OPT04059	1	6.57568				
B.116	STATION	NUAPATANA	0.4 kV			17023STN01	STATION	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	AC3202233	1		0.022117			
B.117	APEX	DHENKANAL	132 kV			17024701	JORONDA TRACTIO	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	OPT02240	1	0.000198				
B.118	APEX	DHENKANAL	132 kV			17024701	JORONDA TRACTIO	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	OPT02241	1	0.002841				
B.119	APEX	DHENKANAL	33 kV			17024407	NARVERAM / SCAW	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	OPT02239	1	0.868121				
B.120	APEX	DHENKANAL	33 kV			17024AP01	TRF1	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	OPT02237	1	29.20144				
B.121	APEX	DHENKANAL	33 kV			17024AP02	TRF2	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	OPT02235	1	29.103619				
B.122	APEX	DHENKANAL	33 kV			17024AP03	TRF3	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	OPT02977	1	29.141313				
B.123	STATION	DHENKANAL	0.4 kV			17024STN02	STATION	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	AC3200130	1		0.050025			
B.124	APEX	CAMAKHYANAGAF	132 kV			17025701	TRACTION FEEDER	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	OPT02985	1	4.41186				
B.125	APEX	CAMAKHYANAGAF	33 kV			17025AP01	TRF1	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	OPT02979	1	17.223827				
B.126	APEX	CAMAKHYANAGAF	33 kV			17025AP02	TRF2	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	OPT02981	1	10.994357				
B.127	APEX	CAMAKHYANAGAF	33 kV			17025AP03	TRF3	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	OPT02983	1	11.092528				
B.128	STATION	CAMAKHYANAGAF	0.4 kV			17025STN01	STATION	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	AC310663	1		0.029027			
B.129	APEX	KALARANGI	33 kV			17026AP01	TRF1	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	OPT03005	1	3.326292				
B.130	APEX	KALARANGI	33 kV			17026AP02	TRF2	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	OPT03006	1	4.525804				
B.131	APEX	KALARANGI	33 kV			17026AP03	TRF3	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	OPT04650	1	4.858604				
B.132	STATION	KALARANGI	0.4 kV			17026STN01	STATION	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	AC3115522	2		0.028156			
B.133	APEX	CHAINPAL	132 kV			17027701	FCI FDR-1	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	OPT02388	1	1.225152				
B.134	APEX	CHAINPAL	132 kV			17027702	TRACTION	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	OPT01213	1	8.581226				
B.135	APEX	CHAINPAL	132 kV			17027702	TRACTION	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	OPT02832	1	17.330394				
B.136	APEX	CHAINPAL	33 kV			17027AP01	TRF1	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	OPT03065	1	36.367881				
B.137	APEX	CHAINPAL	33 kV			17027AP02	TRF2	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	OPT03067	1	35.265985				
B.138	APEX	CHAINPAL	33 kV			17027AP03	TRF3	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	OPT03069	1	34.58823				
B.139	STATION	CHAINPAL	0.4 kV			17027STN01	STATION	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	AC3202699	1		0.01512			
B.140	STATION	CHAINPAL	0.4 kV			17027STN02	STATION	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	AC3201998	1		0.031093			
B.141	APEX	RENGALI	0.4 kV			17028STN02	PGCIL STN. TERTIAI	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	ER1020-A	1	0.005455				
B.142	APEX	RENGALI	33 kV			17028409	BUDHAPAL	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	OPT04009	1		3.450323			
B.143	APEX	RENGALI	33 kV			17028AP01	TRF1	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	OPT03882	1	13.608684				
B.144	APEX	RENGALI	33 kV			17028AP02	TRF2	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	OPT03994	1	20.556441				
B.145	STATION	RENGALI	0.4 kV			17028STN01	STATION	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	AC3202867	1		0.021469			
B.146	APEX	BARKOTE	33 kV			17029401	PALLAHARA FDR	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	APM12599	1	4.833157				
B.147	APEX	ANGUL	0.4 kV			17030STN02	PGCIL STN. TERTIAI	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	NP5942-A	1	0.05244				
B.148	APEX	ANGUL	132 kV			17030701	MCL FEEDER1 132K	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	OPT00706	1	22.936677				
B.149	APEX	ANGUL	132 kV			17030701	MCL FEEDER1 132K	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	OPT02223	1	11.298548				
B.150	APEX	ANGUL	132 kV			17030702	MCL FEEDER2 132K	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	OPT01859	1	9.54319				
B.151	APEX	ANGUL	132 kV			17030702	MCL FEEDER2 132K	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	OPT02224	1	22.137603				
B.152	APEX	ANGUL	33 kV			17030AP01	TRF1	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	OPT02219	1	35.197182				
B.153	APEX	ANGUL	33 kV			17030AP02	TRF2	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	OPT02220	1	34.023194				
B.154	APEX	ANGUL	33 kV			17030AP03	TRF3	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	OPT03040	1	22.073068				
B.155	STATION	ANGUL	0.4 kV			17030STN01	STATION	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	AC3201868	1		0.029167			
B.156	APEX	BOINDA	132 kV			17031701	TRACTION FEEDER	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	OPT03868	1	7.041001				
B.157	APEX	BOINDA	33 kV			17031AP01	TRF1	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	OPT02225	1	17.058824				
B.158	APEX	BOINDA	33 kV			17031AP02	TRF2	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	OPT02227	1	10.742089				
B.159	APEX	BOINDA	33 kV			17031AP03	TRF3	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	OPT03047	1	11.348096				
B.160	STATION	BOINDA	0.4 kV			17031STN01	STATION	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	AC3114180	2		0.022756			
B.161	STATION	BOINDA	0.4 kV			17031STN02	STATION	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	AC3121677	2		0.0042			
B.162	APEX	RAIRAKHOL	33 kV			17032401	BAMUR	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	OPT03735	1	5.82784				

B.163	APEX	PATTAMUNDAI	33 kV			17033AP01	TRF1	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	OPT02949	1	6.813058					
B.164	APEX	PATTAMUNDAI	33 kV			17033AP02	TRF2	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	OPT02951	1	12.098517					
B.165	APEX	PATTAMUNDAI	33 kV			17033AP03	TRF3	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	OPT02953	1	12.243539					
B.166	STATION	PATTAMUNDAI	0.4 kV			17033STN01	STATION	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	AC3110568	4		0.020692				
B.167	APEX	KENDRAPADA	33 kV			17034AP02	TRF2	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	OPT02955	1	37.291145					
B.168	APEX	KENDRAPADA	33 kV			17034AP04	TRF4	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	OPT02957	1	38.167401					
B.169	STATION	KENDRAPADA	0.4 kV			17034STN01	STATION	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	AC3102307	4		0.040596				
B.170	APEX	MARSHAGHAI	33 kV			17035701	KPR TRACTION	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	OPT02959	1	6.393513					
B.171	APEX	MARSHAGHAI	33 kV			17035AP01	TRF1	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	OPT02961	1	18.783969					
B.172	APEX	MARSHAGHAI	33 kV			17035AP02	TRF2	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	OPT02963	1	18.809751					
B.173	STATION	MARSHAGHAI	0.4 kV			17035STN02	STATION	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	AC3111078	2		0.024086				
B.174	APEX	PARADEEP	132 kV			17036701	IFFCO FDR-1	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	OPT01942	1	13.965183					
B.175	APEX	PARADEEP	132 kV			17036702	IFFCO FDR-2	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	OPT01944	1	15.337569					
B.176	APEX	PARADEEP	132 kV			17036703	PPL FDR-1	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	OPT00895	1	15.7558					
B.177	APEX	PARADEEP	132 kV			17036704	PPL FDR-2	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	OPT01149	1	9.46476					
B.178	APEX	PARADEEP	132 kV			17036705	PPT FDR-1	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	OPT01946	1	6.56557					
B.179	APEX	PARADEEP	132 kV			17036706	PPT FDR-2	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	OPT01939	1	38.959488					
B.180	APEX	PARADEEP	132 kV			17036707	SIJU- RTSS FDR (TR	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	OPT02232	1	16.966109					
B.181	APEX	PARADEEP	220 kV			17036801	A. M. NIPPON STEEL	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	OPT02470	1	0.098326					
B.182	APEX	PARADEEP	220 kV			17036802	220KVA. M. NIPPON	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	OPT02472	1	8.742					
B.183	APEX	PARADEEP	220 kV			17036803	IOCL	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	OPT02474	1	84.714044					
B.184	APEX	PARADEEP	33 kV			17036AP01	TRF1	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	OPT02965	1	14.759613					
B.185	APEX	PARADEEP	33 kV			17036AP02	TRF2	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	OPT02967	1	15.202973					
B.186	APEX	PARADEEP	33 kV			17036AP03	TRF3	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	OPT02532	1	15.393098					
B.187	STATION	PARADEEP	0.4 kV			17036STN01	STATION	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	AC3111776	4		0.098496				
B.188	APEX	JAGATSINGHPUR	132 kV			17037701	TRACTION FEEDER	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	OPT02329	1	11.050813					
B.189	APEX	JAGATSINGHPUR	33 kV			17037AP01	TRF1	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	OPT01009	1	18.051144					
B.190	APEX	JAGATSINGHPUR	33 kV			17037AP02	TRF2	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	OPT01216	1	28.65446					
B.191	APEX	JAGATSINGHPUR	33 kV			17037AP03	TRF3	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	OPT02331	1	8.793201					
B.192	APEX	JAGATSINGHPUR	33 kV			17037AP03	TRF3	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	OPT02411	1	19.589625					
B.193	STATION	JAGATSINGHPUR	0.4 kV			17037STN01	STATION	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	AC3109170	4		0.031824				
B.194	APEX	MANIA	33 kV			17038AP01	TRF1	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	OPT02936	1	5.497201					
B.195	APEX	MANIA	33 kV			17038AP02	TRF2	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	OPT02943	1	11.993913					
B.196	APEX	MANIA	33 kV			17038AP03	TRF3	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	OPT02523	1	18.711193					
B.197	STATION	MANIA	0.4 kV			17038STN01	STATION	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	AC3115315	2		0.018804				
B.198	STATION	MANIA	0.4 kV			17038STN02	STATION	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	AC3115154	2		0.009616				
B.199	APEX	OLAVER	33 kV			17039AP01	TRF1	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	OPT02945	1	14.532994					
B.200	APEX	OLAVER	33 kV			17039AP02	TRF2	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	OPT02947	1	16.687828					
B.201	STATION	OLAVER	0.4 kV			17039STN02	STATION	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	AC3107283	2		0.023658				
B.202	APEX	KHAJURIAKATA	33 kV			17040AP01	TRF1	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	OPT02973	1	5.385741					
B.203	APEX	KHAJURIAKATA	33 kV			17040AP02	TRF2	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	OPT02975	1	5.410511					
B.204	APEX	KHAJURIAKATA	33 kV			17040AP03	ABREL SOLAR	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	OPT02438	1	8.155935					
B.205	APEX	KHAJURIAKATA	33 kV			17040AP04	SOLAR EXTRA INJE	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	TPCODL-01	1		2.508192				
B.206	STATION	KHAJURIAKATA	0.4 kV			17040STN01	STATION	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	AC3202237	1		0.027264				
B.207	APEX	INFOCITY -II GIS	33 kV			17041AP01	TRF1	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	OPT03627	1	19.499032					
B.208	APEX	INFOCITY -II GIS	33 kV			17041AP02	TRF2	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	OPT03625	1	19.208896					
B.209	STATION	INFOCITY -II GIS	0.4 kV			17041STN01	STATION	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	AC3115611	2		0.038234				
B.210	STATION	INFOCITY -II GIS	0.4 kV			17041STN02	STATION	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	AC3115614	4		0.018272				
B.211	APEX	PANDIABIL PG	33 kV			17042AP01	PGCIL STN. TERTIAI	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	NP7462-A	1	0.112671					
B.212	APEX	UNIT-8 GIS	33 kV			17043AP01	TRF1	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	OPT02074	1	31.555361					
B.213	APEX	UNIT-8 GIS	33 kV			17043AP02	TRF2	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	OPT03623	1	31.065442					
B.214	STATION	UNIT-8 GIS	0.4 kV			17043STN01	STATION	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	RCUD4563	1		0.029662				
B.215	APEX	KHUNTUNI GIS	132 kV			17044701	SREE CEMENT	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	ORU47775	1	2.361228					
B.216	APEX	KHUNTUNI GIS	33 kV			17044AP01	TRF1	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	OPT03939	1	19.234456					
B.217	APEX	KHUNTUNI GIS	33 kV			17044AP02	TRF2	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	OPT03986	1	18.415488					
B.218	STATION	KHUNTUNI GIS	0.4 kV			17044STN02	STATION	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	AC320223	1		0.033161				
B.219	APEX	NARASINGHPUR	33 kV			17045AP01	TRF1	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	OPT04005	1	11.978511					
B.220	APEX	NARASINGHPUR	33 kV			17045AP02	TRF2	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	OPT04054	1	12.076173					
B.221	STATION	NARASINGHPUR	0.4 kV			17045STN01	STATION	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	AC3201961	1		0.029822				
B.222	STATION	NARASINGHPUR	0.4 kV			17045STN02	STATION	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	AC3115400	2		0.006536				
B.223	APEX	TIRTOL/BODHEI	33 kV			17046AP01	TRF1	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	OPT02969	1	22.122847					
B.224	APEX	TIRTOL/BODHEI	33 kV			17046AP02	TRF2	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	OPT02971	1	22.411467					
B.225	STATION	TIRTOL/BODHEI	0.4 kV			17046STN01	STATION	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	AC3202659	1		0.031213				
B.226	STATION	TIRTOL/BODHEI	0.4 kV			17046STN02	STATION	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	AC3202660	1		0.003698				
B.227	APEX	ANCHESWAR-B G	33 kV			17047AP01	TRF1	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	OPT03629	1	28.668234					
B.228	APEX	ANCHESWAR-B G	33 kV			17047AP02	TRF2	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	OPT03631	1	29.28273					
B.229	STATION	ANCHESWAR-B G	0.4 kV			17047STN01	STATION	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	AC3202354	2		0.036488				
B.230	APEX	MERAMUNDALI	132 kV			17048701	RUNGTA FEEDER 13	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	OPT01391	1	10.964948					
B.231	APEX	MERAMUNDALI	132 kV			17048701	RUNGTA FEEDER 13	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	OPT04128	1	29.422893					
B.232	APEX	MERAMUNDALI	132 kV			17048702	RUNGTA MINES 132	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	ORA00017	1	4.956899					
B.233	APEX	MERAMUNDALI	132 kV			17048703	BRG FDR / RIMJHIM	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	OPT04643	1	35.644065					
B.234	APEX	MERAMUNDALI	220 kV			17048801	TATA POWER BSL-1	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	OPT00331	1	1.832236					
B.235	APEX	MERAMUNDALI	220 kV			17048801	TATA POWER BSL-1	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	OPT02759	1	2.042759					
B.236	APEX	MERAMUNDALI	220 kV			17048802	TATA POWER BSL-2	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	OPT02799	1	3.715265					
B.237	APEX	MERAMUNDALI	400 kV			17048902	JSPL FDR-1	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	OPT02103	1	25.722393					
B.238	APEX	MERAMUNDALI	400 kV			17048903	JSPL FDR-2	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	OPT02105	1	26.158291					
B.239	APEX	ARATI STEEL	132 kV			17049701	ARATI STEEL 132KV	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	OPT01127	1	0.43999					
B.240	APEX	ARATI STEEL	132 kV			17049701	ARATI STEEL 132KV	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	OPT03011	1	0.248444					
B.241	APEX	BARANGA	11 kV			17050201	S N MOHANTY SOLA	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	Y0359639	1	0.183482					
B.242	APEX	BARANGA	11 kV			17050201	S N MOHANTY SOLA	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	Y0359640	1	0.110767					
B.243	APEX	BPPL S/W	132 kV			17051701	TS ALLOY/BHUBANE	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	ORA00357	1	0.000107					
B.244	APEX	BPPL S/W	132 kV			17051702	BIDANASI	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	ORA00356	1	0.0001					
B.245	APEX	BRAJABIHARIPUR	33 kV			17052AP01	TRF1	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	OPT02087	1	28.37039					
B.246	APEX	BRAJABIHARIPUR	33 kV			17052AP02	TRF2	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	OPT02089	1	28.063453					
B.247	STATION	BRAJABIHARIPUR	0.4 kV			17052STN01	STATION	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	AC3202444	1		0.023482				
B.248	STATION	BRAJABIHARIPUR	0.4 kV			17052STN02	STATION	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	AC3115215	2		0.007688				
B.249	APEX	GLOBAL	132 kV			17054701	HEAVY WATER FEE	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	OPT01451	1	0.70623					
B.250	APEX	GLOBAL	132 kV			17054701	HEAVY WATER FEE	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	OPT01452	1	0.228581					
B.251	APEX	GLOBAL	33 kV			17054AP01	TRF1	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	OPT02056	1	2.161819					
B.252	APEX	TALLICS/ KHARAG	132 kV			17056701	MGM FEEDER 132K	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	OPT02996	1	0.187299					
B.253	APEX	TALLICS/ KHARAG	132 kV			17056702	NAVABHARAT FDR1	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	OPT02180	1	0.000001					
B.254	APEX	TALLICS/ KHARAG	132 kV			17056703	NAVABHARAT FDR2	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	OPT02210	1	0.000021					
B.255	APEX	TALLICS/ KHARAG	132 kV			17056704	JAGANATH POWER	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	OPT02992	1	0.158236					
B.256	APEX	TALLICS/ KHARAG	132 kV			17056705	M. MUNDALI TRACTI	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	OPT04633	1	24.114701					
B.257	APEX	TALLICS/ KHARAG	33 kV			17056AP01	TRF2	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	OPT02511	1	8.010701					
B.258	APEX	TALLICS/ KHARAG	33 kV			17056AP02	TRF1	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	OPT02994	1	7.877338					
B.259	STATION	TALLICS/ KHARAG	0.4 kV			17056STN01	STATION	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	3202827	1		0.01812				

B.260	APEX	RATAPSASAN GI	33 kV			17057AP01	TRF1	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	OPT02314	1	34.21327				
B.261	APEX	RATAPSASAN GI	33 kV			17057AP02	TRF2	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	OPT02121	1	34.760956				
B.262	STATION	RATAPSASAN GI	0.4 kV			17057STN01	STATION	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	AC3105968	4		0.02688			
B.263	STATION	RATAPSASAN GI	0.4 kV			17057STN02	STATION	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	AC3103631	4		0.04876			
B.264	APEX	A STEEL MINING	132 kV			17058701	RAWMET FDR	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	OPT02939	1	38.455724				
B.265	APEX	TTPS	132 kV			17059701	TTPS TFR ST 2A 20 I	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	OPT03509	1	0.819481				
B.266	APEX	TTPS	132 kV			17059702	TTPS TFR ST 2B 20 I	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	OPT02287	1	0.316883				
B.267	APEX	TTPS	132 kV			17059702	TTPS TFR ST 2B 20 I	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	OPT02288	1	0.240725				
B.268	APEX	TTPS	132 kV			17059702	TTPS TFR ST 2B 20 I	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	OPT02316	1	0.229098				
B.269	APEX	TTPS	33 kV			17059AP01	TTPS TFR ST 12. 20	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	OPT02245	1	0.649168				
B.270	APEX	TTPS	33 kV			17059AP02	TTPS TFR ST 34. 20	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	OPT02284	1	1.203273				
B.271	APEX	CHANDAKA-B GIS	33 kV			17060AP01	TRF1	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	OPT03577	1	21.723688				
B.272	APEX	CHANDAKA-B GIS	33 kV			17060AP02	TRF2	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	OPT03579	1	22.024768				
B.273	STATION	CHANDAKA-B GIS	0.4 kV			17060STN01	STATION	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	AC3117313	1		0.046152			
B.274	STATION	CHANDAKA-B GIS	0.4 kV			17060STN02	STATION	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	AC3117314	1		0.016012			
B.275	APEX	RAJNAGAR	33 kV			17061AP01	TRF1	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	OPT02243	1	11.093429				
B.276	APEX	RAJNAGAR	33 kV			17061AP02	TRF2	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	OPT02124	1	11.917205				
B.277	STATION	RAJNAGAR	0.4 kV			17061STN01	STATION	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	AC3111076	2		0.03105			
B.278	STATION	RAJNAGAR	0.4 kV			17061STN02	STATION	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	AC3110565	2		0.000976			
B.279	APEX	GODA	33 kV			17062AP01	TRF1	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	OPT01971	1	10.304738				
B.280	APEX	GODA	33 kV			17062AP02	TRF2	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	OPT02136	1	6.269529				
B.281	STATION	GODA	0.4 kV			17062STN01	STATION	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	AC3201763	1		0.039549			
B.282	STATION	GODA	0.4 kV			17062STN02	STATION	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	AC3202242	1		0.021044			
B.283	STATION	ICCL	0.4 kV			17063STN01	STATION	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	CESO0678	40		0.01068			
B.284	APEX	GODISAHI GIS	33 kV			17064AP01	TRF1	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	OPT02344	1	14.867521				
B.285	APEX	GODISAHI GIS	33 kV			17064AP02	TRF2	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	OPT02342	1	14.933383				
B.286	STATION	GODISAHI GIS	0.4 kV			17064STN01	STATION	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	AC3107383	4		0.044776			
B.287	STATION	GODISAHI GIS	0.4 kV			17064STN02	STATION	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	AC3200288	2		0.002492			
B.288	APEX	SATASANKHA	33 kV			17065AP01	TRF2	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	OPT01973	1	22.27406				
B.289	APEX	SATASANKHA	33 kV			17065AP02	TRF1	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	OPT02495	1	22.802685				
B.290	STATION	SATASANKHA	0.4 kV			17065STN01	STATION	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	AC3106308	4		0.026688			
B.291	STATION	SATASANKHA	0.4 kV			17065STN02	STATION	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	AC3106307	4		0.013772			
B.292	APEX	KANTABADA GIS	33 kV			17066AP01	TRF1	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	OPT02401	1	13.802045				
B.293	APEX	KANTABADA GIS	33 kV			17066AP02	TRF2	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	OPT02403	1	13.79471				
B.294	STATION	KANTABADA GIS	0.4 kV			17066STN01	STATION	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	AC3107736	4		0.031212			
B.295	STATION	KANTABADA GIS	0.4 kV			17066STN02	STATION	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	AC3107735	4		0.006988			
B.296	APEX	ATRI	33 kV			17067AP01	TRF1	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	OPT03604	1	26.636413				
B.297	APEX	ATRI	33 kV			17067AP02	TRF2	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	OPT03606	1	16.93523				
B.298	STATION	ATRI	0.4 kV			17067STN01	STATION	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	AC3108690	1		0.04258			
B.299	STATION	ATRI	0.4 kV			17067STN02	STATION	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	AC3108723	1		0.023168			
B.300	APEX	ARNAPUR/GONDU	33 kV			17068AP01	TRF1	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	OPT01975	1	3.476043				
B.301	APEX	ARNAPUR/GONDU	33 kV			17068AP01	TRF1	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	OPT02205	1	7.38397				
B.302	APEX	ARNAPUR/GONDU	33 kV			17068AP02	TRF2	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	OPT02021	1	2.329755				
B.303	APEX	ARNAPUR/GONDU	33 kV			17068AP02	TRF2	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	OPT02207	1	4.352211				
B.304	STATION	ARNAPUR/GONDU	0.4 kV			17068STN01	STATION	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	AC3202605	1		0.02291			
B.305	STATION	ARNAPUR/GONDU	0.4 kV			17068STN02	STATION	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	AC3202606	1		0.012988			
B.306	APEX	BEEKAY STEEL	11KV			17069701	BEEKAY STEEL SW.	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	ORA00256	1	6.277749				
B.307	APEX	ATODA	33 kV			17070AP01	TRF1	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	OPT01989	1	7.333797				
B.308	APEX	ATODA	33 kV			17070AP01	TRF1	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	OPT02325	1	11.173211				
B.309	APEX	ATODA	33 kV			17070AP02	TRF2	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	OPT02327	1	11.180416				
B.310	APEX	ATODA	33 kV			17070AP02	TRF2	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	OPT02328	1	6.272338				
B.311	STATION	ATODA	0.4 kV			17070STN01	STATION	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	AC3109409	4		0.028452			
B.312	STATION	ATODA	0.4 kV			17070STN02	STATION	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	AC3124579	4		0.002356			
B.313	APEX	NAYAPALLI GIS	33 kV			17071AP01	TRF1	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	OPT02502	1	39.863939				
B.314	APEX	NAYAPALLI GIS	33 kV			17071AP02	TRF2	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	OPT02504	1	39.894144				
B.315	STATION	NAYAPALLI GIS	0.4 kV			17071STN01	STATION	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	AC3202209	2		0.03093			
B.316	STATION	NAYAPALLI GIS	0.4 kV			17071STN02	STATION	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	AC3202210	2		0.010682			
B.317	APEX	PALEI	33 kV			17072AP01	TRF1	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	OPT02466	1	6.707175				
B.318	APEX	PALEI	33 kV			17072AP02	TRF2	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	OPT02468	1	10.86392				
B.319	STATION	PALEI	0.4 kV			17072STN01	STATION	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	AC3118410	4		0.0122			
B.320	STATION	PALEI	0.4 kV			17072STN02	STATION	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	AC3123900	4		0.014528			
B.321	APEX	BALIANTA GIS	33 kV			17075AP01	TRF1	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	OPT02594	1	4.210253				
B.322	APEX	BALIANTA GIS	33 kV			17075AP02	TRF2	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	OPT02596	1	17.47464				
B.323	APEX	SCBMCH GIS	33 kV			17076AP01	TRF1	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	OPT02820	1	0.776779				
B.324	APEX	SCBMCH GIS	33 kV			17076AP02	TRF2	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	OPT02826	1	0.774945				
B.325	STATION	SCBMCH GIS	0.4 kV			17076STN01	STATION	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	AC3204012	1		0.02804			
B.326	APEX	SATYANAGAR GIS	33 kV			17077AP01	TRF1	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	OPT02590	1	1.218933				
B.327	APEX	SATYANAGAR GIS	33 kV			17077AP02	TRF2	METERED	FUNCTIONAL	01-07-2026	MIXED	NA	NA	NA	OPT02592	1	2.351239				
B.328	OTHER					ADJ	ADJUSTMENT														
B.329	OTHER					OA-ARATI1	OPEN ACCESS-ARATI STEEL, GHANTIKHAL										0.290017	0.688434			
B.330	OTHER					OA-JSPL1	OPEN ACCESS-JSPL, ANGUL FROM GMR KAMALANGA										11.530853	51.880684			
B.331	OTHER					OA-IOCLPDP1	OPEN ACCESS-IOCL PARADEEP										69.784203	84.714044			
B.332	OTHER					OA-OCL1	OPEN ACCESS-OCL TANGI										8.145	11.578722			
B.333	OTHER					OA-S CEMENT1	OPEN ACCESS-SHREE CEMENT										1.396076	2.361228			
B.334	OTHER					OA-RUNGTA2	OPEN ACCESS-RUNGTA MINES FERRO ALLOY DIVISION										15.091225	40.387841			
B.335	OTHER					OA-RUNGTA1	OPEN ACCESS-RUNGTA MINES/ RUNGTA DSP										4.083968	4.906291			
B.336	OTHER					OA-BRG1	OPEN ACCESS-BRG										20.910603	35.644065			
B.337	OTHER					OA-TPBSL1	OPEN ACCESS-TATA POWER BSL-1 / TATA POWER BSL-2										3.82549	5.059048			
B.338	OTHER					OA-U TECH1	OPEN ACCESS-ULTRA TECH FEEDER 132 KV										13.72245	16.61849			
B.339	OTHER					OA-MCL1	OPEN ACCESS- MCL FEEDER-1 132KV & MCL FEEDER-2 132KV										49.592988	65.916018			
B.340	OTHER					OA-IFFCO	OPEN ACCESS- IFFCO -1 & IFFCO-2 FEEDER										18.316528	29.302752			
B.341	OTHER					OA-BEEKAY1	OPEN ACCESS- BEEKAY STEEL										1.98198	4.009287			
B.342	OTHER					OA-ORIC1	OPEN ACCESS- ORICLEAN										-0.17814	0			
B.343	OTHER					OA-ORIF1	OPEN ACCESS- ORIFOOD										-0.179737	0			
B.344	OTHER					OA-AIRTEL1	OPEN ACCESS-BHARATI AIRTEL										-1.414712	0			
B.345	OTHER					OA-HCOCA1	OPEN ACCESS- HINDUSTAN COCA-COLA BEVERAGES										-3.233642	0			
B.346	OTHER					EXPSOLAR1	EXPORT TO SOLAR FOR OWN CONSUMPTION											0.006972			
B.347	OTHER					EXPDISCOM1	EXPORT TO OTHER DISCOMS											0.879862			
B.348	OTHER					IMPORTDISCOM1	IMPORT FROM OTHER DISCOMS										0.05769408				
B.349																					
B.350																					
B.351																					
B.352																					
B.353																					
B.354																					
B.355																					
B.356																					

B.13395																					
B.13396																					
B.13397																					
B.13398																					
B.13399																					
B.13400																					
B.13401	Total (MU)																4258.63	388.77			
B.13402	Net input energy at DISCOM periphery (MU)																3869.86				

Color code			Parameter
			Please enter voltage level or leave blank
			Please enter feeder id and name or leave blank
			Enter meter no or leave blank
			Enter CT/PT ratio or leave blank
0			Please enter numeric value or 0
			Please select yes or no from list
			Formula protected

I/We undertake that the information supplied in this Document and Pro-forma is accurate to the best of my knowledge and if any of the information supplied is found to be incorrect and such information result into loss to the Central Government or State Government or any of the authority under them or any other person affected, I/we undertake to indemnify such loss.

Authorised Signatory and Seal

Name of Authorised Signatory
Name of the DISCOM:
Full Address:-

Praveen Sharma
Chief RCM
TPCODL

Seal

TP Central Odisha Distribution Limited
Bhubaneswar

Signature:-
Name of Energy Manager*:
Registration Number:

SHANKARSHAN PANIGRAHI
Certified Energy Manager
Regd. No : EA-27961, TPCODL

(Details of Consumers)						
Summary of Energy						
Period From 1st April 2026 to 30th June 2026						
S.No	Type of Consumers	Category of Consumers (EHT/HT/LT/Others)	Voltage Level (In Voltage)	No of Consumers	Total Consumption (In MU)	Remarks (Source of data)
1	Bulk Supply - Domestic	HT	33.000	26	13.095332	
2	Bulk Supply - Domestic	HT	11.000	745	14.403257	
3	Bulk Supply - Domestic	HT	0.400	43	0.178524	
4	Bulk Supply - Domestic	HT	0.230	2	0.011488	
5	Kutir Jyoti <= 30 Units/month	LT	0.230	19222	0.192637	
6	Domestic Others	LT	11.000	3	0.001440	
7	Domestic Others	LT	0.400	64833	119.086055	
8	Domestic Others	LT	0.230	2943542	1361.260339	
9	Emergency Supply to CGP (kWh)	EHT	220.000	1	0.000000	
10	Emergency Supply to CGP (kWh)	EHT	132.000	7	0.706375	
11	General Purpose	EHT	220.000	1	1.602092	
12	General Purpose	EHT	132.000	3	48.602035	
13	Heavy Industry	EHT	220.000	2	15.196776	
14	Heavy Industry	EHT	132.000	2	53.727564	
15	Large Industry	EHT	400.000	1	11.530853	
16	Large Industry	EHT	220.000	1	69.784203	
17	Large Industry	EHT	132.000	7	74.271404	
18	Power Intensive Industry	EHT	132.000	3	74.457666	
19	Railway Traction	EHT	220.000	1	0.785798	
20	Railway Traction	EHT	132.000	13	170.398122	
21	Allied Agro-Industrial Activities	HT	33.000	4	1.108405	
22	Allied Agro-Industrial Activities	HT	11.000	61	3.652878	
23	Allied Agricultural Activities	HT	33	3	1.119814	
24	Allied Agricultural Activities	HT	11.000	457	17.907188	
25	Electric vehicle through public charging system/station > 110 KVA	HT	33.000	1	2.214877	
26	Electric vehicle through public charging system/station > 110 KVA	HT	11.000	1	0.323453	
27	H.T Industrial (M) Supply	HT	33.000	9	0.140250	
28	H.T Industrial (M) Supply	HT	11.000	1530	20.081888	
29	H.T Industrial (M) Supply	HT	0.400	1	0.020056	
30	Irrigation Pumping and Agriculture	HT	11.000	1588	0.711673	
31	Irrigation Pumping and Agriculture	HT	0.400	2	0.009625	
32	Large Industry	HT	33.000	154	143.471209	

S.No	Type of Consumers	Category of Consumers (EHT/HT/LT/Others)	Voltage Level (In Voltage)	No of Consumers	Total Consumption (In MU)	Remarks (Source of data)
33	Large Industry	HT	11.000	693	88.251139	
34	Large Industry	HT	0.400	3	0.003273	
35	Mini Steel Plant	HT	33.000	1	10.560524	
36	Mini Steel Plant	HT	11.000	1	0.026284	
37	Power Intensive Industry	HT	33	2	7.730743	
38	Public Water Works & Sewerage Pumping	HT	33.000	32	26.225335	
39	Public Water Works & Sewerage Pumping	HT	11.000	3223	30.498737	
40	Public Water Works & Sewerage Pumping	HT	0.400	5	0.049600	
41	Public Water Works & Sewerage Pumping	HT	0.230	1	0.003241	
42	General Purpose >70 KVA < 110 KVA	HT	33.000	5	0.322842	
43	General Purpose >70 KVA < 110 KVA	HT	11.000	740	24.030294	
44	General Purpose >70 KVA < 110 KVA	HT	0.400	2	0.000484	
45	General Purpose >= 110 KVA	HT	33.000	92	91.736471	
46	General Purpose >= 110 KVA	HT	11.000	1322	164.013335	
47	General Purpose >= 110 KVA	HT	0.230	1	0.000046	
48	Mega Lift-General Purpose < 110 KVA	HT	11.000	198	0.135780	
49	Mega Lift-General Purpose > 110 KVA	HT	33.000	9	0.158345	
50	Mega Lift-General Purpose > 110 KVA	HT	11.000	2	0.039846	
51	OYT Scheme > 110 KVA	HT	33.000	1	0.790344	
52	OYT Scheme > 110 KVA	HT	11.000	1	0.042773	
53	Specified Public Purpose	HT	33.000	19	19.373397	
54	Specified Public Purpose	HT	11.000	502	30.553496	
55	Allied Agro-Industrial Activities	LT	0.400	85	0.996951	
56	Allied Agro-Industrial Activities	LT	0.230	30	0.046368	
57	Allied Agricultural Activities	LT	11.000	1	0.106284	
58	Allied Agricultural Activities	LT	0.400	2273	10.912222	
59	Allied Agricultural Activities	LT	0.230	7664	4.757338	
60	Electric vehicle through public charging system/station	LT	0.400	109	0.367197	
61	Electric vehicle through public charging system/station	LT	0.230	2	0.001946	
62	General Purpose < 110 KVA	LT	33.000	7	0.149500	
63	General Purpose < 110 KVA	LT	11.000	7274	58.487656	
64	General Purpose < 110 KVA	LT	0.400	31886	157.969005	
65	General Purpose < 110 KVA	LT	0.230	237439	128.356561	
66	Large Industry >=110 KVA	LT	0.400	7	0.561711	
67	Irrigation Pumping and Agriculture	LT	0.400	24936	6.661606	

S.No	Type of Consumers	Category of Consumers (EHT/HT/LT/Others)	Voltage Level (In Voltage)	No of Consumers	Total Consumption (In MU)	Remarks (Source of data)
68	Irrigation Pumping and Agriculture	LT	0.230	6884	2.267707	
69	Public Lighting	LT	11.000	139	1.089228	
70	Public Lighting	LT	0.400	1585	15.077448	
71	Public Lighting	LT	0.230	5055	6.078982	
72	Public Water Works and Sewerage Pumping <110 KVA	LT	0.400	3532	16.184077	
73	Public Water Works and Sewerage Pumping <110 KVA	LT	0.230	324	0.279860	
74	Specified Public Purpose	LT	0.400	2433	7.049879	
75	Specified Public Purpose	LT	0.230	27922	5.694932	
76	General Purpose >= 110 KVA	LT	0.400	32	1.731046	
77	General Purpose >= 110 KVA	LT	0.230	6	0.001158	
78	OYT Scheme < 110 KVA	LT	33.000	2	0.007098	
79	OYT Scheme < 110 KVA	LT	11.000	8	0.112719	
80	OYT Scheme < 110 KVA	LT	0.400	338	2.432922	
81	OYT Scheme < 110 KVA	LT	0.230	1000	1.094426	
82	OYT Scheme > 110 KVA	LT	0.400	1	0.059229	
83	Public Water Works and Sewerage Pumping >=110 KVA	LT	0.400	7	0.377669	
84	L.T. Industrial (M) Supply >=22 KVA and <110 KVA	LT	11.000	1	0.123980	
85	L.T. Industrial (M) Supply >=22 KVA and <110 KVA	LT	0.400	1472	13.196120	
86	L.T. Industrial (S) Supply <22 KVA	LT	11.000	203	0.406509	
87	L.T. Industrial (S) Supply <22 KVA	LT	0.400	7357	7.972531	
88	L.T. Industrial (S) Supply <22 KVA	LT	0.230	7	0.004572	
			Total	**3409145**	**3165.216042**	

(Details of Feeder-wise losses)

Period From 1st April,2026 to 30th Jun, 2026

Sl No.	Zone	Received at Circle (In MU)	Received at Division (In MU)	Received at Sub-division (In MU)	Name of the Station	Feeder Code/ID	Feeder Name	Type of Feeder (Urban/Mixed/Industrial/Agricultural/Rural)	Type of feeder meter (AMI/AMR/Other)	Received at Feeder (Final in MU)	Feeder Consumption (In MU)	Final Net Export at Feeder Level (In MU)	T&D losses	AT&C losses	% Data Received through Automatically (if feeder AMR/AMI)	Remarks
1	TPCODL	BBSR-01	BCDD-02		CS PUR-1	14001202	11 KV POKHRAN	URBAN	AMI	1.902168	1.902168	1.727876	9.16%	14.78%	100%	
2	TPCODL	BBSR-01	BCDD-02		CS PUR-1	14001203	11 KV BDA	URBAN	AMI	3.714848	3.714848	2.988760	19.55%	24.56%	100%	
3	TPCODL	BBSR-01	BCDD-02		CS PUR-1	14001204	11 KV CSPUR H B	URBAN	AMI	3.790204	3.790204	2.925965	22.80%	24.43%	100%	
4	TPCODL	BBSR-01	BCDD-02		CS PUR-2	14002202	11 KV HOUSING BOAF	URBAN	AMI	3.373504	3.373504	2.862086	15.16%	20.49%	100%	
5	TPCODL	BBSR-01	BCDD-02		CS PUR-2	14002204	11 KV HOUSING BOAF	URBAN	AMI	3.474064	3.474064	2.818230	18.88%	21.42%	100%	
6	TPCODL	BBSR-01	BCDD-02		CS PUR-2	14002205	11 KV HOUSING BOAF	URBAN	AMI	3.173392	3.173392	2.273259	28.37%	28.74%	100%	
7	TPCODL	BBSR-01	BCDD-02		CS PUR-2	14002208	11 KV Tulasi Vihar	URBAN	AMI	3.310408	3.310408	2.506174	24.29%	24.51%	100%	
8	TPCODL	BBSR-01	BCDD-02		INFOCITY	14003201	11 KV INFOCITY	URBAN	AMI	0.864138	0.864138	0.840097	2.78%	25.57%	100%	
9	TPCODL	BBSR-01	BCDD-02		INFOCITY	14003203	11 KV NEW INDUSTRY	URBAN	AMI	4.231710	4.231710	3.967734	6.24%	16.00%	100%	
10	TPCODL	BBSR-01	BCDD-02		INFOCITY	14003206	11 KV NEW PATIA	URBAN	AMI	4.563563	4.563563	3.603470	21.04%	26.65%	100%	
11	TPCODL	BBSR-01	BCDD-02		INFOCITY	14003209	11 KV O-TV	URBAN	AMI	2.138784	2.138784	1.759240	17.75%	26.89%	100%	
12	TPCODL	BBSR-01	BCDD-02		BARAMUNDA	14005201	11 KV BARAMUNDA HI	URBAN	AMI	4.511060	4.511060	3.733065	17.25%	18.86%	100%	
13	TPCODL	BBSR-01	BCDD-02		BARAMUNDA	14005202	11 KV BARAMUNDA BI	URBAN	AMI	1.822708	1.822708	1.411046	22.59%	21.81%	100%	
14	TPCODL	BBSR-01	BCDD-02		BARAMUNDA	14005203	11 KV BARAMUNDA DI	URBAN	AMI	4.547076	4.547076	3.966788	12.76%	17.90%	100%	
15	TPCODL	BBSR-01	BCDD-02		BARAMUNDA	14005204	11 KV CRPF	URBAN	AMI	3.150916	3.150916	2.564218	18.62%	24.19%	100%	
16	TPCODL	BBSR-01	BCDD-02		BHARATPUR	14006201	11 KV KHANDAGIRI	URBAN	AMI	4.343596	4.343596	3.998394	7.95%	11.72%	100%	
17	TPCODL	BBSR-01	BCDD-02		BHARATPUR	14006202	11 KV BHARATPUR BI	URBAN	AMI	3.415684	3.415684	3.159064	7.51%	15.08%	100%	
18	TPCODL	BBSR-01	BCDD-02		BHARATPUR	14006203	11 KV PHD	URBAN	AMI	3.778068	3.778068	1.922058	49.13%	53.65%	100%	
19	TPCODL	BBSR-01	BCDD-02		BHARATPUR	14006205	11 KV BHARATPUR	URBAN	AMI	5.872740	5.872740	4.302807	26.73%	26.06%	100%	
20	TPCODL	BBSR-01	BCDD-02		BHARATPUR	14006206	11 KV SAMPUR	URBAN	AMI	3.740076	3.740076	2.041376	45.42%	46.66%	100%	
21	TPCODL	BBSR-01	BCDD-02		KALINGA NAGAR	14007201	11 KV K-9	URBAN	AMI	4.549664	4.549664	4.129665	9.23%	17.00%	100%	
22	TPCODL	BBSR-01	BCDD-02		KALINGA NAGAR	14007203	11 KV OG-1 RMU (INDI	URBAN	AMI	7.045084	7.045084	5.802201	17.64%	25.18%	33%	
23	TPCODL	BBSR-01	BCDD-02		KALINGA NAGAR	14007204	11 KV KN RE	URBAN	AMI	5.349836	5.349836	3.602408	32.66%	35.79%	100%	
24	TPCODL	BBSR-01	BCDD-02		KALINGA NAGAR	14007205	11 KV DUMDUMA	URBAN	AMI	4.681640	4.681640	2.935036	37.31%	44.06%	100%	
25	TPCODL	BBSR-01	BCDD-02		KALINGA NAGAR	14007206	11 KV TAMANDO	URBAN	AMI	3.742364	3.742364	2.929790	21.71%	27.38%	100%	
26	TPCODL	BBSR-01	BCDD-02		NAYAPALLI	14008202	11 KV IRC-2	URBAN	AMI	1.416520	1.416520	0.849793	40.01%	41.43%	100%	
27	TPCODL	BBSR-01	BCDD-02		NAYAPALLI	14008203	11 KV IRC-3	URBAN	AMI	6.781382	6.781382	5.054975	25.46%	27.56%	100%	
28	TPCODL	BBSR-01	BCDD-02		NAYAPALLI	14008204	11 KV JAYDEV VIHAR	URBAN	AMI	3.007900	3.007900	2.246173	25.32%	26.25%	100%	
29	TPCODL	BBSR-01	BCDD-02		NAYAPALLI	14008205	11 KV RENTAL	URBAN	AMI	2.235808	2.235808	1.691763	24.33%	27.43%	100%	
30	TPCODL	BBSR-01	BCDD-02		NAYAPALLI	14008206	11 KV NALCO	URBAN	AMI	3.496258	3.496258	2.283460	34.69%	32.14%	100%	
31	TPCODL	BBSR-01	BCDD-02		NAYAPALLI	14008207	11 KV IRC-4	URBAN	AMI	2.865580	2.865580	2.580055	9.96%	17.14%	100%	
32	TPCODL	BBSR-01	BCDD-02		NAYAPALLI	14008208	11KV RPRC	URBAN	AMI	2.184946	2.184946	1.749429	19.93%	23.99%	100%	
33	TPCODL	BBSR-01	BCDD-02		NAYAPALLI	14008209	11KV BHAGWATI TEM	URBAN	AMI	3.111365	3.111365	2.242641	27.92%	30.89%	100%	
34	TPCODL	BBSR-01	BCDD-02		NAYAPALLI	14008211	11KV RAPTANI BHAW/	URBAN	AMI	3.511506	3.511506	3.156417	10.11%	11.37%	100%	
35	TPCODL	BBSR-01	BCDD-02		SAINIK SCHOOL	14010201	11 KV VSS NAGAR	URBAN	AMI	2.717330	2.717330	2.044068	24.78%	26.44%	100%	
36	TPCODL	BBSR-01	BCDD-02		SAINIK SCHOOL	14010203	11 KV PRESS	URBAN	AMI	2.186826	2.186826	1.980081	9.45%	16.06%	100%	
37	TPCODL	BBSR-01	BCDD-02		SAINIK SCHOOL	14010204	11 KV VANIVIHAR	URBAN	AMI	1.426904	1.426904	1.158154	18.83%	21.86%	100%	
38	TPCODL	BBSR-01	BCDD-02		SAINIK SCHOOL	14010205	11 KV SAINIK SCHOOL	URBAN	AMI	1.921235	1.921235	1.160136	39.62%	42.53%	67%	
39	TPCODL	BBSR-01	BCDD-02		SAINIK SCHOOL	14010206	11 KV KELUCHARAN F	URBAN	AMI	2.284080	2.284080	1.805624	20.95%	23.57%	100%	
40	TPCODL	BBSR-01	BCDD-01		UNIT-8	14011201	11 KV OUAT	URBAN	AMI	3.352976	3.352976	2.760833	17.66%	18.85%	100%	
41	TPCODL	BBSR-01	BCDD-01		UNIT-8	14011203	11 KV GB NAGAR	URBAN	AMI	3.676924	3.676924	3.488523	5.12%	19.05%	100%	
42	TPCODL	BBSR-01	BCDD-01		UNIT-8	14011204	11 KV TELEPHONE BH	URBAN	AMI	1.912704	1.912704	1.739414	9.06%	17.76%	100%	
43	TPCODL	BBSR-01	BCDD-01		UNIT-8	14011207	11 KV RAJBHAWAN	URBAN	AMI	0.193840	0.193840	0.101383	47.70%	41.55%	100%	
44	TPCODL	BBSR-01	BCDD-01		UNIT-8	14011209	11 KV OERC	URBAN	AMI	3.625228	3.625228	2.310885	36.26%	39.71%	100%	
45	TPCODL	BBSR-01	BCDD-01		UNIT-8	14011213	11 KV BM RMU 15	URBAN	AMI	2.200944	2.200944	1.846281	16.11%	31.48%	100%	
46	TPCODL	BBSR-01	BCDD-01		UNIT-6	14012202	11 KV FOREST PARK	URBAN	AMI	3.055582	3.055582	2.035427	33.39%	36.95%	100%	
47	TPCODL	BBSR-01	BCDD-01		UNIT-6	14012203	11 KV UNIT-1	URBAN	AMI	2.032876	2.032876	1.676733	17.52%	20.83%	100%	
48	TPCODL	BBSR-01	BCDD-01		UNIT-6	14012204	11 KV SPRING TANK	URBAN	AMI	2.146316	2.146316	1.858577	13.41%	13.68%	100%	
49	TPCODL	BBSR-01	BCDD-01		UNIT-6	14012205	11 KV BAPUJINAGAR	URBAN	AMI	4.855856	4.855856	4.434315	8.68%	12.26%	100%	
50	TPCODL	BBSR-01	BCDD-01		UNIT-6	14012206	11 KV UNIT-6	URBAN	AMI	1.316308	1.316308	1.066599	18.97%	20.57%	100%	
51	TPCODL	BBSR-01	BCDD-01		UNIT-6	14012209	11 KV RMU-7	URBAN	AMI	0.452800	0.452800	0.430773	4.86%	4.68%	100%	
52	TPCODL	BBSR-01	BCDD-01		UNIT-4	14013201	11 KV MS NAGAR/RMU	URBAN	AMI	2.158826	2.158826	1.773431	17.85%	22.57%	100%	
53	TPCODL	BBSR-01	BCDD-01		UNIT-4	14013203	11 KV RMU-7	URBAN	AMI	1.243156	1.243156	0.738310	40.61%	39.97%	100%	
54	TPCODL	BBSR-01	BCDD-01		UNIT-4	14013205	11 KV RMU-5	URBAN	AMI	1.695010	1.695010	1.566207	7.60%	5.36%	100%	
55	TPCODL	BBSR-01	BCDD-01		UNIT-4	14013207	11 KV RMU-14	URBAN	AMI	0.942772	0.942772	0.644578	31.63%	31.31%	100%	
56	TPCODL	BBSR-01	BCDD-01		UNIT-4	14013208	11 KV RMU-15	URBAN	AMI	0.509788	0.509788	0.438069	14.07%	15.51%	100%	
57	TPCODL	BBSR-01	BCDD-01		SATYA NAGAR	14014203	11 KV PLAZA	URBAN	AMI	1.174816	1.174816	0.847753	27.84%	29.12%	100%	
58	TPCODL	BBSR-01	BCDD-01		SATYA NAGAR	14014204	11 KV RAHULCO	URBAN	AMI	1.027432	1.027432	0.675640	34.24%	35.70%	100%	
59	TPCODL	BBSR-01	BCDD-01		SATYA NAGAR	14014208	11 KV JP RMU-45	URBAN	AMI	1.364976	1.364976	1.141352	16.38%	22.16%	100%	
60	TPCODL	BBSR-01	BCDD-01		UNIT-3	14015202	11 KV UNIT-3	URBAN	AMI	2.702456	2.702456	1.913876	29.18%	31.94%	100%	
61	TPCODL	BBSR-01	BCDD-01		UNIT-3	14015203	11 KV UNIT-2	URBAN	AMI	0.830468	0.830468	0.699483	15.77%	24.31%	100%	
62	TPCODL	BBSR-01	BCDD-01		UNIT-3	14015205	11 kV SM RMU-4	URBAN	AMI	1.789030	1.789030	1.324109	25.99%	23.81%	100%	
63	TPCODL	BBSR-01	BCDD-01		UNIT-3	14015207	11 kV JP RMU-41	URBAN	AMI	0.765646	0.765646	0.565170	26.18%	34.98%	100%	
64	TPCODL	BBSR-01	BCDD-01		SAHID NAGAR	14016202	11 KV Feeder-2	URBAN	AMI	2.979100	2.979100	2.782516	6.60%	11.02%	100%	
65	TPCODL	BBSR-01	BCDD-01		SAHID NAGAR	14016203	11 KV Feeder-3	URBAN	AMI	2.766060	2.766060	2.542856	8.07%	15.20%	100%	
66	TPCODL	BBSR-01	BCDD-01		SAHID NAGAR	14016207	11 KV JP RMU35	URBAN	AMI	0.808902	0.808902	0.450948	44.25%	52.24%	100%	
67	TPCODL	BBSR-01	BCDD-01		BOARD COLONY	14017205	11 KV BM RMU2	URBAN	AMI	1.484072	1.484072	1.105637	25.50%	38.07%	100%	
68	TPCODL	BBSR-01	BCDD-01		BOARD COLONY	14017207	11 KV JP RMU-36	URBAN	AMI	1.470146	1.470146	0.745481	49.29%	50.76%	100%	
69	TPCODL	BBSR-01	BCDD-01		BOARD COLONY	14017208	11 KV JP RMU-37	URBAN	AMI	2.265524	2.265524	1.658296	26.80%	34.74%	100%	
70	TPCODL	BBSR-01	BCDD-01		BOARD COLONY	14017210	11 KV SM RMU1	URBAN	AMI	3.003704	3.003704	2.418008	19.50%	20.82%	100%	
71	TPCODL	BBSR-01	BED		BHIMATANGI	14018201	11 KV POKHARIPUT-1	URBAN	AMI	5.131744	5.131744	4.824655	5.98%	10.37%	100%	
72	TPCODL	BBSR-01	BED		BHIMATANGI	14018202	11 KV LINGARAJ	URBAN	AMI	3.232936	3.232936	2.215107	31.48%	34.05%	100%	
73	TPCODL	BBSR-01	BED		BHIMATANGI	14018203	11 KV BHIMATANGI	URBAN	AMI	4.097132	4.097132	3.201168	21.87%	23.58%	100%	
74	TPCODL	BBSR-01	BED		BHIMATANGI	14018204	11 KV R.E JAMUKOLI	URBAN	AMI	6.288068	6.288068	4.421338	29.69%	34.50%	100%	
75	TPCODL	BBSR-01	BED		BHIMATANGI	14018205	11 KV POKHARIPUT-2	URBAN	AMI	4.299940	4.299940	2.376094	44.74%	45.26%	100%	
76	TPCODL	BBSR-01	BED		BHIMATANGI	14018207	11 KV STATION FDR	URBAN	AMI	1.874440	1.874440	1.301008	30.59%	34.55%	100%	
77	TPCODL	BBSR-01	BED		BADAGADA	14019201	11 KV BRAHMESWAR	URBAN	AMI	6.263960	6.263960	5.317918	15.10%	18.92%	100%	
78	TPCODL	BBSR-01	BED		BADAGADA	14019202	11 KV BADAGADA LIN	URBAN	AMI	2.190764	2.190764	1.334122	39.10%	40.74%	100%	
79	TPCODL	BBSR-01	BED		BADAGADA	14019203	11 KV MAUSIMA	URBAN	AMI	1.733068	1.733068	1.337386	22.83%	27.59%	100%	
80	TPCODL	BBSR-01	BED		BADAGADA	14019204	11 KV WATER WORKS	URBAN	AMI	5.382840	5.382840	4.146640	22.97%	26.99%	100%	
81	TPCODL	BBSR-01	BED		BADAGADA	14019206	11 KV B.J.B NAGAR	URBAN	AMI	1.996812	1.996812	1.335283	33.13%	38.11%	100%	
82	TPCODL	BBSR-01	BED		BADAGADA	14019207	11 KV SAI	URBAN	AMI	2.232040	2.232040	1.184735	46.92%	49.15%	100%	

Sl No.	Zone	Received at Circle (In MU)	Received at Division (In MU)	Received at Sub-division (In MU)	Name of the Station	Feeder Code/ID	Feeder Name	Type of Feeder (Urban/Mixed/Industrial/Agricultural/Rural)	Type of feeder meter (AMI/AMR/Other)	Received at Feeder (Final in MU)	Feeder Consumption (In MU)	Final Net Export at Feeder Level (In MU)	T&D losses	AT&C losses	% Data Received through Automatically (if feeder AMR/AMI)	Remarks
83	TPCODL	BBSR-01	BED		BADAGADA	14019209	11 KV BHUASUNI	URBAN	AMI	5.798088	5.798088	3.055931	47.29%	49.78%	100%	
84	TPCODL	BBSR-01	BED		BADAGADA	14019210	11 KV GOUTAM NAGA	URBAN	AMI	2.825160	2.825160	2.438397	13.69%	14.76%	100%	
85	TPCODL	BBSR-01	BED		BADAGADA	14019211	11 KV RMU-20	URBAN	AMI	0.784552	0.784552	0.333869	57.44%	62.27%	67%	
86	TPCODL	BBSR-01	BED		BADAGADA	14019213	11 KV RMU-11	URBAN	AMI	1.571700	1.571700	1.526254	2.89%	16.45%	100%	
87	TPCODL	BBSR-01	BED		LAXMISAGAR	14020203	11 KV JHARAPADA UG	URBAN	AMI	2.488740	2.488740	2.018635	18.89%	21.32%	100%	
88	TPCODL	BBSR-01	BED		LAXMISAGAR	14020204	11 KV BOMIKHAL	URBAN	AMI	1.386776	1.386776	1.203986	13.18%	14.91%	100%	
89	TPCODL	BBSR-01	BED		LAXMISAGAR	14020205	11 KV KALPANA-2	URBAN	AMI	5.167853	5.167853	4.571867	11.53%	16.32%	100%	
90	TPCODL	BBSR-01	BED		LAXMISAGAR	14020207	11 KV RMU-6A	URBAN	AMI	3.992202	3.992202	2.744191	31.26%	34.32%	100%	
91	TPCODL	BBSR-01	BED		LAXMISAGAR	14020209	11 KV RMU-16	URBAN	AMI	4.971030	4.971030	4.796386	3.51%	9.53%	100%	
92	TPCODL	BBSR-01	BED		LAXMISAGAR	14020211	11 KV JHARPADA OH	URBAN	AMI	2.997427	2.997427	2.045202	31.77%	38.15%	100%	
93	TPCODL	BBSR-01	BED		LAXMISAGAR	14020213	11 KV RMU-14	URBAN	AMI	2.131230	2.131230	1.766168	17.13%	21.06%	100%	
94	TPCODL	BBSR-01	BED		RASULGARH	14021201	11 KV RASULGARH	URBAN	AMI	8.092556	8.092556	6.674710	17.52%	21.20%	100%	
95	TPCODL	BBSR-01	BED		RASULGARH	14021203	11 KV KALPANA	URBAN	AMI	6.641420	6.641420	5.100511	23.20%	24.37%	100%	
96	TPCODL	BBSR-01	BED		MANCHESWAR	14022201	11 KV MANCHESWAR	URBAN	AMI	4.834056	4.834056	4.657106	3.66%	13.15%	100%	
97	TPCODL	BBSR-01	BED		MANCHESWAR	14022202	11 KV MANCHESWAR	URBAN	AMI	6.722224	6.722224	6.361409	5.37%	11.60%	100%	
98	TPCODL	BBSR-01	BED		MANCHESWAR	14022203	11 KV MANCHESWAR	URBAN	AMI	7.345196	7.345196	5.594513	23.83%	23.35%	100%	
99	TPCODL	BBSR-01	BED		MANCHESWAR	14022204	11 KV VSS NAGAR	URBAN	AMI	4.350892	4.350892	3.908536	10.17%	18.07%	100%	
100	TPCODL	BBSR-01	BED		NAKHARA	14023202	11 KV TRINATH BAZAR	URBAN	AMI	1.153758	1.153758	0.937782	18.72%	21.26%	100%	
101	TPCODL	BBSR-01	BED		NAKHARA	14023203	11 KV PAHAL	URBAN	AMI	4.991298	4.991298	3.896817	21.93%	25.73%	100%	
102	TPCODL	BBSR-01	BED		NAKHARA	14023204	11 KV DPS	URBAN	AMI	2.915070	2.915070	2.375784	18.50%	22.82%	100%	
103	TPCODL	BBSR-01	BED		NAKHARA	14023206	11 KV TRINATH BAZAR	URBAN	AMI	3.536512	3.536512	2.741576	22.48%	25.71%	100%	
104	TPCODL	BBSR-01	BED		NAKHARA	14023207	11 KV PAHAL UG	URBAN	AMI	2.101428	2.101428	1.541768	26.63%	30.84%	100%	
105	TPCODL	BBSR-01	NED		BALIPATNA	14024201	11 KV BALIPATNA	RURAL	AMI	2.773244	2.773244	1.666752	39.90%	61.03%	100%	
106	TPCODL	BBSR-01	NED		BALIPATNA	14024202	11 KV BUDHIPADA	RURAL	AMI	5.213200	5.213200	2.107758	59.57%	69.40%	100%	
107	TPCODL	BBSR-01	NED		BALIPATNA	14024204	11 KV NARADA	RURAL	AMI	2.984448	2.984448	1.554823	47.90%	56.97%	100%	
108	TPCODL	BBSR-01	NED		BALAKATI	14025201	11 KV BALAKATI	RURAL	AMI	3.178977	3.178977	2.637832	17.02%	26.10%	100%	
109	TPCODL	BBSR-01	NED		BALAKATI	14025202	11 KV SATYABHAMAP	RURAL	AMI	5.352705	5.352705	3.902755	27.09%	35.55%	100%	
110	TPCODL	BBSR-01	NED		BALAKATI	14025203	11 KV BAINCHUA	RURAL	AMI	1.637978	1.637978	0.847763	48.24%	54.22%	100%	
111	TPCODL	BBSR-01	BED		UTTARA	14026201	11 KV KAUSHALYA	URBAN	AMI	3.180872	3.180872	2.143118	32.62%	35.58%	100%	
112	TPCODL	BBSR-01	BED		UTTARA	14026202	11 KV DHAULI	URBAN	AMI	4.076064	4.076064	2.443772	40.05%	41.95%	100%	
113	TPCODL	BBSR-01	BED		UTTARA	14026203	11 KV KEC	URBAN	AMI	1.231212	1.231212	0.724375	41.17%	49.48%	100%	
114	TPCODL	BBSR-01	BED		UTTARA	14026204	11 KV SARDEIPUR	URBAN	AMI	1.344600	1.344600	1.336979	0.57%	6.24%	100%	
115	TPCODL	BBSR-01	NED		NIMAPARA	14027203	11 KV DANDIPUR	RURAL	AMI	4.487380	4.487380	1.782012	60.29%	68.58%	100%	
116	TPCODL	BBSR-01	NED		NIMAPARA	14027204	11 KV OMFED	RURAL	AMI	5.076280	5.076280	2.817952	44.49%	50.72%	100%	
117	TPCODL	BBSR-01	NED		PIPILI	14028201	11 KV PIPILI	RURAL	AMI	7.569524	7.569524	3.311616	56.25%	65.52%	100%	
118	TPCODL	BBSR-01	NED		PIPILI	14028203	11 KV MANGALAPUR-	RURAL	AMI	3.447584	3.447584	2.087300	39.46%	49.84%	100%	
119	TPCODL	BBSR-01	NED		PIPILI	14028204	11 KV MANGALAPUR-	RURAL	AMI	3.849756	3.849756	2.277691	40.84%	55.79%	100%	
120	TPCODL	BBSR-01	NED		ASTARANGA	14029201	11 KV ASTARANGA	RURAL	AMI	3.049767	3.049767	1.467821	51.87%	58.95%	100%	
121	TPCODL	BBSR-01	NED		ASTARANGA	14029202	11 KV JIUNTY	RURAL	AMI	2.546642	2.546642	1.468321	42.34%	49.93%	100%	
122	TPCODL	BBSR-01	NED		KAKATPUR	14030203	11 KV NILAKANTHAPU	RURAL	AMI	2.405260	2.405260	1.255877	47.79%	57.81%	100%	
123	TPCODL	BBSR-01	NED		KAKATPUR	14030204	11 KV NAYAHAT-2	RURAL	AMI	2.497416	2.497416	2.008558	19.57%	31.70%	100%	
124	TPCODL	BBSR-01	NED		KAKATPUR	14030205	11 KV KAKATPUR-2	RURAL	AMI	5.194528	5.194528	4.070007	21.65%	35.23%	100%	
125	TPCODL	BBSR-01	NED		KONARK	14031201	11 KV KONARK O/H (C	RURAL	AMI	1.904800	1.904800	1.063866	44.15%	52.42%	100%	
126	TPCODL	BBSR-01	NED		KONARK	14031202	11 KV BALIDOKAN	RURAL	AMI	1.975228	1.975228	0.989099	49.92%	57.85%	100%	
127	TPCODL	BBSR-01	NED		KONARK	14031204	11 KV KONARK U/G	RURAL	AMI	1.587994	1.587994	1.362074	14.23%	36.00%	100%	
128	TPCODL	BBSR-01	NED		KONARK	14031205	11 KV ANASARA	RURAL	AMI	1.100748	1.100748	0.719140	34.67%	41.48%	33%	
129	TPCODL	BBSR-01	NED		KONARK	14031206	11 KV DASABATIA	RURAL	AMI	2.145440	2.145440	1.083678	49.49%	59.12%	100%	
130	TPCODL	BBSR-01	NED		KONARK	14031207	11 KV SIRIPUR (KONA	RURAL	AMI	0.992745	0.992745	0.514722	48.15%	57.25%	67%	
131	TPCODL	BBSR-02	KHD		JATANI	14033201	11 KV BACHHARA	RURAL	AMI	3.584580	3.584580	2.182110	39.13%	48.24%	100%	
132	TPCODL	BBSR-02	KHD		JATANI	14033202	11 KV RAJA BAZAR	RURAL	AMI	3.667352	3.667352	2.589466	29.39%	36.24%	100%	
133	TPCODL	BBSR-02	KHD		JATANI	14033203	11 KV KUSUMATI	RURAL	AMI	2.887424	2.887424	1.459893	49.44%	60.24%	100%	
134	TPCODL	BBSR-02	KHD		JATANI	14033204	11 KV JATNI TOWN	RURAL	AMI	2.228828	2.228828	1.576251	29.28%	35.59%	100%	
135	TPCODL	BBSR-02	KHD		JATANI	14033206	11 KV JATANI MEDICA	RURAL	AMI	2.510460	2.510460	1.925381	23.31%	34.04%	100%	
136	TPCODL	BBSR-02	KHD		JATANI	14033207	11 KV GAJAPATI NAGA	RURAL	AMI	2.622384	2.622384	1.920278	26.77%	33.56%	100%	
137	TPCODL	BBSR-02	KHD		JANLA	14034201	11 KV MENDHASAL	RURAL	AMI	1.598865	1.598865	1.296162	18.93%	26.34%	33%	
138	TPCODL	BBSR-02	KHD		JANLA	14034202	11 KV OIL MILL-1	RURAL	AMI	3.827248	3.827248	3.632963	5.08%	10.91%	100%	
139	TPCODL	BBSR-02	KHD		JANLA	14034204	11 KV MADANPUR	RURAL	AMI	5.083320	5.083320	4.137118	18.61%	25.95%	100%	
140	TPCODL	BBSR-02	KHD		HARIRAJPUR	14035201	11 KV KANTIA	RURAL	AMI	5.116550	5.116550	0.719408	85.94%	88.51%	100%	
141	TPCODL	BBSR-02	KHD		HARIRAJPUR	14035203	11 KV KUDIARY	RURAL	AMI	1.450697	1.450697	1.097535	24.34%	32.22%	100%	
142	TPCODL	BBSR-02	KHD		HARIRAJPUR	14035205	11 KV BAHILIPADA	RURAL	AMI	1.677576	1.677576	1.492398	11.04%	42.15%	100%	
143	TPCODL	BBSR-02	KHD		GURUJANGA	14036201	11 KV HALADIA	RURAL	AMI	4.088401	4.088401	3.988256	2.45%	21.06%	100%	
144	TPCODL	BBSR-02	KHD		JANKIA	14037201	11 KV OLASINGH	RURAL	AMI	1.840266	1.840266	0.960543	47.80%	62.36%	100%	
145	TPCODL	BBSR-02	KHD		JANKIA	14037203	11 KV NIRAKARPUR-2	RURAL	AMI	3.768000	3.768000	2.426752	35.60%	46.78%	100%	
146	TPCODL	BBSR-02	KHD		MALIPADA	14038202	11 KV MALIPADA TAPA	RURAL	AMI	1.469308	1.469308	0.881087	40.03%	45.17%	100%	
147	TPCODL	BBSR-02	KHD		MALIPADA	14038203	11 KV NARANGARH-2/	RURAL	AMI	0.098467	0.098467	0.086143	12.52%	10.62%	100%	
148	TPCODL	BBSR-02	KHD		MALIPADA	14038204	11 KV CHATARAMA	RURAL	AMI	2.370372	2.370372	1.428504	39.74%	40.63%	100%	
149	TPCODL	BBSR-02	KHD		NARANGARH	14039203	11 KV KAIMATIA	RURAL	AMI	0.337846	0.337846	0.249600	26.12%	45.46%	100%	
150	TPCODL	BBSR-02	KHD		NARANGARH	14039205	11 KV NARANGARH VI	RURAL	AMI	0.204934	0.204934	0.120686	41.11%	55.67%	100%	
151	TPCODL	BBSR-02	KHD		BAGHAMARI	14040201	11 KV SARUA (Bagham	RURAL	AMI	0.615565	0.615565	0.367904	40.23%	51.03%	100%	
152	TPCODL	BBSR-02	KHD		BAGHAMARI	14040202	11 KV PODADHIA	RURAL	AMI	2.347956	2.347956	1.441443	38.61%	50.42%	100%	
153	TPCODL	BBSR-02	KHD		BAGHAMARI	14040203	11 KV ATRI	RURAL	AMI	1.135218	1.135218	1.094478	3.59%	26.17%	100%	
154	TPCODL	BBSR-02	KHD		PARICHHAL	14041201	11 KV GADAMANITRI	RURAL	AMI	0.600154	0.600154	0.356232	40.64%	56.12%	100%	
155	TPCODL	BBSR-02	KHD		PARICHHAL	14041203	11 KV PARICHHAL	RURAL	AMI	1.138294	1.138294	0.696592	38.80%	51.07%	100%	
156	TPCODL	BBSR-02	KHD		PARICHHAL	14041204	11 KV PATANAHAT	RURAL	AMI	1.838694	1.838694	1.003784	45.41%	56.27%	100%	
157	TPCODL	BBSR-02	KHD		PARICHHAL	14041205	11 KV ROUTPADA	RURAL	AMI	0.722016	0.722016	0.479320	33.61%	44.49%	100%	
158	TPCODL	BBSR-02	KHD		RAJSUNAKHALA	14042201	11 KV BAYAPALLI	RURAL	AMI	0.917892	0.917892	0.543817	40.75%	51.46%	67%	
159	TPCODL	BBSR-02	KHD		RAJSUNAKHALA	14042202	11 KV KADABA	RURAL	AMI	1.027192	1.027192	0.705190	31.35%	45.79%	67%	
160	TPCODL	BBSR-02	KHD		RAJSUNAKHALA	14042204	11 KV BANKOI	RURAL	AMI	0.862069	0.862069	0.779437	9.59%	28.32%	100%	
161	TPCODL	BBSR-02	KHD		RAJSUNAKHALA	14042205	11 KV SANA PADAR	RURAL	AMI	2.029668	2.029668	1.067292	47.42%	57.23%	100%	
162	TPCODL	BBSR-02	KHD		OIL MILL	14043204	11 KV INDUSTRIAL-1	RURAL	AMI	5.445480	5.445480	4.545059	16.54%	10.91%	100%	
163	TPCODL	BBSR-02	KHD		OIL MILL	14043206	11 KV OTPL	RURAL	AMI	1.678954	1.678954	1.530171	8.86%	7.88%	100%	
164	TPCODL	BBSR-02	KHD		10-POLE	14044201	11 KV KHORDHA TOW	RURAL	AMI	2.649088	2.649088	2.550168	3.73%	24.37%	67%	
165	TPCODL	BBSR-02	KHD		10-POLE	14044203	11 KV PANABARAJ	RURAL	AMI	3.708936	3.708936	2.469218	33.43%	46.66%	100%	
166	TPCODL	BBSR-02	KHD		10-POLE	14044205	11 KV GURUJANGA	RURAL	AMI	5.589920	5.589920	3.290815	41.13%	48.13%	100%	

Sl No.	Zone	Received at Circle (In MU)	Received at Division (In MU)	Received at Sub-division (In MU)	Name of the Station	Feeder Code/ID	Feeder Name	Type of Feeder (Urban/Mixed/Industrial/Agricultural/Rural)	Type of feeder meter (AMI/AMR/Other)	Received at Feeder (Final in MU)	Feeder Consumption (In MU)	Final Net Export at Feeder Level (In MU)	T&D losses	AT&C losses	% Data Received through Automatically (if feeder AMR/AMI)	Remarks
167	TPCODL	BBSR-02	KHD		10-POLE	14044206	11 KV TARATUA	RURAL	AMI	3.139904	3.139904	1.887042	39.90%	48.97%	100%	
168	TPCODL	BBSR-02	KHD		TULASIPUR	14045201	11 KV TULASIPUR FEE	RURAL	AMI	1.393442	1.393442	0.878751	36.94%	48.59%	100%	
169	TPCODL	BBSR-02	KHD		SUNADEIMUNDIA	14047203	11 KV VEDA	RURAL	AMI	1.218104	1.218104	0.952930	21.77%	41.26%	100%	
170	TPCODL	BBSR-02	KHD		SUNADEIMUNDIA	14047204	11 KV CHAKAPADA	RURAL	AMI	1.341812	1.341812	0.826631	38.39%	47.97%	100%	
171	TPCODL	BBSR-02	KHD		KALAPATHAR	14048201	11 KV BAIDESWAR	RURAL	AMI	2.794154	2.794154	1.271207	54.50%	61.72%	33%	
172	TPCODL	BBSR-02	KHD		KALAPATHAR	14048203	11 KV KALAPATHAR	RURAL	AMI	2.332224	2.332224	1.254811	46.20%	53.77%	100%	
173	TPCODL	BBSR-02	KHD		JATAMUNDIA	14049201	11 KV TALABASTA	RURAL	AMI	1.976044	1.976044	1.085871	45.05%	56.77%	100%	
174	TPCODL	BBSR-02	KHD		JATAMUNDIA	14049205	11 KV GADAJIT	RURAL	AMI	1.552860	1.552860	0.927950	40.24%	55.39%	100%	
175	TPCODL	BBSR-02	KHD		TIRIMAL	14050201	11 KV TIRUMALLA	RURAL	AMI	0.469994	0.469994	0.241843	48.54%	59.64%	100%	
176	TPCODL	BBSR-02	KHD		TIRIMAL	14050202	11 KV TARABOI	RURAL	AMI	2.256074	2.256074	1.424116	36.88%	43.96%	100%	
177	TPCODL	BBSR-02	KHD		TIRIMAL	14050203	11KV Benapanjari Feed	RURAL	AMI	1.315466	1.315466	0.734604	44.16%	63.26%	100%	
178	TPCODL	BBSR-01	NED		GOP	14051201	11 KV GOP	RURAL	AMI	2.364222	2.364222	1.457311	38.36%	51.52%	100%	
179	TPCODL	BBSR-01	NED		GOP	14051202	11 KV NAGAPUR	RURAL	AMI	1.914000	1.914000	1.201652	37.22%	56.12%	100%	
180	TPCODL	BBSR-01	NED		GOP	14051203	11 KV BEGUNAI	RURAL	AMI	2.635140	2.635140	1.420779	46.08%	58.46%	100%	
181	TPCODL	BBSR-02	NYD		BOLAGARH	14052201	11 KV BOLOGARH	RURAL	AMI	1.273192	1.273192	0.894756	29.72%	35.95%	100%	
182	TPCODL	BBSR-02	NYD		BOLAGARH	14052202	11 KV KAPASIA	RURAL	AMI	1.212368	1.212368	0.751983	37.97%	42.24%	100%	
183	TPCODL	BBSR-02	NYD		BOLAGARH	14052204	11 KV KHANGURIA	RURAL	AMI	0.980939	0.980939	0.722594	26.34%	29.96%	67%	
184	TPCODL	BBSR-02	NYD		BOLAGARH	14052205	11 KV DIBYASINGHPU	RURAL	AMI	1.290774	1.290774	0.704037	45.46%	45.75%	100%	
185	TPCODL	BBSR-02	NYD		ITAMATI	14053201	11 KV ITAMATI	RURAL	AMI	2.474821	2.474821	1.922491	22.32%	27.33%	100%	
186	TPCODL	BBSR-02	NYD		ITAMATI	14053202	11 KV LATHIPADA-1	RURAL	AMI	1.067126	1.067126	0.693310	35.03%	36.77%	100%	
187	TPCODL	BBSR-02	NYD		ITAMATI	14053203	11 KV BADA PANDUSA	RURAL	AMI	2.073652	2.073652	1.558405	24.85%	28.87%	100%	
188	TPCODL	BBSR-02	NYD		ITAMATI	14053204	11 KV CHAMPATIPUR	RURAL	AMI	2.308805	2.308805	1.406881	39.06%	41.13%	100%	
189	TPCODL	BBSR-02	NYD		ITAMATI	14053205	11 KV LATHIPADA-2 (N	RURAL	AMI	0.139414	0.139414	0.104801	24.83%	22.11%	100%	
190	TPCODL	BBSR-02	NYD		KHANDAPADA	14054201	11 KV KHANDAPADA	RURAL	AMI	1.711750	1.711750	1.260273	26.38%	39.26%	100%	
191	TPCODL	BBSR-02	NYD		KHANDAPADA	14054203	11 KV PANIPOILL	RURAL	AMI	0.949412	0.949412	0.809600	14.73%	23.80%	100%	
192	TPCODL	BBSR-02	NYD		KANTILO	14055201	11 KV KANTILO	RURAL	AMI	2.075557	2.075557	1.473163	29.02%	29.81%	100%	
193	TPCODL	BBSR-02	NYD		KANTILO	14055202	11 KV BANAPUR	RURAL	AMI	0.444784	0.444784	0.284568	36.02%	39.34%	100%	
194	TPCODL	BBSR-02	NYD		KANTILO	14055203	11 KV BENAGADIA	RURAL	AMI	0.665040	0.665040	0.474518	28.65%	33.56%	100%	
195	TPCODL	BBSR-02	NYD		FATEGARH	14056202	11 KV BHAPUR	RURAL	AMI	1.139106	1.139106	0.832607	26.91%	37.16%	100%	
196	TPCODL	BBSR-02	NYD		GANIA	14057201	11 KV GANIA	RURAL	AMI	1.458208	1.458208	1.098431	24.67%	34.03%	100%	
197	TPCODL	BBSR-02	NYD		GANIA	14057203	11 KV BALARAM	RURAL	AMI	1.270560	1.270560	0.774109	39.07%	46.17%	100%	
198	TPCODL	BBSR-02	NYD		NAYAGARH	14058201	11 KV NAYAGARH	RURAL	AMI	5.050968	5.050968	4.167270	17.50%	30.09%	100%	
199	TPCODL	BBSR-02	NYD		NAYAGARH	14058202	11 KV OLD TOWN	RURAL	AMI	2.325766	2.325766	1.125235	51.62%	60.11%	100%	
200	TPCODL	BBSR-02	NYD		NAYAGARH	14058203	11 KV SINDURIA	RURAL	AMI	3.388276	3.388276	2.964037	12.52%	22.44%	100%	
201	TPCODL	BBSR-02	NYD		DASPALLA	14059201	11 KV DASPALLA TOW	RURAL	AMI	4.619484	4.619484	3.348414	27.52%	34.18%	100%	
202	TPCODL	BBSR-02	NYD		DASPALLA	14059203	11 KV POIBARI	RURAL	AMI	1.190650	1.190650	0.685990	42.39%	49.03%	100%	
203	TPCODL	BBSR-02	NYD		DASPALLA	14059204	11 KV KUANRIA	RURAL	AMI	1.195256	1.195256	0.753007	37.00%	40.38%	100%	
204	TPCODL	BBSR-02	NYD		DASPALLA	14059205	11 KV KHAMARSAHI	RURAL	AMI	1.227382	1.227382	0.826415	32.67%	38.39%	100%	
205	TPCODL	BBSR-02	NYD		NUAGAON	14060201	11 KV NUAGAON	RURAL	AMI	0.414210	0.414210	0.295979	28.54%	39.46%	100%	
206	TPCODL	BBSR-02	NYD		NUAGAON	14060202	11 KV SANAPADA	RURAL	AMI	0.302920	0.302920	0.172598	43.02%	45.67%	100%	
207	TPCODL	BBSR-02	NYD		NUAGAON	14060203	11 KV MAHITAMA	RURAL	AMI	0.886617	0.886617	0.633923	28.50%	36.82%	100%	
208	TPCODL	BBSR-02	NYD		MAHIPUR	14061202	11 KV VIRUDA	RURAL	AMI	0.863040	0.863040	0.767388	11.08%	24.93%	100%	
209	TPCODL	BBSR-02	NYD		MAHIPUR	14061203	11 KV SINGARPALLY-1	RURAL	AMI	0.839507	0.839507	0.555018	33.89%	37.90%	100%	
210	TPCODL	BBSR-02	NYD		MAHIPUR	14061204	11 KV SINGARPALLY-2	RURAL	AMI	0.204814	0.204814	0.151588	25.99%	44.38%	100%	
211	TPCODL	BBSR-02	NYD		SARANKUL	14062201	11 KV SARANKUL	RURAL	AMI	0.783868	0.783868	0.586217	25.21%	33.31%	100%	
212	TPCODL	BBSR-02	NYD		SARANKUL	14062202	11 KV GODIPADA	RURAL	AMI	0.989235	0.989235	0.686830	30.57%	31.33%	100%	
213	TPCODL	BBSR-02	NYD		SARANKUL	14062203	11 KV MACHHIPADA	RURAL	AMI	0.344413	0.344413	0.251502	26.98%	39.11%	100%	
214	TPCODL	BBSR-02	NYD		SARANKUL	14062204	11 KV DARAPADA	RURAL	AMI	1.009376	1.009376	0.777383	22.98%	36.11%	100%	
215	TPCODL	BBSR-02	NYD		SARANKUL	14062205	11 KV PANCHIDA	RURAL	AMI	1.664583	1.664583	1.177265	29.28%	33.21%	100%	
216	TPCODL	BBSR-02	NYD		SARANKUL	14062206	11 KV SIKHARPUR	RURAL	AMI	0.582177	0.582177	0.398691	31.52%	37.16%	100%	
217	TPCODL	BBSR-02	NYD		ODOGAON	14063201	11 KV BAHADAJHOLA	RURAL	AMI	1.387948	1.387948	1.057625	23.80%	32.82%	100%	
218	TPCODL	BBSR-02	NYD		ODOGAON	14063202	11 KV KOMANDA	RURAL	AMI	0.811720	0.811720	0.625067	22.99%	34.22%	100%	
219	TPCODL	BBSR-02	NYD		ODOGAON	14063203	11 KV ODOGAON-1	RURAL	AMI	0.630676	0.630676	0.488401	22.56%	25.97%	100%	
220	TPCODL	BBSR-02	NYD		ODOGAON	14063204	11 KV ODOGAON-2	RURAL	AMI	2.391287	2.391287	1.773234	25.85%	29.22%	100%	
221	TPCODL	BBSR-02	NYD		ODOGAON	14063205	11 KV AMBARPUR	RURAL	AMI	0.671221	0.671221	0.521000	22.38%	29.31%	100%	
222	TPCODL	BBSR-02	NYD		ODOGAON	14063206	11 KV NANDIGHOR	RURAL	AMI	1.257120	1.257120	0.922428	26.62%	36.51%	100%	
223	TPCODL	BBSR-02	PED		TALABANIA	14064201	11 KV 11kV Sri Mandira	RURAL	AMI	1.892802	1.892802	1.747785	7.66%	21.45%	33%	
224	TPCODL	BBSR-02	PED		TALABANIA	14064202	11 KV 11kV Sri Gundich	RURAL	AMI	1.415872	1.415872	1.050907	25.78%	33.96%	33%	
225	TPCODL	BBSR-02	PED		TALABANIA	14064205	11 KV 11kV Kacheri	RURAL	AMI	3.605132	3.605132	2.654752	26.36%	36.63%	100%	
226	TPCODL	BBSR-02	PED		TALABANIA	14064206	11 KV MAUSIMA U/G	RURAL	AMI	5.023880	5.023880	1.819885	63.78%	68.31%	100%	
227	TPCODL	BBSR-02	PED		TALABANIA	14064207	11kV Medical	RURAL	AMI	0.618724	0.618724	0.613785	0.80%	13.95%	100%	
228	TPCODL	BBSR-02	PED		TALABANIA	14064208	11 KV Talabania- Sri Ma	RURAL	AMI	7.421880	7.421880	6.264386	15.60%	27.68%	100%	
229	TPCODL	BBSR-02	PED		TALABANIA	14064209	11 KV 11kV Raj Bhavar	RURAL	AMI	5.063284	5.063284	2.630225	48.05%	56.60%	100%	
230	TPCODL	BBSR-02	PED		KACHERI	14065201	11 KV 11kV Swargadwa	RURAL	AMI	2.522088	2.522088	2.265778	10.16%	27.27%	100%	
231	TPCODL	BBSR-02	PED		KACHERI	14065202	11 KV Swargadwar-2	RURAL	AMI	6.748004	6.748004	5.583126	17.26%	30.84%	100%	
232	TPCODL	BBSR-02	PED		KACHERI	14065203	11 KV DOLAMANDAP	RURAL	AMI	2.711898	2.711898	1.487920	45.13%	54.00%	100%	
233	TPCODL	BBSR-02	PED		KACHERI	14065204	11 KV 11kV Duttatota	RURAL	AMI	5.036400	5.036400	4.061369	19.36%	23.91%	100%	
234	TPCODL	BBSR-02	PED		KACHERI	14065206	11 KV 11kV Sea Beach	RURAL	AMI	2.317200	2.317200	1.672510	27.82%	45.78%	100%	
235	TPCODL	BBSR-02	PED		BALIAPANDA	14066201	11 KV 11kV Lokanath	RURAL	AMI	6.563920	6.563920	3.804967	42.03%	48.87%	100%	
236	TPCODL	BBSR-02	PED		BALIAPANDA	14066202	11 KV BALIAPANDA KA	RURAL	AMI	6.200400	6.200400	4.508362	27.29%	38.96%	100%	
237	TPCODL	BBSR-02	PED		BALIAPANDA	14066203	11 KV 11kV Baliapanda	RURAL	AMI	0.797820	0.797820	0.626848	21.43%	35.18%	100%	
238	TPCODL	BBSR-02	PED		BALIAPANDA	14066205	11 KV Baliapanda - Sri I	RURAL	AMI	6.055068	6.055068	3.258374	46.19%	57.20%	100%	
239	TPCODL	BBSR-02	PED		BALIAPANDA	14066206	11 KV 11kV Prachi UG	RURAL	AMI	2.858946	2.858946	2.687362	6.00%	20.55%	100%	
240	TPCODL	BBSR-02	PED		CHARINALA	14067201	11 KV M M NAGAR	RURAL	AMI	1.836846	1.836846	1.188105	35.32%	43.83%	100%	
241	TPCODL	BBSR-02	PED		BRAHMAGIRI	14068204	11 KV BASUDEIPUR	RURAL	AMI	1.527765	1.527765	0.823733	46.08%	68.50%	100%	
242	TPCODL	BBSR-02	PED		SUNAMUHIN	14069201	11 KV BRAHMAGIRI	RURAL	AMI	3.730104	3.730104	0.899316	75.89%	75.22%	100%	
243	TPCODL	BBSR-02	PED		SUNAMUHIN	14069203	11 KV SATAPADA	RURAL	AMI	1.069748	1.069748	0.718072	32.87%	53.46%	100%	
244	TPCODL	BBSR-02	PED		SRI RAM NAGAR	14070201	11 KV 11kV PKRIT	RURAL	AMI	5.528092	5.528092	4.031058	27.08%	30.74%	100%	
245	TPCODL	BBSR-02	PED		SRI RAM NAGAR	14070202	11 KV 11kV Baliguali	RURAL	AMI	3.932904	3.932904	2.623864	33.28%	44.33%	100%	
246	TPCODL	BBSR-02	PED		SRI RAM NAGAR	14070204	11 KV 11kV Toshali	RURAL	AMI	2.751966	2.751966	2.104348	23.53%	36.67%	100%	
247	TPCODL	BBSR-02	PED		CHANDANPUR	14071201	11 KV CHANDANPUR	RURAL	AMI	1.705559	1.705559	1.228371	27.98%	46.03%	100%	
248	TPCODL	BBSR-02	PED		CHANDANPUR	14071202	11 KV BIRANARSINGH	RURAL	AMI	4.626860	4.626860	2.862055	38.14%	51.50%	100%	
249	TPCODL	BBSR-02	PED		CHANDANPUR	14071203	11 KV BALABHADRAPI	RURAL	AMI	1.812846	1.812846	1.150668	36.53%	48.27%	100%	
250	TPCODL	BBSR-02	PED		SAKHIGOPAL	14072203	11 KV SARANGAJODI	RURAL	AMI	2.139370	2.139370	1.563054	26.94%	52.91%	100%	

Sl No.	Zone	Received at Circle (In MU)	Received at Division (In MU)	Received at Sub-division (In MU)	Name of the Station	Feeder Code/ID	Feeder Name	Type of Feeder (Urban/Mixed/Industrial/Agricultural/Rural)	Type of feeder meter (AMI/AMR/Other)	Received at Feeder (Final in MU)	Feeder Consumption (In MU)	Final Net Export at Feeder Level (In MU)	T&D losses	AT&C losses	% Data Received through Automatically (if feeder AMR/AMI)	Remarks
251	TPCODL	BBSR-02	PED		SAKHIGOPAL	14072204	11 KV SAKHIGOPALA	RURAL	AMI	3.819594	3.819594	2.789349	26.97%	32.07%	100%	
252	TPCODL	BBSR-02	PED		DELANGA	14073201	11 KV DELANGA	RURAL	AMI	5.163470	5.163470	2.363795	54.22%	68.20%	100%	
253	TPCODL	BBSR-02	PED		DELANGA	14073202	11 KV GHORADIA	RURAL	AMI	2.572920	2.572920	1.650424	35.85%	52.23%	100%	
254	TPCODL	BBSR-02	PED		KANASA	14074201	11 KV KANASA	RURAL	AMI	2.610358	2.610358	1.653570	36.65%	49.58%	100%	
255	TPCODL	BBSR-02	PED		KANASA	14074202	11 KV KARAMALA	RURAL	AMI	1.330000	1.330000	1.285208	3.37%	30.79%	100%	
256	TPCODL	BBSR-02	PED		KANASA	14074203	11 KV JAGANNATHPU	RURAL	AMI	1.441006	1.441006	1.109320	23.02%	39.82%	100%	
257	TPCODL	BBSR-02	BAED		BALUGAON	14075202	11 KV BANPUR-1	RURAL	AMI	2.927860	2.927860	1.680432	42.61%	47.39%	100%	
258	TPCODL	BBSR-02	BAED		BALUGAON	14075203	11 KV BANPUR-2	RURAL	AMI	5.922872	5.922872	4.474093	24.46%	34.27%	100%	
259	TPCODL	BBSR-02	BAED		TANGI	14076201	11 KV BADAPARI	RURAL	AMI	2.529276	2.529276	1.902222	24.79%	35.20%	100%	
260	TPCODL	BBSR-02	BAED		TANGI	14076202	11 KV TANGI CHANDA	RURAL	AMI	1.568794	1.568794	1.525142	2.78%	17.81%	100%	
261	TPCODL	BBSR-02	BAED		TANGI	14076203	11 KV KALUPADA	RURAL	AMI	5.660248	5.660248	4.027982	28.84%	39.18%	100%	
262	TPCODL	BBSR-02	BAED		RANAPUR	14077202	11 KV RANAPUR	RURAL	AMI	2.832628	2.832628	1.946757	31.27%	42.84%	100%	
263	TPCODL	BBSR-02	BAED		RANAPUR	14077203	11 KV RE	RURAL	AMI	2.737344	2.737344	1.817588	33.60%	44.63%	100%	
264	TPCODL	BBSR-02	BAED		RANAPUR	14077204	11 KV HANSARA	RURAL	AMI	0.603708	0.603708	0.505239	16.31%	30.29%	33%	
265	TPCODL	BBSR-02	BAED		NACHUNI	14078201	11 KV KAITHAPALLA	RURAL	AMI	1.028869	1.028869	0.835027	18.84%	29.01%	100%	
266	TPCODL	BBSR-02	BAED		NACHUNI	14078202	11 KV GAMBHARIMUN	RURAL	AMI	1.908472	1.908472	1.568237	17.83%	27.60%	100%	
267	TPCODL	BBSR-02	BAED		NACHUNI	14078203	11 KV NAIRI	RURAL	AMI	1.374986	1.374986	0.880392	35.97%	46.28%	100%	
268	TPCODL	CUTTACK	CDD-1		CDA	14080201	11 KV SATICHOURA	URBAN	AMI	1.857744	1.857744	1.723154	7.24%	8.66%	100%	
269	TPCODL	CUTTACK	CDD-1		CDA	14080202	11 KV SECTOR 6,7	URBAN	AMI	5.784500	5.784500	4.509027	22.05%	21.17%	100%	
270	TPCODL	CUTTACK	CDD-1		CDA	14080203	11 KV SECTOR 9	URBAN	AMI	4.145920	4.145920	3.373670	18.63%	17.68%	100%	
271	TPCODL	CUTTACK	CDD-1		CDA	14080204	11 KV SECTOR 8	URBAN	AMI	2.405308	2.405308	1.656204	31.14%	27.96%	100%	
272	TPCODL	CUTTACK	CDD-1		SISHUBHABAN	14081201	11 KV HIGH COURT	URBAN	AMI	2.677534	2.677534	1.857636	30.62%	34.07%	100%	
273	TPCODL	CUTTACK	CDD-1		SISHUBHABAN	14081203	11 KV Chandini Chowk	URBAN	AMI	6.043960	6.043960	4.707068	22.12%	18.41%	100%	
274	TPCODL	CUTTACK	CDD-1		JOBRA	14082202	11 KV RAILWAY	URBAN	AMI	4.230936	4.230936	3.957513	6.46%	9.68%	100%	
275	TPCODL	CUTTACK	CDD-1		JOBRA	14082203	11 KV RAVENSHAW	URBAN	AMI	2.561800	2.561800	1.970182	23.09%	25.82%	67%	
276	TPCODL	CUTTACK	CDD-1		JOBRA	14082204	11 KV JOBRA BARRAC	URBAN	AMI	3.318816	3.318816	2.656916	19.94%	19.90%	100%	
277	TPCODL	CUTTACK	CDD-1		JOBRA	14082205	11 KV MATAMATHA	URBAN	AMI	3.188504	3.188504	2.679541	15.96%	17.81%	100%	
278	TPCODL	CUTTACK	CDD-1		JOBRA	14082206	11 KV COLLEGE SQ. U	URBAN	AMI	3.127600	3.127600	2.343870	25.06%	27.36%	100%	
279	TPCODL	CUTTACK	CDD-1		MEDICAL	14083203	11 KV MANGALABAG	URBAN	AMI	2.716140	2.716140	2.314186	14.80%	14.34%	100%	
280	TPCODL	CUTTACK	CDD-1		MEDICAL	14083204	11 KV MEDICAL-1	URBAN	AMI	2.359448	2.359448	2.224438	5.72%	31.59%	100%	
281	TPCODL	CUTTACK	CDD-1		KALINGA	14084201	11 KV CHOUDHURY B	URBAN	AMI	5.259232	5.259232	4.785012	9.02%	11.75%	100%	
282	TPCODL	CUTTACK	CDD-1		KALINGA	14084203	11 KV CANTONMENT 2	URBAN	AMI	3.246348	3.246348	2.920741	10.03%	11.04%	100%	
283	TPCODL	CUTTACK	CDD-1		KALINGA	14084204	11 KV GORAKABAR	URBAN	AMI	2.514774	2.514774	1.721793	31.53%	30.40%	100%	
284	TPCODL	CUTTACK	CDD-1		KALINGA	14084205	11 KV JNI Stadium	URBAN	AMI	0.175902	0.175902	0.170116	3.29%	46.08%	100%	
285	TPCODL	CUTTACK	CDD-1		KALINGA	14084209	11 KV DD OH	URBAN	AMI	2.044028	2.044028	1.708632	16.41%	15.53%	100%	
286	TPCODL	CUTTACK	CDD-1		KALINGA	14084210	11 KV SRI VIHAR	URBAN	AMI	0.846798	0.846798	0.516001	39.06%	40.89%	100%	
287	TPCODL	CUTTACK	CDD-1		KALINGA	14084212	11 KV UPPER GROUN	URBAN	AMI	1.286944	1.286944	0.695297	45.97%	50.16%	100%	
288	TPCODL	CUTTACK	CDD-1		KALINGA	14084213	11 KV CHANDI MANDII	URBAN	AMI	1.962028	1.962028	1.324993	32.47%	29.86%	33%	
289	TPCODL	CUTTACK	CDD-1		KALINGA	14084215	11KV SUTAHAT UG FE	URBAN	AMI	3.411996	3.411996	2.139430	37.30%	32.33%	100%	
290	TPCODL	CUTTACK	CDD-1		BIDANASI	14085202	11 KV BIDANASI-1	URBAN	AMI	2.352102	2.352102	1.628634	30.76%	28.96%	67%	
291	TPCODL	CUTTACK	CDD-1		BIDANASI	14085204	11 KV TULASIPUR	URBAN	AMI	3.913508	3.913508	2.650329	32.28%	32.91%	100%	
292	TPCODL	CUTTACK	CDD-1		BIDANASI	14085205	11 KV BIDANASI -2	URBAN	AMI	2.426364	2.426364	2.198199	9.40%	9.04%	67%	
293	TPCODL	CUTTACK	CDD-1		JAIL	14086201	11 KV HATIPOKHARI	URBAN	AMI	3.293848	3.293848	2.673754	18.83%	18.57%	100%	
294	TPCODL	CUTTACK	CDD-1		JAIL	14086203	11 KV CITY	URBAN	AMI	4.314376	4.314376	2.789050	35.35%	36.46%	67%	
295	TPCODL	CUTTACK	CDD-2		BADAMBADI	14087204	11 KV BADAMBADI-2	URBAN	AMI	7.487572	7.487572	4.397609	41.27%	40.33%	100%	
296	TPCODL	CUTTACK	CDD-2		BADAMBADI	14087205	11 KV Badambadi-Kalya	URBAN	AMI	4.336856	4.336856	3.037176	29.97%	34.66%	100%	
297	TPCODL	CUTTACK	CDD-2		JAGATPUR	14088201	11 KV IDCO	URBAN	AMI	2.859540	2.859540	2.672285	6.55%	21.69%	100%	
298	TPCODL	CUTTACK	CDD-2		JAGATPUR	14088202	11 KV BARRAGE	URBAN	AMI	2.825704	2.825704	2.336600	17.31%	25.41%	100%	
299	TPCODL	CUTTACK	CDD-2		JAGATPUR	14088204	11 KV OLD INDUSTRIA	URBAN	AMI	7.855664	7.855664	5.897138	24.93%	32.36%	67%	
300	TPCODL	CUTTACK	CDD-2		KALYANI NAGAR	14089201	11 KV KALYANI NAGAI	URBAN	AMI	5.472420	5.472420	5.035829	7.98%	7.87%	100%	
301	TPCODL	CUTTACK	CDD-2		KALYANI NAGAR	14089202	11 KV MAHANADI	URBAN	AMI	1.064296	1.064296	0.846908	20.43%	27.28%	100%	
302	TPCODL	CUTTACK	CDD-2		KALYANI NAGAR	14089206	11 KV CHAULIAGANJ-2	URBAN	AMI	2.906784	2.906784	1.925571	33.76%	39.13%	100%	
303	TPCODL	CUTTACK	CDD-2		OGP	14090201	11 KV INDUSTRIAL-1	URBAN	AMI	4.359624	4.359624	4.031670	7.52%	18.81%	100%	
304	TPCODL	CUTTACK	CDD-2		OGP	14090202	11 KV INDUSTRIAL-2	URBAN	AMI	4.115375	4.115375	2.627307	36.16%	34.81%	100%	
305	TPCODL	CUTTACK	CDD-2		OGP	14090205	GOSALA	URBAN	AMI	4.684596	4.684596	3.624480	22.63%	21.70%	100%	
306	TPCODL	CUTTACK	CDD-2		CRRI	14091202	11 KV MAHANADI VIHA	URBAN	AMI	3.325492	3.325492	2.119116	36.28%	39.64%	100%	
307	TPCODL	CUTTACK	CDD-2		CRRI	14091204	11 KV NAYABAZAR	URBAN	AMI	3.905352	3.905352	3.389824	13.20%	14.68%	100%	
308	TPCODL	CUTTACK	CDD-2		42 MAUZA	14092201	11 KV CHANDULI	URBAN	AMI	1.840226	1.840226	1.284925	30.18%	41.99%	100%	
309	TPCODL	CUTTACK	CDD-2		42 MAUZA	14092202	11 KV BENTKAR	URBAN	AMI	3.180930	3.180930	2.971432	6.59%	15.24%	100%	
310	TPCODL	CUTTACK	CDD-2		42 MAUZA	14092203	11 KV JHINKIRIA	URBAN	AMI	1.509924	1.509924	1.026236	32.03%	39.07%	100%	
311	TPCODL	CUTTACK	CDD-2		KANDARPUR	14093201	11 KV ALL INDIA RADI	URBAN	AMI	2.040368	2.040368	1.720734	15.67%	20.93%	100%	
312	TPCODL	CUTTACK	CDD-2		KANDARPUR	14093204	11 KV AYATPUR	URBAN	AMI	1.137288	1.137288	1.023443	10.01%	22.32%	100%	
313	TPCODL	CUTTACK	CDD-2		KISHAN NAGAR	14094201	11 KV KISHANNAGAR	URBAN	AMI	0.377500	0.377500	0.354529	6.09%	22.94%	100%	
314	TPCODL	CUTTACK	CDD-2		KISHAN NAGAR	14094202	11 KV MALIPUR	URBAN	AMI	0.337042	0.337042	0.298230	11.52%	18.79%	33%	
315	TPCODL	CUTTACK	CDD-2		KISHAN NAGAR	14094203	11 KV SOMAPUR - II	URBAN	AMI	0.046310	0.046310	0.034256	26.03%	37.61%	100%	
316	TPCODL	CUTTACK	CDD-2		KISHAN NAGAR	14094204	11 KV RAMCHANDRAF	URBAN	AMI	0.482849	0.482849	0.348873	27.75%	33.70%	100%	
317	TPCODL	CUTTACK	CDD-2		KISHAN NAGAR	14094205	11 KV BISWALAPADA	URBAN	AMI	0.452841	0.452841	0.434834	3.98%	16.99%	33%	
318	TPCODL	CUTTACK	SED		SALIPUR	14095201	11 KV NAIGUAN	RURAL	AMI	3.338148	3.338148	2.416177	27.62%	37.16%	100%	
319	TPCODL	CUTTACK	SED		SALIPUR	14095202	11 KV KENDUPATNA	RURAL	AMI	2.741284	2.741284	1.640229	40.17%	48.67%	100%	
320	TPCODL	CUTTACK	SED		SALIPUR	14095204	11 KV CHHANIPUR	RURAL	AMI	3.194196	3.194196	2.434499	23.78%	38.45%	100%	
321	TPCODL	CUTTACK	SED		KOTAPADA	14096203	11 KV MULABASANTA	RURAL	AMI	1.298598	1.298598	0.805250	37.99%	47.42%	100%	
322	TPCODL	CUTTACK	SED		KOTAPADA	14096204	11 KV RWSS MADHUF	RURAL	AMI	0.198708	0.198708	0.154865	22.06%	100.11%	100%	
323	TPCODL	CUTTACK	SED		MAHANGA	14097201	11 KV MAHANGA	RURAL	AMI	2.837964	2.837964	1.792888	36.82%	46.72%	100%	
324	TPCODL	CUTTACK	SED		MAHANGA	14097202	11 KV KUANPALA	RURAL	AMI	1.880858	1.880858	1.081103	42.52%	52.84%	100%	
325	TPCODL	CUTTACK	SED		MAHANGA	14097203	11 KV CHAINPAL	RURAL	AMI	1.525644	1.525644	0.806253	47.15%	53.75%	100%	
326	TPCODL	CUTTACK	SED		BAHUGRAM-2	14098201	11 KV NANDOLA	RURAL	AMI	1.731606	1.731606	1.231554	28.88%	47.85%	100%	
327	TPCODL	CUTTACK	SED		BAHUGRAM-2	14098202	11 KV BAHUGRAM PAI	RURAL	AMI	6.295033	6.295033	3.808726	39.50%	49.99%	100%	
328	TPCODL	CUTTACK	SED		BAHUGRAM-2	14098204	11 KV PATAPUR	RURAL	AMI	2.202351	2.202351	1.346523	38.86%	53.44%	100%	
329	TPCODL	CUTTACK	SED		NISCHINTAKOILI	14099201	11 KV UMARA	RURAL	AMI	2.015312	2.015312	1.451480	27.98%	37.61%	100%	
330	TPCODL	CUTTACK	SED		NISCHINTAKOILI	14099202	11 KV BUHALA	RURAL	AMI	0.599836	0.599836	0.425226	29.11%	38.70%	100%	
331	TPCODL	CUTTACK	SED		NISCHINTAKOILI	14099203	11 KV RAMAKRUSNAF	RURAL	AMI	2.404694	2.404694	1.782020	25.89%	37.21%	100%	
332	TPCODL	CUTTACK	SED		PALADHUAPADIA	14100202	11 KV KHANDASAHI	RURAL	AMI	0.948544	0.948544	0.595861	37.18%	45.44%	100%	
333	TPCODL	CUTTACK	CED		DAMODARPUR	14101201	11 KV GOBINDPUR	RURAL	AMI	2.236740	2.236740	1.354988	39.42%	49.62%	100%	
334	TPCODL	CUTTACK	CED		DAMODARPUR	14101202	11 KV SUNDERGRAM	RURAL	AMI	3.314888	3.314888	2.501288	24.54%	32.55%	100%	

Sl No.	Zone	Received at Circle (In MU)	Received at Division (In MU)	Received at Sub-division (In MU)	Name of the Station	Feeder Code/ID	Feeder Name	Type of Feeder (Urban/Mixed/Industrial/Agricultural/Rural)	Type of feeder meter (AMI/AMR/Other)	Received at Feeder (Final in MU)	Feeder Consumption (In MU)	Final Net Export at Feeder Level (In MU)	T&D losses	AT&C losses	% Data Received through Automatically (if feeder AMR/AMI)	Remarks
335	TPCODL	CUTTACK	CED		DAMODARPUR	14101204	11 KV KANTAPADA	RURAL	AMI	2.829179	2.829179	1.849421	34.63%	50.79%	100%	
336	TPCODL	CUTTACK	CED		BALIKUDA	14102201	11 KV 42 MOUZA	RURAL	AMI	5.653948	5.653948	3.830085	32.26%	45.46%	100%	
337	TPCODL	CUTTACK	CED		BALIKUDA	14102202	11 KV BARANGA	RURAL	AMI	1.657468	1.657468	1.336238	19.38%	31.93%	100%	
338	TPCODL	CUTTACK	CED		BALIKUDA	14102203	11 KV UTTAMPUR	RURAL	AMI	3.495192	3.495192	2.547179	27.12%	38.19%	100%	
339	TPCODL	CUTTACK	CED		CHHATISIA	14103202	11 KV INDUSTRIAL	RURAL	AMI	2.184821	2.184821	2.092878	4.21%	7.65%	100%	
340	TPCODL	CUTTACK	CED		CHHATISIA	14103203	11 KV KUSPANGI	RURAL	AMI	2.631025	2.631025	1.850378	29.67%	36.45%	67%	
341	TPCODL	CUTTACK	CED		ADASPUR	14104201	11 KV ADASPUR	RURAL	AMI	3.795660	3.795660	2.070788	45.44%	57.34%	100%	
342	TPCODL	CUTTACK	CED		BADACHANA	14105205	11 KV DEULAPUR (LO	RURAL	AMI	1.205336	1.205336	0.634794	47.33%	61.86%	100%	
343	TPCODL	CUTTACK	CED		NIALI	14106201	11 KV KALIAGHAI	RURAL	AMI	1.791830	1.791830	1.644486	8.22%	27.96%	100%	
344	TPCODL	CUTTACK	CED		NIALI	14106202	11 KV NIALI TOWN	RURAL	AMI	4.053420	4.053420	2.031171	49.89%	60.06%	100%	
345	TPCODL	CUTTACK	CED		NIALI	14106203	11 KV KAPASI	RURAL	AMI	1.773704	1.773704	0.988599	44.26%	54.83%	100%	
346	TPCODL	CUTTACK	CED		NIALI	14106204	11 KV TOLA	RURAL	AMI	3.725265	3.725265	1.334511	64.18%	72.54%	100%	
347	TPCODL	CUTTACK	CED		TANGI	14107201	11 KV HARIPUR	RURAL	AMI	3.340400	3.340400	3.187117	4.59%	18.88%	100%	
348	TPCODL	CUTTACK	CED		TANGI	14107202	11 kV BHATTIMUNDA	RURAL	AMI	4.448948	4.448948	3.027172	31.96%	44.48%	100%	
349	TPCODL	CUTTACK	CED		TANGI	14107203	11 KV MANGULI	RURAL	AMI	4.041256	4.041256	4.014229	0.67%	2.36%	100%	
350	TPCODL	CUTTACK	CED		CHHATIA	14108201	11 KV CHHATIA	RURAL	AMI	3.541156	3.541156	1.320365	62.71%	68.22%	100%	
351	TPCODL	CUTTACK	CED		BALICHANDRAPUR	14109201	11 KV BALICHANDRAF	RURAL	AMI	2.197272	2.197272	1.163874	47.03%	57.63%	100%	
352	TPCODL	CUTTACK	CED		BALICHANDRAPUR	14109202	11 KV CHARINANGALA	RURAL	AMI	3.497455	3.497455	1.805070	48.39%	55.76%	100%	
353	TPCODL	CUTTACK	CED		BALICHANDRAPUR	14109203	11 KV RUKUTIPATA	RURAL	AMI	1.386068	1.386068	0.782212	43.57%	54.45%	100%	
354	TPCODL	CUTTACK	CED		BALICHANDRAPUR	14109205	11 KV BANDARESWAF	RURAL	AMI	3.492548	3.492548	1.942176	44.39%	52.52%	100%	
355	TPCODL	CUTTACK	AED		BADAMBA	14110201	11 KV GOPAMATHURA	RURAL	AMI	0.726344	0.726344	0.547124	24.67%	32.37%	67%	
356	TPCODL	CUTTACK	AED		BADAMBA	14110202	11 KV BADAMBA TOW	RURAL	AMI	2.508623	2.508623	0.826572	67.05%	69.91%	100%	
357	TPCODL	CUTTACK	AED		BADAMBA	14110203	11 KV RATAPATA	RURAL	AMI	1.058772	1.058772	0.938754	11.34%	34.73%	100%	
358	TPCODL	CUTTACK	AED		BADAMBA	14110204	11 KV RAGADIPADA	RURAL	AMI	0.926605	0.926605	0.473876	48.86%	58.93%	100%	
359	TPCODL	CUTTACK	AED		KANPUR / KANDHABERIN	14111202	11 KV KANPUR	RURAL	AMI	1.952278	1.952278	1.252972	35.82%	40.17%	100%	
360	TPCODL	CUTTACK	AED		KANPUR / KANDHABERIN	14111204	11 KV GODIBANDHA	RURAL	AMI	0.696894	0.696894	0.501315	28.06%	30.63%	100%	
361	TPCODL	CUTTACK	AED		KANPUR / KANDHABERIN	14111205	11 KV BASALIHATA	RURAL	AMI	1.118883	1.118883	0.561752	49.79%	55.54%	100%	
362	TPCODL	CUTTACK	AED		KANPUR / KANDHABERIN	14111206	11 KV KARILO & BAGA	RURAL	AMI	2.468148	2.468148	1.641105	33.51%	37.04%	100%	
363	TPCODL	CUTTACK	AED		NARSINGHPUR	14112201	11 KV NUKHAPADA	RURAL	AMI	2.015712	2.015712	1.123813	44.25%	48.73%	100%	
364	TPCODL	CUTTACK	AED		NARSINGHPUR	14112202	11 KV KAKUDIA (NARA	RURAL	AMI	1.503472	1.503472	1.054251	29.88%	46.96%	100%	
365	TPCODL	CUTTACK	AED		NARSINGHPUR	14112203	11 KV NARSINGHPUR	RURAL	AMI	1.960238	1.960238	1.635546	16.56%	30.68%	100%	
366	TPCODL	CUTTACK	AED		NARANGABASTA	14113201	11 KV NARANGABAST	RURAL	AMI	3.233753	3.233753	1.334293	58.74%	63.88%	100%	
367	TPCODL	CUTTACK	AED		NUAPATANA	14114202	11 KV MANIABANDHA	RURAL	AMI	2.660686	2.660686	1.969201	25.99%	35.24%	100%	
368	TPCODL	CUTTACK	AED		TIGIRIA	14115201	11 KV BINDHANIMA	RURAL	AMI	3.038559	3.038559	0.897861	70.45%	74.91%	100%	
369	TPCODL	CUTTACK	AED		TIGIRIA	14115203	11 KV TIGIRIA	RURAL	AMI	0.648921	0.648921	0.466847	28.06%	44.10%	100%	
370	TPCODL	CUTTACK	AED		TIGIRIA	14115204	11 KV PURUNA TIGIRI	RURAL	AMI	1.146488	1.146488	0.692967	39.56%	45.83%	100%	
371	TPCODL	CUTTACK	AED		ATHAGARH	14116201	11 KV ATHAGARH TOV	RURAL	AMI	7.510604	7.510604	3.980491	47.00%	53.40%	100%	
372	TPCODL	CUTTACK	AED		ATHAGARH	14116202	11 KV KARIKOLA	RURAL	AMI	4.085516	4.085516	2.006711	50.88%	55.51%	100%	
373	TPCODL	CUTTACK	AED		ATHAGARH	14116206	11 KV DHAIPUR	RURAL	AMI	1.298506	1.298506	0.915491	29.50%	43.87%	100%	
374	TPCODL	CUTTACK	AED		KHUNTUNI	14117201	11 KV GURUDIJHATIA	RURAL	AMI	1.328464	1.328464	1.144941	13.81%	17.70%	100%	
375	TPCODL	CUTTACK	AED		KHUNTUNI	14117202	11 KV KULEILO	RURAL	AMI	2.950851	2.950851	1.702087	42.32%	50.49%	100%	
376	TPCODL	CUTTACK	AED		KHUNTUNI	14117203	11 KV MAHALAXMIPUF	RURAL	AMI	2.232268	2.232268	1.579711	29.23%	21.65%	100%	
377	TPCODL	DHENKANAL	DED		DHENKANAL COLLEGE	14118201	11 KV DKL TOWN-1	RURAL	AMI	3.569980	3.569980	3.269602	8.41%	28.13%	100%	
378	TPCODL	DHENKANAL	DED		DHENKANAL COLLEGE	14118203	11 KV GOVINDPUR(DH	RURAL	AMI	3.107699	3.107699	2.164993	30.33%	41.91%	100%	
379	TPCODL	DHENKANAL	DED		DHENKANAL COLLEGE	14118204	11 KV JORANDA	RURAL	AMI	2.874772	2.874772	1.907229	33.66%	46.20%	100%	
380	TPCODL	DHENKANAL	DED		DHENKANAL COLLEGE	14118205	11 KV SAPTASAJYA	RURAL	AMI	2.890400	2.890400	2.130165	26.30%	30.71%	100%	
381	TPCODL	DHENKANAL	DED		DHENKANAL COLLEGE	14118206	11 KV GUDIANALI	RURAL	AMI	5.177172	5.177172	3.459527	33.18%	47.46%	100%	
382	TPCODL	DHENKANAL	DED		BHAPUR	14119202	11 KV GHATIPIRI	RURAL	AMI	0.693930	0.693930	0.512262	26.18%	42.17%	100%	
383	TPCODL	DHENKANAL	DED		BHAPUR	14119203	11 KV Lambodarpur	RURAL	AMI	0.403258	0.403258	0.244820	39.29%	46.96%	67%	
384	TPCODL	DHENKANAL	DED		GONDIA	14120201	11 KV MANDAR	RURAL	AMI	0.921914	0.921914	0.688149	25.36%	35.30%	100%	
385	TPCODL	DHENKANAL	DED		GONDIA	14120202	11 KV KAPILASH	RURAL	AMI	1.814200	1.814200	1.237156	31.81%	49.55%	100%	
386	TPCODL	DHENKANAL	DED		GONDIA	14120203	11 KV GONDIA	RURAL	AMI	1.138273	1.138273	0.907697	20.26%	39.77%	100%	
387	TPCODL	DHENKANAL	DED		GONDIA	14120205	11 KV PASUPATI	RURAL	AMI	0.661772	0.661772	0.576267	12.92%	43.69%	100%	
388	TPCODL	DHENKANAL	DED		HINDOL ROAD	14121201	11 KV TOWN (H.ROAD	RURAL	AMI	1.689342	1.689342	1.372890	18.73%	42.12%	100%	
389	TPCODL	DHENKANAL	DED		HINDOL ROAD	14121202	11 KV NIMIDHA	RURAL	AMI	4.037860	4.037860	2.488287	38.38%	44.35%	100%	
390	TPCODL	DHENKANAL	DED		HINDOL ROAD	14121203	11 KV BADALO	RURAL	AMI	5.216000	5.216000	4.391752	15.80%	17.40%	100%	
391	TPCODL	DHENKANAL	DED		HINDOL ROAD	14121204	11 KV 4 POLE	RURAL	AMI	2.982268	2.982268	1.542481	48.28%	55.27%	100%	
392	TPCODL	DHENKANAL	DED		KHAJURIAKATA	14122202	11 KV Bedapada-1	RURAL	AMI	3.061215	3.061215	2.131226	30.38%	45.69%	67%	
393	TPCODL	DHENKANAL	DED		KHAJURIAKATA	14122203	11 KV KALINGA	RURAL	AMI	1.132689	1.132689	0.868713	23.31%	37.31%	100%	
394	TPCODL	DHENKANAL	DED		HINDOL	14123201	11 KV Hindol	RURAL	AMI	3.511364	3.511364	2.087789	40.54%	57.08%	67%	
395	TPCODL	DHENKANAL	DED		HINDOL	14123202	11 KV Dudurkot	RURAL	AMI	0.409500	0.409500	0.279271	31.80%	62.86%	100%	
396	TPCODL	DHENKANAL	DED		KAMAKHYANAGAR	14124201	11 KV TOWN-1 (K.Ngr)	RURAL	AMI	4.157456	4.157456	1.907226	54.13%	60.79%	100%	
397	TPCODL	DHENKANAL	DED		KAMAKHYANAGAR	14124203	11 KV GUNDICHANALI	RURAL	AMI	0.205620	0.205620	0.146153	28.92%	63.91%	100%	
398	TPCODL	DHENKANAL	DED		BADASUANLA	14125201	11 KV GUNEIBILLI	RURAL	AMI	0.255668	0.255668	0.166799	34.76%	55.62%	67%	
399	TPCODL	DHENKANAL	DED		BADASUANLA	14125202	11 KV BIRASAL	RURAL	AMI	0.546914	0.546914	0.350940	35.83%	48.72%	100%	
400	TPCODL	DHENKANAL	DED		MATHAKARAGOLA	14126202	11 KV BELEISAHI	RURAL	AMI	0.704692	0.704692	0.509061	27.76%	33.87%	100%	
401	TPCODL	DHENKANAL	DED		MATHAKARAGOLA	14126204	11 KV MARTHAPUR	RURAL	AMI	0.910812	0.910812	0.592829	34.91%	44.31%	100%	
402	TPCODL	DHENKANAL	DED		DAHANABIL	14127202	11 KV KANHEIPAL	RURAL	AMI	0.666400	0.666400	0.476979	28.42%	43.46%	100%	
403	TPCODL	DHENKANAL	DED		BHUBAN	14129204	11 KV Anantpur	RURAL	AMI	0.873882	0.873882	0.538919	38.33%	52.86%	100%	
404	TPCODL	DHENKANAL	DED		BHUBAN	14129205	11 KV PADAN	RURAL	AMI	0.059311	0.059311	0.042783	27.87%	56.07%	100%	
405	TPCODL	DHENKANAL	DED		KALIAPANI	14130201	11 KV BAZAR (TISCO)	RURAL	AMI	0.833280	0.833280	0.572553	31.29%	55.39%	100%	
406	TPCODL	DHENKANAL	DED		KALIAPANI	14130202	11 KV CHINGUDIPALA	RURAL	AMI	0.402855	0.402855	0.256010	36.45%	38.64%	100%	
407	TPCODL	DHENKANAL	DED		KALIAPANI	14130203	11 KV KALIAPANI KAN	RURAL	AMI	0.569780	0.569780	0.396512	30.41%	35.74%	100%	
408	TPCODL	DHENKANAL	DED		GUNDICHAPADA	14131201	11 KV SIMINAI	RURAL	AMI	5.888420	5.888420	3.943679	33.03%	41.33%	100%	
409	TPCODL	DHENKANAL	DED		GUNDICHAPADA	14131202	11 KV Industrial (G.Pad	RURAL	AMI	1.571430	1.571430	1.373397	12.60%	16.18%	100%	
410	TPCODL	DHENKANAL	DED		GUNDICHAPADA	14131204	11 KV PHD (G.Pada)	RURAL	AMI	2.338962	2.338962	1.608630	31.22%	43.14%	100%	
411	TPCODL	DHENKANAL	DED		GUNDICHAPADA	14131205	11 KV Bhapur (G,Pada)	RURAL	AMI	4.409322	4.409322	2.253498	48.89%	54.75%	100%	
412	TPCODL	DHENKANAL	ANED		RCMS	14132201	11 KV HARIMAHURI	RURAL	AMI	3.606776	3.606776	2.490435	30.95%	40.40%	100%	
413	TPCODL	DHENKANAL	ANED		RCMS	14132202	11 KV AMALAPADA	RURAL	AMI	2.932816	2.932816	2.431673	17.09%	31.96%	100%	
414	TPCODL	DHENKANAL	ANED		RCMS	14132203	11 KV RCMS THANA	RURAL	AMI	2.741200	2.741200	1.955318	28.67%	35.33%	100%	
415	TPCODL	DHENKANAL	ANED		RCMS	14132204	11 KV RCMS RE-2	RURAL	AMI	4.178084	4.178084	3.077377	26.34%	38.57%	100%	
416	TPCODL	DHENKANAL	ANED		RCMS	14132206	11 kV RCMS BAZAR	RURAL	AMI	3.350920	3.350920	2.610641	22.09%	31.54%	100%	
417	TPCODL	DHENKANAL	ANED		RCMS	14132207	11 KV RCMS COLLEGI	RURAL	AMI	2.180800	2.180800	1.538397	29.46%	38.09%	33%	
418	TPCODL	DHENKANAL	ANED		RCMS	14132209	11 kV PTC	RURAL	AMI	4.414800	4.414800	3.861101	12.54%	24.72%	100%	

Sl No.	Zone	Received at Circle (In MU)	Received at Division (In MU)	Received at Sub-division (In MU)	Name of the Station	Feeder Code/ID	Feeder Name	Type of Feeder (Urban/Mixed/Industrial/Agricultural/Rural)	Type of feeder meter (AMI/AMR/Other)	Received at Feeder (Final in MU)	Feeder Consumption (In MU)	Final Net Export at Feeder Level (In MU)	T&D losses	AT&C losses	% Data Received through Automatically (if feeder AMR/AMI)	Remarks
419	TPCODL	DHENKANAL	ANED		INDUSTRIAL ESTATE	14133201	11 KV INDUSTRIAL FE	RURAL	AMI	3.509228	3.509228	2.863110	18.41%	28.42%	100%	
420	TPCODL	DHENKANAL	ANED		BANTALA	14134202	11 KV SABALABHANG	RURAL	AMI	1.423347	1.423347	1.048089	26.36%	40.79%	100%	
421	TPCODL	DHENKANAL	ANED		BANTALA	14134203	11 KV KHINDA	RURAL	AMI	2.246574	2.246574	1.450535	35.43%	45.67%	100%	
422	TPCODL	DHENKANAL	ANED		BANTALA	14134204	11 KV SARANGAPUR	RURAL	AMI	0.314294	0.314294	0.273393	13.01%	28.96%	67%	
423	TPCODL	DHENKANAL	ANED		JARPADA	14135201	11 KV KATADA	RURAL	AMI	0.805936	0.805936	0.571191	29.13%	39.79%	100%	
424	TPCODL	DHENKANAL	ANED		JARPADA	14135202	11 KV JAGANATHPUR	RURAL	AMI	1.105114	1.105114	0.784932	28.97%	53.96%	100%	
425	TPCODL	DHENKANAL	ANED		JARPADA	14135204	11 KV KANJAR	RURAL	AMI	1.626958	1.626958	1.065043	34.54%	43.97%	100%	
426	TPCODL	DHENKANAL	ANED		JARPADA	14135205	11 KV RAILWAY	RURAL	AMI	0.273160	0.273160	0.221720	18.83%	30.19%	100%	
427	TPCODL	DHENKANAL	ANED		CHHENDIPADA	14136202	11 KV BRAHMANABIL	RURAL	AMI	1.767795	1.767795	1.009236	42.91%	53.67%	100%	
428	TPCODL	DHENKANAL	ANED		CHHENDIPADA	14136203	11 KV BAHALSAHI	RURAL	AMI	1.261336	1.261336	0.866881	31.27%	48.32%	33%	
429	TPCODL	DHENKANAL	ANED		CHHENDIPADA	14136204	11 KV CHHENDIPADA	RURAL	AMI	1.497680	1.497680	1.024857	31.57%	18.89%	100%	
430	TPCODL	DHENKANAL	ANED		CHHENDIPADA	14136205	11 KV BAGEDIA	RURAL	AMI	3.465204	3.465204	2.108347	39.16%	54.46%	100%	
431	TPCODL	DHENKANAL	ANED		CHHENDIPADA	14136206	11 KV PIPALA BAHALA	RURAL	AMI	1.547620	1.547620	0.782245	49.46%	57.55%	100%	
432	TPCODL	DHENKANAL	ANED		BOINDA	14137201	11 KV BOINDA LOCAL	RURAL	AMI	1.352600	1.352600	0.980957	27.48%	35.40%	100%	
433	TPCODL	DHENKANAL	ANED		BOINDA	14137202	11 KV HANDPA	RURAL	AMI	1.889655	1.889655	1.282315	32.14%	36.91%	100%	
434	TPCODL	DHENKANAL	ANED		BOINDA	14137203	11 KV JAMUNALI	RURAL	AMI	0.425307	0.425307	0.306447	27.95%	36.04%	100%	
435	TPCODL	DHENKANAL	ANED		BOINDA	14137204	11 KV PAIKASAHI	RURAL	AMI	3.184210	3.184210	0.599735	81.17%	84.31%	100%	
436	TPCODL	DHENKANAL	ANED		BOINDA	14137206	11 KV SANAHULLA	RURAL	AMI	0.961421	0.961421	0.684547	28.80%	41.81%	100%	
437	TPCODL	DHENKANAL	ANED		ANANDAPUR	14138201	11 KV THAKURGARH	RURAL	AMI	1.115869	1.115869	0.730114	34.57%	51.33%	67%	
438	TPCODL	DHENKANAL	ANED		ANANDAPUR	14138202	11 KV KRUTIBASHPUF	RURAL	AMI	0.435640	0.435640	0.265181	39.13%	49.07%	67%	
439	TPCODL	DHENKANAL	ANED		ANANDAPUR	14138204	11 KV GHODABANDHU	RURAL	AMI	0.184634	0.184634	0.143718	22.16%	30.68%	100%	
440	TPCODL	DHENKANAL	ANED		ATHAMALIK	14139201	11 KV ATHAMALLIK TC	RURAL	AMI	3.167988	3.167988	1.998780	36.91%	48.57%	33%	
441	TPCODL	DHENKANAL	ANED		ATHAMALIK	14139202	11 KV MANTIRI	RURAL	AMI	0.443720	0.443720	0.355481	19.89%	49.63%	100%	
442	TPCODL	DHENKANAL	ANED		ATHAMALIK	14139203	11 KV JADPUR	RURAL	AMI	0.073159	0.073159	0.061159	16.40%	33.22%	100%	
443	TPCODL	DHENKANAL	ANED		ATHAMALIK	14139204	11 KV BINKEI	RURAL	AMI	0.663362	0.663362	0.478196	27.91%	45.27%	100%	
444	TPCODL	DHENKANAL	ANED		ATHAMALIK	14139205	11 KV BAGHUAKATA	RURAL	AMI	0.260348	0.260348	0.183124	29.66%	42.76%	100%	
445	TPCODL	DHENKANAL	ANED		MADHAPUR	14140201	11 KV MADHAPUR	RURAL	AMI	0.921559	0.921559	0.749886	18.63%	26.03%	100%	
446	TPCODL	DHENKANAL	ANED		MADHAPUR	14140202	11 KV KIAKATA	RURAL	AMI	2.034119	2.034119	1.438804	29.27%	42.60%	100%	
447	TPCODL	DHENKANAL	ANED		MADHAPUR	14140203	11 KV NILAKANTHAPA	RURAL	AMI	0.300389	0.300389	0.213478	28.93%	43.56%	100%	
448	TPCODL	DHENKANAL	ANED		MADHAPUR	14140204	11 KV LUNAHANDI	RURAL	AMI	0.402910	0.402910	0.281650	30.10%	41.00%	100%	
449	TPCODL	DHENKANAL	ANED		BAMUR	14141201	11 KV FASHIPAL	RURAL	AMI	0.441680	0.441680	0.305452	30.84%	45.00%	100%	
450	TPCODL	DHENKANAL	ANED		BAMUR	14141202	11 KV BRAHMANIDEI	RURAL	AMI	0.227713	0.227713	0.173948	23.61%	39.00%	100%	
451	TPCODL	DHENKANAL	ANED		BAMUR	14141203	11 KV KHAIRAMUNDA	RURAL	AMI	0.007355	0.007355	0.005250	28.62%	63.46%	100%	
452	TPCODL	DHENKANAL	TED		BANARPAL	14142201	11 KV CHAINPAL	RURAL	AMI	2.272826	2.272826	1.480569	34.86%	54.64%	100%	
453	TPCODL	DHENKANAL	TED		BANARPAL	14142202	11 KV KULAD	RURAL	AMI	6.118297	6.118297	3.588698	41.34%	49.13%	100%	
454	TPCODL	DHENKANAL	TED		BANARPAL	14142203	11 KV HINDOL	RURAL	AMI	3.918100	3.918100	2.319600	40.80%	50.97%	100%	
455	TPCODL	DHENKANAL	TED		BANARPAL	14142204	11 KV MERAMUNDALI	RURAL	AMI	2.924066	2.924066	1.739681	40.50%	47.93%	100%	
456	TPCODL	DHENKANAL	TED		PARJANG	14143204	11 KV Kualo (Parjang)	RURAL	AMI	0.754254	0.754254	0.424604	43.71%	55.71%	33%	
457	TPCODL	DHENKANAL	TED		PARJANG	14143205	11 KV Mahaveer Road	RURAL	AMI	0.999605	0.999605	0.643340	35.64%	46.99%	100%	
458	TPCODL	DHENKANAL	TED		PARJANG	14143206	11 KV Kandar Singha	RURAL	AMI	2.581556	2.581556	1.030959	60.06%	67.42%	100%	
459	TPCODL	DHENKANAL	TED		PARJANG	14143207	11 KV Saranga	RURAL	AMI	1.758860	1.758860	0.904158	48.59%	63.35%	100%	
460	TPCODL	DHENKANAL	TED		HATATOTA	14145202	11 KV Hatatota RE-2	RURAL	AMI	3.508147	3.508147	1.908342	45.60%	54.83%	100%	
461	TPCODL	DHENKANAL	TED		HATATOTA	14145203	11 KV Hatatota Town-1	RURAL	AMI	4.555140	4.555140	2.484454	45.46%	54.37%	100%	
462	TPCODL	DHENKANAL	TED		HATATOTA	14145206	11 KV GODIBANDHA	RURAL	AMI	3.220527	3.220527	1.863200	42.15%	56.01%	33%	
463	TPCODL	DHENKANAL	TED		BALANDA	14146201	11 KV GOBARA	RURAL	AMI	3.521348	3.521348	2.104274	40.24%	47.51%	100%	
464	TPCODL	DHENKANAL	TED		BALANDA	14146202	11 KV JAGANNATHPU	RURAL	AMI	2.362066	2.362066	1.606492	31.99%	41.07%	100%	
465	TPCODL	DHENKANAL	TED		BALANDA	14146203	11 KV GURUDWARA	RURAL	AMI	0.906628	0.906628	0.583695	35.62%	48.37%	100%	
466	TPCODL	DHENKANAL	TED		SAMAL	14147204	11 KV BARRAGE COL(	RURAL	AMI	0.424944	0.424944	0.226370	46.73%	54.38%	100%	
467	TPCODL	DHENKANAL	TED		KANIHA	14148201	11 KV KANIHA-1	RURAL	AMI	0.937649	0.937649	0.562333	40.03%	52.25%	100%	
468	TPCODL	DHENKANAL	TED		KANIHA	14148202	11 KV KANIHA RE-1	RURAL	AMI	0.572990	0.572990	0.326154	43.08%	62.70%	100%	
469	TPCODL	DHENKANAL	TED		KANIHA	14148206	11 KV DERANGA	RURAL	AMI	2.462256	2.462256	1.345477	45.36%	55.99%	100%	
470	TPCODL	DHENKANAL	TED		KANIHA	14148209	11 KV MCL KANIHA	RURAL	AMI	0.900168	0.900168	0.451593	49.83%	49.94%	100%	
471	TPCODL	DHENKANAL	TED		PARABIL	14149201	11 KV PARABIL	RURAL	AMI	1.444300	1.444300	0.859799	40.47%	58.24%	100%	
472	TPCODL	DHENKANAL	TED		PARABIL	14149202	11 KV ARKIL	RURAL	AMI	1.487977	1.487977	0.901360	39.42%	58.20%	100%	
473	TPCODL	DHENKANAL	TED		KHAMAR	14150202	11 KV BARKOTIA	RURAL	AMI	1.117951	1.117951	0.810115	27.54%	46.78%	67%	
474	TPCODL	DHENKANAL	TED		KHAMAR	14150204	11 KV ODAUS	RURAL	AMI	0.713510	0.713510	0.605688	15.11%	35.97%	67%	
475	TPCODL	DHENKANAL	TED		PALLAHARA	14151201	11 KV TOWN (PALLAH	RURAL	AMI	2.573085	2.573085	1.589526	38.22%	51.81%	100%	
476	TPCODL	DHENKANAL	TED		PALLAHARA	14151203	11 KV SEEGARH	RURAL	AMI	0.440520	0.440520	0.292698	33.56%	55.26%	100%	
477	TPCODL	DHENKANAL	TED		PALLAHARA	14151204	11 KV PHAPAND	RURAL	AMI	0.835736	0.835736	0.541816	35.17%	48.36%	100%	
478	TPCODL	DHENKANAL	TED		PALLAHARA	14151205	11 KV BATISUAN	RURAL	AMI	0.969968	0.969968	0.645826	33.42%	51.05%	100%	
479	TPCODL	PARADEEP	KED-01		PATTAMUNDAI	14153201	11 KV JHARIA	RURAL	AMI	4.156500	4.156500	3.014840	27.47%	45.67%	100%	
480	TPCODL	PARADEEP	KED-01		PATTAMUNDAI	14153202	11 KV PATTAMUNDAI I	RURAL	AMI	2.156618	2.156618	1.230585	42.94%	53.68%	67%	
481	TPCODL	PARADEEP	KED-01		PATTAMUNDAI	14153204	11 KV BALIPATANA & S	RURAL	AMI	2.004708	2.004708	1.469916	26.68%	39.76%	100%	
482	TPCODL	PARADEEP	KED-01		PATTAMUNDAI	14153205	11 KV BALDEV	RURAL	AMI	1.316770	1.316770	0.789352	40.05%	50.37%	100%	
483	TPCODL	PARADEEP	KED-01		PATTAMUNDAI	14153206	11 KV BELTAL	RURAL	AMI	1.513864	1.513864	1.021590	32.52%	39.95%	100%	
484	TPCODL	PARADEEP	KED-01		AUL	14154201	11 KV SASAN	RURAL	AMI	0.973291	0.973291	0.889568	8.60%	26.78%	100%	
485	TPCODL	PARADEEP	KED-01		AUL	14154202	11 KV AUL	RURAL	AMI	3.978626	3.978626	2.589312	34.92%	56.14%	67%	
486	TPCODL	PARADEEP	KED-01		AUL	14154203	11 KV CHHOTAKANIKA	RURAL	AMI	0.697882	0.697882	0.591451	15.25%	40.65%	67%	
487	TPCODL	PARADEEP	KED-01		AUL	14154205	11 KV MENDHAPUR	RURAL	AMI	1.264206	1.264206	0.897483	29.01%	45.37%	100%	
488	TPCODL	PARADEEP	KED-01		RAJAKANIKA	14155202	11 KV GIRIA	RURAL	AMI	0.456226	0.456226	0.321902	29.44%	47.59%	100%	
489	TPCODL	PARADEEP	KED-01		RAJAKANIKA	14155205	11 KV RAJAKANIKA BA	RURAL	AMI	0.335988	0.335988	0.211460	37.06%	59.49%	100%	
490	TPCODL	PARADEEP	KED-01		PATRAPUR	14156201	11 KV BATIPADA	RURAL	AMI	1.606920	1.606920	1.119267	30.35%	44.68%	67%	
491	TPCODL	PARADEEP	KED-01		INDUPUR	14157201	11 KV INDUPUR	RURAL	AMI	0.736280	0.736280	0.565726	23.16%	42.73%	100%	
492	TPCODL	PARADEEP	KED-01		INDUPUR	14157202	11 KV DHUMAT	RURAL	AMI	0.908730	0.908730	0.658384	27.55%	45.02%	100%	
493	TPCODL	PARADEEP	KED-01		KENDRAPARA	14158201	11 KV KENDRAPADA T	RURAL	AMI	7.023200	7.023200	3.920343	44.18%	53.20%	100%	
494	TPCODL	PARADEEP	KED-01		KENDRAPARA	14158202	11 KV KENDRAPADA T	RURAL	AMI	3.927628	3.927628	2.478668	36.89%	49.43%	100%	
495	TPCODL	PARADEEP	KED-01		KENDRAPARA	14158203	11 KV THAKURPATAN	RURAL	AMI	3.895572	3.895572	2.878268	26.11%	40.80%	100%	
496	TPCODL	PARADEEP	KED-01		KENDRAPARA	14158204	11 KV BHARATPUR-1	RURAL	AMI	2.219470	2.219470	1.433299	35.42%	45.52%	100%	
497	TPCODL	PARADEEP	KED-01		ADHAJORI	14159203	11 KV DAMARPUR	RURAL	AMI	1.691216	1.691216	1.069561	36.76%	53.27%	67%	
498	TPCODL	PARADEEP	KED-01		RAJANAGAR	14160201	11 KV RAJANAGAR	RURAL	AMI	4.545236	4.545236	2.985626	34.31%	50.26%	100%	
499	TPCODL	PARADEEP	KED-01		RAJANAGAR	14160202	11 KV KOILIPUR	RURAL	AMI	1.349952	1.349952	1.100465	18.48%	34.66%	100%	
500	TPCODL	PARADEEP	KED-01		RAJANAGAR	14160203	11 KV KEREDAGADA	RURAL	AMI	2.146046	2.146046	1.577972	26.47%	37.75%	100%	
501	TPCODL	PARADEEP	KED-01		RAJANAGAR	14160204	11 KV MADANPUR-1	RURAL	AMI	1.748084	1.748084	1.276294	26.99%	38.05%	100%	
502	TPCODL	PARADEEP	KED-01		GOGUA	14161202	11 KV NAPANGA	RURAL	AMI	0.815895	0.815895	0.667318	18.21%	37.57%	100%	

Sl No.	Zone	Received at Circle (In MU)	Received at Division (In MU)	Received at Sub-division (In MU)	Name of the Station	Feeder Code/ID	Feeder Name	Type of Feeder (Urban/Mixed/Industrial/Agricultural/Rural)	Type of feeder meter (AMI/AMR/Other)	Received at Feeder (Final in MU)	Feeder Consumption (In MU)	Final Net Export at Feeder Level (In MU)	T&D losses	AT&C losses	% Data Received through Automatically (if feeder AMR/AMI)	Remarks
503	TPCODL	PARADEEP	KED-01		GOGUA	14161205	11 KV DOBANDHA	RURAL	AMI	0.389630	0.389630	0.327730	15.89%	45.15%	100%	
504	TPCODL	PARADEEP	KED-01		DANDISAHI	14162202	11 KV BERHAMPUR-1	RURAL	AMI	1.278958	1.278958	0.878833	31.29%	47.58%	100%	
505	TPCODL	PARADEEP	KED-01		DANDISAHI	14162203	11 KV PALIMI	RURAL	AMI	0.741412	0.741412	0.540988	27.03%	48.59%	100%	
506	TPCODL	PARADEEP	KED-02		KORUA	14163201	11 KV KORUA	RURAL	AMI	2.620848	2.620848	1.831876	30.10%	41.28%	67%	
507	TPCODL	PARADEEP	KED-02		KORUA	14163202	11 KV NARENDRAPUR	RURAL	AMI	3.268306	3.268306	2.101199	35.71%	44.57%	100%	
508	TPCODL	PARADEEP	KED-02		KORUA	14163203	11 KV NAGANPUR	RURAL	AMI	1.804220	1.804220	1.106638	38.66%	50.55%	33%	
509	TPCODL	PARADEEP	KED-02		KORUA	14163204	11 KV BANAKHUDA	RURAL	AMI	2.491086	2.491086	1.291677	48.15%	56.03%	100%	
510	TPCODL	PARADEEP	KED-01		DANPUR	14164202	11 KV KHARIDASAHI	RURAL	AMI	0.878713	0.878713	0.792306	9.83%	22.06%	33%	
511	TPCODL	PARADEEP	KED-01		DANPUR	14164203	11 KV CHANDOLA	RURAL	AMI	1.687164	1.687164	1.340822	20.53%	34.66%	100%	
512	TPCODL	PARADEEP	KED-02		MARSAGHAI	14165202	11 KV MARSHAGHAI	RURAL	AMI	1.933998	1.933998	1.767413	8.61%	29.07%	100%	
513	TPCODL	PARADEEP	KED-02		LUNA	14166201	11 KV PATAKURA-1(OI	RURAL	AMI	1.843776	1.843776	1.101430	40.26%	50.61%	100%	
514	TPCODL	PARADEEP	KED-02		LUNA	14166202	11 KV ANKO	RURAL	AMI	2.332566	2.332566	1.748892	25.02%	38.66%	100%	
515	TPCODL	PARADEEP	KED-02		LUNA	14166203	11 KV OSTARA	RURAL	AMI	2.280210	2.280210	1.492469	34.55%	43.05%	100%	
516	TPCODL	PARADEEP	KED-02		LUNA	14166204	11 KV KARANJA	RURAL	AMI	1.114050	1.114050	0.825767	25.88%	36.03%	100%	
517	TPCODL	PARADEEP	KED-02		LUNA	14166205	11 KV NALADIA	RURAL	AMI	2.098894	2.098894	1.400060	33.30%	47.40%	100%	
518	TPCODL	PARADEEP	KED-02		MAHAKALPADA	14167202	11 KV CHHAPALI	RURAL	AMI	1.384224	1.384224	0.787792	43.09%	53.94%	100%	
519	TPCODL	PARADEEP	KED-02		MAHAKALPADA	14167205	11 KV DASAMAUJI+BI	RURAL	AMI	1.046443	1.046443	0.653068	37.59%	47.56%	100%	
520	TPCODL	PARADEEP	KED-02		GARDAPUR	14168201	11 KV GARADAPUR-I	RURAL	AMI	2.468104	2.468104	1.651211	33.10%	46.01%	100%	
521	TPCODL	PARADEEP	KED-02		GARDAPUR	14168202	11 KV GARADAPUR-II	RURAL	AMI	1.446758	1.446758	0.977020	32.47%	42.42%	100%	
522	TPCODL	PARADEEP	JED		JAGATSINGHPUR	14169201	11 KV CHHAPADA	RURAL	AMI	3.051720	3.051720	2.254913	26.11%	33.99%	100%	
523	TPCODL	PARADEEP	JED		JAGATSINGHPUR	14169202	11 KV ALIPINGALA	RURAL	AMI	2.602104	2.602104	1.998265	23.21%	32.64%	100%	
524	TPCODL	PARADEEP	JED		JAGATSINGHPUR	14169203	11 KV TOWN	RURAL	AMI	4.480440	4.480440	3.086489	31.11%	38.07%	100%	
525	TPCODL	PARADEEP	JED		JAGATSINGHPUR	14169204	11 KV PUNAGNA	RURAL	AMI	3.857532	3.857532	3.390604	12.10%	19.50%	100%	
526	TPCODL	PARADEEP	JED		RAGHUNATHPUR	14170201	11 KV RAGHUNATHPU	RURAL	AMI	1.910956	1.910956	1.696955	11.20%	22.38%	100%	
527	TPCODL	PARADEEP	JED		RAGHUNATHPUR	14170203	11 KV TARAPUR	RURAL	AMI	1.770052	1.770052	1.332735	24.71%	33.83%	100%	
528	TPCODL	PARADEEP	JED		RAGHUNATHPUR	14170204	11 KV RAILWAY	RURAL	AMI	0.095674	0.095674	0.094388	1.34%	10.19%	100%	
529	TPCODL	PARADEEP	JED		BIRIDI	14171201	11 KV DOGACHHIA	RURAL	AMI	0.975000	0.975000	0.600011	38.46%	46.94%	100%	
530	TPCODL	PARADEEP	JED		BIRIDI	14171202	11 KV DHYANAKUD	RURAL	AMI	0.475857	0.475857	0.253033	46.83%	54.38%	100%	
531	TPCODL	PARADEEP	JED		BIRIDI	14171203	11 KV RANI PADA	RURAL	AMI	1.969884	1.969884	1.450553	26.36%	33.13%	100%	
532	TPCODL	PARADEEP	JED		DHIASAHI / JOGDHARI	14172201	11 KV ODISSO	RURAL	AMI	2.531512	2.531512	1.803204	28.77%	37.73%	100%	
533	TPCODL	PARADEEP	JED		DHIASAHI / JOGDHARI	14172202	11 KV DHIASAHI	RURAL	AMI	2.833232	2.833232	2.007321	29.15%	40.22%	100%	
534	TPCODL	PARADEEP	JED		SOVA	14173201	11 KV AMBASALA	RURAL	AMI	0.651184	0.651184	0.472414	27.45%	33.22%	100%	
535	TPCODL	PARADEEP	JED		SOVA	14173202	11 KV MACHHAGAON	RURAL	AMI	1.839054	1.839054	1.263779	31.28%	37.39%	100%	
536	TPCODL	PARADEEP	JED		SOVA	14173204	11 KV SOVA	RURAL	AMI	0.360562	0.360562	0.263632	26.88%	35.11%	100%	
537	TPCODL	PARADEEP	JED		BALIKUDA	14174201	11 KV DENGAPOLA	RURAL	AMI	2.064506	2.064506	1.554497	24.70%	34.13%	100%	
538	TPCODL	PARADEEP	JED		BALIKUDA	14174204	11 KV BADAGAON	RURAL	AMI	2.382138	2.382138	1.861672	21.85%	31.88%	100%	
539	TPCODL	PARADEEP	JED		BALIKUDA	14174205	11 KV NAGAPUR	RURAL	AMI	1.662042	1.662042	1.358117	18.29%	27.47%	67%	
540	TPCODL	PARADEEP	JED		BALIKUDA	14174206	11 KV RWSS /PHD	RURAL	AMI	0.692250	0.692250	0.600174	13.30%	9.57%	100%	
541	TPCODL	PARADEEP	PDP		PARADEEP	14175201	11 KV INDUSTRIAL/AT	RURAL	AMI	1.734556	1.734556	1.012240	41.64%	48.53%	100%	
542	TPCODL	PARADEEP	PDP		PARADEEP	14175202	11 KV PARADEEPGAR	RURAL	AMI	3.446608	3.446608	2.454446	28.79%	33.43%	100%	
543	TPCODL	PARADEEP	PDP		PARADEEP	14175204	11 KV RANGIAGADA	RURAL	AMI	2.926800	2.926800	2.042558	30.21%	37.82%	100%	
544	TPCODL	PARADEEP	PDP		PARADEEP	14175205	11 KV CHOUMUHANI (	RURAL	AMI	5.208819	5.208819	0.908501	82.56%	84.06%	67%	
545	TPCODL	PARADEEP	PDP		TIRTOL	14176201	11 KV KOTAKANA	RURAL	AMI	2.183274	2.183274	1.462040	33.03%	42.58%	100%	
546	TPCODL	PARADEEP	PDP		TIRTOL	14176202	11 KV KANAKPUR	RURAL	AMI	0.629640	0.629640	0.461700	26.67%	34.00%	100%	
547	TPCODL	PARADEEP	PDP		RAHAMA	14177201	11 KV RAHAMA	RURAL	AMI	2.545708	2.545708	2.248443	11.68%	26.58%	100%	
548	TPCODL	PARADEEP	PDP		RAHAMA	14177202	11 KV PANKAPAL	RURAL	AMI	2.399156	2.399156	1.290449	46.21%	54.28%	100%	
549	TPCODL	PARADEEP	PDP		RAHAMA	14177203	11 KV BEHEDA	RURAL	AMI	1.182640	1.182640	0.864796	26.88%	35.29%	100%	
550	TPCODL	PARADEEP	PDP		RAHAMA	14177204	11 KV MEDICAL(RAHA	RURAL	AMI	0.778288	0.778288	0.649950	16.49%	30.92%	100%	
551	TPCODL	PARADEEP	PDP		ERASAMA	14178204	11 KV PANCHAPALLI	RURAL	AMI	1.012752	1.012752	0.571614	43.56%	49.80%	100%	
552	TPCODL	PARADEEP	PDP		ERASAMA	14178208	11 kV JAPA	RURAL	AMI	3.377294	3.377294	2.937221	13.03%	31.03%	100%	
553	TPCODL	PARADEEP	PDP		KUJANGA	14179201	11 KV TALADANDA	RURAL	AMI	2.333363	2.333363	1.615311	30.77%	36.16%	100%	
554	TPCODL	PARADEEP	PDP		KUJANGA	14179202	11 KV SANTARA	RURAL	AMI	4.817872	4.817872	2.187160	54.60%	61.24%	100%	
555	TPCODL	PARADEEP	PDP		KUJANGA	14179203	11 KV CHATUA	RURAL	AMI	4.067108	4.067108	2.902985	28.62%	40.96%	100%	
556	TPCODL	PARADEEP	PDP		KUJANGA	14179204	11 KV KUJANGA BAZA	RURAL	AMI	1.364404	1.364404	0.979527	28.21%	45.26%	100%	
557	TPCODL	BBSR-01	BED		NAHARKANTA	14180201	11 KV NAHARKANTA	URBAN	AMI	2.806344	2.806344	2.113375	24.69%	29.50%	100%	
558	TPCODL	BBSR-01	BED		NAHARKANTA	14180202	11 KV BALIANTA	URBAN	AMI	5.714896	5.714896	4.336512	24.12%	27.66%	100%	
559	TPCODL	BBSR-01	BED		NAHARKANTA	14180203	11 KV ATALA	URBAN	AMI	8.569532	8.569532	7.400235	13.64%	16.35%	100%	
560	TPCODL	BBSR-01	BED		NAHARKANTA	14180204	11 KV JAYDEV COLLE	URBAN	AMI	1.528400	1.528400	1.106077	27.63%	32.32%	100%	
561	TPCODL	PARADEEP	JED		NUAPOLA / NABAPATNA	14181201	11 KV TARIKUNDA	RURAL	AMI	2.512198	2.512198	1.694315	32.56%	42.77%	100%	
562	TPCODL	PARADEEP	JED		NUAPOLA / NABAPATNA	14181202	11 KV MANDASAHI	RURAL	AMI	2.879217	2.879217	1.971857	31.51%	42.24%	100%	
563	TPCODL	BBSR-02	KHD		BEGUNIA	14182201	11 KV BEGUNIA	RURAL	AMI	1.671480	1.671480	1.359119	18.69%	35.44%	100%	
564	TPCODL	BBSR-01	BED		SBI KESURA	14183202	11 KV KESURA	URBAN	AMI	4.231268	4.231268	3.363255	20.51%	23.58%	100%	
565	TPCODL	CUTTACK	CED		CHOUDWAR	14184201	11 KV CITY BARRAGE	RURAL	AMI	3.500917	3.500917	1.982087	43.38%	55.32%	100%	
566	TPCODL	CUTTACK	CED		CHOUDWAR	14184203	11 KV ARC	RURAL	AMI	1.001532	1.001532	0.650234	35.08%	40.01%	100%	
567	TPCODL	CUTTACK	CED		CHOUDWAR	14184204	11 KV OTM	RURAL	AMI	2.714692	2.714692	1.815303	33.13%	38.75%	100%	
568	TPCODL	CUTTACK	CED		CHOUDWAR	14184205	11 KV LOCAL	RURAL	AMI	2.974787	2.974787	2.166173	27.18%	38.10%	100%	
569	TPCODL	CUTTACK	CED		CHOUDWAR	14184206	11 KV NUNTIKIRI	RURAL	AMI	1.482743	1.482743	1.011673	31.77%	43.00%	33%	
570	TPCODL	CUTTACK	CED		CHOUDWAR	14184207	11 KV CHARBATIA KA	RURAL	AMI	5.472835	5.472835	3.166312	42.14%	64.65%	67%	
571	TPCODL	BBSR-02	BAED		CHANDPUR	14185201	11 KV KAMAGURU	RURAL	AMI	2.028044	2.028044	1.305910	35.61%	47.78%	100%	
572	TPCODL	BBSR-02	BAED		CHANDPUR	14185202	11 KV CHANDAPUR	RURAL	AMI	3.848672	3.848672	2.017720	47.57%	59.61%	100%	
573	TPCODL	DHENKANAL	ANED		HEMSURPADA	14187201	11 KV HEMSURPADA	RURAL	AMI	6.840356	6.840356	4.862222	28.92%	36.16%	100%	
574	TPCODL	DHENKANAL	ANED		HEMSURPADA	14187202	11 KV MCL	RURAL	AMI	3.144792	3.144792	1.916067	39.07%	43.69%	67%	
575	TPCODL	DHENKANAL	ANED		HEMSURPADA	14187204	11 KV SIKHYAKAPADA	RURAL	AMI	4.095268	4.095268	2.909678	28.95%	37.85%	67%	
576	TPCODL	DHENKANAL	ANED		HEMSURPADA	14187205	11 KV JARASINGHA	RURAL	AMI	7.584000	7.584000	6.686355	11.84%	16.87%	100%	
577	TPCODL	DHENKANAL	DED		JORANDA	14188203	11 KV KARAMUL	RURAL	AMI	2.122648	2.122648	1.346612	36.56%	47.53%	100%	
578	TPCODL	DHENKANAL	DED		DAKHINAKALI	14189201	11 KV DEULASAHI	RURAL	AMI	2.632844	2.632844	2.513269	4.54%	21.53%	100%	
579	TPCODL	DHENKANAL	DED		DAKHINAKALI	14189202	11 KV SASAN	RURAL	AMI	5.712656	5.712656	3.657739	35.97%	43.63%	33%	
580	TPCODL	DHENKANAL	DED		DAKHINAKALI	14189204	11 KV KORIA(SPARE)	RURAL	AMI	1.370604	1.370604	0.807652	41.07%	46.45%	100%	
581	TPCODL	DHENKANAL	DED		NIHALPRASAD	14190202	11 KV Kasipur	RURAL	AMI	1.514800	1.514800	1.193055	21.24%	35.74%	100%	
582	TPCODL	DHENKANAL	DED		KANKADAHADA	14191201	11 KV DANDADHAR	RURAL	AMI	0.709676	0.709676	0.499937	29.55%	48.82%	33%	
583	TPCODL	DHENKANAL	TED		CHAINPAL	14192201	11 KV BALHAR	RURAL	AMI	3.758574	3.758574	2.318073	38.33%	48.94%	67%	
584	TPCODL	DHENKANAL	TED		CHAINPAL	14192203	11 KV BHOGABARINI	RURAL	AMI	2.651204	2.651204	2.390092	9.85%	21.75%	67%	
585	TPCODL	PARADEEP	JED		22MAUJA	14193201	11 KV BAGALPUR	RURAL	AMI	1.565346	1.565346	1.115911	28.71%	35.37%	100%	
586	TPCODL	PARADEEP	JED		22MAUJA	14193202	11 KV PARBATIPUR	RURAL	AMI	1.206452	1.206452	0.817144	32.27%	45.98%	100%	

Sl No.	Zone	Received at Circle (In MU)	Received at Division (In MU)	Received at Sub-division (In MU)	Name of the Station	Feeder Code/ID	Feeder Name	Type of Feeder (Urban/Mixed/Industrial/Agricultural/Rural)	Type of feeder meter (AMI/AMR/Other)	Received at Feeder (Final in MU)	Feeder Consumption (In MU)	Final Net Export at Feeder Level (In MU)	T&D losses	AT&C losses	% Data Received through Automatically (if feeder AMR/AMI)	Remarks
587	TPCODL	PARADEEP	JED		NAUGAON	14194201	11 KV ROHIA	RURAL	AMI	2.238792	2.238792	0.708120	68.37%	74.57%	100%	
588	TPCODL	PARADEEP	JED		NAUGAON	14194202	11 KV CHANDPUR	RURAL	AMI	0.588894	0.588894	0.417809	29.05%	39.13%	100%	
589	TPCODL	PARADEEP	JED		NAUGAON	14194203	11 KV SIKHARA	RURAL	AMI	0.453855	0.453855	0.324559	28.49%	40.52%	100%	
590	TPCODL	PARADEEP	JED		NAUGAON	14194204	11 KV NAUGAON HQ	RURAL	AMI	0.976448	0.976448	0.724925	25.76%	41.62%	100%	
591	TPCODL	PARADEEP	JED		NUAPADA	14195201	11 KV PITEIPUR	RURAL	AMI	1.745544	1.745544	1.259172	27.86%	36.87%	100%	
592	TPCODL	PARADEEP	JED		NUAPADA	14195202	11 KV NALIBAR	RURAL	AMI	1.502006	1.502006	1.316336	12.36%	30.82%	100%	
593	TPCODL	PARADEEP	JED		NUAPADA	14195203	11 KV ICHHAPUR	RURAL	AMI	1.397066	1.397066	0.885887	36.59%	40.28%	100%	
594	TPCODL	PARADEEP	PDP		KOLAR(PARUNA)	14196202	11KV PARUNA	RURAL	AMI	0.344690	0.344690	0.239064	30.64%	37.07%	100%	
595	TPCODL	PARADEEP	KED-01		DUHURIA	14197201	11 KV DUHURIA	RURAL	AMI	0.922036	0.922036	0.626440	32.06%	41.57%	100%	
596	TPCODL	PARADEEP	KED-01		DUHURIA	14197202	11 KV LAW COLLEGE	RURAL	AMI	1.951943	1.951943	1.584392	18.83%	25.68%	100%	
597	TPCODL	PARADEEP	KED-01		CHHAGHARIA	14198203	11 KV ICHHAPUR PHD	RURAL	AMI	0.273188	0.273188	0.224469	17.83%	50.88%	100%	
598	TPCODL	PARADEEP	KED-01		CHHATA	14199201	11 KV CHHATA	RURAL	AMI	3.572062	3.572062	2.785246	22.03%	41.98%	100%	
599	TPCODL	PARADEEP	KED-01		CHHATA	14199202	11 KV PANCHUPANDA	RURAL	AMI	2.596000	2.596000	1.956387	24.64%	45.98%	100%	
600	TPCODL	PARADEEP	KED-01		BALARAMPUR	14200203	11 KV DASIPUR	RURAL	AMI	1.874913	1.874913	1.320075	29.59%	45.01%	100%	
601	TPCODL	PARADEEP	KED-01		SAHUPADA	14201201	11 KV BADAPADA	RURAL	AMI	1.317459	1.317459	0.803467	39.01%	47.89%	100%	
602	TPCODL	BBSR-02	BAED		KUHUDI	14202201	11 KV KUHUDI	RURAL	AMI	1.225106	1.225106	0.735173	39.99%	48.82%	100%	
603	TPCODL	BBSR-02	BAED		KUHUDI	14202202	11 KV CHANDESWAR	RURAL	AMI	3.544843	3.544843	2.825130	20.30%	30.06%	100%	
604	TPCODL	BBSR-02	KHD		DADHIMACHAGADIA	14203201	11 KV KAIPADAR	RURAL	AMI	1.666226	1.666226	1.217747	26.92%	40.70%	100%	
605	TPCODL	BBSR-02	KHD		DADHIMACHAGADIA	14203203	11 KV BAJPUR	RURAL	AMI	2.658538	2.658538	2.001916	24.70%	32.79%	33%	
606	TPCODL	BBSR-02	KHD		DADHIMACHAGADIA	14203204	11 KV DALEIPUT	RURAL	AMI	2.083228	2.083228	1.215318	41.66%	41.40%	100%	
607	TPCODL	BBSR-02	BAED		ANKULAPADAR	14204203	11 KV NILADRI	RURAL	AMI	0.492871	0.492871	0.363457	26.26%	38.07%	100%	
608	TPCODL	BBSR-02	BAED		ANKULAPADAR	14204204	11 KV PANCHUGAON	RURAL	AMI	1.931350	1.931350	1.826954	5.41%	10.70%	67%	
609	TPCODL	BBSR-02	BAED		DARPANARANPUR	14205201	11 KV DARPANARANP	RURAL	AMI	1.272538	1.272538	0.895320	29.64%	34.04%	100%	
610	TPCODL	BBSR-02	BAED		BHUSANDAPUR	14206201	11 KV BHUSANDAPUR	RURAL	AMI	2.325200	2.325200	1.817915	21.82%	34.16%	100%	
611	TPCODL	BBSR-02	PED		ATHARNALA	14207201	11 KV MADHUBANA	RURAL	AMI	3.876315	3.876315	3.074367	20.69%	24.93%	100%	
612	TPCODL	BBSR-02	PED		ATHARNALA	14207202	11 KV MAKUBANA	RURAL	AMI	0.303129	0.303129	0.239789	20.90%	24.43%	100%	
613	TPCODL	BBSR-02	PED		ATHARNALA	14207203	11 KV Narendra Pokha	RURAL	AMI	1.763045	1.763045	0.985811	44.08%	49.43%	100%	
614	TPCODL	BBSR-02	PED		ATHARNALA	14207204	11 KV MLCP	RURAL	AMI	1.552290	1.552290	1.005516	35.22%	42.69%	100%	
615	TPCODL	BBSR-02	PED		KUMARESWAR	14208201	11 KV BALANGA	RURAL	AMI	4.079283	4.079283	2.619010	35.80%	51.26%	100%	
616	TPCODL	CUTTACK	CDD-1		MATAMATHA	14209201	11 KV CIRCUIT HOUSE	URBAN	AMI	1.402414	1.402414	1.128463	19.53%	15.97%	100%	
617	TPCODL	CUTTACK	CDD-1		MATAMATHA	14209202	11 KV CB9	URBAN	AMI	2.371888	2.371888	2.165849	8.69%	12.54%	100%	
618	TPCODL	CUTTACK	CDD-1		DRDA	14210201	11 KV GANESHGHAT	URBAN	AMI	3.001233	3.001233	1.962734	34.60%	32.72%	100%	
619	TPCODL	CUTTACK	CDD-1		DRDA	14210202	11 KV KAZIBAZAR	URBAN	AMI	4.550697	4.550697	3.619059	20.47%	19.96%	33%	
620	TPCODL	CUTTACK	CDD-1		DRDA	14210204	11 KV TREASURY	URBAN	AMI	0.183841	0.183841	0.106331	42.16%	70.40%	67%	
621	TPCODL	CUTTACK	CDD-2		MATTAGAJAPUR	14211203	11 KV JAICA	URBAN	AMI	1.564576	1.564576	0.816562	47.81%	50.00%	67%	
622	TPCODL	CUTTACK	CDD-2		MATTAGAJAPUR	14211204	11 KV PHD	URBAN	AMI	0.182652	0.182652	0.181509	0.63%	-3.32%	100%	
623	TPCODL	CUTTACK	SED		ORIKANTA	14212202	11 KV BILAHATA	RURAL	AMI	3.370792	3.370792	1.746459	48.19%	53.99%	100%	
624	TPCODL	BBSR-01	BCDD-01		AIR PORT	14215204	11 KV JP RMU-F34	URBAN	AMI	3.597922	3.597922	2.485258	30.93%	34.56%	100%	
625	TPCODL	BBSR-01	BCDD-02		NEW BARANGA	14216203	11 KV SRIRAM BAZAA	MIXED	AMI	1.683884	1.683884	1.204231	28.48%	35.02%	100%	
626	TPCODL	BBSR-01	BCDD-02		NEW BARANGA	14216204	11 KV FEEDER-1	URBAN	AMI	2.821360	2.821360	2.605434	7.65%	13.77%	100%	
627	TPCODL	BBSR-01	BCDD-02		KANAN BIHAR	14217201	11 KV ROYALTY SQUA	URBAN	AMI	2.145576	2.145576	1.231000	42.63%	46.63%	100%	
628	TPCODL	BBSR-01	BCDD-02		KANAN BIHAR	14217203	11 KV PATIA	URBAN	AMI	4.840248	4.840248	3.964530	18.09%	23.52%	100%	
629	TPCODL	BBSR-01	BCDD-02		KANAN BIHAR	14217204	11 KV PKB	URBAN	AMI	2.658501	2.658501	2.185446	17.79%	21.76%	67%	
630	TPCODL	BBSR-01	BCDD-02		KANAN BIHAR	14217208	11KV PRASANTI VIHAI	URBAN	AMI	4.673172	4.673172	4.010088	14.19%	13.05%	100%	
631	TPCODL	BBSR-01	BCDD-02		KANAN BIHAR	14217210	11KV KIIT	URBAN	AMI	4.856345	4.856345	3.127960	35.59%	41.21%	100%	
632	TPCODL	PARADEEP	JED		SASANPADA	14218202	11 KV ALIPINGAL	RURAL	AMI	1.160864	1.160864	0.868090	25.22%	34.20%	33%	
633	TPCODL	CUTTACK	CED		KASARDA	14220204	11 KV SITHALO	RURAL	AMI	2.320828	2.320828	0.809419	65.12%	73.93%	100%	
634	TPCODL	BBSR-01	BCDD-01		DELTA	14221201	11 KV SIRIPUR	URBAN	AMI	3.779044	3.779044	3.443399	8.88%	9.33%	100%	
635	TPCODL	BBSR-01	BCDD-01		DELTA	14221202	11 KV Shatabdinagar	URBAN	AMI	4.039124	4.039124	3.141865	22.21%	23.86%	100%	
636	TPCODL	BBSR-01	BCDD-01		DELTA	14221203	11 KV FIRE STATION	URBAN	AMI	4.926948	4.926948	3.847628	21.91%	24.62%	100%	
637	TPCODL	BBSR-01	BCDD-02		KHANDAGIRI	14222201	11 KV KOLATHIA	URBAN	AMI	5.376428	5.376428	4.475347	16.76%	21.31%	100%	
638	TPCODL	BBSR-01	BCDD-02		KHANDAGIRI	14222202	11 KV DHARMAVIHAR	URBAN	AMI	3.546844	3.546844	2.870974	19.06%	34.11%	100%	
639	TPCODL	BBSR-01	BCDD-02		KHANDAGIRI	14222203	11 KV GANDMUNDA	URBAN	AMI	4.118302	4.118302	3.033246	26.35%	29.78%	100%	
640	TPCODL	BBSR-01	BCDD-02		KHANDAGIRI	14222204	11 KV JAGAMOHAN NA	URBAN	AMI	6.242329	6.242329	5.665049	9.25%	17.44%	100%	
641	TPCODL	BBSR-01	BCDD-02		KHANDAGIRI	14222205	11kv Green Park Feede	URBAN	AMI	1.508282	1.508282	1.265534	16.09%	20.56%	100%	
642	TPCODL	BBSR-01	BCDD-02		KHANDAGIRI	14222206	11kv Talabania Feeder	URBAN	AMI	2.121485	2.121485	1.315020	38.01%	39.05%	100%	
643	TPCODL	BBSR-01	BCDD-02		KALARAHANGA	14223202	11 KV NANDDANVIHAI	URBAN	AMI	2.556547	2.556547	1.578934	38.24%	43.46%	100%	
644	TPCODL	BBSR-01	BED		BHINGARPUR	14224201	11 KV GANGESWAR	URBAN	AMI	3.243124	3.243124	2.124626	34.49%	41.70%	100%	
645	TPCODL	BBSR-02	PED		KHAJURIA	14225202	11 KV TALAMALA	RURAL	AMI	1.902580	1.902580	0.587486	69.12%	79.26%	100%	
646	TPCODL	PARADEEP	PDP		BIJAYCHANDRAPUR	14226201	11 KV ATHARBANKI M	RURAL	AMI	4.173042	4.173042	3.328445	20.24%	29.61%	100%	
647	TPCODL	DHENKANAL	ANED		BADAKERA	14227201	11 KV BADAKERA	RURAL	AMI	3.002937	3.002937	2.013366	32.95%	45.75%	100%	
648	TPCODL	DHENKANAL	ANED		BADAKERA	14227202	11 KV DUDHIABEDA	RURAL	AMI	5.085078	5.085078	2.984416	41.31%	47.80%	100%	
649	TPCODL	PARADEEP	KED-02		BADIHI	14228201	11 KV BIJAYANAGAR-	RURAL	AMI	1.775020	1.775020	1.257313	29.17%	42.86%	100%	
650	TPCODL	PARADEEP	KED-02		BADIHI	14228202	11 KV BABAR	RURAL	AMI	0.876958	0.876958	0.600274	31.55%	45.79%	100%	
651	TPCODL	PARADEEP	KED-02		BADIHI	14228203	11 KV JAMBOO	RURAL	AMI	1.759349	1.759349	1.182953	32.76%	45.33%	100%	
652	TPCODL	PARADEEP	KED-01		KANDIRA	14229201	11 KV BALARAMPUR	RURAL	AMI	1.007648	1.007648	0.916547	9.04%	22.51%	100%	
653	TPCODL	PARADEEP	KED-01		KANDIRA	14229202	11 KV JARIMULA	RURAL	AMI	1.727772	1.727772	1.200624	30.51%	40.81%	100%	
654	TPCODL	BBSR-01	BCDD-02		VANIVIHAR ODSSP	14230201	11 KV UNIVERSITY-1	URBAN	AMI	1.138392	1.138392	1.138433	0.00%	2.76%	100%	
655	TPCODL	BBSR-01	BCDD-02		VANIVIHAR ODSSP	14230203	11 KV INCOME TAX	URBAN	AMI	2.878836	2.878836	2.470313	14.19%	17.36%	100%	
656	TPCODL	BBSR-01	BCDD-02		VANIVIHAR ODSSP	14230204	11 KV LAXMI VIHAR	URBAN	AMI	2.629251	2.629251	2.189405	16.73%	18.71%	100%	
657	TPCODL	BBSR-01	BCDD-02		RRL ODSSP	14231203	11 KV PAL HEIGHT	URBAN	AMI	5.028810	5.028810	4.686271	6.81%	9.33%	100%	
658	TPCODL	CUTTACK	CED		SANKARPUR ODSSP	14233201	11 KV SANKARPUR	RURAL	AMI	1.416297	1.416297	0.711379	49.77%	61.91%	100%	
659	TPCODL	CUTTACK	CED		SANKARPUR ODSSP	14233202	11 KV BERHAMPUR	RURAL	AMI	0.793020	0.793020	0.426008	46.28%	61.66%	100%	
660	TPCODL	CUTTACK	CED		SANKARPUR ODSSP	14233203	11 KV MANGARAJPUR	RURAL	AMI	0.811794	0.811794	0.630945	22.28%	45.87%	100%	
661	TPCODL	BBSR-01	BCDD-01		MASTER CANTEEN ODS	14234201	11 KV SUCHNA BHAW	URBAN	AMI	3.328950	3.328950	1.709895	48.64%	50.77%	100%	
662	TPCODL	BBSR-01	BCDD-01		MASTER CANTEEN ODS	14234203	11 KV MARKET BUILDI	URBAN	AMI	2.738598	2.738598	1.881765	31.29%	35.16%	100%	
663	TPCODL	BBSR-01	BCDD-01		MASTER CANTEEN ODS	14234204	11 KV JANPATH	URBAN	AMI	2.713542	2.713542	2.647714	2.43%	4.34%	100%	
664	TPCODL	BBSR-01	BCDD-02		RANASINGHPUR ODSSP	14235201	11 KV SARAKANTARA	URBAN	AMI	3.371412	3.371412	2.080614	38.29%	45.92%	100%	
665	TPCODL	BBSR-01	BCDD-02		RANASINGHPUR ODSSP	14235202	11 KV AIGINIA	URBAN	AMI	4.882602	4.882602	2.856875	41.49%	44.22%	100%	
666	TPCODL	BBSR-01	BCDD-02		RANASINGHPUR ODSSP	14235203	11 KV SIJUA	URBAN	AMI	2.182419	2.182419	1.510445	30.79%	36.71%	100%	
667	TPCODL	BBSR-01	BCDD-02		DUMDUMA ODSSP	14236202	11 KV PANCHASAKHA	URBAN	AMI	4.011348	4.011348	3.238306	19.27%	21.02%	100%	
668	TPCODL	BBSR-01	BCDD-02		DUMDUMA ODSSP	14236204	11 KV BEGUNIA	URBAN	AMI	4.499445	4.499445	3.145465	30.09%	34.26%	100%	
669	TPCODL	BBSR-01	BCDD-02		GOTHAPATNA ODSSP	14237202	11 KV NUAGAON	URBAN	AMI	4.078896	4.078896	2.762099	32.28%	36.62%	100%	
670	TPCODL	BBSR-01	BCDD-02		GOTHAPATNA ODSSP	14237203	11 KV PAIKRAYPUR	URBAN	AMI	1.282902	1.282902	0.933986	27.20%	33.73%	100%	

Sl No.	Zone	Received at Circle (In MU)	Received at Division (In MU)	Received at Sub-division (In MU)	Name of the Station	Feeder Code/ID	Feeder Name	Type of Feeder (Urban/Mixed/Industrial/Agricultural/Rural)	Type of feeder meter (AMI/AMR/Other)	Received at Feeder (Final in MU)	Feeder Consumption (In MU)	Final Net Export at Feeder Level (In MU)	T&D losses	AT&C losses	% Data Received through Automatically (if feeder AMR/AMI)	Remarks
671	TPCODL	BBSR-01	BCDD-02		GOTHAPATNA ODSSP	14237204	11 KV GODIBARI	URBAN	AMI	3.032085	3.032085	2.379687	21.52%	30.15%	100%	
672	TPCODL	CUTTACK	CDD-1		SATICHAURA ODSSP	14238201	11 KV TULASIPUR	URBAN	AMI	4.878213	4.878213	3.223229	33.93%	34.64%	100%	
673	TPCODL	CUTTACK	CDD-1		SATICHAURA ODSSP	14238202	11 KV EYE HOSPITAL	URBAN	AMI	4.922856	4.922856	3.302721	32.91%	37.82%	100%	
674	TPCODL	CUTTACK	CDD-1		SECTOR-10 & 11 ODSSP	14239201	11 KV CDA-10	URBAN	AMI	4.087668	4.087668	3.182137	22.15%	23.54%	100%	
675	TPCODL	CUTTACK	CDD-1		SECTOR-10 & 11 ODSSP	14239202	11 KV CDA-11	URBAN	AMI	2.934150	2.934150	2.310372	21.26%	19.95%	100%	
676	TPCODL	CUTTACK	CDD-1		SECTOR-10 & 11 ODSSP	14239203	11 KV NARAJ	URBAN	AMI	0.542442	0.542442	0.298510	44.97%	40.85%	67%	
677	TPCODL	CUTTACK	CDD-1		SECTOR-13 ODSSP	14240203	11 KV SECTOR-13	URBAN	AMI	3.834762	3.834762	2.771719	27.72%	29.13%	100%	
678	TPCODL	CUTTACK	CDD-2		JAGATPUR (IPICOL) ODS	14241203	11 KV KHAIRA	URBAN	AMI	5.108088	5.108088	4.077819	20.17%	26.60%	100%	
679	TPCODL	CUTTACK	CDD-2		MAHANADI VIHAR ODSSF	14242201	11 KV MAHANADI BIHA	URBAN	AMI	4.851882	4.851882	3.330678	31.35%	35.29%	100%	
680	TPCODL	CUTTACK	CDD-2		MAHANADI VIHAR ODSSF	14242202	11 KV MAHANADI BIHA	URBAN	AMI	2.451321	2.451321	2.187731	10.75%	15.58%	100%	
681	TPCODL	CUTTACK	CDD-2		MAHANADI VIHAR ODSSF	14242203	11 KV SIKHARPUR	URBAN	AMI	3.356754	3.356754	1.926212	42.62%	44.62%	100%	
682	TPCODL	CUTTACK	CDD-2		MAHANADI VIHAR ODSSF	14242204	11 KV GANDARPUR	URBAN	AMI	1.535109	1.535109	0.796094	48.14%	50.75%	100%	
683	TPCODL	BBSR-01	BED		CHAKEISIANI ODSSP	14243203	11 KV BHATAPADA	URBAN	AMI	0.957930	0.957930	0.737907	22.97%	25.17%	100%	
684	TPCODL	BBSR-01	BED		LINGIPUR ODSSP	14244201	11 KV SISHUPALA GAI	MIXED	AMI	0.223650	0.223650	0.161896	27.61%	33.87%	100%	
685	TPCODL	BBSR-01	BED		LINGIPUR ODSSP	14244202	11 KV KUAKHAI	MIXED	AMI	3.761634	3.761634	3.010816	19.96%	24.98%	100%	
686	TPCODL	BBSR-01	BED		LINGIPUR ODSSP	14244203	11 KV CIFA	MIXED	AMI	0.875790	0.875790	0.775034	11.50%	16.93%	100%	
687	TPCODL	BBSR-01	BED		LINGIPUR ODSSP	14244204	11 KV GANGUA	MIXED	AMI	2.392062	2.392062	1.693608	29.20%	35.42%	100%	
688	TPCODL	BBSR-01	BED		LINGIPUR ODSSP	14244206	11 KV GANGOTRI NAG	URBAN	AMI	3.418458	3.418458	2.393687	29.98%	33.66%	100%	
689	TPCODL	BBSR-01	BED		LINGIPUR ODSSP	14244207	11 KV INDIRA COLON'	URBAN	AMI	4.100034	4.100034	2.954929	27.93%	32.58%	100%	
690	TPCODL	BBSR-01	BED		KALPANA ODSSP	14245201	11 KV KALPANA FLAT	URBAN	AMI	2.693538	2.693538	2.337871	13.20%	15.85%	100%	
691	TPCODL	BBSR-01	BED		KALPANA ODSSP	14245202	11 KV CUTTACK ROAI	URBAN	AMI	2.558610	2.558610	1.763428	31.08%	33.15%	100%	
692	TPCODL	BBSR-01	BCDD-02		CHANDAKA ODSSP	14246201	11 KV Patharagadia	URBAN	AMI	4.057965	4.057965	1.975735	51.31%	54.57%	100%	
693	TPCODL	BBSR-01	BCDD-02		CHANDAKA ODSSP	14246202	11 KV DASPUR	URBAN	AMI	2.983890	2.983890	1.995022	33.14%	39.95%	100%	
694	TPCODL	BBSR-01	BCDD-02		CHANDAKA ODSSP	14246203	11 KV Kujimahal	URBAN	AMI	3.211245	3.211245	2.316472	27.86%	30.75%	100%	
695	TPCODL	BBSR-01	BCDD-02		GODISAHI (RAMDASPUR	14247202	11 KV INDUSTRIAL	URBAN	AMI	1.874619	1.874619	1.457960	22.23%	34.43%	100%	
696	TPCODL	BBSR-01	BCDD-02		GODISAHI (RAMDASPUR	14247203	11 KV BIDYADHARPUI	URBAN	AMI	2.054718	2.054718	1.498369	27.08%	30.57%	100%	
697	TPCODL	BBSR-01	BCDD-02		(KRUSHNADASPUR) SAIL	14249201	11 KV Vigilance Colony	URBAN	AMI	1.651935	1.651935	1.016288	38.48%	43.04%	100%	
698	TPCODL	BBSR-01	BCDD-02		(KRUSHNADASPUR) SAIL	14249203	11 KV Aryan	URBAN	AMI	2.225199	2.225199	1.979418	11.05%	17.22%	100%	
699	TPCODL	BBSR-01	BCDD-02		NEW KALARAHANGA IPD	14251201	11 KV PATIA STATION	URBAN	AMI	0.230424	0.230424	0.156406	32.12%	31.16%	100%	
700	TPCODL	BBSR-01	BCDD-02		NEW KALARAHANGA IPD	14251202	11 KV DHAWA	URBAN	AMI	3.416520	3.416520	2.047101	40.08%	44.57%	100%	
701	TPCODL	BBSR-01	BCDD-02		NEW KALARAHANGA IPD	14251203	11 KV TANGI BANTA	URBAN	AMI	1.348668	1.348668	1.093541	18.92%	21.79%	100%	
702	TPCODL	BBSR-01	BCDD-02		NEW KALARAHANGA IPD	14251204	11 KV Injama	URBAN	AMI	2.107596	2.107596	1.404313	33.37%	34.40%	100%	
703	TPCODL	BBSR-01	BED		MULAPADIA ODSSP	14252202	11 KV MAHAVIR COTT	URBAN	AMI	3.195870	3.195870	1.664966	47.90%	49.52%	100%	
704	TPCODL	BBSR-01	BED		MULAPADIA ODSSP	14252203	11 KV RATHA ROAD	URBAN	AMI	0.900990	0.900990	0.659257	26.83%	31.52%	67%	
705	TPCODL	BBSR-01	BED		MULAPADIA ODSSP	14252204	11 KV MULAPADIA	URBAN	AMI	3.722778	3.722778	2.932945	21.22%	23.94%	100%	
706	TPCODL	BBSR-01	BED		PRADHAN SAHI ODSSP	14253202	11 kV PRADHANSHAI	URBAN	AMI	1.047555	1.047555	0.691772	33.96%	38.80%	100%	
707	TPCODL	BBSR-01	BED		PRADHAN SAHI ODSSP	14253203	11 kV PANCHA GAON	URBAN	AMI	1.073922	1.073922	0.612748	42.94%	42.00%	100%	
708	TPCODL	BBSR-01	BED		SIULA ODSSP	14254201	11 KV LAXMINARAYAN	URBAN	AMI	2.093895	2.093895	1.075884	48.62%	55.24%	100%	
709	TPCODL	BBSR-01	BED		SIULA ODSSP	14254203	11 KV DAHISPATNA	URBAN	AMI	2.834964	2.834964	1.640439	42.14%	45.86%	100%	
710	TPCODL	BBSR-01	NED		BANAMALIPUR ODSSP	14255201	11 KV BANAMALIPUR	RURAL	AMI	4.505142	4.505142	2.361653	47.58%	59.06%	100%	
711	TPCODL	BBSR-01	NED		PATALDA ODSSP	14256202	11 kV PATALADA	RURAL	AMI	1.187853	1.187853	0.757892	36.20%	45.00%	100%	
712	TPCODL	BBSR-01	NED		BAMANAL ODSSP	14257202	11 KV VBHNTI	RURAL	AMI	1.824021	1.824021	0.919928	49.57%	60.56%	100%	
713	TPCODL	BBSR-01	NED		BHARATIPUR ODSSP	14258201	11 KV Sadamgoi	RURAL	AMI	1.731648	1.731648	0.565827	67.32%	80.05%	100%	
714	TPCODL	BBSR-01	NED		BANGURIGAON ODSSP	14262201	11 KV Bangurigaon	RURAL	AMI	1.702800	1.702800	1.145875	32.71%	42.25%	100%	
715	TPCODL	BBSR-01	NED		JOGESWARPUR (GADA /	14263201	11 KV Binispur	RURAL	AMI	2.366361	2.366361	1.712326	27.64%	36.58%	100%	
716	TPCODL	BBSR-01	NED		JOGESWARPUR (GADA /	14263202	11 KV Nayhata	RURAL	AMI	1.942692	1.942692	1.233983	36.48%	49.08%	100%	
717	TPCODL	BBSR-01	NED		JOGESWARPUR (GADA /	14263203	11 KV GadaAmarprasa	RURAL	AMI	1.544172	1.544172	0.954538	38.18%	51.38%	100%	
718	TPCODL	BBSR-01	NED		KHELAR ODSSP	14264202	11 KV Chingudiakanta	RURAL	AMI	0.280845	0.280845	0.210243	25.14%	24.37%	100%	
719	TPCODL	BBSR-01	NED		KHELAR ODSSP	14264203	11 KV Khelar Bazaar	RURAL	AMI	2.278005	2.278005	1.456945	36.04%	50.00%	100%	
720	TPCODL	BBSR-01	NED		MANGALPUR ODSSP	14265201	11 KV MANGALPUR	RURAL	AMI	4.087179	4.087179	1.757559	57.00%	61.58%	100%	
721	TPCODL	BBSR-01	NED		MADARANG (NAGAPUR)	14266201	11 KV MALLAGRAM	RURAL	AMI	0.667296	0.667296	0.375107	43.79%	54.40%	100%	
722	TPCODL	BBSR-01	NED		MADARANG (NAGAPUR)	14266202	11 KV NAGAPUR BAZA	RURAL	AMI	0.638130	0.638130	0.436114	31.66%	47.91%	100%	
723	TPCODL	BBSR-01	NED		MADARANG (NAGAPUR)	14266203	11 KV MADARANGA	RURAL	AMI	0.820200	0.820200	0.434193	47.06%	64.04%	100%	
724	TPCODL	BBSR-02	KHD		SARUA ODSSP	14267202	11 KV SARUA (Sarua)	RURAL	AMI	0.436059	0.436059	0.365498	16.18%	31.69%	100%	
725	TPCODL	BBSR-02	KHD		SARUA ODSSP	14267203	11 KV PUBUSAHI	RURAL	AMI	1.353147	1.353147	0.777471	42.54%	53.59%	100%	
726	TPCODL	BBSR-02	KHD		SANARAJUA (MENDHASA	14268202	11 KV MENDHASAL-2	RURAL	AMI	1.052379	1.052379	0.570826	45.76%	59.12%	100%	
727	TPCODL	BBSR-02	KHD		SANARAJUA (MENDHASA	14268203	11 KV GIRINGAPUT	RURAL	AMI	0.994080	0.994080	0.899504	9.51%	16.11%	33%	
728	TPCODL	BBSR-02	KHD		GEDIAPALI ODSSP	14269203	11 KV GEDIAPALLI	RURAL	AMI	1.760016	1.760016	1.266634	28.03%	43.03%	100%	
729	TPCODL	BBSR-02	KHD		GEDIAPALI ODSSP	14269204	11 KV MANIBANDHA (M	RURAL	AMI	0.378630	0.378630	0.262491	30.67%	42.98%	100%	
730	TPCODL	BBSR-02	KHD		CHHATABAR ODSSP	14270201	11 KV JAMUJHARI	RURAL	AMI	1.209171	1.209171	0.953503	21.14%	34.54%	100%	
731	TPCODL	BBSR-02	KHD		CHHATABAR ODSSP	14270202	11 KV PANIORA	RURAL	AMI	1.573953	1.573953	0.991815	36.99%	44.72%	100%	
732	TPCODL	BBSR-02	KHD		CHHATABAR ODSSP	14270203	11 KV CHHATABAR IN	RURAL	AMI	2.409114	2.409114	2.196219	8.84%	11.95%	100%	
733	TPCODL	BBSR-02	KHD		JATANI NUAGAON ODSSI	14271201	11 KV Nuagaon	RURAL	AMI	2.053722	2.053722	1.727734	15.87%	32.92%	100%	
734	TPCODL	BBSR-02	KHD		JATANI NUAGAON ODSSI	14271202	11 KV BIKASH NAGAR	RURAL	AMI	0.918882	0.918882	0.584691	36.37%	51.30%	100%	
735	TPCODL	BBSR-02	KHD		(ATHATIRA) BALIPADA OD	14272201	SAHUPADA	RURAL	AMI	0.718083	0.718083	0.425239	40.78%	66.98%	100%	
736	TPCODL	BBSR-02	KHD		(ATHATIRA) BALIPADA OD	14272203	BALIPADA	RURAL	AMI	1.993914	1.993914	0.445876	77.64%	80.80%	100%	
737	TPCODL	BBSR-02	KHD		CHHANAGIRI ODSSP	14273201	11 KV CHHANAGIRI	RURAL	AMI	0.637095	0.637095	0.339730	46.68%	61.59%	100%	
738	TPCODL	BBSR-02	KHD		CHHANAGIRI ODSSP	14273202	11 KV HAJA(Chhanagir	RURAL	AMI	1.211223	1.211223	0.728242	39.88%	52.98%	100%	
739	TPCODL	BBSR-02	KHD		CHHANAGIRI ODSSP	14273203	11 KV SARAPARI	RURAL	AMI	0.331944	0.331944	0.195491	41.11%	51.85%	100%	
740	TPCODL	BBSR-02	KHD		CHHANAGIRI ODSSP	14273204	11 KV SIKO	RURAL	AMI	0.979479	0.979479	0.651332	33.50%	49.71%	100%	
741	TPCODL	BBSR-02	NYD		GODIPADA ODSSP	14274201	11 KV GODIPADA	RURAL	AMI	0.648495	0.648495	0.494432	23.76%	24.74%	100%	
742	TPCODL	BBSR-02	NYD		GODIPADA ODSSP	14274202	11 KV DAMASAHI	RURAL	AMI	0.629121	0.629121	0.427310	32.08%	30.31%	100%	
743	TPCODL	BBSR-02	NYD		GODIPADA ODSSP	14274203	11 KV NAGAMUNDULI	RURAL	AMI	0.629802	0.629802	0.460268	26.92%	36.83%	100%	
744	TPCODL	BBSR-02	NYD		GODIPADA ODSSP	14274204	11 KV KESHPANIA	RURAL	AMI	0.750411	0.750411	0.484184	35.48%	35.47%	67%	
745	TPCODL	BBSR-02	NYD		KURALA ODSSP	14275201	11 KV KURALA	RURAL	AMI	0.602181	0.602181	0.494836	17.83%	23.35%	100%	
746	TPCODL	BBSR-02	NYD		KURALA ODSSP	14275202	11 KV SUNAMUNHI	RURAL	AMI	0.546678	0.546678	0.489893	10.39%	20.57%	100%	
747	TPCODL	BBSR-02	NYD		KURALA ODSSP	14275203	11 KV KOMANDA	RURAL	AMI	0.939348	0.939348	0.845010	10.04%	11.02%	100%	
748	TPCODL	BBSR-02	NYD		DHALABANDHA ODSSP	14276201	11 KV RANICHELI	RURAL	AMI	0.640200	0.640200	0.459682	28.20%	28.69%	100%	
749	TPCODL	BBSR-02	NYD		DHALABANDHA ODSSP	14276202	11 KV BADASAHARA	RURAL	AMI	0.824886	0.824886	0.454060	44.95%	51.29%	100%	
750	TPCODL	BBSR-02	NYD		DHALABANDHA ODSSP	14276203	11 KV SALAPADA	RURAL	AMI	0.534318	0.534318	0.437749	18.07%	23.73%	100%	
751	TPCODL	BBSR-02	NYD		CHAMUNDIA ODSSP	14277201	11 KV CHHAMUNDIA	RURAL	AMI	0.158106	0.158106	0.110749	29.95%	44.64%	100%	
752	TPCODL	BBSR-02	NYD		CHAMUNDIA ODSSP	14277202	11 KV ISWARAPUR	RURAL	AMI	0.182139	0.182139	0.130537	28.33%	47.21%	100%	
753	TPCODL	BBSR-02	NYD		BALUGAON (PANIPOILA)	14278201	11 KV PANIPOILA	RURAL	AMI	0.937089	0.937089	0.508003	45.79%	49.16%	100%	
754	TPCODL	BBSR-02	NYD		BALUGAON (PANIPOILA)	14278202	11 KV MALISAHI	RURAL	AMI	0.582210	0.582210	0.511816	12.09%	18.58%	100%	

Sl No.	Zone	Received at Circle (In MU)	Received at Division (In MU)	Received at Sub-division (In MU)	Name of the Station	Feeder Code/ID	Feeder Name	Type of Feeder (Urban/Mixed/Industrial/Agricultural/Rural)	Type of feeder meter (AMI/AMR/Other)	Received at Feeder (Final in MU)	Feeder Consumption (In MU)	Final Net Export at Feeder Level (In MU)	T&D losses	AT&C losses	% Data Received through Automatically (if feeder AMR/AMI)	Remarks
755	TPCODL	BBSR-02	NYD		MACHHIPADA ODSSP	14279201	11 KV MACHHIPADA B	RURAL	AMI	0.726588	0.726588	0.493028	32.14%	36.17%	100%	
756	TPCODL	BBSR-02	NYD		MACHHIPADA ODSSP	14279202	11 KV KALYANPUR	RURAL	AMI	0.719172	0.719172	0.515102	28.38%	28.62%	100%	
757	TPCODL	BBSR-02	NYD		MACHHIPADA ODSSP	14279203	11 KV PALLISASAN	RURAL	AMI	0.748068	0.748068	0.556073	25.67%	30.52%	100%	
758	TPCODL	BBSR-02	NYD		BIJIPUR ODSSP	14280201	11 KV MARADA	RURAL	AMI	0.596400	0.596400	0.421549	29.32%	33.60%	100%	
759	TPCODL	BBSR-02	NYD		BIJIPUR ODSSP	14280202	11 KV KARA BARA	RURAL	AMI	1.240383	1.240383	0.929431	25.07%	36.10%	100%	
760	TPCODL	BBSR-02	NYD		BIJIPUR ODSSP	14280203	11 KV BIJIPUR	RURAL	AMI	0.748572	0.748572	0.588031	21.45%	28.90%	100%	
761	TPCODL	BBSR-02	NYD		BANIGOCHA(TAKUDA) OI	14281203	11 kV BANIGOCHHA	MIXED	AMI	0.290787	0.290787	0.213149	26.70%	40.76%	100%	
762	TPCODL	BBSR-02	NYD		BARAKOLI (KOTAPOKHAI	14282201	11 KV KHALISAHI	RURAL	AMI	0.953832	0.953832	0.723569	24.14%	20.45%	100%	
763	TPCODL	BBSR-02	NYD		BARAKOLI (KOTAPOKHAI	14282202	11 KV MARDARAJPUR	RURAL	AMI	0.559281	0.559281	0.493118	11.83%	38.92%	100%	
764	TPCODL	BBSR-02	NYD		BARAKOLI (KOTAPOKHAI	14282203	11 KV SINGHAPADA	RURAL	AMI	0.798804	0.798804	0.559811	29.92%	37.11%	100%	
765	TPCODL	BBSR-02	NYD		LATHIPADA ODSSP	14283201	11 KV LATHIPADA	RURAL	AMI	0.650832	0.650832	0.480959	26.10%	35.53%	100%	
766	TPCODL	BBSR-02	NYD		LATHIPADA ODSSP	14283202	11 KV NOTAR	RURAL	AMI	1.103538	1.103538	0.710308	35.63%	40.18%	100%	
767	TPCODL	BBSR-02	NYD		LATHIPADA ODSSP	14283203	11 KV RAJPATANA	RURAL	AMI	0.916491	0.916491	0.635684	30.64%	32.93%	100%	
768	TPCODL	BBSR-02	NYD		LATHIPADA ODSSP	14283204	11 KV GAMBHAIDIHI	RURAL	AMI	0.381312	0.381312	0.315376	17.29%	29.83%	100%	
769	TPCODL	BBSR-02	NYD		KIRIALANJI (SIMILISAHI) (	14284201	11 KV SIMILISAHI	RURAL	AMI	2.008053	2.008053	1.408711	29.85%	36.62%	100%	
770	TPCODL	BBSR-02	NYD		KIRIALANJI (SIMILISAHI) (	14284204	11 KV NUAPALLI	RURAL	AMI	0.098067	0.098067	0.060958	37.84%	41.41%	100%	
771	TPCODL	BBSR-02	NYD		HARIPUR (BAHADAJHOLA	14285201	11 KV BAHADAJHOLA	RURAL	AMI	0.763398	0.763398	0.548517	28.15%	31.45%	100%	
772	TPCODL	BBSR-02	NYD		HARIPUR (BAHADAJHOLA	14285202	11 KV BERUNHABADI	RURAL	AMI	0.372168	0.372168	0.286332	23.06%	24.46%	100%	
773	TPCODL	BBSR-02	BAED		GANGADHARAPUR ODSS	14286201	11 KV HATABARADI	RURAL	AMI	1.751190	1.751190	1.090216	37.74%	51.51%	67%	
774	TPCODL	BBSR-02	BAED		GANGADHARAPUR ODSS	14286202	11 KV BAULABANDHA	RURAL	AMI	1.270275	1.270275	0.902085	28.99%	37.45%	100%	
775	TPCODL	BBSR-02	BAED		KHANDISI ODSSP	14287201	11 KV MAHATPALLA	RURAL	AMI	1.258662	1.258662	0.676248	46.27%	56.75%	100%	
776	TPCODL	BBSR-02	BAED		KHANDISI ODSSP	14287203	11 KV NATIM	RURAL	AMI	0.097500	0.097500	0.072686	25.45%	43.93%	100%	
777	TPCODL	BBSR-02	PED		CHALISIBATIA ODSSP	14288201	11 KV CHALISBATIA	RURAL	AMI	1.200636	1.200636	0.879529	26.74%	38.26%	100%	
778	TPCODL	BBSR-02	PED		CHALISIBATIA ODSSP	14288202	11 KV BALIPUT	RURAL	AMI	1.241667	1.241667	0.689984	44.43%	58.08%	100%	
779	TPCODL	BBSR-02	PED		GABAKUNDA (SUANLO) (	14289201	11 KV KETAKIPATNA	RURAL	AMI	1.644525	1.644525	0.939144	42.89%	54.91%	100%	
780	TPCODL	BBSR-02	PED		GABAKUNDA (SUANLO) (	14289202	11 KV GUALIGORADA	MIXED	AMI	1.307604	1.307604	0.884087	32.39%	47.43%	100%	
781	TPCODL	BBSR-02	PED		ALGUM (SOMESWARPUF	14293201	11KV O/G INDIPUR	RURAL	AMI	0.978483	0.978483	0.642237	34.36%	46.70%	100%	
782	TPCODL	BBSR-02	PED		ALGUM (SOMESWARPUF	14293203	11KV O/G ALAGUM	RURAL	AMI	1.028400	1.028400	0.605244	41.15%	58.86%	100%	
783	TPCODL	BBSR-02	PED		KALAYANPUR ODSSP	14294201	11 KV CHANDOL	RURAL	AMI	0.132141	0.132141	0.088294	33.18%	53.23%	67%	
784	TPCODL	CUTTACK	CDD-2		KHAN NAGAR (BADAMBA	14296202	11 KV HARIPUR	URBAN	AMI	4.165914	4.165914	2.228185	46.51%	48.87%	100%	
785	TPCODL	CUTTACK	CDD-2		SOMAPUR ODSSP	14297202	11 KV TELDIA	MIXED	AMI	0.294831	0.294831	0.195832	33.58%	40.34%	100%	
786	TPCODL	CUTTACK	CED		PRATAP NAGARI (DAHAL	14298201	11KV PHULANAKHARA	RURAL	AMI	4.805298	4.805298	2.657813	44.69%	53.79%	100%	
787	TPCODL	CUTTACK	CED		PRATAP NAGARI (DAHAL	14298202	11KV PRATAP NAGAR	RURAL	AMI	6.985812	6.985812	6.549169	6.25%	23.01%	100%	
788	TPCODL	CUTTACK	CED		KAJALPUR ODSSP	14299201	11 KV NAHALPUR	RURAL	AMI	1.451829	1.451829	0.951333	34.47%	48.49%	100%	
789	TPCODL	CUTTACK	CED		KAJALPUR ODSSP	14299202	11 KV GOBINDPUR-II	RURAL	AMI	1.384563	1.384563	0.817268	40.97%	56.79%	100%	
790	TPCODL	CUTTACK	CED		KAIMATIA ODSSP	14301202	11 KV LOCAL	RURAL	AMI	0.215610	0.215610	0.108944	49.47%	58.84%	100%	
791	TPCODL	CUTTACK	CED		KULA KAPASI ODSSP	14302202	11 KV PODANA	RURAL	AMI	2.685735	2.685735	0.821047	69.43%	76.81%	33%	
792	TPCODL	CUTTACK	CED		KULA KAPASI ODSSP	14302203	11 KV PANIMALA	RURAL	AMI	2.364387	2.364387	1.205222	49.03%	62.82%	100%	
793	TPCODL	CUTTACK	CED		KUNDALA ODSSP	14303203	11 KV KADAMPAL	RURAL	AMI	2.108169	2.108169	0.640763	69.61%	76.66%	100%	
794	TPCODL	CUTTACK	AED		MARDAMEKHA ODSSP	14304201	11 KV KAMALADIHA	RURAL	AMI	1.089288	1.089288	0.800357	26.52%	26.11%	100%	
795	TPCODL	CUTTACK	AED		MARDAMEKHA ODSSP	14304202	11 KV SISUPATHAR	RURAL	AMI	0.367164	0.367164	0.326286	11.13%	21.34%	100%	
796	TPCODL	CUTTACK	AED		MARDAMEKHA ODSSP	14304204	11 KV ODASINGHA	RURAL	AMI	0.301503	0.301503	0.258635	14.22%	26.62%	100%	
797	TPCODL	CUTTACK	AED		GOPAPUR ODSSP	14305202	11 KV GOPAPUR LOC	RURAL	AMI	0.970200	0.970200	0.499303	48.54%	53.85%	100%	
798	TPCODL	CUTTACK	AED		GOPAPUR ODSSP	14305203	11 KV BHATTARIKA	RURAL	AMI	1.542258	1.542258	0.892617	42.12%	55.12%	100%	
799	TPCODL	CUTTACK	AED		SARANDA ODSSP	14306203	11 KV SARANDA	RURAL	AMI	0.029016	0.029016	0.018753	35.37%	56.34%	100%	
800	TPCODL	CUTTACK	AED		BANDALO (BAUNSAPUT)	14307203	11 KV BANDALO	RURAL	AMI	1.077606	1.077606	0.697889	35.24%	46.94%	100%	
801	TPCODL	CUTTACK	AED		DHOBANINALA ODSSP	14308203	11 KV BADABARSINGH	RURAL	AMI	1.057566	1.057566	0.633609	40.09%	47.98%	100%	
802	TPCODL	CUTTACK	SED		RAISUNGUDA (MODHAN(	14309202	11 KV DHARMAGATAP	RURAL	AMI	2.486301	2.486301	1.342792	45.99%	55.21%	100%	
803	TPCODL	CUTTACK	SED		RAISUNGUDA (MODHAN(	14309203	11 KV MANOHARPUR	RURAL	AMI	2.119731	2.119731	1.664463	21.48%	38.60%	100%	
804	TPCODL	CUTTACK	SED		ERAKANA (GOKUNA) ODS	14310201	11 KV LAXMINARAYAN	RURAL	AMI	1.988349	1.988349	1.069854	46.19%	55.29%	100%	
805	TPCODL	CUTTACK	SED		ERAKANA (GOKUNA) ODS	14310202	11 KV KURUJANGA	RURAL	AMI	2.052825	2.052825	1.398107	31.89%	39.93%	100%	
806	TPCODL	CUTTACK	SED		ERAKANA (GOKUNA) ODS	14310203	11 KV GOUDAGOPA	RURAL	AMI	1.253856	1.253856	0.754636	39.81%	45.41%	67%	
807	TPCODL	CUTTACK	SED		ASURESWAR ODSSP	14311201	11 KV SUKARPADA	RURAL	AMI	2.166597	2.166597	1.337988	38.24%	52.73%	100%	
808	TPCODL	CUTTACK	SED		ASURESWAR ODSSP	14311202	11 KV ASURESWAR	RURAL	AMI	1.914120	1.914120	1.210399	36.76%	48.44%	100%	
809	TPCODL	CUTTACK	SED		ASURESWAR ODSSP	14311203	11 KV LUNA	RURAL	AMI	2.156913	2.156913	1.208427	43.97%	58.15%	33%	
810	TPCODL	CUTTACK	SED		JAPAKUDA ODSSP	14312201	11 KV JAPAKUDA	RURAL	AMI	1.437960	1.437960	0.969522	32.58%	44.23%	100%	
811	TPCODL	CUTTACK	SED		JAPAKUDA ODSSP	14312202	11 KV BHIMDASPUR	RURAL	AMI	1.711887	1.711887	1.078633	36.99%	45.11%	100%	
812	TPCODL	CUTTACK	SED		JAPAKUDA ODSSP	14312203	11 KV RAMESWAR SC	RURAL	AMI	2.152980	2.152980	1.475857	31.45%	44.13%	100%	
813	TPCODL	DHENKANAL	DED		PANDUA ODSSP	14313201	11 KV SOGAR	RURAL	AMI	1.103671	1.103671	0.822483	25.48%	44.50%	67%	
814	TPCODL	DHENKANAL	DED		PANDUA ODSSP	14313202	11 KV ANLABERINI	RURAL	AMI	2.092875	2.092875	1.560313	25.45%	38.10%	100%	
815	TPCODL	DHENKANAL	DED		PANDUA ODSSP	14313203	11 KV KOTAGARA	RURAL	AMI	1.751259	1.751259	1.170216	33.18%	42.71%	100%	
816	TPCODL	DHENKANAL	DED		PANDUA ODSSP	14313204	11 KV BARUAN (Pandu	RURAL	AMI	0.890499	0.890499	0.751351	15.63%	28.63%	67%	
817	TPCODL	DHENKANAL	DED		BANASINGH ODSSP	14314201	11 KV CHAULIA	RURAL	AMI	0.692400	0.692400	0.549804	20.59%	29.62%	100%	
818	TPCODL	DHENKANAL	DED		BANASINGH ODSSP	14314204	11 KV BANASINGH	RURAL	AMI	1.192080	1.192080	1.139907	4.38%	16.16%	100%	
819	TPCODL	DHENKANAL	DED		MAHULPAL(BHUBAN) OD	14315202	11 KV EKATALI	RURAL	AMI	1.621659	1.621659	1.302975	19.65%	58.86%	100%	
820	TPCODL	DHENKANAL	DED		MAHULPAL(BHUBAN) OD	14315203	11 KV Murdanga	RURAL	AMI	0.582456	0.582456	0.430643	26.06%	47.91%	100%	
821	TPCODL	DHENKANAL	DED		MUKTAPASI ODSSP	14316201	11 KV Chaulia/Khamara	RURAL	AMI	2.857401	2.857401	0.514321	82.00%	85.35%	100%	
822	TPCODL	DHENKANAL	DED		MUKTAPASI ODSSP	14316203	11 KV Similia	RURAL	AMI	1.715943	1.715943	1.233211	28.13%	38.11%	67%	
823	TPCODL	DHENKANAL	DED		JIRIDAMALI ODSSP	14318201	11 KV BAISINGA	RURAL	AMI	2.391687	2.391687	1.519749	36.46%	55.42%	100%	
824	TPCODL	DHENKANAL	DED		JIRAL ODSSP	14319201	11 KV JIRAL	RURAL	AMI	1.937853	1.937853	1.203139	37.91%	43.85%	100%	
825	TPCODL	DHENKANAL	DED		JIRAL ODSSP	14319202	11 KV GUNEIEIBIL	RURAL	AMI	1.061697	1.061697	0.728719	31.36%	47.92%	100%	
826	TPCODL	DHENKANAL	DED		MANDAR (SADANGI) ODS	14320202	11 KV SADANGI	RURAL	AMI	0.547569	0.547569	0.405241	25.99%	40.31%	100%	
827	TPCODL	DHENKANAL	DED		MANDAR (SADANGI) ODS	14320203	11 KV MANDAR	RURAL	AMI	0.311184	0.311184	0.218352	29.83%	41.71%	100%	
828	TPCODL	DHENKANAL	DED		NUABAG (KODIBHANGA)	14321201	11 KV NUABAG	RURAL	AMI	0.561144	0.561144	0.429881	23.39%	36.58%	100%	
829	TPCODL	DHENKANAL	DED		NUABAG (KODIBHANGA)	14321202	11 KV Rasol (Nuabag)	RURAL	AMI	1.603161	1.603161	1.160418	27.62%	47.34%	100%	
830	TPCODL	DHENKANAL	DED		NUABAG (KODIBHANGA)	14321203	11 KV NAUKIARI	RURAL	AMI	1.642698	1.642698	1.150034	29.99%	43.78%	100%	
831	TPCODL	DHENKANAL	DED		GHATIPIRI ODSSP	14322201	11 KV KALANGA	RURAL	AMI	0.587400	0.587400	0.477946	18.63%	29.62%	100%	
832	TPCODL	DHENKANAL	DED		GHATIPIRI ODSSP	14322202	11 KV GHATIPIRI	RURAL	AMI	0.659955	0.659955	0.349343	47.07%	61.63%	100%	
833	TPCODL	DHENKANAL	DED		GHATIPIRI ODSSP	14322203	11 KV GOBINDAPRAS/	RURAL	AMI	2.193117	2.193117	1.566333	28.58%	36.45%	100%	
834	TPCODL	DHENKANAL	DED		BADALU (PADA) ODSSP	14323201	11 KV KURUMITHA	RURAL	AMI	0.968814	0.968814	0.636736	34.28%	45.33%	100%	
835	TPCODL	DHENKANAL	DED		BADALU (PADA) ODSSP	14323203	11 KV PATALA	RURAL	AMI	1.652016	1.652016	1.145316	30.67%	41.04%	100%	
836	TPCODL	DHENKANAL	DED		BIRASAL (RAHANI) ODSS	14324201	11 KV BIRASAL	RURAL	AMI	0.324300	0.324300	0.240124	25.96%	50.36%	100%	
837	TPCODL	DHENKANAL	DED		BIRASAL (RAHANI) ODSS	14324202	11 KV SENDHASAR	RURAL	AMI	0.378900	0.378900	0.257305	32.09%	62.24%	100%	
838	TPCODL	DHENKANAL	DED		BIRASAL (RAHANI) ODSS	14324203	11KV KHAJURIA	RURAL	AMI	0.668856	0.668856	0.502242	24.91%	45.51%	100%	

Sl No.	Zone	Received at Circle (In MU)	Received at Division (In MU)	Received at Sub-division (In MU)	Name of the Station	Feeder Code/ID	Feeder Name	Type of Feeder (Urban/Mixed/Industrial/Agricultural/Rural)	Type of feeder meter (AMI/AMR/Other)	Received at Feeder (Final in MU)	Feeder Consumption (In MU)	Final Net Export at Feeder Level (In MU)	T&D losses	AT&C losses	% Data Received through Automatically (if feeder AMR/AMI)	Remarks
839	TPCODL	DHENKANAL	ANED		DHAURAPALLI ODSSP	14325201	11 KV TALAPADAR	RURAL	AMI	0.423621	0.423621	0.333489	21.28%	38.09%	100%	
840	TPCODL	DHENKANAL	ANED		DHAURAPALLI ODSSP	14325202	11 KV RANIAKATA	RURAL	AMI	1.722422	1.722422	1.243991	27.78%	36.96%	100%	
841	TPCODL	DHENKANAL	ANED		DHAURAPALLI ODSSP	14325203	11 KV KADALIMUNDA	RURAL	AMI	0.301950	0.301950	0.233366	22.71%	33.26%	100%	
842	TPCODL	DHENKANAL	ANED		DHAURAPALLI ODSSP	14325204	11 KV KISHORENAGAI	RURAL	AMI	1.029516	1.029516	0.762104	25.97%	34.36%	100%	
843	TPCODL	DHENKANAL	ANED		KOSALA ODSSP	14326204	11 KV CHANDAN NAG.	RURAL	AMI	1.354437	1.354437	1.270634	6.19%	22.38%	100%	
844	TPCODL	DHENKANAL	ANED		KOSALA ODSSP	14326205	11 KV RWSS	RURAL	AMI	0.505190	0.505190	0.505132	0.01%	100.07%	100%	
845	TPCODL	DHENKANAL	ANED		NAKCHI ODSSP	14327201	11 KV BUDULIMUNDA	RURAL	AMI	0.519861	0.519861	0.393684	24.27%	35.42%	67%	
846	TPCODL	DHENKANAL	ANED		NAKCHI ODSSP	14327202	11 KV NAKCHI	RURAL	AMI	0.258762	0.258762	0.201157	22.26%	39.67%	100%	
847	TPCODL	DHENKANAL	ANED		NAKCHI ODSSP	14327203	11 KV URUKULA	RURAL	AMI	0.472989	0.472989	0.351153	25.76%	37.62%	100%	
848	TPCODL	DHENKANAL	ANED		KULAD (KANDASAR) ODS	14328201	11 KV NALCO TOWNS	RURAL	AMI	1.870500	1.870500	1.505623	19.51%	31.30%	100%	
849	TPCODL	DHENKANAL	ANED		KULAD (KANDASAR) ODS	14328202	11 KV NALCO MAIN GA	RURAL	AMI	0.987477	0.987477	0.744872	24.57%	35.55%	100%	
850	TPCODL	DHENKANAL	TED		SANDA ODSSP	14329201	11 KV SANDA	RURAL	AMI	0.799488	0.799488	0.550320	31.17%	44.34%	100%	
851	TPCODL	DHENKANAL	TED		SANDA ODSSP	14329202	11 KV PANI GENGUTIA	RURAL	AMI	0.599829	0.599829	0.398325	33.59%	52.99%	100%	
852	TPCODL	DHENKANAL	TED		MERAMUNDALI ODSSP	14330203	11 KV PURUNAKOT	RURAL	AMI	2.400276	2.400276	1.597984	33.42%	47.08%	100%	
853	TPCODL	DHENKANAL	TED		KALAMCHHUIN (DANRA)	14331202	11 KV KALAMCHHUIN	RURAL	AMI	3.280980	3.280980	1.447378	55.89%	58.62%	100%	
854	TPCODL	DHENKANAL	TED		KALAMCHHUIN (DANRA)	14331204	11 KV BADA JORADA	RURAL	AMI	0.139605	0.139605	0.099101	29.01%	58.47%	100%	
855	TPCODL	DHENKANAL	TED		KALAMCHHUIN (DANRA)	14331205	11 KV KHAJUTIA RWS	RURAL	AMI	0.578608	0.578608	0.430252	25.64%	100.06%	100%	
856	TPCODL	DHENKANAL	TED		KUNJAM ODSSP	14332201	11 KV INJIDI	RURAL	AMI	0.707364	0.707364	0.416173	41.17%	56.31%	100%	
857	TPCODL	DHENKANAL	TED		KUNJAM ODSSP	14332202	11 KV NUAGAON	RURAL	AMI	0.964794	0.964794	0.705006	26.93%	41.30%	100%	
858	TPCODL	DHENKANAL	TED		SARANGA ODSSP	14333201	11 KV JATIA	RURAL	AMI	0.421545	0.421545	0.284245	32.57%	45.68%	33%	
859	TPCODL	DHENKANAL	TED		HANUMANPUR ODSSP	14334201	11 KV BAJRAKOTE	RURAL	AMI	1.228797	1.228797	0.710703	42.16%	61.32%	67%	
860	TPCODL	DHENKANAL	TED		HANUMANPUR ODSSP	14334202	11 KV BAUDABEDA	RURAL	AMI	0.103488	0.103488	0.069026	33.30%	58.21%	100%	
861	TPCODL	DHENKANAL	TED		HANUMANPUR ODSSP	14334203	11 KV GUNDURI	RURAL	AMI	0.816048	0.816048	0.454437	44.31%	59.28%	100%	
862	TPCODL	DHENKANAL	TED		MAHABIR ROAD ODSSP	14336201	11 kV PANGATIRA	RURAL	AMI	0.526956	0.526956	0.354018	32.82%	48.34%	100%	
863	TPCODL	DHENKANAL	TED		MAHABIR ROAD ODSSP	14336202	11 kV MAHABIR ROAD	RURAL	AMI	0.346548	0.346548	0.293337	15.35%	30.27%	100%	
864	TPCODL	DHENKANAL	TED		MAHABIR ROAD ODSSP	14336203	GADAPALASUNI KUTU	RURAL	AMI	1.124370	1.124370	0.801182	28.74%	46.99%	100%	
865	TPCODL	DHENKANAL	TED		KANTALA ODSSP	14338201	11 KV JAMARDIHA	RURAL	AMI	0.266655	0.266655	0.169974	36.26%	51.31%	100%	
866	TPCODL	DHENKANAL	TED		KANTALA ODSSP	14338202	11 KV SIMILIPAL	RURAL	AMI	0.133170	0.133170	0.093629	29.69%	52.92%	100%	
867	TPCODL	DHENKANAL	TED		KANTALA ODSSP	14338203	11 KV JHARBEDA	RURAL	AMI	0.309786	0.309786	0.203121	34.43%	67.53%	100%	
868	TPCODL	DHENKANAL	TED		GODIBANDHA (BANARPA	14339201	11 KV DADRAHATI	RURAL	AMI	0.304305	0.304305	0.185603	39.01%	58.86%	100%	
869	TPCODL	DHENKANAL	TED		GODIBANDHA (BANARPA	14339203	11 KV JHARANABAHAI	RURAL	AMI	0.299577	0.299577	0.232299	22.46%	46.85%	100%	
870	TPCODL	DHENKANAL	TED		GODIBANDHA (BANARPA	14339204	11 KV BHEJIA	RURAL	AMI	0.890793	0.890793	0.622912	30.07%	47.08%	100%	
871	TPCODL	PARADEEP	PDP		JAGANNATHPUR ODSSP	14340201	11 KV JAGANNATHPU	RURAL	AMI	1.395936	1.395936	1.005916	27.94%	35.80%	100%	
872	TPCODL	PARADEEP	PDP		JAGANNATHPUR ODSSP	14340202	11 KV DIHASAHI	RURAL	AMI	1.402386	1.402386	1.016101	27.54%	33.29%	100%	
873	TPCODL	PARADEEP	PDP		JAGANNATHPUR ODSSP	14340203	11 KV TULANGA FEED	MIXED	AMI	0.720212	0.720212	0.578107	19.73%	25.77%	100%	
874	TPCODL	PARADEEP	PDP		KANAKPUR ODSSP	14341201	11 KV KANAKPUR-2(K	RURAL	AMI	1.647516	1.647516	1.345482	18.33%	27.22%	100%	
875	TPCODL	PARADEEP	PDP		KANAKPUR ODSSP	14341202	11 KV GOVINDAPUR(K	RURAL	AMI	1.362567	1.362567	1.078193	20.87%	30.06%	100%	
876	TPCODL	PARADEEP	PDP		KANAKPUR ODSSP	14341203	11 KV MULISINGH	RURAL	AMI	1.805316	1.805316	1.250574	30.73%	39.51%	100%	
877	TPCODL	PARADEEP	PDP		TRILOCHANPUR ODSSP	14342201	11 KV DHINKIA	RURAL	AMI	3.303104	3.303104	2.137335	35.29%	53.22%	100%	
878	TPCODL	PARADEEP	PDP		TRILOCHANPUR ODSSP	14342202	11 KV TRILOCHANPUF	RURAL	AMI	0.283038	0.283038	0.146805	48.13%	58.37%	100%	
879	TPCODL	PARADEEP	PDP		TRILOCHANPUR ODSSP	14342203	11 KV SANDHAKUDA	RURAL	AMI	1.608976	1.608976	0.825710	48.68%	39.77%	100%	
880	TPCODL	PARADEEP	PDP		GADA BISHNUPUR ODSS	14343201	11 KV PADMAPUR	RURAL	AMI	1.790316	1.790316	0.973884	45.60%	54.17%	100%	
881	TPCODL	PARADEEP	PDP		GADA BISHNUPUR ODSS	14343202	11 KV GODA	RURAL	AMI	1.036446	1.036446	0.767722	25.93%	41.89%	100%	
882	TPCODL	PARADEEP	PDP		GADA BISHNUPUR ODSS	14343203	11 KV AMBIKI-2	RURAL	AMI	1.321386	1.321386	0.864124	34.60%	44.91%	100%	
883	TPCODL	PARADEEP	PDP		GORADA ODSSP	14344201	11 KV PANDUA	RURAL	AMI	1.163799	1.163799	0.919682	20.98%	39.34%	100%	
884	TPCODL	PARADEEP	PDP		GORADA ODSSP	14344202	11 KV BAILO	RURAL	AMI	0.670320	0.670320	0.496688	25.90%	34.51%	100%	
885	TPCODL	PARADEEP	PDP		GORADA ODSSP	14344203	11 KV NUAPOKHARI	RURAL	AMI	2.094192	2.094192	1.546893	26.13%	40.81%	100%	
886	TPCODL	PARADEEP	PDP		KRISHNANDAPUR (SIBAF	14345203	11 KV DIGABARINI	RURAL	AMI	0.495735	0.495735	0.383780	22.58%	30.79%	100%	
887	TPCODL	PARADEEP	PDP		KRISHNANDAPUR (SIBAF	14345204	11 KV MANAPUR	RURAL	AMI	0.989154	0.989154	0.518303	47.60%	54.46%	100%	
888	TPCODL	PARADEEP	PDP		KOTHI (JHIMANI) ODSSP	14346202	11 KV BAGADIA	RURAL	AMI	0.447549	0.447549	0.250291	44.08%	58.80%	100%	
889	TPCODL	PARADEEP	KED-01		CHAUDAKULATA ODSSP	14347201	11 KV GHAGARA	RURAL	AMI	0.790149	0.790149	0.545810	30.92%	51.27%	67%	
890	TPCODL	PARADEEP	KED-01		CHAUDAKULATA ODSSP	14347202	11 KV CHOUDAKULAT	RURAL	AMI	1.244148	1.244148	1.000506	19.58%	43.32%	100%	
891	TPCODL	PARADEEP	KED-01		BADADIA ODSSP	14348201	11 KV ISWARPUR(BAD	RURAL	AMI	1.748424	1.748424	1.212011	30.68%	43.46%	100%	
892	TPCODL	PARADEEP	KED-01		BADADIA ODSSP	14348202	11 KV TALCHUA	RURAL	AMI	4.068957	4.068957	1.751834	56.95%	65.28%	100%	
893	TPCODL	PARADEEP	KED-01		MADHUBANA ODSSP	14349201	11 KV GOVINDPUR (M	RURAL	AMI	1.268442	1.268442	0.980114	22.73%	39.19%	100%	
894	TPCODL	PARADEEP	KED-01		MADHUBANA ODSSP	14349202	11 KV MAHARAKULA	RURAL	AMI	0.748236	0.748236	0.563535	24.68%	39.42%	100%	
895	TPCODL	PARADEEP	KED-01		JAHARA BARIMUL (D.K.BI	14350201	11 KV Feeder-3 (Bholo)	RURAL	AMI	0.895479	0.895479	0.539254	39.78%	48.05%	100%	
896	TPCODL	PARADEEP	KED-01		JAHARA BARIMUL (D.K.BI	14350202	11 KV Feeder-1 (Jahara	RURAL	AMI	0.641187	0.641187	0.366840	42.79%	51.03%	100%	
897	TPCODL	PARADEEP	KED-01		CHOKADA ODSSP	14351201	11 KV KANSAR	RURAL	AMI	2.517300	2.517300	2.401955	4.58%	26.16%	100%	
898	TPCODL	PARADEEP	KED-01		CHOKADA ODSSP	14351202	11 KV BALDEVJEW	RURAL	AMI	0.649308	0.649308	0.492207	24.20%	42.79%	100%	
899	TPCODL	PARADEEP	KED-01		CHOKADA ODSSP	14351203	11 KV BLOCK	RURAL	AMI	2.866800	2.866800	2.173778	24.17%	33.81%	100%	
900	TPCODL	PARADEEP	KED-01		AYATAN ODSSP	14352201	11 KV AYATAN	RURAL	AMI	3.444096	3.444096	2.667108	22.56%	33.77%	100%	
901	TPCODL	PARADEEP	KED-01		AYATAN ODSSP	14352202	11 KV JAYNAGAR	RURAL	AMI	3.462015	3.462015	2.303595	33.46%	47.19%	67%	
902	TPCODL	PARADEEP	KED-01		AYATAN ODSSP	14352203	11 KV NAHULIA	RURAL	AMI	1.108761	1.108761	0.863827	22.09%	41.94%	100%	
903	TPCODL	PARADEEP	KED-01		KHAMAR KESHPUR ODS:	14353201	11 KV KORO	RURAL	AMI	1.438770	1.438770	0.925921	35.64%	52.51%	100%	
904	TPCODL	PARADEEP	KED-01		KHAMAR KESHPUR ODS:	14353202	11 KV BARO	RURAL	AMI	1.106289	1.106289	0.808860	26.89%	38.20%	100%	
905	TPCODL	PARADEEP	KED-01		KHAMAR KESHPUR ODS:	14353203	11 KV JAJANGA	RURAL	AMI	0.533940	0.533940	0.336585	36.96%	45.71%	100%	
906	TPCODL	PARADEEP	KED-02		GAUDAGAON ODSSP	14354201	11 KV KARILOPATANA	RURAL	AMI	2.249187	2.249187	1.545658	31.28%	42.59%	100%	
907	TPCODL	PARADEEP	KED-02		GAUDAGAON ODSSP	14354202	11KV KARANDIAPATAI	MIXED	AMI	1.209417	1.209417	0.608116	49.72%	61.06%	100%	
908	TPCODL	PARADEEP	KED-02		THAURI ODSSP	14355201	11 KV KURTANGA	RURAL	AMI	1.328100	1.328100	0.959075	27.79%	41.88%	100%	
909	TPCODL	PARADEEP	KED-02		THAURI ODSSP	14355202	11 KV ORATGHAT	RURAL	AMI	1.348617	1.348617	1.059170	21.46%	45.22%	100%	
910	TPCODL	PARADEEP	KED-02		BEDARI ODSSP	14356201	11 KV ANTAI	RURAL	AMI	2.040414	2.040414	1.328687	34.88%	45.55%	100%	
911	TPCODL	PARADEEP	KED-02		BEDARI ODSSP	14356202	11 KV PATKURA	RURAL	AMI	1.363977	1.363977	1.081586	20.70%	32.45%	100%	
912	TPCODL	PARADEEP	JED		DERIK-GANGADA ODSSF	14357201	11 KV DERIKI	RURAL	AMI	0.364110	0.364110	0.265887	26.98%	44.40%	100%	
913	TPCODL	PARADEEP	JED		DERIK-GANGADA ODSSF	14357202	11 KV SALAJANGA	RURAL	AMI	0.762336	0.762336	0.528609	30.66%	43.79%	100%	
914	TPCODL	PARADEEP	JED		DERIK-GANGADA ODSSF	14357203	11 KV TIRUNA	RURAL	AMI	0.613011	0.613011	0.429186	29.99%	41.11%	100%	
915	TPCODL	PARADEEP	JED		DERIK-GANGADA ODSSF	14357204	11 KV MUTUNIA	RURAL	AMI	0.499155	0.499155	0.324639	34.96%	41.21%	100%	
916	TPCODL	PARADEEP	JED		DUVALO (BORIKINA) ODS	14358201	11 KV BORIKINA	RURAL	AMI	1.125531	1.125531	0.827173	26.51%	35.50%	100%	
917	TPCODL	PARADEEP	JED		DUVALO (BORIKINA) ODS	14358203	11 KV TITIRA	RURAL	AMI	0.807810	0.807810	0.559376	30.75%	34.28%	100%	
918	TPCODL	PARADEEP	JED		BALIA (ADHANGA) ODSSI	14359201	11 KV SIBAPUR	RURAL	AMI	0.211374	0.211374	0.148005	29.98%	44.59%	100%	
919	TPCODL	PARADEEP	JED		BALIA (ADHANGA) ODSSI	14359202	11 KV ADHANGA (BAL	RURAL	AMI	0.904641	0.904641	0.699410	22.69%	33.95%	33%	
920	TPCODL	PARADEEP	JED		BALIA (ADHANGA) ODSSI	14359203	11 KV JAYSOL	RURAL	AMI	0.695700	0.695700	0.535464	23.03%	27.62%	100%	
921	TPCODL	PARADEEP	JED		BALIA (ADHANGA) ODSSI	14359204	11 KV BALIA	RURAL	AMI	1.106784	1.106784	0.964982	12.81%	17.80%	100%	
922	TPCODL	PARADEEP	JED		BHATAPADA ODSSP	14360201	11 KV DEVIDOLA	RURAL	AMI	1.297743	1.297743	0.938642	27.67%	35.58%	100%	

Sl No.	Zone	Received at Circle (In MU)	Received at Division (In MU)	Received at Sub-division (In MU)	Name of the Station	Feeder Code/ID	Feeder Name	Type of Feeder (Urban/Mixed/Industrial/Agricultural/Rural)	Type of feeder meter (AMI/AMR/Other)	Received at Feeder (Final in MU)	Feeder Consumption (In MU)	Final Net Export at Feeder Level (In MU)	T&D losses	AT&C losses	% Data Received through Automatically (if feeder AMR/AMI)	Remarks
923	TPCODL	PARADEEP	JED		BHATAPADA ODSSP	14360202	11 KV KHAIRA	RURAL	AMI	2.228484	2.228484	1.905397	14.50%	24.08%	100%	
924	TPCODL	PARADEEP	JED		DUSBATIA ODSSP	14361201	11 KV NAHARANA	RURAL	AMI	0.872346	0.872346	0.555334	36.34%	43.32%	100%	
925	TPCODL	PARADEEP	JED		DUSBATIA ODSSP	14361202	11 KV BANDAR	RURAL	AMI	0.750495	0.750495	0.524088	30.17%	34.66%	100%	
926	TPCODL	PARADEEP	JED		DUSBATIA ODSSP	14361203	11 KV Tentulibelari	RURAL	AMI	0.797994	0.797994	0.541874	32.10%	40.33%	100%	
927	TPCODL	PARADEEP	JED		BARANGA (MARKANDAPU	14362202	11 KV MANGALPUR	RURAL	AMI	1.362780	1.362780	0.956150	29.84%	40.81%	100%	
928	TPCODL	PARADEEP	JED		BARANGA (MARKANDAPU	14362203	11 KV JANKOTHI	RURAL	AMI	1.418172	1.418172	0.812562	42.70%	47.10%	100%	
929	TPCODL	PARADEEP	JED		CHIKINIA (ERANDAPAL) C	14363201	11 KV TARAPUR	RURAL	AMI	1.692636	1.692636	1.177889	30.41%	40.72%	100%	
930	TPCODL	PARADEEP	JED		CHIKINIA (ERANDAPAL) C	14363202	11 KV REDHUA	RURAL	AMI	0.575553	0.575553	0.421828	26.71%	37.80%	100%	
931	TPCODL	BBSR-02	PED		BASUDEIPUR	14364201	11 KV BASUDEIPUR	RURAL	AMI	1.080642	1.080642	0.598108	44.65%	55.23%	100%	
932	TPCODL	CUTTACK	SED		BAHUGRAM-1	14366201	11 KV BAHUGRAM-1 G	RURAL	AMI	2.408518	2.408518	1.654195	31.32%	41.88%	100%	
933	TPCODL	CUTTACK	SED		BAHUGRAM-1	14366202	11 KV BAHUGRAM-1 IC	RURAL	AMI	1.524978	1.524978	0.687893	54.89%	61.16%	100%	
934	TPCODL	BBSR-01	BCDD-02		TRISHULIA	14367201	11 KV NARANPUR	MIXED	AMI	2.378259	2.378259	2.053921	13.64%	19.11%	100%	
935	TPCODL	BBSR-01	BCDD-02		TRISHULIA	14367203	11 KV MUNDAMUHAN	MIXED	AMI	1.911885	1.911885	1.630724	14.71%	24.27%	100%	
936	TPCODL	BBSR-01	BCDD-02		TRISHULIA	14367204	11 KV MADHUPUR	MIXED	AMI	2.073978	2.073978	1.885082	9.11%	13.77%	100%	
937	TPCODL	CUTTACK	CDD-2		OSAP	14368201	11 KV DIVINE NAGAR	URBAN	AMI	3.386352	3.386352	2.330034	31.19%	34.02%	67%	
938	TPCODL	BBSR-01	BED		PANDRA	14370201	11 KV PRACHI	URBAN	AMI	4.048296	4.048296	2.954427	27.02%	31.87%	100%	
939	TPCODL	BBSR-01	BED		PANDRA	14370202	11 KV JAGANNATH NA	URBAN	AMI	0.890406	0.890406	0.659453	25.94%	23.20%	100%	
940	TPCODL	BBSR-01	BED		PANDRA	14370203	11 KV PANDRA VILLAG	URBAN	AMI	4.540482	4.540482	4.266721	6.03%	6.12%	100%	
941	TPCODL	BBSR-01	BED		PANDRA	14370208	11 KV JAGANNATH NA	URBAN	AMI	3.354104	3.354104	2.250623	32.90%	32.02%	100%	
942	TPCODL	BBSR-02	BAED		INS, CHILIKA/NAVAL	14371202	11 KV SUBUDHIPATNA	RURAL	AMI	0.517087	0.517087	0.369966	28.45%	31.47%	100%	
943	TPCODL	DHENKANAL	TED		TALCHER-2 NTPC	14375201	11 KV TALCHER PALA	RURAL	AMI	5.189082	5.189082	1.664180	67.93%	77.65%	100%	
944	TPCODL	DHENKANAL	TED		TALCHER-2 NTPC	14375202	11 KV BANTOL	RURAL	AMI	2.289051	2.289051	1.257554	45.06%	54.62%	100%	
945	TPCODL	DHENKANAL	TED		TALCHER-2 NTPC	14375203	11 KV HANDIDHUA	RURAL	AMI	2.465697	2.465697	1.502586	39.06%	47.43%	100%	
946	TPCODL	BBSR-02	KHD		SEA FOOD PARK DEPOS	14376201	11 KV Feeder-1	RURAL	AMI	1.467876	1.467876	1.424431	2.96%	8.03%	100%	
947	TPCODL	CUTTACK	CDD-1		RANIHAT	14378201	11 KV OGFED-1	URBAN	AMI	0.743340	0.743340	0.713434	4.02%	37.45%	100%	
948	TPCODL	CUTTACK	CDD-1		RANIHAT	14378204	11 KV OGFED-4	URBAN	AMI	1.179556	1.179556	0.670721	43.14%	45.40%	100%	
949	TPCODL	BBSR-02	BAED		SOLARI	14380202	11 KV DHUANLA	RURAL	AMI	0.980097	0.980097	0.677339	30.89%	39.51%	100%	
950	TPCODL	BBSR-02	KHD		EMC PARK	14381202	11 KV SANTI SOLAR	MIXED	AMI	1.031982	1.031982	0.887582	13.99%	27.82%	100%	
951	TPCODL	PARADEEP	KED-02		CHHAPALI	14382202	11KV RAM NAGAR	RURAL	AMI	3.166714	3.166714	2.282452	27.92%	36.35%	100%	
952	TPCODL	BBSR-01	BCDD-01		SHANTI PALLI	14384201	11KV BHAWANI MALL	URBAN	AMI	1.943816	1.943816	1.376513	29.18%	35.59%	100%	
953	TPCODL	BBSR-01	BCDD-01		SHANTI PALLI	14384204	11KV MAHARSHI COLI	URBAN	AMI	1.445508	1.445508	1.054795	27.03%	27.73%	100%	
954	TPCODL	BBSR-01	BED		NAGESWAR TANGI	14398201	11KV GOURI NAGAR	URBAN	AMI	1.039025	1.039025	0.991150	4.61%	7.14%	100%	
955	TPCODL	BBSR-01	BED		NAGESWAR TANGI	14398203	11KV RAMAKRISHNA M	URBAN	AMI	2.187402	2.187402	2.139907	2.17%	5.81%	100%	
956	TPCODL	BBSR-01	BCDD-01		BHUBANESWAR	17001403	FDR-3	33kV	AMI	14.29188	14.12818	0.163704	1.15%		100%	
957	TPCODL	BBSR-01	BCDD-01		UNIT8 GIS	17043401	UNIT8 FDR 4	33kV	AMI	13.11258	13.10976	0.002814	0.02%		100%	
958	TPCODL	BBSR-01	BCDD-01		UNIT8 GIS	17043402	UNIT8 FDR 5	33kV	AMI	19.78910	19.77271	0.016384	0.08%		100%	
959	TPCODL	BBSR-01	BCDD-01		UNIT8 GIS	17043403	SECRETERIAT 2	33kV	AMI	0.01049	0.01049	0.000000	0.00%		100%	
960	TPCODL	BBSR-01	BCDD-01		UNIT8 GIS	17043404	UNIT-6 GIS-1	33kV	AMI	7.61348	7.46255	0.150937	1.98%		67%	
961	TPCODL	BBSR-01	BCDD-01		UNIT8 GIS	17043405	UNIT-6 GIS-2	33kV	AMI	18.12649	17.92338	0.203104	1.12%		100%	
962	TPCODL	BBSR-01	BCDD-01		SATYANAGAR GIS	17077401	SHANTIPALLI	33kV	AMI	3.57017	3.44754	0.122635	3.43%		33%	Merged-1
963	TPCODL	BBSR-01	BCDD-01		SATYANAGAR GIS	17077402	BAPUJI NAGAR	33kV	AMI				3.43%		33%	Merged-1
964	TPCODL	BBSR-01	BCDD-01		SATYANAGAR GIS	17077403	SATYANAGAR-01 AIS	33kV	AMI				3.43%		33%	Merged-1
965	TPCODL	BBSR-01	BCDD-01		SATYANAGAR GIS	17077404	KHARVEL NAGAR UG	33kV	AMI				3.43%		33%	Merged-1
966	TPCODL	BBSR-01	BCDD-02		BHUBANESWAR	17001401	FDR-1	33kV	AMI	22.59963	22.47729	0.122343	0.54%		100%	
967	TPCODL	BBSR-01	BCDD-02		BHUBANESWAR	17001402	FDR-2	33kV	AMI	23.24061	23.04460	0.196008	0.84%		100%	
968	TPCODL	BBSR-01	BCDD-02		BHUBANESWAR	17001404	FDR-4	33kV	AMI	18.14572	18.08708	0.058639	0.32%		100%	
969	TPCODL	BBSR-01	BCDD-02		BHUBANESWAR	17001405	FDR-5	33kV	AMI	14.48496	13.99356	0.491398	3.39%		100%	
970	TPCODL	BBSR-01	BCDD-02		BHUBANESWAR	17001408	FDR-8(RAILWAY)	33kV	AMI	0.30878	0.29696	0.011827	3.83%		100%	
971	TPCODL	BBSR-01	BCDD-02		BHUBANESWAR	17001409	FDR-9(RAILWAY)	33kV	AMI	3.97989	3.79632	0.183568	4.61%		100%	
972	TPCODL	BBSR-01	BCDD-02		BHUBANESWAR	17001410	VANIVIHAR	33kV	AMI	8.06667	8.06442	0.002256	0.03%		100%	
973	TPCODL	BBSR-01	BCDD-02		BHUBANESWAR	17001411	NBCC	33kV	AMI	14.57882	13.88908	0.689747	4.73%		100%	
974	TPCODL	BBSR-01	BCDD-02		CHANDAKA A	17002401	UNIT-8 FDR-1	33kV	AMI	5.56447	5.52813	0.036340	0.65%		100%	
975	TPCODL	BBSR-01	BCDD-02		CHANDAKA A	17002402	UNIT-8 FDR-2 (RAJBHA	33kV	AMI	10.26051	10.19650	0.064011	0.62%		100%	
976	TPCODL	BBSR-01	BCDD-02		CHANDAKA A	17002403	CHANDRASEKHARPU	33kV	AMI	18.61090	18.28359	0.327310	1.76%		100%	
977	TPCODL	BBSR-01	BCDD-02		CHANDAKA A	17002404	CHANDRASEKHARPU	33kV	AMI	25.81403	25.50770	0.306329	1.19%		100%	
978	TPCODL	BBSR-01	BCDD-02		CHANDAKA A	17002405	NAYAPALLI	33kV	AMI	8.60660	8.54915	0.057453	0.67%		100%	
979	TPCODL	BBSR-01	BCDD-02		CHANDAKA A	17002406	XAVIER	33kV	AMI	27.75362	27.58168	0.171933	0.62%		100%	
980	TPCODL	BBSR-01	BCDD-02		CHANDAKA A	17002407	BARANGA	33kV	AMI	10.36051	10.22600	0.134511	1.30%		67%	
981	TPCODL	BBSR-01	BCDD-02		CHANDAKA A	17002408	NARAJ	33kV	AMI	0.44096	0.43823	0.002734	0.62%		100%	
982	TPCODL	BBSR-01	BCDD-02		CHANDAKA A	17002409	TCS	33kV	AMI	0.78980	0.78567	0.004134	0.52%		33%	
983	TPCODL	BBSR-01	BCDD-02		CHANDAKA A	17002410	KIIT	33kV	AMI	13.16897	13.03815	0.130824	0.99%		100%	
984	TPCODL	BBSR-01	BCDD-02		CHANDAKA A	17002411	SJ DEVELOPER	33kV	AMI	2.75776	2.74489	0.012869	0.47%		33%	
985	TPCODL	BBSR-01	BCDD-02		CHANDAKA A	17002412	INFOCITY	33kV	AMI	15.60597	15.14900	0.456975	2.93%		100%	
986	TPCODL	BBSR-01	BCDD-02		CHANDAKA A	17002413	DAV	33kV	AMI	7.17310	7.05278	0.120319	1.68%		100%	
987	TPCODL	BBSR-01	BCDD-02		RANASINGHPUR	17003401	NAYAPALLI	33kV	AMI	25.46469	24.95427	0.510417	2.00%		100%	
988	TPCODL	BBSR-01	BCDD-02		RANASINGHPUR	17003402	BARAMUNDA	33kV	AMI	18.71442	18.43970	0.274726	1.47%		100%	
989	TPCODL	BBSR-01	BCDD-02		RANASINGHPUR	17003403	BHIMATANGI - I	33kV	AMI	25.25107	24.81680	0.434267	1.72%		100%	
990	TPCODL	BBSR-01	BCDD-02		RANASINGHPUR	17003404	BHIMATANGI - II / BAR	33kV	AMI	17.19203	16.76709	0.424946	2.47%		67%	
991	TPCODL	BBSR-01	BCDD-02		RANASINGHPUR	17003405	AIIMS NO-I	33kV	AMI	0.70952	0.70193	0.007590	1.07%		100%	
992	TPCODL	BBSR-01	BCDD-02		RANASINGHPUR	17003406	AIIMS NO-II	33kV	AMI	6.26883	6.20183	0.067002	1.07%		100%	
993	TPCODL	BBSR-01	BCDD-02		RANASINGHPUR	17003407	ASOTECH	33kV	AMI	15.36736	15.06065	0.306710	2.00%		100%	
994	TPCODL	BBSR-01	BCDD-02		RANASINGHPUR	17003409	VIPUL	33kV	AMI	21.94670	21.64625	0.300448	1.37%		100%	
995	TPCODL	BBSR-01	BCDD-02		RANASINGHPUR	17003410	RANASINGHPUR	33kV	AMI	10.45212	10.44821	0.003911	0.04%		100%	
996	TPCODL	BBSR-01	BCDD-02		MENDHASAL	17008402	GOTHAPATANA	33kV	AMI	6.34877	6.30557	0.043204	0.68%		67%	
997	TPCODL	BBSR-01	BCDD-02		CHANDAKAB GIS	17060401	CHANDAKA IDCO	33kV	AMI	14.75412	14.28773	0.466397	3.16%		100%	
998	TPCODL	BBSR-01	BCDD-02		CHANDAKAB GIS	17060402	SAILASHREE VIHAR	33kV	AMI	3.17839	3.13541	0.042979	1.35%		100%	
999	TPCODL	BBSR-01	BCDD-02		CHANDAKAB GIS	17060403	SAPIGEN	33kV	AMI	4.44031	4.36047	0.079847	1.80%		100%	
1000	TPCODL	BBSR-01	BCDD-02		CHANDAKAB GIS	17060404	UNIT 8 FDR-03	33kV	AMI	12.77514	12.54158	0.233556	1.83%		100%	
1001	TPCODL	BBSR-01	BCDD-02		CHANDAKAB GIS	17060405	KISS	33kV	AMI	4.56509	4.56509	0.000000	0.00%		100%	
1002	TPCODL	BBSR-01	BCDD-02		GODISAHI GIS	17064401	ASTAL PIPES	33kV	AMI	33.16354	32.77212	0.391419	1.18%		100%	Merged-2
1003	TPCODL	BBSR-01	BCDD-02		GODISAHI GIS	17064402	GOVINDPUR	33kV	AMI				1.18%		100%	Merged-2
1004	TPCODL	BBSR-01	BCDD-02		GODISAHI GIS	17064403	REVENUE	33kV	AMI				1.18%		100%	Merged-2
1005	TPCODL	BBSR-01	BCDD-02		GODISAHI GIS	17064404	RAMSADPUR	33kV	AMI				1.18%		100%	Merged-2
1006	TPCODL	BBSR-01	BCDD-02		GODISAHI GIS	17064405	WATCO	33kV	AMI				1.18%		100%	Merged-2

Sl No.	Zone	Received at Circle (In MU)	Received at Division (In MU)	Received at Sub-division (In MU)	Name of the Station	Feeder Code/ID	Feeder Name	Type of Feeder (Urban/Mixed/Industrial/Agricultural/Rural)	Type of feeder meter (AMI/AMR/Other)	Received at Feeder (Final in MU)	Feeder Consumption (In MU)	Final Net Export at Feeder Level (In MU)	T&D losses	AT&C losses	% Data Received through Automatically (if feeder AMR/AMI)	Remarks
1007	TPCODL	BBSR-01	BCDD-02		KANTABADA GIS	17066401	KURL-ON	33kV	AMI	11.11023	10.88388	0.226352	2.04%		100%	
1008	TPCODL	BBSR-01	BCDD-02		KANTABADA GIS	17066402	GOTHAPATANA EXPR	33kV	AMI	16.48896	16.34896	0.140002	0.85%		100%	
1009	TPCODL	BBSR-01	BCDD-02		NAYAPALLI GIS	17071401	NAYAPALL1-1	33kV	AMI	21.09463	20.81061	0.284018	1.35%		100%	
1010	TPCODL	BBSR-01	BCDD-02		NAYAPALLI GIS	17071402	NAYAPALL1-2	33kV	AMI	12.32098	12.12575	0.195223	1.58%		100%	
1011	TPCODL	BBSR-01	BCDD-02		NAYAPALLI GIS	17071403	BARAMUNDA	33kV	AMI	22.03284	21.92758	0.105260	0.48%		100%	
1012	TPCODL	BBSR-01	BCDD-02		NAYAPALLI GIS	17071404	BHARATPUR	33kV	AMI	24.47589	24.08119	0.394704	1.61%		100%	
1013	TPCODL	BBSR-01	BED		BHUBANESWAR	17001406	FDR-6	33kV	AMI	20.77804	20.22607	0.551970	2.66%		100%	
1014	TPCODL	BBSR-01	BED		BHUBANESWAR	17001407	FDR-7	33kV	AMI	9.80014	9.53854	0.261595	2.67%		100%	
1015	TPCODL	BBSR-01	BED		KESURA	17004401	BALAKATI	33kV	AMI	16.47362	16.07099	0.402634	2.44%		100%	
1016	TPCODL	BBSR-01	BED		KESURA	17004402	SBI KESURA	33kV	AMI	17.09435	17.04480	0.049554	0.29%		100%	
1017	TPCODL	BBSR-01	BED		KESURA	17004403	LAXMISAGAR (FDR-I)	33kV	AMI	26.40764	26.00823	0.399402	1.51%		100%	
1018	TPCODL	BBSR-01	BED		KESURA	17004404	RASULGARH(FDR-II)	33kV	AMI	27.11164	26.66289	0.448748	1.66%		100%	
1019	TPCODL	BBSR-01	BED		KESURA	17004405	LINGIPUR	33kV	AMI	3.09427	3.08079	0.013480	0.44%		100%	
1020	TPCODL	BBSR-01	BED		PHULNAKAHARA	17022403	PHULNAKAHARA	33kV	AMI	13.02320	12.65473	0.368474	2.83%		100%	
1021	TPCODL	BBSR-01	BED		PHULNAKAHARA	17022404	BANAMALIPUR	33kV	AMI	7.95437	7.80205	0.152320	1.91%		100%	
1022	TPCODL	BBSR-01	BED		PHULNAKAHARA	17022405	BHINGARPUR	33kV	AMI	7.55221	7.53207	0.020134	0.27%		100%	
1023	TPCODL	BBSR-01	BED		MANCHESWAR B GIS	17047401	RASULGARH(UG)	33kV	AMI	16.73774	16.65001	0.087723	0.52%		100%	
1024	TPCODL	BBSR-01	BED		MANCHESWAR B GIS	17047402	MANCHESWAR(UG)	33kV	AMI	23.25144	23.06677	0.184666	0.79%		100%	
1025	TPCODL	BBSR-01	BED		MANCHESWAR B GIS	17047403	9 POLE RMU 1 NEW U	33kV	AMI	16.57821	16.47105	0.107154	0.65%		100%	
1026	TPCODL	BBSR-01	BED		MANCHESWAR B GIS	17047404	IDCO	33kV	AMI	1.43075	1.42186	0.008896	0.62%		100%	
1027	TPCODL	BBSR-01	BED		PRATAPSASAN	17057403	UTTARA 1	33kV	AMI	21.94690	21.41231	0.534592	2.44%		100%	
1028	TPCODL	BBSR-01	BED		PRATAPSASAN	17057404	UTTARA 2	33kV	AMI	17.99733	17.55880	0.438530	2.44%		100%	
1029	TPCODL	BBSR-01	BED		BALIANTA GIS	17075401	Naharkanta UG	33kV	AMI	21.68489	20.99176	0.693132	3.20%		67%	Merged-3
1030	TPCODL	BBSR-01	BED		BALIANTA GIS	17075402	Phulnakhara UG	33kV	AMI				3.20%		67%	Merged-3
1031	TPCODL	BBSR-01	NED		NIMAPARA	17005401	NIMAPADA	33kV	AMI	21.04107	20.81852	0.222548	1.06%		100%	
1032	TPCODL	BBSR-01	NED		NIMAPARA	17005402	KAKATPUR	33kV	AMI	34.77722	33.05138	1.725840	4.96%		100%	
1033	TPCODL	BBSR-01	NED		NIMAPARA	17005403	KONARK	33kV	AMI	4.02584	3.99773	0.028104	0.70%		100%	
1034	TPCODL	BBSR-01	NED		NIMAPARA	17005404	PIPILI	33kV	AMI	0.00005	0.00005	0.000000	0.00%		100%	
1035	TPCODL	BBSR-01	NED		NIMAPARA	17005405	BAMANAL/DANDIPUR	33kV	AMI	13.69724	13.47692	0.220315	1.61%		100%	
1036	TPCODL	BBSR-01	NED		KONARK	17006401	KONARK	33kV	AMI	10.22339	9.94734	0.276046	2.70%		100%	
1037	TPCODL	BBSR-01	NED		KONARK	17006402	GOP	33kV	AMI	12.09512	11.91552	0.179606	1.48%		100%	
1038	TPCODL	BBSR-01	NED		KONARK	17006403	BANGURIGAON	33kV	AMI	5.82212	5.75847	0.063654	1.09%		100%	
1039	TPCODL	BBSR-01	NED		KONARK	17006404	SUTAN	33kV	AMI	2.32906	2.31192	0.017134	0.74%		100%	
1040	TPCODL	BBSR-01	NED		PRATAPSASAN	17057401	BALAKATI	33kV	AMI	10.24717	10.18708	0.060088	0.59%		100%	
1041	TPCODL	BBSR-01	NED		PRATAPSASAN	17057402	BALIPATANA	33kV	AMI	12.13411	11.77277	0.361340	2.98%		100%	
1042	TPCODL	BBSR-01	NED		PRATAPSASAN	17057405	TRAHI ACHYUTANAGA	33kV	AMI	6.71871	6.62414	0.094572	1.41%		100%	
1043	TPCODL	BBSR-01	NED		SATASANKHA	17065401	MANGALPUR	33kV	AMI	25.45528	25.09625	0.359032	1.41%		100%	
1044	TPCODL	BBSR-02	BAED		BALUGAON	17015401	BALUGAON	33kV	AMI	17.60167	17.45989	0.141780	0.81%		100%	
1045	TPCODL	BBSR-02	BAED		BALUGAON	17015402	TANGI	33kV	AMI	9.11975	9.04541	0.074345	0.82%		100%	
1046	TPCODL	BBSR-02	BAED		BALUGAON	17015403	CHILIKA (DEDICATED)	33kV	AMI	1.28586	1.27697	0.008894	0.69%		67%	
1047	TPCODL	BBSR-02	BAED		BALUGAON	17015404	ANGULIA PADAR	33kV	AMI	9.03050	8.93199	0.098510	1.09%		100%	
1048	TPCODL	BBSR-02	BAED		CHANDPUR	17016401	CHANDPUR	33kV	AMI	6.40676	6.23563	0.171121	2.67%		100%	
1049	TPCODL	BBSR-02	BAED		CHANDPUR	17016402	TANGI-CHANDPUR	33kV	AMI	13.94056	13.52095	0.419613	3.01%		100%	
1050	TPCODL	BBSR-02	BAED		CHANDPUR	17016403	BHUSANDAPUR	33kV	AMI	4.13948	4.13073	0.008755	0.21%		33%	
1051	TPCODL	BBSR-02	BAED		CHANDPUR	17016404	KHANDISI	33kV	AMI	10.84767	10.42932	0.418352	3.86%		100%	
1052	TPCODL	BBSR-02	KHD		KHURDA	17007401	BANKI	33kV	AMI	3.61520	3.61125	0.003949	0.11%		33%	
1053	TPCODL	BBSR-02	KHD		KHURDA	17007402	BOLAGARH	33kV	AMI	11.29308	11.27373	0.019355	0.17%		100%	
1054	TPCODL	BBSR-02	KHD		KHURDA	17007403	TANGI / JANKIA	33kV	AMI	9.10597	9.08671	0.019258	0.21%		33%	
1055	TPCODL	BBSR-02	KHD		KHURDA	17007404	KHURDA	33kV	AMI	23.16159	22.71964	0.441952	1.91%		100%	
1056	TPCODL	BBSR-02	KHD		KHURDA	17007405	DELANG	33kV	AMI	26.23090	25.22682	1.004083	3.83%		100%	
1057	TPCODL	BBSR-02	KHD		KHURDA	17007406	RAILWAY	33kV	AMI	14.54808	14.41830	0.129784	0.89%		100%	
1058	TPCODL	BBSR-02	KHD		KHURDA	17007407	JATANI	33kV	AMI	8.27173	8.22113	0.050596	0.61%		100%	
1059	TPCODL	BBSR-02	KHD		KHURDA	17007408	KHURDA INDUSTRIAL	33kV	AMI	11.72646	11.67160	0.054861	0.47%		67%	
1060	TPCODL	BBSR-02	KHD		MENDHASAL	17008401	JATANI-MENDHASAL	33kV	AMI	7.48849	7.28219	0.206300	2.75%		100%	
1061	TPCODL	BBSR-02	KHD		ARGUL	17009401	IIT ARGUL-1	33kV	AMI	2.07843	2.07533	0.003100	0.15%		100%	
1062	TPCODL	BBSR-02	KHD		ARGUL	17009402	NISER 1	33kV	AMI	1.56769	1.56690	0.000791	0.05%		67%	Merged-4
1063	TPCODL	BBSR-02	KHD		ARGUL	17009403	NISER 2	33kV	AMI				0.05%		67%	Merged-4
1064	TPCODL	BBSR-02	KHD		ARGUL	17009404	IIT ARGUL-2	33kV	AMI	0.85996	0.85857	0.001389	0.16%		67%	
1065	TPCODL	BBSR-02	KHD		ARGUL	17009405	ICFMD	33kV	AMI	0.86817	0.86473	0.003437	0.40%		100%	
1066	TPCODL	BBSR-02	KHD		ARGUL	17009406	COCACOLA	33kV	AMI	14.04445	13.90042	0.144026	1.03%		100%	
1067	TPCODL	BBSR-02	KHD		ARGUL	17009407	NUAGAON	33kV	AMI	26.87575	26.39744	0.478316	1.78%		100%	
1068	TPCODL	BBSR-02	KHD		BANKI	17010401	SUNADEI	33kV	AMI	16.71050	15.48480	1.225698	7.33%		100%	
1069	TPCODL	BBSR-02	KHD		BANKI	17010402	CHARCHIKA	33kV	AMI	2.75410	2.55872	0.195376	7.09%		100%	
1070	TPCODL	BBSR-02	KHD		INFOCITYII GIS	17041401	INFOSYS- JATANI	33kV	AMI	25.39246	25.21353	0.178928	0.70%		100%	
1071	TPCODL	BBSR-02	KHD		INFOCITYII GIS	17041402	SEA FOODS	33kV	AMI	1.15740	1.12751	0.029887	2.58%		100%	
1072	TPCODL	BBSR-02	KHD		INFOCITYII GIS	17041403	CHHATABAR	33kV	AMI	5.99527	5.80994	0.185326	3.09%		100%	
1073	TPCODL	BBSR-02	KHD		INFOCITYII GIS	17041404	EMC PARK	33kV	AMI	2.09881	2.08875	0.010065	0.48%		67%	
1074	TPCODL	BBSR-02	KHD		ATRI	17067401	VARUN BEVERAGES	33kV	AMI	8.00473	7.85731	0.147426	1.84%		100%	
1075	TPCODL	BBSR-02	KHD		ATRI	17067403	BAGHAMARI-02	33kV	AMI	23.24299	22.71094	0.532052	2.29%		100%	
1076	TPCODL	BBSR-02	NYED		NAYAGARH	17011401	RANAPUR	33kV	AMI	2.67306	2.62698	0.046082	1.72%		100%	
1077	TPCODL	BBSR-02	NYED		NAYAGARH	17011402	BINOD PADA	33kV	AMI	18.45698	18.43231	0.024672	0.13%		100%	
1078	TPCODL	BBSR-02	NYED		NAYAGARH	17011403	KHANDAPADA	33kV	AMI	14.94994	14.18189	0.768051	5.14%		100%	
1079	TPCODL	BBSR-02	NYED		NAYAGARH	17011404	NAYAGARH	33kV	AMI	9.22080	8.65386	0.566944	6.15%		67%	
1080	TPCODL	BBSR-02	NYED		NAYAGARH	17011405	DASPALLA	33kV	AMI	24.25090	23.85606	0.394846	1.63%		100%	
1081	TPCODL	BBSR-02	NYED		NAYAGARH	17011406	ODAGAON	33kV	AMI	16.50788	16.24775	0.260127	1.58%		100%	
1082	TPCODL	BBSR-02	NYED		NAYAGARH	17011407	LATHIPADA	33kV	AMI	3.06610	3.06440	0.001708	0.06%		100%	
1083	TPCODL	BBSR-02	NYED		NAYAGARH	17011408	GODIPADA	33kV	AMI	1.76881	1.76316	0.005644	0.32%		67%	
1084	TPCODL	BBSR-02	NYED		NAYAGARH	17011409	MACHHIPADA	33kV	AMI	2.60422	2.59273	0.011490	0.44%		67%	
1085	TPCODL	BBSR-02	PED		PURI	17012401	SAKHIGOPAL	33kV	AMI	14.09538	14.01707	0.078309	0.56%		100%	
1086	TPCODL	BBSR-02	PED		PURI	17012403	SRIRAMNAGAR-I	33kV	AMI	8.99045	8.94670	0.043744	0.49%		100%	
1087	TPCODL	BBSR-02	PED		PURI	17012404	SRIRAMNAGAR-II	33kV	AMI	11.88622	11.84831	0.037911	0.32%		100%	
1088	TPCODL	BBSR-02	PED		PURI	17012405	PURI-I	33kV	AMI	7.98932	7.95560	0.033729	0.42%		100%	
1089	TPCODL	BBSR-02	PED		PURI	17012406	PURI-II	33kV	AMI	5.62586	5.59424	0.031614	0.56%		100%	
1090	TPCODL	BBSR-02	PED		PURI	17012408	PURI III	33kV	AMI	21.77986	21.69708	0.082783	0.38%		100%	

Sl No.	Zone	Received at Circle (In MU)	Received at Division (In MU)	Received at Sub-division (In MU)	Name of the Station	Feeder Code/ID	Feeder Name	Type of Feeder (Urban/Mixed/Industrial/Agricultural/Rural)	Type of feeder meter (AMI/AMR/Other)	Received at Feeder (Final in MU)	Feeder Consumption (In MU)	Final Net Export at Feeder Level (In MU)	T&D losses	AT&C losses	% Data Received through Automatically (if feeder AMR/AMI)	Remarks
1091	TPCODL	BBSR-02	PED		SHAMUKA	17013401	ALARNATH	33kV	AMI	22.76484	22.48716	0.277679	1.22%		100%	
1092	TPCODL	BBSR-02	PED		SHAMUKA	17013402	BALIAPANDA-1	33kV	AMI	23.62994	23.55405	0.075898	0.32%		100%	
1093	TPCODL	BBSR-02	PED		SHAMUKA	17013403	BALIAPANDA-2	33kV	AMI	9.24757	9.21202	0.035550	0.38%		100%	
1094	TPCODL	BBSR-02	PED		SHAMUKA	17013404	CHARINALA	33kV	AMI	3.20528	3.16464	0.040633	1.27%		100%	
1095	TPCODL	BBSR-02	PED		SHAMUKA	17013405	SAMANGA	33kV	AMI	13.38309	13.32720	0.055890	0.42%		100%	
1096	TPCODL	BBSR-02	PED		SAMAGARA	17014401	SAMAGARA-1/GABAKU	33kV	AMI	5.50176	5.40260	0.099159	1.80%		100%	
1097	TPCODL	BBSR-02	PED		SAMAGARA	17014402	SAMAGARA-2/SRIRAM	33kV	AMI	18.41817	18.39849	0.019683	0.11%		100%	
1098	TPCODL	BBSR-02	PED		SAMAGARA	17014403	SAMAGARA-3/SRIRAM	33kV	AMI	2.98808	2.92403	0.064045	2.14%		100%	
1099	TPCODL	BBSR-02	PED		SAMAGARA	17014404	MEDICAL COLLEGE U	33kV	AMI	0.31881	0.31734	0.001474	0.46%		100%	
1100	TPCODL	BBSR-02	PED		SATASANKHA	17065403	PATTNAIKA FEEDER	33kV	AMI	2.62433	2.54053	0.083798	3.19%		67%	
1101	TPCODL	CUTTACK	AED		NUAPATNA	17023401	BADAMBA	33kV	AMI	13.22374	13.06159	0.162151	1.23%		100%	
1102	TPCODL	CUTTACK	AED		NUAPATNA	17023402	ATHAGARH	33kV	AMI	6.31310	5.94736	0.365738	5.79%		67%	
1103	TPCODL	CUTTACK	AED		NUAPATNA	17023403	NUAPATNA	33kV	AMI	3.00700	3.00126	0.005740	0.19%		33%	
1104	TPCODL	CUTTACK	AED		NUAPATNA	17023404	TIGIRIA	33kV	AMI	9.42243	9.28365	0.138779	1.47%		100%	
1105	TPCODL	CUTTACK	AED		KHUNTUNI GIS	17044401	KHUNTUNI	33kV	AMI	10.39316	9.92962	0.463540	4.46%		67%	
1106	TPCODL	CUTTACK	AED		KHUNTUNI GIS	17044402	J K LAXMI	33kV	AMI	3.39184	3.38333	0.008512	0.25%		100%	
1107	TPCODL	CUTTACK	AED		KHUNTUNI GIS	17044403	ATHAGARH GIS	33kV	AMI	18.23012	17.56851	0.661612	3.63%		100%	
1108	TPCODL	CUTTACK	AED		NARASINGHPUR	17045401	NARSINGHPUR	33kV	AMI	6.02608	6.02275	0.003338	0.06%		67%	
1109	TPCODL	CUTTACK	AED		NARASINGHPUR	17045402	MEGA LI-1	33kV	AMI	0.02170	0.02170	0.000000	0.00%		100%	
1110	TPCODL	CUTTACK	AED		NARASINGHPUR	17045403	MEGA LI-2	33kV	AMI	0.00202	0.00202	0.000000	0.00%		100%	
1111	TPCODL	CUTTACK	AED		NARASINGHPUR	17045404	MARDAMEKHA	33kV	AMI	0.70005	0.69452	0.005529	0.79%		33%	
1112	TPCODL	CUTTACK	AED		NARASINGHPUR	17045405	KANPUR	33kV	AMI	12.87168	12.77485	0.096827	0.75%		100%	
1113	TPCODL	CUTTACK	CDD-01		BIDANASI	17019401	TULASIPUR 1	33kV	AMI	8.27371	8.22399	0.049717	0.60%		67%	
1114	TPCODL	CUTTACK	CDD-01		BIDANASI	17019402	TULASIPUR 2	33kV	AMI	7.40118	7.35501	0.046162	0.62%		33%	
1115	TPCODL	CUTTACK	CDD-01		BIDANASI	17019403	SECTOR 6	33kV	AMI	15.45794	15.26870	0.189234	1.22%		100%	
1116	TPCODL	CUTTACK	CDD-01		BIDANASI	17019405	SISHUBHABAN	33kV	AMI	18.31203	17.96664	0.345390	1.89%		100%	
1117	TPCODL	CUTTACK	CDD-01		BIDANASI	17019406	IOCL-I	33kV	AMI	22.52127	22.38932	0.131943	0.59%		100%	
1118	TPCODL	CUTTACK	CDD-01		BIDANASI	17019407	IOCL-II	33kV	AMI	2.18470	2.18139	0.003312	0.15%		100%	
1119	TPCODL	CUTTACK	CDD-01		BIDANASI	17019408	SISHUBHABAN-2	33kV	AMI	18.31169	18.21867	0.093024	0.51%		100%	
1120	TPCODL	CUTTACK	CDD-01		CUTTACK	17020408	MEDICAL-1 UG	33kV	AMI	3.23180	3.19134	0.040457	1.25%		33%	
1121	TPCODL	CUTTACK	CDD-01		CUTTACK	17020409	MEDICAL-2 UG	33kV	AMI	12.47958	12.47106	0.008524	0.07%		100%	
1122	TPCODL	CUTTACK	CDD-01		CUTTACK	17020410	BADAMBADI UG	33kV	AMI	19.58746	19.31865	0.268813	1.37%		100%	
1123	TPCODL	CUTTACK	CDD-01		BRAJABIHARIPUR	17052401	BRAJABIHARIPUR	33kV	AMI	11.14117	11.07575	0.065416	0.59%		100%	
1124	TPCODL	CUTTACK	CDD-01		BRAJABIHARIPUR	17052402	WATCO	33kV	AMI	1.42117	1.42065	0.000520	0.04%		33%	
1125	TPCODL	CUTTACK	CDD-01		BRAJABIHARIPUR	17052403	TULASIPUR 1	33kV	AMI	15.76896	15.74268	0.026275	0.17%		67%	
1126	TPCODL	CUTTACK	CDD-01		BRAJABIHARIPUR	17052404	TULASIPUR 2	33kV	AMI	6.20282	6.15007	0.052758	0.85%		67%	
1127	TPCODL	CUTTACK	CDD-01		BRAJABIHARIPUR	17052405	SARPESWAR FEEDER	33kV	AMI	8.56366	8.48879	0.074875	0.87%		100%	
1128	TPCODL	CUTTACK	CDD-01		MEDICAL GSS (SCBMCH)	17076401	33KV New Medical UG	33kV	AMI	0.00000	0.00000	0.000000	0.00%		33%	
1129	TPCODL	CUTTACK	CDD-02		CHOUDWAR	17018405	JAGATPUR	33kV	AMI	7.12561	7.05961	0.066001	0.93%		100%	
1130	TPCODL	CUTTACK	CDD-02		BIDANASI	17019404	BADAMBADI	33kV	AMI	9.86010	9.72160	0.138507	1.40%		100%	
1131	TPCODL	CUTTACK	CDD-02		CUTTACK	17020402	BENTKAR	33kV	AMI	8.56038	8.50249	0.057884	0.68%		100%	
1132	TPCODL	CUTTACK	CDD-02		CUTTACK	17020403	JSPUR RURAL	33kV	AMI	14.42504	14.05367	0.371372	2.57%		67%	
1133	TPCODL	CUTTACK	CDD-02		CUTTACK	17020404	CRRI-1	33kV	AMI	2.57702	2.51619	0.060831	2.36%		33%	
1134	TPCODL	CUTTACK	CDD-02		CUTTACK	17020405	CRRI-2	33kV	AMI	4.16042	4.10196	0.058468	1.41%		67%	
1135	TPCODL	CUTTACK	CDD-02		CUTTACK	17020406	CHAULIAGANJ I	33kV	AMI	5.76882	5.67975	0.089072	1.54%		33%	
1136	TPCODL	CUTTACK	CDD-02		CUTTACK	17020407	CHAULIAGANJ II	33kV	AMI	5.24503	5.23429	0.010740	0.20%		33%	
1137	TPCODL	CUTTACK	CED		CHANDIKHOLE	17017401	BADACHANA	33kV	AMI	23.61917	23.58194	0.037233	0.16%		100%	
1138	TPCODL	CUTTACK	CED		CHANDIKHOLE	17017402	KUNDAL	33kV	AMI	4.49311	4.28544	0.207668	4.62%		100%	
1139	TPCODL	CUTTACK	CED		CHOUDWAR	17018401	BAJRANG BALLY/CDR	33kV	AMI	20.62775	20.55826	0.069496	0.34%		100%	
1140	TPCODL	CUTTACK	CED		CHOUDWAR	17018402	TANGI	33kV	AMI	5.73365	5.68362	0.050034	0.87%		33%	
1141	TPCODL	CUTTACK	CED		CHOUDWAR	17018403	ATHAGARH	33kV	AMI	15.02736	14.88492	0.142436	0.95%		100%	
1142	TPCODL	CUTTACK	CED		CHOUDWAR	17018406	IDCO/CITY	33kV	AMI	0.55071	0.54772	0.002995	0.54%		33%	
1143	TPCODL	CUTTACK	CED		CUTTACK	17020401	BALIKUDA	33kV	AMI	22.97823	22.87922	0.099008	0.43%		100%	
1144	TPCODL	CUTTACK	CED		PHULNAKAHARA	17022401	DAMODARPUR	33kV	AMI	18.32985	18.09522	0.234634	1.28%		100%	
1145	TPCODL	CUTTACK	CED		PHULNAKAHARA	17022402	NIALI	33kV	AMI	29.81580	27.97093	1.844869	6.19%		100%	
1146	TPCODL	CUTTACK	CED		MANIA	17038401	RSB	33kV	AMI	5.75564	5.74378	0.011860	0.21%		100%	
1147	TPCODL	CUTTACK	CED		MANIA	17038402	MANIA-IDCO	33kV	AMI	3.60983	3.57833	0.031501	0.87%		33%	
1148	TPCODL	CUTTACK	CED		MANIA	17038403	KAIMATIA	33kV	AMI	8.78556	8.66922	0.116342	1.32%		100%	
1149	TPCODL	CUTTACK	CED		MANIA	17038404	Biswanahakani	33kV	AMI	2.03571	2.01982	0.015890	0.78%		67%	
1150	TPCODL	CUTTACK	CED		PALEI	17072401	33KV BALICHANDRAP	33kV	AMI	13.38602	12.86354	0.522479	3.90%		100%	
1151	TPCODL	CUTTACK	CED		PALEI	17072402	33KV BALICHANDRAP	33kV	AMI	4.16586	3.95306	0.212803	5.11%		100%	
1152	TPCODL	CUTTACK	SED		CHOUDWAR	17018404	BAHUGRAM	33kV	AMI	6.15247	6.11041	0.042057	0.68%		67%	
1153	TPCODL	CUTTACK	SED		SALIPUR	17021401	SALIPUR	33kV	AMI	26.61368	26.61207	0.001603	0.01%		100%	
1154	TPCODL	CUTTACK	SED		SALIPUR	17021402	MAHANGA	33kV	AMI	16.99288	16.27533	0.717548	4.22%		100%	
1155	TPCODL	CUTTACK	SED		SALIPUR	17021403	JAPAKUDA	33kV	AMI	4.63615	4.62630	0.009850	0.21%		67%	
1156	TPCODL	CUTTACK	SED		SALIPUR	17021404	BAHUGRAM-2	33kV	AMI	0.13193	0.12985	0.002078	1.58%		100%	
1157	TPCODL	CUTTACK	SED		ATODA	17070401	BAHUGRAM 1	33kV	AMI	1.93852	1.92629	0.012226	0.63%		67%	
1158	TPCODL	CUTTACK	SED		ATODA	17070402	JAGATPUR	33kV	AMI	13.17244	13.16613	0.006308	0.05%		100%	
1159	TPCODL	CUTTACK	SED		ATODA	17070403	BAHUGRAM-2	33kV	AMI	7.74578	7.66398	0.081801	1.06%		100%	
1160	TPCODL	CUTTACK	SED		ATODA	17070404	NAGASPUR	33kV	AMI	2.96518	2.95400	0.011188	0.38%		33%	
1161	TPCODL	DHENKANAL	ANED		ANGUL	17030401	RAILWAY	33kV	AMI	0.55834	0.55580	0.002537	0.45%		100%	
1162	TPCODL	DHENKANAL	ANED		ANGUL	17030402	ANGUL-I	33kV	AMI	20.63920	20.53251	0.106691	0.52%		100%	
1163	TPCODL	DHENKANAL	ANED		ANGUL	17030403	ANGUL-II(BANTALA)	33kV	AMI	17.63373	16.99747	0.636262	3.61%		100%	
1164	TPCODL	DHENKANAL	ANED		ANGUL	17030404	M/S GANESH SPONGE	33kV	AMI	30.28931	28.90902	1.380290	4.56%		100%	
1165	TPCODL	DHENKANAL	ANED		ANGUL	17030405	HEMASURPADA	33kV	AMI	22.43978	22.05721	0.382568	1.70%		100%	
1166	TPCODL	DHENKANAL	ANED		BOINDA	17031401	JARPADA	33kV	AMI	22.12454	21.40067	0.723864	3.27%		100%	
1167	TPCODL	DHENKANAL	ANED		RAIRAKHOL	17032401	BAMUR	33kV	AMI	5.83065	5.37138	0.459269	7.88%		100%	
1168	TPCODL	DHENKANAL	DED		DHENKANAL	17024401	DKL TOWN	33kV	AMI	20.37244	20.06185	0.310583	1.52%		100%	
1169	TPCODL	DHENKANAL	DED		DHENKANAL	17024402	GONDIA	33kV	AMI	5.15114	5.07310	0.078040	1.52%		67%	
1170	TPCODL	DHENKANAL	DED		DHENKANAL	17024403	HINDOL ROAD	33kV	AMI	15.07841	14.78222	0.296192	1.96%		100%	
1171	TPCODL	DHENKANAL	DED		DHENKANAL	17024404	OPL	33kV	AMI	0.01136	0.01136	0.000000	0.00%		33%	
1172	TPCODL	DHENKANAL	DED		DHENKANAL	17024405	GUNDICHAPADA-2	33kV	AMI	9.48267	9.44392	0.038756	0.41%		33%	
1173	TPCODL	DHENKANAL	DED		DHENKANAL	17024406	BANASINGHA	33kV	AMI	1.72859	1.66300	0.065591	3.79%		100%	
1174	TPCODL	DHENKANAL	DED		DHENKANAL	17024407	SCAW INDUSTRIES	33kV	AMI	1.36545	1.36545	0.000000	0.00%		100%	

Sl No.	Zone	Received at Circle (In MU)	Received at Division (In MU)	Received at Sub-division (In MU)	Name of the Station	Feeder Code/ID	Feeder Name	Type of Feeder (Urban/Mixed/Industrial/Agricultural/Rural)	Type of feeder meter (AMI/AMR/Other)	Received at Feeder (Final in MU)	Feeder Consumption (In MU)	Final Net Export at Feeder Level (In MU)	T&D losses	AT&C losses	% Data Received through Automatically (if feeder AMR/AMI)	Remarks
1175	TPCODL	DHENKANAL	DED		DHENKANAL	17024408	DAKHINAKALI	33kV	AMI	12.75022	12.40965	0.340572	2.67%		100%	
1176	TPCODL	DHENKANAL	DED		DHENKANAL	17024409	MEGA LIFT	33kV	AMI	0.03082	0.03082	0.000000	0.00%		100%	
1177	TPCODL	DHENKANAL	DED		KAMAKHYANAGAR	17025401	KAMAKHYANAGAR	33kV	AMI	3.66740	3.63212	0.035272	0.96%		33%	
1178	TPCODL	DHENKANAL	DED		KAMAKHYANAGAR	17025402	KANKADAHADA/JIRIDA	33kV	AMI	8.21019	8.19980	0.010388	0.13%		100%	
1179	TPCODL	DHENKANAL	DED		KAMAKHYANAGAR	17025403	SOVAMETAL	33kV	AMI	6.65998	6.63366	0.026314	0.40%		100%	
1180	TPCODL	DHENKANAL	DED		KAMAKHYANAGAR	17025404	MATHAKARGOLA	33kV	AMI	4.78956	4.42089	0.368669	7.70%		67%	
1181	TPCODL	DHENKANAL	DED		KAMAKHYANAGAR	17025405	PANDUA	33kV	AMI	2.02077	2.00108	0.019690	0.97%		33%	
1182	TPCODL	DHENKANAL	DED		KALARANGI	17026401	TISCO	33kV	AMI	0.35771	0.35461	0.003100	0.87%		100%	
1183	TPCODL	DHENKANAL	DED		KALARANGI	17026402	OMC	33kV	AMI	3.22037	3.14665	0.073719	2.29%		100%	
1184	TPCODL	DHENKANAL	DED		KALARANGI	17026403	KALIAPANI	33kV	AMI	2.94118	2.81823	0.122947	4.18%		33%	
1185	TPCODL	DHENKANAL	DED		KALARANGI	17026404	GODA	33kV	AMI	0.00001	0.00001	0.000000	0.00%		100%	
1186	TPCODL	DHENKANAL	DED		KHAJURIAKATA	17040401	KHAJURIAKATA-1	33kV	AMI	5.81765	5.78481	0.032838	0.56%		100%	
1187	TPCODL	DHENKANAL	DED		KHAJURIAKATA	17040402	HINDOL	33kV	AMI	10.59348	10.47608	0.117400	1.11%		100%	
1188	TPCODL	DHENKANAL	DED		GODA	17062401	GODA	33kV	AMI	10.84784	10.07031	0.777524	7.17%		67%	
1189	TPCODL	DHENKANAL	DED		ARNAPUR	17068401	GONDIA	33kV	AMI	13.23848	12.89359	0.344888	2.61%		100%	
1190	TPCODL	DHENKANAL	DED		ARNAPUR	17068402	JORONDA	33kV	AMI	4.12150	3.86878	0.252722	6.13%		100%	
1191	TPCODL	DHENKANAL	DED		ARNAPUR	17068403	IDCO-NEULAPOI FDR	33kV	AMI	0.00000	0.00000	0.000000	0.00%		100%	
1192	TPCODL	DHENKANAL	TED		CHAINPAL	17027401	BANARPAL	33kV	AMI	12.15180	11.58084	0.570964	4.70%		100%	
1193	TPCODL	DHENKANAL	TED		CHAINPAL	17027402	PARJANG	33kV	AMI	23.28096	21.90836	1.372603	5.90%		100%	
1194	TPCODL	DHENKANAL	TED		CHAINPAL	17027403	RENGALI	33kV	AMI	6.25650	6.23200	0.024504	0.39%		33%	
1195	TPCODL	DHENKANAL	TED		CHAINPAL	17027404	INDUSTRIAL	33kV	AMI	24.46426	23.72826	0.736005	3.01%		100%	
1196	TPCODL	DHENKANAL	TED		CHAINPAL	17027405	TALCHER	33kV	AMI	7.39925	7.31164	0.087610	1.18%		33%	
1197	TPCODL	DHENKANAL	TED		CHAINPAL	17027406	CHAINPAL	33kV	AMI	8.43066	8.38940	0.041260	0.49%		100%	
1198	TPCODL	DHENKANAL	TED		RENGALI	17028401	KHAMAR(PALAHARA)	33kV	AMI	12.59705	12.09127	0.505781	4.02%		100%	
1199	TPCODL	DHENKANAL	TED		RENGALI	17028402	KANIHA	33kV	AMI	18.15962	17.98160	0.178016	0.98%		100%	
1200	TPCODL	DHENKANAL	TED		RENGALI	17028405	MEGA LIFT	33kV	AMI	0.00002	0.00002	0.000000	0.00%		100%	
1201	TPCODL	DHENKANAL	TED		BARKOTE	17029401	BARKOTE	33kV	AMI	4.84492	4.73110	0.113812	2.35%		100%	
1202	TPCODL	DHENKANAL	TED		MERAMUNDALI	17048401	MERAMUNDALI	33kV	AMI	15.39683	15.34475	0.052085	0.34%		100%	
1203	TPCODL	DHENKANAL	TED		MERAMUNDALI	17048402	RWSS	33kV	AMI	0.02934	0.02934	0.000000	0.00%		33%	
1204	TPCODL	DHENKANAL	TED		GLOBAL	17054401	GLOBAL	33kV	AMI	1.70762	1.70762	0.000000	0.00%		100%	
1205	TPCODL	DHENKANAL	TED		GLOBAL	17054402	ARYAN	33kV	AMI	0.44745	0.44745	0.000000	0.00%		100%	
1206	TPCODL	PARADEEP	JED		JAGATSINGHPUR	17037401	JAGATSINHPUR	33kV	AMI	14.31089	14.16880	0.142090	0.99%		100%	
1207	TPCODL	PARADEEP	JED		JAGATSINGHPUR	17037402	TIRTOL	33kV	AMI	10.17347	10.06807	0.105402	1.04%		100%	
1208	TPCODL	PARADEEP	JED		JAGATSINGHPUR	17037403	NABAPATANA (MAIN)	33kV	AMI	7.32076	7.02382	0.296940	4.06%		67%	
1209	TPCODL	PARADEEP	JED		JAGATSINGHPUR	17037404	BALIKUDA (NEW)	33kV	AMI	8.15357	8.09651	0.057064	0.70%		33%	
1210	TPCODL	PARADEEP	JED		JAGATSINGHPUR	17037405	NAUGAON (MAIN)	33kV	AMI	4.00499	3.99782	0.007172	0.18%		33%	
1211	TPCODL	PARADEEP	JED		JAGATSINGHPUR	17037406	MARKANDAPUR	33kV	AMI	0.94176	0.94092	0.000840	0.09%		33%	
1212	TPCODL	PARADEEP	KED-I		PATTAMUNDAI	17033401	PATTAMUNDAI	33kV	AMI	11.45867	11.15217	0.306505	2.67%		100%	
1213	TPCODL	PARADEEP	KED-I		PATTAMUNDAI	17033402	AUL	33kV	AMI	3.40052	3.23725	0.163269	4.80%		67%	
1214	TPCODL	PARADEEP	KED-I		PATTAMUNDAI	17033403	RAJANAGAR	33kV	AMI	4.14034	3.77960	0.360748	8.71%		100%	
1215	TPCODL	PARADEEP	KED-I		PATTAMUNDAI	17033404	GOGUA	33kV	AMI	10.89589	10.43138	0.464519	4.26%		100%	
1216	TPCODL	PARADEEP	KED-I		KENDRAPADA	17034401	KENDRAPARA	33kV	AMI	22.19914	22.19680	0.002336	0.01%		100%	
1217	TPCODL	PARADEEP	KED-I		KENDRAPADA	17034402	DANPUR	33kV	AMI	9.20329	8.63620	0.567094	6.16%		67%	
1218	TPCODL	PARADEEP	KED-I		KENDRAPADA	17034403	INDUPUR	33kV	AMI	12.10616	11.33320	0.772958	6.38%		100%	
1219	TPCODL	PARADEEP	KED-I		KENDRAPADA	17034404	LUNA	33kV	AMI	12.80232	12.64827	0.154048	1.20%		100%	
1220	TPCODL	PARADEEP	KED-I		KENDRAPADA	17034405	AUL-PATTAMUNDAI	33kV	AMI	0.99464	0.98771	0.006931	0.70%		33%	
1221	TPCODL	PARADEEP	KED-I		KENDRAPADA	17034406	DANPUR NEW	33kV	AMI	8.20092	7.69213	0.508787	6.20%		67%	
1222	TPCODL	PARADEEP	KED-I		OLAVER	17039401	OLAVER	33kV	AMI	5.50954	5.43560	0.073940	1.34%		100%	
1223	TPCODL	PARADEEP	KED-I		OLAVER	17039403	OLAVER AUL	33kV	AMI	7.79936	7.42283	0.376533	4.83%		67%	
1224	TPCODL	PARADEEP	KED-I		OLAVER	17039404	AYATAN	33kV	AMI	8.28875	8.13203	0.156726	1.89%		100%	
1225	TPCODL	PARADEEP	KED-I		OLAVER	17039405	OLAVER MLIP	33kV	AMI	0.00005	0.00005	0.000000	0.00%		100%	
1226	TPCODL	PARADEEP	KED-I		RAJNAGAR	17061401	RAJNAGAR	33kV	AMI	19.49936	17.85571	1.643651	8.43%		100%	
1227	TPCODL	PARADEEP	KED-I		RAJNAGAR	17061402	ADHAJORI	33kV	AMI	3.97442	3.64965	0.324767	8.17%		100%	
1228	TPCODL	PARADEEP	KED-II		MARSHAGHAI	17035401	LUNA	33kV	AMI	12.21278	11.96754	0.245238	2.01%		67%	
1229	TPCODL	PARADEEP	KED-II		MARSHAGHAI	17035402	MAHAKALPADA	33kV	AMI	19.82782	19.61420	0.213623	1.08%		100%	
1230	TPCODL	PARADEEP	KED-II		MARSHAGHAI	17035403	MEGALIFT PROJECT	33kV	AMI	0.00322	0.00322	0.000000	0.00%		100%	
1231	TPCODL	PARADEEP	PDP		PARADEEP	17036401	INDUSTRIAL	33kV	AMI	14.59098	14.55808	0.032903	0.23%		100%	
1232	TPCODL	PARADEEP	PDP		PARADEEP	17036402	TIRTOL	33kV	AMI	11.55888	11.46402	0.094860	0.82%		100%	
1233	TPCODL	PARADEEP	PDP		PARADEEP	17036405	HPCL	33kV	AMI	1.58646	1.58596	0.000503	0.03%		100%	
1234	TPCODL	PARADEEP	PDP		PARADEEP	17036406	BIJAYACHANDRAPUR	33kV	AMI	8.37035	8.25253	0.117822	1.41%		100%	
1235	TPCODL	PARADEEP	PDP		PARADEEP	17036407	JHIMANI	33kV	AMI	9.09390	8.98157	0.112327	1.24%		100%	
1236	TPCODL	PARADEEP	PDP		TIRTOL	17046401	TIRTOL/BODHEI	33kV	AMI	17.61889	17.51904	0.099847	0.57%		100%	
1237	TPCODL	PARADEEP	PDP		TIRTOL	17046402	GORADA	33kV	AMI	12.72631	12.69970	0.026609	0.21%		100%	
1238	TPCODL	PARADEEP	PDP		TIRTOL	17046403	JAGANNATHPUR	33kV	AMI	15.00493	14.91316	0.091768	0.61%		100%	

(Details of Distribution Transformer (DT Level information)

SI No.	Zone name	Circle name	Division name	Feeder name	Feeder ID	Total no of DT on feeder	No of unmetered DTC	No of metered DTC			No of DT's with functional meters	
								AMR metered (communicable)	AMI metered (Communicable)	No AMR/AMI metered (non communicable)	Communicating (Total no out 0f 07 & 08)	Non-Communicating (Total no out 0f 07 & 08 & 09)
0	1	2	3	4	12	5=(6+7+8+9)	6	7	8	9	10	11
1	TPCODL	CIRCLE-1, BE	BCDD-01,	11 kV BARAMU	14005203	35	22	0	13	0	13	0
2	TPCODL	CIRCLE-1, BE	BCDD-01,	11 kV IRC-3	14008203	65	22	0	43	0	43	0
3	TPCODL	CIRCLE-1, BE	BCDD-01,	11 kV OUAT	14011201	62	33	0	29	0	29	0
4	TPCODL	CIRCLE-1, BE	BCDD-01,	11 kV BM RMU	14011202	1	0	0	1	0	1	0
5	TPCODL	CIRCLE-1, BE	BCDD-01,	11 kV GB NAGA	14011203	58	32	0	26	0	26	0
6	TPCODL	CIRCLE-1, BE	BCDD-01,	11 kV TELEPHO	14011204	18	16	0	2	0	2	0
7	TPCODL	CIRCLE-1, BE	BCDD-01,	11 kV ASSEMBI	14011205	22	16	0	6	0	6	0
8	TPCODL	CIRCLE-1, BE	BCDD-01,	11 kV CBI	14011206	12	4	0	8	0	7	1
9	TPCODL	CIRCLE-1, BE	BCDD-01,	11 kV RAJBHAV	14011207	3	3	0	0	0	0	0
10	TPCODL	CIRCLE-1, BE	BCDD-01,	11 kV BM RMU	14011208	1	0	0	1	0	1	0
11	TPCODL	CIRCLE-1, BE	BCDD-01,	11 kV OERC	14011209	42	20	0	22	0	22	0
12	TPCODL	CIRCLE-1, BE	BCDD-01,	11 kV DELTA	14011210	8	7	0	1	0	1	0
13	TPCODL	CIRCLE-1, BE	BCDD-01,	11 kV KALINGA	14011212	50	32	0	18	0	18	0
14	TPCODL	CIRCLE-1, BE	BCDD-01,	11 kV BM RMU	14011213	34	26	0	8	0	8	0
15	TPCODL	CIRCLE-1, BE	BCDD-01,	11 kV TECHNO	14011214	2	2	0	0	0	0	0
16	TPCODL	CIRCLE-1, BE	BCDD-01,	11 kV BM RMU	14011215	1	1	0	0	0	0	0
17	TPCODL	CIRCLE-1, BE	BCDD-01,	33 kV O/G-1 TC	14011403	1	1	0	0	0	0	0
18	TPCODL	CIRCLE-1, BE	BCDD-01,	33 kV SECRATR	14011404	4	4	0	0	0	0	0
19	TPCODL	CIRCLE-1, BE	BCDD-01,	11 kV MEDICAI	14012201	13	13	0	0	0	0	0
20	TPCODL	CIRCLE-1, BE	BCDD-01,	11 kV FOREST I	14012202	38	14	0	24	0	24	0
21	TPCODL	CIRCLE-1, BE	BCDD-01,	11 kV UNIT-1	14012203	27	17	0	10	0	10	0
22	TPCODL	CIRCLE-1, BE	BCDD-01,	11 kV SPRING T	14012204	14	2	0	12	0	12	0
23	TPCODL	CIRCLE-1, BE	BCDD-01,	11 kV BAPUJIN	14012205	51	23	0	28	0	28	0
24	TPCODL	CIRCLE-1, BE	BCDD-01,	11 kV UNIT-6	14012206	17	7	0	10	0	10	0
25	TPCODL	CIRCLE-1, BE	BCDD-01,	11 kV RMU-19	14012207	13	7	0	6	0	6	0
26	TPCODL	CIRCLE-1, BE	BCDD-01,	11 kV RMU-8	14012208	21	9	0	12	0	12	0
27	TPCODL	CIRCLE-1, BE	BCDD-01,	11 kV RMU-7	14012209	11	4	0	7	0	7	0
28	TPCODL	CIRCLE-1, BE	BCDD-01,	33 kV O/G-1 TC	14012401	1	1	0	0	0	0	0
29	TPCODL	CIRCLE-1, BE	BCDD-01,	11 kV MS NAGA	14013201	29	18	0	11	0	11	0
30	TPCODL	CIRCLE-1, BE	BCDD-01,	11 kV RMU-7	14013203	20	12	0	8	0	8	0
31	TPCODL	CIRCLE-1, BE	BCDD-01,	11 kV RMU-23	14013204	16	3	0	13	0	13	0
32	TPCODL	CIRCLE-1, BE	BCDD-01,	11 kV RMU-5	14013205	34	17	0	17	0	17	0
33	TPCODL	CIRCLE-1, BE	BCDD-01,	11 kV RMU-22	14013206	9	3	0	6	0	6	0
34	TPCODL	CIRCLE-1, BE	BCDD-01,	11 kV RMU-14	14013207	7	4	0	3	0	3	0
35	TPCODL	CIRCLE-1, BE	BCDD-01,	11 kV RMU-15	14013208	10	9	0	1	0	1	0
36	TPCODL	CIRCLE-1, BE	BCDD-01,	33 kV NIC FEED	14013401	2	2	0	0	0	0	0
37	TPCODL	CIRCLE-1, BE	BCDD-01,	11 kV SATYANA	14014201	43	12	0	31	0	31	0
38	TPCODL	CIRCLE-1, BE	BCDD-01,	11 kV PRESS	14014202	6	4	0	2	0	2	0
39	TPCODL	CIRCLE-1, BE	BCDD-01,	11 kV PLAZA	14014203	18	10	0	8	0	7	1
40	TPCODL	CIRCLE-1, BE	BCDD-01,	11 kV RAHULCO	14014204	6	4	0	2	0	2	0
41	TPCODL	CIRCLE-1, BE	BCDD-01,	11 kV JP RMU-3	14014205	32	20	0	12	0	12	0
42	TPCODL	CIRCLE-1, BE	BCDD-01,	11 kV JP RMU-3	14014206	11	5	0	6	0	6	0
43	TPCODL	CIRCLE-1, BE	BCDD-01,	11 kV JP RMU-4	14014207	14	7	0	7	0	7	0
44	TPCODL	CIRCLE-1, BE	BCDD-01,	11 kV JP RMU-4	14014208	14	10	0	4	0	4	0
45	TPCODL	CIRCLE-1, BE	BCDD-01,	11 kV UNIT-3	14015202	15	5	0	10	0	10	0
46	TPCODL	CIRCLE-1, BE	BCDD-01,	11 kV UNIT-2	14015203	16	7	0	9	0	8	1
47	TPCODL	CIRCLE-1, BE	BCDD-01,	11 kV MAA GIR	14015204	21	15	0	6	0	6	0
48	TPCODL	CIRCLE-1, BE	BCDD-01,	11 kV SM RMU	14015205	11	5	0	6	0	6	0
49	TPCODL	CIRCLE-1, BE	BCDD-01,	11 kV JP RMU-4	14015207	13	11	0	2	0	2	0
50	TPCODL	CIRCLE-1, BE	BCDD-01,	11 kV JP RMU-4	14015208	45	29	0	16	0	16	0
51	TPCODL	CIRCLE-1, BE	BCDD-01,	33 kV SATYA N	14015401	11	11	0	0	0	0	0
52	TPCODL	CIRCLE-1, BE	BCDD-01,	11 kV FEEDER-1	14016201	51	25	0	26	0	26	0
53	TPCODL	CIRCLE-1, BE	BCDD-01,	11 kV Feeder-2	14016202	32	21	0	11	0	11	0
54	TPCODL	CIRCLE-1, BE	BCDD-01,	11 kV Feeder-3	14016203	40	19	0	21	0	21	0
55	TPCODL	CIRCLE-1, BE	BCDD-01,	11 kV Feeder-4	14016204	32	26	0	6	0	6	0

SI No.	Zone name	Circle name	Division name	Feeder name	Feeder ID	Total no of DT on feeder	No of unmetered DTC	No of metered DTC			No of DT's with functional meters	
								AMR metered (communicable)	AMI metered (Communicable)	No AMR/AMI metered (non communicable)	Communicating (Total no out 0f 07 & 08)	Non-Communicating (Total no out 0f 07 & 08 & 09)
0	1	2	3	4	12	5=(6+7+8+9)	6	7	8	9	10	11
56	TPCODL	CIRCLE-1, BE	BCDD-01, (	11 kV JP RMU-1	14016205	9	7	0	2	0	2	0
57	TPCODL	CIRCLE-1, BE	BCDD-01, (	11 kV JP RMU-3	14016206	22	15	0	7	0	7	0
58	TPCODL	CIRCLE-1, BE	BCDD-01, (	11 kV JP RMU-3	14016207	7	5	0	2	0	2	0
59	TPCODL	CIRCLE-1, BE	BCDD-01, (	11 kV Flat Unit-	14017201	3	1	0	2	0	2	0
60	TPCODL	CIRCLE-1, BE	BCDD-01, (	11 kV GridcoCo	14017202	19	10	0	9	0	9	0
61	TPCODL	CIRCLE-1, BE	BCDD-01, (	11 kV BM RMU	14017205	15	7	0	8	0	8	0
62	TPCODL	CIRCLE-1, BE	BCDD-01, (	11 kV BM RMU	14017206	7	1	0	6	0	5	1
63	TPCODL	CIRCLE-1, BE	BCDD-01, (	11 kV JP RMU-3	14017207	18	10	0	8	0	7	1
64	TPCODL	CIRCLE-1, BE	BCDD-01, (	11 kV JP RMU-3	14017208	17	11	0	6	0	6	0
65	TPCODL	CIRCLE-1, BE	BCDD-01, (	11 kV SM RMU	14017209	19	5	0	14	0	14	0
66	TPCODL	CIRCLE-1, BE	BCDD-01, (	11 kV SM RMU	14017210	45	21	0	24	0	24	0
67	TPCODL	CIRCLE-1, BE	BCDD-01, (	11 kV JP RMU-1	14215204	49	24	0	25	0	25	0
68	TPCODL	CIRCLE-1, BE	BCDD-01, (	11 kV Navin Niv	14215205	1	0	0	1	0	1	0
69	TPCODL	CIRCLE-1, BE	BCDD-01, (	11 kV RMU-1	14215206	20	12	0	8	0	8	0
70	TPCODL	CIRCLE-1, BE	BCDD-01, (	11 kV SIRIPUR	14221201	56	27	0	29	0	29	0
71	TPCODL	CIRCLE-1, BE	BCDD-01, (	11 kV Shatabdi	14221202	57	28	0	29	0	29	0
72	TPCODL	CIRCLE-1, BE	BCDD-01, (	11 kV FIRE STA	14221203	64	27	0	37	0	37	0
73	TPCODL	CIRCLE-1, BE	BCDD-01, (	11 kV UNIT8	14221204	25	7	0	18	0	17	1
74	TPCODL	CIRCLE-1, BE	BCDD-01, (	11 kV SUCHNA	14234201	17	12	0	5	0	5	0
75	TPCODL	CIRCLE-1, BE	BCDD-01, (	11 kV MARKET	14234203	23	13	0	10	0	10	0
76	TPCODL	CIRCLE-1, BE	BCDD-01, (	11 kV JANPATH	14234204	48	28	0	20	0	19	1
77	TPCODL	CIRCLE-1, BE	BCDD-01, (	11 kV BHAWAN	14384201	17	7	0	10	0	10	0
78	TPCODL	CIRCLE-1, BE	BCDD-01, (	11 kV MAHARS	14384204	19	4	0	15	0	15	0
79	TPCODL	CIRCLE-1, BE	BCDD-01, (	11KV ROBOT P	14384205	17	6	0	11	0	11	0
80	TPCODL	CIRCLE-1, BE	BCDD-01, (	11 kV BIGBAZA	14387201	7	6	0	1	0	1	0
81	TPCODL	CIRCLE-1, BE	BCDD-01, (	33 kV SAINIKSC	17001401	4	4	0	0	0	0	0
82	TPCODL	CIRCLE-1, BE	BCDD-01, (	33 kV KHARBEL	17001402	1	1	0	0	0	0	0
83	TPCODL	CIRCLE-1, BE	BCDD-01, (	33 kV SAHEEDI	17001403	2	2	0	0	0	0	0
84	TPCODL	CIRCLE-1, BE	BCDD-01, (	33 kV RASULGA	17001404	2	2	0	0	0	0	0
85	TPCODL	CIRCLE-1, BE	BCDD-01, (	33 kV UNIT8 FD	17002401	1	1	0	0	0	0	0
86	TPCODL	CIRCLE-1, BE	BCDD-01, (	33 kV UNIT-8 G	17043401	1	1	0	0	0	0	0
87	TPCODL	CIRCLE-1, BE	BCDD-01, (	33 kV UNIT6 GI	17043404	1	1	0	0	0	0	0
88	TPCODL	CIRCLE-1, BE	BCDD-02, (	11 kV KALARAH	1422301	1	1	0	0	0	0	0
89	TPCODL	CIRCLE-1, BE	BCDD-02, (	11 kV SRI VIHA	14001201	102	56	0	46	0	46	0
90	TPCODL	CIRCLE-1, BE	BCDD-02, (	11 kV POKHRA	14001202	42	25	0	17	0	17	0
91	TPCODL	CIRCLE-1, BE	BCDD-02, (	11 kV BDA	14001203	49	32	0	17	0	17	0
92	TPCODL	CIRCLE-1, BE	BCDD-02, (	11 kV CSPUR H	14001204	34	10	0	24	0	24	0
93	TPCODL	CIRCLE-1, BE	BCDD-02, (	11 kV DIST CEN	14001206	78	55	0	23	0	23	0
94	TPCODL	CIRCLE-1, BE	BCDD-02, (	11 kV QUALITY	14001207	1	1	0	0	0	0	0
95	TPCODL	CIRCLE-1, BE	BCDD-02, (	11 kV CSPUR B	14002201	139	107	0	32	0	32	0
96	TPCODL	CIRCLE-1, BE	BCDD-02, (	11 kV HOUSING	14002202	67	50	0	17	0	17	0
97	TPCODL	CIRCLE-1, BE	BCDD-02, (	11 kV CSPUR B	14002203	71	45	0	26	0	26	0
98	TPCODL	CIRCLE-1, BE	BCDD-02, (	11 kV HOUSING	14002204	28	8	0	20	0	20	0
99	TPCODL	CIRCLE-1, BE	BCDD-02, (	11 kV HOUSING	14002205	20	4	0	16	0	16	0
100	TPCODL	CIRCLE-1, BE	BCDD-02, (	11 kV CSPUR IN	14002206	70	57	0	13	0	13	0
101	TPCODL	CIRCLE-1, BE	BCDD-02, (	11 kV NAVAL	14002207	15	10	0	5	0	5	0
102	TPCODL	CIRCLE-1, BE	BCDD-02, (	11 kV TULASI V	14002208	40	21	0	19	0	19	0
103	TPCODL	CIRCLE-1, BE	BCDD-02, (	33 kV INFOCITY	14002401	9	9	0	0	0	0	0
104	TPCODL	CIRCLE-1, BE	BCDD-02, (	11 kV INFOCITY	14003201	11	9	0	2	0	2	0
105	TPCODL	CIRCLE-1, BE	BCDD-02, (	11 kV BANK	14003202	38	35	0	3	0	3	0
106	TPCODL	CIRCLE-1, BE	BCDD-02, (	11 kV NEW IND	14003203	40	32	0	8	0	8	0
107	TPCODL	CIRCLE-1, BE	BCDD-02, (	11 kV POLYME	14003204	98	82	0	16	0	16	0
108	TPCODL	CIRCLE-1, BE	BCDD-02, (	11 kV RAJAVAT	14003205	49	40	0	9	0	9	0
109	TPCODL	CIRCLE-1, BE	BCDD-02, (	11 kV NEW PAT	14003206	47	26	0	21	0	21	0
110	TPCODL	CIRCLE-1, BE	BCDD-02, (	11 kV NEW KIIT	14003207	59	44	0	15	0	15	0
111	TPCODL	CIRCLE-1, BE	BCDD-02, (	11 kV NEW SRI	14003208	16	7	0	9	0	9	0
112	TPCODL	CIRCLE-1, BE	BCDD-02, (	11 kV O-TV	14003209	32	28	0	4	0	4	0
113	TPCODL	CIRCLE-1, BE	BCDD-02, (	11 kV OHPC	14003210	23	20	0	3	0	3	0

SI No.	Zone name	Circle name	Division name	Feeder name	Feeder ID	Total no of DT on feeder	No of unmetered DTC	No of metered DTC			No of DT's with functional meters	
								AMR metered (communicable)	AMI metered (Communicable)	No AMR/AMI metered (non communicable)	Communicating (Total no out 0f 07 & 08)	Non-Communicating (Total no out 0f 07 & 08 & 09)
0	1	2	3	4	12	5=(6+7+8+9)	6	7	8	9	10	11
114	TPCODL	CIRCLE-1, BE	BCDD-02, I	33 kV DLF CYBE	14003401	1	1	0	0	0	0	0
115	TPCODL	CIRCLE-1, BE	BCDD-02, I	33 kV PGCIL	14003402	6	6	0	0	0	0	0
116	TPCODL	CIRCLE-1, BE	BCDD-02, I	11 kV BARAMU	14005201	50	17	0	33	0	32	1
117	TPCODL	CIRCLE-1, BE	BCDD-02, I	11 kV BARAMU	14005202	34	17	0	17	0	17	0
118	TPCODL	CIRCLE-1, BE	BCDD-02, I	11 kV BARAMU	14005203	16	15	0	1	0	1	0
119	TPCODL	CIRCLE-1, BE	BCDD-02, I	11 kV CRPF	14005204	44	21	0	23	0	23	0
120	TPCODL	CIRCLE-1, BE	BCDD-02, I	11 kV BARAMU	14005205	18	13	0	5	0	5	0
121	TPCODL	CIRCLE-1, BE	BCDD-02, I	11 kV ISBT-1	14005206	3	3	0	0	0	0	0
122	TPCODL	CIRCLE-1, BE	BCDD-02, I	11 kV KHANDA	14006201	66	32	0	34	0	34	0
123	TPCODL	CIRCLE-1, BE	BCDD-02, I	11 kV BHARATI	14006202	80	42	0	38	0	38	0
124	TPCODL	CIRCLE-1, BE	BCDD-02, I	11 kV PHD	14006203	46	23	0	23	0	23	0
125	TPCODL	CIRCLE-1, BE	BCDD-02, I	11 kV SATELITE	14006204	48	19	0	29	0	28	1
126	TPCODL	CIRCLE-1, BE	BCDD-02, I	11 kV BHARATI	14006205	117	72	0	45	0	43	2
127	TPCODL	CIRCLE-1, BE	BCDD-02, I	11 kV SAMPUR	14006206	30	16	0	14	0	14	0
128	TPCODL	CIRCLE-1, BE	BCDD-02, I	11 kV K-2	14006207	169	53	0	116	0	114	2
129	TPCODL	CIRCLE-1, BE	BCDD-02, I	33 kV CHANDA	14006402	3	3	0	0	0	0	0
130	TPCODL	CIRCLE-1, BE	BCDD-02, I	33 kV SUM HO	14006403	3	3	0	0	0	0	0
131	TPCODL	CIRCLE-1, BE	BCDD-02, I	11 kV K-9	14007201	84	36	0	48	0	48	0
132	TPCODL	CIRCLE-1, BE	BCDD-02, I	11 kV K-5	14007202	141	69	0	72	0	71	1
133	TPCODL	CIRCLE-1, BE	BCDD-02, I	11 kV OG-1 RM	14007203	100	51	0	49	0	47	2
134	TPCODL	CIRCLE-1, BE	BCDD-02, I	11 kV KN RE	14007204	139	93	0	46	0	46	0
135	TPCODL	CIRCLE-1, BE	BCDD-02, I	11 kV DUMDUI	14007205	68	30	0	38	0	37	1
136	TPCODL	CIRCLE-1, BE	BCDD-02, I	11 kV TAMAND	14007206	62	31	0	31	0	30	1
137	TPCODL	CIRCLE-1, BE	BCDD-02, I	11 KV SUBUDH	14007207	15	15	0	0	0	0	0
138	TPCODL	CIRCLE-1, BE	BCDD-02, I	11 kV IRC-1	14008201	57	32	0	25	0	25	0
139	TPCODL	CIRCLE-1, BE	BCDD-02, I	11 kV IRC-2	14008202	15	11	0	4	0	4	0
140	TPCODL	CIRCLE-1, BE	BCDD-02, I	11 kV IRC-3	14008203	3	1	0	2	0	2	0
141	TPCODL	CIRCLE-1, BE	BCDD-02, I	11 kV JAYDEV V	14008204	32	16	0	16	0	16	0
142	TPCODL	CIRCLE-1, BE	BCDD-02, I	11 kV RENTAL	14008205	48	24	0	24	0	24	0
143	TPCODL	CIRCLE-1, BE	BCDD-02, I	11 kV NALCO	14008206	33	16	0	17	0	17	0
144	TPCODL	CIRCLE-1, BE	BCDD-02, I	11 kV IRC-4	14008207	65	32	0	33	0	33	0
145	TPCODL	CIRCLE-1, BE	BCDD-02, I	11 kV RPRC	14008208	69	48	0	21	0	21	0
146	TPCODL	CIRCLE-1, BE	BCDD-02, I	11 kV BHAGWA	14008209	33	13	0	20	0	20	0
147	TPCODL	CIRCLE-1, BE	BCDD-02, I	11 kV ID MARK	14008210	5	1	0	4	0	4	0
148	TPCODL	CIRCLE-1, BE	BCDD-02, I	11 kV RAPTANI	14008211	67	32	0	35	0	34	1
149	TPCODL	CIRCLE-1, BE	BCDD-02, I	33 kV NAYAPAI	14008401	1	1	0	0	0	0	0
150	TPCODL	CIRCLE-1, BE	BCDD-02, I	33 kV KRISHNA	14008402	4	4	0	0	0	0	0
151	TPCODL	CIRCLE-1, BE	BCDD-02, I	11 kV XAVIER N	14009201	29	23	0	6	0	6	0
152	TPCODL	CIRCLE-1, BE	BCDD-02, I	11 kV STPI	14009202	55	44	0	11	0	11	0
153	TPCODL	CIRCLE-1, BE	BCDD-02, I	11 kV SOI	14009203	20	19	0	1	0	1	0
154	TPCODL	CIRCLE-1, BE	BCDD-02, I	11 kV GOPABA	14009204	11	6	0	5	0	5	0
155	TPCODL	CIRCLE-1, BE	BCDD-02, I	11 kV HATIASU	14009205	21	13	0	8	0	8	0
156	TPCODL	CIRCLE-1, BE	BCDD-02, I	11 kV VSS NAG	14010201	46	19	0	27	0	27	0
157	TPCODL	CIRCLE-1, BE	BCDD-02, I	11 kV GAJAPAT	14010202	30	14	0	16	0	16	0
158	TPCODL	CIRCLE-1, BE	BCDD-02, I	11 kV PRESS	14010203	59	38	0	21	0	21	0
159	TPCODL	CIRCLE-1, BE	BCDD-02, I	11 kV VANIVIH	14010204	24	10	0	14	0	14	0
160	TPCODL	CIRCLE-1, BE	BCDD-02, I	11 kV SAINIK S	14010205	17	7	0	10	0	10	0
161	TPCODL	CIRCLE-1, BE	BCDD-02, I	11 kV KELUCHA	14010206	47	23	0	24	0	24	0
162	TPCODL	CIRCLE-1, BE	BCDD-02, I	33 kV SAINIK S	14010401	1	1	0	0	0	0	0
163	TPCODL	CIRCLE-1, BE	BCDD-02, I	11 kV SM RMU	14017210	6	6	0	0	0	0	0
164	TPCODL	CIRCLE-1, BE	BCDD-02, I	11 kV TRISULIA	14216201	36	31	0	5	0	5	0
165	TPCODL	CIRCLE-1, BE	BCDD-02, I	11 kV ANDHAR	14216202	192	143	0	49	0	49	0
166	TPCODL	CIRCLE-1, BE	BCDD-02, I	11 kV SRIRAM	14216203	60	50	0	10	0	10	0
167	TPCODL	CIRCLE-1, BE	BCDD-02, I	11 kV FEEDER-	14216204	84	56	0	28	0	28	0
168	TPCODL	CIRCLE-1, BE	BCDD-02, I	33 kV GODISAH	14216401	39	32	0	7	0	7	0
169	TPCODL	CIRCLE-1, BE	BCDD-02, I	11 kV ROYALTY	14217201	45	37	0	8	0	8	0
170	TPCODL	CIRCLE-1, BE	BCDD-02, I	11 kV KALARAH	14217202	181	119	0	62	0	61	1
171	TPCODL	CIRCLE-1, BE	BCDD-02, I	11 kV PATIA	14217203	47	32	0	15	0	15	0

SI No.	Zone name	Circle name	Division name	Feeder name	Feeder ID	Total no of DT on feeder	No of unmetered DTC	No of metered DTC			No of DT's with functional meters	
								AMR metered (communicable)	AMI metered (Communicable)	No AMR/AMI metered (non communicable)	Communicating (Total no out 0f 07 & 08)	Non-Communicating (Total no out 0f 07 & 08 & 09)
0	1	2	3	4	12	5=(6+7+8+9)	6	7	8	9	10	11
172	TPCODL	CIRCLE-1, BE	BCDD-02, (	11 kV PKB	14217204	49	15	0	34	0	34	0
173	TPCODL	CIRCLE-1, BE	BCDD-02, (	11 kV RAGHUN	14217205	23	20	0	3	0	3	0
174	TPCODL	CIRCLE-1, BE	BCDD-02, (	11 kV KCL	14217206	1	1	0	0	0	0	0
175	TPCODL	CIRCLE-1, BE	BCDD-02, (	11 kV PRASANT	14217208	44	24	0	20	0	20	0
176	TPCODL	CIRCLE-1, BE	BCDD-02, (	11 kV ROYAL G	14217209	13	8	0	5	0	5	0
177	TPCODL	CIRCLE-1, BE	BCDD-02, (	11 kV KIIT	14217210	51	32	0	19	0	19	0
178	TPCODL	CIRCLE-1, BE	BCDD-02, (	11 kV KOLATHI	14222201	83	44	0	39	0	39	0
179	TPCODL	CIRCLE-1, BE	BCDD-02, (	11 kV DHARMA	14222202	37	20	0	17	0	17	0
180	TPCODL	CIRCLE-1, BE	BCDD-02, (	11 kV GANDMU	14222203	60	28	0	32	0	31	1
181	TPCODL	CIRCLE-1, BE	BCDD-02, (	11 kV JAGAMO	14222204	51	27	0	24	0	24	0
182	TPCODL	CIRCLE-1, BE	BCDD-02, (	11 kV GREEN P	14222205	11	5	0	6	0	6	0
183	TPCODL	CIRCLE-1, BE	BCDD-02, (	11 kV TALABAN	14222206	26	15	0	11	0	11	0
184	TPCODL	CIRCLE-1, BE	BCDD-02, (	11 kV JAGAMA	14222207	43	31	0	12	0	12	0
185	TPCODL	CIRCLE-1, BE	BCDD-02, (	11 kV SIKHAR C	14223201	43	19	0	24	0	24	0
186	TPCODL	CIRCLE-1, BE	BCDD-02, (	11 kV NANDDA	14223202	51	31	0	20	0	20	0
187	TPCODL	CIRCLE-1, BE	BCDD-02, (	11 kV UNIVERS	14230201	11	11	0	0	0	0	0
188	TPCODL	CIRCLE-1, BE	BCDD-02, (	11 kV UNIVERS	14230202	9	9	0	0	0	0	0
189	TPCODL	CIRCLE-1, BE	BCDD-02, (	11 kV INCOME	14230203	39	22	0	17	0	17	0
190	TPCODL	CIRCLE-1, BE	BCDD-02, (	11 kV LAXMI VI	14230204	17	7	0	10	0	10	0
191	TPCODL	CIRCLE-1, BE	BCDD-02, (	11 kV 7TH BAT	14231201	31	21	0	10	0	10	0
192	TPCODL	CIRCLE-1, BE	BCDD-02, (	11 kV RMU 2/P	14231202	6	6	0	0	0	0	0
193	TPCODL	CIRCLE-1, BE	BCDD-02, (	11 kV PAL HEIG	14231203	36	21	0	15	0	15	0
194	TPCODL	CIRCLE-1, BE	BCDD-02, (	11 kV ESI	14232201	2	2	0	0	0	0	0
195	TPCODL	CIRCLE-1, BE	BCDD-02, (	11 kV SARAKAN	14235201	42	24	0	18	0	18	0
196	TPCODL	CIRCLE-1, BE	BCDD-02, (	11 kV AIGINIA	14235202	79	45	0	34	0	33	1
197	TPCODL	CIRCLE-1, BE	BCDD-02, (	11 kV SIJUA	14235203	55	40	0	15	0	15	0
198	TPCODL	CIRCLE-1, BE	BCDD-02, (	11 kV UDAYAG	14235204	61	21	0	40	0	38	2
199	TPCODL	CIRCLE-1, BE	BCDD-02, (	11 kV HOUSING	14236201	38	18	0	20	0	19	1
200	TPCODL	CIRCLE-1, BE	BCDD-02, (	11 kV PANCHA	14236202	32	14	0	18	0	18	0
201	TPCODL	CIRCLE-1, BE	BCDD-02, (	11 kV ASIAN PL	14236203	25	10	0	15	0	15	0
202	TPCODL	CIRCLE-1, BE	BCDD-02, (	11 kV BEGUNIA	14236204	43	20	0	23	0	23	0
203	TPCODL	CIRCLE-1, BE	BCDD-02, (	11 kV IIIT	14237201	15	15	0	0	0	0	0
204	TPCODL	CIRCLE-1, BE	BCDD-02, (	11 kV NUAGAO	14237202	116	69	0	47	0	47	0
205	TPCODL	CIRCLE-1, BE	BCDD-02, (	11 kV PAIKRAY	14237203	50	40	0	10	0	10	0
206	TPCODL	CIRCLE-1, BE	BCDD-02, (	11 kV GODIBAR	14237204	129	104	0	25	0	25	0
207	TPCODL	CIRCLE-1, BE	BCDD-02, (	11 kV Patharag	14246201	50	39	0	11	0	11	0
208	TPCODL	CIRCLE-1, BE	BCDD-02, (	11 kV DASPUR	14246202	72	60	0	12	0	12	0
209	TPCODL	CIRCLE-1, BE	BCDD-02, (	11 kV Kujimaha	14246203	100	79	0	21	0	21	0
210	TPCODL	CIRCLE-1, BE	BCDD-02, (	11 kV Chandak	14246204	65	59	0	6	0	6	0
211	TPCODL	CIRCLE-1, BE	BCDD-02, (	11 kV MADHUB	14247201	34	28	0	6	0	6	0
212	TPCODL	CIRCLE-1, BE	BCDD-02, (	11 kV INDUSTR	14247202	29	29	0	0	0	0	0
213	TPCODL	CIRCLE-1, BE	BCDD-02, (	11 kV BIDYADH	14247203	89	81	0	8	0	8	0
214	TPCODL	CIRCLE-1, BE	BCDD-02, (	11 kV TALAGAR	14247204	51	48	0	3	0	3	0
215	TPCODL	CIRCLE-1, BE	BCDD-02, (	11 kV Vigilance	14249201	51	43	0	8	0	8	0
216	TPCODL	CIRCLE-1, BE	BCDD-02, (	11 kV OERC	14249202	1	1	0	0	0	0	0
217	TPCODL	CIRCLE-1, BE	BCDD-02, (	11 kV Aryan	14249203	45	27	0	18	0	17	1
218	TPCODL	CIRCLE-1, BE	BCDD-02, (	11 kV PATIA ST	14251201	5	3	0	2	0	2	0
219	TPCODL	CIRCLE-1, BE	BCDD-02, (	11 kV DHAWA	14251202	142	111	0	31	0	31	0
220	TPCODL	CIRCLE-1, BE	BCDD-02, (	11 kV Injama	14251204	50	26	0	24	0	24	0
221	TPCODL	CIRCLE-1, BE	BCDD-02, (	11 kV LUMBINI	14300202	8	2	0	6	0	5	1
222	TPCODL	CIRCLE-1, BE	BCDD-02, (	11 kV CENTRAL	14300203	26	16	0	10	0	10	0
223	TPCODL	CIRCLE-1, BE	BCDD-02, (	11 kV NARANP	14367201	72	56	0	16	0	16	0
224	TPCODL	CIRCLE-1, BE	BCDD-02, (	11 kV MUNDAI	14367203	61	51	0	10	0	10	0
225	TPCODL	CIRCLE-1, BE	BCDD-02, (	11 kV MADHUR	14367204	73	61	0	12	0	12	0
226	TPCODL	CIRCLE-1, BE	BCDD-02, (	33 kV MUKIM(	14367401	3	3	0	0	0	0	0
227	TPCODL	CIRCLE-1, BE	BCDD-02, (	11 kV MANI TR	14377201	1	0	0	1	0	1	0
228	TPCODL	CIRCLE-1, BE	BCDD-02, (	11 kV MANI TR	14377202	1	0	0	1	0	1	0
229	TPCODL	CIRCLE-1, BE	BCDD-02, (	11 kV MANI TR	14377203	1	0	0	1	0	1	0

SI No.	Zone name	Circle name	Division name	Feeder name	Feeder ID	Total no of DT on feeder	No of unmetered DTC	No of metered DTC			No of DT's with functional meters	
								AMR metered (communicable)	AMI metered (Communicable)	No AMR/AMI metered (non communicable)	Communicating (Total no out 0f 07 & 08)	Non-Communicating (Total no out 0f 07 & 08 & 09)
0	1	2	3	4	12	5=(6+7+8+9)	6	7	8	9	10	11
230	TPCODL	CIRCLE-1, BE	BCDD-02, (	11 kV MANI TR	14377204	1	1	0	0	0	0	0
231	TPCODL	CIRCLE-1, BE	BCDD-02, (	11 kV MANI TR	14377205	1	1	0	0	0	0	0
232	TPCODL	CIRCLE-1, BE	BCDD-02, (	11 kV MANI TR	14377206	1	1	0	0	0	0	0
233	TPCODL	CIRCLE-1, BE	BCDD-02, (	11 kV MANI TR	14377207	1	1	0	0	0	0	0
234	TPCODL	CIRCLE-1, BE	BCDD-02, (	11 kV FEEDER-1	14388201	2	2	0	0	0	0	0
235	TPCODL	CIRCLE-1, BE	BCDD-02, (	11 kV Feeder-2	14388202	3	3	0	0	0	0	0
236	TPCODL	CIRCLE-1, BE	BCDD-02, (	11 kV FEEDER-1	14389201	4	1	0	3	0	3	0
237	TPCODL	CIRCLE-1, BE	BCDD-02, (	11 kV Feeder-2	14389202	3	0	0	3	0	3	0
238	TPCODL	CIRCLE-1, BE	BCDD-02, (	33 kV SAINIKSC	17001401	2	2	0	0	0	0	0
239	TPCODL	CIRCLE-1, BE	BCDD-02, (	33 kV SAHEEDI	17001403	2	0	0	2	0	2	0
240	TPCODL	CIRCLE-1, BE	BCDD-02, (	33 kV INDUSTR	17001405	1	1	0	0	0	0	0
241	TPCODL	CIRCLE-1, BE	BCDD-02, (	33 kV ECO RLY	17001408	6	6	0	0	0	0	0
242	TPCODL	CIRCLE-1, BE	BCDD-02, (	33 kV ECO RLY	17001409	1	1	0	0	0	0	0
243	TPCODL	CIRCLE-1, BE	BCDD-02, (	33 kV NBCC	17001411	4	4	0	0	0	0	0
244	TPCODL	CIRCLE-1, BE	BCDD-02, (	33 kV CHANDR	17002403	1	1	0	0	0	0	0
245	TPCODL	CIRCLE-1, BE	BCDD-02, (	33 kV CHANDR	17002404	3	3	0	0	0	0	0
246	TPCODL	CIRCLE-1, BE	BCDD-02, (	33 kV NAYAPAI	17002405	5	5	0	0	0	0	0
247	TPCODL	CIRCLE-1, BE	BCDD-02, (	33 kV XAVIER	17002406	19	18	0	1	0	1	0
248	TPCODL	CIRCLE-1, BE	BCDD-02, (	33 kV BARANG	17002407	6	6	0	0	0	0	0
249	TPCODL	CIRCLE-1, BE	BCDD-02, (	33 kV NARAJ	17002408	2	2	0	0	0	0	0
250	TPCODL	CIRCLE-1, BE	BCDD-02, (	33 kV TCS	17002409	2	2	0	0	0	0	0
251	TPCODL	CIRCLE-1, BE	BCDD-02, (	33 kV KIIT	17002410	3	3	0	0	0	0	0
252	TPCODL	CIRCLE-1, BE	BCDD-02, (	33 kV SJ DEVEL	17002411	3	3	0	0	0	0	0
253	TPCODL	CIRCLE-1, BE	BCDD-02, (	33 kV INFOCITY	17002412	2	2	0	0	0	0	0
254	TPCODL	CIRCLE-1, BE	BCDD-02, (	33 kV NAYAPAI	17003401	3	3	0	0	0	0	0
255	TPCODL	CIRCLE-1, BE	BCDD-02, (	33 kV BARAMU	17003402	3	3	0	0	0	0	0
256	TPCODL	CIRCLE-1, BE	BCDD-02, (	33 kV AIIMS NC	17003405	4	4	0	0	0	0	0
257	TPCODL	CIRCLE-1, BE	BCDD-02, (	33 kV AIIMS NC	17003406	8	8	0	0	0	0	0
258	TPCODL	CIRCLE-1, BE	BCDD-02, (	33 kV ASOTECH	17003407	7	7	0	0	0	0	0
259	TPCODL	CIRCLE-1, BE	BCDD-02, (	33 kV VIPUL	17003409	2	2	0	0	0	0	0
260	TPCODL	CIRCLE-1, BE	BCDD-02, (	33 kV RANASIN	17003410	1	1	0	0	0	0	0
261	TPCODL	CIRCLE-1, BE	BCDD-02, (	33 kV CHANDA	17060401	1	1	0	0	0	0	0
262	TPCODL	CIRCLE-1, BE	BCDD-02, (	33 kV SAILASHI	17060402	1	1	0	0	0	0	0
263	TPCODL	CIRCLE-1, BE	BCDD-02, (	33 kV SAPIGEN	17060403	1	1	0	0	0	0	0
264	TPCODL	CIRCLE-1, BE	BCDD-02, (	33 kV ASTAL PI	17064401	1	1	0	0	0	0	0
265	TPCODL	CIRCLE-1, BE	BCDD-02, (	33 kV GOVINDI	17064402	16	14	0	2	0	2	0
266	TPCODL	CIRCLE-1, BE	BCDD-02, (	33 kV WATCO	17064404	7	7	0	0	0	0	0
267	TPCODL	CIRCLE-1, BE	BCDD-02, (	33 kV PAGE INI	17064405	3	3	0	0	0	0	0
268	TPCODL	CIRCLE-1, BE	BCDD-02, (	33 kV GOTHAP	17066402	11	11	0	0	0	0	0
269	TPCODL	CIRCLE-1, BE	BCDD-02, (	33 kV BHARATI	17071404	1	1	0	0	0	0	0
270	TPCODL	CIRCLE-1, BE	BCDD-02, (	Godisahi Aux-I	17064STN01	1	0	0	1	0	1	0
271	TPCODL	CIRCLE-1, BE	BCDD-02, (	Godisahi Aux-II	17064STN02	1	0	0	1	0	1	0
272	TPCODL	CIRCLE-1, BE	BCDD-02, (	Kantabada Aux	17066STN01	1	1	0	0	0	0	0
273	TPCODL	CIRCLE-1, BE	BCDD-02, (	Kantabada Aux	17066STN02	1	1	0	0	0	0	0
274	TPCODL	CIRCLE-1, BE	BCDD-02, (	250 KVA STATI	17071STN01	1	1	0	0	0	0	0
275	TPCODL	CIRCLE-1, BE	BCDD-02, (	250 KVA STATI	17071STN02	1	1	0	0	0	0	0
276	TPCODL	CIRCLE-1, BE	BED, BBSR	11 kV POKHAR	14018201	71	37	0	34	0	34	0
277	TPCODL	CIRCLE-1, BE	BED, BBSR	11 kV LINGARA	14018202	31	15	0	16	0	16	0
278	TPCODL	CIRCLE-1, BE	BED, BBSR	11 kV BHIMATA	14018203	30	12	0	18	0	18	0
279	TPCODL	CIRCLE-1, BE	BED, BBSR	11 kV R.E JAMU	14018204	178	102	0	76	0	76	0
280	TPCODL	CIRCLE-1, BE	BED, BBSR	11 kV POKHAR	14018205	43	25	0	18	0	18	0
281	TPCODL	CIRCLE-1, BE	BED, BBSR	11 KV STATION	14018207	18	8	0	10	0	10	0
282	TPCODL	CIRCLE-1, BE	BED, BBSR	33 kV PRADHA	14018402	1	1	0	0	0	0	0
283	TPCODL	CIRCLE-1, BE	BED, BBSR	33 kV BADAGA	14018403	1	1	0	0	0	0	0
284	TPCODL	CIRCLE-1, BE	BED, BBSR	11 kV BRAHME	14019201	68	24	0	44	0	44	0
285	TPCODL	CIRCLE-1, BE	BED, BBSR	11 kV BADAGA	14019202	76	39	0	37	0	37	0
286	TPCODL	CIRCLE-1, BE	BED, BBSR	11 kV MAUSIM	14019203	73	31	0	42	0	42	0
287	TPCODL	CIRCLE-1, BE	BED, BBSR	11 kV Water W	14019204	17	9	0	8	0	8	0

SI No.	Zone name	Circle name	Division name	Feeder name	Feeder ID	Total no of DT on feeder	No of unmetered DTC	No of metered DTC			No of DT's with functional meters	
								AMR metered (communicable)	AMI metered (Communicable)	No AMR/AMI metered (non communicable)	Communicating (Total no out 0f 07 & 08)	Non-Communicating (Total no out 0f 07 & 08 & 09)
0	1	2	3	4	12	5=(6+7+8+9)	6	7	8	9	10	11
288	TPCODL	CIRCLE-1, BE	BED, BBSR	11 kV BADAGA	14019205	53	25	0	28	0	27	1
289	TPCODL	CIRCLE-1, BE	BED, BBSR	11 kV B.J.B NA	14019206	40	24	0	16	0	16	0
290	TPCODL	CIRCLE-1, BE	BED, BBSR	11 kV SAI	14019207	27	18	0	9	0	8	1
291	TPCODL	CIRCLE-1, BE	BED, BBSR	11 kV RAJARAN	14019208	49	35	0	14	0	14	0
292	TPCODL	CIRCLE-1, BE	BED, BBSR	11 kV BHUASU	14019209	37	18	0	19	0	19	0
293	TPCODL	CIRCLE-1, BE	BED, BBSR	11 kV GOUTAN	14019210	44	24	0	20	0	20	0
294	TPCODL	CIRCLE-1, BE	BED, BBSR	11 kV RMU-20	14019211	11	9	0	2	0	2	0
295	TPCODL	CIRCLE-1, BE	BED, BBSR	11 kV RMU-21	14019212	13	10	0	3	0	3	0
296	TPCODL	CIRCLE-1, BE	BED, BBSR	11 kV RMU-11	14019213	27	22	0	5	0	5	0
297	TPCODL	CIRCLE-1, BE	BED, BBSR	33 kV BHIMAT	14019402	1	1	0	0	0	0	0
298	TPCODL	CIRCLE-1, BE	BED, BBSR	11 kV LAXMISA	14020201	90	39	0	51	0	51	0
299	TPCODL	CIRCLE-1, BE	BED, BBSR	11 kV KALPANA	14020202	26	19	0	7	0	7	0
300	TPCODL	CIRCLE-1, BE	BED, BBSR	11 KV JHARAPA	14020203	26	6	0	20	0	20	0
301	TPCODL	CIRCLE-1, BE	BED, BBSR	11 kV BOMIKH	14020204	27	13	0	14	0	14	0
302	TPCODL	CIRCLE-1, BE	BED, BBSR	11 kV KALPANA	14020205	65	23	0	42	0	42	0
303	TPCODL	CIRCLE-1, BE	BED, BBSR	11 kV RMU-5	14020206	31	15	0	16	0	16	0
304	TPCODL	CIRCLE-1, BE	BED, BBSR	11 kV RMU-6A	14020207	39	18	0	21	0	21	0
305	TPCODL	CIRCLE-1, BE	BED, BBSR	11 kV RMU-15	14020208	21	13	0	8	0	8	0
306	TPCODL	CIRCLE-1, BE	BED, BBSR	11 kV RMU-16	14020209	62	32	0	30	0	29	1
307	TPCODL	CIRCLE-1, BE	BED, BBSR	11 kV RMU-6	14020210	44	15	0	29	0	29	0
308	TPCODL	CIRCLE-1, BE	BED, BBSR	11 kV JHARPAD	14020211	23	10	0	13	0	13	0
309	TPCODL	CIRCLE-1, BE	BED, BBSR	11 kV LAXMISA	14020212	9	3	0	6	0	6	0
310	TPCODL	CIRCLE-1, BE	BED, BBSR	11 kV RMU-14	14020213	37	20	0	17	0	17	0
311	TPCODL	CIRCLE-1, BE	BED, BBSR	11 kV UPTTI	14020214	6	6	0	0	0	0	0
312	TPCODL	CIRCLE-1, BE	BED, BBSR	11 kV RASULGA	14021201	104	63	0	41	0	41	0
313	TPCODL	CIRCLE-1, BE	BED, BBSR	11 kV PURI RO	14021202	63	31	0	32	0	32	0
314	TPCODL	CIRCLE-1, BE	BED, BBSR	11 kV KALPANA	14021203	96	39	0	57	0	57	0
315	TPCODL	CIRCLE-1, BE	BED, BBSR	11 kV PRESS	14021204	17	10	0	7	0	7	0
316	TPCODL	CIRCLE-1, BE	BED, BBSR	11 kV CR RMU-	14021205	3	0	0	3	0	3	0
317	TPCODL	CIRCLE-1, BE	BED, BBSR	33 kV ESPLANA	14021401	4	4	0	0	0	0	0
318	TPCODL	CIRCLE-1, BE	BED, BBSR	11 kV MANCHE	14022201	50	42	0	8	0	8	0
319	TPCODL	CIRCLE-1, BE	BED, BBSR	11 kV MANCHE	14022202	83	71	0	12	0	12	0
320	TPCODL	CIRCLE-1, BE	BED, BBSR	11 kV MANCHE	14022203	74	45	0	29	0	29	0
321	TPCODL	CIRCLE-1, BE	BED, BBSR	11 kV VSS NAG	14022204	66	54	0	12	0	12	0
322	TPCODL	CIRCLE-1, BE	BED, BBSR	33 kV IDCO	14022401	3	3	0	0	0	0	0
323	TPCODL	CIRCLE-1, BE	BED, BBSR	33 kV NSIC	14022402	1	1	0	0	0	0	0
324	TPCODL	CIRCLE-1, BE	BED, BBSR	11 kV GOBINDI	14023201	55	42	0	13	0	13	0
325	TPCODL	CIRCLE-1, BE	BED, BBSR	11 kV TRINATH	14023202	25	14	0	11	0	11	0
326	TPCODL	CIRCLE-1, BE	BED, BBSR	11 kV PAHAL	14023203	145	121	0	24	0	24	0
327	TPCODL	CIRCLE-1, BE	BED, BBSR	11 kV DPS	14023204	73	53	0	20	0	20	0
328	TPCODL	CIRCLE-1, BE	BED, BBSR	11 kV SUM HO	14023205	3	3	0	0	0	0	0
329	TPCODL	CIRCLE-1, BE	BED, BBSR	11 kV TRINATH	14023206	116	78	0	38	0	37	1
330	TPCODL	CIRCLE-1, BE	BED, BBSR	11 KV PAHAL U	14023207	61	50	0	11	0	10	1
331	TPCODL	CIRCLE-1, BE	BED, BBSR	11 kV GOVINDI	14023209	48	34	0	14	0	14	0
332	TPCODL	CIRCLE-1, BE	BED, BBSR	11 kV KAUSHAI	14026201	128	96	0	32	0	31	1
333	TPCODL	CIRCLE-1, BE	BED, BBSR	11 kV DHAULI	14026202	153	125	0	28	0	28	0
334	TPCODL	CIRCLE-1, BE	BED, BBSR	11 kV KEC	14026203	66	55	0	11	0	10	1
335	TPCODL	CIRCLE-1, BE	BED, BBSR	11 kV SARDEIP	14026204	54	48	0	6	0	6	0
336	TPCODL	CIRCLE-1, BE	BED, BBSR	11 kV PIPILI	14028201	1	1	0	0	0	0	0
337	TPCODL	CIRCLE-1, BE	BED, BBSR	11 kV NAHARK	14180201	53	29	0	24	0	24	0
338	TPCODL	CIRCLE-1, BE	BED, BBSR	11 kV BALIANT	14180202	168	101	0	67	0	66	1
339	TPCODL	CIRCLE-1, BE	BED, BBSR	11 kV ATALA	14180203	211	150	0	61	0	60	1
340	TPCODL	CIRCLE-1, BE	BED, BBSR	11 kV JAYDEV (	14180204	30	19	0	11	0	11	0
341	TPCODL	CIRCLE-1, BE	BED, BBSR	11 kV SBI COLO	14183201	4	4	0	0	0	0	0
342	TPCODL	CIRCLE-1, BE	BED, BBSR	11 kV KESURA	14183202	105	81	0	24	0	24	0
343	TPCODL	CIRCLE-1, BE	BED, BBSR	11 kV GANGES	14224201	32	25	0	7	0	7	0
344	TPCODL	CIRCLE-1, BE	BED, BBSR	11 kV BHINGAI	14224202	25	19	0	6	0	6	0
345	TPCODL	CIRCLE-1, BE	BED, BBSR	11 kV BHINGAI	14224203	105	85	0	20	0	20	0

SI No.	Zone name	Circle name	Division name	Feeder name	Feeder ID	Total no of DT on feeder	No of unmetered DTC	No of metered DTC			No of DT's with functional meters	
								AMR metered (communicable)	AMI metered (Communicable)	No AMR/AMI metered (non communicable)	Communicating (Total no out 0f 07 & 08)	Non-Communicating (Total no out 0f 07 & 08 & 09)
0	1	2	3	4	12	5=(6+7+8+9)	6	7	8	9	10	11
346	TPCODL	CIRCLE-1, BE	BED, BBSR	11 kV RAJDHAN	14243201	12	10	0	2	0	2	0
347	TPCODL	CIRCLE-1, BE	BED, BBSR	11 kV GYANA B	14243202	34	31	0	3	0	3	0
348	TPCODL	CIRCLE-1, BE	BED, BBSR	11 kV BHATAPA	14243203	52	40	0	12	0	12	0
349	TPCODL	CIRCLE-1, BE	BED, BBSR	11 kV SISHUPA	14244201	18	18	0	0	0	0	0
350	TPCODL	CIRCLE-1, BE	BED, BBSR	11 kV KUAKHA	14244202	196	171	0	25	0	25	0
351	TPCODL	CIRCLE-1, BE	BED, BBSR	11 kV CIFA	14244203	13	8	0	5	0	5	0
352	TPCODL	CIRCLE-1, BE	BED, BBSR	11 kV GANGUA	14244204	30	19	0	11	0	11	0
353	TPCODL	CIRCLE-1, BE	BED, BBSR	11 kV SHAKTI N	14244205	31	15	0	16	0	15	1
354	TPCODL	CIRCLE-1, BE	BED, BBSR	11 kV GANGOT	14244206	29	17	0	12	0	12	0
355	TPCODL	CIRCLE-1, BE	BED, BBSR	11 kV INDIRA C	14244207	47	25	0	22	0	22	0
356	TPCODL	CIRCLE-1, BE	BED, BBSR	11 kV KALPANA	14245201	25	10	0	15	0	15	0
357	TPCODL	CIRCLE-1, BE	BED, BBSR	11 kV CUTTACK	14245202	43	17	0	26	0	26	0
358	TPCODL	CIRCLE-1, BE	BED, BBSR	11 kV KAPILESV	14252201	39	14	0	25	0	25	0
359	TPCODL	CIRCLE-1, BE	BED, BBSR	11 kV MAHAVI	14252202	22	9	0	13	0	13	0
360	TPCODL	CIRCLE-1, BE	BED, BBSR	11 kV RATHA R	14252203	7	4	0	3	0	3	0
361	TPCODL	CIRCLE-1, BE	BED, BBSR	11 kV MULAPA	14252204	36	12	0	24	0	22	2
362	TPCODL	CIRCLE-1, BE	BED, BBSR	11 kV KALYANI	14253201	40	19	0	21	0	20	1
363	TPCODL	CIRCLE-1, BE	BED, BBSR	11 kV PRADHA	14253202	44	31	0	13	0	13	0
364	TPCODL	CIRCLE-1, BE	BED, BBSR	11 kV PANCHA	14253203	56	43	0	13	0	13	0
365	TPCODL	CIRCLE-1, BE	BED, BBSR	11 kV HITECH-(	14253204	103	77	0	26	0	26	0
366	TPCODL	CIRCLE-1, BE	BED, BBSR	11 kV HITECH-U	14253205	70	45	0	25	0	25	0
367	TPCODL	CIRCLE-1, BE	BED, BBSR	11 kV LAXMINA	14254201	81	65	0	16	0	16	0
368	TPCODL	CIRCLE-1, BE	BED, BBSR	11 kV PATASAI	14254202	85	67	0	18	0	18	0
369	TPCODL	CIRCLE-1, BE	BED, BBSR	11 kV DAHISPA	14254203	114	91	0	23	0	23	0
370	TPCODL	CIRCLE-1, BE	BED, BBSR	11 kV PRACHI	14370201	76	45	0	31	0	31	0
371	TPCODL	CIRCLE-1, BE	BED, BBSR	11 kV JAGANN/	14370202	14	5	0	9	0	9	0
372	TPCODL	CIRCLE-1, BE	BED, BBSR	11 kV PANDRA	14370203	44	33	0	11	0	11	0
373	TPCODL	CIRCLE-1, BE	BED, BBSR	11 kV MANGAF	14370204	143	107	0	36	0	35	1
374	TPCODL	CIRCLE-1, BE	BED, BBSR	11 KV MANGRA	14370205	62	53	0	9	0	9	0
375	TPCODL	CIRCLE-1, BE	BED, BBSR	11 kV JAGANN/	14370208	32	8	0	24	0	24	0
376	TPCODL	CIRCLE-1, BE	BED, BBSR	33 kV INDUSTR	17001405	3	3	0	0	0	0	0
377	TPCODL	CIRCLE-1, BE	BED, BBSR	33 kV LAXMISA	17001406	4	4	0	0	0	0	0
378	TPCODL	CIRCLE-1, BE	BED, BBSR	33 kV NAHARK	17001407	10	10	0	0	0	0	0
379	TPCODL	CIRCLE-1, BE	BED, BBSR	33 kV BHIMATA	17003403	1	1	0	0	0	0	0
380	TPCODL	CIRCLE-1, BE	BED, BBSR	33 kV BHIMATA	17003404	1	1	0	0	0	0	0
381	TPCODL	CIRCLE-1, BE	BED, BBSR	33 kV BALAKAT	17004401	7	1	0	6	0	6	0
382	TPCODL	CIRCLE-1, BE	BED, BBSR	33 kV SBI KESU	17004402	2	1	0	1	0	1	0
383	TPCODL	CIRCLE-1, BE	BED, BBSR	33 kV LAXMISA	17004403	2	0	0	2	0	2	0
384	TPCODL	CIRCLE-1, BE	BED, BBSR	33 kV RASULGA	17004404	10	8	0	2	0	2	0
385	TPCODL	CIRCLE-1, BE	BED, BBSR	33 kV LINGIPUI	17004405	1	1	0	0	0	0	0
386	TPCODL	CIRCLE-1, BE	BED, BBSR	33 kV PHULNA	17022403	5	4	0	1	0	1	0
387	TPCODL	CIRCLE-1, BE	BED, BBSR	33 kV BHINGAF	17022405	1	1	0	0	0	0	0
388	TPCODL	CIRCLE-1, BE	BED, BBSR	33 kV RASULGA	17047401	4	4	0	0	0	0	0
389	TPCODL	CIRCLE-1, BE	BED, BBSR	33 kV MANCHE	17047402	1	1	0	0	0	0	0
390	TPCODL	CIRCLE-1, BE	BED, BBSR	33 kV UTTARA	17057403	1	1	0	0	0	0	0
391	TPCODL	CIRCLE-1, BE	NED, NIMA	11 kV BALIPATI	14024201	105	84	0	21	0	21	0
392	TPCODL	CIRCLE-1, BE	NED, NIMA	11 kV BUDHIPA	14024202	253	212	0	41	0	40	1
393	TPCODL	CIRCLE-1, BE	NED, NIMA	11 kV BANAMA	14024203	26	18	0	8	0	8	0
394	TPCODL	CIRCLE-1, BE	NED, NIMA	11 kV NARADA	14024204	141	113	0	28	0	27	1
395	TPCODL	CIRCLE-1, BE	NED, NIMA	11 kV BALAKAT	14025201	103	86	0	17	0	16	1
396	TPCODL	CIRCLE-1, BE	NED, NIMA	11 kV SATYABH	14025202	205	168	0	37	0	36	1
397	TPCODL	CIRCLE-1, BE	NED, NIMA	11 kV BAINCHU	14025203	44	25	0	19	0	19	0
398	TPCODL	CIRCLE-1, BE	NED, NIMA	11 kV CHARICH	14027201	224	197	0	27	0	27	0
399	TPCODL	CIRCLE-1, BE	NED, NIMA	11 kV DANDIPU	14027203	163	142	0	21	0	21	0
400	TPCODL	CIRCLE-1, BE	NED, NIMA	11 kV OMFED	14027204	66	40	0	26	0	25	1
401	TPCODL	CIRCLE-1, BE	NED, NIMA	11 kV NIMAPA	14027205	145	102	0	43	0	43	0
402	TPCODL	CIRCLE-1, BE	NED, NIMA	11 kV BASANT	14027206	39	32	0	7	0	7	0
403	TPCODL	CIRCLE-1, BE	NED, NIMA	11 kV PIPILI	14028201	210	150	0	60	0	59	1

SI No.	Zone name	Circle name	Division name	Feeder name	Feeder ID	Total no of DT on feeder	No of unmetered DTC	No of metered DTC			No of DT's with functional meters	
								AMR metered (communicable)	AMI metered (Communicable)	No AMR/AMI metered (non communicable)	Communicating (Total no out 0f 07 & 08)	Non-Communicating (Total no out 0f 07 & 08 & 09)
0	1	2	3	4	12	5=(6+7+8+9)	6	7	8	9	10	11
404	TPCODL	CIRCLE-1, BE	NED, NIMA	11 kV RAJAS	14028202	129	109	0	20	0	20	0
405	TPCODL	CIRCLE-1, BE	NED, NIMA	11 kV MANGAL	14028203	76	49	0	27	0	26	1
406	TPCODL	CIRCLE-1, BE	NED, NIMA	11 kV MANGAL	14028204	205	163	0	42	0	42	0
407	TPCODL	CIRCLE-1, BE	NED, NIMA	11 kV ASTARAN	14029201	147	125	0	22	0	22	0
408	TPCODL	CIRCLE-1, BE	NED, NIMA	11 kV JIUNTY	14029202	174	157	0	17	0	17	0
409	TPCODL	CIRCLE-1, BE	NED, NIMA	11 kV SUNDAR	14029203	24	21	0	3	0	3	0
410	TPCODL	CIRCLE-1, BE	NED, NIMA	11 kV KAKATPU	14030201	15	9	0	6	0	5	1
411	TPCODL	CIRCLE-1, BE	NED, NIMA	11 kV NILAKAN	14030203	94	77	0	17	0	17	0
412	TPCODL	CIRCLE-1, BE	NED, NIMA	11 kV NAYAHA	14030204	217	202	0	15	0	15	0
413	TPCODL	CIRCLE-1, BE	NED, NIMA	11 kV KAKATPU	14030205	187	141	0	46	0	46	0
414	TPCODL	CIRCLE-1, BE	NED, NIMA	33 kV ASTARAN	14030401	2	2	0	0	0	0	0
415	TPCODL	CIRCLE-1, BE	NED, NIMA	11 kV KONARK	14031201	40	26	0	14	0	14	0
416	TPCODL	CIRCLE-1, BE	NED, NIMA	11 kV BALIDOK	14031202	119	112	0	7	0	7	0
417	TPCODL	CIRCLE-1, BE	NED, NIMA	11 kV KONARK	14031204	19	8	0	11	0	11	0
418	TPCODL	CIRCLE-1, BE	NED, NIMA	11 kV ANASARA	14031205	44	33	0	11	0	11	0
419	TPCODL	CIRCLE-1, BE	NED, NIMA	11 kV DASABAT	14031206	97	87	0	10	0	10	0
420	TPCODL	CIRCLE-1, BE	NED, NIMA	11 kV SIRIPUR	14031207	62	56	0	6	0	6	0
421	TPCODL	CIRCLE-1, BE	NED, NIMA	11 kV ODAFFP	14031208	1	1	0	0	0	0	0
422	TPCODL	CIRCLE-1, BE	NED, NIMA	11 kV CHARISH	14032201	105	93	0	12	0	12	0
423	TPCODL	CIRCLE-1, BE	NED, NIMA	11 kV DALANA	14032202	81	71	0	10	0	10	0
424	TPCODL	CIRCLE-1, BE	NED, NIMA	11 kV KAKUDIA	14035202	53	39	0	14	0	13	1
425	TPCODL	CIRCLE-1, BE	NED, NIMA	33 kV BHARTIP	14035401	1	1	0	0	0	0	0
426	TPCODL	CIRCLE-1, BE	NED, NIMA	11 kV GOP	14051201	60	48	0	12	0	12	0
427	TPCODL	CIRCLE-1, BE	NED, NIMA	11 kV NAGAPU	14051202	92	79	0	13	0	13	0
428	TPCODL	CIRCLE-1, BE	NED, NIMA	11 kV BEGUNA	14051203	137	121	0	16	0	16	0
429	TPCODL	CIRCLE-1, BE	NED, NIMA	11 kV PAYARA	14051204	100	85	0	15	0	15	0
430	TPCODL	CIRCLE-1, BE	NED, NIMA	33 kV NAGAPU	14051401	1	1	0	0	0	0	0
431	TPCODL	CIRCLE-1, BE	NED, NIMA	11 kV Toshali	14070204	5	5	0	0	0	0	0
432	TPCODL	CIRCLE-1, BE	NED, NIMA	11 kV BHINGAR	14224203	14	11	0	3	0	3	0
433	TPCODL	CIRCLE-1, BE	NED, NIMA	11 kV KALPANA	14245201	1	1	0	0	0	0	0
434	TPCODL	CIRCLE-1, BE	NED, NIMA	11 kV BANAMA	14255201	171	135	0	36	0	36	0
435	TPCODL	CIRCLE-1, BE	NED, NIMA	11 kV VANRA	14255202	27	25	0	2	0	2	0
436	TPCODL	CIRCLE-1, BE	NED, NIMA	11 kV JAYADEV	14255203	93	74	0	19	0	19	0
437	TPCODL	CIRCLE-1, BE	NED, NIMA	11 kV NUAGAD	14256201	75	67	0	8	0	8	0
438	TPCODL	CIRCLE-1, BE	NED, NIMA	11 kV PATALAD	14256202	91	84	0	7	0	7	0
439	TPCODL	CIRCLE-1, BE	NED, NIMA	11 kV KANAMA	14256203	54	49	0	5	0	5	0
440	TPCODL	CIRCLE-1, BE	NED, NIMA	11 kV NUASAN	14257201	82	71	0	11	0	11	0
441	TPCODL	CIRCLE-1, BE	NED, NIMA	11 kV VBHNTI	14257202	71	63	0	8	0	8	0
442	TPCODL	CIRCLE-1, BE	NED, NIMA	11 kV DAVAR	14257203	50	45	0	5	0	5	0
443	TPCODL	CIRCLE-1, BE	NED, NIMA	11 kV Sadamgo	14258201	76	61	0	15	0	15	0
444	TPCODL	CIRCLE-1, BE	NED, NIMA	11 kV TRAHI AC	14259201	42	37	0	5	0	5	0
445	TPCODL	CIRCLE-1, BE	NED, NIMA	11 kV MUKUNI	14259202	51	39	0	12	0	12	0
446	TPCODL	CIRCLE-1, BE	NED, NIMA	11 kV RAJAS(TF	14259203	57	50	0	7	0	7	0
447	TPCODL	CIRCLE-1, BE	NED, NIMA	11 kV ABHAYA	14260201	52	46	0	6	0	6	0
448	TPCODL	CIRCLE-1, BE	NED, NIMA	11 kV BASANTA	14260202	68	63	0	5	0	5	0
449	TPCODL	CIRCLE-1, BE	NED, NIMA	11 kV CHENUA	14260203	31	27	0	4	0	4	0
450	TPCODL	CIRCLE-1, BE	NED, NIMA	11 kV BALI KAP	14261201	72	64	0	8	0	8	0
451	TPCODL	CIRCLE-1, BE	NED, NIMA	11 kV SUTAN	14261203	10	9	0	1	0	1	0
452	TPCODL	CIRCLE-1, BE	NED, NIMA	11 kV Bangurig	14262201	103	94	0	9	0	9	0
453	TPCODL	CIRCLE-1, BE	NED, NIMA	11 kV TIKARPA	14262202	91	84	0	7	0	7	0
454	TPCODL	CIRCLE-1, BE	NED, NIMA	11 kV Binispur	14263201	71	58	0	13	0	13	0
455	TPCODL	CIRCLE-1, BE	NED, NIMA	11 kV Nayhata	14263202	102	86	0	16	0	16	0
456	TPCODL	CIRCLE-1, BE	NED, NIMA	11 kV GadaAm	14263203	82	70	0	12	0	12	0
457	TPCODL	CIRCLE-1, BE	NED, NIMA	11 kV CHINGUI	14264202	9	8	0	1	0	1	0
458	TPCODL	CIRCLE-1, BE	NED, NIMA	11 kV Khelar Ba	14264203	101	88	0	13	0	12	1
459	TPCODL	CIRCLE-1, BE	NED, NIMA	11 kV MANGAL	14265201	88	70	0	18	0	18	0
460	TPCODL	CIRCLE-1, BE	NED, NIMA	11 kV RAHAGIR	14265202	39	28	0	11	0	11	0
461	TPCODL	CIRCLE-1, BE	NED, NIMA	11 kV MALLAG	14266201	46	42	0	4	0	4	0

SI No.	Zone name	Circle name	Division name	Feeder name	Feeder ID	Total no of DT on feeder	No of unmetered DTC	No of metered DTC			No of DT's with functional meters	
								AMR metered (communicable)	AMI metered (Communicable)	No AMR/AMI metered (non communicable)	Communicating (Total no out 0f 07 & 08)	Non-Communicating (Total no out 0f 07 & 08 & 09)
0	1	2	3	4	12	5=(6+7+8+9)	6	7	8	9	10	11
462	TPCODL	CIRCLE-1, BE	NED, NIMA	11 kV NAGAPU	14266202	28	20	0	8	0	7	1
463	TPCODL	CIRCLE-1, BE	NED, NIMA	11 kV MADARA	14266203	53	48	0	5	0	5	0
464	TPCODL	CIRCLE-1, BE	NED, NIMA	33 kV CHHAITA	14266401	1	1	0	0	0	0	0
465	TPCODL	CIRCLE-1, BE	NED, NIMA	11 kV SAILO	14373201	27	24	0	3	0	3	0
466	TPCODL	CIRCLE-1, BE	NED, NIMA	11 kV KALIAPA	14379201	28	25	0	3	0	3	0
467	TPCODL	CIRCLE-1, BE	NED, NIMA	11 kV ALANDA	14379202	60	50	0	10	0	10	0
468	TPCODL	CIRCLE-1, BE	NED, NIMA	11 kV DHANUA	14379203	44	40	0	4	0	4	0
469	TPCODL	CIRCLE-1, BE	NED, NIMA	11 KV BEROBO	14379204	37	33	0	4	0	4	0
470	TPCODL	CIRCLE-1, BE	NED, NIMA	33 kV BALAKAT	17004401	2	2	0	0	0	0	0
471	TPCODL	CIRCLE-1, BE	NED, NIMA	33 kV NIMAPA	17005401	2	1	0	1	0	1	0
472	TPCODL	CIRCLE-1, BE	NED, NIMA	33 kV KAKATPU	17005402	3	3	0	0	0	0	0
473	TPCODL	CIRCLE-1, BE	NED, NIMA	33 kV KONARK	17005403	2	2	0	0	0	0	0
474	TPCODL	CIRCLE-1, BE	NED, NIMA	33 kV PIPILI	17005404	7	6	0	1	0	1	0
475	TPCODL	CIRCLE-1, BE	NED, NIMA	33 kV BAMANA	17005405	3	3	0	0	0	0	0
476	TPCODL	CIRCLE-1, BE	NED, NIMA	33 kV KONARK	17006401	1	1	0	0	0	0	0
477	TPCODL	CIRCLE-1, BE	NED, NIMA	33 kV GOP	17006402	3	3	0	0	0	0	0
478	TPCODL	CIRCLE-1, BE	NED, NIMA	33 kV BANGUR	17006403	3	3	0	0	0	0	0
479	TPCODL	CIRCLE-1, BE	NED, NIMA	33 kV SUTAN	17006404	3	2	0	1	0	1	0
480	TPCODL	CIRCLE-1, BE	NED, NIMA	33 kV BANAMA	17022404	1	1	0	0	0	0	0
481	TPCODL	CIRCLE-1, BE	NED, NIMA	33 kV BALIPAT	17057402	1	1	0	0	0	0	0
482	TPCODL	CIRCLE-2, BE	KHD, KHUI	11 kV MALIPAD	1403802	1	1	0	0	0	0	0
483	TPCODL	CIRCLE-2, BE	KHD, KHUI	11 kV BAGHAM	1404002	1	1	0	0	0	0	0
484	TPCODL	CIRCLE-2, BE	KHD, KHUI	11 kV BACHHA	14033201	67	45	0	22	0	22	0
485	TPCODL	CIRCLE-2, BE	KHD, KHUI	11 kV RAJA BAZ	14033202	28	14	0	14	0	14	0
486	TPCODL	CIRCLE-2, BE	KHD, KHUI	11 kV KUSUMA	14033203	31	11	0	20	0	20	0
487	TPCODL	CIRCLE-2, BE	KHD, KHUI	11 kV JATNI TO	14033204	31	20	0	11	0	11	0
488	TPCODL	CIRCLE-2, BE	KHD, KHUI	11 kV JATANI M	14033206	49	38	0	11	0	11	0
489	TPCODL	CIRCLE-2, BE	KHD, KHUI	11 kV GAJAPAT	14033207	29	16	0	13	0	13	0
490	TPCODL	CIRCLE-2, BE	KHD, KHUI	33 kV HARIRAJ	14033401	5	4	0	1	0	1	0
491	TPCODL	CIRCLE-2, BE	KHD, KHUI	11 kV MENDHA	14034201	57	51	0	6	0	6	0
492	TPCODL	CIRCLE-2, BE	KHD, KHUI	11 kV OIL MILL	14034202	131	120	0	11	0	11	0
493	TPCODL	CIRCLE-2, BE	KHD, KHUI	11 kV JANALA	14034203	22	17	0	5	0	5	0
494	TPCODL	CIRCLE-2, BE	KHD, KHUI	11 kV MADANP	14034204	173	144	0	29	0	29	0
495	TPCODL	CIRCLE-2, BE	KHD, KHUI	11 kV KANTIA	14035201	31	19	0	12	0	12	0
496	TPCODL	CIRCLE-2, BE	KHD, KHUI	11 kV KAKUDIA	14035202	24	21	0	3	0	3	0
497	TPCODL	CIRCLE-2, BE	KHD, KHUI	11 kV KUDIARY	14035203	48	29	0	19	0	18	1
498	TPCODL	CIRCLE-2, BE	KHD, KHUI	11 kV GOLAPAI	14035204	18	14	0	4	0	4	0
499	TPCODL	CIRCLE-2, BE	KHD, KHUI	11 kV BAHILIPA	14035205	63	58	0	5	0	5	0
500	TPCODL	CIRCLE-2, BE	KHD, KHUI	11 kV SUJIMILL	14035206	3	3	0	0	0	0	0
501	TPCODL	CIRCLE-2, BE	KHD, KHUI	33 kV XAVIER	14035402	2	2	0	0	0	0	0
502	TPCODL	CIRCLE-2, BE	KHD, KHUI	11 kV HALADIA	14036201	276	250	0	26	0	26	0
503	TPCODL	CIRCLE-2, BE	KHD, KHUI	11 kV OLASING	14037201	91	78	0	13	0	13	0
504	TPCODL	CIRCLE-2, BE	KHD, KHUI	11 kV GOLABAI	14037202	118	107	0	11	0	11	0
505	TPCODL	CIRCLE-2, BE	KHD, KHUI	11 kV NIRAKAR	14037203	119	94	0	25	0	25	0
506	TPCODL	CIRCLE-2, BE	KHD, KHUI	11 kV BADAPO	14037204	87	79	0	8	0	8	0
507	TPCODL	CIRCLE-2, BE	KHD, KHUI	33 kV MAGANI	14037401	3	2	0	1	0	1	0
508	TPCODL	CIRCLE-2, BE	KHD, KHUI	11 kV NARANG	14038201	53	40	0	13	0	13	0
509	TPCODL	CIRCLE-2, BE	KHD, KHUI	11 kV MALIPAD	14038202	76	66	0	10	0	10	0
510	TPCODL	CIRCLE-2, BE	KHD, KHUI	11 kV NARANG	14038203	7	7	0	0	0	0	0
511	TPCODL	CIRCLE-2, BE	KHD, KHUI	11 kV CHATARA	14038204	121	118	0	3	0	3	0
512	TPCODL	CIRCLE-2, BE	KHD, KHUI	11 kV NIRAKAR	14039201	92	80	0	12	0	12	0
513	TPCODL	CIRCLE-2, BE	KHD, KHUI	11 kV MANDAR	14039202	62	49	0	13	0	13	0
514	TPCODL	CIRCLE-2, BE	KHD, KHUI	11 kV KAIMATI	14039203	12	9	0	3	0	3	0
515	TPCODL	CIRCLE-2, BE	KHD, KHUI	11 kV MANPUR	14039204	75	63	0	12	0	12	0
516	TPCODL	CIRCLE-2, BE	KHD, KHUI	11 kV NARANG	14039205	5	3	0	2	0	2	0
517	TPCODL	CIRCLE-2, BE	KHD, KHUI	11 kV SARUA (B	14040201	17	13	0	4	0	4	0
518	TPCODL	CIRCLE-2, BE	KHD, KHUI	11 kV PODADH	14040202	104	94	0	10	0	10	0
519	TPCODL	CIRCLE-2, BE	KHD, KHUI	11 kV ATRI	14040203	82	70	0	12	0	12	0

SI No.	Zone name	Circle name	Division name	Feeder name	Feeder ID	Total no of DT on feeder	No of unmetered DTC	No of metered DTC			No of DT's with functional meters	
								AMR metered (communicable)	AMI metered (Communicable)	No AMR/AMI metered (non communicable)	Communicating (Total no out 0f 07 & 08)	Non-Communicating (Total no out 0f 07 & 08 & 09)
0	1	2	3	4	12	5=(6+7+8+9)	6	7	8	9	10	11
520	TPCODL	CIRCLE-2, BE	KHD, KHUI	33 kV BEGUNIA	14040401	4	2	0	2	0	2	0
521	TPCODL	CIRCLE-2, BE	KHD, KHUI	33 kV KALAPAT	14040402	2	1	0	1	0	1	0
522	TPCODL	CIRCLE-2, BE	KHD, KHUI	11 kV GADAMA	14041201	44	40	0	4	0	4	0
523	TPCODL	CIRCLE-2, BE	KHD, KHUI	11 kV GUDDUN	14041202	40	37	0	3	0	3	0
524	TPCODL	CIRCLE-2, BE	KHD, KHUI	11 kV PARICHH	14041203	85	80	0	5	0	5	0
525	TPCODL	CIRCLE-2, BE	KHD, KHUI	11 kV PATANAI	14041204	126	122	0	4	0	4	0
526	TPCODL	CIRCLE-2, BE	KHD, KHUI	11 kV ROUTPA	14041205	51	47	0	4	0	4	0
527	TPCODL	CIRCLE-2, BE	KHD, KHUI	11 kV BAYAPAL	14042201	77	69	0	8	0	8	0
528	TPCODL	CIRCLE-2, BE	KHD, KHUI	11 kV KADABA	14042202	121	110	0	11	0	11	0
529	TPCODL	CIRCLE-2, BE	KHD, KHUI	11 kV SUNAKH	14042203	89	74	0	15	0	15	0
530	TPCODL	CIRCLE-2, BE	KHD, KHUI	11 kV BANKOI	14042204	154	146	0	8	0	7	1
531	TPCODL	CIRCLE-2, BE	KHD, KHUI	11 kV SANA PA	14042205	134	115	0	19	0	18	1
532	TPCODL	CIRCLE-2, BE	KHD, KHUI	11 kV BPCL	14043201	1	1	0	0	0	0	0
533	TPCODL	CIRCLE-2, BE	KHD, KHUI	11 kV MUKUNI	14043202	84	53	0	31	0	31	0
534	TPCODL	CIRCLE-2, BE	KHD, KHUI	11 kV INDUSTR	14043204	58	57	0	1	0	1	0
535	TPCODL	CIRCLE-2, BE	KHD, KHUI	11 kV TAPANG	14043205	116	105	0	11	0	11	0
536	TPCODL	CIRCLE-2, BE	KHD, KHUI	11 kV OTPL	14043206	40	34	0	6	0	5	1
537	TPCODL	CIRCLE-2, BE	KHD, KHUI	11 KV SHIVA SA	14043207	44	41	0	3	0	3	0
538	TPCODL	CIRCLE-2, BE	KHD, KHUI	33 kV DENZON	14043402	13	13	0	0	0	0	0
539	TPCODL	CIRCLE-2, BE	KHD, KHUI	11 kV KHORDH	14044201	44	25	0	19	0	18	1
540	TPCODL	CIRCLE-2, BE	KHD, KHUI	11 kV 10 POLE	14044202	4	4	0	0	0	0	0
541	TPCODL	CIRCLE-2, BE	KHD, KHUI	11 kV PANABA	14044203	127	102	0	25	0	25	0
542	TPCODL	CIRCLE-2, BE	KHD, KHUI	11 kV KHORDH	14044204	105	54	0	51	0	51	0
543	TPCODL	CIRCLE-2, BE	KHD, KHUI	11 kV GURUJAI	14044205	67	39	0	28	0	27	1
544	TPCODL	CIRCLE-2, BE	KHD, KHUI	11 kV TARATUA	14044206	86	70	0	16	0	16	0
545	TPCODL	CIRCLE-2, BE	KHD, KHUI	11 kV TULASIPU	14045201	58	50	0	8	0	8	0
546	TPCODL	CIRCLE-2, BE	KHD, KHUI	11 kV BANKI TO	14047201	141	90	0	51	0	50	1
547	TPCODL	CIRCLE-2, BE	KHD, KHUI	11 kV RAJIB	14047202	139	126	0	13	0	13	0
548	TPCODL	CIRCLE-2, BE	KHD, KHUI	11 kV VEDA	14047203	80	71	0	9	0	9	0
549	TPCODL	CIRCLE-2, BE	KHD, KHUI	11 kV CHAKAPA	14047204	40	29	0	11	0	11	0
550	TPCODL	CIRCLE-2, BE	KHD, KHUI	11 kV RWSS	14047205	6	4	0	2	0	2	0
551	TPCODL	CIRCLE-2, BE	KHD, KHUI	33 kV JATAMU	14047401	1	0	0	1	0	1	0
552	TPCODL	CIRCLE-2, BE	KHD, KHUI	11 kV BAIDESW	14048201	123	98	0	25	0	25	0
553	TPCODL	CIRCLE-2, BE	KHD, KHUI	11 kV KALAPAT	14048203	88	70	0	18	0	17	1
554	TPCODL	CIRCLE-2, BE	KHD, KHUI	33 kV BAIDESW	14048401	1	1	0	0	0	0	0
555	TPCODL	CIRCLE-2, BE	KHD, KHUI	11 kV TALABAS	14049201	124	112	0	12	0	12	0
556	TPCODL	CIRCLE-2, BE	KHD, KHUI	11 kV JATAMU	14049202	2	0	0	2	0	2	0
557	TPCODL	CIRCLE-2, BE	KHD, KHUI	11 kV RAMACH	14049203	121	98	0	23	0	23	0
558	TPCODL	CIRCLE-2, BE	KHD, KHUI	11 kV TARAPUI	14049204	44	39	0	5	0	5	0
559	TPCODL	CIRCLE-2, BE	KHD, KHUI	11 kV GADAJIT	14049205	86	69	0	17	0	17	0
560	TPCODL	CIRCLE-2, BE	KHD, KHUI	33 kV BANARA	14049401	1	1	0	0	0	0	0
561	TPCODL	CIRCLE-2, BE	KHD, KHUI	11 kV TIRUMAL	14050201	19	13	0	6	0	6	0
562	TPCODL	CIRCLE-2, BE	KHD, KHUI	11 kV TARABOI	14050202	70	53	0	17	0	17	0
563	TPCODL	CIRCLE-2, BE	KHD, KHUI	11 kV BENAPA	14050203	53	43	0	10	0	10	0
564	TPCODL	CIRCLE-2, BE	KHD, KHUI	11 kV IDCO (Tir	14050204	32	28	0	4	0	4	0
565	TPCODL	CIRCLE-2, BE	KHD, KHUI	11 kV RENGALA	14050205	1	1	0	0	0	0	0
566	TPCODL	CIRCLE-2, BE	KHD, KHUI	33 kV BINDAPA	14052401	4	3	0	1	0	1	0
567	TPCODL	CIRCLE-2, BE	KHD, KHUI	11 kV BEGUNIA	14182201	51	36	0	15	0	14	1
568	TPCODL	CIRCLE-2, BE	KHD, KHUI	11 kV DINGAR	14182202	153	138	0	15	0	15	0
569	TPCODL	CIRCLE-2, BE	KHD, KHUI	11 kV KAIPADA	14203201	99	81	0	18	0	18	0
570	TPCODL	CIRCLE-2, BE	KHD, KHUI	11 kV DADHIM	14203202	60	51	0	9	0	9	0
571	TPCODL	CIRCLE-2, BE	KHD, KHUI	11 kV BAJPUR	14203203	131	117	0	14	0	14	0
572	TPCODL	CIRCLE-2, BE	KHD, KHUI	11 kV DALEIPU	14203204	31	27	0	4	0	4	0
573	TPCODL	CIRCLE-2, BE	KHD, KHUI	33 kV JANKIA	14203401	5	2	0	3	0	3	0
574	TPCODL	CIRCLE-2, BE	KHD, KHUI	33 kV KHUNTIA	14206401	1	0	0	1	0	1	0
575	TPCODL	CIRCLE-2, BE	KHD, KHUI	11 kV KATHAKI	14267201	24	19	0	5	0	5	0
576	TPCODL	CIRCLE-2, BE	KHD, KHUI	11 kV SARUA (S	14267202	20	17	0	3	0	3	0
577	TPCODL	CIRCLE-2, BE	KHD, KHUI	11 kV PUBUSAI	14267203	70	66	0	4	0	4	0

SI No.	Zone name	Circle name	Division name	Feeder name	Feeder ID	Total no of DT on feeder	No of unmetered DTC	No of metered DTC			No of DT's with functional meters	
								AMR metered (communicable)	AMI metered (Communicable)	No AMR/AMI metered (non communicable)	Communicating (Total no out 0f 07 & 08)	Non-Communicating (Total no out 0f 07 & 08 & 09)
0	1	2	3	4	12	5=(6+7+8+9)	6	7	8	9	10	11
578	TPCODL	CIRCLE-2, BI	KHD, KHUI	11 kV INDUSTR	14267204	38	38	0	0	0	0	0
579	TPCODL	CIRCLE-2, BI	KHD, KHUI	11 kV DERAS	14268201	19	17	0	2	0	2	0
580	TPCODL	CIRCLE-2, BI	KHD, KHUI	11 kV MENDHA	14268202	17	10	0	7	0	6	1
581	TPCODL	CIRCLE-2, BI	KHD, KHUI	11 kV GIRINGA	14268203	20	18	0	2	0	2	0
582	TPCODL	CIRCLE-2, BI	KHD, KHUI	11 kV KADHAM	14269201	71	63	0	8	0	8	0
583	TPCODL	CIRCLE-2, BI	KHD, KHUI	11 kV PUINCHI	14269202	24	22	0	2	0	2	0
584	TPCODL	CIRCLE-2, BI	KHD, KHUI	11 kV GEDIAPA	14269203	115	98	0	17	0	17	0
585	TPCODL	CIRCLE-2, BI	KHD, KHUI	11 kV MANIBA	14269204	33	32	0	1	0	1	0
586	TPCODL	CIRCLE-2, BI	KHD, KHUI	11 kV JAMUJHA	14270201	39	32	0	7	0	7	0
587	TPCODL	CIRCLE-2, BI	KHD, KHUI	11 kV PANIORA	14270202	45	39	0	6	0	5	1
588	TPCODL	CIRCLE-2, BI	KHD, KHUI	11 kV CHHATA	14270203	21	21	0	0	0	0	0
589	TPCODL	CIRCLE-2, BI	KHD, KHUI	11 kV NUAGAO	14271201	30	19	0	11	0	11	0
590	TPCODL	CIRCLE-2, BI	KHD, KHUI	11 kV BIKASH N	14271202	19	12	0	7	0	6	1
591	TPCODL	CIRCLE-2, BI	KHD, KHUI	11 kV Badatota	14271203	58	40	0	18	0	18	0
592	TPCODL	CIRCLE-2, BI	KHD, KHUI	33 kV CENTURI	14271401	3	3	0	0	0	0	0
593	TPCODL	CIRCLE-2, BI	KHD, KHUI	11 kV SAHUPA	14272201	35	30	0	5	0	5	0
594	TPCODL	CIRCLE-2, BI	KHD, KHUI	11 kV KHUNTIA	14272202	62	57	0	5	0	5	0
595	TPCODL	CIRCLE-2, BI	KHD, KHUI	11 kV BALIPAD	14272203	50	47	0	3	0	3	0
596	TPCODL	CIRCLE-2, BI	KHD, KHUI	11 kV CHHANA	14273201	21	13	0	8	0	8	0
597	TPCODL	CIRCLE-2, BI	KHD, KHUI	11 kV HAJA(Ch	14273202	75	63	0	12	0	12	0
598	TPCODL	CIRCLE-2, BI	KHD, KHUI	11 kV SARAPAF	14273203	21	18	0	3	0	3	0
599	TPCODL	CIRCLE-2, BI	KHD, KHUI	11 kV SIKO	14273204	57	48	0	9	0	9	0
600	TPCODL	CIRCLE-2, BI	KHD, KHUI	11 kV Hatabast	14374201	91	81	0	10	0	9	1
601	TPCODL	CIRCLE-2, BI	KHD, KHUI	11 kV KUMBHA	14374202	52	47	0	5	0	5	0
602	TPCODL	CIRCLE-2, BI	KHD, KHUI	11 kV FEEDER-	14376201	8	7	0	1	0	1	0
603	TPCODL	CIRCLE-2, BI	KHD, KHUI	11 kV RBI STAF	14381201	3	3	0	0	0	0	0
604	TPCODL	CIRCLE-2, BI	KHD, KHUI	11 kV SANTI SC	14381202	3	3	0	0	0	0	0
605	TPCODL	CIRCLE-2, BI	KHD, KHUI	11 kV IDCO	14381203	5	5	0	0	0	0	0
606	TPCODL	CIRCLE-2, BI	KHD, KHUI	33 kV BAGCHI	14381401	1	1	0	0	0	0	0
607	TPCODL	CIRCLE-2, BI	KHD, KHUI	33 kV BANKI	17007401	8	7	0	1	0	1	0
608	TPCODL	CIRCLE-2, BI	KHD, KHUI	33 kV BOLAGA	17007402	5	4	0	1	0	1	0
609	TPCODL	CIRCLE-2, BI	KHD, KHUI	33 kV TANGI /	17007403	3	3	0	0	0	0	0
610	TPCODL	CIRCLE-2, BI	KHD, KHUI	33 kV KHURDA	17007404	1	0	0	1	0	1	0
611	TPCODL	CIRCLE-2, BI	KHD, KHUI	33 kV DELANG	17007405	2	1	0	1	0	1	0
612	TPCODL	CIRCLE-2, BI	KHD, KHUI	33 kV RAILWAY	17007406	14	14	0	0	0	0	0
613	TPCODL	CIRCLE-2, BI	KHD, KHUI	33 kV JATANI	17007407	19	16	0	3	0	3	0
614	TPCODL	CIRCLE-2, BI	KHD, KHUI	33 kV JATANIM	17008401	1	1	0	0	0	0	0
615	TPCODL	CIRCLE-2, BI	KHD, KHUI	33 kV IIT ARGU	17009401	2	2	0	0	0	0	0
616	TPCODL	CIRCLE-2, BI	KHD, KHUI	33 kV NISER 1	17009402	3	3	0	0	0	0	0
617	TPCODL	CIRCLE-2, BI	KHD, KHUI	33 kV ICFMD	17009405	1	1	0	0	0	0	0
618	TPCODL	CIRCLE-2, BI	KHD, KHUI	33 kV COCACO	17009406	2	2	0	0	0	0	0
619	TPCODL	CIRCLE-2, BI	KHD, KHUI	33 kV NUAGAO	17009407	3	3	0	0	0	0	0
620	TPCODL	CIRCLE-2, BI	KHD, KHUI	33 kV SUNADE	17010401	1	0	0	1	0	1	0
621	TPCODL	CIRCLE-2, BI	KHD, KHUI	33 kV CHARCH	17010402	4	2	0	2	0	2	0
622	TPCODL	CIRCLE-2, BI	KHD, KHUI	33 kV MEGA RV	17010403	2	2	0	0	0	0	0
623	TPCODL	CIRCLE-2, BI	KHD, KHUI	33 kV INFOSYS	17041401	1	1	0	0	0	0	0
624	TPCODL	CIRCLE-2, BI	KHD, KHUI	33 kV CHHATA	17041403	15	14	0	1	0	1	0
625	TPCODL	CIRCLE-2, BI	KHD, KHUI	33 kV EMC PAF	17041404	1	0	0	1	0	1	0
626	TPCODL	CIRCLE-2, BI	KHD, KHUI	33 kV RBI-01	17041405	1	1	0	0	0	0	0
627	TPCODL	CIRCLE-2, BI	KHD, KHUI	33 kV RBI-02	17041406	1	1	0	0	0	0	0
628	TPCODL	CIRCLE-2, BI	KHD, KHUI	33 kV PGCIL	17042401	2	2	0	0	0	0	0
629	TPCODL	CIRCLE-2, BI	KHD, KHUI	33 kV VARUN E	17067401	9	7	0	2	0	2	0
630	TPCODL	CIRCLE-2, BI	NYD, NAYA	11 kV GANIA SS	1405701	1	0	0	1	0	1	0
631	TPCODL	CIRCLE-2, BI	NYD, NAYA	11 kV ODAGAO	1406301	1	1	0	0	0	0	0
632	TPCODL	CIRCLE-2, BI	NYD, NAYA	11 kV BOLOGA	14052201	34	24	0	10	0	10	0
633	TPCODL	CIRCLE-2, BI	NYD, NAYA	11 kV KAPASIA	14052202	53	42	0	11	0	11	0
634	TPCODL	CIRCLE-2, BI	NYD, NAYA	11 kV SHYAMS	14052203	70	61	0	9	0	9	0
635	TPCODL	CIRCLE-2, BI	NYD, NAYA	11 kV KHANGU	14052204	62	53	0	9	0	9	0

SI No.	Zone name	Circle name	Division name	Feeder name	Feeder ID	Total no of DT on feeder	No of unmetered DTC	No of metered DTC			No of DT's with functional meters	
								AMR metered (communicable)	AMI metered (Communicable)	No AMR/AMI metered (non communicable)	Communicating (Total no out 0f 07 & 08)	Non-Communicating (Total no out 0f 07 & 08 & 09)
0	1	2	3	4	12	5=(6+7+8+9)	6	7	8	9	10	11
636	TPCODL	CIRCLE-2, BE	NYD, NAYA	11 kV DIBYASIN	14052205	53	39	0	14	0	14	0
637	TPCODL	CIRCLE-2, BE	NYD, NAYA	11 kV ITAMATI	14053201	58	32	0	26	0	26	0
638	TPCODL	CIRCLE-2, BE	NYD, NAYA	11 kV LATHIPA	14053202	57	51	0	6	0	6	0
639	TPCODL	CIRCLE-2, BE	NYD, NAYA	11 kV BADA PA	14053203	162	139	0	23	0	23	0
640	TPCODL	CIRCLE-2, BE	NYD, NAYA	11 kV CHAMPA	14053204	145	119	0	26	0	25	1
641	TPCODL	CIRCLE-2, BE	NYD, NAYA	11 kV LATHIPA	14053205	8	6	0	2	0	2	0
642	TPCODL	CIRCLE-2, BE	NYD, NAYA	33 kV BULAGAI	14053401	1	0	0	1	0	1	0
643	TPCODL	CIRCLE-2, BE	NYD, NAYA	11 kV KHANDA	14054201	65	30	0	35	0	35	0
644	TPCODL	CIRCLE-2, BE	NYD, NAYA	11 kV BAIGUNI	14054202	149	126	0	23	0	23	0
645	TPCODL	CIRCLE-2, BE	NYD, NAYA	11 kV PANIPOI	14054203	128	113	0	15	0	15	0
646	TPCODL	CIRCLE-2, BE	NYD, NAYA	11 kV KHANDA	14054204	5	4	0	1	0	1	0
647	TPCODL	CIRCLE-2, BE	NYD, NAYA	33 kV FATEGAF	14054401	4	1	0	3	0	3	0
648	TPCODL	CIRCLE-2, BE	NYD, NAYA	33 kV KANTILO	14054402	2	1	0	1	0	1	0
649	TPCODL	CIRCLE-2, BE	NYD, NAYA	33 kV PHD	14054403	2	2	0	0	0	0	0
650	TPCODL	CIRCLE-2, BE	NYD, NAYA	11 kV KANTILO	14055201	98	82	0	16	0	16	0
651	TPCODL	CIRCLE-2, BE	NYD, NAYA	11 kV BANAPU	14055202	32	27	0	5	0	4	1
652	TPCODL	CIRCLE-2, BE	NYD, NAYA	11 kV BENAGA	14055203	74	64	0	10	0	10	0
653	TPCODL	CIRCLE-2, BE	NYD, NAYA	33 kV GANIA	14055401	1	1	0	0	0	0	0
654	TPCODL	CIRCLE-2, BE	NYD, NAYA	33 kV PHD	14055402	2	2	0	0	0	0	0
655	TPCODL	CIRCLE-2, BE	NYD, NAYA	11 kV FATEGAF	14056201	26	21	0	5	0	5	0
656	TPCODL	CIRCLE-2, BE	NYD, NAYA	11 kV BHAPUR	14056202	70	59	0	11	0	11	0
657	TPCODL	CIRCLE-2, BE	NYD, NAYA	11 kV GOLAPO	14056203	155	140	0	15	0	15	0
658	TPCODL	CIRCLE-2, BE	NYD, NAYA	11 kV GANIA	14057201	82	64	0	18	0	18	0
659	TPCODL	CIRCLE-2, BE	NYD, NAYA	11 kV KUSKA	14057202	139	128	0	11	0	11	0
660	TPCODL	CIRCLE-2, BE	NYD, NAYA	11 kV BALARAI	14057203	75	59	0	16	0	16	0
661	TPCODL	CIRCLE-2, BE	NYD, NAYA	33 kV CHAMUI	14057401	1	0	0	1	0	1	0
662	TPCODL	CIRCLE-2, BE	NYD, NAYA	11 kV NAYAGA	14058201	64	37	0	27	0	27	0
663	TPCODL	CIRCLE-2, BE	NYD, NAYA	11 kV OLD TOV	14058202	51	30	0	21	0	21	0
664	TPCODL	CIRCLE-2, BE	NYD, NAYA	11 kV SINDURI	14058203	100	68	0	32	0	32	0
665	TPCODL	CIRCLE-2, BE	NYD, NAYA	11 kV BARABA	14058204	5	4	0	1	0	1	0
666	TPCODL	CIRCLE-2, BE	NYD, NAYA	11 kV MEDICAL	14058205	6	4	0	2	0	2	0
667	TPCODL	CIRCLE-2, BE	NYD, NAYA	11 kV DASPALL	14059201	185	144	0	41	0	40	1
668	TPCODL	CIRCLE-2, BE	NYD, NAYA	11 kV MADHYA	14059202	266	254	0	12	0	11	1
669	TPCODL	CIRCLE-2, BE	NYD, NAYA	11 kV POIBARI	14059203	177	173	0	4	0	4	0
670	TPCODL	CIRCLE-2, BE	NYD, NAYA	11 kV KUANRIA	14059204	304	295	0	9	0	9	0
671	TPCODL	CIRCLE-2, BE	NYD, NAYA	11 kV KHAMAF	14059205	156	152	0	4	0	4	0
672	TPCODL	CIRCLE-2, BE	NYD, NAYA	11 kV NUAGAO	14060201	12	10	0	2	0	2	0
673	TPCODL	CIRCLE-2, BE	NYD, NAYA	11 kV SANAPAI	14060202	69	67	0	2	0	2	0
674	TPCODL	CIRCLE-2, BE	NYD, NAYA	11 kV MAHITAI	14060203	192	188	0	4	0	4	0
675	TPCODL	CIRCLE-2, BE	NYD, NAYA	33 kV GANIA	14060401	1	1	0	0	0	0	0
676	TPCODL	CIRCLE-2, BE	NYD, NAYA	33 kV DASPALL	14060402	1	0	0	1	0	1	0
677	TPCODL	CIRCLE-2, BE	NYD, NAYA	11 kV MAHIPU	14061201	82	71	0	11	0	11	0
678	TPCODL	CIRCLE-2, BE	NYD, NAYA	11 kV VIRUDA	14061202	138	126	0	12	0	12	0
679	TPCODL	CIRCLE-2, BE	NYD, NAYA	11 kV SINGARP	14061203	164	156	0	8	0	8	0
680	TPCODL	CIRCLE-2, BE	NYD, NAYA	11 kV SINGARP	14061204	83	77	0	6	0	5	1
681	TPCODL	CIRCLE-2, BE	NYD, NAYA	33 kV NUAGAO	14061401	1	0	0	1	0	1	0
682	TPCODL	CIRCLE-2, BE	NYD, NAYA	11 kV SARANKU	14062201	28	19	0	9	0	9	0
683	TPCODL	CIRCLE-2, BE	NYD, NAYA	11 kV GODIPAI	14062202	107	84	0	23	0	23	0
684	TPCODL	CIRCLE-2, BE	NYD, NAYA	11 kV MACHHI	14062203	6	3	0	3	0	3	0
685	TPCODL	CIRCLE-2, BE	NYD, NAYA	11 kV DARAPA	14062204	78	64	0	14	0	13	1
686	TPCODL	CIRCLE-2, BE	NYD, NAYA	11 kV PANCHID	14062205	141	119	0	22	0	22	0
687	TPCODL	CIRCLE-2, BE	NYD, NAYA	11 kV SIKHARP	14062206	33	23	0	10	0	10	0
688	TPCODL	CIRCLE-2, BE	NYD, NAYA	11 kV BAHADA	14063201	153	141	0	12	0	12	0
689	TPCODL	CIRCLE-2, BE	NYD, NAYA	11 kV KOMANI	14063202	67	58	0	9	0	9	0
690	TPCODL	CIRCLE-2, BE	NYD, NAYA	11 kV ODOGAO	14063203	9	5	0	4	0	4	0
691	TPCODL	CIRCLE-2, BE	NYD, NAYA	11 kV ODOGAO	14063204	60	44	0	16	0	16	0
692	TPCODL	CIRCLE-2, BE	NYD, NAYA	11 kV AMBARP	14063205	91	84	0	7	0	7	0
693	TPCODL	CIRCLE-2, BE	NYD, NAYA	11 kV NANDIGI	14063206	140	128	0	12	0	12	0

SI No.	Zone name	Circle name	Division name	Feeder name	Feeder ID	Total no of DT on feeder	No of unmetered DTC	No of metered DTC			No of DT's with functional meters	
								AMR metered (communicable)	AMI metered (Communicable)	No AMR/AMI metered (non communicable)	Communicating (Total no out 0f 07 & 08)	Non-Communicating (Total no out 0f 07 & 08 & 09)
0	1	2	3	4	12	5=(6+7+8+9)	6	7	8	9	10	11
694	TPCODL	CIRCLE-2, BE	NYD, NAYA	33 kV KURAL &	14063401	2	0	0	2	0	2	0
695	TPCODL	CIRCLE-2, BE	NYD, NAYA	11 kV GODIPAD	14274201	13	8	0	5	0	5	0
696	TPCODL	CIRCLE-2, BE	NYD, NAYA	11 kV DAMASA	14274202	65	57	0	8	0	8	0
697	TPCODL	CIRCLE-2, BE	NYD, NAYA	11 kV NAGAMU	14274203	57	47	0	10	0	10	0
698	TPCODL	CIRCLE-2, BE	NYD, NAYA	11 kV KESHPAN	14274204	85	76	0	9	0	8	1
699	TPCODL	CIRCLE-2, BE	NYD, NAYA	11 kV KURALA	14275201	39	32	0	7	0	7	0
700	TPCODL	CIRCLE-2, BE	NYD, NAYA	11 kV SUNAMU	14275202	81	74	0	7	0	7	0
701	TPCODL	CIRCLE-2, BE	NYD, NAYA	11 kV KOMAND	14275203	79	72	0	7	0	6	1
702	TPCODL	CIRCLE-2, BE	NYD, NAYA	11 kV RANICHE	14276201	63	53	0	10	0	10	0
703	TPCODL	CIRCLE-2, BE	NYD, NAYA	11 kV BADASAI	14276202	51	41	0	10	0	10	0
704	TPCODL	CIRCLE-2, BE	NYD, NAYA	11 kV SALAPAD	14276203	45	40	0	5	0	4	1
705	TPCODL	CIRCLE-2, BE	NYD, NAYA	11 kV CHHAMU	14277201	43	42	0	1	0	1	0
706	TPCODL	CIRCLE-2, BE	NYD, NAYA	11 kV ISWARAP	14277202	45	43	0	2	0	2	0
707	TPCODL	CIRCLE-2, BE	NYD, NAYA	11 kV PANIPOI	14278201	70	63	0	7	0	7	0
708	TPCODL	CIRCLE-2, BE	NYD, NAYA	11 kV MALISAH	14278202	84	78	0	6	0	6	0
709	TPCODL	CIRCLE-2, BE	NYD, NAYA	11 kV BARABAT	14278203	59	47	0	12	0	12	0
710	TPCODL	CIRCLE-2, BE	NYD, NAYA	11 kV MACHHI	14279201	47	38	0	9	0	9	0
711	TPCODL	CIRCLE-2, BE	NYD, NAYA	11 kV KALYANP	14279202	46	31	0	15	0	14	1
712	TPCODL	CIRCLE-2, BE	NYD, NAYA	11 kV PALLISAS	14279203	55	41	0	14	0	14	0
713	TPCODL	CIRCLE-2, BE	NYD, NAYA	11 kV LEKUDIP	14279204	99	67	0	32	0	32	0
714	TPCODL	CIRCLE-2, BE	NYD, NAYA	11 kV MARADA	14280201	50	39	0	11	0	11	0
715	TPCODL	CIRCLE-2, BE	NYD, NAYA	11 kV KARA BA	14280202	77	57	0	20	0	20	0
716	TPCODL	CIRCLE-2, BE	NYD, NAYA	11 kV BIJIPUR	14280203	56	46	0	10	0	9	1
717	TPCODL	CIRCLE-2, BE	NYD, NAYA	33 kV KARNAV	14280401	2	2	0	0	0	0	0
718	TPCODL	CIRCLE-2, BE	NYD, NAYA	11 kV KULURU	14281201	66	65	0	1	0	1	0
719	TPCODL	CIRCLE-2, BE	NYD, NAYA	11 kV KARNOD	14281202	183	183	0	0	0	0	0
720	TPCODL	CIRCLE-2, BE	NYD, NAYA	11 kV BANIGO	14281203	97	96	0	1	0	1	0
721	TPCODL	CIRCLE-2, BE	NYD, NAYA	11 kV KHALI SA	14282201	46	36	0	10	0	10	0
722	TPCODL	CIRCLE-2, BE	NYD, NAYA	11 kV MARDAR	14282202	45	39	0	6	0	6	0
723	TPCODL	CIRCLE-2, BE	NYD, NAYA	11 kV SINGHAR	14282203	128	122	0	6	0	6	0
724	TPCODL	CIRCLE-2, BE	NYD, NAYA	11 kV LATHIPA	14283201	38	32	0	6	0	6	0
725	TPCODL	CIRCLE-2, BE	NYD, NAYA	11 kV NOTAR	14283202	106	94	0	12	0	12	0
726	TPCODL	CIRCLE-2, BE	NYD, NAYA	11 kV RAJPATA	14283203	86	74	0	12	0	12	0
727	TPCODL	CIRCLE-2, BE	NYD, NAYA	11 kV GAMBHA	14283204	62	52	0	10	0	10	0
728	TPCODL	CIRCLE-2, BE	NYD, NAYA	11 kV SIMILISA	14284201	150	126	0	24	0	24	0
729	TPCODL	CIRCLE-2, BE	NYD, NAYA	11 kV KIRIALAN	14284203	3	1	0	2	0	2	0
730	TPCODL	CIRCLE-2, BE	NYD, NAYA	11 kV NUAPALI	14284204	25	25	0	0	0	0	0
731	TPCODL	CIRCLE-2, BE	NYD, NAYA	11 kV BAHADA	14285201	95	91	0	4	0	4	0
732	TPCODL	CIRCLE-2, BE	NYD, NAYA	11 kV BERUNH	14285202	85	83	0	2	0	2	0
733	TPCODL	CIRCLE-2, BE	NYD, NAYA	11 kV KHAIRA	14360202	1	1	0	0	0	0	0
734	TPCODL	CIRCLE-2, BE	NYD, NAYA	33 kV BINOD P	17011402	1	0	0	1	0	1	0
735	TPCODL	CIRCLE-2, BE	NYD, NAYA	33 kV KHANDA	17011403	2	0	0	2	0	2	0
736	TPCODL	CIRCLE-2, BE	NYD, NAYA	33 kV NAYAGA	17011404	1	0	0	1	0	1	0
737	TPCODL	CIRCLE-2, BE	NYD, NAYA	33 kV DASPALL	17011405	2	0	0	2	0	2	0
738	TPCODL	CIRCLE-2, BE	NYD, NAYA	33 kV ODAGAO	17011406	2	0	0	2	0	2	0
739	TPCODL	CIRCLE-2, BE	NYD, NAYA	33 kV LATHIPA	17011407	1	0	0	1	0	1	0
740	TPCODL	CIRCLE-2, BE	NYD, NAYA	33 kV GODIPAD	17011408	1	0	0	1	0	1	0
741	TPCODL	CIRCLE-2, BE	NYD, NAYA	33 kV MACHHI	17011409	1	0	0	1	0	1	0
742	TPCODL	CIRCLE-2, BE	NYD, NAYA	33 kV BANIGO	17073401	1	1	0	0	0	0	0
743	TPCODL	CIRCLE-2, BE	BAED, BAL	11 kV TANGI SS	1407601	1	1	0	0	0	0	0
744	TPCODL	CIRCLE-2, BE	BAED, BAL	11 kV INS CHIL	1437102	1	0	0	1	0	1	0
745	TPCODL	CIRCLE-2, BE	BAED, BAL	11 kV BALUGA	14075201	155	107	0	48	0	48	0
746	TPCODL	CIRCLE-2, BE	BAED, BAL	11 kV BANPUR	14075202	134	106	0	28	0	28	0
747	TPCODL	CIRCLE-2, BE	BAED, BAL	11 kV BANPUR	14075203	272	209	0	63	0	62	1
748	TPCODL	CIRCLE-2, BE	BAED, BAL	11 kV SINGHES	14075204	115	89	0	26	0	26	0
749	TPCODL	CIRCLE-2, BE	BAED, BAL	33 kV NACHUN	14075401	1	0	0	1	0	1	0
750	TPCODL	CIRCLE-2, BE	BAED, BAL	11 kV BADAPA	14076201	197	180	0	17	0	17	0
751	TPCODL	CIRCLE-2, BE	BAED, BAL	11 kV TANGI CI	14076202	127	101	0	26	0	26	0

SI No.	Zone name	Circle name	Division name	Feeder name	Feeder ID	Total no of DT on feeder	No of unmetered DTC	No of metered DTC			No of DT's with functional meters	
								AMR metered (communicable)	AMI metered (Communicable)	No AMR/AMI metered (non communicable)	Communicating (Total no out 0f 07 & 08)	Non-Communicating (Total no out 0f 07 & 08 & 09)
0	1	2	3	4	12	5=(6+7+8+9)	6	7	8	9	10	11
752	TPCODL	CIRCLE-2, BI	BAED, BAL	11 kV KALUPAI	14076203	276	231	0	45	0	45	0
753	TPCODL	CIRCLE-2, BI	BAED, BAL	11 kV GOPALPU	14077201	214	188	0	26	0	26	0
754	TPCODL	CIRCLE-2, BI	BAED, BAL	11 kV RANAPU	14077202	80	55	0	25	0	25	0
755	TPCODL	CIRCLE-2, BI	BAED, BAL	11 kV RE	14077203	227	194	0	33	0	33	0
756	TPCODL	CIRCLE-2, BI	BAED, BAL	11 kV HANSAR	14077204	50	43	0	7	0	7	0
757	TPCODL	CIRCLE-2, BI	BAED, BAL	11 kV KAITHAP	14078201	83	76	0	7	0	7	0
758	TPCODL	CIRCLE-2, BI	BAED, BAL	11 kV GAMBHA	14078202	142	124	0	18	0	17	1
759	TPCODL	CIRCLE-2, BI	BAED, BAL	11 kV NAIRI	14078203	34	21	0	13	0	13	0
760	TPCODL	CIRCLE-2, BI	BAED, BAL	33 kV FALGON	14078401	2	1	0	1	0	1	0
761	TPCODL	CIRCLE-2, BI	BAED, BAL	33 kV GANGAD	14078402	1	0	0	1	0	1	0
762	TPCODL	CIRCLE-2, BI	BAED, BAL	11 kV KAMAGU	14185201	126	119	0	7	0	7	0
763	TPCODL	CIRCLE-2, BI	BAED, BAL	11 kV CHANDA	14185202	22	13	0	9	0	9	0
764	TPCODL	CIRCLE-2, BI	BAED, BAL	11 kV RAIPADA	14185203	42	37	0	5	0	5	0
765	TPCODL	CIRCLE-2, BI	BAED, BAL	11 kV VIVA CIT	14185204	2	2	0	0	0	0	0
766	TPCODL	CIRCLE-2, BI	BAED, BAL	11 kV KUHUDI	14202201	44	33	0	11	0	11	0
767	TPCODL	CIRCLE-2, BI	BAED, BAL	11 kV CHANDE	14202202	131	119	0	12	0	12	0
768	TPCODL	CIRCLE-2, BI	BAED, BAL	11 kV TOWN	14204201	194	150	0	44	0	44	0
769	TPCODL	CIRCLE-2, BI	BAED, BAL	11 KV PRATAP	14204202	1	1	0	0	0	0	0
770	TPCODL	CIRCLE-2, BI	BAED, BAL	11 kV NILADRI	14204203	133	132	0	1	0	1	0
771	TPCODL	CIRCLE-2, BI	BAED, BAL	11 kV PANCHU	14204204	153	131	0	22	0	21	1
772	TPCODL	CIRCLE-2, BI	BAED, BAL	11 kV DARPAN	14205201	146	136	0	10	0	10	0
773	TPCODL	CIRCLE-2, BI	BAED, BAL	11 kV DARPAN	14205202	68	62	0	6	0	6	0
774	TPCODL	CIRCLE-2, BI	BAED, BAL	33 kV RANPUR	14205401	1	0	0	1	0	1	0
775	TPCODL	CIRCLE-2, BI	BAED, BAL	11 kV BHUSAN	14206201	124	105	0	19	0	19	0
776	TPCODL	CIRCLE-2, BI	BAED, BAL	11 kV HARIPUR	14206202	52	46	0	6	0	6	0
777	TPCODL	CIRCLE-2, BI	BAED, BAL	11 kV INDUSTR	14206203	2	2	0	0	0	0	0
778	TPCODL	CIRCLE-2, BI	BAED, BAL	11 kV HATABAI	14286201	106	90	0	16	0	16	0
779	TPCODL	CIRCLE-2, BI	BAED, BAL	11 kV BAULABA	14286202	74	67	0	7	0	7	0
780	TPCODL	CIRCLE-2, BI	BAED, BAL	11 kV MAHATP	14287201	99	93	0	6	0	5	1
781	TPCODL	CIRCLE-2, BI	BAED, BAL	11 kV MAYURJ	14287202	45	36	0	9	0	9	0
782	TPCODL	CIRCLE-2, BI	BAED, BAL	11 kV NATIM	14287203	20	19	0	1	0	1	0
783	TPCODL	CIRCLE-2, BI	BAED, BAL	11 kV NAVAL-1	14371201	1	1	0	0	0	0	0
784	TPCODL	CIRCLE-2, BI	BAED, BAL	11 kV Subudhig	14371202	24	23	0	1	0	1	0
785	TPCODL	CIRCLE-2, BI	BAED, BAL	11 kV ANKULA	14380201	18	17	0	1	0	1	0
786	TPCODL	CIRCLE-2, BI	BAED, BAL	11 kV DHUANL	14380202	57	47	0	10	0	10	0
787	TPCODL	CIRCLE-2, BI	BAED, BAL	33 kV RANAPU	17011401	1	0	0	1	0	1	0
788	TPCODL	CIRCLE-2, BI	BAED, BAL	33 kV BALUGA	17015401	1	0	0	1	0	1	0
789	TPCODL	CIRCLE-2, BI	BAED, BAL	33 kV ANGULIA	17015404	2	1	0	1	0	1	0
790	TPCODL	CIRCLE-2, BI	BAED, BAL	33 kV CHANDP	17016401	1	0	0	1	0	1	0
791	TPCODL	CIRCLE-2, BI	BAED, BAL	33 kV TANGICH	17016402	3	0	0	3	0	3	0
792	TPCODL	CIRCLE-2, BI	BAED, BAL	33 kV BHUSAN	17016403	3	2	0	1	0	1	0
793	TPCODL	CIRCLE-2, BI	BAED, BAL	33 kV KHANDIS	17016404	1	1	0	0	0	0	0
794	TPCODL	CIRCLE-2, BI	PED, PURI	11 kV KANAS S	1407403	1	1	0	0	0	0	0
795	TPCODL	CIRCLE-2, BI	PED, PURI	11 kV RENGALA	14050205	57	46	0	11	0	11	0
796	TPCODL	CIRCLE-2, BI	PED, PURI	11 kV Sri Mand	14064201	13	7	0	6	0	6	0
797	TPCODL	CIRCLE-2, BI	PED, PURI	11 kV Sri Gund	14064202	9	2	0	7	0	7	0
798	TPCODL	CIRCLE-2, BI	PED, PURI	11 kV Raj Bhaw	14064204	31	25	0	6	0	6	0
799	TPCODL	CIRCLE-2, BI	PED, PURI	11 kV Kacheri	14064205	28	5	0	23	0	22	1
800	TPCODL	CIRCLE-2, BI	PED, PURI	11 kV MAUSIM	14064206	12	4	0	8	0	8	0
801	TPCODL	CIRCLE-2, BI	PED, PURI	11 kV MEDICAL	14064207	3	3	0	0	0	0	0
802	TPCODL	CIRCLE-2, BI	PED, PURI	11 kV Talabania	14064208	53	24	0	29	0	29	0
803	TPCODL	CIRCLE-2, BI	PED, PURI	11 kV Raj Bhav	14064209	32	21	0	11	0	11	0
804	TPCODL	CIRCLE-2, BI	PED, PURI	33 kV ATHARN	14064401	2	2	0	0	0	0	0
805	TPCODL	CIRCLE-2, BI	PED, PURI	11 kV Swargad	14065201	23	17	0	6	0	5	1
806	TPCODL	CIRCLE-2, BI	PED, PURI	11 kV SWARGA	14065202	45	19	0	26	0	26	0
807	TPCODL	CIRCLE-2, BI	PED, PURI	11 kV DOLAMA	14065203	19	9	0	10	0	10	0
808	TPCODL	CIRCLE-2, BI	PED, PURI	11 kV Duttatot	14065204	66	34	0	32	0	32	0
809	TPCODL	CIRCLE-2, BI	PED, PURI	11 kV Kacheri-	14065205	23	6	0	17	0	17	0

SI No.	Zone name	Circle name	Division name	Feeder name	Feeder ID	Total no of DT on feeder	No of unmetered DTC	No of metered DTC			No of DT's with functional meters	
								AMR metered (communicable)	AMI metered (Communicable)	No AMR/AMI metered (non communicable)	Communicating (Total no out 0f 07 & 08)	Non-Communicating (Total no out 0f 07 & 08 & 09)
0	1	2	3	4	12	5=(6+7+8+9)	6	7	8	9	10	11
810	TPCODL	CIRCLE-2, BI	PED, PURI	11 kV Sea Beac	14065206	17	9	0	8	0	8	0
811	TPCODL	CIRCLE-2, BI	PED, PURI	33 kV BALIAPA	14065401	2	2	0	0	0	0	0
812	TPCODL	CIRCLE-2, BI	PED, PURI	11 kV Lokanath	14066201	48	21	0	27	0	26	1
813	TPCODL	CIRCLE-2, BI	PED, PURI	11 kV BALIAPA	14066202	40	26	0	14	0	14	0
814	TPCODL	CIRCLE-2, BI	PED, PURI	11 kV Baliapan	14066203	2	2	0	0	0	0	0
815	TPCODL	CIRCLE-2, BI	PED, PURI	11 kV Prachi OI	14066204	102	78	0	24	0	24	0
816	TPCODL	CIRCLE-2, BI	PED, PURI	11 kV Baliapan	14066205	29	10	0	19	0	19	0
817	TPCODL	CIRCLE-2, BI	PED, PURI	11 kV Prachi UC	14066206	31	27	0	4	0	4	0
818	TPCODL	CIRCLE-2, BI	PED, PURI	33 kV PHD	14066402	1	1	0	0	0	0	0
819	TPCODL	CIRCLE-2, BI	PED, PURI	33 kV SAMANC	14066403	1	1	0	0	0	0	0
820	TPCODL	CIRCLE-2, BI	PED, PURI	11 kV M M NA(	14067201	19	8	0	11	0	11	0
821	TPCODL	CIRCLE-2, BI	PED, PURI	11 kV KHNDIA	14067202	7	3	0	4	0	4	0
822	TPCODL	CIRCLE-2, BI	PED, PURI	11 kV HAREKRU	14067203	81	69	0	12	0	12	0
823	TPCODL	CIRCLE-2, BI	PED, PURI	11 kV VIJAY MA	14067204	6	4	0	2	0	2	0
824	TPCODL	CIRCLE-2, BI	PED, PURI	11 kV BRAHMA	14068201	69	59	0	10	0	10	0
825	TPCODL	CIRCLE-2, BI	PED, PURI	11 kV ALARNAT	14068202	44	28	0	16	0	16	0
826	TPCODL	CIRCLE-2, BI	PED, PURI	11 kV PALANKA	14068203	65	54	0	11	0	11	0
827	TPCODL	CIRCLE-2, BI	PED, PURI	11 kV BASUDEI	14068204	78	68	0	10	0	10	0
828	TPCODL	CIRCLE-2, BI	PED, PURI	11 kV REBANA	14068205	22	19	0	3	0	3	0
829	TPCODL	CIRCLE-2, BI	PED, PURI	33 kV SUNAMU	14068401	2	2	0	0	0	0	0
830	TPCODL	CIRCLE-2, BI	PED, PURI	11 kV BRAHMA	14069201	174	163	0	11	0	11	0
831	TPCODL	CIRCLE-2, BI	PED, PURI	11 kV MODIRA	14069202	45	41	0	4	0	4	0
832	TPCODL	CIRCLE-2, BI	PED, PURI	11 kV SATAPAI	14069203	73	62	0	11	0	11	0
833	TPCODL	CIRCLE-2, BI	PED, PURI	33 kV PANASPA	14069401	1	1	0	0	0	0	0
834	TPCODL	CIRCLE-2, BI	PED, PURI	11 kV PKRIT	14070201	47	18	0	29	0	29	0
835	TPCODL	CIRCLE-2, BI	PED, PURI	11 kV Baliguali	14070202	58	33	0	25	0	25	0
836	TPCODL	CIRCLE-2, BI	PED, PURI	11 kV Water W	14070203	74	42	0	32	0	32	0
837	TPCODL	CIRCLE-2, BI	PED, PURI	11 kV Toshali	14070204	67	58	0	9	0	8	1
838	TPCODL	CIRCLE-2, BI	PED, PURI	33 kV PHD	14070404	1	1	0	0	0	0	0
839	TPCODL	CIRCLE-2, BI	PED, PURI	11 kV CHANDA	14071201	57	44	0	13	0	13	0
840	TPCODL	CIRCLE-2, BI	PED, PURI	11 kV BIRANAR	14071202	292	259	0	33	0	33	0
841	TPCODL	CIRCLE-2, BI	PED, PURI	11 kV BALABHA	14071203	31	16	0	15	0	15	0
842	TPCODL	CIRCLE-2, BI	PED, PURI	33 kV SAKHIGC	14071401	1	1	0	0	0	0	0
843	TPCODL	CIRCLE-2, BI	PED, PURI	11 kV EXPRESS	14072201	94	80	0	14	0	14	0
844	TPCODL	CIRCLE-2, BI	PED, PURI	11 kV SATASAN	14072202	93	78	0	15	0	15	0
845	TPCODL	CIRCLE-2, BI	PED, PURI	11 kV SARANGA	14072203	108	87	0	21	0	21	0
846	TPCODL	CIRCLE-2, BI	PED, PURI	11 kV SAKHIGC	14072204	101	66	0	35	0	35	0
847	TPCODL	CIRCLE-2, BI	PED, PURI	33 kV KUMARE	14072401	1	0	0	1	0	1	0
848	TPCODL	CIRCLE-2, BI	PED, PURI	11 kV DELANGA	14073201	196	170	0	26	0	26	0
849	TPCODL	CIRCLE-2, BI	PED, PURI	11 kV GHORAD	14073202	162	128	0	34	0	34	0
850	TPCODL	CIRCLE-2, BI	PED, PURI	11 kV MAA GEI	14073203	49	42	0	7	0	7	0
851	TPCODL	CIRCLE-2, BI	PED, PURI	11 kV KANASA	14074201	100	82	0	18	0	18	0
852	TPCODL	CIRCLE-2, BI	PED, PURI	11 kV KARAMA	14074202	157	139	0	18	0	18	0
853	TPCODL	CIRCLE-2, BI	PED, PURI	11 kV JAGANNA	14074203	208	187	0	21	0	21	0
854	TPCODL	CIRCLE-2, BI	PED, PURI	11 kV MADHUE	14207201	16	5	0	11	0	11	0
855	TPCODL	CIRCLE-2, BI	PED, PURI	11 kV MAKUBA	14207202	4	0	0	4	0	4	0
856	TPCODL	CIRCLE-2, BI	PED, PURI	11 kV Narendra	14207203	16	11	0	5	0	5	0
857	TPCODL	CIRCLE-2, BI	PED, PURI	11 KV MLCP	14207204	13	6	0	7	0	7	0
858	TPCODL	CIRCLE-2, BI	PED, PURI	11 kV BALANGA	14208201	134	108	0	26	0	26	0
859	TPCODL	CIRCLE-2, BI	PED, PURI	11 kV KUMARE	14208202	4	3	0	1	0	1	0
860	TPCODL	CIRCLE-2, BI	PED, PURI	11 kV SATASAN	14208203	71	63	0	8	0	7	1
861	TPCODL	CIRCLE-2, BI	PED, PURI	11 kV KHAJURI	14225201	109	99	0	10	0	10	0
862	TPCODL	CIRCLE-2, BI	PED, PURI	11 kV TALAMA	14225202	123	115	0	8	0	8	0
863	TPCODL	CIRCLE-2, BI	PED, PURI	33 kV KALYANI	14225401	1	0	0	1	0	1	0
864	TPCODL	CIRCLE-2, BI	PED, PURI	11 kV CHALISBA	14288201	46	38	0	8	0	6	2
865	TPCODL	CIRCLE-2, BI	PED, PURI	11 kV BALIPUT	14288202	76	70	0	6	0	6	0
866	TPCODL	CIRCLE-2, BI	PED, PURI	11 kV KETAKIPA	14289201	100	85	0	15	0	15	0
867	TPCODL	CIRCLE-2, BI	PED, PURI	11 kV GUALIGC	14289202	82	74	0	8	0	8	0

SI No.	Zone name	Circle name	Division name	Feeder name	Feeder ID	Total no of DT on feeder	No of unmetered DTC	No of metered DTC			No of DT's with functional meters	
								AMR metered (communicable)	AMI metered (Communicable)	No AMR/AMI metered (non communicable)	Communicating (Total no out 0f 07 & 08)	Non-Communicating (Total no out 0f 07 & 08 & 09)
0	1	2	3	4	12	5=(6+7+8+9)	6	7	8	9	10	11
868	TPCODL	CIRCLE-2, BI	PED, PURI	11 kV PANASPA	14290201	54	48	0	6	0	6	0
869	TPCODL	CIRCLE-2, BI	PED, PURI	11 kV SATAPAI	14290202	102	90	0	12	0	12	0
870	TPCODL	CIRCLE-2, BI	PED, PURI	11 kV Koilada	14291201	54	41	0	13	0	13	0
871	TPCODL	CIRCLE-2, BI	PED, PURI	11 kV Damodai	14291202	20	15	0	5	0	5	0
872	TPCODL	CIRCLE-2, BI	PED, PURI	11 kV Managal	14291203	16	4	0	12	0	12	0
873	TPCODL	CIRCLE-2, BI	PED, PURI	33 kV WTP	14291401	1	1	0	0	0	0	0
874	TPCODL	CIRCLE-2, BI	PED, PURI	11 kV O/G INDI	14293201	72	62	0	10	0	10	0
875	TPCODL	CIRCLE-2, BI	PED, PURI	11 kV O/G DEY	14293202	52	50	0	2	0	2	0
876	TPCODL	CIRCLE-2, BI	PED, PURI	11 kV O/G ALA	14293203	65	59	0	6	0	6	0
877	TPCODL	CIRCLE-2, BI	PED, PURI	11 kV O/G SUK	14293204	60	51	0	9	0	9	0
878	TPCODL	CIRCLE-2, BI	PED, PURI	11 kV CHANDO	14294201	25	24	0	1	0	1	0
879	TPCODL	CIRCLE-2, BI	PED, PURI	11 kV KALYANI	14294202	48	34	0	14	0	14	0
880	TPCODL	CIRCLE-2, BI	PED, PURI	33 kV KANAS	14294401	1	1	0	0	0	0	0
881	TPCODL	CIRCLE-2, BI	PED, PURI	11 kV GADISAG	14295203	104	89	0	15	0	15	0
882	TPCODL	CIRCLE-2, BI	PED, PURI	11 kV BASUDEI	14364201	52	39	0	13	0	13	0
883	TPCODL	CIRCLE-2, BI	PED, PURI	11 kV HANTUK	14364202	19	16	0	3	0	3	0
884	TPCODL	CIRCLE-2, BI	PED, PURI	11 kV KAPILESV	14364203	83	75	0	8	0	8	0
885	TPCODL	CIRCLE-2, BI	PED, PURI	11 KV BEROBO	14379204	2	2	0	0	0	0	0
886	TPCODL	CIRCLE-2, BI	PED, PURI	33 kV DELANG	17007405	2	1	0	1	0	1	0
887	TPCODL	CIRCLE-2, BI	PED, PURI	33 kV SAKHIGO	17012401	2	1	0	1	0	1	0
888	TPCODL	CIRCLE-2, BI	PED, PURI	33 kV SRIRAMI	17012403	1	1	0	0	0	0	0
889	TPCODL	CIRCLE-2, BI	PED, PURI	33 kV PURI II	17012406	1	1	0	0	0	0	0
890	TPCODL	CIRCLE-2, BI	PED, PURI	33 kV ALARNAT	17013401	1	1	0	0	0	0	0
891	TPCODL	CIRCLE-2, BI	PED, PURI	33 kV CHARINA	17013404	1	1	0	0	0	0	0
892	TPCODL	CIRCLE-2, BI	PED, PURI	33 kV SAMAGA	17014401	2	2	0	0	0	0	0
893	TPCODL	CIRCLE-2, BI	PED, PURI	33 kV SAMAGA	17014403	3	3	0	0	0	0	0
894	TPCODL	CIRCLE-2, BI	PED, PURI	33 kV MEDICAI	17014404	3	3	0	0	0	0	0
895	TPCODL	CIRCLE-2, BI	PED, PURI	33 kV SATASAI	17065402	1	1	0	0	0	0	0
896	TPCODL	CIRCLE-2, BI	PED, PURI	PURI	17012STN0	1	0	0	1	0	1	0
897	TPCODL	CIRCLE-2, BI	PED, PURI	33 kV SAMUKA	17013STN0	1	0	0	1	0	1	0
898	TPCODL	CIRCLE-2, BI	PED, PURI	33 kV SAMUKA	17013STN0	1	0	0	1	0	1	0
899	TPCODL	CIRCLE-2, BI	PED, PURI	33 kV SAMAGA	17014STN0	1	0	0	1	0	1	0
900	TPCODL	CIRCLE-2, BI	PED, PURI	33 kV SAMAGA	17014STN0	1	0	0	1	0	1	0
901	TPCODL	CUTTACK CI	CDD-1, CU	11 kV SATICHO	14080201	18	12	0	6	0	6	0
902	TPCODL	CUTTACK CI	CDD-1, CU	11 kV SECTOR (	14080202	55	27	0	28	0	28	0
903	TPCODL	CUTTACK CI	CDD-1, CU	11 kV SECTOR !	14080203	36	18	0	18	0	18	0
904	TPCODL	CUTTACK CI	CDD-1, CU	11 kV SECTOR 8	14080204	20	8	0	12	0	12	0
905	TPCODL	CUTTACK CI	CDD-1, CU	11 kV HIGH CO	14081201	13	12	0	1	0	1	0
906	TPCODL	CUTTACK CI	CDD-1, CU	11 kV TOWNHA	14081202	37	17	0	20	0	20	0
907	TPCODL	CUTTACK CI	CDD-1, CU	11 kV Chandini	14081203	44	19	0	25	0	25	0
908	TPCODL	CUTTACK CI	CDD-1, CU	11 kV AAYAKAI	14081204	28	27	0	1	0	1	0
909	TPCODL	CUTTACK CI	CDD-1, CU	11 kV PURI GH	14081205	18	8	0	10	0	10	0
910	TPCODL	CUTTACK CI	CDD-1, CU	11 kV SISHUBH	14081206	2	2	0	0	0	0	0
911	TPCODL	CUTTACK CI	CDD-1, CU	11 kV RAILWAY	14082202	38	24	0	14	0	14	0
912	TPCODL	CUTTACK CI	CDD-1, CU	11 kV RAVENSH	14082203	27	18	0	9	0	9	0
913	TPCODL	CUTTACK CI	CDD-1, CU	11 kV JOBRA B	14082204	32	16	0	16	0	16	0
914	TPCODL	CUTTACK CI	CDD-1, CU	11 kV MATAM	14082205	34	24	0	10	0	9	1
915	TPCODL	CUTTACK CI	CDD-1, CU	11 kV COLLEGE	14082206	40	29	0	11	0	11	0
916	TPCODL	CUTTACK CI	CDD-1, CU	11 kV TELEPHO	14083201	37	15	0	22	0	22	0
917	TPCODL	CUTTACK CI	CDD-1, CU	11 kV RANIHAT	14083202	19	9	0	10	0	10	0
918	TPCODL	CUTTACK CI	CDD-1, CU	11 kV MANGAL	14083203	22	11	0	11	0	11	0
919	TPCODL	CUTTACK CI	CDD-1, CU	11 kV MEDICAI	14083204	28	28	0	0	0	0	0
920	TPCODL	CUTTACK CI	CDD-1, CU	11 kV MEDICAI	14083205	15	15	0	0	0	0	0
921	TPCODL	CUTTACK CI	CDD-1, CU	11 kV LINAC	14083206	5	5	0	0	0	0	0
922	TPCODL	CUTTACK CI	CDD-1, CU	33 kV RANIHAT	14083401	1	1	0	0	0	0	0
923	TPCODL	CUTTACK CI	CDD-1, CU	11 kV CHOUDH	14084201	49	29	0	20	0	20	0
924	TPCODL	CUTTACK CI	CDD-1, CU	11 kV CHOUDH	14084202	27	17	0	10	0	10	0
925	TPCODL	CUTTACK CI	CDD-1, CU	11 kV CANTON	14084203	40	15	0	25	0	25	0

SI No.	Zone name	Circle name	Division name	Feeder name	Feeder ID	Total no of DT on feeder	No of unmetered DTC	No of metered DTC			No of DT's with functional meters	
								AMR metered (communicable)	AMI metered (Communicable)	No AMR/AMI metered (non communicable)	Communicating (Total no out 0f 07 & 08)	Non-Communicating (Total no out 0f 07 & 08 & 09)
0	1	2	3	4	12	5=(6+7+8+9)	6	7	8	9	10	11
926	TPCODL	CUTTACK CI	CDD-1, CU	11 kV GORAKA	14084204	36	19	0	17	0	17	0
927	TPCODL	CUTTACK CI	CDD-1, CU	11 kV JNI Stadi	14084205	3	2	0	1	0	1	0
928	TPCODL	CUTTACK CI	CDD-1, CU	11 kV CANTON	14084206	11	5	0	6	0	6	0
929	TPCODL	CUTTACK CI	CDD-1, CU	11 kV HIGH CO	14084208	19	10	0	9	0	9	0
930	TPCODL	CUTTACK CI	CDD-1, CU	11 kV DD OH	14084209	26	16	0	10	0	10	0
931	TPCODL	CUTTACK CI	CDD-1, CU	11 kV SRI VIHA	14084210	2	0	0	2	0	2	0
932	TPCODL	CUTTACK CI	CDD-1, CU	11 kV LOWER C	14084211	2	0	0	2	0	2	0
933	TPCODL	CUTTACK CI	CDD-1, CU	11 kV UPPER G	14084212	6	2	0	4	0	4	0
934	TPCODL	CUTTACK CI	CDD-1, CU	11 kV CHANDI	14084213	15	13	0	2	0	2	0
935	TPCODL	CUTTACK CI	CDD-1, CU	11 kV KANIKA I	14084214	38	17	0	21	0	21	0
936	TPCODL	CUTTACK CI	CDD-1, CU	11 kV SUTAHAT	14084215	32	16	0	16	0	16	0
937	TPCODL	CUTTACK CI	CDD-1, CU	33 kV IOCL	14084401	1	1	0	0	0	0	0
938	TPCODL	CUTTACK CI	CDD-1, CU	11 kV BIDANAS	14085202	80	68	0	12	0	11	1
939	TPCODL	CUTTACK CI	CDD-1, CU	11 kV TULASIPI	14085204	68	49	0	19	0	19	0
940	TPCODL	CUTTACK CI	CDD-1, CU	11 kV BIDANAS	14085205	20	10	0	10	0	10	0
941	TPCODL	CUTTACK CI	CDD-1, CU	11 kV Hatipokh	14086201	47	23	0	24	0	24	0
942	TPCODL	CUTTACK CI	CDD-1, CU	11 kV CITY	14086203	32	14	0	18	0	18	0
943	TPCODL	CUTTACK CI	CDD-1, CU	11 kV MAHANA	14089202	5	3	0	2	0	2	0
944	TPCODL	CUTTACK CI	CDD-1, CU	11 kV CIRCUIT	14209201	13	9	0	4	0	4	0
945	TPCODL	CUTTACK CI	CDD-1, CU	11 kV CB9	14209202	54	29	0	25	0	25	0
946	TPCODL	CUTTACK CI	CDD-1, CU	11 kV MUSEUN	14209203	10	6	0	4	0	4	0
947	TPCODL	CUTTACK CI	CDD-1, CU	11 kV BUXI BAZ	14209204	37	17	0	20	0	20	0
948	TPCODL	CUTTACK CI	CDD-1, CU	11 kV GANESH	14210201	24	8	0	16	0	16	0
949	TPCODL	CUTTACK CI	CDD-1, CU	11 kV KAZIBAZ	14210202	28	9	0	19	0	19	0
950	TPCODL	CUTTACK CI	CDD-1, CU	11 kV JUDGE C	14210203	19	10	0	9	0	9	0
951	TPCODL	CUTTACK CI	CDD-1, CU	11 kV TREASUF	14210204	3	1	0	2	0	2	0
952	TPCODL	CUTTACK CI	CDD-1, CU	11 kV TULASIPI	14238201	107	65	0	42	0	41	1
953	TPCODL	CUTTACK CI	CDD-1, CU	11 kV EYE HOS	14238202	30	13	0	17	0	17	0
954	TPCODL	CUTTACK CI	CDD-1, CU	11 kV JUDICIAL	14238203	1	1	0	0	0	0	0
955	TPCODL	CUTTACK CI	CDD-1, CU	11 kV CDA-10	14239201	28	13	0	15	0	15	0
956	TPCODL	CUTTACK CI	CDD-1, CU	11 kV CDA-11	14239202	22	11	0	11	0	11	0
957	TPCODL	CUTTACK CI	CDD-1, CU	11 kV NARAJ	14239203	15	10	0	5	0	5	0
958	TPCODL	CUTTACK CI	CDD-1, CU	11 kV LAW UNI	14240201	5	5	0	0	0	0	0
959	TPCODL	CUTTACK CI	CDD-1, CU	11 kV SECTOR-	14240203	41	16	0	25	0	25	0
960	TPCODL	CUTTACK CI	CDD-1, CU	11 kV OGFED-1	14378201	16	14	0	2	0	2	0
961	TPCODL	CUTTACK CI	CDD-1, CU	11 kV OGFED-2	14378202	14	7	0	7	0	7	0
962	TPCODL	CUTTACK CI	CDD-1, CU	11 kV OGFED-3	14378203	13	10	0	3	0	3	0
963	TPCODL	CUTTACK CI	CDD-1, CU	11 kV OGFED-4	14378204	13	7	0	6	0	6	0
964	TPCODL	CUTTACK CI	CDD-1, CU	33 kV TULASIPI	17019401	1	1	0	0	0	0	0
965	TPCODL	CUTTACK CI	CDD-1, CU	33 kV TULASIPI	17019402	2	1	0	1	0	1	0
966	TPCODL	CUTTACK CI	CDD-1, CU	33 kV SECTOR (	17019403	3	2	0	1	0	1	0
967	TPCODL	CUTTACK CI	CDD-1, CU	33 kV SISHUBH	17019405	3	1	0	2	0	2	0
968	TPCODL	CUTTACK CI	CDD-1, CU	33 kV IOCLI	17019406	1	0	0	1	0	1	0
969	TPCODL	CUTTACK CI	CDD-1, CU	33 kV SECTOR-	17019409	1	1	0	0	0	0	0
970	TPCODL	CUTTACK CI	CDD-1, CU	33 kV WATCO	17052402	4	4	0	0	0	0	0
971	TPCODL	CUTTACK CI	CDD-1, CU	33 kV TULASIPI	17052404	1	0	0	1	0	1	0
972	TPCODL	CUTTACK CI	CDD-2, CU	11 kV KANDAR	1409301	1	1	0	0	0	0	0
973	TPCODL	CUTTACK CI	CDD-2, CU	11 kV RANIHAT	14083202	7	5	0	2	0	2	0
974	TPCODL	CUTTACK CI	CDD-2, CU	11 kV Badamba	14087202	49	25	0	24	0	24	0
975	TPCODL	CUTTACK CI	CDD-2, CU	11 kV BADAMB	14087204	54	27	0	27	0	27	0
976	TPCODL	CUTTACK CI	CDD-2, CU	11 kV Badamba	14087205	26	14	0	12	0	12	0
977	TPCODL	CUTTACK CI	CDD-2, CU	11 kV IDCO	14088201	18	11	0	7	0	7	0
978	TPCODL	CUTTACK CI	CDD-2, CU	11 kV BARRAG	14088202	36	21	0	15	0	15	0
979	TPCODL	CUTTACK CI	CDD-2, CU	11 kV NADIKUL	14088203	18	16	0	2	0	2	0
980	TPCODL	CUTTACK CI	CDD-2, CU	11 kV OLD IND	14088204	108	64	0	44	0	43	1
981	TPCODL	CUTTACK CI	CDD-2, CU	11 kV KALYANI	14089201	23	7	0	16	0	16	0
982	TPCODL	CUTTACK CI	CDD-2, CU	11 kV MAHANA	14089202	16	10	0	6	0	6	0
983	TPCODL	CUTTACK CI	CDD-2, CU	11 kV RING-1	14089203	51	20	0	31	0	31	0

SI No.	Zone name	Circle name	Division name	Feeder name	Feeder ID	Total no of DT on feeder	No of unmetered DTC	No of metered DTC			No of DT's with functional meters	
								AMR metered (communicable)	AMI metered (Communicable)	No AMR/AMI metered (non communicable)	Communicating (Total no out 0f 07 & 08)	Non-Communicating (Total no out 0f 07 & 08 & 09)
0	1	2	3	4	12	5=(6+7+8+9)	6	7	8	9	10	11
984	TPCODL	CUTTACK CI	CDD-2, CU	11 kV CHAULIA	14089206	36	20	0	16	0	16	0
985	TPCODL	CUTTACK CI	CDD-2, CU	11 kV INDUSTR	14090201	40	25	0	15	0	15	0
986	TPCODL	CUTTACK CI	CDD-2, CU	11 kV INDUSTR	14090202	39	17	0	22	0	22	0
987	TPCODL	CUTTACK CI	CDD-2, CU	11 kV OGP	14090203	2	0	0	2	0	2	0
988	TPCODL	CUTTACK CI	CDD-2, CU	11 kV GOSALA	14090205	36	14	0	22	0	22	0
989	TPCODL	CUTTACK CI	CDD-2, CU	11 kV OGP BAD	14090206	13	11	0	2	0	2	0
990	TPCODL	CUTTACK CI	CDD-2, CU	11 kV OGP-KAL	14090207	7	2	0	5	0	5	0
991	TPCODL	CUTTACK CI	CDD-2, CU	11 kV MAHANA	14091202	60	24	0	36	0	35	1
992	TPCODL	CUTTACK CI	CDD-2, CU	11 kV CRRI	14091203	9	4	0	5	0	5	0
993	TPCODL	CUTTACK CI	CDD-2, CU	11 kV NAYABAZ	14091204	37	19	0	18	0	17	1
994	TPCODL	CUTTACK CI	CDD-2, CU	11 kV CHANDU	14092201	74	48	0	26	0	25	1
995	TPCODL	CUTTACK CI	CDD-2, CU	11 kV BENTKAR	14092202	87	45	0	42	0	42	0
996	TPCODL	CUTTACK CI	CDD-2, CU	11 kV JHINKIRI	14092203	31	16	0	15	0	15	0
997	TPCODL	CUTTACK CI	CDD-2, CU	11 kV KALAPAD	14092204	44	22	0	22	0	22	0
998	TPCODL	CUTTACK CI	CDD-2, CU	11 kV ALL INDI	14093201	89	63	0	26	0	25	1
999	TPCODL	CUTTACK CI	CDD-2, CU	11 kV KANDAR	14093202	101	66	0	35	0	35	0
1000	TPCODL	CUTTACK CI	CDD-2, CU	11 kV PARAMA	14093203	100	69	0	31	0	31	0
1001	TPCODL	CUTTACK CI	CDD-2, CU	11 kV AYATPUR	14093204	78	48	0	30	0	29	1
1002	TPCODL	CUTTACK CI	CDD-2, CU	33 kV SOMPUR	14093401	1	1	0	0	0	0	0
1003	TPCODL	CUTTACK CI	CDD-2, CU	11 kV KISHANN	14094201	22	15	0	7	0	7	0
1004	TPCODL	CUTTACK CI	CDD-2, CU	11 kV MALIPUR	14094202	21	10	0	11	0	11	0
1005	TPCODL	CUTTACK CI	CDD-2, CU	11 kV SOMAPU	14094203	3	2	0	1	0	1	0
1006	TPCODL	CUTTACK CI	CDD-2, CU	11 kV RAMCHA	14094204	21	15	0	6	0	6	0
1007	TPCODL	CUTTACK CI	CDD-2, CU	11 kV BISWALA	14094205	22	12	0	10	0	10	0
1008	TPCODL	CUTTACK CI	CDD-2, CU	11 kV RANI PAI	14171203	2	2	0	0	0	0	0
1009	TPCODL	CUTTACK CI	CDD-2, CU	11 kV POPARAI	14211201	30	16	0	14	0	14	0
1010	TPCODL	CUTTACK CI	CDD-2, CU	11 kV MATAGA	14211202	14	7	0	7	0	7	0
1011	TPCODL	CUTTACK CI	CDD-2, CU	11 kV JAICA	14211203	21	14	0	7	0	7	0
1012	TPCODL	CUTTACK CI	CDD-2, CU	11 kV PHD	14211204	4	1	0	3	0	3	0
1013	TPCODL	CUTTACK CI	CDD-2, CU	11 kV MAHANA	14241201	71	60	0	11	0	11	0
1014	TPCODL	CUTTACK CI	CDD-2, CU	11 kV NEW IND	14241202	58	48	0	10	0	10	0
1015	TPCODL	CUTTACK CI	CDD-2, CU	11 kV KHAIRA	14241203	76	58	0	18	0	18	0
1016	TPCODL	CUTTACK CI	CDD-2, CU	11 kV MAHANA	14242201	67	34	0	33	0	32	1
1017	TPCODL	CUTTACK CI	CDD-2, CU	11 kV MAHANA	14242202	26	12	0	14	0	14	0
1018	TPCODL	CUTTACK CI	CDD-2, CU	11 kV SIKHARP	14242203	30	12	0	18	0	18	0
1019	TPCODL	CUTTACK CI	CDD-2, CU	11 kV GANDAR	14242204	15	9	0	6	0	6	0
1020	TPCODL	CUTTACK CI	CDD-2, CU	11 kV Mahatab	14296201	39	15	0	24	0	24	0
1021	TPCODL	CUTTACK CI	CDD-2, CU	11 kV HARIPUR	14296202	15	8	0	7	0	7	0
1022	TPCODL	CUTTACK CI	CDD-2, CU	11 kV SOMAPU	14297201	9	6	0	3	0	3	0
1023	TPCODL	CUTTACK CI	CDD-2, CU	11 kV TELDIA	14297202	10	6	0	4	0	4	0
1024	TPCODL	CUTTACK CI	CDD-2, CU	11 kV RAMKUN	14297203	40	23	0	17	0	17	0
1025	TPCODL	CUTTACK CI	CDD-2, CU	33 kV KISHAN I	14297401	1	1	0	0	0	0	0
1026	TPCODL	CUTTACK CI	CDD-2, CU	11 kV DIVINE N	14368201	17	6	0	11	0	11	0
1027	TPCODL	CUTTACK CI	CDD-2, CU	11 kV OSAP	14368202	66	45	0	21	0	21	0
1028	TPCODL	CUTTACK CI	CDD-2, CU	33 kV BAHUGR	17018404	5	5	0	0	0	0	0
1029	TPCODL	CUTTACK CI	CDD-2, CU	33 kV JAGATPU	17018405	2	1	0	1	0	1	0
1030	TPCODL	CUTTACK CI	CDD-2, CU	33 kV TULASIP	17019401	2	2	0	0	0	0	0
1031	TPCODL	CUTTACK CI	CDD-2, CU	33 kV TULASIP	17019402	1	1	0	0	0	0	0
1032	TPCODL	CUTTACK CI	CDD-2, CU	33 kV BADAMB	17019404	1	1	0	0	0	0	0
1033	TPCODL	CUTTACK CI	CDD-2, CU	33 kV BENTKAR	17020402	1	1	0	0	0	0	0
1034	TPCODL	CUTTACK CI	CDD-2, CU	33 kV JSPUR RU	17020403	1	1	0	0	0	0	0
1035	TPCODL	CUTTACK CI	CDD-2, CU	33 kV CRRI2	17020405	2	2	0	0	0	0	0
1036	TPCODL	CUTTACK CI	CDD-2, CU	33 kV CHAULIA	17020407	1	1	0	0	0	0	0
1037	TPCODL	CUTTACK CI	CDD-2, CU	33 kV BADAMB	17020410	1	1	0	0	0	0	0
1038	TPCODL	CUTTACK CI	CED, CUTT	11 kV BALIKUD	1410201	1	0	0	1	0	1	0
1039	TPCODL	CUTTACK CI	CED, CUTT	11 kV CHHATIA	1410802	1	0	0	1	0	1	0
1040	TPCODL	CUTTACK CI	CED, CUTT	11 kV BALIRAP	1410901	1	1	0	0	0	0	0
1041	TPCODL	CUTTACK CI	CED, CUTT	11 kV GOVINDI	14023209	26	22	0	4	0	4	0

SI No.	Zone name	Circle name	Division name	Feeder name	Feeder ID	Total no of DT on feeder	No of unmetered DTC	No of metered DTC			No of DT's with functional meters	
								AMR metered (communicable)	AMI metered (Communicable)	No AMR/AMI metered (non communicable)	Communicating (Total no out 0f 07 & 08)	Non-Communicating (Total no out 0f 07 & 08 & 09)
0	1	2	3	4	12	5=(6+7+8+9)	6	7	8	9	10	11
1042	TPCODL	CUTTACK CI	CED, CUTT	11 kV BASUDEV	14096202	3	2	0	1	0	1	0
1043	TPCODL	CUTTACK CI	CED, CUTT	11 kV CHAINPA	14097203	7	6	0	1	0	1	0
1044	TPCODL	CUTTACK CI	CED, CUTT	33 kV BALICHA	14097404	1	0	0	1	0	1	0
1045	TPCODL	CUTTACK CI	CED, CUTT	11 kV GOBINDI	14101201	88	72	0	16	0	16	0
1046	TPCODL	CUTTACK CI	CED, CUTT	11 kV SUNDER	14101202	135	106	0	29	0	29	0
1047	TPCODL	CUTTACK CI	CED, CUTT	11 kV NIRTAR	14101203	8	8	0	0	0	0	0
1048	TPCODL	CUTTACK CI	CED, CUTT	11 kV KANTAPA	14101204	119	98	0	21	0	21	0
1049	TPCODL	CUTTACK CI	CED, CUTT	11 kV 42 MOUZ	14102201	129	75	0	54	0	53	1
1050	TPCODL	CUTTACK CI	CED, CUTT	11 kV BARANG	14102202	26	15	0	11	0	11	0
1051	TPCODL	CUTTACK CI	CED, CUTT	11 kV UTTAMP	14102203	74	47	0	27	0	27	0
1052	TPCODL	CUTTACK CI	CED, CUTT	11 kV BANIPAD	14103201	22	13	0	9	0	9	0
1053	TPCODL	CUTTACK CI	CED, CUTT	11 kV INDUSTR	14103202	74	62	0	12	0	11	1
1054	TPCODL	CUTTACK CI	CED, CUTT	11 kV KUSPAN	14103203	83	71	0	12	0	12	0
1055	TPCODL	CUTTACK CI	CED, CUTT	33 kV NARANG	14103401	3	3	0	0	0	0	0
1056	TPCODL	CUTTACK CI	CED, CUTT	33 kV SANKARI	14103402	1	0	0	1	0	1	0
1057	TPCODL	CUTTACK CI	CED, CUTT	33 kV SATYAM	14103403	2	2	0	0	0	0	0
1058	TPCODL	CUTTACK CI	CED, CUTT	11 kV ADASPUI	14104201	136	105	0	31	0	30	1
1059	TPCODL	CUTTACK CI	CED, CUTT	11 kV SITHALO	14104202	11	10	0	1	0	1	0
1060	TPCODL	CUTTACK CI	CED, CUTT	11 kV UTTARAI	14104203	57	46	0	11	0	11	0
1061	TPCODL	CUTTACK CI	CED, CUTT	33 kV KASARAI	14104401	1	0	0	1	0	1	0
1062	TPCODL	CUTTACK CI	CED, CUTT	33 kV NIALI-I	14104402	2	1	0	1	0	1	0
1063	TPCODL	CUTTACK CI	CED, CUTT	11 kV BADCHA	14105201	74	64	0	10	0	10	0
1064	TPCODL	CUTTACK CI	CED, CUTT	11 kV OLD BAD	14105202	74	61	0	13	0	13	0
1065	TPCODL	CUTTACK CI	CED, CUTT	11 kV SAKUNTA	14105203	71	56	0	15	0	15	0
1066	TPCODL	CUTTACK CI	CED, CUTT	11 kV CHANDIK	14105204	113	90	0	23	0	23	0
1067	TPCODL	CUTTACK CI	CED, CUTT	11 kV DEULAPU	14105205	21	13	0	8	0	8	0
1068	TPCODL	CUTTACK CI	CED, CUTT	33 kV JUTEMIL	14105403	5	4	0	1	0	1	0
1069	TPCODL	CUTTACK CI	CED, CUTT	33 kV CHHATIA	14105404	11	11	0	0	0	0	0
1070	TPCODL	CUTTACK CI	CED, CUTT	33 kV MEGHA	14105405	2	2	0	0	0	0	0
1071	TPCODL	CUTTACK CI	CED, CUTT	11 kV KALIAGH	14106201	135	96	0	39	0	39	0
1072	TPCODL	CUTTACK CI	CED, CUTT	11 kV NIALI TO	14106202	63	32	0	31	0	31	0
1073	TPCODL	CUTTACK CI	CED, CUTT	11 kV KAPASI	14106203	49	34	0	15	0	15	0
1074	TPCODL	CUTTACK CI	CED, CUTT	11 kV TOLA	14106204	119	92	0	27	0	27	0
1075	TPCODL	CUTTACK CI	CED, CUTT	33 kV KULAKAI	14106401	1	1	0	0	0	0	0
1076	TPCODL	CUTTACK CI	CED, CUTT	11 kV HARIPUR	14107201	284	262	0	22	0	22	0
1077	TPCODL	CUTTACK CI	CED, CUTT	11 kV BHATTIM	14107202	100	80	0	20	0	20	0
1078	TPCODL	CUTTACK CI	CED, CUTT	11 kV MANGUI	14107203	183	157	0	26	0	26	0
1079	TPCODL	CUTTACK CI	CED, CUTT	11 kV GOBINDI	14107204	69	62	0	7	0	7	0
1080	TPCODL	CUTTACK CI	CED, CUTT	11 kV TANGI LO	14107205	35	26	0	9	0	9	0
1081	TPCODL	CUTTACK CI	CED, CUTT	33 kV CHHATIA	14107401	19	17	0	2	0	2	0
1082	TPCODL	CUTTACK CI	CED, CUTT	11 kV CHHATIA	14108201	90	67	0	23	0	23	0
1083	TPCODL	CUTTACK CI	CED, CUTT	11 kV BAIREE	14108202	73	66	0	7	0	7	0
1084	TPCODL	CUTTACK CI	CED, CUTT	11 kV CHAMPA	14108203	112	96	0	16	0	16	0
1085	TPCODL	CUTTACK CI	CED, CUTT	11 kV KADHEI	14108204	63	48	0	15	0	15	0
1086	TPCODL	CUTTACK CI	CED, CUTT	11 kV BANDALO	14108205	33	26	0	7	0	7	0
1087	TPCODL	CUTTACK CI	CED, CUTT	11 kV CHHATIA	14108206	2	1	0	1	0	1	0
1088	TPCODL	CUTTACK CI	CED, CUTT	11 kV BALICHA	14109201	51	30	0	21	0	21	0
1089	TPCODL	CUTTACK CI	CED, CUTT	11 kV CHARINA	14109202	187	155	0	32	0	32	0
1090	TPCODL	CUTTACK CI	CED, CUTT	11 kV RUKUTIP	14109203	67	57	0	10	0	10	0
1091	TPCODL	CUTTACK CI	CED, CUTT	11 kV MANITRI	14109204	71	60	0	11	0	11	0
1092	TPCODL	CUTTACK CI	CED, CUTT	11 kV BANDAR	14109205	155	134	0	21	0	20	1
1093	TPCODL	CUTTACK CI	CED, CUTT	11 kV CITY BAR	14184201	67	45	0	22	0	22	0
1094	TPCODL	CUTTACK CI	CED, CUTT	11 kV CHOUDV	14184202	26	9	0	17	0	17	0
1095	TPCODL	CUTTACK CI	CED, CUTT	11 kV ARC	14184203	20	11	0	9	0	9	0
1096	TPCODL	CUTTACK CI	CED, CUTT	11 kV OTM	14184204	70	48	0	22	0	21	1
1097	TPCODL	CUTTACK CI	CED, CUTT	11 kV LOCAL	14184205	36	18	0	18	0	18	0
1098	TPCODL	CUTTACK CI	CED, CUTT	11 kV NUNTIKI	14184206	58	51	0	7	0	7	0
1099	TPCODL	CUTTACK CI	CED, CUTT	11 kV CHARBA	14184207	93	52	0	41	0	41	0

Sl No.	Zone name	Circle name	Division name	Feeder name	Feeder ID	Total no of DT on feeder	No of unmetered DTC	No of metered DTC			No of DT's with functional meters	
								AMR metered (communicable)	AMI metered (Communicable)	No AMR/AMI metered (non communicable)	Communicating (Total no out 0f 07 & 08)	Non-Communicating (Total no out 0f 07 & 08 & 09)
0	1	2	3	4	12	5=(6+7+8+9)	6	7	8	9	10	11
1100	TPCODL	CUTTACK CI	CED, CUTT	11 kV PANCHU	14199202	3	2	0	1	0	1	0
1101	TPCODL	CUTTACK CI	CED, CUTT	11 kV ERANCH	14220201	104	88	0	16	0	16	0
1102	TPCODL	CUTTACK CI	CED, CUTT	11 kV KASARDA	14220202	62	55	0	7	0	7	0
1103	TPCODL	CUTTACK CI	CED, CUTT	11 kV KULASHF	14220203	26	21	0	5	0	5	0
1104	TPCODL	CUTTACK CI	CED, CUTT	11 kV SITHALO	14220204	104	87	0	17	0	17	0
1105	TPCODL	CUTTACK CI	CED, CUTT	11 kV GANGES	14224201	90	64	0	26	0	26	0
1106	TPCODL	CUTTACK CI	CED, CUTT	11 kV SANKARI	14233201	53	40	0	13	0	13	0
1107	TPCODL	CUTTACK CI	CED, CUTT	11 kV BERHAM	14233202	45	36	0	9	0	9	0
1108	TPCODL	CUTTACK CI	CED, CUTT	11 kV MANGAF	14233203	61	57	0	4	0	4	0
1109	TPCODL	CUTTACK CI	CED, CUTT	11 kV PHULNA	14298201	71	57	0	14	0	13	1
1110	TPCODL	CUTTACK CI	CED, CUTT	11 kV PRATAP	14298202	132	93	0	39	0	39	0
1111	TPCODL	CUTTACK CI	CED, CUTT	11 kV NAHALPI	14299201	59	48	0	11	0	11	0
1112	TPCODL	CUTTACK CI	CED, CUTT	11 kV GOBINDI	14299202	64	51	0	13	0	13	0
1113	TPCODL	CUTTACK CI	CED, CUTT	11 kV KHALARI	14299203	49	38	0	11	0	11	0
1114	TPCODL	CUTTACK CI	CED, CUTT	11 kV SALAPAI	14301201	183	174	0	9	0	9	0
1115	TPCODL	CUTTACK CI	CED, CUTT	11 kV LOCAL	14301202	19	17	0	2	0	2	0
1116	TPCODL	CUTTACK CI	CED, CUTT	11 kV BARI THE	14301203	99	95	0	4	0	4	0
1117	TPCODL	CUTTACK CI	CED, CUTT	11 kV SIHA	14301204	47	45	0	2	0	2	0
1118	TPCODL	CUTTACK CI	CED, CUTT	11 kV ARAKATA	14302201	71	59	0	12	0	12	0
1119	TPCODL	CUTTACK CI	CED, CUTT	11 kV PODANA	14302202	118	99	0	19	0	19	0
1120	TPCODL	CUTTACK CI	CED, CUTT	11 kV PANIMA	14302203	101	81	0	20	0	20	0
1121	TPCODL	CUTTACK CI	CED, CUTT	11 kV KULAHAI	14303201	17	16	0	1	0	1	0
1122	TPCODL	CUTTACK CI	CED, CUTT	11 kV BHAKUD	14303202	79	71	0	8	0	8	0
1123	TPCODL	CUTTACK CI	CED, CUTT	11 kV KADAMF	14303203	137	117	0	20	0	20	0
1124	TPCODL	CUTTACK CI	CED, CUTT	11 kV KUNDAL	14303204	10	8	0	2	0	2	0
1125	TPCODL	CUTTACK CI	CED, CUTT	11 kV LAXMINA	14310201	2	2	0	0	0	0	0
1126	TPCODL	CUTTACK CI	CED, CUTT	33 kV BADACH	17017401	1	0	0	1	0	1	0
1127	TPCODL	CUTTACK CI	CED, CUTT	33 kV KUNDAL	17017402	2	2	0	0	0	0	0
1128	TPCODL	CUTTACK CI	CED, CUTT	33 kV BAJRANG	17018401	1	1	0	0	0	0	0
1129	TPCODL	CUTTACK CI	CED, CUTT	33 kV TANGI	17018402	8	6	0	2	0	2	0
1130	TPCODL	CUTTACK CI	CED, CUTT	33 kV ATHAGA	17018403	1	0	0	1	0	1	0
1131	TPCODL	CUTTACK CI	CED, CUTT	33 kV IDCO/CIT	17018406	9	6	0	3	0	3	0
1132	TPCODL	CUTTACK CI	CED, CUTT	33 kV BALIKUD	17020401	2	2	0	0	0	0	0
1133	TPCODL	CUTTACK CI	CED, CUTT	33 kV DAMODA	17022401	2	2	0	0	0	0	0
1134	TPCODL	CUTTACK CI	CED, CUTT	33 kV NIALI	17022402	3	2	0	1	0	1	0
1135	TPCODL	CUTTACK CI	CED, CUTT	33 kV RSB	17038401	5	5	0	0	0	0	0
1136	TPCODL	CUTTACK CI	CED, CUTT	33 kV KAIMATI	17038403	8	8	0	0	0	0	0
1137	TPCODL	CUTTACK CI	CED, CUTT	33 kV BISWANA	17038404	1	1	0	0	0	0	0
1138	TPCODL	CUTTACK CI	CED, CUTT	PALEI	17072STN0	1	0	0	1	0	1	0
1139	TPCODL	CUTTACK CI	AED, ATHA	11 kV BADAMB	1411001	1	1	0	0	0	0	0
1140	TPCODL	CUTTACK CI	AED, ATHA	11 kV ATHAGA	1411601	1	0	0	1	0	1	0
1141	TPCODL	CUTTACK CI	AED, ATHA	33 kV NARANG	14103401	12	12	0	0	0	0	0
1142	TPCODL	CUTTACK CI	AED, ATHA	11 kV GOPAMA	14110201	51	37	0	14	0	14	0
1143	TPCODL	CUTTACK CI	AED, ATHA	11 kV BADAMB	14110202	80	65	0	15	0	14	1
1144	TPCODL	CUTTACK CI	AED, ATHA	11 kV RATAPAT	14110203	113	102	0	11	0	11	0
1145	TPCODL	CUTTACK CI	AED, ATHA	11 kV RAGADIF	14110204	44	35	0	9	0	9	0
1146	TPCODL	CUTTACK CI	AED, ATHA	11 kV GOPINAT	14110205	91	77	0	14	0	14	0
1147	TPCODL	CUTTACK CI	AED, ATHA	33 kV GOPAPU	14110401	3	3	0	0	0	0	0
1148	TPCODL	CUTTACK CI	AED, ATHA	11 kV KANPUR	14111202	79	61	0	18	0	18	0
1149	TPCODL	CUTTACK CI	AED, ATHA	11 kV BALIJHAF	14111203	74	58	0	16	0	15	1
1150	TPCODL	CUTTACK CI	AED, ATHA	11 kV GODIBAN	14111204	85	76	0	9	0	9	0
1151	TPCODL	CUTTACK CI	AED, ATHA	11 kV BASALIH	14111205	60	43	0	17	0	17	0
1152	TPCODL	CUTTACK CI	AED, ATHA	11 kV KARILO &	14111206	152	130	0	22	0	22	0
1153	TPCODL	CUTTACK CI	AED, ATHA	11 kV NUKHAP	14112201	105	86	0	19	0	19	0
1154	TPCODL	CUTTACK CI	AED, ATHA	11 kV KAKUDIA	14112202	86	78	0	8	0	8	0
1155	TPCODL	CUTTACK CI	AED, ATHA	11 kV NARSING	14112203	81	57	0	24	0	24	0
1156	TPCODL	CUTTACK CI	AED, ATHA	11 kV KAMALA	14112204	163	148	0	15	0	15	0
1157	TPCODL	CUTTACK CI	AED, ATHA	11 kV JAIPUR	14112205	57	54	0	3	0	3	0

Sl No.	Zone name	Circle name	Division name	Feeder name	Feeder ID	Total no of DT on feeder	No of unmetered DTC	No of metered DTC			No of DT's with functional meters	
								AMR metered (communicable)	AMI metered (Communicable)	No AMR/AMI metered (non communicable)	Communicating (Total no out 0f 07 & 08)	Non-Communicating (Total no out 0f 07 & 08 & 09)
0	1	2	3	4	12	5=(6+7+8+9)	6	7	8	9	10	11
1158	TPCODL	CUTTACK CI	AED, ATHA	11 kV NARANG	14113201	93	78	0	15	0	15	0
1159	TPCODL	CUTTACK CI	AED, ATHA	11 kV NARANG	14113202	40	32	0	8	0	8	0
1160	TPCODL	CUTTACK CI	AED, ATHA	33 kV SARPESV	14113401	1	1	0	0	0	0	0
1161	TPCODL	CUTTACK CI	AED, ATHA	11 kV NUAPAT	14114201	124	95	0	29	0	29	0
1162	TPCODL	CUTTACK CI	AED, ATHA	11 kV MANIAB	14114202	121	100	0	21	0	21	0
1163	TPCODL	CUTTACK CI	AED, ATHA	11 kV BINDHAI	14115201	79	64	0	15	0	15	0
1164	TPCODL	CUTTACK CI	AED, ATHA	11 kV PANCHA	14115202	72	67	0	5	0	5	0
1165	TPCODL	CUTTACK CI	AED, ATHA	11 kV TIGIRIA	14115203	22	21	0	1	0	1	0
1166	TPCODL	CUTTACK CI	AED, ATHA	11 kV PURUNA	14115204	56	43	0	13	0	13	0
1167	TPCODL	CUTTACK CI	AED, ATHA	11 kV ATHAGA	14116201	202	152	0	50	0	50	0
1168	TPCODL	CUTTACK CI	AED, ATHA	11 kV KARIKOL	14116202	175	143	0	32	0	32	0
1169	TPCODL	CUTTACK CI	AED, ATHA	11 kV ATHAGA	14116204	20	12	0	8	0	8	0
1170	TPCODL	CUTTACK CI	AED, ATHA	11 kV DORODA	14116205	40	34	0	6	0	6	0
1171	TPCODL	CUTTACK CI	AED, ATHA	11 kV DHAIPUF	14116206	72	61	0	11	0	11	0
1172	TPCODL	CUTTACK CI	AED, ATHA	11 kV GURUDIJ	14117201	61	57	0	4	0	4	0
1173	TPCODL	CUTTACK CI	AED, ATHA	11 kV KULEILO	14117202	78	70	0	8	0	8	0
1174	TPCODL	CUTTACK CI	AED, ATHA	11 kV MAHALA	14117203	133	127	0	6	0	6	0
1175	TPCODL	CUTTACK CI	AED, ATHA	11 kV HINDOL	14123201	38	37	0	1	0	1	0
1176	TPCODL	CUTTACK CI	AED, ATHA	11 kV GURUDIJ	14213201	76	64	0	12	0	12	0
1177	TPCODL	CUTTACK CI	AED, ATHA	11 kV KUMARP	14213202	130	119	0	11	0	11	0
1178	TPCODL	CUTTACK CI	AED, ATHA	11 kV KHUNTA	14214201	42	31	0	11	0	11	0
1179	TPCODL	CUTTACK CI	AED, ATHA	11 kV GODIJHA	14214202	170	143	0	27	0	27	0
1180	TPCODL	CUTTACK CI	AED, ATHA	11 kV KHUNTA	14214203	35	30	0	5	0	5	0
1181	TPCODL	CUTTACK CI	AED, ATHA	11 kV KAMALA	14304201	69	64	0	5	0	5	0
1182	TPCODL	CUTTACK CI	AED, ATHA	11 kV SISUPAT	14304202	52	51	0	1	0	1	0
1183	TPCODL	CUTTACK CI	AED, ATHA	11 kV ODASING	14304204	32	32	0	0	0	0	0
1184	TPCODL	CUTTACK CI	AED, ATHA	11 kV RATTAPA	14305201	104	91	0	13	0	13	0
1185	TPCODL	CUTTACK CI	AED, ATHA	11 kV GOPAPU	14305202	36	29	0	7	0	7	0
1186	TPCODL	CUTTACK CI	AED, ATHA	11 kV BHATTAF	14305203	83	72	0	11	0	11	0
1187	TPCODL	CUTTACK CI	AED, ATHA	11 kV KANTAPA	14306201	77	60	0	17	0	16	1
1188	TPCODL	CUTTACK CI	AED, ATHA	11 kV SUBARNA	14306202	60	53	0	7	0	7	0
1189	TPCODL	CUTTACK CI	AED, ATHA	11 kV SARANDA	14306203	2	2	0	0	0	0	0
1190	TPCODL	CUTTACK CI	AED, ATHA	11 kV GHODAB	14306204	32	22	0	10	0	10	0
1191	TPCODL	CUTTACK CI	AED, ATHA	11 kV GADADH	14307201	30	27	0	3	0	3	0
1192	TPCODL	CUTTACK CI	AED, ATHA	11 kV MANAPU	14307202	43	38	0	5	0	5	0
1193	TPCODL	CUTTACK CI	AED, ATHA	11 kV BANDALO	14307203	60	47	0	13	0	12	1
1194	TPCODL	CUTTACK CI	AED, ATHA	11 kV BANGAR	14308201	56	53	0	3	0	3	0
1195	TPCODL	CUTTACK CI	AED, ATHA	11 kV BADABA	14308203	51	45	0	6	0	6	0
1196	TPCODL	CUTTACK CI	AED, ATHA	11 kV KHUNTA	14308204	31	29	0	2	0	2	0
1197	TPCODL	CUTTACK CI	AED, ATHA	33 kV BADAMB	14308401	1	0	0	1	0	1	0
1198	TPCODL	CUTTACK CI	AED, ATHA	11 kV SARPESV	14365201	92	74	0	18	0	18	0
1199	TPCODL	CUTTACK CI	AED, ATHA	33 kV BADAMB	17023401	1	1	0	0	0	0	0
1200	TPCODL	CUTTACK CI	AED, ATHA	33 kV ATHAGA	17023402	2	2	0	0	0	0	0
1201	TPCODL	CUTTACK CI	AED, ATHA	33 kV NUAPAT	17023403	1	0	0	1	0	1	0
1202	TPCODL	CUTTACK CI	AED, ATHA	33 kV TIGIRIA	17023404	2	1	0	1	0	1	0
1203	TPCODL	CUTTACK CI	AED, ATHA	33 kV KHUNTU	17044401	1	1	0	0	0	0	0
1204	TPCODL	CUTTACK CI	AED, ATHA	33 kV J K LAXM	17044402	1	1	0	0	0	0	0
1205	TPCODL	CUTTACK CI	AED, ATHA	33 kV ATHAGA	17044403	2	2	0	0	0	0	0
1206	TPCODL	CUTTACK CI	AED, ATHA	33 kV NARSING	17045401	1	0	0	1	0	1	0
1207	TPCODL	CUTTACK CI	AED, ATHA	33 kV MEGA LI	17045402	8	8	0	0	0	0	0
1208	TPCODL	CUTTACK CI	AED, ATHA	33 kV MEGA LI	17045403	4	4	0	0	0	0	0
1209	TPCODL	CUTTACK CI	AED, ATHA	33 kV MARDAN	17045404	2	2	0	0	0	0	0
1210	TPCODL	CUTTACK CI	AED, ATHA	33 kV KANPUR	17045405	4	4	0	0	0	0	0
1211	TPCODL	CUTTACK CI	SED, SALIP	11 kV SALIPUR	1409502	1	0	0	1	0	1	0
1212	TPCODL	CUTTACK CI	SED, SALIP	11 kV NAIGUAI	14095201	69	49	0	20	0	20	0
1213	TPCODL	CUTTACK CI	SED, SALIP	11 kV RAISUNG	14095202	61	41	0	20	0	20	0
1214	TPCODL	CUTTACK CI	SED, SALIP	11 kV MEDICAI	14095203	40	31	0	9	0	9	0
1215	TPCODL	CUTTACK CI	SED, SALIP	11 kV CHHANIF	14095204	72	54	0	18	0	18	0

SI No.	Zone name	Circle name	Division name	Feeder name	Feeder ID	Total no of DT on feeder	No of unmetered DTC	No of metered DTC			No of DT's with functional meters	
								AMR metered (communicable)	AMI metered (Communicable)	No AMR/AMI metered (non communicable)	Communicating (Total no out 0f 07 & 08)	Non-Communicating (Total no out 0f 07 & 08 & 09)
0	1	2	3	4	12	5=(6+7+8+9)	6	7	8	9	10	11
1216	TPCODL	CUTTACK CI	SED, SALIP	11 kV JAIPUR/K	14096201	82	68	0	14	0	14	0
1217	TPCODL	CUTTACK CI	SED, SALIP	11 kV BASUDEV	14096202	74	68	0	6	0	6	0
1218	TPCODL	CUTTACK CI	SED, SALIP	11 kV MULABA	14096203	65	58	0	7	0	7	0
1219	TPCODL	CUTTACK CI	SED, SALIP	11 kV RWSS M	14096204	2	2	0	0	0	0	0
1220	TPCODL	CUTTACK CI	SED, SALIP	11 kV MAHANC	14097201	124	94	0	30	0	30	0
1221	TPCODL	CUTTACK CI	SED, SALIP	11 kV KUANPA	14097202	99	86	0	13	0	13	0
1222	TPCODL	CUTTACK CI	SED, SALIP	11 kV CHAINPA	14097203	68	49	0	19	0	19	0
1223	TPCODL	CUTTACK CI	SED, SALIP	33 kV ERKANA	14097402	1	1	0	0	0	0	0
1224	TPCODL	CUTTACK CI	SED, SALIP	33 kV KOTAPAI	14097403	1	1	0	0	0	0	0
1225	TPCODL	CUTTACK CI	SED, SALIP	11 kV NANDOL	14098201	67	59	0	8	0	7	1
1226	TPCODL	CUTTACK CI	SED, SALIP	11 kV BAHUGR	14098202	146	114	0	32	0	31	1
1227	TPCODL	CUTTACK CI	SED, SALIP	11 kV PATAPUI	14098204	68	57	0	11	0	11	0
1228	TPCODL	CUTTACK CI	SED, SALIP	11 kV UMARA	14099201	93	72	0	21	0	21	0
1229	TPCODL	CUTTACK CI	SED, SALIP	11 kV BUHALA	14099202	24	12	0	12	0	12	0
1230	TPCODL	CUTTACK CI	SED, SALIP	11 kV RAMAKR	14099203	93	68	0	25	0	25	0
1231	TPCODL	CUTTACK CI	SED, SALIP	33 kV ORIKANT	14099402	1	1	0	0	0	0	0
1232	TPCODL	CUTTACK CI	SED, SALIP	11 kV NISCHINT	14100201	26	18	0	8	0	8	0
1233	TPCODL	CUTTACK CI	SED, SALIP	11 kV KHANDA	14100202	37	28	0	9	0	9	0
1234	TPCODL	CUTTACK CI	SED, SALIP	11 kV OLD BAD	14105202	6	6	0	0	0	0	0
1235	TPCODL	CUTTACK CI	SED, SALIP	11 kV SAKUNTA	14105203	9	8	0	1	0	1	0
1236	TPCODL	CUTTACK CI	SED, SALIP	11 kV CHAMPA	14108203	20	18	0	2	0	2	0
1237	TPCODL	CUTTACK CI	SED, SALIP	11 kV BANDAR	14109205	2	2	0	0	0	0	0
1238	TPCODL	CUTTACK CI	SED, SALIP	11 kV NAREND	14163202	116	85	0	31	0	31	0
1239	TPCODL	CUTTACK CI	SED, SALIP	11 kV NAGANP	14163203	14	14	0	0	0	0	0
1240	TPCODL	CUTTACK CI	SED, SALIP	11 kV BANAKH	14163204	17	17	0	0	0	0	0
1241	TPCODL	CUTTACK CI	SED, SALIP	11 kV CHANDO	14164203	5	2	0	3	0	3	0
1242	TPCODL	CUTTACK CI	SED, SALIP	11 kV ASURESV	14164204	10	9	0	1	0	1	0
1243	TPCODL	CUTTACK CI	SED, SALIP	33 kV ASURESV	14164402	1	1	0	0	0	0	0
1244	TPCODL	CUTTACK CI	SED, SALIP	11 kV CHHATA	14199201	11	9	0	2	0	2	0
1245	TPCODL	CUTTACK CI	SED, SALIP	11 kV PANCHU	14199202	2	0	0	2	0	2	0
1246	TPCODL	CUTTACK CI	SED, SALIP	11 kV GOPINAT	14212201	115	98	0	17	0	17	0
1247	TPCODL	CUTTACK CI	SED, SALIP	11 kV BILAHAT	14212202	129	102	0	27	0	27	0
1248	TPCODL	CUTTACK CI	SED, SALIP	11 kV SOGAL	14212203	74	60	0	14	0	14	0
1249	TPCODL	CUTTACK CI	SED, SALIP	11 kV NEMALO	14212204	76	63	0	13	0	13	0
1250	TPCODL	CUTTACK CI	SED, SALIP	11 kV KHAIRA	14241203	13	10	0	3	0	2	1
1251	TPCODL	CUTTACK CI	SED, SALIP	11 kV BHAKUD	14303202	1	1	0	0	0	0	0
1252	TPCODL	CUTTACK CI	SED, SALIP	11 kV RAISUNG	14309201	10	7	0	3	0	3	0
1253	TPCODL	CUTTACK CI	SED, SALIP	11 kV DHARMA	14309202	85	74	0	11	0	11	0
1254	TPCODL	CUTTACK CI	SED, SALIP	11 kV MANOHA	14309203	78	64	0	14	0	14	0
1255	TPCODL	CUTTACK CI	SED, SALIP	11 kV LAXMINA	14310201	98	82	0	16	0	16	0
1256	TPCODL	CUTTACK CI	SED, SALIP	11 kV KURUJAN	14310202	101	83	0	18	0	18	0
1257	TPCODL	CUTTACK CI	SED, SALIP	11 kV GOUDAG	14310203	72	59	0	13	0	13	0
1258	TPCODL	CUTTACK CI	SED, SALIP	11 kV SUKARPA	14311201	87	70	0	17	0	17	0
1259	TPCODL	CUTTACK CI	SED, SALIP	11 kV ASURESV	14311202	64	48	0	16	0	16	0
1260	TPCODL	CUTTACK CI	SED, SALIP	11 kV LUNA	14311203	88	64	0	24	0	24	0
1261	TPCODL	CUTTACK CI	SED, SALIP	11 kV JAPAKUI	14312201	73	63	0	10	0	10	0
1262	TPCODL	CUTTACK CI	SED, SALIP	11 kV BHIMDA	14312202	84	71	0	13	0	13	0
1263	TPCODL	CUTTACK CI	SED, SALIP	11 kV RAMESW	14312203	89	73	0	16	0	16	0
1264	TPCODL	CUTTACK CI	SED, SALIP	11 kV MALAMC	14312204	85	77	0	8	0	8	0
1265	TPCODL	CUTTACK CI	SED, SALIP	11 kV Feeder-1	14350202	3	3	0	0	0	0	0
1266	TPCODL	CUTTACK CI	SED, SALIP	11 kV BAHUGR	14366201	64	45	0	19	0	19	0
1267	TPCODL	CUTTACK CI	SED, SALIP	11 kV BAHUGR	14366202	33	28	0	5	0	5	0
1268	TPCODL	CUTTACK CI	SED, SALIP	33 kV SALIPUR	17021401	8	4	0	4	0	4	0
1269	TPCODL	CUTTACK CI	SED, SALIP	33 kV MAHANC	17021402	2	2	0	0	0	0	0
1270	TPCODL	CUTTACK CI	SED, SALIP	33 kV JAPAKUI	17021403	1	1	0	0	0	0	0
1271	TPCODL	CUTTACK CI	SED, SALIP	33 kV BAHUGR	17070403	2	2	0	0	0	0	0
1272	TPCODL	DHENKANA	DED, DHEN	11 kV DHENKA	1411804	1	1	0	0	0	0	0
1273	TPCODL	DHENKANA	DED, DHEN	11 kV GONDIA	1412002	1	1	0	0	0	0	0

Sl No.	Zone name	Circle name	Division name	Feeder name	Feeder ID	Total no of DT on feeder	No of unmetered DTC	No of metered DTC			No of DT's with functional meters	
								AMR metered (communicable)	AMI metered (Communicable)	No AMR/AMI metered (non communicable)	Communicating (Total no out 0f 07 & 08)	Non-Communicating (Total no out 0f 07 & 08 & 09)
0	1	2	3	4	12	5=(6+7+8+9)	6	7	8	9	10	11
1274	TPCODL	DHENKANA	DED, DHEN	11 kV KHAJURI	1412201	1	1	0	0	0	0	0
1275	TPCODL	DHENKANA	DED, DHEN	11 kV BADASU	1412501	1	1	0	0	0	0	0
1276	TPCODL	DHENKANA	DED, DHEN	11 kV DAYANA	1412701	1	1	0	0	0	0	0
1277	TPCODL	DHENKANA	DED, DHEN	11 kV GUNDICH	1413102	1	1	0	0	0	0	0
1278	TPCODL	DHENKANA	DED, DHEN	11 kV KANKAD	1419101	1	1	0	0	0	0	0
1279	TPCODL	DHENKANA	DED, DHEN	11 kV DKL TOW	14118201	102	55	0	47	0	46	1
1280	TPCODL	DHENKANA	DED, DHEN	11 kV DKL TOW	14118202	51	37	0	14	0	14	0
1281	TPCODL	DHENKANA	DED, DHEN	11 kV GOVINDI	14118203	203	165	0	38	0	38	0
1282	TPCODL	DHENKANA	DED, DHEN	11 kV JORANDA	14118204	189	162	0	27	0	27	0
1283	TPCODL	DHENKANA	DED, DHEN	11 kV SAPTASA	14118205	138	117	0	21	0	21	0
1284	TPCODL	DHENKANA	DED, DHEN	11 kV BHAPUR	14119201	156	130	0	26	0	26	0
1285	TPCODL	DHENKANA	DED, DHEN	11 kV GHATIPII	14119202	45	39	0	6	0	6	0
1286	TPCODL	DHENKANA	DED, DHEN	11 kV Lamboda	14119203	29	29	0	0	0	0	0
1287	TPCODL	DHENKANA	DED, DHEN	33 kV GHATIPII	14119401	1	1	0	0	0	0	0
1288	TPCODL	DHENKANA	DED, DHEN	11 kV MANDAR	14120201	86	78	0	8	0	8	0
1289	TPCODL	DHENKANA	DED, DHEN	11 kV KAPILASI	14120202	128	112	0	16	0	16	0
1290	TPCODL	DHENKANA	DED, DHEN	11 kV GONDIA	14120203	55	42	0	13	0	13	0
1291	TPCODL	DHENKANA	DED, DHEN	11 kV ANKURD	14120204	47	38	0	9	0	8	1
1292	TPCODL	DHENKANA	DED, DHEN	11 kV PASUPAT	14120205	61	57	0	4	0	4	0
1293	TPCODL	DHENKANA	DED, DHEN	33 kV PINGUA	14120401	1	1	0	0	0	0	0
1294	TPCODL	DHENKANA	DED, DHEN	33 kV MANDAR	14120403	1	1	0	0	0	0	0
1295	TPCODL	DHENKANA	DED, DHEN	11 kV TOWN (H	14121201	43	33	0	10	0	10	0
1296	TPCODL	DHENKANA	DED, DHEN	11 kV NIMIDHA	14121202	122	100	0	22	0	22	0
1297	TPCODL	DHENKANA	DED, DHEN	11 kV BADALO	14121203	154	145	0	9	0	9	0
1298	TPCODL	DHENKANA	DED, DHEN	11 kV 4 POLE	14121204	162	142	0	20	0	20	0
1299	TPCODL	DHENKANA	DED, DHEN	11 kV RASOLA	14122201	42	33	0	9	0	9	0
1300	TPCODL	DHENKANA	DED, DHEN	11 kV Bedapad	14122202	217	199	0	18	0	17	1
1301	TPCODL	DHENKANA	DED, DHEN	11 kV KALINGA	14122203	85	71	0	14	0	14	0
1302	TPCODL	DHENKANA	DED, DHEN	11 kV Bedapad	14122204	13	11	0	2	0	2	0
1303	TPCODL	DHENKANA	DED, DHEN	11 kV HINDOL	14123201	262	237	0	25	0	24	1
1304	TPCODL	DHENKANA	DED, DHEN	11 kV Dudurko	14123202	53	52	0	1	0	1	0
1305	TPCODL	DHENKANA	DED, DHEN	11 kV TOWN-1	14124201	45	18	0	27	0	27	0
1306	TPCODL	DHENKANA	DED, DHEN	11 kV BAUNSA	14124202	72	42	0	30	0	30	0
1307	TPCODL	DHENKANA	DED, DHEN	11 kV GUNDICH	14124203	31	31	0	0	0	0	0
1308	TPCODL	DHENKANA	DED, DHEN	11 kV MAHULP	14124204	94	79	0	15	0	14	1
1309	TPCODL	DHENKANA	DED, DHEN	11 kV KADUA	14124205	102	91	0	11	0	11	0
1310	TPCODL	DHENKANA	DED, DHEN	11 kV GUNEIBI	14125201	35	33	0	2	0	2	0
1311	TPCODL	DHENKANA	DED, DHEN	11 kV BIRASAL	14125202	44	41	0	3	0	3	0
1312	TPCODL	DHENKANA	DED, DHEN	11 kV BELEISAH	14126202	33	26	0	7	0	7	0
1313	TPCODL	DHENKANA	DED, DHEN	11 kV BALISAH	14126203	55	52	0	3	0	3	0
1314	TPCODL	DHENKANA	DED, DHEN	11 kV MARTHA	14126204	67	58	0	9	0	9	0
1315	TPCODL	DHENKANA	DED, DHEN	11 kV SURAPRA	14127201	53	47	0	6	0	6	0
1316	TPCODL	DHENKANA	DED, DHEN	11 kV KANHEIP	14127202	114	102	0	12	0	12	0
1317	TPCODL	DHENKANA	DED, DHEN	11 kV GODA	14128201	21	19	0	2	0	2	0
1318	TPCODL	DHENKANA	DED, DHEN	11 kV Baruan	14128202	60	48	0	12	0	12	0
1319	TPCODL	DHENKANA	DED, DHEN	11 kV Dhalpada	14128203	94	83	0	11	0	11	0
1320	TPCODL	DHENKANA	DED, DHEN	11 kV Bhuban T	14129202	55	26	0	29	0	29	0
1321	TPCODL	DHENKANA	DED, DHEN	11 kV BHUSAL	14129203	70	64	0	6	0	6	0
1322	TPCODL	DHENKANA	DED, DHEN	11 kV Anantpu	14129204	61	54	0	7	0	7	0
1323	TPCODL	DHENKANA	DED, DHEN	11 kV PADAN	14129205	8	8	0	0	0	0	0
1324	TPCODL	DHENKANA	DED, DHEN	11 kV BHUBAN	14129206	39	33	0	6	0	6	0
1325	TPCODL	DHENKANA	DED, DHEN	33 kV MAHULP	14129401	1	1	0	0	0	0	0
1326	TPCODL	DHENKANA	DED, DHEN	11 kV BAZAR (T	14130201	50	46	0	4	0	4	0
1327	TPCODL	DHENKANA	DED, DHEN	11 kV CHINGUI	14130202	114	112	0	2	0	2	0
1328	TPCODL	DHENKANA	DED, DHEN	11 kV KALIAPA	14130203	58	58	0	0	0	0	0
1329	TPCODL	DHENKANA	DED, DHEN	11 kV SIMINAI	14131201	181	129	0	52	0	51	1
1330	TPCODL	DHENKANA	DED, DHEN	11 kV Industria	14131202	8	6	0	2	0	2	0
1331	TPCODL	DHENKANA	DED, DHEN	11 kV CALTAX	14131203	69	44	0	25	0	25	0

SI No.	Zone name	Circle name	Division name	Feeder name	Feeder ID	Total no of DT on feeder	No of unmetered DTC	No of metered DTC			No of DT's with functional meters	
								AMR metered (communicable)	AMI metered (Communicable)	No AMR/AMI metered (non communicable)	Communicating (Total no out 0f 07 & 08)	Non-Communicating (Total no out 0f 07 & 08 & 09)
0	1	2	3	4	12	5=(6+7+8+9)	6	7	8	9	10	11
1332	TPCODL	DHENKANA	DED, DHEN	11 kV PHD (G.P	14131204	135	102	0	33	0	32	1
1333	TPCODL	DHENKANA	DED, DHEN	11 kV Bhapur (	14131205	206	173	0	33	0	33	0
1334	TPCODL	DHENKANA	DED, DHEN	33 kV MUKTAP	14131401	1	1	0	0	0	0	0
1335	TPCODL	DHENKANA	DED, DHEN	11 kV NATIMA	14188201	81	55	0	26	0	26	0
1336	TPCODL	DHENKANA	DED, DHEN	11 kV KARAMU	14188203	168	143	0	25	0	25	0
1337	TPCODL	DHENKANA	DED, DHEN	11 kV DEULASA	14189201	74	48	0	26	0	25	1
1338	TPCODL	DHENKANA	DED, DHEN	11 kV SASAN	14189202	54	32	0	22	0	22	0
1339	TPCODL	DHENKANA	DED, DHEN	11 kV KORIA(SP	14189204	38	24	0	14	0	14	0
1340	TPCODL	DHENKANA	DED, DHEN	11 kV Nihalpras	14190201	196	181	0	15	0	15	0
1341	TPCODL	DHENKANA	DED, DHEN	11 kV Kasipur	14190202	134	109	0	25	0	23	2
1342	TPCODL	DHENKANA	DED, DHEN	11 kV ARUNI	14190204	1	1	0	0	0	0	0
1343	TPCODL	DHENKANA	DED, DHEN	11 kV DANDAD	14191201	75	69	0	6	0	6	0
1344	TPCODL	DHENKANA	DED, DHEN	11 kV Rupabed	14191202	145	143	0	2	0	2	0
1345	TPCODL	DHENKANA	DED, DHEN	11 kV URBENG	14191203	143	139	0	4	0	4	0
1346	TPCODL	DHENKANA	DED, DHEN	11 kV SALAPAD	14301201	18	13	0	5	0	5	0
1347	TPCODL	DHENKANA	DED, DHEN	11 kV SOGAR	14313201	77	71	0	6	0	6	0
1348	TPCODL	DHENKANA	DED, DHEN	11 kV ANLABER	14313202	126	116	0	10	0	10	0
1349	TPCODL	DHENKANA	DED, DHEN	11 kV KOTAGA	14313203	120	104	0	16	0	16	0
1350	TPCODL	DHENKANA	DED, DHEN	11 kV BARUAN	14313204	55	50	0	5	0	5	0
1351	TPCODL	DHENKANA	DED, DHEN	11 kV CHAULIA	14314201	30	25	0	5	0	5	0
1352	TPCODL	DHENKANA	DED, DHEN	11 kV KAIMATI	14314202	2	2	0	0	0	0	0
1353	TPCODL	DHENKANA	DED, DHEN	11 kV BANASIN	14314204	138	111	0	27	0	27	0
1354	TPCODL	DHENKANA	DED, DHEN	11 kV KUNDA	14315201	27	24	0	3	0	3	0
1355	TPCODL	DHENKANA	DED, DHEN	11 kV EKATALI	14315202	46	38	0	8	0	7	1
1356	TPCODL	DHENKANA	DED, DHEN	11 kV MURDAN	14315203	54	39	0	15	0	14	1
1357	TPCODL	DHENKANA	DED, DHEN	11 kV Chaulia/I	14316201	74	43	0	31	0	30	1
1358	TPCODL	DHENKANA	DED, DHEN	11 kV Tarva	14316202	58	51	0	7	0	6	1
1359	TPCODL	DHENKANA	DED, DHEN	11 kV Similia	14316203	104	80	0	24	0	23	1
1360	TPCODL	DHENKANA	DED, DHEN	11 kV BAISINGA	14318201	75	67	0	8	0	8	0
1361	TPCODL	DHENKANA	DED, DHEN	11 kV JIRIDAM/	14318202	39	25	0	14	0	13	1
1362	TPCODL	DHENKANA	DED, DHEN	11 kV KANPUR/	14318203	18	17	0	1	0	1	0
1363	TPCODL	DHENKANA	DED, DHEN	11 kV JIRAL	14319201	105	82	0	23	0	23	0
1364	TPCODL	DHENKANA	DED, DHEN	11 kV GUNEIEI	14319202	104	87	0	17	0	16	1
1365	TPCODL	DHENKANA	DED, DHEN	11 kV BEDAPAL	14319203	1	1	0	0	0	0	0
1366	TPCODL	DHENKANA	DED, DHEN	11 kV PINGUA	14320201	22	17	0	5	0	5	0
1367	TPCODL	DHENKANA	DED, DHEN	11 kV SADANG	14320202	33	26	0	7	0	7	0
1368	TPCODL	DHENKANA	DED, DHEN	11 kV MANDAR	14320203	35	32	0	3	0	3	0
1369	TPCODL	DHENKANA	DED, DHEN	33 kV NIHALPR	14320401	1	1	0	0	0	0	0
1370	TPCODL	DHENKANA	DED, DHEN	11 kV NUABAG	14321201	44	42	0	2	0	2	0
1371	TPCODL	DHENKANA	DED, DHEN	11 kV Rasol (Nu	14321202	87	82	0	5	0	5	0
1372	TPCODL	DHENKANA	DED, DHEN	11 kV NAUKIAR	14321203	149	143	0	6	0	6	0
1373	TPCODL	DHENKANA	DED, DHEN	11 kV KALANGA	14322201	68	66	0	2	0	2	0
1374	TPCODL	DHENKANA	DED, DHEN	11 kV GHATIPIP	14322202	63	60	0	3	0	3	0
1375	TPCODL	DHENKANA	DED, DHEN	11 kV GOBINDA	14322203	110	100	0	10	0	10	0
1376	TPCODL	DHENKANA	DED, DHEN	11 kV KURUMI	14323201	82	75	0	7	0	7	0
1377	TPCODL	DHENKANA	DED, DHEN	11 kV PATALA	14323203	109	97	0	12	0	12	0
1378	TPCODL	DHENKANA	DED, DHEN	11 kV BIRASAL	14324201	25	24	0	1	0	1	0
1379	TPCODL	DHENKANA	DED, DHEN	11 kV SENDHAS	14324202	55	53	0	2	0	2	0
1380	TPCODL	DHENKANA	DED, DHEN	11 kV KHAJURI	14324203	76	70	0	6	0	6	0
1381	TPCODL	DHENKANA	DED, DHEN	11 kV KAMALA	14330202	18	13	0	5	0	5	0
1382	TPCODL	DHENKANA	DED, DHEN	11 kV PURUNA	14330203	2	2	0	0	0	0	0
1383	TPCODL	DHENKANA	DED, DHEN	33 kV DKL TOW	17024401	1	1	0	0	0	0	0
1384	TPCODL	DHENKANA	DED, DHEN	33 kV GONDIA	17024402	4	4	0	0	0	0	0
1385	TPCODL	DHENKANA	DED, DHEN	33 kV HINDOL	17024403	1	1	0	0	0	0	0
1386	TPCODL	DHENKANA	DED, DHEN	33 kV OPL	17024404	3	3	0	0	0	0	0
1387	TPCODL	DHENKANA	DED, DHEN	33 kV GUNDICH	17024405	1	1	0	0	0	0	0
1388	TPCODL	DHENKANA	DED, DHEN	33 kV BANASIN	17024406	2	2	0	0	0	0	0
1389	TPCODL	DHENKANA	DED, DHEN	33 kV SCAW IN	17024407	1	1	0	0	0	0	0

Sl No.	Zone name	Circle name	Division name	Feeder name	Feeder ID	Total no of DT on feeder	No of unmetered DTC	No of metered DTC			No of DT's with functional meters	
								AMR metered (communicable)	AMI metered (Communicable)	No AMR/AMI metered (non communicable)	Communicating (Total no out 0f 07 & 08)	Non-Communicating (Total no out 0f 07 & 08 & 09)
0	1	2	3	4	12	5=(6+7+8+9)	6	7	8	9	10	11
1390	TPCODL	DHENKANA	DED, DHEI	33 kV DAKHINA	17024408	4	4	0	0	0	0	0
1391	TPCODL	DHENKANA	DED, DHEI	33 kV MEGA LI	17024409	1	1	0	0	0	0	0
1392	TPCODL	DHENKANA	DED, DHEI	33 kV VINAYAK	17024411	1	1	0	0	0	0	0
1393	TPCODL	DHENKANA	DED, DHEI	33 kV KAMAKH	17025401	1	1	0	0	0	0	0
1394	TPCODL	DHENKANA	DED, DHEI	33 kV KANKAD	17025402	3	3	0	0	0	0	0
1395	TPCODL	DHENKANA	DED, DHEI	33 kV SOVAME	17025403	2	2	0	0	0	0	0
1396	TPCODL	DHENKANA	DED, DHEI	33 kV MATHAK	17025404	2	2	0	0	0	0	0
1397	TPCODL	DHENKANA	DED, DHEI	33 kV PANDUA	17025405	2	2	0	0	0	0	0
1398	TPCODL	DHENKANA	DED, DHEI	33 kV TISCO	17026401	4	4	0	0	0	0	0
1399	TPCODL	DHENKANA	DED, DHEI	33 kV OMC	17026402	6	6	0	0	0	0	0
1400	TPCODL	DHENKANA	DED, DHEI	33 kV KALIAPA	17026403	23	23	0	0	0	0	0
1401	TPCODL	DHENKANA	DED, DHEI	33 kV KHAJURI	17040401	1	1	0	0	0	0	0
1402	TPCODL	DHENKANA	DED, DHEI	33 kV HINDOL	17040402	5	5	0	0	0	0	0
1403	TPCODL	DHENKANA	DED, DHEI	33 kV RWSS	17048402	2	2	0	0	0	0	0
1404	TPCODL	DHENKANA	DED, DHEI	33 kV GODA	17062401	1	1	0	0	0	0	0
1405	TPCODL	DHENKANA	DED, DHEI	33 kV JOROND	17068402	1	1	0	0	0	0	0
1406	TPCODL	DHENKANA	ANED, AN(	11 kV INDUSTR	1413302	1	1	0	0	0	0	0
1407	TPCODL	DHENKANA	ANED, AN(	11 kV BAMUR S	1414101	1	0	0	1	0	1	0
1408	TPCODL	DHENKANA	ANED, AN(	11 kV HARIMA	14132201	22	10	0	12	0	12	0
1409	TPCODL	DHENKANA	ANED, AN(	11 kV Amalapa	14132202	50	33	0	17	0	17	0
1410	TPCODL	DHENKANA	ANED, AN(	11 kV RCMS TH	14132203	37	21	0	16	0	16	0
1411	TPCODL	DHENKANA	ANED, AN(	11 kV RCMS RE	14132204	238	197	0	41	0	41	0
1412	TPCODL	DHENKANA	ANED, AN(	11 kV RCMS BA	14132206	50	31	0	19	0	19	0
1413	TPCODL	DHENKANA	ANED, AN(	11 kV RCMS CO	14132207	24	8	0	16	0	16	0
1414	TPCODL	DHENKANA	ANED, AN(	11 kV KHALARI	14132208	20	11	0	9	0	9	0
1415	TPCODL	DHENKANA	ANED, AN(	11 kV PTC	14132209	67	40	0	27	0	27	0
1416	TPCODL	DHENKANA	ANED, AN(	11 kV BANIABA	14132210	23	13	0	10	0	10	0
1417	TPCODL	DHENKANA	ANED, AN(	11 kV INDUSTR	14133201	42	26	0	16	0	16	0
1418	TPCODL	DHENKANA	ANED, AN(	11 kV KURDUL	14133202	133	98	0	35	0	35	0
1419	TPCODL	DHENKANA	ANED, AN(	11 kV BANTALA	14134201	308	266	0	42	0	40	2
1420	TPCODL	DHENKANA	ANED, AN(	11 kV SABALAE	14134202	102	94	0	8	0	8	0
1421	TPCODL	DHENKANA	ANED, AN(	11 kV KHINDA	14134203	190	171	0	19	0	19	0
1422	TPCODL	DHENKANA	ANED, AN(	11 kV SARANG	14134204	34	30	0	4	0	4	0
1423	TPCODL	DHENKANA	ANED, AN(	11 kV KATADA	14135201	47	40	0	7	0	7	0
1424	TPCODL	DHENKANA	ANED, AN(	11 kV JAGANAT	14135202	253	246	0	7	0	7	0
1425	TPCODL	DHENKANA	ANED, AN(	11 kV KOSALA	14135203	51	50	0	1	0	1	0
1426	TPCODL	DHENKANA	ANED, AN(	11 kV KANJAR	14135204	109	93	0	16	0	16	0
1427	TPCODL	DHENKANA	ANED, AN(	11 kV RAILWAY	14135205	5	2	0	3	0	3	0
1428	TPCODL	DHENKANA	ANED, AN(	11 kV DUBANA	14136201	212	197	0	15	0	15	0
1429	TPCODL	DHENKANA	ANED, AN(	11 kV BRAHMA	14136202	173	163	0	10	0	10	0
1430	TPCODL	DHENKANA	ANED, AN(	11 kV BAHALSA	14136203	137	131	0	6	0	6	0
1431	TPCODL	DHENKANA	ANED, AN(	11 kV CHHEND	14136204	34	26	0	8	0	8	0
1432	TPCODL	DHENKANA	ANED, AN(	11 kV BAGEDIA	14136205	159	138	0	21	0	21	0
1433	TPCODL	DHENKANA	ANED, AN(	11 kV PIPALA B	14136206	137	127	0	10	0	10	0
1434	TPCODL	DHENKANA	ANED, AN(	11 kV BOINDA	14137201	24	14	0	10	0	10	0
1435	TPCODL	DHENKANA	ANED, AN(	11 kV HANDPA	14137202	197	187	0	10	0	10	0
1436	TPCODL	DHENKANA	ANED, AN(	11 kV JAMUNA	14137203	85	85	0	0	0	0	0
1437	TPCODL	DHENKANA	ANED, AN(	11 kV PAIKASA	14137204	133	113	0	20	0	19	1
1438	TPCODL	DHENKANA	ANED, AN(	11 kV LUHAMU	14137205	118	114	0	4	0	4	0
1439	TPCODL	DHENKANA	ANED, AN(	11 kV SANAHU	14137206	137	130	0	7	0	7	0
1440	TPCODL	DHENKANA	ANED, AN(	11 kV THAKUR	14138201	161	155	0	6	0	6	0
1441	TPCODL	DHENKANA	ANED, AN(	11 kV KRUTIBA	14138202	59	58	0	1	0	1	0
1442	TPCODL	DHENKANA	ANED, AN(	11 kV KUTULIS	14138203	108	106	0	2	0	2	0
1443	TPCODL	DHENKANA	ANED, AN(	11 kV GHODAB	14138204	34	32	0	2	0	2	0
1444	TPCODL	DHENKANA	ANED, AN(	11 kV ATHAMA	14139201	89	59	0	30	0	30	0
1445	TPCODL	DHENKANA	ANED, AN(	11 kV MANTIRI	14139202	94	90	0	4	0	4	0
1446	TPCODL	DHENKANA	ANED, AN(	11 kV JADPUR	14139203	21	21	0	0	0	0	0
1447	TPCODL	DHENKANA	ANED, AN(	11 kV BINKEI	14139204	129	125	0	4	0	4	0

SI No.	Zone name	Circle name	Division name	Feeder name	Feeder ID	Total no of DT on feeder	No of unmetered DTC	No of metered DTC			No of DT's with functional meters	
								AMR metered (communicable)	AMI metered (Communicable)	No AMR/AMI metered (non communicable)	Communicating (Total no out 0f 07 & 08)	Non-Communicating (Total no out 0f 07 & 08 & 09)
0	1	2	3	4	12	5=(6+7+8+9)	6	7	8	9	10	11
1448	TPCODL	DHENKANA	ANED, ANG	11 kV BAGHUA	14139205	55	53	0	2	0	2	0
1449	TPCODL	DHENKANA	ANED, ANG	33 kV MEGA LI	14139401	2	2	0	0	0	0	0
1450	TPCODL	DHENKANA	ANED, ANG	11 kV MADHAF	14140201	55	51	0	4	0	4	0
1451	TPCODL	DHENKANA	ANED, ANG	11 kV KIAKATA	14140202	256	253	0	3	0	3	0
1452	TPCODL	DHENKANA	ANED, ANG	11 kV NILAKAN	14140203	38	38	0	0	0	0	0
1453	TPCODL	DHENKANA	ANED, ANG	11 kV LUNAHA	14140204	35	32	0	3	0	3	0
1454	TPCODL	DHENKANA	ANED, ANG	33 kV MEGA LI	14140401	2	2	0	0	0	0	0
1455	TPCODL	DHENKANA	ANED, ANG	11 kV FASHIPA	14141201	41	41	0	0	0	0	0
1456	TPCODL	DHENKANA	ANED, ANG	11 kV BRAHMA	14141202	30	30	0	0	0	0	0
1457	TPCODL	DHENKANA	ANED, ANG	11 kV KHAIRAN	14141203	3	3	0	0	0	0	0
1458	TPCODL	DHENKANA	ANED, ANG	11 kV AMBAPA	14141204	34	33	0	1	0	1	0
1459	TPCODL	DHENKANA	ANED, ANG	11 kV GOBARA	14146201	1	1	0	0	0	0	0
1460	TPCODL	DHENKANA	ANED, ANG	11 kV HEMSUR	14187201	92	66	0	26	0	26	0
1461	TPCODL	DHENKANA	ANED, ANG	11 kV MCL	14187202	118	95	0	23	0	23	0
1462	TPCODL	DHENKANA	ANED, ANG	11 kV MEDICAL	14187203	10	10	0	0	0	0	0
1463	TPCODL	DHENKANA	ANED, ANG	11 kV SIKHYAK	14187204	31	13	0	18	0	18	0
1464	TPCODL	DHENKANA	ANED, ANG	11 kV JARASIN	14187205	199	162	0	37	0	37	0
1465	TPCODL	DHENKANA	ANED, ANG	11 kV BADAKEI	14227201	213	185	0	28	0	28	0
1466	TPCODL	DHENKANA	ANED, ANG	11 kV DUDHIAI	14227202	189	115	0	74	0	73	1
1467	TPCODL	DHENKANA	ANED, ANG	33 kV MOMIT	14227401	2	2	0	0	0	0	0
1468	TPCODL	DHENKANA	ANED, ANG	11 kV TALAPAL	14325201	63	61	0	2	0	2	0
1469	TPCODL	DHENKANA	ANED, ANG	11 kV RANIAKA	14325202	237	229	0	8	0	8	0
1470	TPCODL	DHENKANA	ANED, ANG	11 kV KADALIM	14325203	43	41	0	2	0	2	0
1471	TPCODL	DHENKANA	ANED, ANG	11 kV KISHORE	14325204	55	49	0	6	0	6	0
1472	TPCODL	DHENKANA	ANED, ANG	11 kV KOSALA	14326201	81	72	0	9	0	9	0
1473	TPCODL	DHENKANA	ANED, ANG	11 kV CHANDA	14326204	61	51	0	10	0	10	0
1474	TPCODL	DHENKANA	ANED, ANG	11 kV RWSS	14326205	2	2	0	0	0	0	0
1475	TPCODL	DHENKANA	ANED, ANG	11 kV BUDULIN	14327201	73	69	0	4	0	4	0
1476	TPCODL	DHENKANA	ANED, ANG	11 kV NAKCHI	14327202	29	27	0	2	0	2	0
1477	TPCODL	DHENKANA	ANED, ANG	11 kV URUKUL	14327203	83	83	0	0	0	0	0
1478	TPCODL	DHENKANA	ANED, ANG	11 kV NALCO T	14328201	46	36	0	10	0	10	0
1479	TPCODL	DHENKANA	ANED, ANG	11 kV NALCO N	14328202	16	9	0	7	0	7	0
1480	TPCODL	DHENKANA	ANED, ANG	11 kV TURANG	14328203	30	18	0	12	0	12	0
1481	TPCODL	DHENKANA	ANED, ANG	11 kV BENTPUI	14328204	11	10	0	1	0	1	0
1482	TPCODL	DHENKANA	ANED, ANG	11 kV PHULPAI	14337201	1	1	0	0	0	0	0
1483	TPCODL	DHENKANA	ANED, ANG	11 kV POLYTEC	14383201	30	19	0	11	0	11	0
1484	TPCODL	DHENKANA	ANED, ANG	11 kV KARADA	14383202	57	52	0	5	0	5	0
1485	TPCODL	DHENKANA	ANED, ANG	11 kV SARADAI	14383203	19	18	0	1	0	1	0
1486	TPCODL	DHENKANA	ANED, ANG	11 kV ADARSH	14383204	39	37	0	2	0	2	0
1487	TPCODL	DHENKANA	ANED, ANG	33 kV RAILWAY	17030401	1	1	0	0	0	0	0
1488	TPCODL	DHENKANA	ANED, ANG	33 kV ANGULI	17030402	2	1	0	1	0	1	0
1489	TPCODL	DHENKANA	ANED, ANG	33 kV ANGULII	17030403	4	3	0	1	0	1	0
1490	TPCODL	DHENKANA	ANED, ANG	33 kV M/S GAN	17030404	2	1	0	1	0	1	0
1491	TPCODL	DHENKANA	ANED, ANG	33 kV HEMASU	17030405	1	1	0	0	0	0	0
1492	TPCODL	DHENKANA	ANED, ANG	33 kV JARPADA	17031401	5	5	0	0	0	0	0
1493	TPCODL	DHENKANA	ANED, ANG	33 kV BOINDA	17031402	1	1	0	0	0	0	0
1494	TPCODL	DHENKANA	ANED, ANG	33 kV ATHAMA	17031403	3	3	0	0	0	0	0
1495	TPCODL	DHENKANA	ANED, ANG	33 kV BAMUR	17032401	3	2	0	1	0	1	0
1496	TPCODL	DHENKANA	ANED, ANG	11 kV BUDHAP	30000001	2	2	0	0	0	0	0
1497	TPCODL	DHENKANA	TED, CHAI	11 kV PARJANG	1414301	1	1	0	0	0	0	0
1498	TPCODL	DHENKANA	TED, CHAI	11 kV BALANDA	1414602	1	1	0	0	0	0	0
1499	TPCODL	DHENKANA	TED, CHAI	11 kV SAMAL S	1414702	1	1	0	0	0	0	0
1500	TPCODL	DHENKANA	TED, CHAI	11 kV PARABIL	1414901	1	1	0	0	0	0	0
1501	TPCODL	DHENKANA	TED, CHAI	11 kV KHAMAR	1415001	1	1	0	0	0	0	0
1502	TPCODL	DHENKANA	TED, CHAI	11 kV PALLAHA	1415101	1	0	0	1	0	1	0
1503	TPCODL	DHENKANA	TED, CHAI	11 kV OHPC (R	1418601	1	1	0	0	0	0	0
1504	TPCODL	DHENKANA	TED, CHAI	11 kV RCMS RE	14132204	6	6	0	0	0	0	0
1505	TPCODL	DHENKANA	TED, CHAI	11 kV BRAHMA	14136202	8	8	0	0	0	0	0

Sl No.	Zone name	Circle name	Division name	Feeder name	Feeder ID	Total no of DT on feeder	No of unmetered DTC	No of metered DTC			No of DT's with functional meters	
								AMR metered (communicable)	AMI metered (Communicable)	No AMR/AMI metered (non communicable)	Communicating (Total no out 0f 07 & 08)	Non-Communicating (Total no out 0f 07 & 08 & 09)
0	1	2	3	4	12	5=(6+7+8+9)	6	7	8	9	10	11
1506	TPCODL	DHENKANA	TED, CHAI	11 kV CHAINPA	14142201	53	40	0	13	0	13	0
1507	TPCODL	DHENKANA	TED, CHAI	11 kV KULAD	14142202	100	72	0	28	0	28	0
1508	TPCODL	DHENKANA	TED, CHAI	11 kV HINDOL	14142203	181	153	0	28	0	28	0
1509	TPCODL	DHENKANA	TED, CHAI	11 kV MERAMU	14142204	75	57	0	18	0	17	1
1510	TPCODL	DHENKANA	TED, CHAI	11 kV BANARPA	14142205	30	18	0	12	0	12	0
1511	TPCODL	DHENKANA	TED, CHAI	11 kV OLD PAR	14143201	226	202	0	24	0	24	0
1512	TPCODL	DHENKANA	TED, CHAI	11 kV Rengali (	14143202	32	23	0	9	0	9	0
1513	TPCODL	DHENKANA	TED, CHAI	11 kV RN PUR	14143203	22	20	0	2	0	2	0
1514	TPCODL	DHENKANA	TED, CHAI	11 kV Kualo (Pa	14143204	50	43	0	7	0	7	0
1515	TPCODL	DHENKANA	TED, CHAI	11 kV Mahavee	14143205	71	64	0	7	0	7	0
1516	TPCODL	DHENKANA	TED, CHAI	11 kV Kandar S	14143206	116	91	0	25	0	25	0
1517	TPCODL	DHENKANA	TED, CHAI	11 kV Saranga	14143207	83	61	0	22	0	22	0
1518	TPCODL	DHENKANA	TED, CHAI	11 kV New Parj	14143208	18	15	0	3	0	3	0
1519	TPCODL	DHENKANA	TED, CHAI	11 kV SARANG	14144201	12	10	0	2	0	2	0
1520	TPCODL	DHENKANA	TED, CHAI	11 kV HATATO	14145201	108	94	0	14	0	14	0
1521	TPCODL	DHENKANA	TED, CHAI	11 kV HATATO	14145202	137	119	0	18	0	18	0
1522	TPCODL	DHENKANA	TED, CHAI	11 kV Hatatota	14145203	54	33	0	21	0	20	1
1523	TPCODL	DHENKANA	TED, CHAI	11 kV Hatatota	14145204	59	33	0	26	0	26	0
1524	TPCODL	DHENKANA	TED, CHAI	11 kV Hatatota	14145205	109	73	0	36	0	36	0
1525	TPCODL	DHENKANA	TED, CHAI	11 kV GODIBAI	14145206	210	190	0	20	0	20	0
1526	TPCODL	DHENKANA	TED, CHAI	33 kV SAMAL	14145401	2	2	0	0	0	0	0
1527	TPCODL	DHENKANA	TED, CHAI	11 kV GOBARA	14146201	123	104	0	19	0	19	0
1528	TPCODL	DHENKANA	TED, CHAI	11 kV JAGANN	14146202	97	78	0	19	0	19	0
1529	TPCODL	DHENKANA	TED, CHAI	11 kV GURUDV	14146203	33	25	0	8	0	8	0
1530	TPCODL	DHENKANA	TED, CHAI	11 kV NTPC (KA	14146204	4	4	0	0	0	0	0
1531	TPCODL	DHENKANA	TED, CHAI	11 kV SAMAL V	14147201	35	31	0	4	0	4	0
1532	TPCODL	DHENKANA	TED, CHAI	11 kV BIJIGOL	14147202	48	47	0	1	0	1	0
1533	TPCODL	DHENKANA	TED, CHAI	11 kV BARRAG	14147203	3	0	0	3	0	3	0
1534	TPCODL	DHENKANA	TED, CHAI	11 kV BARRAG	14147204	6	2	0	4	0	4	0
1535	TPCODL	DHENKANA	TED, CHAI	11 kV KANIHA-	14148201	38	34	0	4	0	3	1
1536	TPCODL	DHENKANA	TED, CHAI	11 kV KANIHA	14148202	54	52	0	2	0	2	0
1537	TPCODL	DHENKANA	TED, CHAI	11 kV KANIHA	14148203	148	135	0	13	0	13	0
1538	TPCODL	DHENKANA	TED, CHAI	11 kV KANIHA-	14148204	4	2	0	2	0	2	0
1539	TPCODL	DHENKANA	TED, CHAI	11 kV KARADI	14148205	99	61	0	38	0	38	0
1540	TPCODL	DHENKANA	TED, CHAI	11 kV DERANG	14148206	170	150	0	20	0	20	0
1541	TPCODL	DHENKANA	TED, CHAI	11 kV KIAJHAR	14148207	22	21	0	1	0	1	0
1542	TPCODL	DHENKANA	TED, CHAI	11 kV MCL KAN	14148209	3	3	0	0	0	0	0
1543	TPCODL	DHENKANA	TED, CHAI	11 kV PARABIL	14149201	148	137	0	11	0	11	0
1544	TPCODL	DHENKANA	TED, CHAI	11 kV ARKIL	14149202	184	178	0	6	0	6	0
1545	TPCODL	DHENKANA	TED, CHAI	11 kV GAHAM	14149203	23	19	0	4	0	4	0
1546	TPCODL	DHENKANA	TED, CHAI	11 kV BARKOTI	14150202	175	168	0	7	0	6	1
1547	TPCODL	DHENKANA	TED, CHAI	11 kV SANKHA	14150203	175	159	0	16	0	16	0
1548	TPCODL	DHENKANA	TED, CHAI	11 kV ODAUS	14150204	78	69	0	9	0	9	0
1549	TPCODL	DHENKANA	TED, CHAI	33 kV KUNJAM	14150401	1	1	0	0	0	0	0
1550	TPCODL	DHENKANA	TED, CHAI	11 kV TOWN (P	14151201	98	82	0	16	0	16	0
1551	TPCODL	DHENKANA	TED, CHAI	11 kV KANTALA	14151202	33	33	0	0	0	0	0
1552	TPCODL	DHENKANA	TED, CHAI	11 kV SEEGARH	14151203	67	65	0	2	0	2	0
1553	TPCODL	DHENKANA	TED, CHAI	11 kV PHAPAN	14151204	122	119	0	3	0	3	0
1554	TPCODL	DHENKANA	TED, CHAI	11 kV BATISUA	14151205	163	159	0	4	0	4	0
1555	TPCODL	DHENKANA	TED, CHAI	33 kV KANTALA	14151401	1	1	0	0	0	0	0
1556	TPCODL	DHENKANA	TED, CHAI	11 kV TUMUGA	14152201	73	69	0	4	0	4	0
1557	TPCODL	DHENKANA	TED, CHAI	11 kV KULEI	14152202	37	37	0	0	0	0	0
1558	TPCODL	DHENKANA	TED, CHAI	11 kV RENGALI	14186201	39	33	0	6	0	6	0
1559	TPCODL	DHENKANA	TED, CHAI	11 kV PGCIL	14186202	32	25	0	7	0	7	0
1560	TPCODL	DHENKANA	TED, CHAI	11 kV BALHAR	14192201	92	55	0	37	0	37	0
1561	TPCODL	DHENKANA	TED, CHAI	11 kV GOTAMA	14192202	35	28	0	7	0	7	0
1562	TPCODL	DHENKANA	TED, CHAI	11 kV BHOGAB	14192203	108	84	0	24	0	24	0
1563	TPCODL	DHENKANA	TED, CHAI	11 kV SANDA	14329201	63	53	0	10	0	10	0

SI No.	Zone name	Circle name	Division name	Feeder name	Feeder ID	Total no of DT on feeder	No of unmetered DTC	No of metered DTC			No of DT's with functional meters	
								AMR metered (communicable)	AMI metered (Communicable)	No AMR/AMI metered (non communicable)	Communicating (Total no out 0f 07 & 08)	Non-Communicating (Total no out 0f 07 & 08 & 09)
0	1	2	3	4	12	5=(6+7+8+9)	6	7	8	9	10	11
1564	TPCODL	DHENKANA	TED, CHAI	11 kV PANI GE	14329202	57	52	0	5	0	5	0
1565	TPCODL	DHENKANA	TED, CHAI	11 kV KANKILI	14329204	46	41	0	5	0	5	0
1566	TPCODL	DHENKANA	TED, CHAI	11 kV KAMALA	14330202	256	221	0	35	0	35	0
1567	TPCODL	DHENKANA	TED, CHAI	11 kV PURUNA	14330203	145	124	0	21	0	21	0
1568	TPCODL	DHENKANA	TED, CHAI	11 kV DANARA	14331201	18	10	0	8	0	8	0
1569	TPCODL	DHENKANA	TED, CHAI	11 kV KALAMC	14331202	103	75	0	28	0	28	0
1570	TPCODL	DHENKANA	TED, CHAI	11 kV GOPAL P	14331203	83	74	0	9	0	9	0
1571	TPCODL	DHENKANA	TED, CHAI	11 kV BADA JO	14331204	17	12	0	5	0	5	0
1572	TPCODL	DHENKANA	TED, CHAI	11 kV KHAJUTI	14331205	2	2	0	0	0	0	0
1573	TPCODL	DHENKANA	TED, CHAI	11 kV KARNAP	14331206	2	2	0	0	0	0	0
1574	TPCODL	DHENKANA	TED, CHAI	11 kV INJIDI	14332201	139	137	0	2	0	2	0
1575	TPCODL	DHENKANA	TED, CHAI	11 kV NUAGAC	14332202	136	130	0	6	0	6	0
1576	TPCODL	DHENKANA	TED, CHAI	11 kV RAJADAN	14332203	29	29	0	0	0	0	0
1577	TPCODL	DHENKANA	TED, CHAI	11 kV JATIA	14333201	24	21	0	3	0	3	0
1578	TPCODL	DHENKANA	TED, CHAI	11 kV SARANG	14333203	26	16	0	10	0	10	0
1579	TPCODL	DHENKANA	TED, CHAI	11 kV BAJRAKC	14334201	146	137	0	9	0	9	0
1580	TPCODL	DHENKANA	TED, CHAI	11 kV BAUDAB	14334202	12	12	0	0	0	0	0
1581	TPCODL	DHENKANA	TED, CHAI	11 kV GUNDUR	14334203	92	83	0	9	0	9	0
1582	TPCODL	DHENKANA	TED, CHAI	11 kV PANGAT	14336201	61	56	0	5	0	4	1
1583	TPCODL	DHENKANA	TED, CHAI	11 kV MAHABI	14336202	22	18	0	4	0	4	0
1584	TPCODL	DHENKANA	TED, CHAI	11 kV GADAPA	14336203	87	78	0	9	0	9	0
1585	TPCODL	DHENKANA	TED, CHAI	11 kV PHULPAI	14337201	126	112	0	14	0	14	0
1586	TPCODL	DHENKANA	TED, CHAI	11 kV JAMARD	14338201	83	83	0	0	0	0	0
1587	TPCODL	DHENKANA	TED, CHAI	11 kV SIMILIPA	14338202	46	46	0	0	0	0	0
1588	TPCODL	DHENKANA	TED, CHAI	11 kV JHARBED	14338203	94	92	0	2	0	2	0
1589	TPCODL	DHENKANA	TED, CHAI	11 kV DADRAH	14339201	52	51	0	1	0	1	0
1590	TPCODL	DHENKANA	TED, CHAI	11 kV BASULEI	14339202	47	45	0	2	0	2	0
1591	TPCODL	DHENKANA	TED, CHAI	11 kV JHARANA	14339203	23	22	0	1	0	1	0
1592	TPCODL	DHENKANA	TED, CHAI	11 kV BHEJIA	14339204	95	82	0	13	0	13	0
1593	TPCODL	DHENKANA	TED, CHAI	33 kV MAHABI	14339401	1	0	0	1	0	1	0
1594	TPCODL	DHENKANA	TED, CHAI	11 kV TALCHER	14375201	71	41	0	30	0	29	1
1595	TPCODL	DHENKANA	TED, CHAI	11 kV BANTOL	14375202	67	47	0	20	0	20	0
1596	TPCODL	DHENKANA	TED, CHAI	11 kV HANDIDI	14375203	46	30	0	16	0	16	0
1597	TPCODL	DHENKANA	TED, CHAI	11 kV ITI	14375204	5	2	0	3	0	3	0
1598	TPCODL	DHENKANA	TED, CHAI	33 kV BANARP	17027401	1	1	0	0	0	0	0
1599	TPCODL	DHENKANA	TED, CHAI	33 kV PARJANG	17027402	5	5	0	0	0	0	0
1600	TPCODL	DHENKANA	TED, CHAI	33 kV RENGALI	17027403	2	2	0	0	0	0	0
1601	TPCODL	DHENKANA	TED, CHAI	33 kV INDUSTR	17027404	7	7	0	0	0	0	0
1602	TPCODL	DHENKANA	TED, CHAI	33 kV TALCHER	17027405	1	1	0	0	0	0	0
1603	TPCODL	DHENKANA	TED, CHAI	33 kV CHAINPA	17027406	1	1	0	0	0	0	0
1604	TPCODL	DHENKANA	TED, CHAI	33 kV KHAMAR	17028401	8	8	0	0	0	0	0
1605	TPCODL	DHENKANA	TED, CHAI	33 kV KANIHA	17028402	4	4	0	0	0	0	0
1606	TPCODL	DHENKANA	TED, CHAI	33 kV MEGA LI	17028405	2	2	0	0	0	0	0
1607	TPCODL	DHENKANA	TED, CHAI	33 kV BARKOTE	17029401	1	0	0	1	0	1	0
1608	TPCODL	DHENKANA	TED, CHAI	33 kV ANGULII	17030403	3	3	0	0	0	0	0
1609	TPCODL	DHENKANA	TED, CHAI	33 kV MERAMU	17048401	1	1	0	0	0	0	0
1610	TPCODL	DHENKANA	TED, CHAI	11 kV SIBIDA	30000001	1	1	0	0	0	0	0
1611	TPCODL	PARADEEP (	KED-01, KE	11 kV ADHAJOI	1415902	1	1	0	0	0	0	0
1612	TPCODL	PARADEEP (	KED-01, KE	11 kV DANPUR	1416402	1	1	0	0	0	0	0
1613	TPCODL	PARADEEP (	KED-01, KE	11 kV JHARIA	14153201	127	94	0	33	0	33	0
1614	TPCODL	PARADEEP (	KED-01, KE	11 kV PATTAM	14153202	24	16	0	8	0	8	0
1615	TPCODL	PARADEEP (	KED-01, KE	11 kV BALIPAT	14153204	68	47	0	21	0	21	0
1616	TPCODL	PARADEEP (	KED-01, KE	11 kV BALDEV	14153205	22	14	0	8	0	8	0
1617	TPCODL	PARADEEP (	KED-01, KE	11 kV BELTAL	14153206	37	28	0	9	0	9	0
1618	TPCODL	PARADEEP (	KED-01, KE	11 kV SASAN	14154201	63	44	0	19	0	19	0
1619	TPCODL	PARADEEP (	KED-01, KE	11 kV AUL	14154202	151	104	0	47	0	47	0
1620	TPCODL	PARADEEP (	KED-01, KE	11 kV CHHOTA	14154203	45	25	0	20	0	19	1
1621	TPCODL	PARADEEP (	KED-01, KE	11 kV BHUINPU	14154204	126	85	0	41	0	41	0

SI No.	Zone name	Circle name	Division name	Feeder name	Feeder ID	Total no of DT on feeder	No of unmetered DTC	No of metered DTC			No of DT's with functional meters	
								AMR metered (communicable)	AMI metered (Communicable)	No AMR/AMI metered (non communicable)	Communicating (Total no out 0f 07 & 08)	Non-Communicating (Total no out 0f 07 & 08 & 09)
0	1	2	3	4	12	5=(6+7+8+9)	6	7	8	9	10	11
1622	TPCODL	PARADEEP (	KED-01, KE	11 kV MENDHA	14154205	80	55	0	25	0	25	0
1623	TPCODL	PARADEEP (	KED-01, KE	33 kV MADHUE	14154401	1	1	0	0	0	0	0
1624	TPCODL	PARADEEP (	KED-01, KE	11 kV OSTIA	14155201	143	123	0	20	0	20	0
1625	TPCODL	PARADEEP (	KED-01, KE	11 kV GIRIA	14155202	14	11	0	3	0	3	0
1626	TPCODL	PARADEEP (	KED-01, KE	11 kV BHARIGU	14155203	72	57	0	15	0	15	0
1627	TPCODL	PARADEEP (	KED-01, KE	11 kV OLAVER	14155204	25	20	0	5	0	5	0
1628	TPCODL	PARADEEP (	KED-01, KE	11 kV RAJAKAN	14155205	2	0	0	2	0	2	0
1629	TPCODL	PARADEEP (	KED-01, KE	11 kV BATIPAD	14156201	86	64	0	22	0	22	0
1630	TPCODL	PARADEEP (	KED-01, KE	11 kV PATRAPU	14156202	90	65	0	25	0	24	1
1631	TPCODL	PARADEEP (	KED-01, KE	11 kV INDUPUF	14157201	17	7	0	10	0	10	0
1632	TPCODL	PARADEEP (	KED-01, KE	11 kV DHUMAT	14157202	48	39	0	9	0	9	0
1633	TPCODL	PARADEEP (	KED-01, KE	11 kV NIKIREI	14157203	108	82	0	26	0	26	0
1634	TPCODL	PARADEEP (	KED-01, KE	11 kV BAIRI	14157204	57	53	0	4	0	4	0
1635	TPCODL	PARADEEP (	KED-01, KE	11 kV KENDRAI	14158201	74	46	0	28	0	28	0
1636	TPCODL	PARADEEP (	KED-01, KE	11 kV KENDRAI	14158202	46	25	0	21	0	21	0
1637	TPCODL	PARADEEP (	KED-01, KE	11 kV THAKURI	14158203	135	113	0	22	0	21	1
1638	TPCODL	PARADEEP (	KED-01, KE	11 kV BHARATI	14158204	83	71	0	12	0	12	0
1639	TPCODL	PARADEEP (	KED-01, KE	11 kV TINIMUH	14158205	92	68	0	24	0	23	1
1640	TPCODL	PARADEEP (	KED-01, KE	11 kV KORIAPA	14159201	56	50	0	6	0	6	0
1641	TPCODL	PARADEEP (	KED-01, KE	11 kV CHANDA	14159202	103	90	0	13	0	13	0
1642	TPCODL	PARADEEP (	KED-01, KE	11 kV DAMARF	14159203	93	74	0	19	0	19	0
1643	TPCODL	PARADEEP (	KED-01, KE	11 kV RAJANAC	14160201	228	158	0	70	0	69	1
1644	TPCODL	PARADEEP (	KED-01, KE	11 kV KOILIPUF	14160202	102	95	0	7	0	7	0
1645	TPCODL	PARADEEP (	KED-01, KE	11 kV KEREDAC	14160203	126	100	0	26	0	26	0
1646	TPCODL	PARADEEP (	KED-01, KE	11 kV MADANF	14160204	74	63	0	11	0	11	0
1647	TPCODL	PARADEEP (	KED-01, KE	33 kV KANDIRA	14160401	1	1	0	0	0	0	0
1648	TPCODL	PARADEEP (	KED-01, KE	11 kV NAPANG	14161202	45	36	0	9	0	9	0
1649	TPCODL	PARADEEP (	KED-01, KE	11 kV DOBAND	14161205	17	15	0	2	0	2	0
1650	TPCODL	PARADEEP (	KED-01, KE	33 kV KHAMAF	14161402	1	1	0	0	0	0	0
1651	TPCODL	PARADEEP (	KED-01, KE	11 kV DANDISA	14162201	75	59	0	16	0	16	0
1652	TPCODL	PARADEEP (	KED-01, KE	11 kV BERHAM	14162202	62	48	0	14	0	14	0
1653	TPCODL	PARADEEP (	KED-01, KE	11 kV PALIMI	14162203	59	49	0	10	0	10	0
1654	TPCODL	PARADEEP (	KED-01, KE	11 kV NAGANP	14163203	1	1	0	0	0	0	0
1655	TPCODL	PARADEEP (	KED-01, KE	11 kV DANPUR	14164201	91	74	0	17	0	17	0
1656	TPCODL	PARADEEP (	KED-01, KE	11 kV KHARIDA	14164202	38	27	0	11	0	11	0
1657	TPCODL	PARADEEP (	KED-01, KE	11 kV CHANDO	14164203	30	16	0	14	0	14	0
1658	TPCODL	PARADEEP (	KED-01, KE	11 kV ASURESV	14164204	6	4	0	2	0	2	0
1659	TPCODL	PARADEEP (	KED-01, KE	33 kV JAHARAN	14164403	1	1	0	0	0	0	0
1660	TPCODL	PARADEEP (	KED-01, KE	11 kV MARSHA	14165202	1	1	0	0	0	0	0
1661	TPCODL	PARADEEP (	KED-01, KE	11 kV DUHURIA	14197201	18	11	0	7	0	7	0
1662	TPCODL	PARADEEP (	KED-01, KE	11 kV LAW COL	14197202	68	57	0	11	0	11	0
1663	TPCODL	PARADEEP (	KED-01, KE	11 kV BAGADA	14198201	58	43	0	15	0	14	1
1664	TPCODL	PARADEEP (	KED-01, KE	11 kV GOPA CH	14198202	31	28	0	3	0	3	0
1665	TPCODL	PARADEEP (	KED-01, KE	11 kV ICHHAPU	14198203	7	6	0	1	0	1	0
1666	TPCODL	PARADEEP (	KED-01, KE	11 kV CHHATA	14199201	136	111	0	25	0	25	0
1667	TPCODL	PARADEEP (	KED-01, KE	11 kV PANCHU	14199202	106	91	0	15	0	15	0
1668	TPCODL	PARADEEP (	KED-01, KE	11 kV OLAVAR	14200201	62	49	0	13	0	13	0
1669	TPCODL	PARADEEP (	KED-01, KE	11 kV HATASAI	14200202	155	143	0	12	0	12	0
1670	TPCODL	PARADEEP (	KED-01, KE	11 kV DASIPUR	14200203	105	87	0	18	0	18	0
1671	TPCODL	PARADEEP (	KED-01, KE	11 kV NAHUNI	14200204	34	31	0	3	0	3	0
1672	TPCODL	PARADEEP (	KED-01, KE	11 kV BADAPAI	14201201	82	74	0	8	0	8	0
1673	TPCODL	PARADEEP (	KED-01, KE	11 kV GANGAR	14201202	114	105	0	9	0	9	0
1674	TPCODL	PARADEEP (	KED-01, KE	11 kV BIJAYAN/	14228201	2	1	0	1	0	1	0
1675	TPCODL	PARADEEP (	KED-01, KE	11 kV BALARAN	14229201	55	53	0	2	0	2	0
1676	TPCODL	PARADEEP (	KED-01, KE	11 kV JARIMUL	14229202	119	113	0	6	0	6	0
1677	TPCODL	PARADEEP (	KED-01, KE	33 kV BADADIA	14229401	1	1	0	0	0	0	0
1678	TPCODL	PARADEEP (	KED-01, KE	11 kV LUNA	14311203	2	2	0	0	0	0	0
1679	TPCODL	PARADEEP (	KED-01, KE	11 kV GHAGAR	14347201	41	32	0	9	0	9	0

SI No.	Zone name	Circle name	Division name	Feeder name	Feeder ID	Total no of DT on feeder	No of unmetered DTC	No of metered DTC			No of DT's with functional meters	
								AMR metered (communicable)	AMI metered (Communicable)	No AMR/AMI metered (non communicable)	Communicating (Total no out 0f 07 & 08)	Non-Communicating (Total no out 0f 07 & 08 & 09)
0	1	2	3	4	12	5=(6+7+8+9)	6	7	8	9	10	11
1680	TPCODL	PARADEEP (	KED-01, KE	11 kV CHOUDA	14347202	47	38	0	9	0	9	0
1681	TPCODL	PARADEEP (	KED-01, KE	11 kV ISWARPU	14348201	92	83	0	9	0	9	0
1682	TPCODL	PARADEEP (	KED-01, KE	11 kV TALCHUA	14348202	176	168	0	8	0	8	0
1683	TPCODL	PARADEEP (	KED-01, KE	11 kV GOVINDI	14349201	72	41	0	31	0	31	0
1684	TPCODL	PARADEEP (	KED-01, KE	11 kV MAHARA	14349202	60	36	0	24	0	23	1
1685	TPCODL	PARADEEP (	KED-01, KE	11 kV Feeder-3	14350201	33	26	0	7	0	7	0
1686	TPCODL	PARADEEP (	KED-01, KE	11 kV Feeder-1	14350202	23	20	0	3	0	3	0
1687	TPCODL	PARADEEP (	KED-01, KE	11 kV KANSAR	14351201	133	95	0	38	0	38	0
1688	TPCODL	PARADEEP (	KED-01, KE	11 kV BALDEVJ	14351202	10	5	0	5	0	5	0
1689	TPCODL	PARADEEP (	KED-01, KE	11 kV BLOCK	14351203	71	45	0	26	0	25	1
1690	TPCODL	PARADEEP (	KED-01, KE	11 kV Chakoda	14351204	2	2	0	0	0	0	0
1691	TPCODL	PARADEEP (	KED-01, KE	33 kV CHHAGH	14351401	1	1	0	0	0	0	0
1692	TPCODL	PARADEEP (	KED-01, KE	11 kV AYATAN	14352201	156	144	0	12	0	12	0
1693	TPCODL	PARADEEP (	KED-01, KE	11 kV JAYNAGA	14352202	97	93	0	4	0	4	0
1694	TPCODL	PARADEEP (	KED-01, KE	11 kV NAHULIA	14352203	80	72	0	8	0	8	0
1695	TPCODL	PARADEEP (	KED-01, KE	33 kV MEGA RV	14352402	1	1	0	0	0	0	0
1696	TPCODL	PARADEEP (	KED-01, KE	11 kV KORO	14353201	53	46	0	7	0	7	0
1697	TPCODL	PARADEEP (	KED-01, KE	11 kV BARO	14353202	69	64	0	5	0	5	0
1698	TPCODL	PARADEEP (	KED-01, KE	11 kV JAJANGA	14353203	22	18	0	4	0	4	0
1699	TPCODL	PARADEEP (	KED-01, KE	11 kV KARILOP	14354201	8	7	0	1	0	1	0
1700	TPCODL	PARADEEP (	KED-01, KE	11 kV KURTAN	14355201	5	5	0	0	0	0	0
1701	TPCODL	PARADEEP (	KED-01, KE	33 kV PATTAM	17033401	2	1	0	1	0	1	0
1702	TPCODL	PARADEEP (	KED-01, KE	33 kV AUL	17033402	6	2	0	4	0	4	0
1703	TPCODL	PARADEEP (	KED-01, KE	33 kV RAJANAC	17033403	1	1	0	0	0	0	0
1704	TPCODL	PARADEEP (	KED-01, KE	33 kV GOGUA	17033404	8	4	0	4	0	4	0
1705	TPCODL	PARADEEP (	KED-01, KE	33 kV KENDRAI	17034401	1	1	0	0	0	0	0
1706	TPCODL	PARADEEP (	KED-01, KE	33 kV INDUPUI	17034403	4	3	0	1	0	1	0
1707	TPCODL	PARADEEP (	KED-01, KE	33 kV LUNA	17034404	1	1	0	0	0	0	0
1708	TPCODL	PARADEEP (	KED-01, KE	33 kV AULPATT	17034405	1	1	0	0	0	0	0
1709	TPCODL	PARADEEP (	KED-01, KE	33 kV DANPUR	17034406	1	1	0	0	0	0	0
1710	TPCODL	PARADEEP (	KED-01, KE	33 kV OLAVER	17039401	1	1	0	0	0	0	0
1711	TPCODL	PARADEEP (	KED-01, KE	33 kV RAJKANI	17039402	1	1	0	0	0	0	0
1712	TPCODL	PARADEEP (	KED-01, KE	33 kV AYATAN	17039404	1	1	0	0	0	0	0
1713	TPCODL	PARADEEP (	KED-01, KE	33 kV OLAVER	17039405	1	1	0	0	0	0	0
1714	TPCODL	PARADEEP (	KED-01, KE	33 kV RAJNAGA	17061401	1	1	0	0	0	0	0
1715	TPCODL	PARADEEP (	KED-02, M	11 kV BHARATI	14158204	6	5	0	1	0	1	0
1716	TPCODL	PARADEEP (	KED-02, M	11 kV CHANDA	14159202	3	3	0	0	0	0	0
1717	TPCODL	PARADEEP (	KED-02, M	11 kV KORUA	14163201	140	120	0	20	0	20	0
1718	TPCODL	PARADEEP (	KED-02, M	11 kV NAREND	14163202	14	11	0	3	0	3	0
1719	TPCODL	PARADEEP (	KED-02, M	11 kV NAGANP	14163203	109	94	0	15	0	15	0
1720	TPCODL	PARADEEP (	KED-02, M	11 kV BANAKH	14163204	102	83	0	19	0	19	0
1721	TPCODL	PARADEEP (	KED-02, M	11 kV ANGULA	14165201	33	26	0	7	0	7	0
1722	TPCODL	PARADEEP (	KED-02, M	11 kV MARSHA	14165202	72	49	0	23	0	23	0
1723	TPCODL	PARADEEP (	KED-02, M	11 kV SILIPUR	14165203	77	63	0	14	0	13	1
1724	TPCODL	PARADEEP (	KED-02, M	11 kV PATAKUI	14166201	73	62	0	11	0	11	0
1725	TPCODL	PARADEEP (	KED-02, M	11 kV ANKO	14166202	116	89	0	27	0	27	0
1726	TPCODL	PARADEEP (	KED-02, M	11 kV OSTARA	14166203	90	66	0	24	0	24	0
1727	TPCODL	PARADEEP (	KED-02, M	11 kV KARANJA	14166204	68	54	0	14	0	14	0
1728	TPCODL	PARADEEP (	KED-02, M	11 kV NALADIA	14166205	119	97	0	22	0	22	0
1729	TPCODL	PARADEEP (	KED-02, M	33 kV GARADP	14166401	3	2	0	1	0	1	0
1730	TPCODL	PARADEEP (	KED-02, M	33 kV MASAKA	14166402	1	1	0	0	0	0	0
1731	TPCODL	PARADEEP (	KED-02, M	11 kV CHHAPA	14167202	75	68	0	7	0	7	0
1732	TPCODL	PARADEEP (	KED-02, M	11 kV MAHAKA	14167203	64	49	0	15	0	15	0
1733	TPCODL	PARADEEP (	KED-02, M	11 kV DASAMA	14167205	84	79	0	5	0	5	0
1734	TPCODL	PARADEEP (	KED-02, M	33 kV BADHI	14167401	1	0	0	1	0	1	0
1735	TPCODL	PARADEEP (	KED-02, M	33 kV CHAPALI	14167402	1	0	0	1	0	1	0
1736	TPCODL	PARADEEP (	KED-02, M	11 kV GARADA	14168201	109	93	0	16	0	16	0
1737	TPCODL	PARADEEP (	KED-02, M	11 kV GARADA	14168202	91	78	0	13	0	13	0

SI No.	Zone name	Circle name	Division name	Feeder name	Feeder ID	Total no of DT on feeder	No of unmetered DTC	No of metered DTC			No of DT's with functional meters	
								AMR metered (communicable)	AMI metered (Communicable)	No AMR/AMI metered (non communicable)	Communicating (Total no out 0f 07 & 08)	Non-Communicating (Total no out 0f 07 & 08 & 09)
0	1	2	3	4	12	5=(6+7+8+9)	6	7	8	9	10	11
1738	TPCODL	PARADEEP (	KED-02, M	11 kV BALIKUD	14174203	1	1	0	0	0	0	0
1739	TPCODL	PARADEEP (	KED-02, M	33 kV GAUDAG	14198401	1	1	0	0	0	0	0
1740	TPCODL	PARADEEP (	KED-02, M	11 kV BADAPA	14201201	5	5	0	0	0	0	0
1741	TPCODL	PARADEEP (	KED-02, M	11 kV BIJAYAN	14228201	109	97	0	12	0	12	0
1742	TPCODL	PARADEEP (	KED-02, M	11 kV BABAR	14228202	49	45	0	4	0	4	0
1743	TPCODL	PARADEEP (	KED-02, M	11 kV JAMBOO	14228203	156	153	0	3	0	3	0
1744	TPCODL	PARADEEP (	KED-02, M	11 kV Feeder-3	14350201	10	10	0	0	0	0	0
1745	TPCODL	PARADEEP (	KED-02, M	11 kV Feeder-1	14350202	1	1	0	0	0	0	0
1746	TPCODL	PARADEEP (	KED-02, M	33 kV KUDANA	14350402	1	0	0	1	0	1	0
1747	TPCODL	PARADEEP (	KED-02, M	11 kV KANSAR	14351201	4	3	0	1	0	1	0
1748	TPCODL	PARADEEP (	KED-02, M	11 kV KARILOP	14354201	139	116	0	23	0	23	0
1749	TPCODL	PARADEEP (	KED-02, M	11 kV KARAND	14354202	75	69	0	6	0	6	0
1750	TPCODL	PARADEEP (	KED-02, M	11 kV KURTAN	14355201	52	42	0	10	0	10	0
1751	TPCODL	PARADEEP (	KED-02, M	11 kV ORATGH	14355202	56	44	0	12	0	12	0
1752	TPCODL	PARADEEP (	KED-02, M	11 kV ANTAI	14356201	85	63	0	22	0	22	0
1753	TPCODL	PARADEEP (	KED-02, M	11 kV PATKURA	14356202	60	44	0	16	0	15	1
1754	TPCODL	PARADEEP (	KED-02, M	11 kV MARINE	14382201	4	4	0	0	0	0	0
1755	TPCODL	PARADEEP (	KED-02, M	11 kV RAM NA	14382202	178	166	0	12	0	12	0
1756	TPCODL	PARADEEP (	KED-02, M	33 kV LUNA	17035401	1	0	0	1	0	1	0
1757	TPCODL	PARADEEP (	KED-02, M	33 kV MAHAKA	17035402	4	1	0	3	0	3	0
1758	TPCODL	PARADEEP (	JED, JAGAT	33 kV SOMPUR	14093401	1	0	0	1	0	1	0
1759	TPCODL	PARADEEP (	JED, JAGAT	33 kV BIRIDI	14093402	1	0	0	1	0	1	0
1760	TPCODL	PARADEEP (	JED, JAGAT	11 kV CHHAPA	14169201	145	118	0	27	0	27	0
1761	TPCODL	PARADEEP (	JED, JAGAT	11 kV ALIPINGA	14169202	77	54	0	23	0	23	0
1762	TPCODL	PARADEEP (	JED, JAGAT	11 kV TOWN	14169203	83	40	0	43	0	43	0
1763	TPCODL	PARADEEP (	JED, JAGAT	11 kV PUNAGN	14169204	95	52	0	43	0	41	2
1764	TPCODL	PARADEEP (	JED, JAGAT	11 kV MEDICAL	14169205	8	6	0	2	0	2	0
1765	TPCODL	PARADEEP (	JED, JAGAT	11 kV RAGHUN	14170201	50	41	0	9	0	9	0
1766	TPCODL	PARADEEP (	JED, JAGAT	11 kV KUNTAH	14170202	73	58	0	15	0	15	0
1767	TPCODL	PARADEEP (	JED, JAGAT	11 kV TARAPUI	14170203	101	86	0	15	0	15	0
1768	TPCODL	PARADEEP (	JED, JAGAT	11 kV RAILWAY	14170204	10	10	0	0	0	0	0
1769	TPCODL	PARADEEP (	JED, JAGAT	11 kV PRAHARA	14170205	76	66	0	10	0	10	0
1770	TPCODL	PARADEEP (	JED, JAGAT	11 kV BALIA	14171201	32	25	0	7	0	7	0
1771	TPCODL	PARADEEP (	JED, JAGAT	11 kV 22 MOUZ	14171202	15	11	0	4	0	4	0
1772	TPCODL	PARADEEP (	JED, JAGAT	11 kV RANI PAI	14171203	75	59	0	16	0	15	1
1773	TPCODL	PARADEEP (	JED, JAGAT	11 kV ODISSO	14172201	113	89	0	24	0	24	0
1774	TPCODL	PARADEEP (	JED, JAGAT	11 kV DHIASAH	14172202	108	82	0	26	0	26	0
1775	TPCODL	PARADEEP (	JED, JAGAT	11 kV AMBASA	14173201	33	29	0	4	0	4	0
1776	TPCODL	PARADEEP (	JED, JAGAT	11 kV MACHHA	14173202	132	120	0	12	0	12	0
1777	TPCODL	PARADEEP (	JED, JAGAT	11 kV SOVA	14173204	18	14	0	4	0	4	0
1778	TPCODL	PARADEEP (	JED, JAGAT	11 kV OSKANA	14173205	38	31	0	7	0	6	1
1779	TPCODL	PARADEEP (	JED, JAGAT	33 kV DUSBATI	14173401	1	1	0	0	0	0	0
1780	TPCODL	PARADEEP (	JED, JAGAT	33 kV DUVALO	14173402	1	1	0	0	0	0	0
1781	TPCODL	PARADEEP (	JED, JAGAT	11 kV DENGAP	14174201	107	94	0	13	0	13	0
1782	TPCODL	PARADEEP (	JED, JAGAT	11 kV SANGRA	14174202	84	72	0	12	0	12	0
1783	TPCODL	PARADEEP (	JED, JAGAT	11 kV BALIKUD	14174203	25	17	0	8	0	8	0
1784	TPCODL	PARADEEP (	JED, JAGAT	11 kV BORIKIN	14174204	141	130	0	11	0	11	0
1785	TPCODL	PARADEEP (	JED, JAGAT	11 kV NAGAPU	14174205	91	67	0	24	0	24	0
1786	TPCODL	PARADEEP (	JED, JAGAT	11 kV RWSS /P	14174206	20	19	0	1	0	1	0
1787	TPCODL	PARADEEP (	JED, JAGAT	33 kV SOBHA	14174401	3	3	0	0	0	0	0
1788	TPCODL	PARADEEP (	JED, JAGAT	11 kV KOTAKAI	14176201	52	43	0	9	0	9	0
1789	TPCODL	PARADEEP (	JED, JAGAT	11 kV PANCHA	14178204	2	2	0	0	0	0	0
1790	TPCODL	PARADEEP (	JED, JAGAT	11 kV TARIKUN	14181201	106	92	0	14	0	13	1
1791	TPCODL	PARADEEP (	JED, JAGAT	11 kV MANDAS	14181202	149	129	0	20	0	20	0
1792	TPCODL	PARADEEP (	JED, JAGAT	33 kV 22 MOUZ	14181401	2	0	0	2	0	2	0
1793	TPCODL	PARADEEP (	JED, JAGAT	11 kV BAGALPU	14193201	102	91	0	11	0	11	0
1794	TPCODL	PARADEEP (	JED, JAGAT	11 kV PARBATI	14193202	76	64	0	12	0	12	0
1795	TPCODL	PARADEEP (	JED, JAGAT	11 kV ROHIA	14194201	52	47	0	5	0	5	0

Sl No.	Zone name	Circle name	Division name	Feeder name	Feeder ID	Total no of DT on feeder	No of unmetered DTC	No of metered DTC			No of DT's with functional meters	
								AMR metered (communicable)	AMI metered (Communicable)	No AMR/AMI metered (non communicable)	Communicating (Total no out 0f 07 & 08)	Non-Communicating (Total no out 0f 07 & 08 & 09)
0	1	2	3	4	12	5=(6+7+8+9)	6	7	8	9	10	11
1796	TPCODL	PARADEEP (	JED, JAGAT	11 kV CHANDP	14194202	22	17	0	5	0	5	0
1797	TPCODL	PARADEEP (	JED, JAGAT	11 kV SIKHARA	14194203	17	13	0	4	0	4	0
1798	TPCODL	PARADEEP (	JED, JAGAT	11 kV NAUGAC	14194204	41	35	0	6	0	6	0
1799	TPCODL	PARADEEP (	JED, JAGAT	11 kV PITEIPUF	14195201	67	57	0	10	0	10	0
1800	TPCODL	PARADEEP (	JED, JAGAT	11 kV NALIBAR	14195202	80	72	0	8	0	8	0
1801	TPCODL	PARADEEP (	JED, JAGAT	11 kV ICHHAPU	14195203	82	76	0	6	0	6	0
1802	TPCODL	PARADEEP (	JED, JAGAT	33 kV CHIKINIA	14195401	1	1	0	0	0	0	0
1803	TPCODL	PARADEEP (	JED, JAGAT	33 kV NAUAPA	14195402	1	1	0	0	0	0	0
1804	TPCODL	PARADEEP (	JED, JAGAT	11 kV SITHAL	14218201	21	17	0	4	0	4	0
1805	TPCODL	PARADEEP (	JED, JAGAT	11 kV ALIPINGA	14218202	79	60	0	19	0	19	0
1806	TPCODL	PARADEEP (	JED, JAGAT	11 kV DIHASAH	14340202	1	1	0	0	0	0	0
1807	TPCODL	PARADEEP (	JED, JAGAT	11 kV KANAKPI	14341201	16	15	0	1	0	1	0
1808	TPCODL	PARADEEP (	JED, JAGAT	11 kV DERIKI	14357201	15	12	0	3	0	3	0
1809	TPCODL	PARADEEP (	JED, JAGAT	11 kV SALAJAN	14357202	48	43	0	5	0	5	0
1810	TPCODL	PARADEEP (	JED, JAGAT	11 kV TIRUNA	14357203	30	27	0	3	0	3	0
1811	TPCODL	PARADEEP (	JED, JAGAT	11 kV MUTUNI	14357204	27	21	0	6	0	6	0
1812	TPCODL	PARADEEP (	JED, JAGAT	11 kV BORIKIN/	14358201	87	78	0	9	0	9	0
1813	TPCODL	PARADEEP (	JED, JAGAT	11 kV TITIRA	14358203	50	41	0	9	0	9	0
1814	TPCODL	PARADEEP (	JED, JAGAT	11 kV SIBAPUR	14359201	10	8	0	2	0	2	0
1815	TPCODL	PARADEEP (	JED, JAGAT	11 kV ADHANG	14359202	46	40	0	6	0	6	0
1816	TPCODL	PARADEEP (	JED, JAGAT	11 kV JAYSOL	14359203	33	25	0	8	0	8	0
1817	TPCODL	PARADEEP (	JED, JAGAT	11 kV BALIA	14359204	39	31	0	8	0	8	0
1818	TPCODL	PARADEEP (	JED, JAGAT	11 kV DEVIDOL	14360201	61	51	0	10	0	10	0
1819	TPCODL	PARADEEP (	JED, JAGAT	11 kV KHAIRA	14360202	82	65	0	17	0	17	0
1820	TPCODL	PARADEEP (	JED, JAGAT	11 kV MUNDAI	14360203	3	3	0	0	0	0	0
1821	TPCODL	PARADEEP (	JED, JAGAT	11 kV NAHARA	14361201	42	33	0	9	0	9	0
1822	TPCODL	PARADEEP (	JED, JAGAT	11 kV BANDAR	14361202	48	40	0	8	0	8	0
1823	TPCODL	PARADEEP (	JED, JAGAT	11 kV Tentulibe	14361203	51	48	0	3	0	3	0
1824	TPCODL	PARADEEP (	JED, JAGAT	11 kV Badabag	14362201	10	5	0	5	0	5	0
1825	TPCODL	PARADEEP (	JED, JAGAT	11 kV MANGAL	14362202	57	46	0	11	0	11	0
1826	TPCODL	PARADEEP (	JED, JAGAT	11 kV JANKOTH	14362203	58	41	0	17	0	17	0
1827	TPCODL	PARADEEP (	JED, JAGAT	11 kV TARAPUI	14363201	75	66	0	9	0	9	0
1828	TPCODL	PARADEEP (	JED, JAGAT	11 kV REDHUA	14363202	42	36	0	6	0	6	0
1829	TPCODL	PARADEEP (	JED, JAGAT	33 kV JAGATSIN	17037401	2	0	0	2	0	2	0
1830	TPCODL	PARADEEP (	JED, JAGAT	33 kV TIRTOL	17037402	1	1	0	0	0	0	0
1831	TPCODL	PARADEEP (	JED, JAGAT	33 kV NABAPA	17037403	1	1	0	0	0	0	0
1832	TPCODL	PARADEEP (	JED, JAGAT	33 kV BALIKUD	17037404	2	1	0	1	0	1	0
1833	TPCODL	PARADEEP (	JED, JAGAT	33 kV NAUGAC	17037405	4	4	0	0	0	0	0
1834	TPCODL	PARADEEP (	JED, JAGAT	33 kV MARKAN	17037406	1	1	0	0	0	0	0
1835	TPCODL	PARADEEP (	PDP, PARA	11 kV ERASAM	1417803	1	1	0	0	0	0	0
1836	TPCODL	PARADEEP (	PDP, PARA	11 kV KOLAR (F	1419601	1	1	0	0	0	0	0
1837	TPCODL	PARADEEP (	PDP, PARA	11 kV GARADA	14168201	32	24	0	8	0	8	0
1838	TPCODL	PARADEEP (	PDP, PARA	11 kV GARADA	14168202	1	0	0	1	0	1	0
1839	TPCODL	PARADEEP (	PDP, PARA	11 kV DENGAP	14174201	1	1	0	0	0	0	0
1840	TPCODL	PARADEEP (	PDP, PARA	11 kV INDUSTR	14175201	38	29	0	9	0	8	1
1841	TPCODL	PARADEEP (	PDP, PARA	11 kV PARADEI	14175202	68	51	0	17	0	16	1
1842	TPCODL	PARADEEP (	PDP, PARA	11 kV PLASTIC	14175203	94	74	0	20	0	20	0
1843	TPCODL	PARADEEP (	PDP, PARA	11 kV RANGIAC	14175204	58	41	0	17	0	17	0
1844	TPCODL	PARADEEP (	PDP, PARA	11 kV CHOMUI	14175205	53	39	0	14	0	14	0
1845	TPCODL	PARADEEP (	PDP, PARA	33 kV GOA CAF	14175402	1	1	0	0	0	0	0
1846	TPCODL	PARADEEP (	PDP, PARA	11 kV KOTAKAI	14176201	55	48	0	7	0	7	0
1847	TPCODL	PARADEEP (	PDP, PARA	11 kV KANAKPI	14176202	30	27	0	3	0	3	0
1848	TPCODL	PARADEEP (	PDP, PARA	11 kV TARTOL	14176203	11	11	0	0	0	0	0
1849	TPCODL	PARADEEP (	PDP, PARA	11 kV TIRTOL B	14176204	58	42	0	16	0	16	0
1850	TPCODL	PARADEEP (	PDP, PARA	33 kV KANAKPI	14176401	1	1	0	0	0	0	0
1851	TPCODL	PARADEEP (	PDP, PARA	33 kV PURANA	14176404	2	2	0	0	0	0	0
1852	TPCODL	PARADEEP (	PDP, PARA	11 kV RAHAMA	14177201	85	70	0	15	0	15	0
1853	TPCODL	PARADEEP (	PDP, PARA	11 kV PANKAPA	14177202	77	52	0	25	0	25	0

Sl No.	Zone name	Circle name	Division name	Feeder name	Feeder ID	Total no of DT on feeder	No of unmetered DTC	No of metered DTC			No of DT's with functional meters	
								AMR metered (communicable)	AMI metered (Communicable)	No AMR/AMI metered (non communicable)	Communicating (Total no out 0f 07 & 08)	Non-Communicating (Total no out 0f 07 & 08 & 09)
0	1	2	3	4	12	5=(6+7+8+9)	6	7	8	9	10	11
1854	TPCODL	PARADEEP (	PDP, PARA	11 kV BEHEDA	14177203	50	40	0	10	0	10	0
1855	TPCODL	PARADEEP (	PDP, PARA	11 kV MEDICAI	14177204	21	16	0	5	0	5	0
1856	TPCODL	PARADEEP (	PDP, PARA	33 kV RAHAMA	14177401	1	1	0	0	0	0	0
1857	TPCODL	PARADEEP (	PDP, PARA	11 kV AMBIKI	14178201	28	27	0	1	0	1	0
1858	TPCODL	PARADEEP (	PDP, PARA	11 kV ERASAM	14178203	60	51	0	9	0	9	0
1859	TPCODL	PARADEEP (	PDP, PARA	11 kV PANCHA	14178204	68	65	0	3	0	3	0
1860	TPCODL	PARADEEP (	PDP, PARA	11 kV KOTHI	14178207	38	31	0	7	0	7	0
1861	TPCODL	PARADEEP (	PDP, PARA	11 kV JAPA	14178208	158	150	0	8	0	8	0
1862	TPCODL	PARADEEP (	PDP, PARA	33 kV GADA BI	14178401	1	1	0	0	0	0	0
1863	TPCODL	PARADEEP (	PDP, PARA	11 kV TALADAI	14179201	69	49	0	20	0	20	0
1864	TPCODL	PARADEEP (	PDP, PARA	11 kV SANTARA	14179202	130	102	0	28	0	28	0
1865	TPCODL	PARADEEP (	PDP, PARA	11 kV CHATUA	14179203	240	218	0	22	0	22	0
1866	TPCODL	PARADEEP (	PDP, PARA	11 kV KUJANGA	14179204	38	31	0	7	0	6	1
1867	TPCODL	PARADEEP (	PDP, PARA	11 kV PARUNA	14196202	46	43	0	3	0	3	0
1868	TPCODL	PARADEEP (	PDP, PARA	11 kV POSAL	14196203	172	144	0	28	0	28	0
1869	TPCODL	PARADEEP (	PDP, PARA	33 kV KRISHNA	14196402	1	1	0	0	0	0	0
1870	TPCODL	PARADEEP (	PDP, PARA	11 kV ATHARBA	14226201	80	56	0	24	0	23	1
1871	TPCODL	PARADEEP (	PDP, PARA	11 kV HANDIA	14226202	78	64	0	14	0	14	0
1872	TPCODL	PARADEEP (	PDP, PARA	11 kV BIJAYCHA	14226203	30	26	0	4	0	4	0
1873	TPCODL	PARADEEP (	PDP, PARA	11 kV JAGANNA	14340201	57	44	0	13	0	13	0
1874	TPCODL	PARADEEP (	PDP, PARA	11 kV DIHASAH	14340202	134	130	0	4	0	4	0
1875	TPCODL	PARADEEP (	PDP, PARA	11 kV TULANGA	14340203	36	30	0	6	0	6	0
1876	TPCODL	PARADEEP (	PDP, PARA	11 kV KANAKPU	14341201	86	77	0	9	0	9	0
1877	TPCODL	PARADEEP (	PDP, PARA	11 kV GOVINDA	14341202	92	79	0	13	0	13	0
1878	TPCODL	PARADEEP (	PDP, PARA	11 kV MULISIN	14341203	76	64	0	12	0	12	0
1879	TPCODL	PARADEEP (	PDP, PARA	11 kV SARALA I	14341204	5	5	0	0	0	0	0
1880	TPCODL	PARADEEP (	PDP, PARA	11 kV DHINKIA	14342201	105	96	0	9	0	8	1
1881	TPCODL	PARADEEP (	PDP, PARA	11 kV TRILOCH	14342202	10	10	0	0	0	0	0
1882	TPCODL	PARADEEP (	PDP, PARA	11 kV SANDHA	14342203	22	16	0	6	0	6	0
1883	TPCODL	PARADEEP (	PDP, PARA	11 kV BALITUT	14342204	35	28	0	7	0	7	0
1884	TPCODL	PARADEEP (	PDP, PARA	11 kV PADMAP	14343201	122	120	0	2	0	2	0
1885	TPCODL	PARADEEP (	PDP, PARA	11 kV GODA	14343202	69	66	0	3	0	3	0
1886	TPCODL	PARADEEP (	PDP, PARA	11 kV AMBIKI-2	14343203	62	60	0	2	0	2	0
1887	TPCODL	PARADEEP (	PDP, PARA	11 kV PANDUA	14344201	60	52	0	8	0	8	0
1888	TPCODL	PARADEEP (	PDP, PARA	11 kV BAILO	14344202	41	37	0	4	0	4	0
1889	TPCODL	PARADEEP (	PDP, PARA	11 kV NUAPOK	14344203	65	49	0	16	0	16	0
1890	TPCODL	PARADEEP (	PDP, PARA	33 kV RAHAMA	14344404	1	1	0	0	0	0	0
1891	TPCODL	PARADEEP (	PDP, PARA	11 kV KRISHNA	14345201	67	40	0	27	0	26	1
1892	TPCODL	PARADEEP (	PDP, PARA	11 kV PAIKAKU	14345202	34	26	0	8	0	8	0
1893	TPCODL	PARADEEP (	PDP, PARA	11 kV DIGABAR	14345203	49	44	0	5	0	4	1
1894	TPCODL	PARADEEP (	PDP, PARA	11 kV MANAPU	14345204	45	38	0	7	0	7	0
1895	TPCODL	PARADEEP (	PDP, PARA	11 kV JHIMANI	14346201	2	1	0	1	0	1	0
1896	TPCODL	PARADEEP (	PDP, PARA	11 kV BAGADIA	14346202	11	8	0	3	0	3	0
1897	TPCODL	PARADEEP (	PDP, PARA	11 kV KOTHI	14346203	33	26	0	7	0	7	0
1898	TPCODL	PARADEEP (	PDP, PARA	33 kV TRILOCH	14346402	1	1	0	0	0	0	0
1899	TPCODL	PARADEEP (	PDP, PARA	11 kV BORIKIN/	14358201	2	2	0	0	0	0	0
1900	TPCODL	PARADEEP (	PDP, PARA	11 kV TITIRA	14358203	2	2	0	0	0	0	0
1901	TPCODL	PARADEEP (	PDP, PARA	11 kV Tentulibe	14361203	3	3	0	0	0	0	0
1902	TPCODL	PARADEEP (	PDP, PARA	33 kV INDUSTR	17036401	1	1	0	0	0	0	0
1903	TPCODL	PARADEEP (	PDP, PARA	33 kV TIRTOL	17036402	1	1	0	0	0	0	0
1904	TPCODL	PARADEEP (	PDP, PARA	33 kV HPCL	17036405	7	7	0	0	0	0	0
1905	TPCODL	PARADEEP (	PDP, PARA	33 kV BIJAYACH	17036406	1	1	0	0	0	0	0
1906	TPCODL	PARADEEP (	PDP, PARA	33 kV JHIMANI	17036407	1	1	0	0	0	0	0
1907	TPCODL	PARADEEP (	PDP, PARA	33 kV GORADA	17046402	1	1	0	0	0	0	0
1908	TPCODL	PARADEEP (	PDP, PARA	33 kV JAGANNA	17046403	1	1	0	0	0	0	0
1909	TPCODL	PARADEEP (	PDP, PARA	220/132/33 KV	17036STN0	1	0	0	1	0	1	0

Details of DT-wise losses (please add more rows as per requirement)

Sl. No.	Zone Name	Circle name	Division name	Name of the Sub-division	Name of the Sub-station	Substation Code	Name of the 11 kV Feeder	Feeder Code	Name of the Location where DT situated	DT code	DT Capacity (kVA)	Predominant consumer type of DT (Domestic/Industrial/Agriculture/Mixed)	Type of metering AMR/AMI/ Communicable/Conventional metered/Unmetered	Status of Meter-whether Functional (Yes/No)	% of data received automatically (if AMR/AMI)	No. of Connected Consumers	Input Energy (MU) (A)	Billed Energy (MU) (B)	Loss (MU) (A-B)	% DT Loss (A-B)/A
1	TPCODL	BBSR1	BCDD-1	SDO 1	DELTA	14221	11 kV FIRE STATION	14221203	ADITYA PALACE FRONT	1111DT036	100	MIXED	AMI	Yes	0%	22	0.06576556	0.041683	0.02408256	36.62%
2	TPCODL	BBSR1	BCDD-1	SDO 1	UNIT-8	14011	11 kV GB NAGAR	14011203	NEAR 2RA QTR(MANGALA MANDIR)(	1111DT048	100	MIXED	AMI	Yes	100%	84	0.06868772	0.054759	0.01392872	20.28%
3	TPCODL	BBSR1	BCDD-1	SDO 1	DELTA	14221	11 kV Shatabdinagar	14221202	TRINATH KRUSHI VIHAR	1112DT002	250	MIXED	AMI	Yes	100%	65	0.07035956	0.03639	0.03396956	48.28%
4	TPCODL	BBSR1	BCDD-1	SDO 1	DELTA	14221	11 kV Shatabdinagar	14221202	BOYS HIGH SCHOOL	1112DT007	500	MIXED	AMI	Yes	100%	6	0.08448872	0.019035	0.06545372	77.47%
5	TPCODL	BBSR1	BCDD-1	SDO 1	UNIT-8	14011	11 kV OUAT	14011201	LAXMIPADIA	1114DT019	200	MIXED	AMI	Yes	0%	97	0.14334532	0.098939	0.04440632	30.98%
6	TPCODL	BBSR1	BCDD-1	SDO 1	UNIT-8	14011	11 kV OUAT	14011201	PRIVATE PLOT-1	1114DT024	500	MIXED	AMI	Yes	67%	98	0.14694248	0.122191	0.02475148	16.84%
7	TPCODL	BBSR1	BCDD-1	SDO 1	UNIT-8	14011	11 kV OUAT	14011201	AMBEDKAR ENCLAVE	1114DT029	250	MIXED	AMI	Yes	100%	36	0.0493342	0.036051	0.0132832	26.92%
8	TPCODL	BBSR1	BCDD-1	SDO 1	AIR PORT	14215	11 kV JP RMU-F34	14215204	SWEETY COMPLEX-1	1114DT061	500	MIXED	AMI	Yes	0%	121	0.19803808	0.144383	0.05365508	27.09%
9	TPCODL	BBSR1	BCDD-1	SDO 1	UNIT-8	14011	11 kV OERC	14011209	AKHANBALMANI	1115DT076	250	MIXED	AMI	Yes	0%	127	0.22286716	0.168912	0.05395516	24.21%
10	TPCODL	BBSR1	BCDD-1	SDO 1	DELTA	14221	11 kV UNIT8	14221204	SALINI KHEMKA	1115DT169	100	MIXED	AMI	Yes	0%	9	0.00857868	0.008542	3.668E-05	0.43%
11	TPCODL	BBSR1	BCDD-1	SDO 1	UNIT-8	14011	11 KV BM RMU 15	14011213	SE CSS-02	1114DT120	630	MIXED	AMI	Yes	100%	80	0.1367735	0.038634	0.0981395	71.75%
12	TPCODL	BBSR1	BCDD-1	SDO 1	UNIT-8	14011	11 KV BM RMU 15	14011213	SBI OFFICE	1114DT125	250	MIXED	AMI	Yes	100%	41	0.10836992	0.09665	0.01171992	10.81%
13	TPCODL	BBSR1	BCDD-1	SDO 1	AIR PORT	14215	RMU-1 Ganganagar	14215203	ANGANBADI	1114DT037	500	MIXED	AMI	Yes	100%	138	0.31487064	0.229382	0.08548864	27.15%
14	TPCODL	BBSR1	BCDD-1	SDO 1	AIR PORT	14215	RMU-1 Ganganagar	14215203	SM CSS-11	1114DT071	630	MIXED	AMI	Yes	100%	17	0.08602626	0.079853	0.00617326	7.18%
15	TPCODL	BBSR1	BCDD-1	SDO 1	AIR PORT	14215	11 KV JP RMU-F34	14215204	PWD COLONY-CAPEX	1112DT149	100	MIXED	AMI	Yes	100%	59	0.04406413	0.028494	0.01557013	35.34%
16	TPCODL	BBSR1	BCDD-1	SDO 1	AIR PORT	14215	11 KV JP RMU-F34	14215204	BEALNO OF STATISTICS	1112DT152	250	MIXED	AMI	Yes	100%	101	0.14284276	0.051453	0.09138976	63.98%
17	TPCODL	BBSR1	BCDD-1	SDO 1	AIR PORT	14215	11 KV JP RMU-F34	14215204	FARNITUNE(I)	1112DT154	100	MIXED	AMI	Yes	0%	104	0.10777376	0.083025	0.02474876	22.96%
18	TPCODL	BBSR1	BCDD-1	SDO 1	AIR PORT	14215	11 KV JP RMU-F34	14215204	BHABANI ASHOKA	1112DT158	100	MIXED	AMI	Yes	100%	21	0.04222804	0.024968	0.01726004	40.87%
19	TPCODL	BBSR1	BCDD-1	SDO 1	AIR PORT	14215	11 KV JP RMU-F34	14215204	PARK TOWER	1114DT045	250	MIXED	AMI	Yes	0%	44	0.07484172	0.037571	0.03727072	49.80%
20	TPCODL	BBSR1	BCDD-1	SDO 1	AIR PORT	14215	11 KV JP RMU-F34	14215204	JHARANA RAPDRP	1114DT048	100	MIXED	AMI	Yes	100%	43	0.09894704	0.084072	0.01487504	15.03%
21	TPCODL	BBSR1	BCDD-1	SDO 1	AIR PORT	14215	11 KV JP RMU-F34	14215204	JEEMUTA	1114DT060	100	MIXED	AMI	Yes	0%	13	0.01404182	0.009199	0.00484282	34.49%
22	TPCODL	BBSR1	BCDD-1	SDO 1	AIR PORT	14215	11 KV JP RMU-F34	14215204	SWEETY COMPLEX-2	1114DT062	250	MIXED	AMI	Yes	100%	50	0.0830986	0.060865	0.0222336	26.76%
23	TPCODL	BBSR1	BCDD-1	SDO 1	AIR PORT	14215	11 KV JP RMU-F34	14215204	PRAMOD	1114DT064	250	MIXED	AMI	Yes	100%	148	0.28451096	0.184927	0.09958396	35.00%
24	TPCODL	BBSR1	BCDD-1	SDO 1	AIR PORT	14215	11 KV JP RMU-F34	14215204	GUNA	1114DT065	250	MIXED	AMI	Yes	100%	161	0.2118688	0.144993	0.0668758	31.56%
25	TPCODL	BBSR1	BCDD-1	SDO 1	AIR PORT	14215	11 KV JP RMU-F34	14215204	PG HOSTEL NO-7	1114DT067	100	MIXED	AMI	Yes	100%	94	0.10875861	0.040975	0.06778361	62.32%
26	TPCODL	BBSR1	BCDD-1	SDO 1	AIR PORT	14215	11 KV JP RMU-F34	14215204	2R	1114DT069	250	MIXED	AMI	Yes	100%	174	0.24154964	0.178294	0.06325564	26.19%
27	TPCODL	BBSR1	BCDD-1	SDO 1	AIR PORT	14215	11 KV JP RMU-F34	14215204	2R	1114DT070	100	MIXED	AMI	Yes	0%	74	0.12859124	0.057274	0.07131724	55.46%
28	TPCODL	BBSR1	BCDD-1	SDO 1	AIR PORT	14215	11 KV RMU-1	14215206	BHORA COMPLEX	1114DT036	250	MIXED	AMI	Yes	100%	27	0.07006412	0.058436	0.01162812	16.60%
29	TPCODL	BBSR1	BCDD-1	SDO 1	AIR PORT	14215	11 KV RMU-1	14215206	BHIMPUR	1114DT040	500	MIXED	AMI	Yes	100%	111	0.37031744	0.16323	0.20708744	55.92%
30	TPCODL	BBSR1	BCDD-1	SDO 1	AIR PORT	14215	11 KV RMU-1	14215206	MAHADEV RESIDENCY	1114DT041	100	MIXED	AMI	Yes	100%	6	0.02515618	0.013138	0.01201818	47.77%
31	TPCODL	BBSR1	BCDD-1	SDO 1	AIR PORT	14215	11 KV RMU-1	14215206	CHITTA MOHANTY GALLI	1114DT043	250	MIXED	AMI	Yes	100%	75	0.17405436	0.169266	0.00478836	2.75%
32	TPCODL	BBSR1	BCDD-1	SDO 1	BARAMUNDA	14005	11 KV BARAMUNDA DEL	14005203	NABARD-I	1112DT077	250	MIXED	AMI	Yes	67%	79	0.19968256	0.080521	0.11916156	59.68%
33	TPCODL	BBSR1	BCDD-1	SDO 1	BARAMUNDA	14005	11 KV BARAMUNDA DEL	14005203	NABARD-II	1112DT078	250	MIXED	AMI	Yes	100%	202	0.23878204	0.229239	0.00954304	4.00%
34	TPCODL	BBSR1	BCDD-1	SDO 1	BARAMUNDA	14005	11 KV BARAMUNDA DEL	14005203	JAGANNATH-I	1112DT081	500	MIXED	AMI	Yes	0%	270	0.55638096	0.348044	0.20833696	37.45%
35	TPCODL	BBSR1	BCDD-1	SDO 1	BARAMUNDA	14005	11 KV BARAMUNDA DEL	14005203	JAGANNATH-II	1112DT082	500	MIXED	AMI	Yes	100%	315	0.46944816	0.384533	0.08491516	18.09%
36	TPCODL	BBSR1	BCDD-1	SDO 1	BARAMUNDA	14005	11 KV BARAMUNDA DEL	14005203	HADISAHI-I	1112DT085	250	MIXED	AMI	Yes	67%	183	0.20142904	0.18583	0.01559904	7.74%
37	TPCODL	BBSR1	BCDD-1	SDO 1	BARAMUNDA	14005	11 KV BARAMUNDA DEL	14005203	HADISAHI-II	1112DT086	100	MIXED	AMI	Yes	100%	53	0.12335582	0.062573	0.06078282	49.27%
38	TPCODL	BBSR1	BCDD-1	SDO 1	BARAMUNDA	14005	11 KV BARAMUNDA DEL	14005203	DALI MILL(I)	1112DT089	500	MIXED	AMI	Yes	100%	197	0.33875936	0.242249	0.09651036	28.49%
39	TPCODL	BBSR1	BCDD-1	SDO 1	BARAMUNDA	14005	11 KV BARAMUNDA DEL	14005203	GHUSUNI GUHALA	1112DT167	250	MIXED	AMI	Yes	0%	35	0.08121844	0.028858	0.05236044	64.47%
40	TPCODL	BBSR1	BCDD-1	SDO 1	DELTA	14221	11 KV SIRIPUR	14221201	BRIT OFFICE	1111DT071	500	MIXED	AMI	Yes	67%	224	0.19089692	0.171689	0.01920792	10.06%
41	TPCODL	BBSR1	BCDD-1	SDO 1	DELTA	14221	11 KV SIRIPUR	14221201	NEAR HUNUMAN TEMPIL	1111DT072	100	MIXED	AMI	Yes	100%	55	0.0547117	0.042152	0.0125597	22.96%
42	TPCODL	BBSR1	BCDD-1	SDO 1	DELTA	14221	11 KV SIRIPUR	14221201	NILAPANI TANKI BASTI	1111DT076	100	MIXED	AMI	Yes	100%	106	0.07822838	0.076583	0.00164538	2.10%
43	TPCODL	BBSR1	BCDD-1	SDO 1	DELTA	14221	11 KV SIRIPUR	14221201	NILAPANI TANKI	1111DT077	500	MIXED	AMI	Yes	100%	204	0.23048432	0.142542	0.08794232	38.16%
44	TPCODL	BBSR1	BCDD-1	SDO 1	DELTA	14221	11 KV SIRIPUR	14221201	OMC MANDIR	1111DT078	250	MIXED	AMI	Yes	100%	57	0.08712724	0.0331	0.05402724	62.01%
45	TPCODL	BBSR1	BCDD-1	SDO 1	DELTA	14221	11 KV SIRIPUR	14221201	PPT COLONY	1111DT080	100	MIXED	AMI	Yes	100%	78	0.06892326	0.062991	0.00593226	8.61%
46	TPCODL	BBSR1	BCDD-1	SDO 1	DELTA	14221	11 KV SIRIPUR	14221201	F TYPE	1111DT086	250	MIXED	AMI	Yes	100%	111	0.07640412	0.058567	0.01783712	23.35%
47	TPCODL	BBSR1	BCDD-1	SDO 1	DELTA	14221	11 KV SIRIPUR	14221201	OCC COLONY (100KVA)	1111DT087	100	MIXED	AMI	Yes	100%	102	0.06000242	0.044208	0.01579442	26.32%
48	TPCODL	BBSR1	BCDD-1	SDO 1	DELTA	14221	11 KV SIRIPUR	14221201	BRIT COLONY	1115DT093	500	MIXED	AMI	Yes	100%	292	0.3308528	0.314071	0.0167818	5.07%
49	TPCODL	BBSR1	BCDD-1	SDO 1	DELTA	14221	11 KV SIRIPUR	14221201	CAPEX BRIT COLONY	1115DT094	250	MIXED	AMI	Yes	100%	98	0.1307266	0.093462	0.0372646	28.51%
50	TPCODL	BBSR1	BCDD-1	SDO 1	DELTA	14221	11 KV SIRIPUR	14221201	SIVA MOHAPATRA	1115DT095	500	MIXED	AMI	Yes	100%	162	0.28818664	0.194087	0.09409964	32.65%
51	TPCODL	BBSR1	BCDD-1	SDO 1	DELTA	14221	11 KV SIRIPUR	14221201	BHAGABAT VILLA	1115DT096	250	MIXED	AMI	Yes	100%	23	0.04352842	0.033577	0.00995142	22.86%
52	TPCODL	BBSR1	BCDD-1	SDO 1	DELTA	14221	11 KV SIRIPUR	14221201	STEWART SCHOOL	1115DT099	250	MIXED	AMI	Yes	100%	107	0.17986952	0.139349	0.04052052	22.53%
53	TPCODL	BBSR1	BCDD-1	SDO 1	DELTA	14221	11 KV Shatabdinagar	14221202	BHOLI(C TYPE)	1112DT003	100	MIXED	AMI	Yes	100%	92	0.09934516	0.070051	0.02929416	29.49%
54	TPCODL	BBSR1	BCDD-1	SDO 1	DELTA	14221	11 KV Shatabdinagar	14221202	SAMASTI RESIDENCY	1112DT011	250	MIXED	AMI	Yes	0%	78	0.19378036	0.107075	0.08670536	44.74%
55	TPCODL	BBSR1	BCDD-1	SDO 1	DELTA	14221	11 KV Shatabdinagar	14221202	MAHAVEER CLASSIC	1112DT013	250	MIXED	AMI	Yes	100%	31	0.04442072	0.040901	0.00351972	7.92%
56	TPCODL	BBSR1	BCDD-1	SDO 1	DELTA	14221	11 KV Shatabdinagar	14221202	PRASANTI VIHAR PUMP(PHD)	1112DT016	250	MIXED	AMI	Yes	100%	54	0.14658988	0.093977	0.05261288	35.89%
57	TPCODL	BBSR1	BCDD-1	SDO 1	DELTA	14221	11 KV Shatabdinagar	14221202	KUSUM VATIKA	1112DT018	250	MIXED	AMI	Yes	100%	27	0.0424408	0.040011	0.0024298	5.73%
58	TPCODL	BBSR1	BCDD-1	SDO 1	DELTA	14221	11 KV Shatabdinagar	14221202	LANE-10 S.NAGAR(CAPEX)	1112DT022	100	MIXED	AMI	Yes	100%	68	0.12497575	0.082005	0.04297075	34.38%
59	TPCODL	BBSR1	BCDD-1	SDO 1	DELTA	14221	11 KV Shatabdinagar	14221202	RATNA VILLA	1112DT023	250	MIXED	AMI	Yes	100%	31	0.12228225	0.038417	0.08386525	68.58%
60	TPCODL	BBSR1	BCDD-1	SDO 1	DELTA	14221	11 KV Shatabdinagar	14221202	FRIENDS COLONY	1112DT024	250	MIXED	AMI	Yes	100%	90	0.12558744	0.119321	0.00626644	4.99%
61	TPCODL	BBSR1	BCDD-1	SDO 1	DELTA	14221	11 KV Shatabdinagar	14221202	SBI-2	1112DT032	500	MIXED	AMI	Yes	100%	156	0.34004504	0.325483	0.01456204	4.28%
62	TPCODL	BBSR1	BCDD-1	SDO 1	DELTA	14221	11 KV Shatabdinagar	14221202	J.J.KORON(RAJPEEP APP)	1112DT034	315	MIXED	AMI	Yes	100%	32	0.04407148	0.041394	0.00267748	6.08%
63	TPCODL	BBSR1	BCDD-1	SDO 1	DELTA	14221	11 KV Shatabdinagar	14221202	GHANA S/S	1112DT035	250	MIXED	AMI	Yes	100%	57	0.09039612	0.075518	0.01487812	16.46%
64	TPCODL	BBSR1	BCDD-1	SDO 1	DELTA	14221	11 KV Shatabdinagar	14221202	S.NAGAR SBI BANK	1112DT040	100	MIXED	AMI	Yes	100%	6	0.04888598	0.016159	0.03272698	66.95%
65	TPCODL	BBSR1	BCDD-1	SDO 1	DELTA	14221	11 KV Shatabdinagar	14221202	STALWART	1112DT186	500	MIXED	AMI	Yes	100%	15	0.04987768	0.012804	0.03707368	74.33%
66	TPCODL	BBSR1	BCDD-1	SDO 1	DELTA	14221	11 KV Shatabdinagar	14221202	STALWART 2	1112DT282	500	MIXED	AMI	Yes	100%	43	0.07554944	0.072899	0.00265044	3.51%
67	TPCODL	BBSR1	BCDD-1	SDO 1	DELTA	14221	11 KV FIRE STATION	14221203	GED QTRS	1111DT001	250	MIXED	AMI	Yes	100%	103	0.12582824	0.08403	0.04179824	33.22%
68	TPCODL	BBSR1	BCDD-1	SDO 1	DELTA	14221	11 KV FIRE STATION	14221203	DELTA-C COLONY	1111DT003	500	MIXED	AMI	Yes	100%	170	0.22539816	0.138551	0.08684716	38.53%
69	TPCODL	BBSR1	BCDD-1	SDO 1	DELTA	14221	11 KV FIRE STATION	14221203	SIRD SOCIETY COLONY	1111DT006	500	MIXED	AMI	Yes	100%	27	0.11399264	0.077635	0.03635764	31.89%
70	TPCODL	BBSR1	BCDD-1	SDO 1	DELTA	14221	11 KV FIRE STATION	14221203	DELTA-IB	1111DT008	250	MIXED	AMI	Yes	100%	121	0.24620452	0.15891	0.08729452	35.46%
71	TPCODL	BBSR1	BCDD-1	SDO 1	DELTA	14221	11 KV FIRE STATION	14221203	OWPO D TYPE	1111DT010	500	MIXED	AMI	Yes	100%	63	0.10882448	0.057641	0.05118348	47.03%
72	TPCODL	BBSR1	BCDD-1	SDO 1	DELTA	14221	11 KV FIRE STATION	14221203	SATTELITE COLONY	1111DT024	100	MIXED	AMI	Yes	100%	31	0.03529538	0.018057	0.01723838	48.84%

Sl. No.	Zone Name	Circle name	Division name	Name of the Sub-division	Name of the Sub-station	Substation Code	Name of the 11 kV Feeder	Feeder Code	Name of the Location where DT situated	DT code	DT Capacity (kVA)	Predominant consumer type of DT (Domestic/Industrial/Agriculture/Mixed)	Type of metering AMR/AMI/ Communicable/Conventional metered/Unmetered	Status of Meter-whether Functional (Yes/No)	% of data received automatically (if AMR/AMI)	No. of Connected Consumers	Input Energy (MU) (A)	Billed Energy (MU) (B)	Loss (MU) (A-B)	% DT Loss (A-B)/A
73	TPCODL	BBSR1	BCDD-1	SDO 1	DELTA	14221	11 KV FIRE STATION	14221203	WEST PAIKANAGAR	1111DT026	100	MIXED	AMI	Yes	100%	26	0.04609421	0.035658	0.01043621	22.64%
74	TPCODL	BBSR1	BCDD-1	SDO 1	DELTA	14221	11 KV FIRE STATION	14221203	MANIA PAIKRA	1111DT028	100	MIXED	AMI	Yes	0%	42	0.07153518	0.065869	0.00566618	7.92%
75	TPCODL	BBSR1	BCDD-1	SDO 1	DELTA	14221	11 KV FIRE STATION	14221203	RBI COLONY	1111DT029	100	MIXED	AMI	Yes	0%	49	0.06680656	0.064332	0.00247456	3.70%
76	TPCODL	BBSR1	BCDD-1	SDO 1	DELTA	14221	11 KV FIRE STATION	14221203	PAIKANAGAR CLUB	1111DT030	500	MIXED	AMI	Yes	100%	214	0.34874036	0.282075	0.06666536	19.12%
77	TPCODL	BBSR1	BCDD-1	SDO 1	DELTA	14221	11 KV FIRE STATION	14221203	PAIKANAGAR FIRST LANE	1111DT031	100	MIXED	AMI	Yes	0%	33	0.05528468	0.03951	0.01577468	28.53%
78	TPCODL	BBSR1	BCDD-1	SDO 1	DELTA	14221	11 KV FIRE STATION	14221203	ADITYA PLACE	1111DT035	250	MIXED	AMI	Yes	100%	31	0.03529134	0.023853	0.01143834	32.41%
79	TPCODL	BBSR1	BCDD-1	SDO 1	DELTA	14221	11 KV FIRE STATION	14221203	NEW POST OFFICE	1112DT044	100	MIXED	AMI	Yes	100%	49	0.06415262	0.040194	0.02395862	37.35%
80	TPCODL	BBSR1	BCDD-1	SDO 1	DELTA	14221	11 KV FIRE STATION	14221203	ATC STREET LIGHT	1112DT045	500	MIXED	AMI	Yes	100%	174	0.40353168	0.188199	0.21533268	53.36%
81	TPCODL	BBSR1	BCDD-1	SDO 1	DELTA	14221	11 KV FIRE STATION	14221203	KESHARI APARTMENT	1112DT053	250	MIXED	AMI	Yes	100%	56	0.06179032	0.044042	0.01774832	28.72%
82	TPCODL	BBSR1	BCDD-1	SDO 1	DELTA	14221	11 KV FIRE STATION	14221203	ANNAPURNA ENCLAVE	1112DT059	100	MIXED	AMI	Yes	100%	21	0.02690379	0.019607	0.00729679	27.12%
83	TPCODL	BBSR1	BCDD-1	SDO 1	DELTA	14221	11 KV FIRE STATION	14221203	FIRE STATION-2	1112DT063	100	MIXED	AMI	Yes	100%	32	0.04317166	0.035552	0.00761966	17.65%
84	TPCODL	BBSR1	BCDD-1	SDO 1	DELTA	14221	11 KV FIRE STATION	14221203	KISHORE LIFE STYLE	1112DT298	250	MIXED	AMI	Yes	100%	17	0.01986116	0.019701	0.00016016	0.81%
85	TPCODL	BBSR1	BCDD-1	SDO 1	KALINGA NAGAR	14007	11 KV K-5	14007202	K-5,NEAR BSNL	1213DT158	250	MIXED	AMI	Yes	100%	118	0.1852751	0.152787	0.0324881	17.54%
86	TPCODL	BBSR1	BCDD-1	SDO 1	NAYAPALLI	14008	11 KV IRC-3	14008203	BHOI SAHI	1115DT036	100	MIXED	AMI	Yes	33%	103	0.14967068	0.143776	0.00589468	3.94%
87	TPCODL	BBSR1	BCDD-1	SDO 1	NAYAPALLI	14008	11 KV IRC-3	14008203	OLD BHOI SAHI	1115DT049	250	MIXED	AMI	Yes	100%	104	0.20369476	0.146314	0.05738076	28.17%
88	TPCODL	BBSR1	BCDD-1	SDO 1	NAYAPALLI	14008	11 KV IRC-3	14008203	SRABANI APPT	1115DT050	100	MIXED	AMI	Yes	100%	16	0.01947152	0.012007	0.00746452	38.34%
89	TPCODL	BBSR1	BCDD-1	SDO 1	NAYAPALLI	14008	11 KV IRC-3	14008203	LIC	1115DT120	500	MIXED	AMI	Yes	100%	116	0.36141496	0.237535	0.12387996	34.28%
90	TPCODL	BBSR1	BCDD-1	SDO 1	NAYAPALLI	14008	11 KV IRC-3	14008203	JGANATH SAKUNTALA	1115DT123	100	MIXED	AMI	Yes	100%	15	0.01807832	0.012394	0.00568432	31.44%
91	TPCODL	BBSR1	BCDD-1	SDO 1	NAYAPALLI	14008	11 KV IRC-3	14008203	KRISHNA TOWERS	1115DT125	500	MIXED	AMI	Yes	100%	151	0.14647448	0.107208	0.03926648	26.81%
92	TPCODL	BBSR1	BCDD-1	SDO 1	NAYAPALLI	14008	11 KV IRC-3	14008203	SADANANDA BHAWN	1115DT129	250	MIXED	AMI	Yes	100%	94	0.20151796	0.172711	0.02880696	14.29%
93	TPCODL	BBSR1	BCDD-1	SDO 1	NAYAPALLI	14008	11 KV IRC-3	14008203	I. G.	1115DT131	250	MIXED	AMI	Yes	100%	59	0.17192304	0.112226	0.05969704	34.72%
94	TPCODL	BBSR1	BCDD-1	SDO 1	NAYAPALLI	14008	11 KV IRC-3	14008203	ARADHANA APPT	1115DT136	100	MIXED	AMI	Yes	100%	14	0.02058166	0.008884	0.01169766	56.84%
95	TPCODL	BBSR1	BCDD-1	SDO 1	NAYAPALLI	14008	11 KV IRC-3	14008203	JAGANNATHA COMPLEX	1115DT138	100	MIXED	AMI	Yes	100%	15	0.02210636	0.021761	0.00034536	1.56%
96	TPCODL	BBSR1	BCDD-1	SDO 1	NAYAPALLI	14008	11 KV IRC-3	14008203	SURAMA PADHI	1115DT139	250	MIXED	AMI	Yes	100%	131	0.186599	0.172983	0.013616	7.30%
97	TPCODL	BBSR1	BCDD-1	SDO 1	NAYAPALLI	14008	11 KV IRC-3	14008203	PARAKA DABAIL	1115DT140	100	MIXED	AMI	Yes	100%	6	0.01324326	0.01217	0.00107326	8.10%
98	TPCODL	BBSR1	BCDD-1	SDO 1	NAYAPALLI	14008	11 KV IRC-3	14008203	SATYAM HOMES	1115DT151	250	MIXED	AMI	Yes	100%	31	0.04134476	0.039877	0.00146776	3.55%
99	TPCODL	BBSR1	BCDD-1	SDO 1	NAYAPALLI	14008	11 KV IRC-3	14008203	BHABANI VILLA	1115DT153	250	MIXED	AMI	Yes	100%	14	0.01771812	0.012257	0.00546112	30.82%
100	TPCODL	BBSR1	BCDD-1	SDO 1	NAYAPALLI	14008	11 KV IRC-3	14008203	AKHANDALMANI	1115DT156	250	MIXED	AMI	Yes	100%	134	0.15677972	0.147731	0.00904872	5.77%
101	TPCODL	BBSR1	BCDD-1	SDO 1	NAYAPALLI	14008	11 KV IRC-3	14008203	METRO RESIDENCY	1115DT158	500	MIXED	AMI	Yes	100%	64	0.0939488	0.054414	0.0395348	42.08%
102	TPCODL	BBSR1	BCDD-1	SDO 1	NAYAPALLI	14008	11 KV IRC-3	14008203	SHEKHAR PALACE	1115DT161	250	MIXED	AMI	Yes	100%	21	0.02761692	0.017538	0.01007892	36.50%
103	TPCODL	BBSR1	BCDD-1	SDO 1	NAYAPALLI	14008	11 KV IRC-3	14008203	SRABANI LAKE VIEW	1115DT164	250	MIXED	AMI	Yes	100%	13	0.02036716	0.016903	0.00346416	17.01%
104	TPCODL	BBSR1	BCDD-1	SDO 1	NAYAPALLI	14008	11 KV IRC-3	14008203	LS AVENUE 1	1115DT165	500	MIXED	AMI	Yes	100%	59	0.0733304	0.063055	0.0102754	14.01%
105	TPCODL	BBSR1	BCDD-1	SDO 1	NAYAPALLI	14008	11 KV IRC-3	14008203	LS AVENUE 2.	1115DT166	250	MIXED	AMI	Yes	100%	39	0.04996508	0.038245	0.01172008	23.46%
106	TPCODL	BBSR1	BCDD-1	SDO 1	NAYAPALLI	14008	11 KV IRC-3	14008203	KABADIA-2	1115DT172	250	MIXED	AMI	Yes	100%	218	0.2825616	0.281761	0.0008006	0.28%
107	TPCODL	BBSR1	BCDD-1	SDO 1	SATYA NAGAR	14014	11 KV JP RMU14	14014205	CHANDAMA BLOCK-B	1121DT072	250	MIXED	AMI	Yes	100%	102	0.1169324	0.105531	0.0114014	9.75%
108	TPCODL	BBSR1	BCDD-1	SDO 1	UNIT-6	14012	11 KV UNIT-6	14012206	NEAR VR-87	1114DT074	100	MIXED	AMI	Yes	100%	45	0.06416704	0.055689	0.00847804	13.21%
109	TPCODL	BBSR1	BCDD-1	SDO 1	UNIT-6	14012	11 KV UNIT-6	14012206	TYPE-8	1114DT079	250	MIXED	AMI	Yes	100%	63	0.2176355	0.171256	0.0463795	21.31%
110	TPCODL	BBSR1	BCDD-1	SDO 1	UNIT-6	14012	11 KV UNIT-6	14012206	TYPE-8	1114DT080	100	MIXED	AMI	Yes	100%	52	0.07310136	0.064725	0.00837636	11.46%
111	TPCODL	BBSR1	BCDD-1	SDO 1	UNIT-6	14012	11 KV UNIT-6	14012206	NEAR IVR-11	1114DT081	100	MIXED	AMI	Yes	100%	28	0.06903276	0.063305	0.00572776	8.30%
112	TPCODL	BBSR1	BCDD-1	SDO 1	UNIT-6	14012	11 KV UNIT-6	14012206	OLD OFFICE	1114DT083	100	MIXED	AMI	Yes	100%	44	0.05407577	0.039054	0.01502177	27.78%
113	TPCODL	BBSR1	BCDD-1	SDO 1	UNIT-6	14012	11 KV UNIT-6	14012206	6R-2	1114DT090	100	MIXED	AMI	Yes	100%	31	0.07845952	0.045978	0.03248152	41.40%
114	TPCODL	BBSR1	BCDD-1	SDO 1	UNIT-6	14012	11 KV RMU-19	14012207	BM CSS-11	1114DT091	630	MIXED	AMI	Yes	100%	105	0.15195676	0.125792	0.02616476	17.22%
115	TPCODL	BBSR1	BCDD-1	SDO 1	UNIT-8	14011	11 KV OUAT	14011201	TOWER	1112DT135	100	MIXED	AMI	Yes	100%	10	0.01176686	0.01165	0.00011686	0.99%
116	TPCODL	BBSR1	BCDD-1	SDO 1	UNIT-8	14011	11 KV OUAT	14011201	DURGA MANDAP-III	1112DT143	250	MIXED	AMI	Yes	100%	147	0.17020824	0.112708	0.05750024	33.78%
117	TPCODL	BBSR1	BCDD-1	SDO 1	UNIT-8	14011	11 KV OUAT	14011201	DURGA MANDAP-I	1112DT144	500	MIXED	AMI	Yes	100%	168	0.2764324	0.23931	0.0371224	13.43%
118	TPCODL	BBSR1	BCDD-1	SDO 1	UNIT-8	14011	11 KV OUAT	14011201	JAGABANDHU	1112DT161	250	MIXED	AMI	Yes	100%	59	0.08350308	0.082174	0.00132908	1.59%
119	TPCODL	BBSR1	BCDD-1	SDO 1	UNIT-8	14011	11 KV OUAT	14011201	KUMUD TOWER	1112DT164	100	MIXED	AMI	Yes	100%	11	0.02625314	0.015292	0.01096114	41.75%
120	TPCODL	BBSR1	BCDD-1	SDO 1	UNIT-8	14011	11 KV OUAT	14011201	KALPATARU APPARTMENT	1112DT166	100	MIXED	AMI	Yes	100%	7	0.0115224	0.011428	9.44E-05	0.82%
121	TPCODL	BBSR1	BCDD-1	SDO 1	UNIT-8	14011	11 KV OUAT	14011201	BANAJA-1	1114DT017	500	MIXED	AMI	Yes	0%	67	0.07734024	0.04555	0.03179024	41.10%
122	TPCODL	BBSR1	BCDD-1	SDO 1	UNIT-8	14011	11 KV OUAT	14011201	BANAJA-2	1114DT018	500	MIXED	AMI	Yes	100%	65	0.09726168	0.058011	0.03925068	40.36%
123	TPCODL	BBSR1	BCDD-1	SDO 1	UNIT-8	14011	11 KV OUAT	14011201	PVT-PLOT-2	1114DT023	250	MIXED	AMI	Yes	100%	64	0.11929145	0.105029	0.01426245	11.96%
124	TPCODL	BBSR1	BCDD-1	SDO 1	UNIT-8	14011	11 KV OUAT	14011201	C-TYPE	1114DT031	100	MIXED	AMI	Yes	100%	11	0.0411409	0.016907	0.0242339	58.90%
125	TPCODL	BBSR1	BCDD-1	SDO 1	UNIT-8	14011	11 KV GB NAGAR	14011203	POLICE COLONY PARK	1111DT049	100	MIXED	AMI	Yes	100%	27	0.01689005	0.009058	0.00783205	46.37%
126	TPCODL	BBSR1	BCDD-1	SDO 1	UNIT-8	14011	11 KV GB NAGAR	14011203	POLICE COLONY F-TYPE	1111DT050	100	MIXED	AMI	Yes	100%	10	0.00718803	0.003047	0.00414103	57.61%
127	TPCODL	BBSR1	BCDD-1	SDO 1	UNIT-8	14011	11 KV GB NAGAR	14011203	SIRIPUR PHD	1112DT103	100	MIXED	AMI	Yes	100%	28	0.091336	0.062066	0.02927	32.05%
128	TPCODL	BBSR1	BCDD-1	SDO 1	UNIT-8	14011	11 KV GB NAGAR	14011203	OLD GOPABANDHU	1112DT109	250	MIXED	AMI	Yes	33%	263	0.23390996	0.166069	0.06784096	29.00%
129	TPCODL	BBSR1	BCDD-1	SDO 1	UNIT-8	14011	11 KV GB NAGAR	14011203	BAINSI	1112DT114	250	MIXED	AMI	Yes	100%	36	0.17658388	0.136376	0.04020788	22.77%
130	TPCODL	BBSR1	BCDD-1	SDO 1	UNIT-8	14011	11 KV GB NAGAR	14011203	SIRIPUR SABARSANI	1112DT118	250	MIXED	AMI	Yes	100%	168	0.18923104	0.138967	0.05026404	26.56%
131	TPCODL	BBSR1	BCDD-1	SDO 1	UNIT-8	14011	11 KV GB NAGAR	14011203	BAMRA MANSION	1112DT129	250	MIXED	AMI	Yes	100%	14	0.08265486	0.027878	0.05477686	66.27%
132	TPCODL	BBSR1	BCDD-1	SDO 1	UNIT-8	14011	11 KV GB NAGAR	14011203	TINAGHARA	1112DT131	250	MIXED	AMI	Yes	100%	115	0.10708958	0.103007	0.00408258	3.81%
133	TPCODL	BBSR1	BCDD-1	SDO 1	UNIT-8	14011	11 KV GB NAGAR	14011203	NEAR COLLEGE B C& H,	1112DT173	250	MIXED	AMI	Yes	100%	240	0.13050904	0.07619	0.05431904	41.62%
134	TPCODL	BBSR1	BCDD-1	SDO 1	UNIT-8	14011	11 KV GB NAGAR	14011203	G TYPE	1115DT043	250	MIXED	AMI	Yes	100%	101	0.12085128	0.046905	0.07394628	61.19%
135	TPCODL	BBSR1	BCDD-1	SDO 1	UNIT-8	14011	11 KV ASSEMBLY	14011205	WOMENS POLYTECHNIC	1115DT110	250	MIXED	AMI	Yes	100%	61	0.14883575	0.098603	0.05023275	33.75%
136	TPCODL	BBSR1	BCDD-1	SDO 1	UNIT-8	14011	11 KV CBI	14011206	KALYANI FISH MARKET	1115DT001	500	MIXED	AMI	Yes	100%	98	0.38028496	0.177645	0.20263996	53.29%
137	TPCODL	BBSR1	BCDD-1	SDO 1	UNIT-8	14011	11 KV CBI	14011206	NUASAHI	1115DT006	250	MIXED	AMI	Yes	100%	98	0.2428596	0.132109	0.1107506	45.60%
138	TPCODL	BBSR1	BCDD-1	SDO 1	UNIT-8	14011	11 KV CBI	14011206	KESHARI ENCLAVE	1115DT007	500	MIXED	AMI	Yes	100%	83	0.12623512	0.087098	0.03913712	31.00%
139	TPCODL	BBSR1	BCDD-1	SDO 1	UNIT-8	14011	11 KV CBI	14011206	NATRAJ TOWER	1115DT020	100	MIXED	AMI	Yes	100%	13	0.02984434	0.009731	0.02011334	67.39%
140	TPCODL	BBSR1	BCDD-1	SDO 1	UNIT-8	14011	11 KV CBI	14011206	CHANDRAMADHAB	1115DT023	250	MIXED	AMI	Yes	0%	145	0.26017144	0.194882	0.06528944	25.09%
141	TPCODL	BBSR1	BCDD-1	SDO 1	UNIT-8	14011	11 KV CBI	14011206	SHYAM ARCADE	1115DT024	100	MIXED	AMI	Yes	100%	9	0.0143148	0.014208	0.0001068	0.75%
142	TPCODL	BBSR1	BCDD-1	SDO 1	UNIT-8	14011	11 KV CBI	14011206	TINIKONIA	1115DT025	250	MIXED	AMI	Yes	100%	172	0.16372776	0.135744	0.02798376	17.09%
143	TPCODL	BBSR1	BCDD-1	SDO 1	UNIT-8	14011	11 KV CBI	14011206	P.ROUTRAY	1115DT027	250	MIXED	AMI	Yes	100%	54	0.16412624	0.056707	0.10741924	65.45%
144	TPCODL	BBSR1	BCDD-1	SDO 1	UNIT-8	14011	11 KV CBI	14011206	GADASAHI	1115DT028	250	MIXED	AMI	Yes	100%	175	0.18761484	0.176956	0.01065884	5.68%
145	TPCODL	BBSR1	BCDD-1	SDO 1	UNIT-8	14011	11 KV CBI	14011206	B.D.A. APARTMEENT	1115DT029	250	MIXED	AMI	Yes	100%	26	0.06178516	0.029936	0.03184916	51.55%

Sl. No.	Zone Name	Circle name	Division name	Name of the Sub-division	Name of the Sub-station	Substation Code	Name of the 11 kV Feeder	Feeder Code	Name of the Location where DT situated	DT code	DT Capacity (kVA)	Predominant consumer type of DT (Domestic/Industrial/Agriculture/Mixed)	Type of metering AMR/AMI/ Communicable/Conventional metered/Unmetered	Status of Meter-whether Functional (Yes/No)	% of data received automatically (if AMR/AMI)	No. of Connected Consumers	Input Energy (MU) (A)	Billed Energy (MU) (B)	Loss (MU) (A-B)	% DT Loss (A-B)/A
146	TPCODL	BBSR1	BCDD-1	SDO 1	UNIT-8	14011	11 KV CBI	14011206	KALVIK OMMKAR	1115DT033	100	MIXED	AMI	Yes	100%	29	0.02982646	0.025017	0.00480946	16.12%
147	TPCODL	BBSR1	BCDD-1	SDO 1	UNIT-8	14011	11 KV OERC	14011209	ICWAI	1115DT056	250	MIXED	AMI	Yes	100%	42	0.07923232	0.054791	0.02444132	30.85%
148	TPCODL	BBSR1	BCDD-1	SDO 1	UNIT-8	14011	11 KV OERC	14011209	ARYALOY	1115DT071	500	MIXED	AMI	Yes	100%	50	0.08569776	0.067416	0.01828176	21.33%
149	TPCODL	BBSR1	BCDD-1	SDO 1	UNIT-8	14011	11 KV OERC	14011209	ARYALOY 2	1115DT072	500	MIXED	AMI	Yes	100%	43	0.06174024	0.045938	0.01580224	25.59%
150	TPCODL	BBSR1	BCDD-1	SDO 1	UNIT-8	14011	11 KV OERC	14011209	ISHA-1	1115DT077	500	MIXED	AMI	Yes	100%	72	0.0889956	0.065957	0.0230386	25.89%
151	TPCODL	BBSR1	BCDD-1	SDO 1	UNIT-8	14011	11 KV OERC	14011209	ISHA-2	1115DT078	500	MIXED	AMI	Yes	0%	69	0.08779456	0.075976	0.01181856	13.46%
152	TPCODL	BBSR1	BCDD-1	SDO 1	UNIT-8	14011	11 KV OERC	14011209	GOPAL ENCLAVE	1115DT080	100	MIXED	AMI	Yes	100%	18	0.0193627	0.015937	0.0034257	17.69%
153	TPCODL	BBSR1	BCDD-1	SDO 1	UNIT-8	14011	11 KV OERC	14011209	SHASTREE NAGAR PMU	1115DT084	100	MIXED	AMI	Yes	100%	32	0.07860638	0.034321	0.04428538	56.34%
154	TPCODL	BBSR1	BCDD-1	SDO 1	UNIT-8	14011	11 KV OERC	14011209	PRATIMA TOWER	1115DT087	100	MIXED	AMI	Yes	0%	14	0.01474596	0.014662	8.396E-05	0.57%
155	TPCODL	BBSR1	BCDD-1	SDO 1	UNIT-8	14011	11 KV OERC	14011209	SASTRINAGAR-3	1124DT008	500	MIXED	AMI	Yes	0%	197	0.34785408	0.250136	0.09771808	28.09%
156	TPCODL	BBSR1	BCDD-1	SDO 1	UNIT-8	14011	11 KV DELTA	14011210	RAPDRP IDBI	1111DT040	250	MIXED	AMI	Yes	100%	164	0.16202248	0.088514	0.07350848	45.37%
157	TPCODL	BBSR1	BCDD-1	SDO 2	UNIT-3	14015	11 kV JP RMU-42	14015208	JP CSS-40	1121DT126	630	MIXED	AMI	Yes	100%	151	0.22265713	0.153606	0.06905113	31.01%
158	TPCODL	BBSR1	BCDD-1	SDO 2	UNIT-6	14012	11 kV SPRING TANK	14012204	A12 PALLASHPALLI	1122DT046	250	MIXED	AMI	Yes	100%	96	0.21008488	0.174792	0.03529288	16.80%
159	TPCODL	BBSR1	BCDD-1	SDO 2	MASTER CANTEEN (	14234	11 kV SUCHNA BHAWAN	14234201	LALIT KALA-2	1123DT054	500	MIXED	AMI	Yes	100%	47	0.0669825	0.05593	0.0110525	16.50%
160	TPCODL	BBSR1	BCDD-1	SDO 2	UNIT-6	14012	11 kV RMU-19	14012207	CSS-42	1123DT056	630	MIXED	AMI	Yes	100%	124	0.13592175	0.093056	0.04286575	31.54%
161	TPCODL	BBSR1	BCDD-1	SDO 2	UNIT-6	14012	11 kV RMU-19	14012207	C S.S-44	1123DT058	630	MIXED	AMI	Yes	100%	41	0.20789776	0.072263	0.13563476	65.24%
162	TPCODL	BBSR1	BCDD-1	SDO 2	UNIT-4	14013	11 kV RMU-22	14013206	BM-CSS-14	1124DT015	630	MIXED	AMI	Yes	0%	71	0.14371975	0.1387	0.00501975	3.49%
163	TPCODL	BBSR1	BCDD-1	SDO 2	AIR PORT	14215	11 KV RMU-1	14215206	METROLOGY COLONY	1122DT006	250	MIXED	AMI	Yes	100%	28	0.0209664	0.015638	0.0053284	25.41%
164	TPCODL	BBSR1	BCDD-1	SDO 2	MASTER CANTEEN (	14234	11 KV SUCHNA BHAWAN	14234201	SDO OFFICE	1123DT016	500	MIXED	AMI	Yes	100%	132	0.16526216	0.120846	0.04441616	26.88%
165	TPCODL	BBSR1	BCDD-1	SDO 2	MASTER CANTEEN (	14234	11 KV SUCHNA BHAWAN	14234201	CSS-41	1123DT035	630	MIXED	AMI	Yes	100%	78	0.13798776	0.096272	0.04171576	30.23%
166	TPCODL	BBSR1	BCDD-1	SDO 2	MASTER CANTEEN (	14234	11 KV ASHOK NAGAR	14234202	CSS-43	1123DT055	630	MIXED	AMI	Yes	0%	40	0.11115688	0.025303	0.08585388	77.24%
167	TPCODL	BBSR1	BCDD-1	SDO 2	MASTER CANTEEN (	14234	11 KV ASHOK NAGAR	14234202	BINODEEP APARTMENT	1123DT068	250	MIXED	AMI	Yes	0%	53	0.05265824	0.041926	0.01073224	20.38%
168	TPCODL	BBSR1	BCDD-1	SDO 2	MASTER CANTEEN (	14234	11 KV ASHOK NAGAR	14234202	ASHOK NAGAR	1123DT081	500	MIXED	AMI	Yes	100%	67	0.36466968	0.175014	0.18965568	52.01%
169	TPCODL	BBSR1	BCDD-1	SDO 2	MASTER CANTEEN (	14234	11 KV ASHOK NAGAR	14234202	AB SENAPATI	1123DT083	250	MIXED	AMI	Yes	100%	31	0.083761	0.045092	0.038669	46.17%
170	TPCODL	BBSR1	BCDD-1	SDO 2	MASTER CANTEEN (	14234	11 KV MARKET BUILDING	14234203	COOKS	1123DT001	500	MIXED	AMI	Yes	100%	152	0.23105616	0.164202	0.06685416	28.93%
171	TPCODL	BBSR1	BCDD-1	SDO 2	MASTER CANTEEN (	14234	11 KV MARKET BUILDING	14234203	KALA MANDIR-1	1123DT007	500	MIXED	AMI	Yes	100%	81	0.2299004	0.174952	0.0549484	23.90%
172	TPCODL	BBSR1	BCDD-1	SDO 2	MASTER CANTEEN (	14234	11 KV MARKET BUILDING	14234203	MUKESH MISHRA	1123DT011	250	MIXED	AMI	Yes	100%	82	0.10071452	0.091661	0.00905352	8.99%
173	TPCODL	BBSR1	BCDD-1	SDO 2	MASTER CANTEEN (	14234	11 KV MARKET BUILDING	14234203	DHOBA GHARA	1123DT013	250	MIXED	AMI	Yes	100%	35	0.16605176	0.122864	0.04318776	26.01%
174	TPCODL	BBSR1	BCDD-1	SDO 2	MASTER CANTEEN (	14234	11 KV MARKET BUILDING	14234203	AKHANDALMANI	1123DT021	100	MIXED	AMI	Yes	100%	11	0.01490094	0.005015	0.00988594	66.34%
175	TPCODL	BBSR1	BCDD-1	SDO 2	MASTER CANTEEN (	14234	11 KV JANPATH	14234204	JP CSSNEW	1123DT036	630	MIXED	AMI	Yes	100%	38	0.15616351	0.125352	0.03081151	19.73%
176	TPCODL	BBSR1	BCDD-1	SDO 2	MASTER CANTEEN (	14234	11 KV JANPATH	14234204	JANPATH TOWER	1123DT040	500	MIXED	AMI	Yes	100%	69	0.11404592	0.082354	0.03169192	27.79%
177	TPCODL	BBSR1	BCDD-1	SDO 2	MASTER CANTEEN (	14234	11 KV JANPATH	14234204	CSS-27	1123DT041	630	MIXED	AMI	Yes	100%	29	0.26101213	0.102998	0.15801413	60.54%
178	TPCODL	BBSR1	BCDD-1	SDO 2	MASTER CANTEEN (	14234	11 KV JANPATH	14234204	CSS-28	1123DT043	630	MIXED	AMI	Yes	100%	64	0.35230638	0.164988	0.18731838	53.17%
179	TPCODL	BBSR1	BCDD-1	SDO 2	MASTER CANTEEN (	14234	11 KV JANPATH	14234204	CSS-25	1123DT046	630	MIXED	AMI	Yes	33%	28	0.18202475	0.108403	0.07362175	40.45%
180	TPCODL	BBSR1	BCDD-1	SDO 2	MASTER CANTEEN (	14234	11 KV JANPATH	14234204	KASTURI ESTATE	1123DT047	500	MIXED	AMI	Yes	100%	30	0.06588048	0.038471	0.02740948	41.60%
181	TPCODL	BBSR1	BCDD-1	SDO 2	MASTER CANTEEN (	14234	11 KV JANPATH	14234204	UTTAM TOWER	1123DT051	100	MIXED	AMI	Yes	100%	4	0.0462338	0.044494	0.0017398	3.76%
182	TPCODL	BBSR1	BCDD-1	SDO 2	NAYAPALLI	14008	11 KV IRC-3	14008203	RADHARANI TOWER	1115DT127	100	MIXED	AMI	Yes	0%	22	0.02736486	0.018855	0.00850986	31.10%
183	TPCODL	BBSR1	BCDD-1	SDO 2	SATYA NAGAR	14014	11 KV JP RMU14	14014205	NEAR SRIYA	1121DT062	250	MIXED	AMI	Yes	100%	92	0.0777438	0.075114	0.0026298	3.38%
184	TPCODL	BBSR1	BCDD-1	SDO 2	SATYA NAGAR	14014	11 KV JP RMU14	14014205	CHANDRAMA BLOCK-A	1121DT071	250	MIXED	AMI	Yes	100%	79	0.10280684	0.089614	0.01319284	12.83%
185	TPCODL	BBSR1	BCDD-1	SDO 2	SATYA NAGAR	14014	11 KV JP RMU14	14014205	CHANDAMA BLOCK-C	1121DT073	250	MIXED	AMI	Yes	100%	50	0.09396644	0.031699	0.06226744	66.27%
186	TPCODL	BBSR1	BCDD-1	SDO 2	SATYA NAGAR	14014	11 KV JP RMU14	14014205	GIRIDURGA APPT	1121DT078	100	MIXED	AMI	Yes	0%	24	0.03558968	0.024897	0.01069268	30.04%
187	TPCODL	BBSR1	BCDD-1	SDO 2	SATYA NAGAR	14014	11 KV JP RMU14	14014205	JP CSS-C6	1121DT118	630	MIXED	AMI	Yes	0%	7	0.05472663	0.047062	0.00766463	14.01%
188	TPCODL	BBSR1	BCDD-1	SDO 2	TIRTOL	14176	11 KV TIRTOL BAZAR	14176204	TRITOL BAZAR 4	5433DT164	250	MIXED	AMI	Yes	100%	116	0.07302252	0.059935	0.01308752	17.92%
189	TPCODL	BBSR1	BCDD-1	SDO 2	UNIT-3	14015	11 KV UNIT-3	14015202	EXHIBITION GROUND	1121DT034	500	MIXED	AMI	Yes	100%	50	0.10198712	0.069037	0.03295012	32.31%
190	TPCODL	BBSR1	BCDD-1	SDO 2	UNIT-3	14015	11 KV UNIT-3	14015202	AGL BARAK	1121DT043	250	MIXED	AMI	Yes	100%	82	0.13279796	0.087452	0.04534596	34.15%
191	TPCODL	BBSR1	BCDD-1	SDO 2	UNIT-3	14015	11 KV UNIT-3	14015202	SPEAKER	1121DT045	100	MIXED	AMI	Yes	100%	13	0.05362672	0.041066	0.01256072	23.42%
192	TPCODL	BBSR1	BCDD-1	SDO 2	UNIT-3	14015	11 KV UNIT-3	14015202	BM CSS-09	1121DT124	630	MIXED	AMI	Yes	100%	40	0.15534313	0.080663	0.07468013	48.07%
193	TPCODL	BBSR1	BCDD-1	SDO 2	UNIT-3	14015	11 KV UNIT-2	14015203	SRI RAM MISSION	1121DT020	100	MIXED	AMI	Yes	100%	12	0.0164011	0.008701	0.0077001	46.95%
194	TPCODL	BBSR1	BCDD-1	SDO 2	UNIT-3	14015	11 KV UNIT-2	14015203	JAGANNATH COMPLEX	1121DT023	100	MIXED	AMI	Yes	100%	10	0.01121562	0.008613	0.00260262	23.21%
195	TPCODL	BBSR1	BCDD-1	SDO 2	UNIT-3	14015	11 KV UNIT-2	14015203	EXHIBITION GROUND	1121DT029	250	MIXED	AMI	Yes	100%	127	0.2005972	0.147959	0.0526382	26.24%
196	TPCODL	BBSR1	BCDD-1	SDO 2	UNIT-3	14015	11 KV UNIT-2	14015203	PLOT-52A	1121DT033	100	MIXED	AMI	Yes	100%	12	0.01642214	0.015559	0.00086314	5.26%
197	TPCODL	BBSR1	BCDD-1	SDO 2	UNIT-3	14015	11 KV MAA GIRI DURGA	14015204	PHD-I	1121DT015	250	MIXED	AMI	Yes	100%	98	0.10410922	0.101177	0.00293222	2.82%
198	TPCODL	BBSR1	BCDD-1	SDO 2	UNIT-3	14015	11 KV MAA GIRI DURGA	14015204	PHD-II	1121DT016	250	MIXED	AMI	Yes	100%	7	0.13120408	0.101627	0.02957708	22.54%
199	TPCODL	BBSR1	BCDD-1	SDO 2	UNIT-3	14015	11 kV JP RMU-42	14015208	PHD-2	1121DT090	250	MIXED	AMI	Yes	100%	48	0.1778705	0.086011	0.0918595	51.64%
200	TPCODL	BBSR1	BCDD-1	SDO 2	UNIT-3	14015	11 kV JP RMU-42	14015208	JP CSS-18	1121DT120	630	MIXED	AMI	Yes	0%	75	0.13045663	0.079787	0.05066963	38.84%
201	TPCODL	BBSR1	BCDD-1	SDO 2	UNIT-3	14015	11 kV JP RMU-42	14015208	JP CSS-22	1121DT122	630	MIXED	AMI	Yes	0%	83	0.39842838	0.28109	0.11733838	29.45%
202	TPCODL	BBSR1	BCDD-1	SDO 2	UNIT-4	14013	11 KV MS NAGAR/RMU-(	14013201	MASJID	1124DT019	100	MIXED	AMI	Yes	100%	16	0.0335431	0.033188	0.0003551	1.06%
203	TPCODL	BBSR1	BCDD-1	SDO 2	UNIT-4	14013	11 KV MS NAGAR/RMU-(	14013201	MARKET-2 A	1124DT021	250	MIXED	AMI	Yes	100%	193	0.1293952	0.080471	0.0489242	37.81%
204	TPCODL	BBSR1	BCDD-1	SDO 2	UNIT-4	14013	11 KV MS NAGAR/RMU-(	14013201	MARKET-1	1124DT023	500	MIXED	AMI	Yes	0%	310	0.20825096	0.133593	0.07465796	35.85%
205	TPCODL	BBSR1	BCDD-1	SDO 2	UNIT-4	14013	11 KV MS NAGAR/RMU-(	14013201	MLA-2	1124DT025	250	MIXED	AMI	Yes	100%	56	0.18028964	0.045614	0.13467564	74.70%
206	TPCODL	BBSR1	BCDD-1	SDO 2	UNIT-4	14013	11 KV MS NAGAR/RMU-(	14013201	UTKAL ENCLAVE	1124DT099	250	MIXED	AMI	Yes	100%	6	0.00831272	0.003876	0.00443672	53.37%
207	TPCODL	BBSR1	BCDD-1	SDO 2	UNIT-4	14013	11 KV RMU-7	14013203	PANCHADEEP (BMC MALL) -1	1124DT085	250	MIXED	AMI	Yes	100%	11	0.0600352	0.016861	0.0431742	71.91%
208	TPCODL	BBSR1	BCDD-1	SDO 2	UNIT-4	14013	11 KV RMU-23	14013204	S. JENA	1124DT001	100	MIXED	AMI	Yes	100%	7	0.02015548	0.015332	0.00482348	23.93%
209	TPCODL	BBSR1	BCDD-1	SDO 2	UNIT-4	14013	11 KV RMU-23	14013204	BM CSS-15A	1124DT004	630	MIXED	AMI	Yes	0%	298	0.52250613	0.321447	0.20105913	38.48%
210	TPCODL	BBSR1	BCDD-1	SDO 2	UNIT-4	14013	11 KV RMU-23	14013204	HARIHARA PALACE	1124DT006	250	MIXED	AMI	Yes	100%	29	0.0355374	0.02402	0.0115174	32.41%
211	TPCODL	BBSR1	BCDD-1	SDO 2	UNIT-4	14013	11 KV RMU-23	14013204	NANDAN RESIDENCY	1124DT115	100	MIXED	AMI	Yes	100%	9	0.01514544	0.015092	5.344E-05	0.35%
212	TPCODL	BBSR1	BCDD-1	SDO 2	UNIT-4	14013	11 KV RMU-23	14013204	ABPS PROPERTIES	1124DT121	100	MIXED	AMI	Yes	100%	7	0.00240122	0.002349	0.00005222	2.17%
213	TPCODL	BBSR1	BCDD-1	SDO 2	UNIT-4	14013	11 KV RMU-5	14013205	M. S NAGAR -3	1124DT051	500	MIXED	AMI	Yes	100%	154	0.31853512	0.229186	0.08934912	28.05%
214	TPCODL	BBSR1	BCDD-1	SDO 2	UNIT-4	14013	11 KV RMU-5	14013205	SUDARSHAN PALACE-1	1124DT057	100	MIXED	AMI	Yes	100%	10	0.00962786	0.006014	0.00361386	37.54%
215	TPCODL	BBSR1	BCDD-1	SDO 2	UNIT-4	14013	11 KV RMU-5	14013205	SUDARSHAN PALACE-1	1124DT066	100	MIXED	AMI	Yes	100%	11	0.01584265	0.010471	0.00537165	33.91%
216	TPCODL	BBSR1	BCDD-1	SDO 2	UNIT-4	14013	11 KV RMU-5	14013205	A. G COLONY VOLLEY FIELD	1124DT072	100	MIXED	AMI	Yes	100%	44	0.03151936	0.025583	0.00593636	18.83%
217	TPCODL	BBSR1	BCDD-1	SDO 2	UNIT-4	14013	11 KV RMU-5	14013205	VOLLEY FIELD 1/A	1124DT073	250	MIXED	AMI	Yes	100%	36	0.03885928	0.021086	0.01777328	45.74%
218	TPCODL	BBSR1	BCDD-1	SDO 2	UNIT-4	14013	11 KV RMU-5	14013205	CPWD-2	1124DT076	100	MIXED	AMI	Yes	100%	53	0.05699422	0.033674	0.02332022	40.92%

Sl. No.	Zone Name	Circle name	Division name	Name of the Sub-division	Name of the Sub-station	Substation Code	Name of the 11 kV Feeder	Feeder Code	Name of the Location where DT situated	DT code	DT Capacity (kVA)	Predominant consumer type of DT (Domestic/Industrial/Agriculture/Mixed)	Type of metering AMR/AMI/ Communicable/Conventional metered/Unmetered	Status of Meter-whether Functional (Yes/No)	% of data received automatically (if AMR/AMI)	No. of Connected Consumers	Input Energy (MU) (A)	Billed Energy (MU) (B)	Loss (MU) (A-B)	% DT Loss (A-B)/A
219	TPCODL	BBSR1	BCDD-1	SDO 2	UNIT-4	14013	11 KV RMU-22	14013206	RAJ KISHORE VILLA	1124DT010	100	MIXED	AMI	Yes	0%	10	0.01306274	0.011639	0.00142374	10.90%
220	TPCODL	BBSR1	BCDD-1	SDO 2	UNIT-4	14013	11 KV RMU-22	14013206	JAGANNATH HEIGHT	1124DT011	250	MIXED	AMI	Yes	100%	25	0.03050492	0.021195	0.00930992	30.52%
221	TPCODL	BBSR1	BCDD-1	SDO 2	UNIT-4	14013	11 KV RMU-22	14013206	JYOSHNA GARDEN	1124DT012	250	MIXED	AMI	Yes	100%	47	0.07314028	0.0612	0.01194028	16.33%
222	TPCODL	BBSR1	BCDD-1	SDO 2	UNIT-4	14013	11 KV RMU-22	14013206	CREATIVE ENCLAVE	1124DT014	500	MIXED	AMI	Yes	100%	49	0.08720648	0.082478	0.00472848	5.42%
223	TPCODL	BBSR1	BCDD-1	SDO 2	UNIT-4	14013	11 KV RMU-22	14013206	T.PATRA NEAR RAJ KISHORE RUPAL P.	1124DT101	250	MIXED	AMI	Yes	100%	8	0.0102246	0.009757	0.0004676	4.57%
224	TPCODL	BBSR1	BCDD-1	SDO 2	UNIT-6	14012	11 KV FOREST PARK	14012202	JP CSS-48 TINIKONI FOREST PARK	1122DT116	630	MIXED	AMI	Yes	100%	69	0.2419315	0.181143	0.0607885	25.13%
225	TPCODL	BBSR1	BCDD-1	SDO 2	UNIT-6	14012	11 KV FOREST PARK	14012202	JHARNA BASTI	1122DT117	200	MIXED	AMI	Yes	100%	359	0.2233287	0.168187	0.0551417	24.69%
226	TPCODL	BBSR1	BCDD-1	SDO 2	UNIT-6	14012	11 KV FOREST PARK	14012202	JP CSS-33 ODISHA PLASTIC FRONT	1122DT122	630	MIXED	AMI	Yes	100%	85	0.22301114	0.124095	0.09891614	44.35%
227	TPCODL	BBSR1	BCDD-1	SDO 2	UNIT-6	14012	11 KV FOREST PARK	14012202	BRAJAMAN JHARA SAHI	1122DT123	500	MIXED	AMI	Yes	100%	353	0.43568872	0.348641	0.08704772	19.98%
228	TPCODL	BBSR1	BCDD-1	SDO 2	UNIT-6	14012	11 KV FOREST PARK	14012202	SURYALOK APARTMENT	1122DT124	100	MIXED	AMI	Yes	100%	12	0.02227594	0.02148	0.00079594	3.57%
229	TPCODL	BBSR1	BCDD-1	SDO 2	UNIT-6	14012	11 KV FOREST PARK	14012202	RATNA CASTLE	1122DT125	100	MIXED	AMI	Yes	100%	12	0.01786584	0.008757	0.00910884	50.98%
230	TPCODL	BBSR1	BCDD-1	SDO 2	UNIT-6	14012	11 KV FOREST PARK	14012202	DHUNA BABU	1122DT129	250	MIXED	AMI	Yes	100%	98	0.25039232	0.164216	0.08617632	34.42%
231	TPCODL	BBSR1	BCDD-1	SDO 2	UNIT-6	14012	11 KV FOREST PARK	14012202	SB TOWER APPARTMENT	1122DT130	63	MIXED	AMI	Yes	100%	7	0.00732772	0.006797	0.00053072	7.24%
232	TPCODL	BBSR1	BCDD-1	SDO 2	UNIT-6	14012	11 KV FOREST PARK	14012202	BASANT PARK	1122DT131	500	MIXED	AMI	Yes	100%	64	0.08433616	0.05624	0.02809616	33.31%
233	TPCODL	BBSR1	BCDD-1	SDO 2	UNIT-6	14012	11 KV FOREST PARK	14012202	DADU NIWAS	1122DT134	100	MIXED	AMI	Yes	100%	10	0.01658296	0.015872	0.00071096	4.29%
234	TPCODL	BBSR1	BCDD-1	SDO 2	UNIT-6	14012	11 KV FOREST PARK	14012202	RASHMI VILLA	1122DT135	100	MIXED	AMI	Yes	0%	17	0.0350524	0.02073	0.0143224	40.86%
235	TPCODL	BBSR1	BCDD-1	SDO 2	UNIT-6	14012	11 KV FOREST PARK	14012202	FOREST PARK NEW	1122DT136	250	MIXED	AMI	Yes	0%	138	0.26866448	0.19191	0.07675448	28.57%
236	TPCODL	BBSR1	BCDD-1	SDO 2	UNIT-6	14012	11 KV FOREST PARK	14012202	ADITYA ENCLAVE	1122DT164	100	MIXED	AMI	Yes	0%	7	0.01332344	0.008262	0.00506144	37.99%
237	TPCODL	BBSR1	BCDD-1	SDO 2	UNIT-6	14012	11 KV UNIT-1	14012203	KASTURBA NARI MAHAL	1122DT018	500	MIXED	AMI	Yes	100%	94	0.19381072	0.096058	0.09775272	50.44%
238	TPCODL	BBSR1	BCDD-1	SDO 2	UNIT-6	14012	11 KV UNIT-1	14012203	DRIVING SCHOOL(NAVODAYA CLUB)	1122DT022	250	MIXED	AMI	Yes	100%	153	0.2373512	0.18101	0.0563412	23.74%
239	TPCODL	BBSR1	BCDD-1	SDO 2	UNIT-6	14012	11 KV UNIT-1	14012203	CAPITAL MARKRT-1	1122DT026	500	MIXED	AMI	Yes	100%	531	0.26732232	0.209462	0.05786032	21.64%
240	TPCODL	BBSR1	BCDD-1	SDO 2	UNIT-6	14012	11 KV UNIT-1	14012203	CAPITAL MARKRT-2	1122DT027	250	MIXED	AMI	Yes	0%	359	0.17207152	0.126365	0.04570652	26.56%
241	TPCODL	BBSR1	BCDD-1	SDO 2	UNIT-6	14012	11 KV SPRING TANK	14012204	PATRA MEDICAL	1122DT044	630	MIXED	AMI	Yes	100%	53	0.22688238	0.081598	0.14528438	64.04%
242	TPCODL	BBSR1	BCDD-1	SDO 2	UNIT-6	14012	11 KV SPRING TANK	14012204	A12 PALLASHPALLI	1122DT047	250	MIXED	AMI	Yes	100%	14	0.03273152	0.031093	0.00163852	5.01%
243	TPCODL	BBSR1	BCDD-1	SDO 2	UNIT-6	14012	11 KV SPRING TANK	14012204	SAI ATCATI HOME LANE-04	1122DT050	100	MIXED	AMI	Yes	100%	9	0.01407218	0.01214	0.00193218	13.73%
244	TPCODL	BBSR1	BCDD-1	SDO 2	UNIT-6	14012	11 KV SPRING TANK	14012204	SPRING TANK OFFICE	1122DT051	630	MIXED	AMI	Yes	100%	35	0.17045213	0.095359	0.07509313	44.06%
245	TPCODL	BBSR1	BCDD-1	SDO 2	UNIT-6	14012	11 KV SPRING TANK	14012204	BHARTI TOWER	1122DT052	500	MIXED	AMI	Yes	100%	103	0.119692	0.060721	0.058971	49.27%
246	TPCODL	BBSR1	BCDD-1	SDO 2	UNIT-6	14012	11 KV BAPUJINAGAR	14012205	JPCSS -49 60 FOREST PARK	1122DT073	630	MIXED	AMI	Yes	100%	24	0.11411851	0.101684	0.01243451	10.90%
247	TPCODL	BBSR1	BCDD-1	SDO 2	UNIT-6	14012	11 KV BAPUJINAGAR	14012205	60 FOREST PARK	1122DT074	250	MIXED	AMI	Yes	100%	18	0.14526404	0.050114	0.09515004	65.50%
248	TPCODL	BBSR1	BCDD-1	SDO 2	UNIT-6	14012	11 KV BAPUJINAGAR	14012205	PANI TANKI-2	1122DT093	500	MIXED	AMI	Yes	0%	70	0.37330816	0.15728	0.21602816	57.87%
249	TPCODL	BBSR1	BCDD-1	SDO 2	UNIT-6	14012	11 KV BAPUJINAGAR	14012205	HOTEL SHUSHI	1122DT102	250	MIXED	AMI	Yes	100%	109	0.19012616	0.144487	0.04563916	24.00%
250	TPCODL	BBSR1	BCDD-1	SDO 2	UNIT-6	14012	11 KV BAPUJINAGAR	14012205	JPCSS-29 NEAR BHARAT FURNITURE	1122DT107	630	MIXED	AMI	Yes	100%	28	0.33415901	0.090903	0.24325601	72.80%
251	TPCODL	BBSR1	BCDD-1	SDO 2	UNIT-6	14012	11 KV BAPUJINAGAR	14012205	JPCSS-30 NEAR BHARAT FURNITURE	1122DT108	630	MIXED	AMI	Yes	100%	59	0.19602801	0.090198	0.10583001	53.99%
252	TPCODL	BBSR1	BCDD-1	SDO 2	UNIT-6	14012	11 KV BAPUJINAGAR	14012205	JPCSS -31 OLD RAJ ELECTRICAL	1122DT109	630	MIXED	AMI	Yes	100%	26	0.09189313	0.057947	0.03394613	36.94%
253	TPCODL	BBSR1	BCDD-1	SDO 2	UNIT-6	14012	11 KV BAPUJINAGAR	14012205	KALI MANDIRA -2 (DHUNA BABU)	1122DT111	250	MIXED	AMI	Yes	100%	115	0.16457516	0.144167	0.02040816	12.40%
254	TPCODL	BBSR1	BCDD-1	SDO 2	UNIT-6	14012	11 KV BAPUJINAGAR	14012205	KALI MANDIR	1122DT112	500	MIXED	AMI	Yes	100%	133	0.32563536	0.316966	0.00866936	2.66%
255	TPCODL	BBSR1	BCDD-1	SDO 2	UNIT-6	14012	11 KV BAPUJINAGAR	14012205	JPCSS-32 BADAL NIWAS	1122DT115	630	MIXED	AMI	Yes	100%	80	0.18917963	0.10828	0.08089963	42.76%
256	TPCODL	BBSR1	BCDD-1	SDO 2	UNIT-6	14012	11 KV RMU-8	14012208	NEW NIRMAL PLAZA TRAFFIC SQUAR	1122DT056	630	MIXED	AMI	Yes	100%	47	0.17292488	0.065493	0.10743188	62.13%
257	TPCODL	BBSR1	BCDD-1	SDO 2	UNIT-6	14012	11 KV RMU-8	14012208	TRICONE SQUARE	1122DT064	250	MIXED	AMI	Yes	100%	69	0.17391442	0.150798	0.02311642	13.29%
258	TPCODL	BBSR1	BCDD-1	SDO 2	UNIT-6	14012	11 KV RMU-8	14012208	BHIMTANGI RD 2	1122DT065	100	MIXED	AMI	Yes	100%	231	0.1177283	0.073807	0.0439213	37.31%
259	TPCODL	BBSR1	BCDD-1	SDO 2	UNIT-6	14012	11 KV RMU-8	14012208	BHIMTANGI RD 1	1122DT066	200	MIXED	AMI	Yes	100%	13	0.03091096	0.018246	0.01266496	40.97%
260	TPCODL	BBSR1	BCDD-1	SDO 2	UNIT-6	14012	11 KV RMU-7	14012209	TATI BASTI	1122DT014	100	MIXED	AMI	Yes	100%	69	0.04977431	0.028658	0.02111631	42.42%
261	TPCODL	BBSR1	BCDD-1	SDO 2	UNIT-8	14011	11 KV OERC	14011209	SASTRINAGAR-4	1124DT009	250	MIXED	AMI	Yes	100%	97	0.13644132	0.113232	0.02320932	17.01%
262	TPCODL	BBSR1	BCDD-1	SDO 3	SAHID NAGAR	14016	11 kV Feeder-1	14016201	PLOT NO-2	1132DT005	250	MIXED	AMI	Yes	0%	16	0.0251052	0.021224	0.0038812	15.46%
263	TPCODL	BBSR1	BCDD-1	SDO 3	SAHID NAGAR	14016	11 kV Feeder-1	14016201	PLOT NO 295/A	1132DT024	100	MIXED	AMI	Yes	0%	6	0.01674948	0.016744	5.48E-06	0.03%
264	TPCODL	BBSR1	BCDD-1	SDO 3	SHANTI PALLI	14384	11KV MAHARSHI COLLEG	14384204	PLOT NO 509	1132DT036	100	MIXED	AMI	Yes	0%	8	0.01773099	0.016955	0.00077599	4.38%
265	TPCODL	BBSR1	BCDD-1	SDO 3	SAHID NAGAR	14016	11 kV Feeder-4	14016204	PLOT NO A/156	1132DT080	250	MIXED	AMI	Yes	0%	13	0.02075908	0.020501	0.00025808	1.24%
266	TPCODL	BBSR1	BCDD-1	SDO 3	SHANTI PALLI	14384	11 kV MAHARSHI COLLEG	14384204	SANTI NAGAR HOUSING-2	1132DT206	500	MIXED	AMI	Yes	100%	256	0.10061464	0.095952	0.00466264	4.63%
267	TPCODL	BBSR1	BCDD-1	SDO 3	BOARD COLONY	14017	11 kV BM RMU2	14017205	AG PANI TANKI	1133DT034	100	MIXED	AMI	Yes	100%	26	0.01286442	0.011909	0.00095542	7.43%
268	TPCODL	BBSR1	BCDD-1	SDO 3	SATYA NAGAR	14014	11 kV PLAZA	14014203	MAHILA COMMITION	1134DT001	250	MIXED	AMI	Yes	0%	9	0.07185344	0.036369	0.03548444	49.38%
269	TPCODL	BBSR1	BCDD-1	SDO 3	SHANTI PALLI	14384	11KV BHAWANI MALL	14384201	BHAWANI-8	1132DT154	500	MIXED	AMI	Yes	100%	15	0.09575848	0.078616	0.01714248	17.90%
270	TPCODL	BBSR1	BCDD-1	SDO 3	SHANTI PALLI	14384	11KV BHAWANI MALL	14384201	BHAWANI-2	1132DT155	500	MIXED	AMI	Yes	100%	9	0.15029032	0.119353	0.03093732	20.59%
271	TPCODL	BBSR1	BCDD-1	SDO 3	SHANTI PALLI	14384	11KV BHAWANI MALL	14384201	BHAWANI 4	1132DT159	500	MIXED	AMI	Yes	100%	28	0.17139864	0.139663	0.03173564	18.52%
272	TPCODL	BBSR1	BCDD-1	SDO 3	SHANTI PALLI	14384	11KV BHAWANI MALL	14384201	BHAWANI-1	1132DT161	500	MIXED	AMI	Yes	100%	20	0.1013852	0.025231	0.0761542	75.11%
273	TPCODL	BBSR1	BCDD-1	SDO 3	BOARD COLONY	14017	11 KV GridcoColony	14017202	3R-250	1131DT064	250	MIXED	AMI	Yes	67%	95	0.14415404	0.118397	0.02575704	17.87%
274	TPCODL	BBSR1	BCDD-1	SDO 3	BOARD COLONY	14017	11 KV GridcoColony	14017202	SR-100	1131DT065	100	MIXED	AMI	Yes	0%	30	0.03890994	0.036004	0.00290594	7.47%
275	TPCODL	BBSR1	BCDD-1	SDO 3	BOARD COLONY	14017	11 KV GridcoColony	14017202	PMv	1131DT067	100	MIXED	AMI	Yes	0%	18	0.01983156	0.011877	0.00795456	40.11%
276	TPCODL	BBSR1	BCDD-1	SDO 3	BOARD COLONY	14017	11 KV GridcoColony	14017202	OPTCL POWER CLUB	1131DT068	250	MIXED	AMI	Yes	100%	45	0.05848052	0.044495	0.01398552	23.91%
277	TPCODL	BBSR1	BCDD-1	SDO 3	BOARD COLONY	14017	11 KV GridcoColony	14017202	DHABALESWAR TEMPLE	1131DT069	500	MIXED	AMI	Yes	100%	146	0.21568056	0.165338	0.05034256	23.34%
278	TPCODL	BBSR1	BCDD-1	SDO 3	BOARD COLONY	14017	11 KV BM RMU2	14017205	UTKAL VILLAS	1133DT032	500	MIXED	AMI	Yes	100%	35	0.07889952	0.074204	0.00469552	5.95%
279	TPCODL	BBSR1	BCDD-1	SDO 3	BOARD COLONY	14017	11 KV BM RMU2	14017205	BM-CSS-01	1133DT033	630	MIXED	AMI	Yes	0%	63	0.09591113	0.070265	0.02564613	26.74%
280	TPCODL	BBSR1	BCDD-1	SDO 3	BOARD COLONY	14017	11 KV BM RMU2	14017205	AG QTRS.	1133DT039	500	MIXED	AMI	Yes	67%	44	0.0479852	0.017519	0.0304662	63.49%
281	TPCODL	BBSR1	BCDD-1	SDO 3	BOARD COLONY	14017	11 KV BM RMU1	14017206	SP BASTI	1133DT051	250	MIXED	AMI	Yes	100%	349	0.21282768	0.126771	0.08605668	40.43%
282	TPCODL	BBSR1	BCDD-1	SDO 3	BOARD COLONY	14017	11 KV BM RMU1	14017206	NIRUPAMA APPARTMENT	1133DT057	250	MIXED	AMI	Yes	100%	83	0.0802948	0.050221	0.0300738	37.45%
283	TPCODL	BBSR1	BCDD-1	SDO 3	BOARD COLONY	14017	11 KV BM RMU1	14017206	BM CSS-13	1133DT060	630	MIXED	AMI	Yes	100%	141	0.24235701	0.209815	0.03254201	13.43%
284	TPCODL	BBSR1	BCDD-1	SDO 3	BOARD COLONY	14017	11 KV BM RMU1	14017206	SUSHILA APPARTMENT	1133DT062	500	MIXED	AMI	Yes	33%	40	0.06504224	0.027436	0.03760624	57.82%
285	TPCODL	BBSR1	BCDD-1	SDO 3	BOARD COLONY	14017	11 KV BM RMU1	14017206	BEHERA SAHI	1133DT064	500	MIXED	AMI	Yes	67%	78	0.36333348	0.133167	0.23016648	63.35%
286	TPCODL	BBSR1	BCDD-1	SDO 3	BOARD COLONY	14017	11 KV BM RMU1	14017206	SINGA BEHERA	1133DT065	250	MIXED	AMI	Yes	100%	29	0.20098104	0.045031	0.15595004	77.59%
287	TPCODL	BBSR1	BCDD-1	SDO 3	BOARD COLONY	14017	11 KV BM RMU1	14017206	M.C.PH-1A	1133DT067	500	MIXED	AMI	Yes	100%	23	0.08448232	0.019521	0.06496132	76.89%
288	TPCODL	BBSR1	BCDD-1	SDO 3	BOARD COLONY	14017	11 KV BM RMU1	14017206	M.C.PH-1	1133DT068	500	MIXED	AMI	Yes	100%	102	0.12211104	0.093792	0.02831904	23.19%
289	TPCODL	BBSR1	BCDD-1	SDO 3	BOARD COLONY	14017	11 KV BM RMU1	14017206	M.C.PH-2	1133DT069	500	MIXED	AMI	Yes	100%	55	0.061625	0.048109	0.013516	21.93%
290	TPCODL	BBSR1	BCDD-1	SDO 3	BOARD COLONY	14017	11 KV BM RMU1	14017206	KANCHAN VILLA	1133DT073	100	MIXED	AMI	Yes	0%	9	0.01247196	0.008302	0.00416996	33.43%
291	TPCODL	BBSR1	BCDD-1	SDO 3	BOARD COLONY	14017	11 KV BM RMU1	14017206	BM CSS-12	1133DT074	630	MIXED	AMI	Yes	100%	27	0.06827638	0.050451	0.01782538	26.11%

Sl. No.	Zone Name	Circle name	Division name	Name of the Sub-division	Name of the Sub-station	Substation Code	Name of the 11 kV Feeder	Feeder Code	Name of the Location where DT situated	DT code	DT Capacity (kVA)	Predominant consumer type of DT (Domestic/Industrial/Agriculture/Mixed)	Type of metering AMR/AMI/ Communicable/Conventional metered/Unmetered	Status of Meter-whether Functional (Yes/No)	% of data received automatically (if AMR/AMI)	No. of Connected Consumers	Input Energy (MU) (A)	Billed Energy (MU) (B)	Loss (MU) (A-B)	% DT Loss (A-B)/A
292	TPCODL	BBSR1	BCDD-1	SDO 3	BOARD COLONY	14017	11 KV JP RMU-36	14017207	MI COLONY	1133DT022	250	MIXED	AMI	Yes	100%	38	0.14508112	0.041986	0.10309512	71.06%
293	TPCODL	BBSR1	BCDD-1	SDO 3	BOARD COLONY	14017	11 KV JP RMU-36	14017207	E-TYPE S/S	1133DT027	250	MIXED	AMI	Yes	100%	112	0.09729132	0.060656	0.03663532	37.66%
294	TPCODL	BBSR1	BCDD-1	SDO 3	BOARD COLONY	14017	11 KV JP RMU-36	14017207	E-TYPE ADDITIONAL	1133DT028	250	MIXED	AMI	Yes	100%	194	0.13616992	0.101418	0.03475192	25.52%
295	TPCODL	BBSR1	BCDD-1	SDO 3	BOARD COLONY	14017	11 KV JP RMU-36	14017207	OFFICE S/S	1133DT042	500	MIXED	AMI	Yes	0%	140	0.233408	0.084109	0.149299	63.96%
296	TPCODL	BBSR1	BCDD-1	SDO 3	BOARD COLONY	14017	11 KV JP RMU-37	14017208	CENSUS	1133DT096	250	MIXED	AMI	Yes	100%	60	0.18758356	0.139664	0.04791956	25.55%
297	TPCODL	BBSR1	BCDD-1	SDO 3	BOARD COLONY	14017	11 KV SM RMU-2	14017209	NEW ADDITIONL-1	1133DT008	500	MIXED	AMI	Yes	100%	149	0.25525272	0.183219	0.07203372	28.22%
298	TPCODL	BBSR1	BCDD-1	SDO 3	BOARD COLONY	14017	11 KV SM RMU-2	14017209	OLD ADDITIONAL	1133DT011	500	MIXED	AMI	Yes	100%	150	0.18267148	0.105687	0.07698448	42.14%
299	TPCODL	BBSR1	BCDD-1	SDO 3	BOARD COLONY	14017	11 KV SM RMU-2	14017209	D-TYPE	1133DT013	250	MIXED	AMI	Yes	100%	163	0.15798624	0.155496	0.00249024	1.58%
300	TPCODL	BBSR1	BCDD-1	SDO 3	BOARD COLONY	14017	11 KV SM RMU-2	14017209	PATTANAIK S/S	1133DT046	100	MIXED	AMI	Yes	100%	41	0.06825732	0.055255	0.01300232	19.05%
301	TPCODL	BBSR1	BCDD-1	SDO 3	BOARD COLONY	14017	11 KV SM RMU-2	14017209	SM CSS-2A	1133DT047	630	MIXED	AMI	Yes	0%	275	0.31924263	0.246575	0.07266763	22.76%
302	TPCODL	BBSR1	BCDD-1	SDO 3	BOARD COLONY	14017	11 KV SM RMU1	14017210	SM-CSS-01	1131DT016	630	MIXED	AMI	Yes	0%	131	0.21122276	0.187505	0.02371776	11.23%
303	TPCODL	BBSR1	BCDD-1	SDO 3	BOARD COLONY	14017	11 KV SM RMU1	14017210	ACHRAYAVHAR SIDE	1131DT022	250	MIXED	AMI	Yes	100%	65	0.14068384	0.106718	0.03396584	24.14%
304	TPCODL	BBSR1	BCDD-1	SDO 3	BOARD COLONY	14017	11 KV SM RMU1	14017210	SM CSS-09	1131DT024	630	MIXED	AMI	Yes	0%	90	0.18885813	0.13181	0.05704813	30.21%
305	TPCODL	BBSR1	BCDD-1	SDO 3	BOARD COLONY	14017	11 KV SM RMU1	14017210	KRISHNA HAPPY HOME	1131DT040	100	MIXED	AMI	Yes	100%	11	0.02777688	0.027646	0.00013088	0.47%
306	TPCODL	BBSR1	BCDD-1	SDO 3	BOARD COLONY	14017	11 KV SM RMU1	14017210	L3-59	1131DT041	250	MIXED	AMI	Yes	100%	51	0.13421124	0.100058	0.03415324	25.45%
307	TPCODL	BBSR1	BCDD-1	SDO 3	BOARD COLONY	14017	11 KV SM RMU1	14017210	JAGGNATH PALACE	1131DT043	500	MIXED	AMI	Yes	100%	34	0.05546296	0.051897	0.00356596	6.43%
308	TPCODL	BBSR1	BCDD-1	SDO 3	BOARD COLONY	14017	11 KV SM RMU1	14017210	MARBLES	1131DT044	100	MIXED	AMI	Yes	100%	17	0.08686036	0.026774	0.06008636	69.18%
309	TPCODL	BBSR1	BCDD-1	SDO 3	BOARD COLONY	14017	11 KV SM RMU1	14017210	SKY AUTOMOBILE	1131DT049	100	MIXED	AMI	Yes	67%	15	0.02006604	0.019403	0.00066304	3.30%
310	TPCODL	BBSR1	BCDD-1	SDO 3	BOARD COLONY	14017	11 KV SM RMU1	14017210	SIDHI SAI EMERALD	1131DT056	100	MIXED	AMI	Yes	100%	7	0.01753196	0.017343	0.00018896	1.08%
311	TPCODL	BBSR1	BCDD-1	SDO 3	DELTA	14221	11 KV SIRIPUR	14221201	MUNDASAHI	1111DT100	250	MIXED	AMI	Yes	100%	299	0.19886956	0.142463	0.05640656	28.36%
312	TPCODL	BBSR1	BCDD-1	SDO 3	MASTER CANTEEN (	14234	11 KV MARKET BUILDING	14234203	MARKET BUILDING	1123DT009	500	MIXED	AMI	Yes	100%	183	0.23816864	0.229092	0.00907664	3.81%
313	TPCODL	BBSR1	BCDD-1	SDO 3	SAHID NAGAR	14016	11 KV Feeder-1	14016201	TELGU BASTI	1132DT004	100	MIXED	AMI	Yes	0%	206	0.0884191	0.073019	0.0154001	17.42%
314	TPCODL	BBSR1	BCDD-1	SDO 3	SAHID NAGAR	14016	11 KV Feeder-1	14016201	PLOT NO-31	1132DT008	100	MIXED	AMI	Yes	100%	16	0.03256982	0.020735	0.01183482	36.34%
315	TPCODL	BBSR1	BCDD-1	SDO 3	SAHID NAGAR	14016	11 KV Feeder-1	14016201	NEAR KALYAN MONDAP	1132DT009	250	MIXED	AMI	Yes	100%	78	0.14448892	0.103759	0.04072992	28.19%
316	TPCODL	BBSR1	BCDD-1	SDO 3	SAHID NAGAR	14016	11 KV Feeder-1	14016201	CREATIVE NILAYAM	1132DT013	250	MIXED	AMI	Yes	100%	24	0.03639848	0.033435	0.00296348	8.14%
317	TPCODL	BBSR1	BCDD-1	SDO 3	SAHID NAGAR	14016	11 KV Feeder-1	14016201	PLOT-38	1132DT015	100	MIXED	AMI	Yes	0%	8	0.02126789	0.007314	0.01395389	65.61%
318	TPCODL	BBSR1	BCDD-1	SDO 3	SAHID NAGAR	14016	11 KV Feeder-1	14016201	NEAR POTE NO 200	1132DT017	100	MIXED	AMI	Yes	100%	71	0.1150465	0.108334	0.0067125	5.83%
319	TPCODL	BBSR1	BCDD-1	SDO 3	SAHID NAGAR	14016	11 KV Feeder-1	14016201	PLOT NO -305	1132DT019	100	MIXED	AMI	Yes	100%	8	0.01430672	0.014278	2.872E-05	0.20%
320	TPCODL	BBSR1	BCDD-1	SDO 3	SAHID NAGAR	14016	11 KV Feeder-1	14016201	BEHERA S/S	1132DT025	250	MIXED	AMI	Yes	100%	140	0.16795228	0.110614	0.05733828	34.14%
321	TPCODL	BBSR1	BCDD-1	SDO 3	SAHID NAGAR	14016	11 KV Feeder-1	14016201	PLOT NO 274	1132DT026	100	MIXED	AMI	Yes	100%	7	0.01587071	0.012594	0.00327671	20.65%
322	TPCODL	BBSR1	BCDD-1	SDO 3	SAHID NAGAR	14016	11 KV Feeder-1	14016201	ROBERT PARK	1132DT037	250	MIXED	AMI	Yes	100%	67	0.09993564	0.083363	0.01657264	16.58%
323	TPCODL	BBSR1	BCDD-1	SDO 3	SAHID NAGAR	14016	11 KV Feeder-1	14016201	BERENA	1132DT041	250	MIXED	AMI	Yes	100%	76	0.2972544	0.162437	0.1348174	45.35%
324	TPCODL	BBSR1	BCDD-1	SDO 3	SAHID NAGAR	14016	11 KV Feeder-1	14016201	SUMITRA COMPLEX	1132DT042	100	MIXED	AMI	Yes	100%	10	0.0194262	0.008877	0.0105492	54.30%
325	TPCODL	BBSR1	BCDD-1	SDO 3	SAHID NAGAR	14016	11 KV Feeder-1	14016201	YOGA ASHARAM NEW	1132DT043	100	MIXED	AMI	Yes	100%	38	0.0671268	0.044318	0.0228088	33.98%
326	TPCODL	BBSR1	BCDD-1	SDO 3	SAHID NAGAR	14016	11 KV Feeder-1	14016201	QUELITY CONTROL	1132DT045	250	MIXED	AMI	Yes	100%	36	0.175026	0.080151	0.094875	54.21%
327	TPCODL	BBSR1	BCDD-1	SDO 3	SAHID NAGAR	14016	11 KV Feeder-1	14016201	MANGLA MANDIR	1132DT052	500	MIXED	AMI	Yes	100%	56	0.20445744	0.109421	0.09503644	46.48%
328	TPCODL	BBSR1	BCDD-1	SDO 3	SAHID NAGAR	14016	11 KV Feeder-1	14016201	SIDE VETENARY	1132DT056	200	MIXED	AMI	Yes	100%	80	0.15083192	0.129299	0.02153292	14.28%
329	TPCODL	BBSR1	BCDD-1	SDO 3	SAHID NAGAR	14016	11 KV Feeder-1	14016201	SHIVE MANDIR	1132DT057	500	MIXED	AMI	Yes	100%	63	0.22387128	0.085924	0.13794728	61.62%
330	TPCODL	BBSR1	BCDD-1	SDO 3	SAHID NAGAR	14016	11 KV Feeder-1	14016201	PLOT NO-A322	1132DT066	100	MIXED	AMI	Yes	67%	15	0.03599775	0.015852	0.02014575	55.96%
331	TPCODL	BBSR1	BCDD-1	SDO 3	SAHID NAGAR	14016	11 KV Feeder-1	14016201	NEAR HAPPY HOUR SCHOOL	1132DT067	100	MIXED	AMI	Yes	100%	24	0.04240886	0.033303	0.00910586	21.47%
332	TPCODL	BBSR1	BCDD-1	SDO 3	SAHID NAGAR	14016	11 KV Feeder-1	14016201	LINK S/S	1132DT068	250	MIXED	AMI	Yes	0%	148	0.22670344	0.144824	0.08187944	36.12%
333	TPCODL	BBSR1	BCDD-1	SDO 3	SAHID NAGAR	14016	11 KV Feeder-1	14016201	IPICOL CONY	1132DT073	100	MIXED	AMI	Yes	100%	16	0.01561226	0.014557	0.00105526	6.76%
334	TPCODL	BBSR1	BCDD-1	SDO 3	SAHID NAGAR	14016	11 KV Feeder-1	14016201	SHANTI PALLI	1132DT127	500	MIXED	AMI	Yes	100%	410	0.17114064	0.141275	0.02986564	17.45%
335	TPCODL	BBSR1	BCDD-1	SDO 3	SAHID NAGAR	14016	11 KV Feeder-1	14016201	PND NIRVAN ,PLOT NO -33	1132DT200	100	MIXED	AMI	Yes	100%	8	0.0205599	0.018983	0.0015769	7.67%
336	TPCODL	BBSR1	BCDD-1	SDO 3	SAHID NAGAR	14016	11 KV Feeder-1	14016201	PLOT NO -304	1132DT204	100	MIXED	AMI	Yes	100%	7	0.01873002	0.011867	0.00686302	36.64%
337	TPCODL	BBSR1	BCDD-1	SDO 3	SAHID NAGAR	14016	11 KV Feeder-1	14016201	PLOT NO -318/319	1132DT205	250	MIXED	AMI	Yes	100%	8	0.01800624	0.009783	0.00822324	45.67%
338	TPCODL	BBSR1	BCDD-1	SDO 3	SAHID NAGAR	14016	11 KV Feeder-2	14016202	PLOT NO-267	1132DT104	100	MIXED	AMI	Yes	100%	7	0.02069616	0.017658	0.00303816	14.68%
339	TPCODL	BBSR1	BCDD-1	SDO 3	SAHID NAGAR	14016	11 KV Feeder-2	14016202	PLOT NO-352	1132DT105	100	MIXED	AMI	Yes	0%	34	0.04333119	0.032193	0.01113819	25.70%
340	TPCODL	BBSR1	BCDD-1	SDO 3	SAHID NAGAR	14016	11 KV Feeder-2	14016202	PLOT NO B15	1132DT110	250	MIXED	AMI	Yes	0%	6	0.00925366	0.008381	0.00087266	9.43%
341	TPCODL	BBSR1	BCDD-1	SDO 3	SAHID NAGAR	14016	11 KV Feeder-3	14016203	PLOT NO 9	1132DT130	500	MIXED	AMI	Yes	100%	40	0.07009184	0.06672	0.00337184	4.81%
342	TPCODL	BBSR1	BCDD-1	SDO 3	SAHID NAGAR	14016	11 KV Feeder-3	14016203	PLOT NO 42	1132DT131	100	MIXED	AMI	Yes	0%	22	0.03114562	0.020567	0.01057862	33.97%
343	TPCODL	BBSR1	BCDD-1	SDO 3	SAHID NAGAR	14016	11 KV Feeder-3	14016203	PLOT NO 45	1132DT133	100	MIXED	AMI	Yes	100%	11	0.02426822	0.016844	0.00742422	30.59%
344	TPCODL	BBSR1	BCDD-1	SDO 3	SAHID NAGAR	14016	11 KV Feeder-3	14016203	PANI TANKI-2	1132DT135	250	MIXED	AMI	Yes	0%	126	0.31312864	0.196364	0.11676464	37.29%
345	TPCODL	BBSR1	BCDD-1	SDO 3	SAHID NAGAR	14016	11 KV Feeder-3	14016203	NEAR UP SCHOOL	1132DT138	100	MIXED	AMI	Yes	0%	25	0.03071825	0.02132	0.00939825	30.60%
346	TPCODL	BBSR1	BCDD-1	SDO 3	SAHID NAGAR	14016	11 KV Feeder-3	14016203	PLOT NO 190	1132DT139	100	MIXED	AMI	Yes	100%	10	0.01904842	0.018692	0.00035642	1.87%
347	TPCODL	BBSR1	BCDD-1	SDO 3	SAHID NAGAR	14016	11 KV Feeder-3	14016203	PLOT NO 258	1132DT141	100	MIXED	AMI	Yes	100%	6	0.01209186	0.009923	0.00216886	17.94%
348	TPCODL	BBSR1	BCDD-1	SDO 3	SAHID NAGAR	14016	11 KV Feeder-3	14016203	S/S NO -6	1132DT146	500	MIXED	AMI	Yes	100%	182	0.35114352	0.257825	0.09331852	26.58%
349	TPCODL	BBSR1	BCDD-1	SDO 3	SAHID NAGAR	14016	11 KV Feeder-3	14016203	PLOT NO-326	1132DT173	100	MIXED	AMI	Yes	100%	6	0.01255088	0.008325	0.00422588	33.67%
350	TPCODL	BBSR1	BCDD-1	SDO 3	SAHID NAGAR	14016	11 KV Feeder-3	14016203	DEBADAS MOHANTY	1132DT251	100	MIXED	AMI	Yes	0%	7	0.031613	0.016843	0.01477	46.72%
351	TPCODL	BBSR1	BCDD-1	SDO 3	SAHID NAGAR	14016	11 KV Feeder-4	14016204	DHAWN 1	1132DT083	250	MIXED	AMI	Yes	100%	48	0.17990738	0.146314	0.03359338	18.67%
352	TPCODL	BBSR1	BCDD-1	SDO 3	SAHID NAGAR	14016	11 KV JP RMU-2	14016205	PLOT NO. A/175	1132DT255	100	MIXED	AMI	Yes	100%	7	0.0046991	0.003823	0.0008761	18.64%
353	TPCODL	BBSR1	BCDD-1	SDO 3	SAHID NAGAR	14016	11 KV JP RMU35	14016207	JP CSS-35	1131DT009	630	MIXED	AMI	Yes	0%	5	0.07856176	0.074808	0.00375376	4.78%
354	TPCODL	BBSR1	BCDD-1	SDO 3	SATYA NAGAR	14014	11 KV SATYANAGAR	14014201	CENTRAL SCHOOL STAFF QUARTER	1134DT005	250	MIXED	AMI	Yes	100%	86	0.07169536	0.035831	0.03586436	50.02%
355	TPCODL	BBSR1	BCDD-1	SDO 3	SATYA NAGAR	14014	11 KV SATYANAGAR	14014201	DURGA MANDAP 2	1134DT008	250	MIXED	AMI	Yes	100%	336	0.25241328	0.201822	0.05059128	20.04%
356	TPCODL	BBSR1	BCDD-1	SDO 3	SATYA NAGAR	14014	11 KV SATYANAGAR	14014201	DURGA MANDAP 1	1134DT009	500	MIXED	AMI	Yes	100%	142	0.31345685	0.217285	0.09617185	30.68%
357	TPCODL	BBSR1	BCDD-1	SDO 3	SATYA NAGAR	14014	11 KV SATYANAGAR	14014201	SUNGREEN HOTEL BACK SIDE	1134DT011	250	MIXED	AMI	Yes	100%	184	0.18833448	0.153193	0.03514148	18.66%
358	TPCODL	BBSR1	BCDD-1	SDO 3	SATYA NAGAR	14014	11 KV SATYANAGAR	14014201	BASUDHA RESIDENCY	1134DT013	100	MIXED	AMI	Yes	100%	13	0.01520948	0.012803	0.00240648	15.82%
359	TPCODL	BBSR1	BCDD-1	SDO 3	SATYA NAGAR	14014	11 KV SATYANAGAR	14014201	MANORAMA ENCLAVE	1134DT018	250	MIXED	AMI	Yes	100%	28	0.03252992	0.019617	0.01291292	39.70%
360	TPCODL	BBSR1	BCDD-1	SDO 3	SATYA NAGAR	14014	11 KV SATYANAGAR	14014201	HEALTH ASSURANCE	1134DT020	500	MIXED	AMI	Yes	100%	42	0.04047268	0.039712	0.00076068	1.88%
361	TPCODL	BBSR1	BCDD-1	SDO 3	SATYA NAGAR	14014	11 KV SATYANAGAR	14014201	SAHNI RESIDENCY	1134DT026	100	MIXED	AMI	Yes	100%	11	0.0151166	0.014057	0.0010596	7.01%
362	TPCODL	BBSR1	BCDD-1	SDO 3	SATYA NAGAR	14014	11 KV SATYANAGAR	14014201	ANNAPURNA RESIDENCY	1134DT027	250	MIXED	AMI	Yes	100%	15	0.02413056	0.020497	0.00363356	15.06%
363	TPCODL	BBSR1	BCDD-1	SDO 3	SATYA NAGAR	14014	11 KV SATYANAGAR	14014201	YASHODHAM ENCLAVE	1134DT028	100	MIXED	AMI	Yes	100%	12	0.0147109	0.010327	0.0043839	29.80%
364	TPCODL	BBSR1	BCDD-1	SDO 3	SATYA NAGAR	14014	11 KV SATYANAGAR	14014201	KAMALA PLACE	1134DT029	100	MIXED	AMI	Yes	100%	17	0.02051244	0.016303	0.00420944	20.52%

Sl. No.	Zone Name	Circle name	Division name	Name of the Sub-division	Name of the Sub-station	Substation Code	Name of the 11 kV Feeder	Feeder Code	Name of the Location where DT situated	DT code	DT Capacity (kVA)	Predominant consumer type of DT (Domestic/Industrial/Agriculture/Mixed)	Type of metering AMR/AMI/ Communicable/Conventional metered/Unmetered	Status of Meter- whether Functional (Yes/No)	% of data received automatically (if AMR/AMI)	No. of Connected Consumers	Input Energy (MU) (A)	Billed Energy (MU) (B)	Loss (MU) (A-B)	% DT Loss (A-B)/A
365	TPCODL	BBSR1	BCDD-1	SDO 3	SATYA NAGAR	14014	11 KV SATYANAGAR	14014201	BERANA	1134DT030	500	MIXED	AMI	Yes	67%	97	0.27598472	0.181816	0.09416872	34.12%
366	TPCODL	BBSR1	BCDD-1	SDO 3	SATYA NAGAR	14014	11 KV SATYANAGAR	14014201	P-49	1134DT041	100	MIXED	AMI	Yes	100%	9	0.01541726	0.014305	0.00111226	7.21%
367	TPCODL	BBSR1	BCDD-1	SDO 3	SATYA NAGAR	14014	11 KV SATYANAGAR	14014201	SRADHA RESIDENCY P 7	1134DT042	250	MIXED	AMI	Yes	100%	16	0.02688304	0.025862	0.00102104	3.80%
368	TPCODL	BBSR1	BCDD-1	SDO 3	SATYA NAGAR	14014	11 KV SATYANAGAR	14014201	KESABA APARTMENT	1134DT128	100	MIXED	AMI	Yes	100%	13	0.00950554	0.008893	0.00061254	6.44%
369	TPCODL	BBSR1	BCDD-1	SDO 3	SATYA NAGAR	14014	11 KV SATYANAGAR	14014201	MOHAN PLAZA	1134DT129	100	MIXED	AMI	Yes	100%	13	0.01371696	0.013311	0.00040596	2.96%
370	TPCODL	BBSR1	BCDD-1	SDO 3	SATYA NAGAR	14014	11 KV SATYANAGAR	14014201	JAPANI PALACE	1134DT134	100	MIXED	AMI	Yes	100%	11	0.01249306	0.00709	0.00540306	43.25%
371	TPCODL	BBSR1	BCDD-1	SDO 3	SATYA NAGAR	14014	11 KV PRESS	14014202	PWD	1134DT055	250	MIXED	AMI	Yes	67%	81	0.07253408	0.061925	0.01060908	14.63%
372	TPCODL	BBSR1	BCDD-1	SDO 3	SATYA NAGAR	14014	11 KV PRESS	14014202	PWD COLONY	1134DT056	250	MIXED	AMI	Yes	100%	19	0.02537092	0.01448	0.01089092	42.93%
373	TPCODL	BBSR1	BCDD-1	SDO 3	SATYA NAGAR	14014	11 KV PLAZA	14014203	MOTI APP	1134DT002	250	MIXED	AMI	Yes	0%	49	0.05005516	0.03323	0.01682516	33.61%
374	TPCODL	BBSR1	BCDD-1	SDO 3	SATYA NAGAR	14014	11 KV RAHULCO	14014204	PURATATTVA NIVAS	1134DT063	500	MIXED	AMI	Yes	100%	71	0.11948928	0.057335	0.06215428	52.02%
375	TPCODL	BBSR1	BCDD-1	SDO 3	SATYA NAGAR	14014	11 KV RAHULCO	14014204	HIRA	1134DT065	250	MIXED	AMI	Yes	100%	53	0.07202836	0.055839	0.01618936	22.48%
376	TPCODL	BBSR1	BCDD-1	SDO 3	SATYA NAGAR	14014	11 KV JP RMU14	14014205	JP -CSS-C8	1134DT098	630	MIXED	AMI	Yes	100%	7	0.06250263	0.021051	0.04145163	66.32%
377	TPCODL	BBSR1	BCDD-1	SDO 3	SATYA NAGAR	14014	11 KV JP RMU-45	14014208	JP-CSS-14	1134DT095	630	MIXED	AMI	Yes	100%	9	0.09715275	0.026822	0.07033075	72.39%
378	TPCODL	BBSR1	BCDD-1	SDO 3	UNIT-3	14015	11 kV SM RMU-4	14015205	MAILA TANKI-3	1134DT119	250	MIXED	AMI	Yes	100%	146	0.16535048	0.092572	0.07277848	44.01%
379	TPCODL	BBSR1	BCDD-1	SDO 3	UNIT-3	14015	11 kV SM RMU-4	14015205	ROAD NO 3,UNIT 9	1134DT122	500	MIXED	AMI	Yes	0%	257	0.2363464	0.231474	0.0048724	2.06%
380	TPCODL	BBSR1	BCDD-1	SDO 3	UNIT-3	14015	11 kV SM RMU-4	14015205	JPESS-3	1134DT123	650	MIXED	AMI	Yes	100%	155	0.26723626	0.144507	0.12272926	45.93%
381	TPCODL	BBSR1	BCDD-1	SDO 3	UNIT-3	14015	11 kV JP RMU-41	14015207	JP CSS-37	1121DT112	630	MIXED	AMI	Yes	100%	54	0.09748251	0.086088	0.01139451	11.69%
382	TPCODL	BBSR1	BCDD-1	SDO 3	UNIT-4	14013	11 KV RMU-5	14013205	RAMPUR BASTI	1124DT062	500	MIXED	AMI	Yes	100%	217	0.27080784	0.225413	0.04539484	16.76%
383	TPCODL	BBSR1	BCDD-1	SDO 3	UNIT-8	14011	11 KV OUAT	14011201	NCC OFFICE	1112DT165	250	MIXED	AMI	Yes	100%	53	0.11418185	0.088203	0.02597885	22.75%
384	TPCODL	BBSR1	BCDD-1	SDO 3	UNIT-8	14011	11 KV OERC	14011209	SHASTREE NAGAR 1	1115DT085	500	MIXED	AMI	Yes	100%	88	0.32305416	0.111459	0.21159516	65.50%
385	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	BHARATPUR	14006	11 kV PHD	14006203	BARAMANA SAHI, GHATIKIA	1211DT031	100	MIXED	AMI	Yes	0%	40	0.0750576	0.036991	0.0380666	50.72%
386	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	BHARATPUR	14006	11 kV SAMPUR	14006206	RAMAKANTA DHIR ,SAMPUR	1211DT066	100	MIXED	AMI	Yes	0%	8	0.02260202	0.007755	0.01484702	65.69%
387	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	BHARATPUR	14006	11 kV SAMPUR	14006206	ARUN KUMAR DASH,K-8/41	1211DT071	100	MIXED	AMI	Yes	0%	3	0.01346266	0.013362	0.00010066	0.75%
388	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	BHARATPUR	14006	11 kV SATELITE	14006204	MAHIMA ENCLAVE, SAMPUR	1211DT091	100	MIXED	AMI	Yes	0%	7	0.0144402	0.005911	0.0085292	59.07%
389	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	BHARATPUR	14006	11 kV SATELITE	14006204	MAHIMA RESIDENCY, SAMPUR	1211DT114	100	MIXED	AMI	Yes	0%	10	0.006869	0.005946	0.000923	13.44%
390	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	GOTHAPATNA ODSS	14237	11 kV NUAGAON	14237202	COUNTRY SIDE APPARTMENT	1211DT442	100	MIXED	AMI	Yes	100%	6	0.00788904	0.004464	0.00342504	43.42%
391	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	GOTHAPATNA ODSS	14237	11 kV NUAGAON	14237202	NEAR ASHOK DAS, MALIPADA (R-APD	1211DT502	100	MIXED	AMI	Yes	0%	55	0.0951335	0.054213	0.0409205	43.01%
392	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	GOTHAPATNA ODSS	14237	11 kV NUAGAON	14237202	BROOKIN INFRA, MALIPADA	1211DT504	100	MIXED	AMI	Yes	0%	13	0.01724338	0.00827	0.00897338	52.04%
393	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	GOTHAPATNA ODSS	14237	11 kV GODIBARI	14237204	INDRAPRASTA	1211DT539	100	MIXED	AMI	Yes	0%	26	0.01686518	0.013856	0.00300918	17.84%
394	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	DUMDUMA ODSSP	14236	11 kV PANCHASAKHA NA	14236202	MAA CONSTRUCTION	1212DT013	100	MIXED	AMI	Yes	0%	11	0.0222111	0.018002	0.0042091	18.95%
395	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	DUMDUMA ODSSP	14236	11 kV PANCHASAKHA NA	14236202	PK MOHANTY (BARSANA RESIDENCY)	1212DT024	100	MIXED	AMI	Yes	0%	15	0.01813108	0.010612	0.00751908	41.47%
396	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	DUMDUMA ODSSP	14236	11 kV PANCHASAKHA NA	14236202	PLEASURE HOTEL	1212DT025	100	MIXED	AMI	Yes	0%	86	0.16672518	0.102596	0.06412918	38.46%
397	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	DUMDUMA ODSSP	14236	11 kV BEGUNIA	14236204	SHABNAM NASIM	1212DT049	100	MIXED	AMI	Yes	0%	48	0.07743318	0.050105	0.02732818	35.29%
398	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	KALINGA NAGAR	14007	11 kV K-9	14007201	SUBASHNAGAR NO2	1212DT138	100	MIXED	AMI	Yes	0%	29	0.04777236	0.013946	0.03382636	70.81%
399	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	RANASINGHPUR OD	14235	11 kV AIGINIA	14235202	RAGHUNATH NAGAR(3),SHARMA RO	1212DT159	100	MIXED	AMI	Yes	100%	118	0.07453448	0.055165	0.01936948	25.99%
400	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	RANASINGHPUR OD	14235	11 kV SIJUA	14235203	RANSINGPUR NO 2	1212DT163	100	MIXED	AMI	Yes	0%	12	0.01083058	0.009862	0.00096858	8.94%
401	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	DUMDUMA ODSSP	14236	11 kV HOUSING BOARD	14236201	PHASE -7 NO-4 SUDARSHAN ENCLAV	1212DT177	500	MIXED	AMI	Yes	0%	88	0.04049344	0.027773	0.01272044	31.41%
402	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	KALINGA NAGAR	14007	11 kV K-9	14007201	BN RESIDENCY	1213DT084	100	MIXED	AMI	Yes	0%	9	0.01756178	0.009314	0.00824778	46.96%
403	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	KALINGA NAGAR	14007	11 kV KN RE	14007204	BADA MAHURA BPL	1213DT318	100	MIXED	AMI	Yes	0%	98	0.08526194	0.045856	0.03940594	46.22%
404	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	RANASINGHPUR OD	14235	11 kV AIGINIA	14235202	INFRONT OF CLASS ART	1213DT579	100	MIXED	AMI	Yes	100%	55	0.10033172	0.080933	0.01939872	19.33%
405	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	RANASINGHPUR OD	14235	11 kV SIJUA	14235203	BADSHA EXCELLENCY-1	1213DT613	250	MIXED	AMI	Yes	100%	21	0.02279292	0.021572	0.00122092	5.36%
406	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	DUMDUMA ODSSP	14236	11 kV ASIAN PLAZA	14236203	AMRIT NAGAR-2	1214DT178	100	MIXED	AMI	Yes	0%	72	0.1191294	0.110865	0.0082644	6.94%
407	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	KHANDAGIRI	14222	11 kV KOLATHIA	14222201	BRINDABAN GARDEN -2	1214DT256	500	MIXED	AMI	Yes	100%	97	0.21615712	0.142108	0.07404912	34.26%
408	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	KHANDAGIRI	14222	11 kV KOLATHIA	14222201	JAYARAM BHAGABATI BHAWAN(MA	1214DT263	250	MIXED	AMI	Yes	100%	68	0.09744575	0.065929	0.03151675	32.34%
409	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	KHANDAGIRI	14222	11 kV KOLATHIA	14222201	KAILASH DAS,SANKAPUR	1214DT278	100	MIXED	AMI	Yes	0%	27	0.06058416	0.03092	0.02966416	48.96%
410	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	KALINGA NAGAR	14007	11 kV DUMDUMA	14007205	PANDA SHOP NO-1	1214DT284	100	MIXED	AMI	Yes	100%	46	0.08178216	0.064369	0.01741316	21.29%
411	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	KALINGA NAGAR	14007	11 kV DUMDUMA	14007205	AIGINIA DURGA PUJA MANDAP -1	1214DT305	100	MIXED	AMI	Yes	100%	49	0.0672998	0.061251	0.0060488	8.99%
412	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	KANAN BIHAR	14217	11 kV PATIA	14217203	MIG 102	1235DT393	500	MIXED	AMI	Yes	100%	219	0.2847872	0.280619	0.0041682	1.46%
413	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	KHANDAGIRI	14222	11kv Green Park Feeder	14222205	GREEN PARK HOUSING COLONY-1	1214DT031	500	MIXED	AMI	Yes	100%	205	0.31618984	0.261699	0.05449084	17.23%
414	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	KHANDAGIRI	14222	11kv Green Park Feeder	14222205	GREEN PARK HOUSING COLONY-2	1214DT032	500	MIXED	AMI	Yes	100%	174	0.23377956	0.202176	0.03160356	13.52%
415	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	KHANDAGIRI	14222	11kv Green Park Feeder	14222205	PDN HORIZON	1214DT033	500	MIXED	AMI	Yes	100%	59	0.09395128	0.078512	0.01543928	16.43%
416	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	KHANDAGIRI	14222	11kv Green Park Feeder	14222205	SAINATH PALCE	1214DT037	250	MIXED	AMI	Yes	100%	27	0.03205856	0.021016	0.01104256	34.44%
417	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	KHANDAGIRI	14222	11kv Green Park Feeder	14222205	NEAR ITR COLLEGE CAPEX S/S	1214DT043	200	MIXED	AMI	Yes	100%	85	0.22372224	0.145247	0.07847524	35.08%
418	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	KHANDAGIRI	14222	11kv Talabania Feeder	14222206	RATNA ARCAD	1214DT093	250	MIXED	AMI	Yes	0%	25	0.028315	0.02813	0.000185	0.65%
419	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	KHANDAGIRI	14222	11kv Talabania Feeder	14222206	GANESH NAGAR	1214DT095	500	MIXED	AMI	Yes	100%	98	0.1275936	0.11821	0.0093836	7.35%
420	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	KHANDAGIRI	14222	11kv Talabania Feeder	14222206	LOTUS ENCLAVE (LAKEVALLEY)	1214DT101	500	MIXED	AMI	Yes	100%	192	0.28571112	0.279884	0.00582712	2.04%
421	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	KHANDAGIRI	14222	11kv Talabania Feeder	14222206	LOTUS ENCLAVE-2	1214DT102	100	MIXED	AMI	Yes	0%	22	0.07076838	0.029841	0.04092738	57.83%
422	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	KHANDAGIRI	14222	11kv Talabania Feeder	14222206	OMMKAR VILLA	1214DT109	250	MIXED	AMI	Yes	100%	72	0.09370532	0.070632	0.02307332	24.62%
423	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	KHANDAGIRI	14222	11 KV JAGAMARA	14222207	JAGAMARA NO-1	1214DT167	250	MIXED	AMI	Yes	67%	132	0.32702448	0.145931	0.18109348	55.38%
424	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	KHANDAGIRI	14222	11 KV JAGAMARA	14222207	CAVE VIEW NO-2	1214DT198	250	MIXED	AMI	Yes	100%	59	0.09807802	0.078166	0.01991202	20.30%
425	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	KHANDAGIRI	14222	11 KV JAGAMARA	14222207	AIGINIA PENDAL	1214DT211	250	MIXED	AMI	Yes	100%	45	0.09530246	0.073264	0.02203846	23.12%
426	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	KHANDAGIRI	14222	11 KV JAGAMARA	14222207	ARUN CHAUDHURY	1214DT224	250	MIXED	AMI	Yes	100%	49	0.10995516	0.089148	0.02080716	18.92%
427	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	BARAMUNDA	14005	11 KV BARAMUNDA HB	14005201	LANE-4, ROAD-2, JAGANNATH VIHAR	1221DT112	100	MIXED	AMI	Yes	100%	81	0.09660986	0.095195	0.00141486	1.46%
428	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	BARAMUNDA	14005	11 KV CRPF	14005204	MAHARANA BASTI,RENTAL	1221DT058	100	MIXED	AMI	Yes	100%	27	0.03546838	0.017829	0.01763938	49.73%
429	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	BARAMUNDA	14005	11 KV BARAMUNDA RE	14005205	JAYDEV BATIKA CHHAKA (RAPDRP)	1211DT367	250	MIXED	AMI	Yes	67%	131	0.2620207	0.212608	0.0494127	18.86%
430	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	BARAMUNDA	14005	11 KV BARAMUNDA RE	14005205	TAPOBAN LANE BASTI (RAPDRP)	1211DT373	100	MIXED	AMI	Yes	67%	289	0.12299266	0.083313	0.03967966	32.26%
431	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	BARAMUNDA	14005	11 KV BARAMUNDA RE	14005205	TAPOBAN HIGH SCHOOL	1211DT375	100	MIXED	AMI	Yes	67%	55	0.07208044	0.067397	0.00468344	6.50%
432	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	BHARATPUR	14006	11 KV KHANDAGIRI	14006201	CHALA SAHI, NAKAGATE	1211DT124	63	MIXED	AMI	Yes	100%	51	0.02564648	0.020915	0.00473148	18.45%
433	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	BHARATPUR	14006	11 KV KHANDAGIRI	14006201	MARUTI VILLAGE	1211DT126	250	MIXED	AMI	Yes	100%	85	0.144352	0.102989	0.041363	28.65%
434	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	BHARATPUR	14006	11 KV KHANDAGIRI	14006201	SHUVAM ROYAL, MARUTI VILLAGE	1211DT127	500	MIXED	AMI	Yes	100%	58	0.06506388	0.053586	0.01147788	17.64%
435	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	BHARATPUR	14006	11 KV KHANDAGIRI	14006201	SATYAM ROYAL, MARUTI VILLAGE NO	1211DT130	500	MIXED	AMI	Yes	100%	66	0.08495964	0.077691	0.00726864	8.56%
436	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	BHARATPUR	14006	11 KV KHANDAGIRI	14006201	INFRONT OF CET, NAKAGATE (R- APD	1211DT137	500	MIXED	AMI	Yes	100%	144	0.44915664	0.165279	0.28387764	63.20%
437	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	BHARATPUR	14006	11 KV KHANDAGIRI	14006201	BRUNDABAN ENCLAVE, NAKAGATE	1211DT143	250	MIXED	AMI	Yes	33%	31	0.03114924	0.015834	0.01531524	49.17%

Sl. No.	Zone Name	Circle name	Division name	Name of the Sub-division	Name of the Sub-station	Substation Code	Name of the 11 kV Feeder	Feeder Code	Name of the Location where DT situated	DT code	DT Capacity (kVA)	Predominant consumer type of DT (Domestic/Industrial/Agriculture/Mixed)	Type of metering AMR/AMI/ Communicable/Conventional metered/Unmetered	Status of Meter-whether Functional (Yes/No)	% of data received automatically (if AMR/AMI)	No. of Connected Consumers	Input Energy (MU) (A)	Billed Energy (MU) (B)	Loss (MU) (A-B)	% DT Loss (A-B)/A
438	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	BHARATPUR	14006	11 KV KHANDAGIRI	14006201	KHANDAHIRI BARI NO-2(B)	1211DT146	500	MIXED	AMI	Yes	100%	327	0.43711392	0.369804	0.06730992	15.40%
439	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	BHARATPUR	14006	11 KV KHANDAGIRI	14006201	DILIP KUMAR KHATOI(KHANDAGIRI)	1211DT147	100	MIXED	AMI	Yes	100%	13	0.01419917	0.013804	0.00039517	2.78%
440	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	BHARATPUR	14006	11 KV KHANDAGIRI	14006201	KHANDAGIRI BARI NO-3(A)	1211DT148	500	MIXED	AMI	Yes	100%	289	0.43819912	0.18819	0.25000912	57.05%
441	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	BHARATPUR	14006	11 KV KHANDAGIRI	14006201	SUSANTA ROUT, GHAGIDI	1211DT154	100	MIXED	AMI	Yes	100%	72	0.10590219	0.064499	0.04140319	39.10%
442	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	BHARATPUR	14006	11 KV KHANDAGIRI	14006201	KHANDAGIRI HEIGHTS	1211DT156	100	MIXED	AMI	Yes	0%	10	0.02312056	0.018927	0.00419356	18.14%
443	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	BHARATPUR	14006	11 KV KHANDAGIRI	14006201	PHD, KHANADAGIRI	1211DT161	250	MIXED	AMI	Yes	100%	151	0.20767292	0.150504	0.05716892	27.53%
444	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	BHARATPUR	14006	11 KV KHANDAGIRI	14006201	STYAKANTA INFRA, KHANDAGIRI C/O-	1211DT162	100	MIXED	AMI	Yes	100%	18	0.02547194	0.024209	0.00126294	4.96%
445	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	BHARATPUR	14006	11 KV KHANDAGIRI	14006201	JAYDEV VATIKA (CAPEX) S/S	1211DT163	250	MIXED	AMI	Yes	67%	79	0.0932878	0.074546	0.0187418	20.09%
446	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	BHARATPUR	14006	11 KV KHANDAGIRI	14006201	ABHIRAM MATHA, S/S TAPOBON	1211DT172	100	MIXED	AMI	Yes	67%	171	0.14025369	0.095433	0.04482069	31.96%
447	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	BHARATPUR	14006	11 KV BHARATPUR BDA	14006202	LEELA MAHAL	1211DT003	63	MIXED	AMI	Yes	100%	6	0.01178634	0.008935	0.00285134	24.19%
448	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	BHARATPUR	14006	11 KV BHARATPUR BDA	14006202	PRAVABATI BEHERA	1211DT857	100	MIXED	AMI	Yes	100%	4	0.02321212	0.02316	5.212E-05	0.22%
449	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	BHARATPUR	14006	11 KV BHARATPUR BDA	14006202	HIGH FIELD HOMES	1211DT866	100	MIXED	AMI	Yes	100%	9	0.00930534	0.009268	3.734E-05	0.40%
450	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	BHARATPUR	14006	11 KV PHD	14006203	78 DREAMS APPT., GHATIKIA NO-1	1211DT025	500	MIXED	AMI	Yes	0%	38	0.07810188	0.052801	0.02530088	32.39%
451	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	BHARATPUR	14006	11 KV PHD	14006203	SAMASTI 1001 GREENS NO-2	1211DT028	500	MIXED	AMI	Yes	0%	51	0.08045592	0.049807	0.03064892	38.09%
452	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	BHARATPUR	14006	11 KV PHD	14006203	SAMBIT VILLA, GHATIKIA	1211DT032	250	MIXED	AMI	Yes	100%	105	0.11986996	0.100183	0.01968696	16.42%
453	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	BHARATPUR	14006	11 KV PHD	14006203	GOUDA SAHI, GHATIKIA	1211DT033	100	MIXED	AMI	Yes	100%	51	0.0709505	0.067957	0.0029935	4.22%
454	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	BHARATPUR	14006	11 KV PHD	14006203	GHATIKIA VILLAGE NO -1	1211DT035	500	MIXED	AMI	Yes	100%	79	0.20064004	0.06765	0.13299004	66.28%
455	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	BHARATPUR	14006	11 KV PHD	14006203	GHATIKIA VILLAGE NO -2	1211DT036	500	MIXED	AMI	Yes	100%	61	0.39943704	0.081423	0.31801404	79.62%
456	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	BHARATPUR	14006	11 KV PHD	14006203	BRAMHAN SAHI GHATIKIA	1211DT042	63	MIXED	AMI	Yes	100%	45	0.08488053	0.053588	0.03129253	36.87%
457	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	BHARATPUR	14006	11 KV PHD	14006203	RATHA S/S GHATIKIA	1211DT045	200	MIXED	AMI	Yes	100%	220	0.20054564	0.175902	0.02464364	12.29%
458	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	BHARATPUR	14006	11 KV PHD	14006203	JAGDISH VILLA GHATIKIA	1211DT048	100	MIXED	AMI	Yes	100%	17	0.03099227	0.029931	0.00106127	3.42%
459	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	BHARATPUR	14006	11 KV PHD	14006203	HILL VIEW APPT. GHATIKIA	1211DT050	250	MIXED	AMI	Yes	0%	17	0.02179156	0.021638	0.00015356	0.70%
460	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	BHARATPUR	14006	11 KV PHD	14006203	UPPAR SAHI GHATIKIA	1211DT051	100	MIXED	AMI	Yes	100%	40	0.04096932	0.040421	0.00054832	1.34%
461	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	BHARATPUR	14006	11 KV SATELITE	14006204	KALAS RESIDENCY SAMPUR	1211DT085	250	MIXED	AMI	Yes	100%	33	0.04092752	0.040904	2.352E-05	0.06%
462	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	BHARATPUR	14006	11 KV SATELITE	14006204	KESHARI APPARTMENT	1211DT086	250	MIXED	AMI	Yes	100%	17	0.03021576	0.011479	0.01873676	62.01%
463	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	BHARATPUR	14006	11 KV SATELITE	14006204	DATTATREYA APPARTMENT	1211DT089	250	MIXED	AMI	Yes	100%	17	0.0202686	0.015701	0.0045676	22.54%
464	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	BHARATPUR	14006	11 KV SATELITE	14006204	MAHALAXMI VIHAR (R-APDRP) SAMP	1211DT090	250	MIXED	AMI	Yes	100%	142	0.18409184	0.14636	0.03773184	20.50%
465	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	BHARATPUR	14006	11 KV SATELITE	14006204	VAISHNAMATA ENCLAVE	1211DT092	250	MIXED	AMI	Yes	100%	23	0.03014616	0.023271	0.00687516	22.81%
466	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	BHARATPUR	14006	11 KV SATELITE	14006204	NEHA PALACE	1211DT093	63	MIXED	AMI	Yes	100%	9	0.01721857	0.007605	0.00961357	55.83%
467	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	BHARATPUR	14006	11 KV SATELITE	14006204	UDHABA BEHERA, SUMPUR	1211DT101	250	MIXED	AMI	Yes	100%	108	0.18678176	0.178339	0.00844276	4.52%
468	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	BHARATPUR	14006	11 KV SATELITE	14006204	SAMPUR BHAI SAHI, SAMPUR	1211DT108	250	MIXED	AMI	Yes	100%	95	0.17909385	0.064077	0.11501685	64.22%
469	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	BHARATPUR	14006	11 KV SATELITE	14006204	CSS HARAPRIYA, SAMPUR	1211DT109	100	MIXED	AMI	Yes	100%	12	0.0112771	0.008307	0.0029701	26.34%
470	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	BHARATPUR	14006	11 KV SATELITE	14006204	GYM KHANA PALM RESIDENCY, SAMI	1211DT110	200	MIXED	AMI	Yes	100%	39	0.10432312	0.088112	0.01621112	15.54%
471	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	BHARATPUR	14006	11 KV SATELITE	14006204	GYM KHANA PALM HEIGHTS, NO-1 SA	1211DT111	500	MIXED	AMI	Yes	100%	67	0.14813336	0.111477	0.03665636	24.75%
472	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	BHARATPUR	14006	11 KV SATELITE	14006204	GYM KHANA PALM HEIGHTS, NO-2 SA	1211DT112	500	MIXED	AMI	Yes	100%	107	0.131888	0.119989	0.011899	9.02%
473	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	BHARATPUR	14006	11 KV SATELITE	14006204	OMM HOMES SAMPUR	1211DT121	500	MIXED	AMI	Yes	67%	52	0.04917408	0.042206	0.00696808	14.17%
474	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	BHARATPUR	14006	11 KV BHARATPUR	14006205	BISWANATH SAHOO, SAMPUR	1211DT201	250	MIXED	AMI	Yes	100%	17	0.00070744	0.000637	7.044E-05	9.96%
475	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	BHARATPUR	14006	11 KV BHARATPUR	14006205	BHARATPUR NO-5, (NEAR SHIVA MAI	1211DT214	500	MIXED	AMI	Yes	100%	643	0.31507432	0.283624	0.03145032	9.98%
476	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	BHARATPUR	14006	11 KV BHARATPUR	14006205	BHARATPUR NO-2, INFRONT OF ITI	1211DT217	250	MIXED	AMI	Yes	0%	234	0.20874205	0.145946	0.06279605	30.08%
477	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	BHARATPUR	14006	11 KV BHARATPUR	14006205	BHARATPUR NO-1, NEAR G. A COLON	1211DT219	250	MIXED	AMI	Yes	100%	201	0.15158988	0.10437	0.04721988	31.15%
478	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	BHARATPUR	14006	11 KV BHARATPUR	14006205	HARAMANI S/S, SAMPUR	1211DT235	500	MIXED	AMI	Yes	100%	288	0.33727888	0.268782	0.06849688	20.31%
479	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	BHARATPUR	14006	11 KV BHARATPUR	14006205	BINA BHARATI, SAMPUR	1211DT237	250	MIXED	AMI	Yes	0%	296	0.2252068	0.124424	0.1007828	44.75%
480	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	BHARATPUR	14006	11 KV BHARATPUR	14006205	RAJESWARI PADHI APPARTMENT, SAI	1211DT239	100	MIXED	AMI	Yes	67%	10	0.00565192	0.003541	0.00211092	37.35%
481	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	BHARATPUR	14006	11 KV BHARATPUR	14006205	SAI VIHAR, SAMPUR	1211DT243	500	MIXED	AMI	Yes	67%	532	0.37630344	0.352298	0.02400544	6.38%
482	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	BHARATPUR	14006	11 KV BHARATPUR	14006205	ODYSSA HOME, ANDHARUA	1211DT252	500	MIXED	AMI	Yes	67%	83	0.06111072	0.050643	0.01046772	17.13%
483	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	BHARATPUR	14006	11 KV BHARATPUR	14006205	MR PRADYMNA KU ROUT	1211DT733	100	MIXED	AMI	Yes	67%	14	0.03798792	0.00964	0.02834792	74.62%
484	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	BHARATPUR	14006	11 KV BHARATPUR	14006205	GIRI GOVARDHAN	1211DT919	100	MIXED	AMI	Yes	67%	6	0.00708652	0.002086	0.00500052	70.56%
485	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	BHARATPUR	14006	11 KV SAMPUR	14006206	AAHAR CENTRE, SUMPUR(L&T)	1211DT061	250	MIXED	AMI	Yes	0%	213	0.34500436	0.289873	0.05513136	15.98%
486	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	BHARATPUR	14006	11 KV SAMPUR	14006206	SAI AVENUE APPARTMENT ,SAMPUR	1211DT063	250	MIXED	AMI	Yes	100%	17	0.02110668	0.017	0.00410668	19.46%
487	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	BHARATPUR	14006	11 KV SAMPUR	14006206	GRANDMARK EXCOTIKA NO-2, SAMP	1211DT065	100	MIXED	AMI	Yes	100%	17	0.0137214	0.009225	0.0044964	32.77%
488	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	BHARATPUR	14006	11 KV SAMPUR	14006206	GRANDMARK EXCOTIKA NO-1, SAMP	1211DT067	100	MIXED	AMI	Yes	0%	11	0.01907046	0.016152	0.00291846	15.30%
489	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	BHARATPUR	14006	11 KV SAMPUR	14006206	K-8(NO NAME) SUMPUR(MANOJ PAI	1211DT072	250	MIXED	AMI	Yes	100%	3	0.04203504	0.041651	0.00038404	0.91%
490	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	BHARATPUR	14006	11 KV SAMPUR	14006206	SAMPUR CAPEX (NEAR PHD)	1211DT073	250	MIXED	AMI	Yes	0%	216	0.2211086	0.187941	0.0331676	15.00%
491	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	BHARATPUR	14006	11 KV SAMPUR	14006206	DEVINE LALINGE APPARTMENT NO-1	1211DT077	250	MIXED	AMI	Yes	100%	22	0.03901614	0.035835	0.00318114	8.15%
492	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	BHARATPUR	14006	11 KV SAMPUR	14006206	DEVINE LALINGE APPARTMENT NO-2	1211DT078	250	MIXED	AMI	Yes	0%	22	0.03250756	0.02377	0.00873756	26.88%
493	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	BHARATPUR	14006	11 KV K-2	14006207	SUESNA APPT., K-1	1211DT265	100	MIXED	AMI	Yes	100%	9	0.00888824	0.007818	0.00107024	12.04%
494	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	BHARATPUR	14006	11 KV K-2	14006207	U-23(SUNSINE ENCLAVE)	1211DT266	100	MIXED	AMI	Yes	100%	10	0.02320035	0.023191	9.35E-06	0.04%
495	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	BHARATPUR	14006	11 KV K-2	14006207	DEVENCLAVE, K_1	1211DT278	100	MIXED	AMI	Yes	100%	7	0.00578598	0.005731	5.498E-05	0.95%
496	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	BHARATPUR	14006	11 KV K-2	14006207	PRADIPTA KUMAR MOHAPATRA	1211DT280	100	MIXED	AMI	Yes	0%	8	0.01223672	0.008446	0.00379072	30.98%
497	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	BHARATPUR	14006	11 KV K-2	14006207	DURGA ENCLAVE, K-1	1211DT281	100	MIXED	AMI	Yes	100%	9	0.01086238	0.007664	0.00319838	29.44%
498	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	BHARATPUR	14006	11 KV K-2	14006207	MANMATH PALACE, PLOT-38, K-1	1211DT286	100	MIXED	AMI	Yes	100%	9	0.01350844	0.012369	0.00113944	8.44%
499	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	BHARATPUR	14006	11 KV K-2	14006207	SARASWATI BUILDERS, C/O-TUSHAR	1211DT290	100	MIXED	AMI	Yes	100%	9	0.01065606	0.010228	0.00042806	4.02%
500	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	BHARATPUR	14006	11 KV K-2	14006207	NARAYAN ENCLAVE, K-1	1211DT291	100	MIXED	AMI	Yes	100%	7	0.01298796	0.009536	0.00345196	26.58%
501	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	BHARATPUR	14006	11 KV K-2	14006207	ANCHAL HOMES, K-1	1211DT293	100	MIXED	AMI	Yes	100%	12	0.0151515	0.011206	0.0039455	26.04%
502	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	BHARATPUR	14006	11 KV K-2	14006207	B. J DEVOLPERS, K-1	1211DT294	100	MIXED	AMI	Yes	100%	7	0.01153054	0.007625	0.00390554	33.87%
503	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	BHARATPUR	14006	11 KV K-2	14006207	DHPL PRIDE	1211DT296	100	MIXED	AMI	Yes	100%	7	0.01005678	0.004471	0.00558578	55.54%
504	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	BHARATPUR	14006	11 KV K-2	14006207	SHIV DARSHAN, (GASTRO FRONT)	1211DT297	100	MIXED	AMI	Yes	100%	9	0.01015978	0.005907	0.00425278	41.86%
505	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	BHARATPUR	14006	11 KV K-2	14006207	JAYASHREE ENCLAVE, K-1(ORCHID-5)	1211DT299	100	MIXED	AMI	Yes	100%	11	0.00780745	0.007576	0.00023145	2.96%
506	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	BHARATPUR	14006	11 KV K-2	14006207	GRANDMARK EXCOTIKA -4	1211DT300	100	MIXED	AMI	Yes	67%	13	0.01484844	0.010703	0.00414544	27.92%
507	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	BHARATPUR	14006	11 KV K-2	14006207	FRONT HOME -21 , K-1	1211DT303	100	MIXED	AMI	Yes	100%	7	0.00660748	0.005777	0.00083048	12.57%
508	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	BHARATPUR	14006	11 KV K-2	14006207	BHABISHYA HOMES, PLOT NO -55, K-	1211DT304	100	MIXED	AMI	Yes	100%	8	0.00789942	0.007431	0.00046842	5.93%
509	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	BHARATPUR	14006	11 KV K-2	14006207	KOUSTAVA APPT., K-1(KASTURIKA)	1211DT309	100	MIXED	AMI	Yes	100%	13	0.012681	0.008113	0.004568	36.02%
510	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	BHARATPUR	14006	11 KV K-2	14006207	NIGAM ENCLAVE(PATITAPABAN BHU	1211DT310	100	MIXED	AMI	Yes	100%	13	0.01158824	0.008902	0.00268624	23.18%

Sl. No.	Zone Name	Circle name	Division name	Name of the Sub-division	Name of the Sub-station	Substation Code	Name of the 11 kV Feeder	Feeder Code	Name of the Location where DT situated	DT code	DT Capacity (kVA)	Predominant consumer type of DT (Domestic/Industrial/Agriculture/Mixed)	Type of metering AMR/AMI/ Communicable/Conventional metered/Unmetered	Status of Meter- whether Functional (Yes/No)	% of data received automatically (if AMR/AMI)	No. of Connected Consumers	Input Energy (MU) (A)	Billed Energy (MU) (B)	Loss (MU) (A-B)	% DT Loss (A-B)/A
511	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	BHARATPUR	14006	11 KV K-2	14006207	SAI HOMETECH, (ASRIYA HOME)	1211DT312	100	MIXED	AMI	Yes	100%	6	0.00883636	0.005985	0.00285136	32.27%
512	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	BHARATPUR	14006	11 KV K-2	14006207	ALEEVA HOME, K-1	1211DT313	100	MIXED	AMI	Yes	100%	8	0.01202952	0.00836	0.00366952	30.50%
513	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	BHARATPUR	14006	11 KV K-2	14006207	SHREE SAI TOWER, C/O-P.T BHUYAN	1211DT314	100	MIXED	AMI	Yes	100%	13	0.01104086	0.008513	0.00252786	22.90%
514	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	BHARATPUR	14006	11 KV K-2	14006207	NITASHA VALLEY, MALIPADA	1211DT333	250	MIXED	AMI	Yes	100%	33	0.05991296	0.05555	0.00436296	7.28%
515	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	BHARATPUR	14006	11 KV K-2	14006207	MALIPADA (NEAR KUNA BABU HOUS	1211DT334	100	MIXED	AMI	Yes	0%	13	0.02326942	0.015054	0.00821542	35.31%
516	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	BHARATPUR	14006	11 KV K-2	14006207	SAI SHREE DUPLEX, C/O-ROKKAM, MA	1211DT337	100	MIXED	AMI	Yes	100%	7	0.01269504	0.008327	0.00436804	34.41%
517	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	BHARATPUR	14006	11 KV K-2	14006207	MALIPADA VILLAGE	1211DT339	250	MIXED	AMI	Yes	0%	221	0.18496324	0.176426	0.00853724	4.62%
518	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	BHARATPUR	14006	11 KV K-2	14006207	KAUMUDI APPT. K-1	1211DT342	100	MIXED	AMI	Yes	100%	14	0.01585384	0.006333	0.00952084	60.05%
519	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	BHARATPUR	14006	11 KV K-2	14006207	TRINITY GREEN	1211DT345	500	MIXED	AMI	Yes	100%	53	0.0906576	0.075145	0.0155126	17.11%
520	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	BHARATPUR	14006	11 KV K-2	14006207	SIDHI VINAYAK, PLOT NO-400, K-1	1211DT349	100	MIXED	AMI	Yes	100%	8	0.01207506	0.00639	0.00568506	47.08%
521	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	BHARATPUR	14006	11 KV K-2	14006207	AURU VILLA -2 , K-1	1211DT350	100	MIXED	AMI	Yes	100%	9	0.01122774	0.007919	0.00330874	29.47%
522	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	BHARATPUR	14006	11 KV K-2	14006207	SHRI JAGANNATH CONSTRUCTION	1211DT351	100	MIXED	AMI	Yes	100%	11	0.00942362	0.006556	0.00286762	30.43%
523	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	BHARATPUR	14006	11 KV K-2	14006207	UMESH KHANDELWAL	1211DT353	100	MIXED	AMI	Yes	100%	6	0.00645122	0.006075	0.00037622	5.83%
524	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	BHARATPUR	14006	11 KV K-2	14006207	BDA HOUSING PROJECT,1531,PAIKAR	1211DT355	500	MIXED	AMI	Yes	100%	95	0.05040204	0.038796	0.01160604	23.03%
525	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	BHARATPUR	14006	11 KV K-2	14006207	BDA HOUSING PROJECT,1531,PAIKAR	1211DT356	500	MIXED	AMI	Yes	100%	99	0.03980356	0.038606	0.00119756	3.01%
526	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	BHARATPUR	14006	11 KV K-2	14006207	IXORA MANSOON, K-2	1211DT358	250	MIXED	AMI	Yes	100%	17	0.01472856	0.014299	0.00042956	2.92%
527	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	BHARATPUR	14006	11 KV K-2	14006207	J. B. RESIDENCY, K-2	1211DT361	250	MIXED	AMI	Yes	100%	14	0.0387738	0.011196	0.0275778	71.12%
528	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	BHARATPUR	14006	11 KV K-2	14006207	SANDEEP KUMAR PANDA, GOKUL HO	1211DT661	100	MIXED	AMI	Yes	100%	9	0.01208728	0.012055	3.228E-05	0.27%
529	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	BHARATPUR	14006	11 KV K-2	14006207	AURU VILLA -4	1211DT709	100	MIXED	AMI	Yes	33%	13	0.01130084	0.009301	0.00199984	17.70%
530	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	BHARATPUR	14006	11 KV K-2	14006207	GRANDMARK EXOTICA-6	1211DT731	100	MIXED	AMI	Yes	0%	9	0.01362716	0.009787	0.00384016	28.18%
531	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	BHARATPUR	14006	11 KV K-2	14006207	NILANCHAL HOMES	1211DT734	100	MIXED	AMI	Yes	100%	9	0.0125859	0.012392	0.0001939	1.54%
532	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	BHARATPUR	14006	11 KV K-2	14006207	RADHA GOBINDA FUTURE SOLUTION	1211DT735	100	MIXED	AMI	Yes	100%	11	0.01117772	0.011114	6.372E-05	0.57%
533	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	BHARATPUR	14006	11 KV K-2	14006207	JAGANNATH AVENUE	1211DT736	100	MIXED	AMI	Yes	100%	10	0.0100469	0.009781	0.0002659	2.65%
534	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	BHARATPUR	14006	11 KV K-2	14006207	ODITECH MOON	1211DT772	100	MIXED	AMI	Yes	100%	17	0.01488644	0.011847	0.00303944	20.42%
535	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	BHIMATANGI	14018	11 KV POKHARIPUT-1	14018201	ABHIRAM NAGAR	1322DT171	100	MIXED	AMI	Yes	67%	159	0.10916878	0.066112	0.04305678	39.44%
536	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	CS PUR-2	14002	11 KV CSPUR BDA -1	14002201	MAHAVIR BASTI	1233DT176	100	MIXED	AMI	Yes	100%	169	0.0530608	0.040077	0.0129838	24.47%
537	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	DUMDUMA ODSSP	14236	11 KV HOUSING BOARD	14236201	PHASE 6 NO 1	1212DT063	500	MIXED	AMI	Yes	67%	55	0.07424808	0.065844	0.00840408	11.32%
538	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	DUMDUMA ODSSP	14236	11 KV HOUSING BOARD	14236201	PHASE 6 NO 3	1212DT065	500	MIXED	AMI	Yes	67%	68	0.07241224	0.066387	0.00602524	8.32%
539	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	DUMDUMA ODSSP	14236	11 KV HOUSING BOARD	14236201	NEAR 1356 PHASE 2	1212DT066	100	MIXED	AMI	Yes	33%	83	0.113	0.084659	0.028341	25.08%
540	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	DUMDUMA ODSSP	14236	11 KV HOUSING BOARD	14236201	PHASE 1 (NEAR DDL,DDHB COLONY 1	1212DT076	500	MIXED	AMI	Yes	0%	318	0.2494208	0.223424	0.0259968	10.42%
541	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	DUMDUMA ODSSP	14236	11 KV HOUSING BOARD	14236201	PHASE 1 (NEAR DDHB COLONY 292)	1212DT078	500	MIXED	AMI	Yes	100%	240	0.19547272	0.176522	0.01895072	9.69%
542	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	DUMDUMA ODSSP	14236	11 KV HOUSING BOARD	14236201	JADUPUR,BEGUNIA HELP CLUB (BPL)	1212DT089	200	MIXED	AMI	Yes	0%	161	0.187238	0.123499	0.063739	34.04%
543	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	DUMDUMA ODSSP	14236	11 KV HOUSING BOARD	14236201	JADUPUR VILLAGE (NEAR JAFIR SIR)	1212DT095	500	MIXED	AMI	Yes	100%	219	0.28668112	0.226231	0.06045012	21.09%
544	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	DUMDUMA ODSSP	14236	11 KV HOUSING BOARD	14236201	PHASE-7NO-1 SUDARSHAN ENCLAVE	1212DT173	500	MIXED	AMI	Yes	0%	95	0.07270456	0.050364	0.02234056	30.73%
545	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	DUMDUMA ODSSP	14236	11 KV HOUSING BOARD	14236201	PHASE-7NO-3 SUDARSHAN ENCLAVE	1212DT175	500	MIXED	AMI	Yes	0%	98	0.07234184	0.051157	0.02118484	29.28%
546	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	DUMDUMA ODSSP	14236	11 KV HOUSING BOARD	14236201	PHASE -7 NO-5 SUDARSHAN ENCLAVI	1212DT178	500	MIXED	AMI	Yes	0%	97	0.04048136	0.025136	0.01534536	37.91%
547	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	DUMDUMA ODSSP	14236	11 KV PANCHASAKHA NA	14236202	CHINTAMANI VIHAR NO-1	1212DT015	500	MIXED	AMI	Yes	100%	193	0.35268024	0.273508	0.07917224	22.45%
548	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	DUMDUMA ODSSP	14236	11 KV PANCHASAKHA NA	14236202	ARCHANA ENCLAVE (OK)	1212DT018	100	MIXED	AMI	Yes	0%	56	0.1112682	0.059348	0.0519202	46.66%
549	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	DUMDUMA ODSSP	14236	11 KV PANCHASAKHA NA	14236202	PANCHASAKHA NAGAR NO 1(PARMA	1212DT019	500	MIXED	AMI	Yes	100%	100	0.16066374	0.12409	0.03657374	22.76%
550	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	DUMDUMA ODSSP	14236	11 KV PANCHASAKHA NA	14236202	KL SIR NO 2	1212DT021	500	MIXED	AMI	Yes	100%	171	0.30234816	0.271388	0.03096016	10.24%
551	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	DUMDUMA ODSSP	14236	11 KV PANCHASAKHA NA	14236202	PDN	1212DT030	500	MIXED	AMI	Yes	100%	53	0.07543848	0.06305	0.01238848	16.42%
552	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	DUMDUMA ODSSP	14236	11 KV PANCHASAKHA NA	14236202	MARS VILLA	1212DT034	250	MIXED	AMI	Yes	100%	18	0.02510144	0.022771	0.00233044	9.28%
553	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	DUMDUMA ODSSP	14236	11 KV ASIAN PLAZA	14236203	PIPE FACTORY	1214DT160	250	MIXED	AMI	Yes	100%	48	0.10245616	0.083481	0.01897516	18.52%
554	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	DUMDUMA ODSSP	14236	11 KV ASIAN PLAZA	14236203	ASIAN PLAZA NO-1	1214DT170	500	MIXED	AMI	Yes	0%	192	0.50241208	0.24563	0.25678208	51.11%
555	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	DUMDUMA ODSSP	14236	11 KV ASIAN PLAZA	14236203	ASIAN PLAZA NO-2	1214DT171	100	MIXED	AMI	Yes	100%	59	0.09493478	0.081576	0.01335878	14.07%
556	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	DUMDUMA ODSSP	14236	11 KV ASIAN PLAZA	14236203	M.S NAGAR	1214DT175	500	MIXED	AMI	Yes	67%	100	0.1777008	0.168986	0.0087148	4.90%
557	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	DUMDUMA ODSSP	14236	11 KV ASIAN PLAZA	14236203	CONVEVIEW BUGFLOW	1214DT179	100	MIXED	AMI	Yes	0%	9	0.04279238	0.009348	0.03344438	78.15%
558	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	DUMDUMA ODSSP	14236	11 KV ASIAN PLAZA	14236203	SEKHARA GARDEN	1214DT186	500	MIXED	AMI	Yes	100%	39	0.05702384	0.044354	0.01266984	22.22%
559	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	DUMDUMA ODSSP	14236	11 KV BEGUNIA	14236204	DURGA PUJA MANDAP	1212DT002	100	MIXED	AMI	Yes	0%	22	0.03402394	0.016905	0.01711894	50.31%
560	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	DUMDUMA ODSSP	14236	11 KV BEGUNIA	14236204	JAGANNATH MANDIR PHASE 2 (DDHE	1212DT004	500	MIXED	AMI	Yes	100%	340	0.41531184	0.33522	0.08009184	19.28%
561	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	DUMDUMA ODSSP	14236	11 KV BEGUNIA	14236204	PHASE 5 NO-1 DDHB COLONY	1212DT006	500	MIXED	AMI	Yes	100%	223	0.26879696	0.226344	0.04245296	15.79%
562	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	DUMDUMA ODSSP	14236	11 KV BEGUNIA	14236204	BASARA COMPLEX NO-1	1212DT036	250	MIXED	AMI	Yes	100%	23	0.02600108	0.019236	0.00676508	26.02%
563	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	DUMDUMA ODSSP	14236	11 KV BEGUNIA	14236204	BASARA COMPLEX NO-2	1212DT037	250	MIXED	AMI	Yes	0%	71	0.11096472	0.106775	0.00418972	3.78%
564	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	DUMDUMA ODSSP	14236	11 KV BEGUNIA	14236204	ARJUN DIPO	1212DT046	250	MIXED	AMI	Yes	0%	178	0.18778792	0.143534	0.04425392	23.57%
565	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	DUMDUMA ODSSP	14236	11 KV BEGUNIA	14236204	BEGUNIA VILLAGE (OLD)	1212DT054	100	MIXED	AMI	Yes	33%	36	0.06088738	0.033939	0.02694838	44.26%
566	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	DUMDUMA ODSSP	14236	11 KV BEGUNIA	14236204	BEGUNIA NO-2 CAPEX	1212DT055	250	MIXED	AMI	Yes	100%	126	0.15906872	0.12085	0.03821872	24.03%
567	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	DUMDUMA ODSSP	14236	11 KV BEGUNIA	14236204	NARAYANI APPARTMENT	1212DT059	100	MIXED	AMI	Yes	100%	15	0.01385954	0.01312	0.00073954	5.34%
568	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	DUMDUMA ODSSP	14236	11 KV BEGUNIA	14236204	ASBM 2	1212DT062	500	MIXED	AMI	Yes	100%	16	0.15183624	0.038883	0.11295324	74.39%
569	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	GOTHAPATNA ODSS	14237	11 KV NUAGAON	14237202	GOTHAPATNA VILLAGE	1211DT450	250	MIXED	AMI	Yes	100%	142	0.16102236	0.136271	0.02475136	15.37%
570	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	GOTHAPATNA ODSS	14237	11 KV NUAGAON	14237202	MANORAMA ENCLAVE, GOTHAPATN	1211DT452	250	MIXED	AMI	Yes	100%	22	0.04562624	0.013252	0.03237424	70.96%
571	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	GOTHAPATNA ODSS	14237	11 KV NUAGAON	14237202	MANTRA MANNOR (A), GOTHAPATN	1211DT454	500	MIXED	AMI	Yes	100%	70	0.08943	0.070298	0.019132	21.39%
572	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	GOTHAPATNA ODSS	14237	11 KV NUAGAON	14237202	GOTHAPATNA VILLAGE (R- APDRP)	1211DT457	250	MIXED	AMI	Yes	0%	161	0.19900848	0.133678	0.06533048	32.83%
573	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	GOTHAPATNA ODSS	14237	11 KV NUAGAON	14237202	SAI PRATIK APPARTMENT, GOTHPATI	1211DT458	500	MIXED	AMI	Yes	100%	11	0.0616192	0.017788	0.0438312	71.13%
574	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	GOTHAPATNA ODSS	14237	11 KV NUAGAON	14237202	SHREE VILLA APPARTMENT, GOTHAP	1211DT459	250	MIXED	AMI	Yes	100%	10	0.01958744	0.012461	0.00712644	36.38%
575	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	GOTHAPATNA ODSS	14237	11 KV NUAGAON	14237202	SAI SUDHA APPARTMENT, GOTHAPA	1211DT461	500	MIXED	AMI	Yes	100%	30	0.02746184	0.025064	0.00239784	8.73%
576	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	GOTHAPATNA ODSS	14237	11 KV NUAGAON	14237202	ANKITA VILLA, GOTHAPATNA	1211DT471	250	MIXED	AMI	Yes	100%	55	0.068595	0.053671	0.014924	21.76%
577	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	GOTHAPATNA ODSS	14237	11 KV NUAGAON	14237202	SAI SOMU HERITATE,SAYAN REALITY	1211DT478	250	MIXED	AMI	Yes	100%	48	0.06929988	0.046308	0.02299188	33.18%
578	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	GOTHAPATNA ODSS	14237	11 KV NUAGAON	14237202	SAI RESIDENCY, GOTHPATNA	1211DT480	250	MIXED	AMI	Yes	100%	35	0.03167256	0.023189	0.00848356	26.79%
579	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	GOTHAPATNA ODSS	14237	11 KV NUAGAON	14237202	NIBEDITA DAS (AKANKSHA AVENUE).	1211DT483	250	MIXED	AMI	Yes	0%	11	0.0180308	0.00523	0.0128008	70.99%
580	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	GOTHAPATNA ODSS	14237	11 KV NUAGAON	14237202	AMBIENCE APPARMENT, DREAM MA	1211DT488	250	MIXED	AMI	Yes	100%	37	0.04848656	0.043901	0.00458556	9.46%
581	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	GOTHAPATNA ODSS	14237	11 KV NUAGAON	14237202	LOTUS AVENUE, GOTHPATNA NO 2	1211DT493	500	MIXED	AMI	Yes	100%	24	0.06163712	0.03004	0.03159712	51.26%
582	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	GOTHAPATNA ODSS	14237	11 KV NUAGAON	14237202	DINABANDHU DAS, MALIPADA	1211DT495	100	MIXED	AMI	Yes	100%	69	0.09957872	0.084827	0.01475172	14.81%
583	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	GOTHAPATNA ODSS	14237	11 KV NUAGAON	14237202	SAUVAGYA ENCLAVE 200 M NEAR	1211DT505	100	MIXED	AMI	Yes	100%	15	0.02500104	0.012172	0.01282904	51.31%

Sl. No.	Zone Name	Circle name	Division name	Name of the Sub-division	Name of the Sub-station	Substation Code	Name of the 11 kV Feeder	Feeder Code	Name of the Location where DT situated	DT code	DT Capacity (kVA)	Predominant consumer type of DT (Domestic/Industrial/Agriculture/Mixed)	Type of metering AMR/AMI/ Communicable/Conventional metered/Unmetered	Status of Meter-whether Functional (Yes/No)	% of data received automatically (if AMR/AMI)	No. of Connected Consumers	Input Energy (MU) (A)	Billed Energy (MU) (B)	Loss (MU) (A-B)	% DT Loss (A-B)/A
584	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	GOTHAPATNA ODSS	14237	11 KV NUAGAON	14237202	D. B MANSOON APPATMENT, MALIP/	1211DT507	100	MIXED	AMI	Yes	100%	11	0.01560476	0.011354	0.00425076	27.24%
585	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	GOTHAPATNA ODSS	14237	11 KV NUAGAON	14237202	KADAMBIBI ENCLAVE	1211DT517	250	MIXED	AMI	Yes	100%	20	0.0298072	0.017805	0.0120022	40.27%
586	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	GOTHAPATNA ODSS	14237	11 KV NUAGAON	14237202	SP AANGAN	1211DT519	100	MIXED	AMI	Yes	100%	7	0.011301	0.005798	0.005503	48.69%
587	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	GOTHAPATNA ODSS	14237	11 KV NUAGAON	14237202	ADITYA PARK CONSTRUCTION, GOTH	1211DT664	500	MIXED	AMI	Yes	100%	28	0.0274336	0.026587	0.0008466	3.09%
588	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	GOTHAPATNA ODSS	14237	11 KV NUAGAON	14237202	ACHYUTANANDA RESIDENCY-1	1211DT804	500	MIXED	AMI	Yes	100%	36	0.04194104	0.034797	0.00714404	17.03%
589	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	GOTHAPATNA ODSS	14237	11 KV NUAGAON	14237202	AVENEW REALCON	1211DT876	100	MIXED	AMI	Yes	100%	10	0.00848718	0.008487	1.8E-07	0.00%
590	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	GOTHAPATNA ODSS	14237	11 KV PAIKRAYPUR	14237203	SUBHOLAXMI ARYA APPT.	1211DT416	250	MIXED	AMI	Yes	100%	9	0.0245856	0.007822	0.0167636	68.18%
591	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	GOTHAPATNA ODSS	14237	11 KV PAIKRAYPUR	14237203	GANGA PATNA VILL. (RGGVY)	1211DT426	100	MIXED	AMI	Yes	100%	89	0.09161007	0.050693	0.04091707	44.66%
592	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	GOTHAPATNA ODSS	14237	11 KV PAIKRAYPUR	14237203	GANGYA PATNA VILLAGE	1211DT430	100	MIXED	AMI	Yes	100%	114	0.10528875	0.068163	0.03712575	35.26%
593	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	GOTHAPATNA ODSS	14237	11 KV GODIBARI	14237204	KANTABADA NUASAHI	1211DT532	100	MIXED	AMI	Yes	100%	130	0.08800276	0.064909	0.02309376	26.24%
594	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	GOTHAPATNA ODSS	14237	11 KV GODIBARI	14237204	KANTABADA VILLEDGE(R-APDRP),BIT	1211DT536	100	MIXED	AMI	Yes	100%	115	0.09585434	0.086031	0.00982334	10.25%
595	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	GOTHAPATNA ODSS	14237	11 KV GODIBARI	14237204	HILL VIEW RESORTS(JAYASHREE HOM	1211DT548	500	MIXED	AMI	Yes	67%	64	0.05230776	0.037611	0.01469676	28.10%
596	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	GOTHAPATNA ODSS	14237	11 KV GODIBARI	14237204	HILL VIEW RESORTS(JAYASHREE HOM	1211DT549	500	MIXED	AMI	Yes	100%	44	0.0518486	0.030825	0.0210236	40.55%
597	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	GOTHAPATNA ODSS	14237	11 KV GODIBARI	14237204	KANTABADA VILLAGE	1211DT560	250	MIXED	AMI	Yes	100%	296	0.1742824	0.149711	0.0245714	14.10%
598	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	GOTHAPATNA ODSS	14237	11 KV GODIBARI	14237204	JENA SAHI, KANTABADA	1211DT563	100	MIXED	AMI	Yes	100%	126	0.08310253	0.06557	0.01753253	21.10%
599	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	GOTHAPATNA ODSS	14237	11 KV GODIBARI	14237204	ACRUX REALCON,GOTHAPATNA NO-I	1211DT584	500	MIXED	AMI	Yes	100%	96	0.08437728	0.076411	0.00796628	9.44%
600	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	GOTHAPATNA ODSS	14237	11 KV GODIBARI	14237204	ACRUX REALCON,GOTHAPATNA NO-I	1211DT586	500	MIXED	AMI	Yes	100%	94	0.07871024	0.050917	0.02779324	35.31%
601	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	GOTHAPATNA ODSS	14237	11 KV GODIBARI	14237204	ACRUX REALCON,GOTHAPATNA NO-I	1211DT587	500	MIXED	AMI	Yes	100%	132	0.07981776	0.059568	0.02024976	25.37%
602	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	GOTHAPATNA ODSS	14237	11 KV GODIBARI	14237204	ACRUX REALCON,GOTHAPATNA NO-\	1211DT590	500	MIXED	AMI	Yes	100%	92	0.10468312	0.046936	0.05774712	55.16%
603	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	GOTHAPATNA ODSS	14237	11 KV GODIBARI	14237204	KATENI VILLEDGE	1211DT592	100	MIXED	AMI	Yes	100%	107	0.09879126	0.069665	0.02912626	29.48%
604	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	GOTHAPATNA ODSS	14237	11 KV GODIBARI	14237204	SAI ANAND APT.	1211DT613	250	MIXED	AMI	Yes	100%	36	0.02548852	0.024268	0.00122052	4.79%
605	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	GOTHAPATNA ODSS	14237	11 KV GODIBARI	14237204	IRANI MOHANTY	1211DT858	100	MIXED	AMI	Yes	100%	6	0.01013698	0.008188	0.00194898	19.23%
606	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	KALINGA NAGAR	14007	11 KV K-9	14007201	SUBASHNAGARBASTI NO1	1212DT140	250	MIXED	AMI	Yes	100%	166	0.24710357	0.06215	0.18495357	74.85%
607	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	KALINGA NAGAR	14007	11 KV K-9	14007201	R.K STEEL CHOWK	1213DT067	100	MIXED	AMI	Yes	100%	32	0.09829776	0.03707	0.06122776	62.29%
608	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	KALINGA NAGAR	14007	11 KV K-9	14007201	MP LAD	1213DT073	250	MIXED	AMI	Yes	100%	54	0.21028924	0.061269	0.14902024	70.86%
609	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	KALINGA NAGAR	14007	11 KV K-9	14007201	SAI KRUPA	1213DT074	100	MIXED	AMI	Yes	0%	10	0.010566	0.006095	0.004471	42.31%
610	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	KALINGA NAGAR	14007	11 KV K-9	14007201	BIJAY KUMAR PANDA	1213DT075	250	MIXED	AMI	Yes	100%	3	0.02341972	0.02341	9.72E-06	0.04%
611	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	KALINGA NAGAR	14007	11 KV K-9	14007201	HARSPRIYA APT	1213DT076	250	MIXED	AMI	Yes	100%	9	0.02282428	0.006268	0.01655628	72.54%
612	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	KALINGA NAGAR	14007	11 KV K-9	14007201	UTPAL APT	1213DT082	250	MIXED	AMI	Yes	100%	12	0.03406656	0.011305	0.02276156	66.81%
613	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	KALINGA NAGAR	14007	11 KV K-9	14007201	ARUNDATHI RESIDENCY	1213DT086	100	MIXED	AMI	Yes	0%	8	0.0047834	0.004007	0.0007764	16.23%
614	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	KALINGA NAGAR	14007	11 KV K-9	14007201	SURAVI VENTURE	1213DT088	100	MIXED	AMI	Yes	0%	18	0.0185277	0.017996	0.0005317	2.87%
615	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	KALINGA NAGAR	14007	11 KV K-9	14007201	SAIPARADISE RESIDENCY	1213DT089	250	MIXED	AMI	Yes	100%	11	0.02079532	0.01018	0.01061532	51.05%
616	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	KALINGA NAGAR	14007	11 KV K-9	14007201	SRIMAA ENCLAVE	1213DT095	100	MIXED	AMI	Yes	100%	12	0.0170274	0.015342	0.0016854	9.90%
617	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	KALINGA NAGAR	14007	11 KV K-9	14007201	IMARAT TRINATH PLAZA	1213DT096	250	MIXED	AMI	Yes	100%	25	0.0292194	0.027603	0.0016164	5.53%
618	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	KALINGA NAGAR	14007	11 KV K-9	14007201	A.MOHAPRASAD V.2	1213DT098	500	MIXED	AMI	Yes	100%	6	0.11009824	0.105138	0.00496024	4.51%
619	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	KALINGA NAGAR	14007	11 KV K-9	14007201	SHRI KRISHNA PLAZA	1213DT104	500	MIXED	AMI	Yes	100%	13	0.06041168	0.055225	0.00518668	8.59%
620	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	KALINGA NAGAR	14007	11 KV K-9	14007201	SUVAM HOMES	1213DT109	250	MIXED	AMI	Yes	100%	25	0.03247546	0.030962	0.00151346	4.66%
621	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	KALINGA NAGAR	14007	11 KV K-9	14007201	ASHOK SAHOO	1213DT114	100	MIXED	AMI	Yes	0%	4	0.02061022	0.020593	1.722E-05	0.08%
622	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	KALINGA NAGAR	14007	11 KV K-9	14007201	PURUSHOTTAM ENCLAVES	1213DT117	250	MIXED	AMI	Yes	100%	6	0.0161206	0.00415	0.0119706	74.26%
623	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	KALINGA NAGAR	14007	11 KV K-9	14007201	K-9A NEAR BELABANIA MIG-107	1213DT120	250	MIXED	AMI	Yes	100%	150	0.1864782	0.182631	0.0038472	2.06%
624	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	KALINGA NAGAR	14007	11 KV K-9	14007201	KALINGA VIHAR NEAR MASANI	1213DT122	500	MIXED	AMI	Yes	0%	75	0.12110824	0.094734	0.02637424	21.78%
625	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	KALINGA NAGAR	14007	11 KV K-9	14007201	K9 A, PHD	1213DT123	250	MIXED	AMI	Yes	100%	162	0.28148824	0.202753	0.07873524	27.97%
626	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	KALINGA NAGAR	14007	11 KV K-5	14007202	SUDHANSU SEKHAR MOHAPATRA	1211DT732	100	MIXED	AMI	Yes	100%	16	0.0130441	0.011529	0.0015151	11.62%
627	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	KALINGA NAGAR	14007	11 KV K-5	14007202	K-5,NEAR HIG-255	1213DT159	250	MIXED	AMI	Yes	100%	77	0.13126316	0.114324	0.01693916	12.90%
628	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	KALINGA NAGAR	14007	11 KV K-5	14007202	NEAR BANADURGA TEMPLE	1213DT160	500	MIXED	AMI	Yes	100%	89	0.13778112	0.111832	0.02594912	18.83%
629	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	KALINGA NAGAR	14007	11 KV K-5	14007202	CITY HOME	1213DT167	500	MIXED	AMI	Yes	100%	54	0.05676984	0.055627	0.00114284	2.01%
630	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	KALINGA NAGAR	14007	11 KV K-5	14007202	SIJIPUT VILLAGE	1213DT171	250	MIXED	AMI	Yes	100%	236	0.25797904	0.182968	0.07501104	29.08%
631	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	KALINGA NAGAR	14007	11 KV K-5	14007202	(RAPDRP)K-4 NEAR LIG-1509	1213DT175	250	MIXED	AMI	Yes	100%	173	0.19107863	0.151417	0.03966163	20.76%
632	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	KALINGA NAGAR	14007	11 KV K-5	14007202	RK MANSION	1213DT177	250	MIXED	AMI	Yes	0%	21	0.01935452	0.018863	0.00049152	2.54%
633	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	KALINGA NAGAR	14007	11 KV K-5	14007202	K4 NEAR LIG-1005	1213DT200	500	MIXED	AMI	Yes	100%	242	0.33951416	0.218744	0.12077016	35.57%
634	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	KALINGA NAGAR	14007	11 KV K-5	14007202	NIRMALYA ENCLAVE	1213DT203	250	MIXED	AMI	Yes	67%	19	0.01731092	0.016839	0.00047192	2.73%
635	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	KALINGA NAGAR	14007	11 KV K-5	14007202	BACK SIDE OF TATA	1213DT218	250	MIXED	AMI	Yes	100%	121	0.16744208	0.151188	0.01625408	9.71%
636	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	KALINGA NAGAR	14007	11 KV K-5	14007202	K-7 PHD	1213DT227	500	MIXED	AMI	Yes	0%	271	0.36310456	0.342112	0.02099256	5.78%
637	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	KALINGA NAGAR	14007	11 KV K-5	14007202	A ONE MA SION	1213DT232	100	MIXED	AMI	Yes	0%	19	0.01720002	0.016768	0.00043202	2.51%
638	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	KALINGA NAGAR	14007	11 KV K-5	14007202	K-3 PHD	1213DT235	250	MIXED	AMI	Yes	0%	43	0.1509148	0.074523	0.0763918	50.62%
639	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	KALINGA NAGAR	14007	11 KV K-5	14007202	BDA HOUSING-4	1213DT245	500	MIXED	AMI	Yes	100%	49	0.0468704	0.043489	0.0033814	7.21%
640	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	KALINGA NAGAR	14007	11 KV K-5	14007202	SANKARPUR MANDATA	1213DT251	63	MIXED	AMI	Yes	100%	52	0.060415	0.044164	0.016251	26.90%
641	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	KALINGA NAGAR	14007	11 KV K-5	14007202	K-6B NEAR HIG-59	1213DT253	250	MIXED	AMI	Yes	100%	214	0.28228524	0.229035	0.05325024	18.86%
642	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	KALINGA NAGAR	14007	11 KV K-5	14007202	ALISHAN CONSULTANCY	1213DT639	500	MIXED	AMI	Yes	100%	6	0.0241328	0.005405	0.0187278	77.60%
643	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	KALINGA NAGAR	14007	11 KV OG-1 RMU (INDUS	14007203	ROYAL SRIMATI RESIDENCY	1213DT387	100	MIXED	AMI	Yes	0%	13	0.01576682	0.014687	0.00107982	6.85%
644	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	KALINGA NAGAR	14007	11 KV OG-1 RMU (INDUS	14007203	UDAY APPT.	1213DT391	100	MIXED	AMI	Yes	0%	12	0.01405438	0.012904	0.00115038	8.19%
645	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	KALINGA NAGAR	14007	11 KV OG-1 RMU (INDUS	14007203	RAPDRP PATRAPADA CHOWK	1213DT392	250	MIXED	AMI	Yes	100%	102	0.17870558	0.118261	0.06044458	33.82%
646	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	KALINGA NAGAR	14007	11 KV OG-1 RMU (INDUS	14007203	UDAYAGIRI VIHAR ROAD	1213DT406	250	MIXED	AMI	Yes	0%	24	0.03097236	0.02352	0.00745236	24.06%
647	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	KALINGA NAGAR	14007	11 KV OG-1 RMU (INDUS	14007203	SHRADHA SABURI	1213DT407	250	MIXED	AMI	Yes	0%	9	0.02869164	0.007384	0.02130764	74.26%
648	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	KALINGA NAGAR	14007	11 KV OG-1 RMU (INDUS	14007203	S.R RESIDENCY	1213DT414	250	MIXED	AMI	Yes	0%	21	0.0380186	0.016194	0.0218246	57.41%
649	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	KALINGA NAGAR	14007	11 KV OG-1 RMU (INDUS	14007203	KUNJAL GARDEN	1213DT415	100	MIXED	AMI	Yes	0%	24	0.03491104	0.022245	0.01266604	36.28%
650	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	KALINGA NAGAR	14007	11 KV OG-1 RMU (INDUS	14007203	SAI GOURANGA	1213DT417	500	MIXED	AMI	Yes	100%	47	0.04297896	0.041601	0.00137796	3.21%
651	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	KALINGA NAGAR	14007	11 KV OG-1 RMU (INDUS	14007203	KALYANI HOMES	1213DT420	500	MIXED	AMI	Yes	100%	36	0.04560696	0.034583	0.01102396	24.17%
652	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	KALINGA NAGAR	14007	11 KV OG-1 RMU (INDUS	14007203	SHREYA PALACE	1213DT421	500	MIXED	AMI	Yes	33%	44	0.06719432	0.030753	0.03644132	54.23%
653	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	KALINGA NAGAR	14007	11 KV OG-1 RMU (INDUS	14007203	PATRAPADA NEAR SRI ITC	1213DT427	250	MIXED	AMI	Yes	100%	241	0.23762848	0.220283	0.01734548	7.30%
654	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	KALINGA NAGAR	14007	11 KV OG-1 RMU (INDUS	14007203	MINAT ENCLAVE	1213DT429	100	MIXED	AMI	Yes	100%	19	0.01595052	0.01206	0.00389052	24.39%
655	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	KALINGA NAGAR	14007	11 KV OG-1 RMU (INDUS	14007203	SAI HEMALATA	1213DT430	100	MIXED	AMI	Yes	100%	11	0.01363112	0.011352	0.00227912	16.72%
656	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	KALINGA NAGAR	14007	11 KV OG-1 RMU (INDUS	14007203	PARAS RESIDENCY	1213DT432	250	MIXED	AMI	Yes	0%	16	0.01323984	0.012074	0.00116584	8.81%

Sl. No.	Zone Name	Circle name	Division name	Name of the Sub-division	Name of the Sub-station	Substation Code	Name of the 11 kV Feeder	Feeder Code	Name of the Location where DT situated	DT code	DT Capacity (kVA)	Predominant consumer type of DT (Domestic/Industrial/Agriculture/Mixed)	Type of metering AMR/AMI/ Communicable/Conventional metered/Unmetered	Status of Meter-whether Functional (Yes/No)	% of data received automatically (if AMR/AMI)	No. of Connected Consumers	Input Energy (MU) (A)	Billed Energy (MU) (B)	Loss (MU) (A-B)	% DT Loss (A-B)/A
657	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	KALINGA NAGAR	14007	11 KV OG-1 RMU (INDUS	14007203	ADARSH RESIDENCY	1213DT435	100	MIXED	AMI	Yes	100%	14	0.02515588	0.017195	0.00796088	31.65%
658	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	KALINGA NAGAR	14007	11 KV OG-1 RMU (INDUS	14007203	NANDINI PLAZA	1213DT436	100	MIXED	AMI	Yes	100%	19	0.0160873	0.012122	0.0039653	24.65%
659	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	KALINGA NAGAR	14007	11 KV OG-1 RMU (INDUS	14007203	RASHMITA ENCLAVE	1213DT437	250	MIXED	AMI	Yes	0%	13	0.00056648	0.000526	4.048E-05	7.15%
660	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	KALINGA NAGAR	14007	11 KV OG-1 RMU (INDUS	14007203	BLUE HILL-1	1213DT442	500	MIXED	AMI	Yes	100%	69	0.07401232	0.055788	0.01822432	24.62%
661	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	KALINGA NAGAR	14007	11 KV OG-1 RMU (INDUS	14007203	BLUE HILL	1213DT443	250	MIXED	AMI	Yes	100%	28	0.01824052	0.014551	0.00368952	20.23%
662	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	KALINGA NAGAR	14007	11 KV OG-1 RMU (INDUS	14007203	SRIDEV COMPLEX	1213DT445	100	MIXED	AMI	Yes	0%	14	0.08030084	0.024292	0.05600884	69.75%
663	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	KALINGA NAGAR	14007	11 KV OG-1 RMU (INDUS	14007203	GUPTESWAR ENCLAVE	1213DT447	250	MIXED	AMI	Yes	100%	23	0.03051124	0.010731	0.01978024	64.83%
664	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	KALINGA NAGAR	14007	11 KV OG-1 RMU (INDUS	14007203	BHAGABANPUR BGJY	1213DT454	100	MIXED	AMI	Yes	0%	80	0.16155975	0.050036	0.11152375	69.03%
665	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	KALINGA NAGAR	14007	11 KV OG-1 RMU (INDUS	14007203	BRUNDABAN GARDEN	1213DT461	250	MIXED	AMI	Yes	100%	32	0.0363182	0.023325	0.0129932	35.78%
666	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	KALINGA NAGAR	14007	11 KV OG-1 RMU (INDUS	14007203	BANYAN COURTYARD	1213DT470	500	MIXED	AMI	Yes	100%	68	0.09545864	0.066267	0.02919164	30.58%
667	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	KALINGA NAGAR	14007	11 KV OG-1 RMU (INDUS	14007203	URBAN RESIDENCY	1213DT473	100	MIXED	AMI	Yes	0%	12	0.01266614	0.010704	0.00196214	15.49%
668	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	KALINGA NAGAR	14007	11 KV OG-1 RMU (INDUS	14007203	ULTRA LOCK	1213DT477	250	MIXED	AMI	Yes	100%	8	0.01286236	0.005668	0.00719436	55.93%
669	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	KALINGA NAGAR	14007	11 KV OG-1 RMU (INDUS	14007203	SAI RESIDENCY	1213DT479	250	MIXED	AMI	Yes	100%	21	0.02488172	0.017933	0.00694872	27.93%
670	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	KALINGA NAGAR	14007	11 KV OG-1 RMU (INDUS	14007203	RAPDRP BHAGABANPUR(NEAR MANT	1213DT482	100	MIXED	AMI	Yes	0%	26	0.07102166	0.031703	0.03931866	55.36%
671	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	KALINGA NAGAR	14007	11 KV OG-1 RMU (INDUS	14007203	DAYA ENCLAVE-2	1213DT631	500	MIXED	AMI	Yes	100%	39	0.03281912	0.02193	0.01088912	33.18%
672	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	KALINGA NAGAR	14007	11 KV OG-1 RMU (INDUS	14007203	DAYA ENCLAVE-1	1213DT632	500	MIXED	AMI	Yes	100%	12	0.0193848	0.006147	0.0132378	68.29%
673	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	KALINGA NAGAR	14007	11 KV OG-1 RMU (INDUS	14007203	DAYA ENCLAVE	1213DT633	500	MIXED	AMI	Yes	0%	11	0.02202512	0.01074	0.01128512	51.24%
674	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	KALINGA NAGAR	14007	11 KV KN RE	14007204	BALIA PADA-1	1213DT258	100	MIXED	AMI	Yes	100%	122	0.13273477	0.076133	0.05660177	42.64%
675	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	KALINGA NAGAR	14007	11 KV KN RE	14007204	SANDYA VIHAR	1213DT262	250	MIXED	AMI	Yes	0%	24	0.0413158	0.011718	0.0295978	71.64%
676	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	KALINGA NAGAR	14007	11 KV KN RE	14007204	GRAND MARK	1213DT270	100	MIXED	AMI	Yes	0%	27	0.03403328	0.021502	0.01253128	36.82%
677	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	KALINGA NAGAR	14007	11 KV KN RE	14007204	RAPDRP NEAR COLLEGE PHARMACY	1213DT273	100	MIXED	AMI	Yes	0%	26	0.14564642	0.039417	0.10622942	72.94%
678	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	KALINGA NAGAR	14007	11 KV KN RE	14007204	AMRITA HIGHWAY ENCLAVE	1213DT292	250	MIXED	AMI	Yes	100%	17	0.01766908	0.016041	0.00162808	9.21%
679	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	KALINGA NAGAR	14007	11 KV KN RE	14007204	SWASTIK ENCLAVE	1213DT296	500	MIXED	AMI	Yes	100%	69	0.05700536	0.039678	0.01732736	30.40%
680	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	KALINGA NAGAR	14007	11 KV KN RE	14007204	CGEWHO,KENDRIYA VIHAR-1	1213DT297	500	MIXED	AMI	Yes	100%	37	0.07508472	0.040486	0.03459872	46.08%
681	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	KALINGA NAGAR	14007	11 KV KN RE	14007204	CGEWHO,KENDRIYA VIHAR-6	1213DT298	500	MIXED	AMI	Yes	100%	51	0.06509712	0.041431	0.02366612	36.36%
682	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	KALINGA NAGAR	14007	11 KV KN RE	14007204	CGEWHO,KENDRIYA VIHAR-2	1213DT299	500	MIXED	AMI	Yes	100%	76	0.08139736	0.050721	0.03067636	37.69%
683	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	KALINGA NAGAR	14007	11 KV KN RE	14007204	ADINATH ARNAPURNA-1	1213DT300	500	MIXED	AMI	Yes	100%	43	0.03681024	0.030665	0.00614524	16.69%
684	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	KALINGA NAGAR	14007	11 KV KN RE	14007204	ADINATH ARNAPURNA-2	1213DT301	500	MIXED	AMI	Yes	100%	61	0.04157752	0.038432	0.00314552	7.57%
685	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	KALINGA NAGAR	14007	11 KV KN RE	14007204	CGEWHO,KENDRIYA VIHAR-3	1213DT302	500	MIXED	AMI	Yes	100%	84	0.0649244	0.05876	0.0061644	9.49%
686	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	KALINGA NAGAR	14007	11 KV KN RE	14007204	CGEWHO,KENDRIYA VIHAR-4	1213DT303	500	MIXED	AMI	Yes	100%	56	0.0650424	0.031962	0.0330804	50.86%
687	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	KALINGA NAGAR	14007	11 KV KN RE	14007204	CGEWHO,KENDRIYA VIHAR-5	1213DT305	500	MIXED	AMI	Yes	100%	96	0.07519472	0.062638	0.01255672	16.70%
688	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	KALINGA NAGAR	14007	11 KV KN RE	14007204	RETANGA VILLAGE	1213DT340	250	MIXED	AMI	Yes	0%	211	0.16781848	0.115919	0.05189948	30.93%
689	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	KALINGA NAGAR	14007	11 KV KN RE	14007204	BADA MAHURA	1213DT344	100	MIXED	AMI	Yes	100%	75	0.09853416	0.052234	0.04630016	46.99%
690	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	KALINGA NAGAR	14007	11 KV KN RE	14007204	SANA MAHURA	1213DT345	100	MIXED	AMI	Yes	33%	52	0.05479841	0.0441	0.01069841	19.52%
691	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	KALINGA NAGAR	14007	11 KV KN RE	14007204	JHINKARADA VILLAGE	1213DT347	100	MIXED	AMI	Yes	100%	47	0.05962286	0.018181	0.04144186	69.51%
692	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	KALINGA NAGAR	14007	11 KV KN RE	14007204	PANCHU PALI VILLAGE	1213DT348	100	MIXED	AMI	Yes	100%	132	0.09106636	0.065932	0.02513436	27.60%
693	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	KALINGA NAGAR	14007	11 KV KN RE	14007204	RAPDRP PANCHUPALI VILLAGE	1213DT350	100	MIXED	AMI	Yes	100%	61	0.09318044	0.032491	0.06068944	65.13%
694	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	KALINGA NAGAR	14007	11 KV KN RE	14007204	SANA NUAGAON BPL	1213DT358	16	MIXED	AMI	Yes	100%	18	0.01072912	0.009115	0.00161412	15.04%
695	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	KALINGA NAGAR	14007	11 KV KN RE	14007204	BAIRANGA VILLAGE-2	1213DT362	100	MIXED	AMI	Yes	0%	66	0.03775296	0.015608	0.02214496	58.66%
696	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	KALINGA NAGAR	14007	11 KV KN RE	14007204	ANANTA VILLA	1213DT601	500	MIXED	AMI	Yes	100%	42	0.02751856	0.016807	0.01071156	38.92%
697	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	KALINGA NAGAR	14007	11 KV KN RE	14007204	ANANTA VILLA-2	1213DT602	500	MIXED	AMI	Yes	100%	47	0.01493552	0.014021	0.00091452	6.12%
698	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	KALINGA NAGAR	14007	11 KV KN RE	14007204	ADINATH ARNAPURNA-3	1213DT607	500	MIXED	AMI	Yes	0%	60	0.05961336	0.046648	0.01296536	21.75%
699	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	KALINGA NAGAR	14007	11 KV KN RE	14007204	DHANANJAYA RESIDENCY	1213DT614	250	MIXED	AMI	Yes	0%	26	0.03554292	0.02555	0.00999292	28.12%
700	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	KALINGA NAGAR	14007	11 KV KN RE	14007204	POLICE ACCADEMY OFFICE	1213DT615	500	MIXED	AMI	Yes	0%	18	0.013358	0.007943	0.005415	40.54%
701	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	KALINGA NAGAR	14007	11 KV DUMDUMA	14007205	PATASHA BANIA	1213DT127	100	MIXED	AMI	Yes	33%	34	0.04318286	0.036426	0.00675686	15.65%
702	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	KALINGA NAGAR	14007	11 KV DUMDUMA	14007205	RAPDRP,NEAR SANI TEMPLE	1213DT131	100	MIXED	AMI	Yes	100%	78	0.07770532	0.042273	0.03543232	45.60%
703	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	KALINGA NAGAR	14007	11 KV DUMDUMA	14007205	AROMA	1213DT138	100	MIXED	AMI	Yes	100%	8	0.01224172	0.007565	0.00467672	38.20%
704	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	KALINGA NAGAR	14007	11 KV DUMDUMA	14007205	SHREEKHETRA RESIDENCY-2	1213DT142	500	MIXED	AMI	Yes	67%	25	0.07305788	0.025254	0.04780388	65.43%
705	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	KALINGA NAGAR	14007	11 KV DUMDUMA	14007205	NEAR ARAY SCHOOL	1213DT144	250	MIXED	AMI	Yes	100%	229	0.13806932	0.136961	0.00110832	0.80%
706	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	KALINGA NAGAR	14007	11 KV DUMDUMA	14007205	MM RESIDENCY	1213DT145	250	MIXED	AMI	Yes	100%	21	0.01909352	0.016586	0.00250752	13.13%
707	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	KALINGA NAGAR	14007	11 KV DUMDUMA	14007205	PHULESWAR BASTI	1213DT147	500	MIXED	AMI	Yes	100%	537	0.2826192	0.22843	0.0541892	19.17%
708	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	KALINGA NAGAR	14007	11 KV DUMDUMA	14007205	RUDRAKHYA INFRA	1213DT148	250	MIXED	AMI	Yes	0%	40	0.02755048	0.02399	0.00356048	12.92%
709	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	KALINGA NAGAR	14007	11 KV DUMDUMA	14007205	RATHA CRUSHER	1213DT155	250	MIXED	AMI	Yes	100%	86	0.11348848	0.112306	0.00118248	1.04%
710	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	KALINGA NAGAR	14007	11 KV DUMDUMA	14007205	ANAND VIHAR	1214DT285	250	MIXED	AMI	Yes	100%	53	0.13767248	0.04843	0.08924248	64.82%
711	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	KALINGA NAGAR	14007	11 KV DUMDUMA	14007205	PANDA SHOP NO-2	1214DT286	250	MIXED	AMI	Yes	100%	52	0.15280705	0.092192	0.06061505	39.67%
712	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	KALINGA NAGAR	14007	11 KV DUMDUMA	14007205	TATWAMASI ENCLAVE NO-1	1214DT291	100	MIXED	AMI	Yes	100%	10	0.01224956	0.010512	0.00173756	14.18%
713	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	KALINGA NAGAR	14007	11 KV DUMDUMA	14007205	TATWAMASI ENCLAVE NO-2	1214DT292	100	MIXED	AMI	Yes	0%	12	0.02030138	0.018133	0.00216838	10.68%
714	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	KALINGA NAGAR	14007	11 KV DUMDUMA	14007205	SHREEKHETRE VIHAR & SHIVA TEMPL	1214DT297	500	MIXED	AMI	Yes	100%	109	0.23173856	0.125244	0.10649456	45.95%
715	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	KALINGA NAGAR	14007	11 KV DUMDUMA	14007205	LAXMI NARAYAN TEMPLE	1214DT299	250	MIXED	AMI	Yes	100%	90	0.1515354	0.132983	0.0185524	12.24%
716	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	KALINGA NAGAR	14007	11 KV DUMDUMA	14007205	AIGINIA DURGA PUJA MANDAP -2	1214DT306	250	MIXED	AMI	Yes	0%	124	0.15561368	0.137426	0.01818768	11.69%
717	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	KALINGA NAGAR	14007	11 KV TAMANDO	14007206	12MILESTON HOUSING SOCIETY	1213DT015	250	MIXED	AMI	Yes	100%	46	0.07535864	0.062347	0.01301164	17.27%
718	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	KALINGA NAGAR	14007	11 KV TAMANDO	14007206	TAMANDO INDIRA MAIDAN	1213DT018	2500	MIXED	AMI	Yes	100%	137	0.180157	0.170819	0.009338	5.18%
719	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	KALINGA NAGAR	14007	11 KV TAMANDO	14007206	MAHODADHI NILAYA-1	1213DT021	500	MIXED	AMI	Yes	100%	7	0.08140288	0.033238	0.04816488	59.17%
720	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	KALINGA NAGAR	14007	11 KV TAMANDO	14007206	MAHODADHI NILAYA-2	1213DT022	500	MIXED	AMI	Yes	100%	56	0.05121744	0.041294	0.00992344	19.38%
721	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	KALINGA NAGAR	14007	11 KV TAMANDO	14007206	SAMRUDHI ENCLAVE	1213DT025	250	MIXED	AMI	Yes	100%	23	0.02381844	0.018515	0.00530344	22.27%
722	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	KALINGA NAGAR	14007	11 KV TAMANDO	14007206	SARASWAT GOLAB	1213DT028	500	MIXED	AMI	Yes	67%	23	0.0209536	0.017285	0.0036686	17.51%
723	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	KALINGA NAGAR	14007	11 KV TAMANDO	14007206	THE PRIDE	1213DT030	500	MIXED	AMI	Yes	100%	53	0.04185456	0.030122	0.01173256	28.03%
724	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	KALINGA NAGAR	14007	11 KV TAMANDO	14007206	TAMANDO CAPEX	1213DT033	100	MIXED	AMI	Yes	100%	104	0.17082873	0.103715	0.06711373	39.29%
725	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	KALINGA NAGAR	14007	11 KV TAMANDO	14007206	HEMABATI RESIDENCY	1213DT034	500	MIXED	AMI	Yes	100%	57	0.05866088	0.057186	0.00147488	2.51%
726	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	KALINGA NAGAR	14007	11 KV TAMANDO	14007206	UDAYA ENCLAVE	1213DT049	250	MIXED	AMI	Yes	100%	25	0.03282736	0.032719	0.00010836	0.33%
727	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	KALINGA NAGAR	14007	11 KV TAMANDO	14007206	SOUBHAGYA LAXMINAGAR-1	1213DT059	100	MIXED	AMI	Yes	0%	207	0.16302742	0.124463	0.03856442	23.66%
728	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	KALINGA NAGAR	14007	11 KV TAMANDO	14007206	SOUBHAGYA LAXMINAGAR-2	1213DT060	250	MIXED	AMI	Yes	0%	279	0.16497858	0.118375	0.04660358	28.25%
729	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	KALINGA NAGAR	14007	11 KV TAMANDO	14007206	BIDYA ENCLAVE	1213DT062	100	MIXED	AMI	Yes	100%	10	0.02151896	0.009739	0.01177996	54.74%

Sl. No.	Zone Name	Circle name	Division name	Name of the Sub-division	Name of the Sub-station	Substation Code	Name of the 11 kV Feeder	Feeder Code	Name of the Location where DT situated	DT code	DT Capacity (kVA)	Predominant consumer type of DT (Domestic/Industrial/Agriculture/Mixed)	Type of metering AMR/AMI/ Communicable/Conventional metered/Unmetered	Status of Meter-whether Functional (Yes/No)	% of data received automatically (if AMR/AMI)	No. of Connected Consumers	Input Energy (MU) (A)	Billed Energy (MU) (B)	Loss (MU) (A-B)	% DT Loss (A-B)/A
730	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	KALINGA NAGAR	14007	11 KV TAMANDO	14007206	SHREEKRISHNA VILLA	1213DT063	250	MIXED	AMI	Yes	0%	52	0.06013836	0.040873	0.01926536	32.04%
731	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	KALINGA NAGAR	14007	11 KV TAMANDO	14007206	OMM PARO NIWAS	1213DT603	250	MIXED	AMI	Yes	100%	16	0.01290632	0.012023	0.00088332	6.84%
732	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	KALINGA NAGAR	14007	11 KV SUBUDHIPUR(EKA	14007207	VIPUL GARDEN-3	1213DT003	500	MIXED	AMI	Yes	100%	54	0.07748016	0.067235	0.01024516	13.22%
733	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	KALINGA NAGAR	14007	11 KV SUBUDHIPUR(EKA	14007207	VIPUL GARDEN-4	1213DT004	500	MIXED	AMI	Yes	100%	52	0.07410952	0.059287	0.01482252	20.00%
734	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	KALINGA NAGAR	14007	11 KV SUBUDHIPUR(EKA	14007207	VIPUL GARDEN-5	1213DT005	500	MIXED	AMI	Yes	100%	50	0.07248888	0.05572	0.01676888	23.13%
735	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	KALINGA NAGAR	14007	11 KV SUBUDHIPUR(EKA	14007207	VIPUL GARDEN-6	1213DT006	500	MIXED	AMI	Yes	100%	50	0.0649076	0.051932	0.0129756	19.99%
736	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	KALINGA NAGAR	14007	11 KV SUBUDHIPUR(EKA	14007207	VIPUL GARDEN-7	1213DT007	500	MIXED	AMI	Yes	100%	48	0.07101168	0.050663	0.02034868	28.66%
737	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	KALINGA NAGAR	14007	11 KV SUBUDHIPUR(EKA	14007207	VIPUL GARDEN-8	1213DT008	500	MIXED	AMI	Yes	100%	63	0.05444336	0.052291	0.00215236	3.95%
738	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	KALINGA NAGAR	14007	11 KV SUBUDHIPUR(EKA	14007207	VIPUL GARDEN-9	1213DT009	500	MIXED	AMI	Yes	100%	54	0.0599784	0.050925	0.0090534	15.09%
739	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	KALINGA NAGAR	14007	11 KV SUBUDHIPUR(EKA	14007207	VIPUL GARDEN-10	1213DT010	500	MIXED	AMI	Yes	100%	45	0.05623888	0.034804	0.02143488	38.11%
740	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	KALINGA NAGAR	14007	11 KV SUBUDHIPUR(EKA	14007207	VIPUL GARDEN-11	1213DT011	250	MIXED	AMI	Yes	100%	40	0.05976192	0.044238	0.01552392	25.98%
741	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	KANAN BIHAR	14217	11 KV KALARAHANGA	14217202	MASON ESTATE PVT LTD	1235DT171	250	MIXED	AMI	Yes	67%	63	0.1487594	0.070494	0.0782654	52.61%
742	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	KHANDAGIRI	14222	11 KV KOLATHIA	14222201	SRI SAI ANGAN	1214DT161	250	MIXED	AMI	Yes	100%	75	0.0947292	0.052971	0.0417582	44.08%
743	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	KHANDAGIRI	14222	11 KV KOLATHIA	14222201	WINE SHOP NH SIDE	1214DT163	250	MIXED	AMI	Yes	100%	96	0.15343632	0.106173	0.04726332	30.80%
744	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	KHANDAGIRI	14222	11 KV KOLATHIA	14222201	SIVANANDA SCHOOL	1214DT195	250	MIXED	AMI	Yes	100%	106	0.22567024	0.177247	0.04842324	21.46%
745	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	KHANDAGIRI	14222	11 KV KOLATHIA	14222201	RAJIV NAGAR NO-2	1214DT239	100	MIXED	AMI	Yes	100%	66	0.10824788	0.094272	0.01397588	12.91%
746	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	KHANDAGIRI	14222	11 KV KOLATHIA	14222201	KHANDAGIRI UDYAN APPARTMENT	1214DT242	250	MIXED	AMI	Yes	100%	18	0.03143036	0.02346	0.00797036	25.36%
747	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	KHANDAGIRI	14222	11 KV KOLATHIA	14222201	SISHUGHNA	1214DT248	500	MIXED	AMI	Yes	0%	114	0.1999828	0.132505	0.0674778	33.74%
748	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	KHANDAGIRI	14222	11 KV KOLATHIA	14222201	SATYA SAI ENCLAVE NO-2(PANITANK	1214DT252	500	MIXED	AMI	Yes	100%	164	0.25131528	0.222018	0.02929728	11.66%
749	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	KHANDAGIRI	14222	11 KV KOLATHIA	14222201	BRINDABAN GARDEN -1	1214DT257	100	MIXED	AMI	Yes	0%	81	0.10337463	0.086741	0.01663363	16.09%
750	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	KHANDAGIRI	14222	11 KV KOLATHIA	14222201	MANGALA MANDIR,KOLOTHIA	1214DT265	500	MIXED	AMI	Yes	100%	155	0.20930788	0.176199	0.03310888	15.82%
751	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	KHANDAGIRI	14222	11 KV KOLATHIA	14222201	GREEN LAND	1214DT268	250	MIXED	AMI	Yes	100%	27	0.04360844	0.034495	0.00911344	20.90%
752	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	KHANDAGIRI	14222	11 KV KOLATHIA	14222201	MOHAN DAS ENCLAVE	1214DT275	250	MIXED	AMI	Yes	100%	78	0.17334556	0.099113	0.07423256	42.82%
753	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	KHANDAGIRI	14222	11 KV DHARMAVIHAR	14222202	DHARMAVIHAR NO-2	1214DT131	500	MIXED	AMI	Yes	100%	117	0.14494104	0.126506	0.01843504	12.72%
754	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	KHANDAGIRI	14222	11 KV DHARMAVIHAR	14222202	JAGANNATH TEMPLE	1214DT133	100	MIXED	AMI	Yes	100%	31	0.06956406	0.047938	0.02162606	31.09%
755	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	KHANDAGIRI	14222	11 KV DHARMAVIHAR	14222202	SIDHIVIHAR NO-1	1214DT140	500	MIXED	AMI	Yes	100%	151	0.32892756	0.202429	0.12649856	38.46%
756	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	KHANDAGIRI	14222	11 KV DHARMAVIHAR	14222202	SIDHIVIHAR NO-2	1214DT142	250	MIXED	AMI	Yes	0%	117	0.24148196	0.156906	0.08457596	35.02%
757	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	KHANDAGIRI	14222	11 KV DHARMAVIHAR	14222202	KRISHNA GARDEN COMPLEX, PHASE-	1214DT143	500	MIXED	AMI	Yes	100%	119	0.16284808	0.159336	0.00351208	2.16%
758	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	KHANDAGIRI	14222	11 KV DHARMAVIHAR	14222202	DHARMA VIHAR (SOUBHAGYA)	1214DT144	250	MIXED	AMI	Yes	0%	103	0.14558872	0.049047	0.09654172	66.31%
759	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	KHANDAGIRI	14222	11 KV DHARMAVIHAR	14222202	TAPOBANA BASTI NO-1	1214DT148	100	MIXED	AMI	Yes	33%	115	0.08016263	0.050099	0.03006363	37.50%
760	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	KHANDAGIRI	14222	11 KV DHARMAVIHAR	14222202	TAPOBANA BASTI NO-2	1214DT149	100	MIXED	AMI	Yes	100%	117	0.05194517	0.039337	0.01260817	24.27%
761	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	KHANDAGIRI	14222	11 KV GANDMUNDA	14222203	MILAN MANDAP	1214DT056	100	MIXED	AMI	Yes	100%	34	0.03933777	0.029903	0.00943477	23.98%
762	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	KHANDAGIRI	14222	11 KV GANDMUNDA	14222203	SUBHADRAVILLA	1214DT059	100	MIXED	AMI	Yes	0%	19	0.03798562	0.031016	0.00696962	18.35%
763	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	KHANDAGIRI	14222	11 KV GANDMUNDA	14222203	PRAVABATI MANSION	1214DT066	250	MIXED	AMI	Yes	100%	16	0.02140264	0.019415	0.00198764	9.29%
764	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	KHANDAGIRI	14222	11 KV GANDMUNDA	14222203	KRISHNA GARDEN PHASE 2	1214DT068	500	MIXED	AMI	Yes	100%	115	0.20355656	0.136733	0.06682356	32.83%
765	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	KHANDAGIRI	14222	11 KV GANDMUNDA	14222203	M COMPLEX NO-5	1214DT069	250	MIXED	AMI	Yes	100%	140	0.21810352	0.164689	0.05341452	24.49%
766	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	KHANDAGIRI	14222	11 KV GANDMUNDA	14222203	MALLICK COMPLEX NO -3	1214DT073	500	MIXED	AMI	Yes	100%	110	0.15196544	0.137695	0.01427044	9.39%
767	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	KHANDAGIRI	14222	11 KV GANDMUNDA	14222203	MALLICK COMPLEX NO-4	1214DT074	250	MIXED	AMI	Yes	67%	115	0.19596916	0.158742	0.03722716	19.00%
768	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	KHANDAGIRI	14222	11 KV GANDMUNDA	14222203	KIAN GAETTA S/S	1214DT078	500	MIXED	AMI	Yes	100%	103	0.42362824	0.225616	0.19801224	46.74%
769	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	KHANDAGIRI	14222	11 KV GANDMUNDA	14222203	BIMAL NANDA TOWER	1214DT080	250	MIXED	AMI	Yes	100%	7	0.01818628	0.015259	0.00292728	16.10%
770	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	KHANDAGIRI	14222	11 KV GANDMUNDA	14222203	SSV ENCLAVE	1214DT081	250	MIXED	AMI	Yes	0%	23	0.02624748	0.023574	0.00267348	10.19%
771	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	KHANDAGIRI	14222	11 KV GANDMUNDA	14222203	LANE- 1 B.M NAGAR	1214DT085	250	MIXED	AMI	Yes	100%	127	0.21296228	0.14692	0.06604228	31.01%
772	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	KHANDAGIRI	14222	11 KV GANDMUNDA	14222203	KOKILA PARADISE	1214DT086	500	MIXED	AMI	Yes	100%	58	0.07600536	0.068438	0.00756736	9.96%
773	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	KHANDAGIRI	14222	11 KV GANDMUNDA	14222203	COIR BOARD	1214DT123	100	MIXED	AMI	Yes	100%	22	0.03080396	0.007354	0.02344996	76.13%
774	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	KHANDAGIRI	14222	11 KV JAGAMOHAN NAG	14222204	GOLAP TOWER 1	1214DT011	250	MIXED	AMI	Yes	100%	21	0.02507628	0.021558	0.00351828	14.03%
775	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	KHANDAGIRI	14222	11 KV JAGAMOHAN NAG	14222204	GOLAP TOWER-2	1214DT012	100	MIXED	AMI	Yes	100%	12	0.02161326	0.020815	0.00079826	3.69%
776	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	KHANDAGIRI	14222	11 KV JAGAMOHAN NAG	14222204	SIDHESWAR NAGAR	1214DT017	500	MIXED	AMI	Yes	100%	128	0.20566124	0.182252	0.02340924	11.38%
777	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	KHANDAGIRI	14222	11 KV JAGAMOHAN NAG	14222204	SUPRATIK ELEGANCE -2	1214DT019	250	MIXED	AMI	Yes	100%	40	0.05693792	0.042745	0.01419292	24.93%
778	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	KHANDAGIRI	14222	11 KV JAGAMOHAN NAG	14222204	KRISHNA GARDEN APPARTMENT	1214DT021	500	MIXED	AMI	Yes	100%	46	0.06268104	0.049205	0.01347604	21.50%
779	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	KHANDAGIRI	14222	11 KV JAGAMOHAN NAG	14222204	NARENDRA GARDEN COLONY	1214DT022	100	MIXED	AMI	Yes	100%	25	0.04014664	0.034306	0.00584064	14.55%
780	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	KHANDAGIRI	14222	11 KV JAGAMOHAN NAG	14222204	TULASI VIHAR	1214DT023	500	MIXED	AMI	Yes	100%	77	0.15074584	0.125898	0.02484784	16.48%
781	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	KHANDAGIRI	14222	11 KV JAGAMOHAN NAG	14222204	PAWANI COMPLEX	1214DT035	500	MIXED	AMI	Yes	100%	211	0.37320856	0.288529	0.08467956	22.69%
782	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	KHANDAGIRI	14222	11 KV JAGAMOHAN NAG	14222204	PRATYAKSHA ENCLAVE	1214DT044	100	MIXED	AMI	Yes	100%	12	0.01270737	0.012643	6.437E-05	0.51%
783	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	RANASINGHPUR OD	14235	11 KV SARAKANTARA	14235201	RANSINGPUR VILLAGE	1212DT096	200	MIXED	AMI	Yes	100%	133	0.14199988	0.090597	0.05140288	36.20%
784	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	RANASINGHPUR OD	14235	11 KV SARAKANTARA	14235201	GAYATRIBIHAR	1212DT104	500	MIXED	AMI	Yes	0%	58	0.0605808	0.054287	0.0062938	10.39%
785	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	RANASINGHPUR OD	14235	11 KV SARAKANTARA	14235201	KHANDUAL TAMPLE, SARAKANTARA	1212DT108	250	MIXED	AMI	Yes	0%	195	0.21393268	0.190958	0.02297468	10.74%
786	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	RANASINGHPUR OD	14235	11 KV SARAKANTARA	14235201	SAMBADIK, JADUPUR	1212DT109	250	MIXED	AMI	Yes	100%	220	0.27978136	0.249865	0.02991636	10.69%
787	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	RANASINGHPUR OD	14235	11 KV SARAKANTARA	14235201	JADUPUR ALLIMAA SAHI BPL	1212DT115	100	MIXED	AMI	Yes	67%	62	0.06236474	0.051822	0.01054274	16.90%
788	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	RANASINGHPUR OD	14235	11 KV SARAKANTARA	14235201	JADUPUR NEAR FOOTBALL FIELD CAP	1212DT116	250	MIXED	AMI	Yes	0%	108	0.23777372	0.148184	0.08958972	37.68%
789	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	RANASINGHPUR OD	14235	11 KV SARAKANTARA	14235201	MEDICAL (R.NAGAR)	1212DT119	250	MIXED	AMI	Yes	67%	157	0.23714744	0.088714	0.14843344	62.59%
790	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	RANASINGHPUR OD	14235	11 KV SARAKANTARA	14235201	RAGHUNATH NAGAR (BARBARBARI)	1212DT120	100	MIXED	AMI	Yes	100%	128	0.10144876	0.053685	0.04776376	47.08%
791	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	RANASINGHPUR OD	14235	11 KV SARAKANTARA	14235201	SATYASAI SCHOOL	1212DT124	250	MIXED	AMI	Yes	0%	99	0.12857826	0.087822	0.04075626	31.70%
792	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	RANASINGHPUR OD	14235	11 KV SARAKANTARA	14235201	KESHARIPLAZA 4	1212DT132	500	MIXED	AMI	Yes	100%	16	0.0482396	0.019399	0.0288406	59.79%
793	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	RANASINGHPUR OD	14235	11 KV AIGINIA	14235202	BHUBAN	1212DT147	500	MIXED	AMI	Yes	100%	37	0.05066872	0.033471	0.01719772	33.94%
794	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	RANASINGHPUR OD	14235	11 KV AIGINIA	14235202	BHUBAN-1	1212DT148	250	MIXED	AMI	Yes	100%	26	0.02917764	0.022214	0.00696364	23.87%
795	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	RANASINGHPUR OD	14235	11 KV AIGINIA	14235202	SANIMANDIR NO 1	1212DT151	250	MIXED	AMI	Yes	100%	243	0.16294574	0.112128	0.05081774	31.19%
796	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	RANASINGHPUR OD	14235	11 KV AIGINIA	14235202	N. PATTNAYAK	1212DT154	250	MIXED	AMI	Yes	100%	247	0.133677	0.125849	0.007828	5.86%
797	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	RANASINGHPUR OD	14235	11 KV AIGINIA	14235202	RAGHUNATH NAGAR (MOHAPATRA H	1212DT160	100	MIXED	AMI	Yes	0%	181	0.09460299	0.072786	0.02181699	23.06%
798	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	RANASINGHPUR OD	14235	11 KV AIGINIA	14235202	PARAS ENCLAVE	1213DT562	250	MIXED	AMI	Yes	100%	14	0.02070724	0.017738	0.00296924	14.34%
799	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	RANASINGHPUR OD	14235	11 KV AIGINIA	14235202	ARUNASTAMBHA APPT.	1213DT567	250	MIXED	AMI	Yes	100%	18	0.02594396	0.020579	0.00536496	20.68%
800	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	RANASINGHPUR OD	14235	11 KV AIGINIA	14235202	ORO AVENUE	1213DT569	100	MIXED	AMI	Yes	100%	7	0.0132156	0.003679	0.0095366	72.16%
801	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	RANASINGHPUR OD	14235	11 KV AIGINIA	14235202	ROYAL HERITAGE-1	1213DT574	500	MIXED	AMI	Yes	100%	64	0.08472112	0.083197	0.00152412	1.80%
802	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	RANASINGHPUR OD	14235	11 KV AIGINIA	14235202	SAYED RAHAMAN TULA	1213DT578	63	MIXED	AMI	Yes	0%	281	0.15585002	0.131697	0.02415302	15.50%

Sl. No.	Zone Name	Circle name	Division name	Name of the Sub-division	Name of the Sub-station	Substation Code	Name of the 11 kV Feeder	Feeder Code	Name of the Location where DT situated	DT code	DT Capacity (kVA)	Predominant consumer type of DT (Domestic/Industrial/Agriculture/Mixed)	Type of metering AMR/AMI/ Communicable/Conventional metered/Unmetered	Status of Meter-whether Functional (Yes/No)	% of data received automatically (if AMR/AMI)	No. of Connected Consumers	Input Energy (MU) (A)	Billed Energy (MU) (B)	Loss (MU) (A-B)	% DT Loss (A-B)/A
803	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	RANASINGHPUR OD	14235	11 KV AIGINIA	14235202	OMM ENCLAVE	1213DT580	100	MIXED	AMI	Yes	100%	14	0.0156189	0.012949	0.0026699	17.09%
804	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	RANASINGHPUR OD	14235	11 KV AIGINIA	14235202	SUKANTI ENCLAVE	1213DT583	250	MIXED	AMI	Yes	100%	17	0.03771216	0.022268	0.01544416	40.95%
805	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	RANASINGHPUR OD	14235	11 KV AIGINIA	14235202	BIJU PATTANAIK POLICE ACADEMY	1213DT586	500	MIXED	AMI	Yes	100%	61	0.09784536	0.034934	0.06291136	64.30%
806	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	RANASINGHPUR OD	14235	11 KV AIGINIA	14235202	ASHIRBAD ENCLAVE	1213DT679	500	MIXED	AMI	Yes	100%	53	0.03558944	0.025279	0.01031044	28.97%
807	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	RANASINGHPUR OD	14235	11 KV SIJUA	14235203	SPACE LINK NO-1	1212DT161	500	MIXED	AMI	Yes	33%	26	0.0205208	0.013464	0.0070568	34.39%
808	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	RANASINGHPUR OD	14235	11 KV SIJUA	14235203	SPACE LINK NO-2	1212DT162	500	MIXED	AMI	Yes	100%	10	0.00434368	0.002808	0.00153568	35.35%
809	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	RANASINGHPUR OD	14235	11 KV SIJUA	14235203	OFFICERS ENCLAVE-1	1213DT517	500	MIXED	AMI	Yes	100%	54	0.06001136	0.049921	0.01009036	16.81%
810	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	RANASINGHPUR OD	14235	11 KV SIJUA	14235203	SIJUA OLD	1213DT523	200	MIXED	AMI	Yes	33%	137	0.20289963	0.174852	0.02804763	13.82%
811	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	RANASINGHPUR OD	14235	11 KV SIJUA	14235203	SIJUA NEW	1213DT539	200	MIXED	AMI	Yes	67%	90	0.21469056	0.122643	0.09204756	42.87%
812	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	RANASINGHPUR OD	14235	11 KV SIJUA	14235203	CHHOTRAYPUR VILLAGE	1213DT541	250	MIXED	AMI	Yes	100%	159	0.1831422	0.147034	0.0361082	19.72%
813	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	RANASINGHPUR OD	14235	11 KV SIJUA	14235203	DAMODARPUR VILLAGE	1213DT542	250	MIXED	AMI	Yes	100%	89	0.1095021	0.077605	0.0318971	29.13%
814	TPCODL	BBSR1	BCDD-2	KHANDAGIRI	TIGIRIA	14115	11 KV BINDHANIMA	14115201	GOPINATHPUR SASAN-2	3425DT047	100	MIXED	AMI	Yes	100%	88	0.07344318	0.035949	0.03749418	51.05%
815	TPCODL	BBSR1	BCDD-2	NAYAPALLI	BARAMUNDA	14005	11 kV BARAMUNDA HB	14005201	NEAR L-71,BHB COLONY (NO.2)	1221DT099	500	MIXED	AMI	Yes	0%	133	0.21978424	0.15894	0.06084424	27.68%
816	TPCODL	BBSR1	BCDD-2	NAYAPALLI	NAYAPALLI	14008	11 kV IRC-1	14008201	N5-19	1222DT002	250	MIXED	AMI	Yes	0%	42	0.20919792	0.056698	0.15249992	72.90%
817	TPCODL	BBSR1	BCDD-2	NAYAPALLI	NAYAPALLI	14008	11 kV BHAGWATI TEMPL	14008209	N6/PARK NO.1	1222DT133	100	MIXED	AMI	Yes	100%	31	0.06767978	0.053543	0.01413678	20.89%
818	TPCODL	BBSR1	BCDD-2	NAYAPALLI	NAYAPALLI	14008	11 kV BHAGWATI TEMPL	14008209	BASTI SURYAKSHA MANCHA	1222DT140	500	MIXED	AMI	Yes	100%	192	0.27065856	0.193641	0.07701756	28.46%
819	TPCODL	BBSR1	BCDD-2	NAYAPALLI	NAYAPALLI	14008	11 kV IRC-4	14008207	SLN BASTI NO.2	1222DT223	200	MIXED	AMI	Yes	67%	286	0.1514138	0.105629	0.0457848	30.24%
820	TPCODL	BBSR1	BCDD-2	NAYAPALLI	NAYAPALLI	14008	11 kV RPRC	14008208	SLN BASTI NO1	1222DT326	100	MIXED	AMI	Yes	100%	182	0.11113192	0.086521	0.02461092	22.15%
821	TPCODL	BBSR1	BCDD-2	NAYAPALLI	NAYAPALLI	14008	11 kV RPRC	14008208	VIP-48 ROYALE RESIDENCY	1222DT337	100	MIXED	AMI	Yes	100%	8	0.01423986	0.012685	0.00155486	10.92%
822	TPCODL	BBSR1	BCDD-2	NAYAPALLI	RRL ODSSP	14231	11 kV PAL HEIGHT	14231203	ESI HOSPITAL COLONY	1222DT356	250	MIXED	AMI	Yes	100%	19	0.02727048	0.013879	0.01339148	49.11%
823	TPCODL	BBSR1	BCDD-2	NAYAPALLI	NAYAPALLI	14008	11 kV IRC-4	14008207	N1/A23	1222DT385	100	MIXED	AMI	Yes	100%	9	0.01300522	0.012969	0.00003622	0.28%
824	TPCODL	BBSR1	BCDD-2	NAYAPALLI	SAINIK SCHOOL	14010	11 kV KELUCHARAN PAR	14010206	BDA FIRE A&B BLOCK	1223DT145	250	MIXED	AMI	Yes	100%	31	0.05168052	0.035265	0.01641552	31.76%
825	TPCODL	BBSR1	BCDD-2	NAYAPALLI	SAINIK SCHOOL	14010	11 kV KELUCHARAN PAR	14010206	BDA H&K BLOCK	1223DT155	250	MIXED	AMI	Yes	0%	8	0.03953872	0.007918	0.03162072	79.97%
826	TPCODL	BBSR1	BCDD-2	NAYAPALLI	RRL ODSSP	14231	11 kV PAL HEIGHT	14231203	XAVIER MAYFAIR ROAD	1224DT017	100	MIXED	AMI	Yes	0%	88	0.06035706	0.044783	0.01557406	25.80%
827	TPCODL	BBSR1	BCDD-2	NAYAPALLI	NAYAPALLI	14008	11 kV NALCO	14008206	SALIA SAHI, ADIVASSI	1224DT062	100	MIXED	AMI	Yes	100%	31	0.01518468	0.01123	0.00395468	26.04%
828	TPCODL	BBSR1	BCDD-2	NAYAPALLI	NAYAPALLI	14008	11 kV NALCO	14008206	SALIA SAHI, ADIBASIGAM 2	1224DT064	100	MIXED	AMI	Yes	100%	168	0.06251182	0.053735	0.00877682	14.04%
829	TPCODL	BBSR1	BCDD-2	NAYAPALLI	NAYAPALLI	14008	11 kV NALCO	14008206	SAKTI VIHAR	1224DT067	250	MIXED	AMI	Yes	0%	261	0.16113416	0.097401	0.06373316	39.55%
830	TPCODL	BBSR1	BCDD-2	NAYAPALLI	SAINIK SCHOOL	14010	11 kV GAJAPATINAGAR	14010202	SAINIK SCHOOL CHAKA	1224DT121	100	MIXED	AMI	Yes	100%	42	0.10261734	0.058175	0.04444234	43.31%
831	TPCODL	BBSR1	BCDD-2	NAYAPALLI	SAINIK SCHOOL	14010	11 kV VANIVIHAR	14010204	LAXMI VIHAR-1 (LANE-3)	1224DT346	100	MIXED	AMI	Yes	0%	62	0.08500754	0.072511	0.01249654	14.70%
832	TPCODL	BBSR1	BCDD-2	NAYAPALLI	CS PUR-1	14001	11 kV SRI VIHAR	14001201	NALCO CHHAKA	1232DT018	100	MIXED	AMI	Yes	0%	56	0.06097094	0.03611	0.02486094	40.78%
833	TPCODL	BBSR1	BCDD-2	NAYAPALLI	NAYAPALLI	14008	11KV RPRC	14008208	N3/19	1222DT301	500	MIXED	AMI	Yes	100%	90	0.23799616	0.147611	0.09038516	37.98%
834	TPCODL	BBSR1	BCDD-2	NAYAPALLI	NAYAPALLI	14008	11KV ID MARKET B-TYPE	14008210	B-TYPE MARKET NO2	1222DT014	100	MIXED	AMI	Yes	100%	57	0.0676559	0.040727	0.0269289	39.80%
835	TPCODL	BBSR1	BCDD-2	NAYAPALLI	NAYAPALLI	14008	11KV RAPTANI BHAWAN	14008211	RBI NO1	1222DT069	500	MIXED	AMI	Yes	100%	36	0.05577856	0.025792	0.02998656	53.76%
836	TPCODL	BBSR1	BCDD-2	NAYAPALLI	NAYAPALLI	14008	11KV RAPTANI BHAWAN	14008211	KALANDI BEHERA NO2	1222DT072	100	MIXED	AMI	Yes	0%	38	0.02181204	0.018288	0.00352404	16.16%
837	TPCODL	BBSR1	BCDD-2	NAYAPALLI	NAYAPALLI	14008	11KV RAPTANI BHAWAN	14008211	ISKON BASTI	1222DT074	100	MIXED	AMI	Yes	100%	122	0.08175574	0.061138	0.02061774	25.22%
838	TPCODL	BBSR1	BCDD-2	NAYAPALLI	NAYAPALLI	14008	11KV RAPTANI BHAWAN	14008211	ESI COLONY	1222DT076	100	MIXED	AMI	Yes	33%	18	0.01234229	0.008214	0.00412829	33.45%
839	TPCODL	BBSR1	BCDD-2	NAYAPALLI	NAYAPALLI	14008	11KV RAPTANI BHAWAN	14008211	LAXMI TAMPLE NO2	1222DT079	250	MIXED	AMI	Yes	100%	99	0.13279396	0.120821	0.01197296	9.02%
840	TPCODL	BBSR1	BCDD-2	NAYAPALLI	NAYAPALLI	14008	11KV RAPTANI BHAWAN	14008211	NEAR N1/40 NO2	1222DT092	100	MIXED	AMI	Yes	0%	23	0.07116296	0.041622	0.02954096	41.51%
841	TPCODL	BBSR1	BCDD-2	NAYAPALLI	NAYAPALLI	14008	11KV RAPTANI BHAWAN	14008211	N1-114	1222DT104	250	MIXED	AMI	Yes	0%	90	0.24935584	0.124254	0.12510184	50.17%
842	TPCODL	BBSR1	BCDD-2	NAYAPALLI	NAYAPALLI	14008	11KV RAPTANI BHAWAN	14008211	N1-285 HEMGOPALA	1222DT407	100	MIXED	AMI	Yes	100%	8	0.01081344	0.009422	0.00139144	12.87%
843	TPCODL	BBSR1	BCDD-2	NAYAPALLI	SAINIK SCHOOL	14010	11 KV KELUCHARAN PAR	14010206	SAINATH BASTI	1223DT134	100	MIXED	AMI	Yes	100%	88	0.04580246	0.044502	0.00130046	2.84%
844	TPCODL	BBSR1	BCDD-2	NAYAPALLI	SAINIK SCHOOL	14010	11 KV KELUCHARAN PAR	14010206	TRW	1223DT135	250	MIXED	AMI	Yes	100%	90	0.1050136	0.088827	0.0161866	15.41%
845	TPCODL	BBSR1	BCDD-2	NAYAPALLI	SAINIK SCHOOL	14010	11 KV KELUCHARAN PAR	14010206	BDA FIRE F BLOCK	1223DT141	250	MIXED	AMI	Yes	100%	14	0.02690308	0.015366	0.01153708	42.88%
846	TPCODL	BBSR1	BCDD-2	NAYAPALLI	SAINIK SCHOOL	14010	11 KV KELUCHARAN PAR	14010206	BDA FIRE E BLOCK	1223DT143	250	MIXED	AMI	Yes	100%	14	0.01949904	0.013802	0.00569704	29.22%
847	TPCODL	BBSR1	BCDD-2	NAYAPALLI	SAINIK SCHOOL	14010	11 KV KELUCHARAN PAR	14010206	BDA L BLOCK	1223DT149	250	MIXED	AMI	Yes	100%	8	0.0241714	0.009826	0.0143454	59.35%
848	TPCODL	BBSR1	BCDD-2	NAYAPALLI	SAINIK SCHOOL	14010	11 KV KELUCHARAN PAR	14010206	BDA R BLOCK	1223DT150	250	MIXED	AMI	Yes	100%	17	0.0604378	0.015978	0.0444598	73.56%
849	TPCODL	BBSR1	BCDD-2	NAYAPALLI	SAINIK SCHOOL	14010	11 KV KELUCHARAN PAR	14010206	BDA S&T BLOCK	1223DT152	250	MIXED	AMI	Yes	0%	29	0.02212476	0.021689	0.00043576	1.97%
850	TPCODL	BBSR1	BCDD-2	NAYAPALLI	SAINIK SCHOOL	14010	11 KV KELUCHARAN PAR	14010206	BDA U BLOCK	1223DT153	250	MIXED	AMI	Yes	100%	15	0.03601716	0.016287	0.01973016	54.78%
851	TPCODL	BBSR1	BCDD-2	NAYAPALLI	SAINIK SCHOOL	14010	11 KV KELUCHARAN PAR	14010206	BDA G&J BLOCK	1223DT154	250	MIXED	AMI	Yes	100%	16	0.04570816	0.021437	0.02427116	53.10%
852	TPCODL	BBSR1	BCDD-2	NAYAPALLI	SAINIK SCHOOL	14010	11 KV KELUCHARAN PAR	14010206	GADAKANA SABAR SAI RAPDRP	1223DT160	100	MIXED	AMI	Yes	0%	40	0.10586705	0.034867	0.07100005	67.07%
853	TPCODL	BBSR1	BCDD-2	NAYAPALLI	SAINIK SCHOOL	14010	11 KV KELUCHARAN PAR	14010206	GADAKANA HANUMAN TEMPEL	1223DT164	500	MIXED	AMI	Yes	100%	156	0.2337024	0.17635	0.0573524	24.54%
854	TPCODL	BBSR1	BCDD-2	NAYAPALLI	SAINIK SCHOOL	14010	11 KV KELUCHARAN PAR	14010206	RAY PROJECT	1223DT169	500	MIXED	AMI	Yes	67%	215	0.11499008	0.08721	0.02778008	24.16%
855	TPCODL	BBSR1	BCDD-2	NAYAPALLI	BARAMUNDA	14005	11 KV BARAMUNDA HB	14005201	NEAR K-12, RUCHIKA MARKET-1(NEW	1221DT074	100	MIXED	AMI	Yes	100%	78	0.14057626	0.056793	0.08378326	59.60%
856	TPCODL	BBSR1	BCDD-2	NAYAPALLI	BARAMUNDA	14005	11 KV BARAMUNDA HB	14005201	MANGALA TEMPLE NO-2	1221DT084	250	MIXED	AMI	Yes	100%	96	0.14742464	0.11961	0.02781464	18.87%
857	TPCODL	BBSR1	BCDD-2	NAYAPALLI	BARAMUNDA	14005	11 KV BARAMUNDA HB	14005201	SANKAR BAZAR, BHB COLONY NO-1	1221DT086	100	MIXED	AMI	Yes	33%	10	0.05786064	0.01902	0.03884064	67.13%
858	TPCODL	BBSR1	BCDD-2	NAYAPALLI	BARAMUNDA	14005	11 KV BARAMUNDA HB	14005201	NEAR E-41, BHB COLONY NO-1	1221DT087	250	MIXED	AMI	Yes	100%	165	0.15255688	0.141349	0.01120788	7.35%
859	TPCODL	BBSR1	BCDD-2	NAYAPALLI	BARAMUNDA	14005	11 KV BARAMUNDA HB	14005201	NEAR E-41, BHB COLONY NO-2	1221DT088	250	MIXED	AMI	Yes	100%	124	0.14465416	0.135363	0.00929116	6.42%
860	TPCODL	BBSR1	BCDD-2	NAYAPALLI	BARAMUNDA	14005	11 KV BARAMUNDA HB	14005201	NEAR L-404, BHB COLONY NO-1	1221DT089	250	MIXED	AMI	Yes	67%	77	0.13667348	0.097594	0.03907948	28.59%
861	TPCODL	BBSR1	BCDD-2	NAYAPALLI	BARAMUNDA	14005	11 KV BARAMUNDA HB	14005201	NEAR L-404, BHB COLONY NO-2	1221DT090	250	MIXED	AMI	Yes	67%	134	0.16818154	0.138918	0.02926354	17.40%
862	TPCODL	BBSR1	BCDD-2	NAYAPALLI	BARAMUNDA	14005	11 KV BARAMUNDA HB	14005201	NEAR L-355, BHB COLONY(FISH MAR	1221DT094	100	MIXED	AMI	Yes	100%	35	0.07667492	0.037209	0.03946592	51.47%
863	TPCODL	BBSR1	BCDD-2	NAYAPALLI	BARAMUNDA	14005	11 KV BARAMUNDA HB	14005201	NEAR L-123,BHB COLONY NO-1(NEW	1221DT097	500	MIXED	AMI	Yes	100%	114	0.28501864	0.131305	0.15371364	53.93%
864	TPCODL	BBSR1	BCDD-2	NAYAPALLI	BARAMUNDA	14005	11 KV BARAMUNDA HB	14005201	ABHIJITA MOHAPATRA ROAD-1,JAGA	1221DT110	150	MIXED	AMI	Yes	100%	10	0.01961722	0.008268	0.01134922	57.85%
865	TPCODL	BBSR1	BCDD-2	NAYAPALLI	BARAMUNDA	14005	11 KV BARAMUNDA HB	14005201	LANE-4, ROAD-2, JAGANNATH VIHAR	1221DT111	100	MIXED	AMI	Yes	100%	63	0.0985134	0.085138	0.0133754	13.58%
866	TPCODL	BBSR1	BCDD-2	NAYAPALLI	BARAMUNDA	14005	11 KV BARAMUNDA BDA	14005202	B-28, BDA DUPLEX	1221DT016	500	MIXED	AMI	Yes	100%	106	0.24643624	0.146605	0.09983124	40.51%
867	TPCODL	BBSR1	BCDD-2	NAYAPALLI	BARAMUNDA	14005	11 KV BARAMUNDA BDA	14005202	NEAR TELCO COLONY 1	1221DT018	100	MIXED	AMI	Yes	100%	75	0.04749564	0.036939	0.01055664	22.23%
868	TPCODL	BBSR1	BCDD-2	NAYAPALLI	BARAMUNDA	14005	11 KV BARAMUNDA BDA	14005202	NEAR TELCO COLONY 3	1221DT020	100	MIXED	AMI	Yes	100%	16	0.01457186	0.00635	0.00822186	56.42%
869	TPCODL	BBSR1	BCDD-2	NAYAPALLI	BARAMUNDA	14005	11 KV BARAMUNDA BDA	14005202	APEX SHELTER APPERTMENT	1221DT026	250	MIXED	AMI	Yes	100%	8	0.02917096	0.010432	0.01873896	64.24%
870	TPCODL	BBSR1	BCDD-2	NAYAPALLI	BARAMUNDA	14005	11 KV BARAMUNDA BDA	14005202	BIVAB APPT	1221DT034	500	MIXED	AMI	Yes	100%	54	0.15162136	0.046948	0.10467336	69.04%
871	TPCODL	BBSR1	BCDD-2	NAYAPALLI	BARAMUNDA	14005	11 KV BARAMUNDA BDA	14005202	NEAR C-178, BDA DUPLEX (SAHAN M	1221DT038	500	MIXED	AMI	Yes	100%	124	0.13787056	0.127245	0.01062556	7.71%
872	TPCODL	BBSR1	BCDD-2	NAYAPALLI	BARAMUNDA	14005	11 KV BARAMUNDA BDA	14005202	RBI STAFF QUARTER-2	1221DT132	500	MIXED	AMI	Yes	100%	28	0.0225708	0.007937	0.0146338	64.84%
873	TPCODL	BBSR1	BCDD-2	NAYAPALLI	BARAMUNDA	14005	11 KV BARAMUNDA BDA	14005202	RBI STAFF QUARTER-3	1221DT133	500	MIXED	AMI	Yes	100%	53	0.02376704	0.012977	0.01079004	45.40%
874	TPCODL	BBSR1	BCDD-2	NAYAPALLI	BARAMUNDA	14005	11 KV CRPF	14005204	IN FRONT OF HIG A-15,BHB COLONY	1221DT049	250	MIXED	AMI	Yes	100%	86	0.15285722	0.124856	0.02800122	18.32%
875	TPCODL	BBSR1	BCDD-2	NAYAPALLI	BARAMUNDA	14005	11 KV CRPF	14005204	NEAR F-04 BLOCK RENTAL	1221DT050	100	MIXED	AMI	Yes	100%	113	0.05593888	0.040057	0.01588188	28.39%

Sl. No.	Zone Name	Circle name	Division name	Name of the Sub-division	Name of the Sub-station	Substation Code	Name of the 11 kV Feeder	Feeder Code	Name of the Location where DT situated	DT code	DT Capacity (kVA)	Predominant consumer type of DT (Domestic/Industrial/Agriculture/Mixed)	Type of metering AMR/AMI/ Communicable/Conventional metered/Unmetered	Status of Meter-whether Functional (Yes/No)	% of data received automatically (if AMR/AMI)	No. of Connected Consumers	Input Energy (MU) (A)	Billed Energy (MU) (B)	Loss (MU) (A-B)	% DT Loss (A-B)/A
876	TPCODL	BBSR1	BCDD-2	NAYAPALLI	BARAMUNDA	14005	11 KV CRPF	14005204	NEAR F-12 BLOCK,RENTAL	1221DT051	100	MIXED	AMI	Yes	100%	103	0.05721804	0.047168	0.01005004	17.56%
877	TPCODL	BBSR1	BCDD-2	NAYAPALLI	BARAMUNDA	14005	11 KV CRPF	14005204	NEAR T-10 BLOCK,RENTAL	1221DT052	100	MIXED	AMI	Yes	100%	106	0.07196162	0.058602	0.01335962	18.56%
878	TPCODL	BBSR1	BCDD-2	NAYAPALLI	BARAMUNDA	14005	11 KV CRPF	14005204	NEAR E-05 BLOCK, RENTAL	1221DT053	250	MIXED	AMI	Yes	67%	79	0.05286788	0.028764	0.02410388	45.59%
879	TPCODL	BBSR1	BCDD-2	NAYAPALLI	BARAMUNDA	14005	11 KV CRPF	14005204	NEAR E-18 BLOCK,RENTAL	1221DT055	100	MIXED	AMI	Yes	100%	86	0.05652766	0.040315	0.01621266	28.68%
880	TPCODL	BBSR1	BCDD-2	NAYAPALLI	BARAMUNDA	14005	11 KV CRPF	14005204	NEAR E-35 BLOCK, RENTAL	1221DT057	100	MIXED	AMI	Yes	100%	68	0.0453525	0.032971	0.0123815	27.30%
881	TPCODL	BBSR1	BCDD-2	NAYAPALLI	BARAMUNDA	14005	11 KV CRPF	14005204	NEAR F-41 BLOCK, RENTAL	1221DT060	250	MIXED	AMI	Yes	0%	101	0.08488776	0.03149	0.05339776	62.90%
882	TPCODL	BBSR1	BCDD-2	NAYAPALLI	BARAMUNDA	14005	11 KV CRPF	14005204	NEAR F-28 BLOCK, RENTAL	1221DT061	100	MIXED	AMI	Yes	100%	100	0.04712418	0.033652	0.01347218	28.59%
883	TPCODL	BBSR1	BCDD-2	NAYAPALLI	BARAMUNDA	14005	11 KV CRPF	14005204	NEAR F-22 BLOCK, RENTAL	1221DT062	100	MIXED	AMI	Yes	100%	90	0.06053614	0.030886	0.02965014	48.98%
884	TPCODL	BBSR1	BCDD-2	NAYAPALLI	BARAMUNDA	14005	11 KV CRPF	14005204	NEAR F-9 BLOCK, RENTAL	1221DT063	100	MIXED	AMI	Yes	100%	92	0.0513806	0.031172	0.0202086	39.33%
885	TPCODL	BBSR1	BCDD-2	NAYAPALLI	BARAMUNDA	14005	11 KV CRPF	14005204	NEAR F-17 BLOCK RENTAL	1221DT064	100	MIXED	AMI	Yes	100%	46	0.03753523	0.027342	0.01019323	27.16%
886	TPCODL	BBSR1	BCDD-2	NAYAPALLI	BARAMUNDA	14005	11 KV CRPF	14005204	GOPAL BASTI, JAGANNATH VIHAR	1221DT066	100	MIXED	AMI	Yes	100%	25	0.02119562	0.011581	0.00961462	45.36%
887	TPCODL	BBSR1	BCDD-2	NAYAPALLI	BARAMUNDA	14005	11 KV CRPF	14005204	LANE 12,JAGANATH VIHAR NO-2	1221DT069	250	MIXED	AMI	Yes	100%	43	0.20012595	0.06353	0.13659595	68.25%
888	TPCODL	BBSR1	BCDD-2	NAYAPALLI	BARAMUNDA	14005	11 KV CRPF	14005204	LANE-7, ROAD-3, JAGANNATH VIHAR	1221DT072	500	MIXED	AMI	Yes	100%	291	0.32603396	0.231057	0.09497696	29.13%
889	TPCODL	BBSR1	BCDD-2	NAYAPALLI	CS PUR-1	14001	11 KV BDA	14001203	MIG-I-BLOCK-4	1232DT189	250	MIXED	AMI	Yes	100%	240	0.16601334	0.122727	0.04328634	26.07%
890	TPCODL	BBSR1	BCDD-2	NAYAPALLI	INFOCITY	14003	11 KV RAJVATIKA	14003205	RAJVATIKA APPARTMENT	1233DT827	500	MIXED	AMI	Yes	100%	65	0.09903224	0.086645	0.01238724	12.51%
891	TPCODL	BBSR1	BCDD-2	NAYAPALLI	KANAN BIHAR	14217	11 KV PKB	14217204	COSMO	1235DT033	500	MIXED	AMI	Yes	0%	50	0.1160724	0.070959	0.0451134	38.87%
892	TPCODL	BBSR1	BCDD-2	NAYAPALLI	NAYAPALLI	14008	11 KV IRC-1	14008201	BACK SIDE OF TAKSILA SCHOOL	1222DT005	250	MIXED	AMI	Yes	100%	89	0.15090024	0.121301	0.02959924	19.62%
893	TPCODL	BBSR1	BCDD-2	NAYAPALLI	NAYAPALLI	14008	11 KV IRC-1	14008201	N5/383, HANUMAN TEMPLE	1222DT021	100	MIXED	AMI	Yes	100%	53	0.08499633	0.058438	0.02655833	31.25%
894	TPCODL	BBSR1	BCDD-2	NAYAPALLI	NAYAPALLI	14008	11 KV IRC-1	14008201	N5/383, HANUMAN TEMPLE-2	1222DT022	250	MIXED	AMI	Yes	100%	79	0.18468502	0.116023	0.06866202	37.18%
895	TPCODL	BBSR1	BCDD-2	NAYAPALLI	NAYAPALLI	14008	11 KV IRC-1	14008201	RICHIE BACK SIDE NO2	1222DT026	250	MIXED	AMI	Yes	100%	87	0.21123836	0.122438	0.08880036	42.04%
896	TPCODL	BBSR1	BCDD-2	NAYAPALLI	NAYAPALLI	14008	11 KV IRC-1	14008201	ID MARKET NEAR RAINBOW NO1	1222DT031	250	MIXED	AMI	Yes	100%	162	0.1955904	0.117338	0.0782524	40.01%
897	TPCODL	BBSR1	BCDD-2	NAYAPALLI	NAYAPALLI	14008	11 KV IRC-1	14008201	ID MARKET NEAR RAINBOW NO2	1222DT032	100	MIXED	AMI	Yes	0%	95	0.07170568	0.054817	0.01688868	23.55%
898	TPCODL	BBSR1	BCDD-2	NAYAPALLI	NAYAPALLI	14008	11 KV IRC-1	14008201	BALUNGA BASTI	1222DT043	100	MIXED	AMI	Yes	0%	248	0.10840816	0.10725	0.00115816	1.07%
899	TPCODL	BBSR1	BCDD-2	NAYAPALLI	NAYAPALLI	14008	11 KV IRC-1	14008201	GANAPATI BASTI	1222DT044	100	MIXED	AMI	Yes	100%	187	0.05374994	0.049527	0.00422294	7.86%
900	TPCODL	BBSR1	BCDD-2	NAYAPALLI	NAYAPALLI	14008	11 KV IRC-1	14008201	GANDHI BASTI	1222DT045	100	MIXED	AMI	Yes	100%	76	0.09137326	0.090395	0.00097826	1.07%
901	TPCODL	BBSR1	BCDD-2	NAYAPALLI	NAYAPALLI	14008	11 KV IRC-1	14008201	D-TYPE	1222DT046	100	MIXED	AMI	Yes	0%	19	0.02522542	0.019719	0.00550642	21.83%
902	TPCODL	BBSR1	BCDD-2	NAYAPALLI	NAYAPALLI	14008	11 KV IRC-1	14008201	NAYAPALLI POLICE STATION NO1	1222DT047	250	MIXED	AMI	Yes	100%	106	0.1700016	0.159718	0.0102836	6.05%
903	TPCODL	BBSR1	BCDD-2	NAYAPALLI	NAYAPALLI	14008	11 KV IRC-1	14008201	NAYAPALLI POLICE STATION NO2	1222DT048	250	MIXED	AMI	Yes	100%	43	0.0839492	0.072764	0.0111852	13.32%
904	TPCODL	BBSR1	BCDD-2	NAYAPALLI	NAYAPALLI	14008	11 KV IRC-1	14008201	TARINI BASTI	1222DT049	100	MIXED	AMI	Yes	100%	268	0.10848132	0.096202	0.01227932	11.32%
905	TPCODL	BBSR1	BCDD-2	NAYAPALLI	NAYAPALLI	14008	11 KV IRC-1	14008201	NEAR IDC NO1	1222DT166	100	MIXED	AMI	Yes	100%	39	0.03709137	0.029031	0.00806037	21.73%
906	TPCODL	BBSR1	BCDD-2	NAYAPALLI	NAYAPALLI	14008	11 KV IRC-2	14008202	NEAR N4/237 RELIANCE FRESH BACK	1222DT055	500	MIXED	AMI	Yes	67%	50	0.18978616	0.144472	0.04531416	23.88%
907	TPCODL	BBSR1	BCDD-2	NAYAPALLI	NAYAPALLI	14008	11 KV IRC-2	14008202	N4-HIGH SCHOOL NO2	1222DT244	250	MIXED	AMI	Yes	100%	140	0.21270088	0.187163	0.02553788	12.01%
908	TPCODL	BBSR1	BCDD-2	NAYAPALLI	NAYAPALLI	14008	11 KV IRC-3	14008203	ISKON TEMPLE 1	1222DT371	250	MIXED	AMI	Yes	100%	20	0.07790912	0.056124	0.02178512	27.96%
909	TPCODL	BBSR1	BCDD-2	NAYAPALLI	NAYAPALLI	14008	11 KV JAYDEV VIHAR	14008204	S RATH	1222DT120	100	MIXED	AMI	Yes	0%	8	0.01494478	0.014498	0.00044678	2.99%
910	TPCODL	BBSR1	BCDD-2	NAYAPALLI	NAYAPALLI	14008	11 KV JAYDEV VIHAR	14008204	LANE 3	1222DT123	500	MIXED	AMI	Yes	100%	131	0.37826208	0.219272	0.15899008	42.03%
911	TPCODL	BBSR1	BCDD-2	NAYAPALLI	NAYAPALLI	14008	11 KV JAYDEV VIHAR	14008204	IDBI BANK	1222DT126	100	MIXED	AMI	Yes	0%	2	0.03569096	0.035528	0.00016296	0.46%
912	TPCODL	BBSR1	BCDD-2	NAYAPALLI	NAYAPALLI	14008	11 KV JAYDEV VIHAR	14008204	N6/PARK NO.2	1222DT132	100	MIXED	AMI	Yes	0%	23	0.06420044	0.037328	0.02687244	41.86%
913	TPCODL	BBSR1	BCDD-2	NAYAPALLI	NAYAPALLI	14008	11 KV JAYDEV VIHAR	14008204	N6/145	1222DT135	100	MIXED	AMI	Yes	100%	80	0.10322816	0.103151	7.716E-05	0.07%
914	TPCODL	BBSR1	BCDD-2	NAYAPALLI	NAYAPALLI	14008	11 KV JAYDEV VIHAR	14008204	BESIDE OF N6 SCHOOL	1222DT137	250	MIXED	AMI	Yes	100%	60	0.20758952	0.116257	0.09133252	44.00%
915	TPCODL	BBSR1	BCDD-2	NAYAPALLI	NAYAPALLI	14008	11 KV JAYDEV VIHAR	14008204	JAYDEB TOWER 1	1222DT145	250	MIXED	AMI	Yes	100%	54	0.07291504	0.071308	0.00160704	2.20%
916	TPCODL	BBSR1	BCDD-2	NAYAPALLI	NAYAPALLI	14008	11 KV JAYDEV VIHAR	14008204	JAYDEB TOWER 2	1222DT146	100	MIXED	AMI	Yes	0%	18	0.03509754	0.019641	0.01545654	44.04%
917	TPCODL	BBSR1	BCDD-2	NAYAPALLI	NAYAPALLI	14008	11 KV JAYDEV VIHAR	14008204	BHAGABATI TEMPLE 1	1222DT150	500	MIXED	AMI	Yes	0%	148	0.35667304	0.298843	0.05783004	16.21%
918	TPCODL	BBSR1	BCDD-2	NAYAPALLI	NAYAPALLI	14008	11 KV JAYDEV VIHAR	14008204	BHAGABATI TEMPLE 2	1222DT151	100	MIXED	AMI	Yes	100%	13	0.01725324	0.009442	0.00781124	45.27%
919	TPCODL	BBSR1	BCDD-2	NAYAPALLI	NAYAPALLI	14008	11 KV JAYDEV VIHAR	14008204	JAYDEB BIHAR VENDING ZONE	1222DT152	100	MIXED	AMI	Yes	100%	59	0.07449072	0.055861	0.01862972	25.01%
920	TPCODL	BBSR1	BCDD-2	NAYAPALLI	NAYAPALLI	14008	11 KV JAYDEV VIHAR	14008204	D TYPE QUATER.JAYDEB BIHAR SQUA	1222DT153	500	MIXED	AMI	Yes	100%	92	0.19440848	0.140866	0.05354248	27.54%
921	TPCODL	BBSR1	BCDD-2	NAYAPALLI	NAYAPALLI	14008	11 KV JAYDEV VIHAR	14008204	BISHNUPRIYA DRAIN SIDE	1224DT005	250	MIXED	AMI	Yes	0%	33	0.12725297	0.042228	0.08502497	66.82%
922	TPCODL	BBSR1	BCDD-2	NAYAPALLI	NAYAPALLI	14008	11 KV JAYDEV VIHAR	14008204	SHREE JAGANNATH VILLA	1224DT007	100	MIXED	AMI	Yes	100%	13	0.01454168	0.009349	0.00519268	35.71%
923	TPCODL	BBSR1	BCDD-2	NAYAPALLI	NAYAPALLI	14008	11 KV JAYDEV VIHAR	14008204	DASARATHI ENCLAVE	1224DT012	100	MIXED	AMI	Yes	100%	28	0.03826634	0.030593	0.00767334	20.05%
924	TPCODL	BBSR1	BCDD-2	NAYAPALLI	NAYAPALLI	14008	11 KV JAYDEV VIHAR	14008204	N.K. DAS	1224DT013	250	MIXED	AMI	Yes	100%	172	0.17561484	0.118512	0.05710284	32.52%
925	TPCODL	BBSR1	BCDD-2	NAYAPALLI	NAYAPALLI	14008	11 KV JAYDEV VIHAR	14008204	NILACHAKRA NAGAR 1	1224DT014	250	MIXED	AMI	Yes	100%	670	0.3012492	0.239722	0.0615272	20.42%
926	TPCODL	BBSR1	BCDD-2	NAYAPALLI	NAYAPALLI	14008	11 KV JAYDEV VIHAR	14008204	NILACHAKRA NAGAR 2	1224DT015	100	MIXED	AMI	Yes	67%	394	0.1331484	0.13229	0.0008584	0.64%
927	TPCODL	BBSR1	BCDD-2	NAYAPALLI	NAYAPALLI	14008	11 KV RENTAL	14008205	SECTION OFFICE BACKSIDE NO1	1222DT245	250	MIXED	AMI	Yes	100%	64	0.1223962	0.108595	0.0138012	11.28%
928	TPCODL	BBSR1	BCDD-2	NAYAPALLI	NAYAPALLI	14008	11 KV RENTAL	14008205	D.S.NANDA NO1	1222DT250	250	MIXED	AMI	Yes	0%	262	0.31337308	0.168795	0.14457808	46.14%
929	TPCODL	BBSR1	BCDD-2	NAYAPALLI	NAYAPALLI	14008	11 KV RENTAL	14008205	D.S.NANDA NO2	1222DT251	250	MIXED	AMI	Yes	100%	61	0.11238524	0.073334	0.03905124	34.75%
930	TPCODL	BBSR1	BCDD-2	NAYAPALLI	NAYAPALLI	14008	11 KV RENTAL	14008205	N3 ADIVASI BASTI	1222DT252	100	MIXED	AMI	Yes	0%	89	0.05863946	0.032238	0.02640146	45.02%
931	TPCODL	BBSR1	BCDD-2	NAYAPALLI	NAYAPALLI	14008	11 KV RENTAL	14008205	N3/319	1222DT265	100	MIXED	AMI	Yes	0%	32	0.06491356	0.052014	0.01289956	19.87%
932	TPCODL	BBSR1	BCDD-2	NAYAPALLI	NAYAPALLI	14008	11 KV RENTAL	14008205	JANATA NAGAR	1224DT032	250	MIXED	AMI	Yes	100%	42	0.1048806	0.045456	0.0594246	56.66%
933	TPCODL	BBSR1	BCDD-2	NAYAPALLI	NAYAPALLI	14008	11 KV RENTAL	14008205	SABYASACHI 1	1224DT034	100	MIXED	AMI	Yes	100%	7	0.0087876	0.00602	0.0027676	31.49%
934	TPCODL	BBSR1	BCDD-2	NAYAPALLI	NAYAPALLI	14008	11 KV NALCO	14008206	MAILA TANKI, SALIA SAHI	1224DT048	500	MIXED	AMI	Yes	100%	509	0.49065168	0.210539	0.28011268	57.09%
935	TPCODL	BBSR1	BCDD-2	NAYAPALLI	NAYAPALLI	14008	11 KV NALCO	14008206	HANDIA HATA	1224DT055	250	MIXED	AMI	Yes	100%	212	0.22522296	0.07064	0.15458296	68.64%
936	TPCODL	BBSR1	BCDD-2	NAYAPALLI	NAYAPALLI	14008	11 KV NALCO	14008206	NIRANKARI NAGAR,SAI YOUTH DEVEL	1224DT057	250	MIXED	AMI	Yes	0%	262	0.22922328	0.105775	0.12344828	53.86%
937	TPCODL	BBSR1	BCDD-2	NAYAPALLI	NAYAPALLI	14008	11 KV NALCO	14008206	EKAMBRE VIHAR	1224DT061	500	MIXED	AMI	Yes	100%	1215	0.54789152	0.428031	0.11986052	21.88%
938	TPCODL	BBSR1	BCDD-2	NAYAPALLI	NAYAPALLI	14008	11 KV NALCO	14008206	HATIASAHI	1224DT069	100	MIXED	AMI	Yes	100%	220	0.1303556	0.07615	0.0542056	41.58%
939	TPCODL	BBSR1	BCDD-2	NAYAPALLI	NAYAPALLI	14008	11 KV NALCO	14008206	HATIASAHI 1	1224DT070	100	MIXED	AMI	Yes	67%	67	0.03269631	0.021456	0.01124031	34.38%
940	TPCODL	BBSR1	BCDD-2	NAYAPALLI	NAYAPALLI	14008	11 KV NALCO	14008206	SALIA SAHI, NEAR BISHNUPRIYA APAI	1224DT072	250	MIXED	AMI	Yes	100%	289	0.15932605	0.109077	0.05024905	31.54%
941	TPCODL	BBSR1	BCDD-2	NAYAPALLI	NAYAPALLI	14008	11 KV IRC-4	14008207	N2/54	1222DT186	100	MIXED	AMI	Yes	100%	4	0.0102894	0.00981	0.0004794	4.66%
942	TPCODL	BBSR1	BCDD-2	NAYAPALLI	NAYAPALLI	14008	11 KV IRC-4	14008207	MAHAVEER TEMPLE	1222DT209	500	MIXED	AMI	Yes	100%	35	0.12596024	0.064337	0.06162324	48.92%
943	TPCODL	BBSR1	BCDD-2	NAYAPALLI	NAYAPALLI	14008	11 KV IRC-4	14008207	N1/17 R.K BEHERA	1222DT214	250	MIXED	AMI	Yes	0%	9	0.03226352	0.023461	0.00880252	27.28%
944	TPCODL	BBSR1	BCDD-2	NAYAPALLI	RRL ODSSP	14231	11 KV 7TH BATTALION	14231201	SAFETY MINES COLONY	1224DT196	100	MIXED	AMI	Yes	100%	9	0.01611224	0.008103	0.00800924	49.71%
945	TPCODL	BBSR1	BCDD-2	NAYAPALLI	RRL ODSSP	14231	11 KV PAL HEIGHT	14231203	SHRESTHA APPARTMENT	1222DT345	500	MIXED	AMI	Yes	100%	35	0.0478674	0.027853	0.0200144	41.81%
946	TPCODL	BBSR1	BCDD-2	NAYAPALLI	RRL ODSSP	14231	11 KV PAL HEIGHT	14231203	DARSHAN ACADEMY LANE	1222DT354	250	MIXED	AMI	Yes	100%	101	0.19323532	0.181334	0.01190132	6.16%
947	TPCODL	BBSR1	BCDD-2	NAYAPALLI	RRL ODSSP	14231	11 KV PAL HEIGHT	14231203	HATIASAHI PHD	1224DT021	500	MIXED	AMI	Yes	100%	173	0.20211464	0.196016	0.00609864	3.02%
948	TPCODL	BBSR1	BCDD-2	NAYAPALLI	RRL ODSSP	14231	11 KV PAL HEIGHT	14231203	JYOTSHNA APP.	1224DT025	500	MIXED	AMI	Yes	100%	69	0.13103064	0.070845	0.06018564	45.93%

Sl. No.	Zone Name	Circle name	Division name	Name of the Sub-division	Name of the Sub-station	Substation Code	Name of the 11 kV Feeder	Feeder Code	Name of the Location where DT situated	DT code	DT Capacity (kVA)	Predominant consumer type of DT (Domestic/Industrial/Agriculture/Mixed)	Type of metering AMR/AMI/ Communicable/Conventional metered/Unmetered	Status of Meter-whether Functional (Yes/No)	% of data received automatically (if AMR/AMI)	No. of Connected Consumers	Input Energy (MU) (A)	Billed Energy (MU) (B)	Loss (MU) (A-B)	% DT Loss (A-B)/A
949	TPCODL	BBSR1	BCDD-2	NAYAPALLI	RRL ODSSP	14231	11 KV PAL HEIGHT	14231203	SIBRAT APP.	1224DT030	100	MIXED	AMI	Yes	0%	117	0.07889406	0.051411	0.02748306	34.84%
950	TPCODL	BBSR1	BCDD-2	NAYAPALLI	SAINIK SCHOOL	14010	11 KV VSS NAGAR	14010201	DHIRUKUTI MOHANTY COLONY	1223DT090	63	MIXED	AMI	Yes	100%	44	0.03879124	0.026637	0.01215424	31.33%
951	TPCODL	BBSR1	BCDD-2	NAYAPALLI	SAINIK SCHOOL	14010	11 KV VSS NAGAR	14010201	DHIRUKUTI NO-2 (JAGANNATH TEMP	1223DT091	250	MIXED	AMI	Yes	100%	365	0.1990976	0.148804	0.0502936	25.26%
952	TPCODL	BBSR1	BCDD-2	NAYAPALLI	SAINIK SCHOOL	14010	11 KV VSS NAGAR	14010201	MAHAVIR BASTI VSS NAGAR	1223DT094	100	MIXED	AMI	Yes	100%	150	0.07427251	0.064137	0.01013551	13.65%
953	TPCODL	BBSR1	BCDD-2	NAYAPALLI	SAINIK SCHOOL	14010	11 KV VSS NAGAR	14010201	DHIRUKUTI KHELA PADIA (RAPDRP)	1223DT096	100	MIXED	AMI	Yes	33%	129	0.097363	0.080739	0.016624	17.07%
954	TPCODL	BBSR1	BCDD-2	NAYAPALLI	SAINIK SCHOOL	14010	11 KV VSS NAGAR	14010201	DHIRIKUTI BASTI NO-1	1223DT101	250	MIXED	AMI	Yes	100%	333	0.16808574	0.117598	0.05048774	30.04%
955	TPCODL	BBSR1	BCDD-2	NAYAPALLI	SAINIK SCHOOL	14010	11 KV VSS NAGAR	14010201	SUBHADRA APARTMENT	1223DT105	250	MIXED	AMI	Yes	100%	21	0.03129084	0.023298	0.00799284	25.54%
956	TPCODL	BBSR1	BCDD-2	NAYAPALLI	SAINIK SCHOOL	14010	11 KV VSS NAGAR	14010201	RANGAMATIA-1(UPPER SAHI)	1223DT106	500	MIXED	AMI	Yes	0%	322	0.4022012	0.332325	0.0698762	17.37%
957	TPCODL	BBSR1	BCDD-2	NAYAPALLI	SAINIK SCHOOL	14010	11 KV VSS NAGAR	14010201	SRD EXOTIC	1223DT109	100	MIXED	AMI	Yes	100%	14	0.01664768	0.01276	0.00388768	23.35%
958	TPCODL	BBSR1	BCDD-2	NAYAPALLI	SAINIK SCHOOL	14010	11 KV VSS NAGAR	14010201	RADHADAMODAR APPARTMENT	1223DT110	250	MIXED	AMI	Yes	0%	18	0.0467702	0.01298	0.0337902	72.25%
959	TPCODL	BBSR1	BCDD-2	NAYAPALLI	SAINIK SCHOOL	14010	11 KV VSS NAGAR	14010201	SOMANATH ENCLAVE	1223DT112	100	MIXED	AMI	Yes	100%	10	0.01440382	0.008654	0.00574982	39.92%
960	TPCODL	BBSR1	BCDD-2	NAYAPALLI	SAINIK SCHOOL	14010	11 KV VSS NAGAR	14010201	DHPL HOMES	1223DT113	500	MIXED	AMI	Yes	100%	57	0.07514648	0.053406	0.02174048	28.93%
961	TPCODL	BBSR1	BCDD-2	NAYAPALLI	SAINIK SCHOOL	14010	11 KV VSS NAGAR	14010201	RANGAMATIA 2	1223DT115	250	MIXED	AMI	Yes	100%	195	0.2314102	0.195695	0.0357152	15.43%
962	TPCODL	BBSR1	BCDD-2	NAYAPALLI	SAINIK SCHOOL	14010	11 KV VSS NAGAR	14010201	RANGAMATIA TALA SAHI	1223DT117	250	MIXED	AMI	Yes	100%	196	0.18520284	0.182424	0.00277884	1.50%
963	TPCODL	BBSR1	BCDD-2	NAYAPALLI	SAINIK SCHOOL	14010	11 KV VSS NAGAR	14010201	APARTI ENCLAVE	1223DT118	250	MIXED	AMI	Yes	100%	15	0.02707496	0.020445	0.00662996	24.49%
964	TPCODL	BBSR1	BCDD-2	NAYAPALLI	SAINIK SCHOOL	14010	11 KV VSS NAGAR	14010201	DHPL SAHOO COMPLEX	1223DT119	500	MIXED	AMI	Yes	100%	74	0.09133784	0.056026	0.03531184	38.66%
965	TPCODL	BBSR1	BCDD-2	NAYAPALLI	SAINIK SCHOOL	14010	11 KV VSS NAGAR	14010201	HARSHA PRIYA NEELACHAL (MAHALA	1223DT121	500	MIXED	AMI	Yes	100%	29	0.0613032	0.029225	0.0320782	52.33%
966	TPCODL	BBSR1	BCDD-2	NAYAPALLI	SAINIK SCHOOL	14010	11 KV VSS NAGAR	14010201	NEELACHAL LAGOON	1223DT182	250	MIXED	AMI	Yes	100%	12	0.01528412	0.011392	0.00389212	25.47%
967	TPCODL	BBSR1	BCDD-2	NAYAPALLI	SAINIK SCHOOL	14010	11 KV VSS NAGAR	14010201	JAGANNATH ENCLAVE	1223DT183	100	MIXED	AMI	Yes	100%	13	0.0119525	0.009292	0.0026605	22.26%
968	TPCODL	BBSR1	BCDD-2	NAYAPALLI	SAINIK SCHOOL	14010	11 KV GAJAPATINAGAR	14010202	PURNA CHANDRA ENCLAVE	1224DT133	100	MIXED	AMI	Yes	100%	14	0.01474647	0.013527	0.00121947	8.27%
969	TPCODL	BBSR1	BCDD-2	NAYAPALLI	SAINIK SCHOOL	14010	11 KV GAJAPATINAGAR	14010202	JAGANNATH APPARENT	1224DT137	500	MIXED	AMI	Yes	100%	77	0.10146104	0.067758	0.03370304	33.22%
970	TPCODL	BBSR1	BCDD-2	NAYAPALLI	SAINIK SCHOOL	14010	11 KV GAJAPATINAGAR	14010202	DR. HOUSE	1224DT140	250	MIXED	AMI	Yes	100%	57	0.14545392	0.088819	0.05663492	38.94%
971	TPCODL	BBSR1	BCDD-2	NAYAPALLI	SAINIK SCHOOL	14010	11 KV GAJAPATINAGAR	14010202	JANAKAR SAHOO	1224DT142	100	MIXED	AMI	Yes	100%	13	0.02092333	0.017662	0.00326133	15.59%
972	TPCODL	BBSR1	BCDD-2	NAYAPALLI	SAINIK SCHOOL	14010	11 KV GAJAPATINAGAR	14010202	THE BATTALION	1224DT146	200	MIXED	AMI	Yes	100%	68	0.0954577	0.074064	0.0213937	22.41%
973	TPCODL	BBSR1	BCDD-2	NAYAPALLI	SAINIK SCHOOL	14010	11 KV GAJAPATINAGAR	14010202	GARAGE S/S 7TH BATTALION	1224DT150	250	MIXED	AMI	Yes	100%	124	0.10755712	0.077489	0.03006812	27.96%
974	TPCODL	BBSR1	BCDD-2	NAYAPALLI	SAINIK SCHOOL	14010	11 KV GAJAPATINAGAR	14010202	POLICE BARAK NEW QUARTER	1224DT312	200	MIXED	AMI	Yes	100%	17	0.0266106	0.014925	0.0116856	43.91%
975	TPCODL	BBSR1	BCDD-2	NAYAPALLI	SAINIK SCHOOL	14010	11 KV PRESS	14010203	ADIMATA COLONY 2	1223DT058	250	MIXED	AMI	Yes	100%	43	0.16081496	0.081022	0.07979296	49.62%
976	TPCODL	BBSR1	BCDD-2	NAYAPALLI	SAINIK SCHOOL	14010	11 KV PRESS	14010203	GOVT COLONY F-12	1223DT062	500	MIXED	AMI	Yes	100%	142	0.07775088	0.056133	0.02161788	27.80%
977	TPCODL	BBSR1	BCDD-2	NAYAPALLI	SAINIK SCHOOL	14010	11 KV PRESS	14010203	GOVT COLONY, D TYPE	1223DT064	500	MIXED	AMI	Yes	67%	61	0.07361648	0.042124	0.03149248	42.78%
978	TPCODL	BBSR1	BCDD-2	NAYAPALLI	SAINIK SCHOOL	14010	11 KV PRESS	14010203	GOVT COLONY, E TYPE	1223DT066	500	MIXED	AMI	Yes	100%	206	0.1305796	0.096945	0.0336346	25.76%
979	TPCODL	BBSR1	BCDD-2	NAYAPALLI	SAINIK SCHOOL	14010	11 KV PRESS	14010203	GOVT COLONY, F-1 TYPE	1223DT067	500	MIXED	AMI	Yes	100%	118	0.08999216	0.050889	0.03910316	43.45%
980	TPCODL	BBSR1	BCDD-2	NAYAPALLI	SAINIK SCHOOL	14010	11 KV PRESS	14010203	ADIMATA MASJID	1223DT068	200	MIXED	AMI	Yes	100%	64	0.14852688	0.093511	0.05501588	37.04%
981	TPCODL	BBSR1	BCDD-2	NAYAPALLI	SAINIK SCHOOL	14010	11 KV PRESS	14010203	SUDASHAN HILL	1223DT070	100	MIXED	AMI	Yes	100%	11	0.00831786	0.00555	0.00276786	33.28%
982	TPCODL	BBSR1	BCDD-2	NAYAPALLI	SAINIK SCHOOL	14010	11 KV PRESS	14010203	MISHRA SHESADEV	1224DT088	250	MIXED	AMI	Yes	100%	15	0.01416116	0.012662	0.00149916	10.59%
983	TPCODL	BBSR1	BCDD-2	NAYAPALLI	SAINIK SCHOOL	14010	11 KV PRESS	14010203	SAMANTA VIHAR	1224DT100	250	MIXED	AMI	Yes	100%	25	0.14941664	0.090778	0.05863864	39.25%
984	TPCODL	BBSR1	BCDD-2	NAYAPALLI	SAINIK SCHOOL	14010	11 KV PRESS	14010203	AADYA PALACE	1224DT112	250	MIXED	AMI	Yes	100%	31	0.0383446	0.035735	0.0026096	6.81%
985	TPCODL	BBSR1	BCDD-2	NAYAPALLI	SAINIK SCHOOL	14010	11 KV PRESS	14010203	SAI ROYAL SIGNATURE	1224DT359	100	MIXED	AMI	Yes	100%	9	0.03620766	0.013833	0.02237466	61.80%
986	TPCODL	BBSR1	BCDD-2	NAYAPALLI	SAINIK SCHOOL	14010	11 KV PRESS	14010203	AADYA PALACE BLACK-C	1224DT363	500	MIXED	AMI	Yes	100%	40	0.03850888	0.036546	0.00196288	5.10%
987	TPCODL	BBSR1	BCDD-2	NAYAPALLI	SAINIK SCHOOL	14010	11 KV VANIVIHAR	14010204	SAINIK SCHOOL	1223DT074	250	MIXED	AMI	Yes	100%	7	0.14675584	0.145537	0.00121884	0.83%
988	TPCODL	BBSR1	BCDD-2	NAYAPALLI	SAINIK SCHOOL	14010	11 KV VANIVIHAR	14010204	LAXMI VIHAR-2 (LANE-3)	1223DT077	100	MIXED	AMI	Yes	0%	8	0.02206644	0.012353	0.00971344	44.02%
989	TPCODL	BBSR1	BCDD-2	NAYAPALLI	SAINIK SCHOOL	14010	11 KV VANIVIHAR	14010204	JYOTI ENCLAVE	1224DT347	100	MIXED	AMI	Yes	100%	14	0.0229872	0.016067	0.0069202	30.10%
990	TPCODL	BBSR1	BCDD-2	NAYAPALLI	SAINIK SCHOOL	14010	11 KV VANIVIHAR	14010204	LAXMI VIHAR LANE-1 RAPDRP	1224DT348	250	MIXED	AMI	Yes	100%	113	0.25804588	0.192912	0.06513388	25.24%
991	TPCODL	BBSR1	BCDD-2	NAYAPALLI	SAINIK SCHOOL	14010	11 KV VANIVIHAR	14010204	GOURI SHANKAR RESIDENCY	1224DT349	250	MIXED	AMI	Yes	100%	27	0.0481462	0.046217	0.0019292	4.01%
992	TPCODL	BBSR1	BCDD-2	NAYAPALLI	SAINIK SCHOOL	14010	11 KV SAINIK SCHOOL	14010205	ADIMATA COLONY	1223DT054	100	MIXED	AMI	Yes	0%	13	0.05692772	0.018795	0.03813272	66.98%
993	TPCODL	BBSR1	BCDD-2	NAYAPALLI	SAINIK SCHOOL	14010	11 KV SAINIK SCHOOL	14010205	GADAKANA TALA SAHI-2	1223DT126	250	MIXED	AMI	Yes	100%	118	0.18378712	0.129769	0.05401812	29.39%
994	TPCODL	BBSR1	BCDD-2	NAYAPALLI	SAINIK SCHOOL	14010	11 KV SAINIK SCHOOL	14010205	GADAKANA PATRA SAHI	1223DT127	250	MIXED	AMI	Yes	100%	107	0.183134	0.146134	0.037	20.20%
995	TPCODL	BBSR1	BCDD-2	NAYAPALLI	SAINIK SCHOOL	14010	11 KV SAINIK SCHOOL	14010205	HARSHAPRIYA NEELACHLA-2	1223DT129	500	MIXED	AMI	Yes	100%	57	0.0523764	0.043383	0.0089934	17.17%
996	TPCODL	BBSR1	BCDD-2	NAYAPALLI	SAINIK SCHOOL	14010	11 KV SAINIK SCHOOL	14010205	GADAKANA SUNDHI SAHI	1223DT133	500	MIXED	AMI	Yes	0%	295	0.36129288	0.252512	0.10878088	30.11%
997	TPCODL	BBSR1	BCDD-2	NAYAPALLI	SAINIK SCHOOL	14010	11 KV SAINIK SCHOOL	14010205	AHALYA ENCLAVE-1	1223DT205	500	MIXED	AMI	Yes	0%	41	0.04966664	0.048491	0.00117564	2.37%
998	TPCODL	BBSR1	BCDD-2	NAYAPALLI	SAINIK SCHOOL	14010	11 KV SAINIK SCHOOL	14010205	AHALYA ENCLAVE-2	1223DT206	500	MIXED	AMI	Yes	100%	55	0.05311608	0.051291	0.00182508	3.44%
999	TPCODL	BBSR1	BCDD-2	NAYAPALLI	VANIVIHAR ODSSP	14230	11 KV INCOME TAX	14230203	GL COLONY	1223DT022	500	MIXED	AMI	Yes	100%	152	0.22117776	0.198373	0.02280476	10.31%
1000	TPCODL	BBSR1	BCDD-2	NAYAPALLI	VANIVIHAR ODSSP	14230	11 KV INCOME TAX	14230203	GOJABAYANI TEMPLE	1223DT026	100	MIXED	AMI	Yes	100%	47	0.06021169	0.048971	0.01124069	18.67%
1001	TPCODL	BBSR1	BCDD-2	NAYAPALLI	VANIVIHAR ODSSP	14230	11 KV INCOME TAX	14230203	VM COLONY	1223DT030	100	MIXED	AMI	Yes	0%	77	0.11509016	0.090635	0.02445516	21.25%
1002	TPCODL	BBSR1	BCDD-2	NAYAPALLI	VANIVIHAR ODSSP	14230	11 KV INCOME TAX	14230203	PATHAR BANDHA BASTI 3	1223DT038	500	MIXED	AMI	Yes	100%	111	0.11323488	0.059321	0.05391388	47.61%
1003	TPCODL	BBSR1	BCDD-2	NAYAPALLI	VANIVIHAR ODSSP	14230	11 KV INCOME TAX	14230203	PATHAR BANDHA BASTI 1	1223DT039	500	MIXED	AMI	Yes	100%	474	0.20162616	0.152351	0.04927516	24.44%
1004	TPCODL	BBSR1	BCDD-2	NAYAPALLI	VANIVIHAR ODSSP	14230	11 KV INCOME TAX	14230203	PATHAR BANDHA BASTI 2	1223DT040	100	MIXED	AMI	Yes	0%	280	0.09864386	0.089089	0.00955486	9.69%
1005	TPCODL	BBSR1	BCDD-2	NAYAPALLI	VANIVIHAR ODSSP	14230	11 KV INCOME TAX	14230203	INCOMETEX QTER	1223DT042	250	MIXED	AMI	Yes	100%	28	0.05130204	0.018602	0.03270004	63.74%
1006	TPCODL	BBSR1	BCDD-2	NAYAPALLI	VANIVIHAR ODSSP	14230	11 KV INCOME TAX	14230203	VANIVIHAR AKHANDALA MANI BASTI	1223DT048	100	MIXED	AMI	Yes	100%	85	0.04746257	0.026469	0.02099357	44.23%
1007	TPCODL	BBSR1	BCDD-2	NAYAPALLI	VANIVIHAR ODSSP	14230	11 KV INCOME TAX	14230203	TARINI BAST	1223DT050	100	MIXED	AMI	Yes	33%	161	0.09937733	0.050082	0.04929533	49.60%
1008	TPCODL	BBSR1	BCDD-2	NAYAPALLI	VANIVIHAR ODSSP	14230	11 KV LAXMI VIHAR	14230204	CL COLONY	1223DT002	250	MIXED	AMI	Yes	100%	75	0.11577512	0.087576	0.02819912	24.36%
1009	TPCODL	BBSR1	BCDD-2	NAYAPALLI	VANIVIHAR ODSSP	14230	11 KV LAXMI VIHAR	14230204	NEAR CL-9	1223DT003	100	MIXED	AMI	Yes	0%	30	0.03658866	0.020612	0.01597666	43.67%
1010	TPCODL	BBSR1	BCDD-2	NAYAPALLI	VANIVIHAR ODSSP	14230	11 KV LAXMI VIHAR	14230204	MALATI ROUTRAY (CM-1)	1223DT005	250	MIXED	AMI	Yes	0%	82	0.19649612	0.094344	0.10215212	51.99%
1011	TPCODL	BBSR1	BCDD-2	NAYAPALLI	VANIVIHAR ODSSP	14230	11 KV LAXMI VIHAR	14230204	AE&AL COLONY	1223DT006	500	MIXED	AMI	Yes	100%	331	0.38605328	0.323332	0.06272128	16.25%
1012	TPCODL	BBSR1	BCDD-2	NAYAPALLI	VANIVIHAR ODSSP	14230	11 KV LAXMI VIHAR	14230204	AE&AL COLONY	1223DT007	500	MIXED	AMI	Yes	100%	318	0.32645504	0.314711	0.01174404	3.60%
1013	TPCODL	BBSR1	BCDD-2	NAYAPALLI	VANIVIHAR ODSSP	14230	11 KV LAXMI VIHAR	14230204	AM & BM COLONY	1223DT009	500	MIXED	AMI	Yes	100%	258	0.39791376	0.294192	0.10372176	26.07%
1014	TPCODL	BBSR1	BCDD-2	NAYAPALLI	VANIVIHAR ODSSP	14230	11 KV LAXMI VIHAR	14230204	VSS NAGAR HATA	1223DT012	500	MIXED	AMI	Yes	100%	416	0.32668008	0.272515	0.05416508	16.58%
1015	TPCODL	BBSR1	BCDD-2	NAYAPALLI	XAVIER	14009	11 KV STPI	14009202	MATRI VIHAR D-TYPE	1224DT278	500	MIXED	AMI	Yes	100%	60	0.24850544	0.09743	0.15107544	60.79%
1016	TPCODL	BBSR1	BCDD-2	NAYAPALLI	XAVIER	14009	11 KV STPI	14009202	MAITRI BIHAR PH-I	1224DT281	500	MIXED	AMI	Yes	100%	177	0.22394024	0.221159	0.00278124	1.24%
1017	TPCODL	BBSR1	BCDD-2	NAYAPALLI	XAVIER	14009	11 KV STPI	14009202	AUM GARDENS	1224DT284	250	MIXED	AMI	Yes	100%	18	0.0759562	0.034973	0.0409832	53.96%
1018	TPCODL	BBSR1	BCDD-2	NAYAPALLI	XAVIER	14009	11 KV STPI	14009202	PRIMIER PREMISES	1224DT286	250	MIXED	AMI	Yes	100%	31	0.03476886	0.024985	0.00978386	28.14%
1019	TPCODL	BBSR1	BCDD-2	NAYAPALLI	XAVIER	14009	11 KV STPI	14009202	LAXMIPUR SANTAL BASTI	1224DT288	100	MIXED	AMI	Yes	100%	152	0.09011164	0.054576	0.03553564	39.44%
1020	TPCODL	BBSR1	BCDD-2	NAYAPALLI	XAVIER	14009	11 KV HATIASUNI	14009205	PHD INFRONT OF LOYOLA SCHOOL	1224DT169	250	MIXED	AMI	Yes	100%	428	0.14243444	0.126615	0.01581944	11.11%
1021	TPCODL	BBSR1	BCDD-2	NAYAPALLI	XAVIER	14009	11 KV HATIASUNI	14009205	SAMBHU SHOP	1224DT178	250	MIXED	AMI	Yes	100%	231	0.32657716	0.090826	0.23575116	72.19%

Sl. No.	Zone Name	Circle name	Division name	Name of the Sub-division	Name of the Sub-station	Substation Code	Name of the 11 kV Feeder	Feeder Code	Name of the Location where DT situated	DT code	DT Capacity (kVA)	Predominant consumer type of DT (Domestic/Industrial/Agriculture/Mixed)	Type of metering AMR/AMI/ Communicable/Conventional metered/Unmetered	Status of Meter- whether Functional (Yes/No)	% of data received automatically (if AMR/AMI)	No. of Connected Consumers	Input Energy (MU) (A)	Billed Energy (MU) (B)	Loss (MU) (A-B)	% DT Loss (A-B)/A
1022	TPCODL	BBSR1	BCDD-2	NAYAPALLI	XAVIER	14009	11 KV HATIASUNI	14009205	TARINI NAGAR-I	1224DT182	100	MIXED	AMI	Yes	100%	135	0.15796534	0.06146	0.09650534	61.09%
1023	TPCODL	BBSR1	BCDD-2	NAYAPALLI	XAVIER	14009	11 KV HATIASUNI	14009205	WOMANS POLYTECHNIC HOSTEL	1224DT185	250	MIXED	AMI	Yes	33%	362	0.16463476	0.152225	0.01240976	7.54%
1024	TPCODL	BBSR1	BCDD-2	PERIPHERI	NAYAPALLI	14008	11 kV IRC-4	14008207	N2/29	1222DT198	100	MIXED	AMI	Yes	100%	34	0.11264244	0.074628	0.03801444	33.75%
1025	TPCODL	BBSR1	BCDD-2	PERIPHERI	CHANDAKA ODSSP	14246	11 kV DASPUR	14246202	TRINATH MANDIR	1231DT373	100	MIXED	AMI	Yes	0%	76	0.11192962	0.056305	0.05562462	49.70%
1026	TPCODL	BBSR1	BCDD-2	PERIPHERI	CHANDAKA ODSSP	14246	11 kV DASPUR	14246202	MAHIMA PRAVU KRUPU	1231DT380	100	MIXED	AMI	Yes	100%	19	0.03499944	0.008463	0.02653644	75.82%
1027	TPCODL	BBSR1	BCDD-2	PERIPHERI	CHANDAKA ODSSP	14246	11 kV DASPUR	14246202	ANDARUA-IV	1231DT396	100	MIXED	AMI	Yes	100%	64	0.0519251	0.037455	0.0144701	27.87%
1028	TPCODL	BBSR1	BCDD-2	PERIPHERI	NEW KALARAHANG	14251	11 kV DHAWA	14251202	TANGIBANTA NO-1	1231DT519	100	MIXED	AMI	Yes	0%	138	0.08272368	0.070623	0.01210068	14.63%
1029	TPCODL	BBSR1	BCDD-2	PERIPHERI	NEW KALARAHANG	14251	11 kV DHAWA	14251202	GOKANPUR	1231DT530	100	MIXED	AMI	Yes	0%	108	0.07937514	0.071229	0.00814614	10.26%
1030	TPCODL	BBSR1	BCDD-2	PERIPHERI	NEW KALARAHANG	14251	11 kV DHAWA	14251202	NUABANTA	1231DT558	100	MIXED	AMI	Yes	0%	51	0.04799812	0.023554	0.02444412	50.93%
1031	TPCODL	BBSR1	BCDD-2	PERIPHERI	NEW BARANGA	14216	11 kV ANDHARUA	14216202	NEAR DARUTENGA BAKULESWAR MA	1231DT759	250	MIXED	AMI	Yes	67%	107	0.12197698	0.035811	0.08616598	70.64%
1032	TPCODL	BBSR1	BCDD-2	PERIPHERI	NEW BARANGA	14216	11 kV ANDHARUA	14216202	DARUTENGA ROAD 2_1	1231DT764	100	MIXED	AMI	Yes	0%	42	0.08728582	0.034136	0.05314982	60.89%
1033	TPCODL	BBSR1	BCDD-2	PERIPHERI	ROYAL LAGOON	14389	11 kV Feeder-2	14389202	ROYAL LAGOON DT-3	1231DT784	500	MIXED	AMI	Yes	100%	114	0.19017264	0.178251	0.01192164	6.27%
1034	TPCODL	BBSR1	BCDD-2	PERIPHERI	ROYAL LAGOON	14389	11 kV Feeder-1	14389201	ROYAL LAGOON DT-5	1231DT786	500	MIXED	AMI	Yes	100%	99	0.1757324	0.146196	0.0295364	16.81%
1035	TPCODL	BBSR1	BCDD-2	PERIPHERI	ROYAL LAGOON	14389	11 kV Feeder-1	14389201	ROYAL LAGOON DT-7	1231DT787	500	MIXED	AMI	Yes	100%	105	0.18315992	0.157143	0.02601692	14.20%
1036	TPCODL	BBSR1	BCDD-2	PERIPHERI	ROYAL LAGOON	14389	11 kV Feeder-1	14389201	ROYAL LAGOON DT-6	1231DT788	500	MIXED	AMI	Yes	100%	119	0.16604528	0.158939	0.00710628	4.28%
1037	TPCODL	BBSR1	BCDD-2	PERIPHERI	ROYAL LAGOON	14389	11 kV Feeder-2	14389202	ROYAL LAGOON DT-2	1231DT789	500	MIXED	AMI	Yes	100%	102	0.17018088	0.152795	0.01738588	10.22%
1038	TPCODL	BBSR1	BCDD-2	PERIPHERI	NEW BARANGA	14216	11 kV FEEDER-1	14216204	Dream villa	1231DT887	500	MIXED	AMI	Yes	0%	13	0.03027544	0.009877	0.02039844	67.38%
1039	TPCODL	BBSR1	BCDD-2	PERIPHERI	CS PUR-1	14001	11 kV CSPUR H B	14001204	RAPDRP NEAR 7 ACRE	1232DT049	250	MIXED	AMI	Yes	0%	144	0.09363	0.082818	0.010812	11.55%
1040	TPCODL	BBSR1	BCDD-2	PERIPHERI	CS PUR-1	14001	11 kV SRI VIHAR	14001201	NILAPODIA BASTI	1232DT111	100	MIXED	AMI	Yes	67%	118	0.03064382	0.026042	0.00460182	15.02%
1041	TPCODL	BBSR1	BCDD-2	PERIPHERI	CS PUR-1	14001	11 kV SRI VIHAR	14001201	OM VILL	1232DT129	250	MIXED	AMI	Yes	0%	33	0.0389794	0.029332	0.0096474	24.75%
1042	TPCODL	BBSR1	BCDD-2	PERIPHERI	CS PUR-2	14002	11 kV HOUSING BOARD-	14002205	VIM-26	1233DT001	500	MIXED	AMI	Yes	0%	219	0.27287184	0.221345	0.05152684	18.88%
1043	TPCODL	BBSR1	BCDD-2	PERIPHERI	CS PUR-2	14002	11 kV HOUSING BOARD-	14002205	VIM-666-2	1233DT011	500	MIXED	AMI	Yes	0%	156	0.16057104	0.149894	0.01067704	6.65%
1044	TPCODL	BBSR1	BCDD-2	PERIPHERI	(KRUSHNADASPUR)	14249	11 kV Vigilance Colony	14249201	PLOT NO-GA/23,SAILASHREE VIHAR	1233DT192	100	MIXED	AMI	Yes	100%	7	0.00658784	0.006525	6.284E-05	0.95%
1045	TPCODL	BBSR1	BCDD-2	PERIPHERI	(KRUSHNADASPUR)	14249	11 kV Vigilance Colony	14249201	NEAR OERC 4 POLE	1233DT194	250	MIXED	AMI	Yes	100%	43	0.09928944	0.06835	0.03093944	31.16%
1046	TPCODL	BBSR1	BCDD-2	PERIPHERI	CS PUR-2	14002	11 kV CSPUR BDA -2	14002203	S-2 LANE, BIKASH SAMANTARAY	1233DT275	250	MIXED	AMI	Yes	0%	95	0.20423488	0.138274	0.06596088	32.30%
1047	TPCODL	BBSR1	BCDD-2	PERIPHERI	CS PUR-2	14002	11 kV CSPUR BDA -2	14002203	JAGANNATH PARK ENCLAVE GA-32	1233DT284	200	MIXED	AMI	Yes	0%	18	0.02813932	0.01815	0.00998932	35.50%
1048	TPCODL	BBSR1	BCDD-2	PERIPHERI	CS PUR-2	14002	11 kV TULASI VIHAR	14002208	MA SANTOSHI MANDIR	1233DT504	250	MIXED	AMI	Yes	100%	219	0.24685532	0.185649	0.06120632	24.79%
1049	TPCODL	BBSR1	BCDD-2	PERIPHERI	INFOCITY	14003	11 kV INFOCITY	14003201	SUBHAS NAGAR	1233DT557	100	MIXED	AMI	Yes	0%	11	0.0202229	0.00861	0.0116129	57.42%
1050	TPCODL	BBSR1	BCDD-2	PERIPHERI	INFOCITY	14003	11 kV BANK	14003202	NEAR BY INFOCITY MAINGATE	1233DT567	500	MIXED	AMI	Yes	100%	7	0.03607976	0.02677	0.00930976	25.80%
1051	TPCODL	BBSR1	BCDD-2	PERIPHERI	INFOCITY	14003	11 kV O-TV	14003209	NEAR BY MEAT BAZAR	1233DT619	100	MIXED	AMI	Yes	100%	67	0.06919804	0.029933	0.03926504	56.74%
1052	TPCODL	BBSR1	BCDD-2	PERIPHERI	KANAN BIHAR	14217	11 kV KIIT UG(KIIT)	14217210	HOTEL GALAXY	1233DT757	250	MIXED	AMI	Yes	0%	116	0.23330636	0.213525	0.01978136	8.48%
1053	TPCODL	BBSR1	BCDD-2	PERIPHERI	KANAN BIHAR	14217	11 kV KIIT UG(KIIT)	14217210	NEAR GALAXY	1233DT760	500	MIXED	AMI	Yes	0%	31	0.25610504	0.053829	0.20227604	78.98%
1054	TPCODL	BBSR1	BCDD-2	PERIPHERI	(MAHULA MAJANA)	14300	11 kV CENTRAL SCHOOL	14300203	MANGALA BASTI	1233DT805	100	MIXED	AMI	Yes	0%	143	0.14450064	0.077859	0.06664164	46.12%
1055	TPCODL	BBSR1	BCDD-2	PERIPHERI	TRISHULIA	14367	11 kV MUNDAMUHAN	14367203	FAKIRAPARA 6	1234DT163	100	MIXED	AMI	Yes	0%	41	0.03113588	0.022002	0.00913388	29.34%
1056	TPCODL	BBSR1	BCDD-2	PERIPHERI	TRISHULIA	14367	11 kV NARANPUR	14367201	JAYPUR VILLAGE	1234DT265	100	MIXED	AMI	Yes	0%	92	0.05809586	0.045636	0.01245986	21.45%
1057	TPCODL	BBSR1	BCDD-2	PERIPHERI	TRISHULIA	14367	11 kV MADHUPUR	14367204	BRAHMANA SAHI (MEDICAL)	1234DT283	100	MIXED	AMI	Yes	0%	130	0.08472118	0.052103	0.03261818	38.50%
1058	TPCODL	BBSR1	BCDD-2	PERIPHERI	TRISHULIA	14367	11 kV MADHUPUR	14367204	BELGACCHIA PANI SAHI	1234DT324	100	MIXED	AMI	Yes	0%	87	0.08496946	0.054393	0.03057646	35.99%
1059	TPCODL	BBSR1	BCDD-2	PERIPHERI	NEW BARANGA	14216	33 kV GODISAHI	14216401	MUNDALI HP GASH VITARAK	1234DT369	250	MIXED	AMI	Yes	100%	269	0.22237488	0.123986	0.09838888	44.24%
1060	TPCODL	BBSR1	BCDD-2	PERIPHERI	NEW BARANGA	14216	33 kV GODISAHI	14216401	NEAR MUNDOLI BIRZE	1234DT371	250	MIXED	AMI	Yes	100%	115	0.10131688	0.046746	0.05457088	53.86%
1061	TPCODL	BBSR1	BCDD-2	PERIPHERI	NEW BARANGA	14216	33 kV GODISAHI	14216401	NEAR NARAJ HILL TOP IB	1234DT395	100	MIXED	AMI	Yes	0%	119	0.1208405	0.050632	0.0702085	58.10%
1062	TPCODL	BBSR1	BCDD-2	PERIPHERI	TRISHULIA	14367	11 kV NARANPUR	14367201	LIG PROJECT-I	1234DT464	500	MIXED	AMI	Yes	0%	64	0.03222536	0.013727	0.01849836	57.40%
1063	TPCODL	BBSR1	BCDD-2	PERIPHERI	TRISHULIA	14367	11 kV NARANPUR	14367201	EWS HOUSING PROJECT-I	1234DT466	500	MIXED	AMI	Yes	0%	80	0.03594584	0.032327	0.00361884	10.07%
1064	TPCODL	BBSR1	BCDD-2	PERIPHERI	TRISHULIA	14367	11 kV NARANPUR	14367201	EWS HOUSING PROJECT-II	1234DT467	500	MIXED	AMI	Yes	0%	176	0.06581792	0.02699	0.03882792	58.99%
1065	TPCODL	BBSR1	BCDD-2	PERIPHERI	KANAN BIHAR	14217	11 kV KALARAHANGA	14217202	SAI SHUBAM	1235DT079	100	MIXED	AMI	Yes	0%	17	0.02101362	0.017765	0.00324862	15.46%
1066	TPCODL	BBSR1	BCDD-2	PERIPHERI	KANAN BIHAR	14217	11 kV KALARAHANGA	14217202	ARCHIF HOME COLONY	1235DT191	250	MIXED	AMI	Yes	0%	32	0.06352788	0.034189	0.02933888	46.18%
1067	TPCODL	BBSR1	BCDD-2	PERIPHERI	KANAN BIHAR	14217	11 kV KALARAHANGA	14217202	PATIA VILLAGE NEAR NEELAKANTHA	1235DT192	100	MIXED	AMI	Yes	100%	22	0.08428278	0.020545	0.06373778	75.62%
1068	TPCODL	BBSR1	BCDD-2	PERIPHERI	KANAN BIHAR	14217	11 kV KIIT OH(Royalty Sq	14217201	NEAR PRASANT PLAZA	1235DT218	250	MIXED	AMI	Yes	0%	93	0.20193592	0.13279	0.06914592	34.24%
1069	TPCODL	BBSR1	BCDD-2	PERIPHERI	KANAN BIHAR	14217	11 kV ROYALTY SQUARE	14217201	TRISHNA PHASE-5	1235DT244	250	MIXED	AMI	Yes	100%	18	0.24329614	0.049742	0.19355414	79.55%
1070	TPCODL	BBSR1	BCDD-2	PERIPHERI	KANAN BIHAR	14217	11 kV KIIT UG(KIIT)	14217210	ZENSIS VILLA PRIYAJIT CASTLE	1235DT264	100	MIXED	AMI	Yes	0%	15	0.07021006	0.036374	0.03383606	48.19%
1071	TPCODL	BBSR1	BCDD-2	PERIPHERI	KANAN BIHAR	14217	11 kV KIIT UG(KIIT)	14217210	MARUYI VILLA PH-1	1235DT274	500	MIXED	AMI	Yes	100%	139	0.29436504	0.246801	0.04756404	16.16%
1072	TPCODL	BBSR1	BCDD-2	PERIPHERI	KALARAHANGA	14223	11 kV NANDDANVIHAR	14223202	LIZA SAHOO	1235DT349	100	MIXED	AMI	Yes	0%	18	0.0196625	0.017414	0.0022485	11.44%
1073	TPCODL	BBSR1	BCDD-2	PERIPHERI	MANI TRIBHUVAN	14377	11 kV MANI TRIBHUVAN	14377202	33/11 KV MANI TRIBHUVAN SS ST	1235DT594	100	MIXED	AMI	Yes	0%	159	0.37231588	0.235399	0.13691688	36.77%
1074	TPCODL	BBSR1	BCDD-2	PERIPHERI	CS PUR-2	14002	11 KV Tulasi Vihar	14002208	SHUVAM PLACE	1233DT461	250	MIXED	AMI	Yes	100%	37	0.04132512	0.029267	0.01205812	29.18%
1075	TPCODL	BBSR1	BCDD-2	PERIPHERI	CS PUR-2	14002	11 KV Tulasi Vihar	14002208	CENTER POINT	1233DT466	500	MIXED	AMI	Yes	100%	63	0.10081104	0.091204	0.00960704	9.53%
1076	TPCODL	BBSR1	BCDD-2	PERIPHERI	CS PUR-2	14002	11 KV Tulasi Vihar	14002208	IDEL PLAZA - 1	1233DT470	500	MIXED	AMI	Yes	100%	39	0.07215176	0.046942	0.02520976	34.94%
1077	TPCODL	BBSR1	BCDD-2	PERIPHERI	CS PUR-2	14002	11 KV Tulasi Vihar	14002208	LOWER FORE POLE(GARIMA HALL)-1	1233DT472	500	MIXED	AMI	Yes	100%	138	0.2073836	0.07622	0.1311636	63.25%
1078	TPCODL	BBSR1	BCDD-2	PERIPHERI	CS PUR-2	14002	11 KV Tulasi Vihar	14002208	SRI JAGANATH TOWERS	1233DT474	250	MIXED	AMI	Yes	100%	35	0.04653212	0.045754	0.00077812	1.67%
1079	TPCODL	BBSR1	BCDD-2	PERIPHERI	CS PUR-2	14002	11 KV Tulasi Vihar	14002208	SAI SAROJ APARMENTS	1233DT477	250	MIXED	AMI	Yes	100%	25	0.08723378	0.030692	0.05654178	64.82%
1080	TPCODL	BBSR1	BCDD-2	PERIPHERI	CS PUR-2	14002	11 KV Tulasi Vihar	14002208	SHREE RESIDENCY APPARMENT	1233DT478	250	MIXED	AMI	Yes	100%	16	0.02721044	0.023081	0.00412944	15.18%
1081	TPCODL	BBSR1	BCDD-2	PERIPHERI	CS PUR-2	14002	11 KV Tulasi Vihar	14002208	PRAGATI VIHAR	1233DT494	250	MIXED	AMI	Yes	100%	89	0.21338868	0.150122	0.06326668	29.65%
1082	TPCODL	BBSR1	BCDD-2	PERIPHERI	CS PUR-2	14002	11 KV Tulasi Vihar	14002208	ROYAL ENCLAVE	1233DT495	500	MIXED	AMI	Yes	100%	70	0.08808672	0.063748	0.02433872	27.63%
1083	TPCODL	BBSR1	BCDD-2	PERIPHERI	CS PUR-2	14002	11 KV Tulasi Vihar	14002208	LOGIN ENCLACE	1233DT496	250	MIXED	AMI	Yes	100%	17	0.02103488	0.02039	0.00064488	3.07%
1084	TPCODL	BBSR1	BCDD-2	PERIPHERI	INFOCITY	14003	11 KV O-TV	14003209	PRASANTI BIHAR	1233DT626	100	MIXED	AMI	Yes	100%	36	0.05275782	0.019474	0.03328382	63.09%
1085	TPCODL	BBSR1	BCDD-2	PERIPHERI	KANAN BIHAR	14217	11 KV RAGHUNATHPUR	14217205	SOMNATH NAGAR	1231DT236	250	MIXED	AMI	Yes	100%	142	0.1482799	0.139193	0.0090869	6.13%
1086	TPCODL	BBSR1	BCDD-2	PERIPHERI	KANAN BIHAR	14217	11KV PRASANTI VIHAR	14217208	SHIKHARCHANDI 1	1235DT478	500	MIXED	AMI	Yes	100%	385	0.40573392	0.266233	0.13950092	34.38%
1087	TPCODL	BBSR1	BCDD-2	PERIPHERI	KANAN BIHAR	14217	11KV PRASANTI VIHAR	14217208	Jagannath Joshi & Others	1235DT488	250	MIXED	AMI	Yes	0%	54	0.14733084	0.111161	0.03616984	24.55%
1088	TPCODL	BBSR1	BCDD-2	PERIPHERI	KANAN BIHAR	14217	11KV PRASANTI VIHAR	14217208	PRASHANTI VIHAR 2(RAPDRP)	1235DT515	500	MIXED	AMI	Yes	33%	315	0.24921008	0.243937	0.00527308	2.12%
1089	TPCODL	BBSR1	BCDD-2	PERIPHERI	KANAN BIHAR	14217	11KV PRASANTI VIHAR	14217208	PRASHANTI VIHAR 2(NEAR DURGA M	1235DT529	100	MIXED	AMI	Yes	67%	88	0.09426232	0.041733	0.05252932	55.73%
1090	TPCODL	BBSR1	BCDD-2	PERIPHERI	KANAN BIHAR	14217	11KV PRASANTI VIHAR	14217208	SHIKHARCHANDI (SOUBHAGYA)	1235DT530	100	MIXED	AMI	Yes	100%	72	0.06901246	0.068985	2.746E-05	0.04%
1091	TPCODL	BBSR1	BCDD-2	PERIPHERI	KANAN BIHAR	14217	11KV ROYAL GARDEN	14217209	STAR CLUB APPT	1235DT145	250	MIXED	AMI	Yes	100%	67	0.08028844	0.056394	0.02389444	29.76%
1092	TPCODL	BBSR1	BCDD-2	PERIPHERI	KANAN BIHAR	14217	11KV ROYAL GARDEN	14217209	NEAR MOHABABU ENCLAV	1235DT196	100	MIXED	AMI	Yes	0%	23	0.06854228	0.024868	0.04367428	63.72%
1093	TPCODL	BBSR1	BCDD-2	PERIPHERI	KANAN BIHAR	14217	11KV KIIT	14217210	N CHAND	1235DT252	250	MIXED	AMI	Yes	100%	157	0.2835479	0.274374	0.0091739	3.24%
1094	TPCODL	BBSR1	BCDD-2	PERIPHERI	KANAN BIHAR	14217	11KV KIIT	14217210	BAISNABI PALACE	1235DT255	250	MIXED	AMI	Yes	100%	41	0.05727636	0.056955	0.00032136	0.56%

Sl. No.	Zone Name	Circle name	Division name	Name of the Sub-division	Name of the Sub-station	Substation Code	Name of the 11 kV Feeder	Feeder Code	Name of the Location where DT situated	DT code	DT Capacity (kVA)	Predominant consumer type of DT (Domestic/Industrial/Agriculture/Mixed)	Type of metering AMR/AMI/ Communicable/Conventional metered/Unmetered	Status of Meter-whether Functional (Yes/No)	% of data received automatically (if AMR/AMI)	No. of Connected Consumers	Input Energy (MU) (A)	Billed Energy (MU) (B)	Loss (MU) (A-B)	% DT Loss (A-B)/A
1095	TPCODL	BBSR1	BCDD-2	PERIPHERI	KANAN BIHAR	14217	11KV KIIT	14217210	LAKSHMI VIHAR	1235DT258	63	MIXED	AMI	Yes	100%	22	0.05842624	0.044708	0.01371824	23.48%
1096	TPCODL	BBSR1	BCDD-2	PERIPHERI	KANAN BIHAR	14217	11KV KIIT	14217210	SASWAT HOMES-2	1235DT267	250	MIXED	AMI	Yes	100%	38	0.06502828	0.052749	0.01227928	18.88%
1097	TPCODL	BBSR1	BCDD-2	PERIPHERI	KANAN BIHAR	14217	11KV KIIT	14217210	ADARSH VIHAR	1235DT269	500	MIXED	AMI	Yes	100%	167	0.2691316	0.259518	0.0096136	3.57%
1098	TPCODL	BBSR1	BCDD-2	PERIPHERI	KANAN BIHAR	14217	11KV KIIT	14217210	EASHMI RANJAN DAS	1235DT277	250	MIXED	AMI	Yes	100%	9	0.08834084	0.080807	0.00753384	8.53%
1099	TPCODL	BBSR1	BCDD-2	PERIPHERI	KHANDAGIRI	14222	11 KV JAGAMARA	14222207	JAGAMARA NO-2	1214DT168	500	MIXED	AMI	Yes	100%	163	0.22543812	0.207698	0.01774012	7.87%
1100	TPCODL	BBSR1	BCDD-2	PERIPHERI	(KRUSHNADASPUR)	14249	11 KV Vigilance Colony	14249201	POWER GRID AVE 1	1233DT215	500	MIXED	AMI	Yes	0%	121	0.45881528	0.176159	0.28265628	61.61%
1101	TPCODL	BBSR1	BCDD-2	PERIPHERI	(KRUSHNADASPUR)	14249	11 KV Vigilance Colony	14249201	VIGILANCE STAFF QATARE	1233DT526	250	MIXED	AMI	Yes	100%	25	0.02087784	0.015956	0.00492184	23.57%
1102	TPCODL	BBSR1	BCDD-2	PERIPHERI	(KRUSHNADASPUR)	14249	11 KV Vigilance Colony	14249201	PLOT NO-GA36, APARTMENT	1233DT594	100	MIXED	AMI	Yes	100%	9	0.01190798	0.011855	5.298E-05	0.44%
1103	TPCODL	BBSR1	BCDD-2	PERIPHERI	(KRUSHNADASPUR)	14249	11 KV Aryan	14249203	WESTEND APARTMENT	1233DT014	500	MIXED	AMI	Yes	100%	65	0.12087824	0.096328	0.02455024	20.31%
1104	TPCODL	BBSR1	BCDD-2	PERIPHERI	(KRUSHNADASPUR)	14249	11 KV Aryan	14249203	DIVYASAI APARTMENT	1233DT015	100	MIXED	AMI	Yes	100%	23	0.03545634	0.024914	0.01054234	29.73%
1105	TPCODL	BBSR1	BCDD-2	PERIPHERI	(KRUSHNADASPUR)	14249	11 KV Aryan	14249203	GA-301, KIRAN RESIDENCY	1233DT016	250	MIXED	AMI	Yes	0%	16	0.03137508	0.018805	0.01257008	40.06%
1106	TPCODL	BBSR1	BCDD-2	PERIPHERI	(KRUSHNADASPUR)	14249	11 KV Aryan	14249203	PLOT NO GA-146 SAI SATYAM APART	1233DT027	100	MIXED	AMI	Yes	100%	9	0.0140398	0.012762	0.0012778	9.10%
1107	TPCODL	BBSR1	BCDD-2	PERIPHERI	(KRUSHNADASPUR)	14249	11 KV Aryan	14249203	PLOT NO GA-11 OLIVE ENCLAVE	1233DT030	100	MIXED	AMI	Yes	100%	8	0.01876302	0.015742	0.00302102	16.10%
1108	TPCODL	BBSR1	BCDD-2	PERIPHERI	(KRUSHNADASPUR)	14249	11 KV Aryan	14249203	PLOT NO GA-10	1233DT031	100	MIXED	AMI	Yes	100%	9	0.01398332	0.013835	0.00014832	1.06%
1109	TPCODL	BBSR1	BCDD-2	PERIPHERI	(KRUSHNADASPUR)	14249	11 KV Aryan	14249203	PLOT NO GA-3 VAKTI VIHAR	1233DT034	100	MIXED	AMI	Yes	100%	49	0.05699072	0.054178	0.00281272	4.94%
1110	TPCODL	BBSR1	BCDD-2	PERIPHERI	(KRUSHNADASPUR)	14249	11 KV Aryan	14249203	PLOT NO DEFENCE GA-242,243	1233DT040	100	MIXED	AMI	Yes	100%	18	0.01876376	0.013587	0.00517676	27.59%
1111	TPCODL	BBSR1	BCDD-2	PERIPHERI	(KRUSHNADASPUR)	14249	11 KV Aryan	14249203	REN INFRASTRUCTURE-1	1233DT051	500	MIXED	AMI	Yes	67%	11	0.0400816	0.014244	0.0258376	64.46%
1112	TPCODL	BBSR1	BCDD-2	PERIPHERI	(KRUSHNADASPUR)	14249	11 KV Aryan	14249203	REN INFRASTRUCTURE-2	1233DT052	500	MIXED	AMI	Yes	100%	47	0.085762	0.084941	0.000821	0.96%
1113	TPCODL	BBSR1	BCDD-2	PERIPHERI	(KRUSHNADASPUR)	14249	11 KV Aryan	14249203	RASHMI ANNEX	1233DT055	100	MIXED	AMI	Yes	100%	13	0.01613562	0.009468	0.00666762	41.32%
1114	TPCODL	BBSR1	BCDD-2	PERIPHERI	(MAHULA MAJANA)	14300	11 KV LUMBINI VIHAR	14300202	BUDHA VIHAR-2	1233DT669	500	MIXED	AMI	Yes	100%	266	0.07227576	0.053653	0.01862276	25.77%
1115	TPCODL	BBSR1	BCDD-2	PERIPHERI	(MAHULA MAJANA)	14300	11 KV CENTRAL SCHOOL	14300203	NILADRI VIHAR GA-233 DATTATREYA	1233DT293	100	MIXED	AMI	Yes	100%	11	0.02180158	0.018826	0.00297558	13.65%
1116	TPCODL	BBSR1	BCDD-2	PERIPHERI	(MAHULA MAJANA)	14300	11 KV CENTRAL SCHOOL	14300203	LUMBINI VIHAR HIG-137	1233DT295	100	MIXED	AMI	Yes	100%	10	0.04915054	0.030854	0.01829654	37.23%
1117	TPCODL	BBSR1	BCDD-2	PERIPHERI	(MAHULA MAJANA)	14300	11 KV CENTRAL SCHOOL	14300203	LUMBINI VIHAR HIG-113	1233DT298	100	MIXED	AMI	Yes	100%	11	0.0769661	0.076278	0.0006881	0.89%
1118	TPCODL	BBSR1	BCDD-2	PERIPHERI	BHARATPUR	14006	11 KV BHARATPUR	14006205	HANUMAN PRASAD BASTI, SAMPUR	1211DT241	200	MIXED	AMI	Yes	100%	185	0.09767404	0.076168	0.02150604	22.02%
1119	TPCODL	BBSR1	BCDD-2	PERIPHERI	CHANDAKA ODSSP	14246	11 KV Patharagadia	14246201	MJ WOODS II	1231DT262	500	MIXED	AMI	Yes	100%	49	0.0401736	0.039123	0.0010506	2.62%
1120	TPCODL	BBSR1	BCDD-2	PERIPHERI	CHANDAKA ODSSP	14246	11 KV Patharagadia	14246201	MJ WOODS III	1231DT263	500	MIXED	AMI	Yes	100%	65	0.07783304	0.072844	0.00498904	6.41%
1121	TPCODL	BBSR1	BCDD-2	PERIPHERI	CHANDAKA ODSSP	14246	11 KV Patharagadia	14246201	MJ WOODS V	1231DT265	500	MIXED	AMI	Yes	100%	83	0.07121264	0.069654	0.00155864	2.19%
1122	TPCODL	BBSR1	BCDD-2	PERIPHERI	CHANDAKA ODSSP	14246	11 KV Patharagadia	14246201	LIFESTYLE ORCHID	1231DT351	500	MIXED	AMI	Yes	100%	80	0.07591296	0.060103	0.01580996	20.83%
1123	TPCODL	BBSR1	BCDD-2	PERIPHERI	CHANDAKA ODSSP	14246	11 KV Patharagadia	14246201	LIFESTYLE ORCHID	1231DT352	500	MIXED	AMI	Yes	100%	77	0.07140864	0.058506	0.01290264	18.07%
1124	TPCODL	BBSR1	BCDD-2	PERIPHERI	CHANDAKA ODSSP	14246	11 KV Patharagadia	14246201	GALAXY TOWER PL.HOMES LTD	1231DT354	250	MIXED	AMI	Yes	67%	41	0.0262866	0.024151	0.0021356	8.12%
1125	TPCODL	BBSR1	BCDD-2	PERIPHERI	CHANDAKA ODSSP	14246	11 KV Patharagadia	14246201	SUNDARPUR	1231DT619	100	MIXED	AMI	Yes	33%	69	0.07906909	0.039895	0.03917409	49.54%
1126	TPCODL	BBSR1	BCDD-2	PERIPHERI	CHANDAKA ODSSP	14246	11 KV Patharagadia	14246201	PATHARGADIA	1231DT632	100	MIXED	AMI	Yes	67%	40	0.08452488	0.028147	0.05637788	66.70%
1127	TPCODL	BBSR1	BCDD-2	PERIPHERI	CHANDAKA ODSSP	14246	11 KV Patharagadia	14246201	PATHARGADIA	1231DT633	100	MIXED	AMI	Yes	0%	99	0.09490182	0.082281	0.01262082	13.30%
1128	TPCODL	BBSR1	BCDD-2	PERIPHERI	CHANDAKA ODSSP	14246	11 KV Patharagadia	14246201	PATHARGADIA (DT Additional of KAII	1231DT821	250	MIXED	AMI	Yes	67%	31	0.18313824	0.048487	0.13465124	73.52%
1129	TPCODL	BBSR1	BCDD-2	PERIPHERI	CHANDAKA ODSSP	14246	11 KV Patharagadia	14246201	S.N CONSTRUCTION	1231DT863	500	MIXED	AMI	Yes	67%	24	0.0277746	0.016878	0.0108966	39.23%
1130	TPCODL	BBSR1	BCDD-2	PERIPHERI	CHANDAKA ODSSP	14246	11 KV DASPUR	14246202	NEAR MANDIR	1231DT393	100	MIXED	AMI	Yes	100%	91	0.10022382	0.051662	0.04856182	48.45%
1131	TPCODL	BBSR1	BCDD-2	PERIPHERI	CHANDAKA ODSSP	14246	11 KV DASPUR	14246202	DASPUR CHAK	1231DT405	25	MIXED	AMI	Yes	100%	73	0.03675206	0.032248	0.00450406	12.26%
1132	TPCODL	BBSR1	BCDD-2	PERIPHERI	CHANDAKA ODSSP	14246	11 KV DASPUR	14246202	ANDARUA JAGANATH PRASAD PANCI	1231DT415	250	MIXED	AMI	Yes	100%	115	0.1373122	0.062353	0.0749592	54.59%
1133	TPCODL	BBSR1	BCDD-2	PERIPHERI	CHANDAKA ODSSP	14246	11 KV DASPUR	14246202	JAGANNATH NIWAS	1231DT906	250	MIXED	AMI	Yes	100%	9	0.01394808	0.00936	0.00458808	32.89%
1134	TPCODL	BBSR1	BCDD-2	PERIPHERI	CHANDAKA ODSSP	14246	11 KV Kujimahal	14246203	SIMILI PATTNA BEHERA SIDE	1231DT282	100	MIXED	AMI	Yes	100%	56	0.04031364	0.022424	0.01788964	44.38%
1135	TPCODL	BBSR1	BCDD-2	PERIPHERI	CHANDAKA ODSSP	14246	11 KV Kujimahal	14246203	SAI PRAGATI I	1231DT286	250	MIXED	AMI	Yes	100%	36	0.03717516	0.030382	0.00679316	18.27%
1136	TPCODL	BBSR1	BCDD-2	PERIPHERI	CHANDAKA ODSSP	14246	11 KV Kujimahal	14246203	SAI PRAGATI II	1231DT287	250	MIXED	AMI	Yes	100%	51	0.02903876	0.026353	0.00268576	9.25%
1137	TPCODL	BBSR1	BCDD-2	PERIPHERI	CHANDAKA ODSSP	14246	11 KV Kujimahal	14246203	SIMILI PATTNA II	1231DT295	100	MIXED	AMI	Yes	100%	89	0.09561557	0.048839	0.04677657	48.92%
1138	TPCODL	BBSR1	BCDD-2	PERIPHERI	CHANDAKA ODSSP	14246	11 KV Kujimahal	14246203	NANDAN INDUSTRIES	1231DT695	250	MIXED	AMI	Yes	0%	24	0.07033056	0.016979	0.05335156	75.86%
1139	TPCODL	BBSR1	BCDD-2	PERIPHERI	CHANDAKA ODSSP	14246	11 KV Kujimahal	14246203	SAI HARMONY	1231DT696	250	MIXED	AMI	Yes	67%	30	0.02407044	0.023829	0.00024144	1.00%
1140	TPCODL	BBSR1	BCDD-2	PERIPHERI	CHANDAKA ODSSP	14246	11 KV Kujimahal	14246203	SAI NILAY	1231DT705	250	MIXED	AMI	Yes	100%	38	0.03275224	0.022941	0.00981124	29.96%
1141	TPCODL	BBSR1	BCDD-2	PERIPHERI	CHANDAKA ODSSP	14246	11 KV Kujimahal	14246203	BHOTSANA APARTMENT II	1231DT709	250	MIXED	AMI	Yes	67%	17	0.0171924	0.011335	0.0058574	34.07%
1142	TPCODL	BBSR1	BCDD-2	PERIPHERI	CHANDAKA ODSSP	14246	11 KV Kujimahal	14246203	CHANDAKA BEHERA SAHI	1231DT722	100	MIXED	AMI	Yes	67%	89	0.07688991	0.062812	0.01407791	18.31%
1143	TPCODL	BBSR1	BCDD-2	PERIPHERI	CHANDAKA ODSSP	14246	11 KV Chandaka Industri	14246204	KUJAMAHAL VILLEGE	1231DT305	100	MIXED	AMI	Yes	100%	198	0.14030152	0.091122	0.04917952	35.05%
1144	TPCODL	BBSR1	BCDD-2	PERIPHERI	CHANDAKA ODSSP	14246	11 KV Chandaka Industri	14246204	BPL BHOLA	1231DT338	100	MIXED	AMI	Yes	0%	70	0.0565627	0.034224	0.0223387	39.49%
1145	TPCODL	BBSR1	BCDD-2	PERIPHERI	CS PUR-1	14001	11 KV SRI VIHAR	14001201	RAPDRP NEAR PNB	1232DT002	100	MIXED	AMI	Yes	100%	25	0.04951253	0.039745	0.00976753	19.73%
1146	TPCODL	BBSR1	BCDD-2	PERIPHERI	CS PUR-1	14001	11 KV SRI VIHAR	14001201	RABINDRA PLAZA	1232DT014	100	MIXED	AMI	Yes	100%	16	0.02061996	0.012123	0.00849696	41.21%
1147	TPCODL	BBSR1	BCDD-2	PERIPHERI	CS PUR-1	14001	11 KV SRI VIHAR	14001201	RAPDRP NEAR SION SHRAMIC BASTI	1232DT015	100	MIXED	AMI	Yes	100%	138	0.07046083	0.057905	0.01255583	17.82%
1148	TPCODL	BBSR1	BCDD-2	PERIPHERI	CS PUR-1	14001	11 KV SRI VIHAR	14001201	SAMANTAVIHAR	1232DT017	250	MIXED	AMI	Yes	100%	6	0.05398848	0.02156	0.03242848	60.07%
1149	TPCODL	BBSR1	BCDD-2	PERIPHERI	CS PUR-1	14001	11 KV SRI VIHAR	14001201	INDUSLND BANK	1232DT108	250	MIXED	AMI	Yes	0%	13	0.05669228	0.017998	0.03869428	68.25%
1150	TPCODL	BBSR1	BCDD-2	PERIPHERI	CS PUR-1	14001	11 KV SRI VIHAR	14001201	BOLORAM BASTI	1232DT115	250	MIXED	AMI	Yes	100%	25	0.04710532	0.022733	0.02437232	51.74%
1151	TPCODL	BBSR1	BCDD-2	PERIPHERI	CS PUR-1	14001	11 KV SRI VIHAR	14001201	SUDHIR DUPAR	1232DT116	250	MIXED	AMI	Yes	100%	3	0.05043896	0.048516	0.00192296	3.81%
1152	TPCODL	BBSR1	BCDD-2	PERIPHERI	CS PUR-1	14001	11 KV SRI VIHAR	14001201	CLUB TOWN 1	1232DT118	500	MIXED	AMI	Yes	100%	53	0.09561071	0.075431	0.02017971	21.11%
1153	TPCODL	BBSR1	BCDD-2	PERIPHERI	CS PUR-1	14001	11 KV SRI VIHAR	14001201	CLUB TWON 2	1232DT119	500	MIXED	AMI	Yes	100%	59	0.10679304	0.084286	0.02250704	21.08%
1154	TPCODL	BBSR1	BCDD-2	PERIPHERI	CS PUR-1	14001	11 KV SRI VIHAR	14001201	CLUB TOWN 3	1232DT120	500	MIXED	AMI	Yes	100%	63	0.08728752	0.087079	0.00020852	0.24%
1155	TPCODL	BBSR1	BCDD-2	PERIPHERI	CS PUR-1	14001	11 KV SRI VIHAR	14001201	PRIMIER RESIDENCY	1232DT130	100	MIXED	AMI	Yes	100%	19	0.01639404	0.012502	0.00389204	23.74%
1156	TPCODL	BBSR1	BCDD-2	PERIPHERI	CS PUR-1	14001	11 KV SRI VIHAR	14001201	GDS RESIDENCY	1232DT131	100	MIXED	AMI	Yes	100%	9	0.0845332	0.019334	0.0651992	77.13%
1157	TPCODL	BBSR1	BCDD-2	PERIPHERI	CS PUR-1	14001	11 KV SRI VIHAR	14001201	BHUJUBAL	1232DT132	250	MIXED	AMI	Yes	100%	146	0.21472128	0.206225	0.00849628	3.96%
1158	TPCODL	BBSR1	BCDD-2	PERIPHERI	CS PUR-1	14001	11 KV SRI VIHAR	14001201	LIFE STYLE	1232DT138	500	MIXED	AMI	Yes	100%	36	0.06363152	0.049701	0.01393052	21.89%
1159	TPCODL	BBSR1	BCDD-2	PERIPHERI	CS PUR-1	14001	11 KV SRI VIHAR	14001201	SAI GARDEN 1	1232DT152	500	MIXED	AMI	Yes	100%	61	0.0803244	0.04762	0.0327044	40.72%
1160	TPCODL	BBSR1	BCDD-2	PERIPHERI	CS PUR-1	14001	11 KV SRI VIHAR	14001201	VARSHA VILLAGE	1232DT157	250	MIXED	AMI	Yes	100%	113	0.17272584	0.156748	0.01597784	9.25%
1161	TPCODL	BBSR1	BCDD-2	PERIPHERI	CS PUR-1	14001	11 KV SRI VIHAR	14001201	CHABINDRA KUMAR PRADHAN-2	1232DT303	500	MIXED	AMI	Yes	100%	89	0.0921742	0.075777	0.0163972	17.79%
1162	TPCODL	BBSR1	BCDD-2	PERIPHERI	CS PUR-1	14001	11 KV POKHRAN	14001202	NEAR GONGATRI	1232DT059	16	MIXED	AMI	Yes	100%	43	0.04484216	0.015126	0.02971616	66.27%
1163	TPCODL	BBSR1	BCDD-2	PERIPHERI	CS PUR-1	14001	11 KV POKHRAN	14001202	GONGATRI APRATMAN	1232DT060	250	MIXED	AMI	Yes	100%	58	0.07820812	0.05166	0.02654812	33.95%
1164	TPCODL	BBSR1	BCDD-2	PERIPHERI	CS PUR-1	14001	11 KV POKHRAN	14001202	NANDA DEVI APPARMENT	1232DT062	250	MIXED	AMI	Yes	100%	69	0.1119578	0.088442	0.0235158	21.00%
1165	TPCODL	BBSR1	BCDD-2	PERIPHERI	CS PUR-1	14001	11 KV POKHRAN	14001202	ANUPAM RESIDENCY	1232DT071	100	MIXED	AMI	Yes	100%	10	0.00766929	0.007536	0.00013329	1.74%
1166	TPCODL	BBSR1	BCDD-2	PERIPHERI	CS PUR-1	14001	11 KV POKHRAN	14001202	PHOKHARAN	1232DT072	250	MIXED	AMI	Yes	33%	73	0.14296248	0.125574	0.01738848	12.16%
1167	TPCODL	BBSR1	BCDD-2	PERIPHERI	CS PUR-1	14001	11 KV POKHRAN	14001202	E.EDIVISION NABINA NIBAS 1	1232DT073	250	MIXED	AMI	Yes	100%	108	0.05726712	0.030458	0.02680912	46.81%

Sl. No.	Zone Name	Circle name	Division name	Name of the Sub-division	Name of the Sub-station	Substation Code	Name of the 11 kV Feeder	Feeder Code	Name of the Location where DT situated	DT code	DT Capacity (kVA)	Predominant consumer type of DT (Domestic/Industrial/Agriculture/Mixed)	Type of metering AMR/AMI/ Communicable/Conventional metered/Unmetered	Status of Meter-whether Functional (Yes/No)	% of data received automatically (if AMR/AMI)	No. of Connected Consumers	Input Energy (MU) (A)	Billed Energy (MU) (B)	Loss (MU) (A-B)	% DT Loss (A-B)/A
1168	TPCODL	BBSR1	BCDD-2	PERIPHERI	CS PUR-1	14001	11 KV POKHRAN	14001202	E.EDIVISION NABINA NIBAS 2	1232DT074	250	MIXED	AMI	Yes	100%	102	0.04038836	0.028951	0.01143736	28.32%
1169	TPCODL	BBSR1	BCDD-2	PERIPHERI	CS PUR-1	14001	11 KV POKHRAN	14001202	BINAYAK (SAI SAMARPAN)-1	1232DT080	500	MIXED	AMI	Yes	100%	56	0.07123696	0.049251	0.02198596	30.86%
1170	TPCODL	BBSR1	BCDD-2	PERIPHERI	CS PUR-1	14001	11 KV POKHRAN	14001202	P.S.ARCADE	1232DT085	100	MIXED	AMI	Yes	100%	8	0.01161468	0.009094	0.00252068	21.70%
1171	TPCODL	BBSR1	BCDD-2	PERIPHERI	CS PUR-1	14001	11 KV POKHRAN	14001202	BASERA HARMONY	1232DT094	200	MIXED	AMI	Yes	100%	37	0.04852792	0.033542	0.01498592	30.88%
1172	TPCODL	BBSR1	BCDD-2	PERIPHERI	CS PUR-1	14001	11 KV POKHRAN	14001202	BHRAMARA ENCLAVE	1232DT097	250	MIXED	AMI	Yes	100%	28	0.04853512	0.02518	0.02335512	48.12%
1173	TPCODL	BBSR1	BCDD-2	PERIPHERI	CS PUR-1	14001	11 KV BDA	14001203	NABAD OLD	1232DT177	500	MIXED	AMI	Yes	100%	33	0.05510184	0.02135	0.03375184	61.25%
1174	TPCODL	BBSR1	BCDD-2	PERIPHERI	CS PUR-1	14001	11 KV BDA	14001203	BDA	1232DT179	1000	MIXED	AMI	Yes	0%	401	0.3295938	0.290332	0.0392618	11.91%
1175	TPCODL	BBSR1	BCDD-2	PERIPHERI	CS PUR-1	14001	11 KV BDA	14001203	BDA MARKET	1232DT182	250	MIXED	AMI	Yes	100%	177	0.1436537	0.093695	0.0499587	34.78%
1176	TPCODL	BBSR1	BCDD-2	PERIPHERI	CS PUR-1	14001	11 KV BDA	14001203	LIG BLOCK-2	1232DT184	250	MIXED	AMI	Yes	100%	418	0.15380312	0.13949	0.01431312	9.31%
1177	TPCODL	BBSR1	BCDD-2	PERIPHERI	CS PUR-1	14001	11 KV BDA	14001203	CHHOTI	1232DT187	250	MIXED	AMI	Yes	100%	257	0.10258292	0.085066	0.01751692	17.08%
1178	TPCODL	BBSR1	BCDD-2	PERIPHERI	CS PUR-1	14001	11 KV BDA	14001203	NILAMADHAB AWAS JOGONA-3	1232DT300	500	MIXED	AMI	Yes	100%	131	0.0851036	0.026355	0.0587486	69.03%
1179	TPCODL	BBSR1	BCDD-2	PERIPHERI	CS PUR-1	14001	11 KV CSPUR H B	14001204	NANDI HOTEL	1232DT028	500	MIXED	AMI	Yes	100%	241	0.35246408	0.237911	0.11455308	32.50%
1180	TPCODL	BBSR1	BCDD-2	PERIPHERI	CS PUR-1	14001	11 KV CSPUR H B	14001204	DAMANA HATA	1232DT029	500	MIXED	AMI	Yes	0%	110	0.13379952	0.110899	0.02290052	17.12%
1181	TPCODL	BBSR1	BCDD-2	PERIPHERI	CS PUR-1	14001	11 KV CSPUR H B	14001204	HIG	1232DT032	500	MIXED	AMI	Yes	100%	184	0.19823664	0.181401	0.01683564	8.49%
1182	TPCODL	BBSR1	BCDD-2	PERIPHERI	CS PUR-1	14001	11 KV CSPUR H B	14001204	MIG TWIN	1232DT033	250	MIXED	AMI	Yes	100%	177	0.191577	0.114975	0.076602	39.98%
1183	TPCODL	BBSR1	BCDD-2	PERIPHERI	CS PUR-1	14001	11 KV CSPUR H B	14001204	MIG TWIN	1232DT034	100	MIXED	AMI	Yes	100%	18	0.06103559	0.012604	0.04843159	79.35%
1184	TPCODL	BBSR1	BCDD-2	PERIPHERI	CS PUR-1	14001	11 KV CSPUR H B	14001204	MIG TWIN	1232DT035	250	MIXED	AMI	Yes	100%	115	0.13377064	0.085203	0.04856764	36.31%
1185	TPCODL	BBSR1	BCDD-2	PERIPHERI	CS PUR-1	14001	11 KV CSPUR H B	14001204	PRAGATI	1232DT037	100	MIXED	AMI	Yes	100%	145	0.17768208	0.094551	0.08313108	46.79%
1186	TPCODL	BBSR1	BCDD-2	PERIPHERI	CS PUR-1	14001	11 KV CSPUR H B	14001204	PRAGATI ENCLAVE-1 PHE	1232DT038	250	MIXED	AMI	Yes	100%	53	0.1060348	0.071098	0.0349368	32.95%
1187	TPCODL	BBSR1	BCDD-2	PERIPHERI	CS PUR-1	14001	11 KV CSPUR H B	14001204	PIJULI GACHHA	1232DT040	250	MIXED	AMI	Yes	0%	269	0.28600516	0.170278	0.11572716	40.46%
1188	TPCODL	BBSR1	BCDD-2	PERIPHERI	CS PUR-1	14001	11 KV CSPUR H B	14001204	AKHANDALAMANI	1232DT042	500	MIXED	AMI	Yes	0%	268	0.34070504	0.135502	0.20520304	60.23%
1189	TPCODL	BBSR1	BCDD-2	PERIPHERI	CS PUR-1	14001	11 KV CSPUR H B	14001204	7 ACRE	1232DT048	250	MIXED	AMI	Yes	0%	163	0.2145276	0.200033	0.0144946	6.76%
1190	TPCODL	BBSR1	BCDD-2	PERIPHERI	CS PUR-1	14001	11 KV CSPUR H B	14001204	SAI SMURTI CONSTRUCTION	1232DT050	500	MIXED	AMI	Yes	67%	40	0.10211904	0.063699	0.03842004	37.62%
1191	TPCODL	BBSR1	BCDD-2	PERIPHERI	CS PUR-1	14001	11 KV CSPUR H B	14001204	DAMANA HATA BASTI CAPEX	1232DT051	100	MIXED	AMI	Yes	100%	81	0.06359035	0.055436	0.00815435	12.82%
1192	TPCODL	BBSR1	BCDD-2	PERIPHERI	CS PUR-1	14001	11 KV CSPUR H B	14001204	BIJU PATTNAIK MARKET	1232DT052	250	MIXED	AMI	Yes	100%	9	0.05799016	0.025007	0.03298316	56.88%
1193	TPCODL	BBSR1	BCDD-2	PERIPHERI	CS PUR-1	14001	11 KV CSPUR H B	14001204	BADRI GARDEN	1232DT053	250	MIXED	AMI	Yes	0%	27	0.03194436	0.016955	0.01498936	46.92%
1194	TPCODL	BBSR1	BCDD-2	PERIPHERI	CS PUR-1	14001	11 KV CSPUR H B	14001204	JAGGANANATH APPARMENT	1232DT056	250	MIXED	AMI	Yes	100%	39	0.05962036	0.048022	0.01159836	19.45%
1195	TPCODL	BBSR1	BCDD-2	PERIPHERI	CS PUR-1	14001	11 KV CSPUR H B	14001204	BSJY INFRONT ATMARAM	1232DT105	500	MIXED	AMI	Yes	0%	101	0.17883664	0.096546	0.08229064	46.01%
1196	TPCODL	BBSR1	BCDD-2	PERIPHERI	CS PUR-1	14001	11 KV DIST CENTER	14001206	FANDI	1232DT221	500	MIXED	AMI	Yes	100%	72	0.34705	0.186438	0.160612	46.28%
1197	TPCODL	BBSR1	BCDD-2	PERIPHERI	CS PUR-1	14001	11 KV DIST CENTER	14001206	PRACHI PHD	1232DT223	250	MIXED	AMI	Yes	100%	83	0.23384072	0.191376	0.04246472	18.16%
1198	TPCODL	BBSR1	BCDD-2	PERIPHERI	CS PUR-1	14001	11 KV DIST CENTER	14001206	PARCHI 4(PARK)	1232DT225	250	MIXED	AMI	Yes	100%	107	0.2270276	0.200102	0.0269256	11.86%
1199	TPCODL	BBSR1	BCDD-2	PERIPHERI	CS PUR-1	14001	11 KV DIST CENTER	14001206	PRACHI 1	1232DT234	500	MIXED	AMI	Yes	100%	69	0.1995932	0.116423	0.0831702	41.67%
1200	TPCODL	BBSR1	BCDD-2	PERIPHERI	CS PUR-1	14001	11 KV DIST CENTER	14001206	RAPDRP 100KVA	1232DT240	100	MIXED	AMI	Yes	100%	8	0.0326593	0.020606	0.0120533	36.91%
1201	TPCODL	BBSR1	BCDD-2	PERIPHERI	CS PUR-1	14001	11 KV DIST CENTER	14001206	PHD MUNDIA	1232DT260	500	MIXED	AMI	Yes	0%	77	0.24948912	0.195944	0.05354512	21.46%
1202	TPCODL	BBSR1	BCDD-2	PERIPHERI	CS PUR-1	14001	11 KV DIST CENTER	14001206	KIRAN PLAZA	1232DT265	250	MIXED	AMI	Yes	100%	12	0.08539004	0.025509	0.05988104	70.13%
1203	TPCODL	BBSR1	BCDD-2	PERIPHERI	CS PUR-1	14001	11 KV DIST CENTER	14001206	NEAR BPCL	1232DT267	500	MIXED	AMI	Yes	100%	54	0.14471712	0.123894	0.02082312	14.39%
1204	TPCODL	BBSR1	BCDD-2	PERIPHERI	CS PUR-2	14002	11 KV CSPUR BDA -1	14002201	LIG-BLOCK-NO-1	1233DT108	100	MIXED	AMI	Yes	100%	17	0.04298222	0.013471	0.02951122	68.66%
1205	TPCODL	BBSR1	BCDD-2	PERIPHERI	CS PUR-2	14002	11 KV CSPUR BDA -1	14002201	LIG-BLOCK-NO-11	1233DT110	100	MIXED	AMI	Yes	0%	51	0.05957992	0.028677	0.03090292	51.87%
1206	TPCODL	BBSR1	BCDD-2	PERIPHERI	CS PUR-2	14002	11 KV CSPUR BDA -1	14002201	MAJOR PADMAPANI AVE-1	1233DT145	500	MIXED	AMI	Yes	100%	21	0.0772612	0.019793	0.0574682	74.38%
1207	TPCODL	BBSR1	BCDD-2	PERIPHERI	CS PUR-2	14002	11 KV CSPUR BDA -1	14002201	MAJOR PADMAPANI AVE-2	1233DT146	500	MIXED	AMI	Yes	100%	36	0.04797137	0.030653	0.01731837	36.10%
1208	TPCODL	BBSR1	BCDD-2	PERIPHERI	CS PUR-2	14002	11 KV CSPUR BDA -1	14002201	NEAR ANVI ENT &HEAD NECK HOSPIT	1233DT161	250	MIXED	AMI	Yes	67%	170	0.32270165	0.234913	0.08778865	27.20%
1209	TPCODL	BBSR1	BCDD-2	PERIPHERI	CS PUR-2	14002	11 KV CSPUR BDA -1	14002201	NEAR KUNTALA NIVAS KAILASH VIHA	1233DT169	500	MIXED	AMI	Yes	100%	117	0.22069584	0.21561	0.00508584	2.30%
1210	TPCODL	BBSR1	BCDD-2	PERIPHERI	CS PUR-2	14002	11 KV CSPUR BDA -1	14002201	NILADRI VIHAR 5TH LANE	1233DT209	500	MIXED	AMI	Yes	100%	89	0.14227192	0.141933	0.00033892	0.24%
1211	TPCODL	BBSR1	BCDD-2	PERIPHERI	CS PUR-2	14002	11 KV CSPUR BDA -1	14002201	HAREKRISTO BASTI SOUBHAGYA -1	1233DT226	100	MIXED	AMI	Yes	100%	133	0.0749505	0.056925	0.0180255	24.05%
1212	TPCODL	BBSR1	BCDD-2	PERIPHERI	CS PUR-2	14002	11 KV CSPUR BDA -1	14002201	HAREKRISTO NAGAR(PANDA PARK)SC	1233DT252	100	MIXED	AMI	Yes	100%	101	0.0457015	0.040847	0.0048545	10.62%
1213	TPCODL	BBSR1	BCDD-2	PERIPHERI	CS PUR-2	14002	11 KV CSPUR BDA -1	14002201	P. R. ENCLAV	1233DT263	250	MIXED	AMI	Yes	100%	16	0.03220798	0.030131	0.00207698	6.45%
1214	TPCODL	BBSR1	BCDD-2	PERIPHERI	CS PUR-2	14002	11 KV CSPUR BDA -1	14002201	SADASHIVA REALCON	1233DT904	100	MIXED	AMI	Yes	100%	6	0.01060612	0.010605	1.12E-06	0.01%
1215	TPCODL	BBSR1	BCDD-2	PERIPHERI	CS PUR-2	14002	11 KV HOUSING BOARD-	14002202	SUBRATA PALACE	1233DT401	250	MIXED	AMI	Yes	100%	10	0.02656356	0.009773	0.01679056	63.21%
1216	TPCODL	BBSR1	BCDD-2	PERIPHERI	CS PUR-2	14002	11 KV HOUSING BOARD-	14002202	BISHNU PRIYA COMPLEX,P-40	1233DT419	200	MIXED	AMI	Yes	33%	28	0.0520901	0.043296	0.0087941	16.88%
1217	TPCODL	BBSR1	BCDD-2	PERIPHERI	CS PUR-2	14002	11 KV HOUSING BOARD-	14002202	PLOT NO-CH-152	1233DT442	100	MIXED	AMI	Yes	100%	40	0.08493568	0.069976	0.01495968	17.61%
1218	TPCODL	BBSR1	BCDD-2	PERIPHERI	CS PUR-2	14002	11 KV HOUSING BOARD-	14002202	KONARK AGESTER	1233DT445	250	MIXED	AMI	Yes	100%	23	0.18156064	0.039641	0.14191964	78.17%
1219	TPCODL	BBSR1	BCDD-2	PERIPHERI	CS PUR-2	14002	11 KV HOUSING BOARD-	14002202	KANAK DURGA NAGAR	1233DT447	250	MIXED	AMI	Yes	100%	66	0.15691452	0.127633	0.02928152	18.66%
1220	TPCODL	BBSR1	BCDD-2	PERIPHERI	CS PUR-2	14002	11 KV HOUSING BOARD-	14002202	GV ENCLAVES	1233DT448	250	MIXED	AMI	Yes	100%	31	0.03887616	0.034724	0.00415216	10.68%
1221	TPCODL	BBSR1	BCDD-2	PERIPHERI	CS PUR-2	14002	11 KV HOUSING BOARD-	14002202	SATYABATI ENCLAVE	1233DT453	250	MIXED	AMI	Yes	100%	18	0.02477776	0.017842	0.00693576	27.99%
1222	TPCODL	BBSR1	BCDD-2	PERIPHERI	CS PUR-2	14002	11 KV CSPUR BDA -2	14002203	PUMP HOUSE NILADRI VIHAR SECTOR	1233DT064	500	MIXED	AMI	Yes	100%	314	0.34163344	0.238169	0.10346444	30.29%
1223	TPCODL	BBSR1	BCDD-2	PERIPHERI	CS PUR-2	14002	11 KV CSPUR BDA -2	14002203	NILADRI VIHAR SECTOR 3 PLOT NO S-	1233DT065	500	MIXED	AMI	Yes	100%	292	0.23725224	0.22283	0.01442224	6.08%
1224	TPCODL	BBSR1	BCDD-2	PERIPHERI	CS PUR-2	14002	11 KV CSPUR BDA -2	14002203	NULADRI BIHAR, S2-PLOT NO-119	1233DT267	250	MIXED	AMI	Yes	67%	171	0.23416104	0.182767	0.05139404	21.95%
1225	TPCODL	BBSR1	BCDD-2	PERIPHERI	CS PUR-2	14002	11 KV CSPUR BDA -2	14002203	NULADRI BIHAR, S2-PLOT NO-119-1	1233DT268	250	MIXED	AMI	Yes	100%	194	0.27051096	0.205341	0.06516996	24.09%
1226	TPCODL	BBSR1	BCDD-2	PERIPHERI	CS PUR-2	14002	11 KV CSPUR BDA -2	14002203	SARASWATI SISHU BIDYA GYAN MAN	1233DT269	500	MIXED	AMI	Yes	0%	213	0.33673656	0.22557	0.11116656	33.01%
1227	TPCODL	BBSR1	BCDD-2	PERIPHERI	CS PUR-2	14002	11 KV CSPUR BDA -2	14002203	NILADRI VIHAR PLOT NO-S-1/133-1	1233DT271	100	MIXED	AMI	Yes	100%	67	0.12674295	0.086427	0.04031595	31.81%
1228	TPCODL	BBSR1	BCDD-2	PERIPHERI	CS PUR-2	14002	11 KV CSPUR BDA -2	14002203	S-2, BIKASH SAMANTARAY	1233DT274	250	MIXED	AMI	Yes	0%	147	0.34848544	0.31084	0.03764544	10.80%
1229	TPCODL	BBSR1	BCDD-2	PERIPHERI	CS PUR-2	14002	11 KV CSPUR BDA -2	14002203	NEAR GA-66	1233DT278	500	MIXED	AMI	Yes	33%	159	0.31915576	0.284003	0.03515276	11.01%
1230	TPCODL	BBSR1	BCDD-2	PERIPHERI	CS PUR-2	14002	11 KV CSPUR BDA -2	14002203	SWOSTI ENCLAVE GA-4	1233DT286	100	MIXED	AMI	Yes	0%	12	0.02155268	0.015827	0.00572568	26.57%
1231	TPCODL	BBSR1	BCDD-2	PERIPHERI	CS PUR-2	14002	11 KV CSPUR BDA -2	14002203	LUMBINI ENCLUB	1233DT302	500	MIXED	AMI	Yes	100%	55	0.0888036	0.083198	0.0056056	6.31%
1232	TPCODL	BBSR1	BCDD-2	PERIPHERI	CS PUR-2	14002	11 KV CSPUR BDA -2	14002203	NELADREE MANSION-1	1233DT308	250	MIXED	AMI	Yes	100%	58	0.02194292	0.019827	0.00211592	9.64%
1233	TPCODL	BBSR1	BCDD-2	PERIPHERI	CS PUR-2	14002	11 KV CSPUR BDA -2	14002203	MALATI MANSIO	1233DT309	250	MIXED	AMI	Yes	100%	14	0.0458302	0.04079	0.0050402	11.00%
1234	TPCODL	BBSR1	BCDD-2	PERIPHERI	CS PUR-2	14002	11 KV CSPUR BDA -2	14002203	UTSHAV ENCLAVE NILADRI VIHAR	1233DT310	250	MIXED	AMI	Yes	100%	28	0.0375388	0.037426	0.0001128	0.30%
1235	TPCODL	BBSR1	BCDD-2	PERIPHERI	CS PUR-2	14002	11 KV CSPUR BDA -2	14002203	M/S MAHANAGAR NIRUPAMA HOME	1233DT928	100	MIXED	AMI	Yes	100%	8	0.0129236	0.011171	0.0017526	13.56%
1236	TPCODL	BBSR1	BCDD-2	PERIPHERI	CS PUR-2	14002	11 KV HOUSING BOARD-	14002204	PLOT NO - L. C. - 138/4	1233DT479	250	MIXED	AMI	Yes	0%	257	0.35140564	0.15156	0.19984564	56.87%
1237	TPCODL	BBSR1	BCDD-2	PERIPHERI	CS PUR-2	14002	11 KV HOUSING BOARD-	14002204	MANISHA ENCLAVE	1233DT482	250	MIXED	AMI	Yes	100%	21	0.02567136	0.016382	0.00928936	36.19%
1238	TPCODL	BBSR1	BCDD-2	PERIPHERI	CS PUR-2	14002	11 KV HOUSING BOARD-	14002204	BAIKUNTHA NATH (SASWAT VIHAR)	1233DT484	100	MIXED	AMI	Yes	100%	6	0.0249388	0.024224	0.0007148	2.87%
1239	TPCODL	BBSR1	BCDD-2	PERIPHERI	CS PUR-2	14002	11 KV HOUSING BOARD-	14002204	UPPER FOUR POLE -2	1233DT488	500	MIXED	AMI	Yes	100%	423	0.32799936	0.26834	0.05965936	18.19%
1240	TPCODL	BBSR1	BCDD-2	PERIPHERI	CS PUR-2	14002	11 KV HOUSING BOARD-	14002204	SONALI PLACE-1	1233DT489	250	MIXED	AMI	Yes	100%	35	0.0717895	0.034373	0.0374165	52.12%

Sl. No.	Zone Name	Circle name	Division name	Name of the Sub-division	Name of the Sub-station	Substation Code	Name of the 11 kV Feeder	Feeder Code	Name of the Location where DT situated	DT code	DT Capacity (kVA)	Predominant consumer type of DT (Domestic/Industrial/Agriculture/Mixed)	Type of metering AMR/AMI/ Communicable/Conventional metered/Unmetered	Status of Meter-whether Functional (Yes/No)	% of data received automatically (if AMR/AMI)	No. of Connected Consumers	Input Energy (MU) (A)	Billed Energy (MU) (B)	Loss (MU) (A-B)	% DT Loss (A-B)/A
1241	TPCODL	BBSR1	BCDD-2	PERIPHERI	CS PUR-2	14002	11 KV HOUSING BOARD-	14002204	HIGHLAND RESIDENCY	1233DT507	500	MIXED	AMI	Yes	100%	51	0.09487688	0.076185	0.01869188	19.70%
1242	TPCODL	BBSR1	BCDD-2	PERIPHERI	CS PUR-2	14002	11 KV HOUSING BOARD-	14002204	MILAN PARADISE F-264	1233DT510	200	MIXED	AMI	Yes	100%	86	0.14671688	0.13967	0.00704688	4.80%
1243	TPCODL	BBSR1	BCDD-2	PERIPHERI	CS PUR-2	14002	11 KV HOUSING BOARD-	14002204	SUNRISE COLONY	1233DT513	100	MIXED	AMI	Yes	100%	26	0.04666502	0.028645	0.01802002	38.62%
1244	TPCODL	BBSR1	BCDD-2	PERIPHERI	CS PUR-2	14002	11 KV HOUSING BOARD-	14002205	VIM-183	1233DT002	500	MIXED	AMI	Yes	100%	207	0.24546168	0.204266	0.04119568	16.78%
1245	TPCODL	BBSR1	BCDD-2	PERIPHERI	CS PUR-2	14002	11 KV HOUSING BOARD-	14002205	VIM-94-1	1233DT003	500	MIXED	AMI	Yes	100%	184	0.37754224	0.251881	0.12566124	33.28%
1246	TPCODL	BBSR1	BCDD-2	PERIPHERI	CS PUR-2	14002	11 KV HOUSING BOARD-	14002205	VIM-94-2	1233DT004	250	MIXED	AMI	Yes	100%	94	0.15525304	0.105983	0.04927004	31.74%
1247	TPCODL	BBSR1	BCDD-2	PERIPHERI	CS PUR-2	14002	11 KV HOUSING BOARD-	14002205	VIM-357-2	1233DT006	250	MIXED	AMI	Yes	100%	114	0.16971828	0.121215	0.04850328	28.58%
1248	TPCODL	BBSR1	BCDD-2	PERIPHERI	CS PUR-2	14002	11 KV HOUSING BOARD-	14002205	VIM-666-1	1233DT010	250	MIXED	AMI	Yes	100%	66	0.07402626	0.06426	0.00976626	13.19%
1249	TPCODL	BBSR1	BCDD-2	PERIPHERI	CS PUR-2	14002	11 KV HOUSING BOARD-	14002205	VIM-746-1	1233DT012	250	MIXED	AMI	Yes	100%	159	0.2846201	0.231097	0.0535231	18.81%
1250	TPCODL	BBSR1	BCDD-2	PERIPHERI	CS PUR-2	14002	11 KV CSPUR INDUSTRIA	14002206	SPECIFIC ROYAL PALACE	1233DT527	250	MIXED	AMI	Yes	100%	20	0.02642044	0.025693	0.00072744	2.75%
1251	TPCODL	BBSR1	BCDD-2	PERIPHERI	CS PUR-2	14002	11 KV CSPUR INDUSTRIA	14002206	STAR RESIDENCY	1233DT528	250	MIXED	AMI	Yes	100%	7	0.03464656	0.012932	0.02171456	62.67%
1252	TPCODL	BBSR1	BCDD-2	PERIPHERI	CS PUR-2	14002	11 KV CSPUR INDUSTRIA	14002206	SRI JAGANNATH ROYAL HEIGHT	1233DT529	250	MIXED	AMI	Yes	0%	30	0.04688898	0.03747	0.00941898	20.09%
1253	TPCODL	BBSR1	BCDD-2	PERIPHERI	CS PUR-2	14002	11 KV CSPUR INDUSTRIA	14002206	PLOT NO-346,2725 NEAR ODM-1	1235DT581	500	MIXED	AMI	Yes	100%	110	0.2261894	0.2245	0.0016894	0.75%
1254	TPCODL	BBSR1	BCDD-2	PERIPHERI	CS PUR-2	14002	11 KV CSPUR INDUSTRIA	14002206	NEAR SISHU VIHAR	1235DT586	200	MIXED	AMI	Yes	100%	153	0.19068432	0.165505	0.02517932	13.20%
1255	TPCODL	BBSR1	BCDD-2	PERIPHERI	CS PUR-2	14002	11 KV NAVAL	14002207	JALVAYU TOWER-1	1233DT059	500	MIXED	AMI	Yes	100%	54	0.06714888	0.057403	0.00974588	14.51%
1256	TPCODL	BBSR1	BCDD-2	PERIPHERI	CS PUR-2	14002	11 KV NAVAL	14002207	JALVAYU TOWER-3	1233DT061	500	MIXED	AMI	Yes	100%	98	0.08489968	0.059901	0.02499868	29.44%
1257	TPCODL	BBSR1	BCDD-2	PERIPHERI	DHALABANDHA OD	14276	11 KV BADASAHARA	14276202	ARAKHAPALLI 2	2231DT149	100	MIXED	AMI	Yes	67%	143	0.02953772	0.022653	0.00688472	23.31%
1258	TPCODL	BBSR1	BCDD-2	PERIPHERI	GODISAHI (RAMDAS	14247	11 KV MADHUBAN	14247201	RWSS	1234DT049	63	MIXED	AMI	Yes	100%	66	0.1063078	0.024613	0.0816948	76.85%
1259	TPCODL	BBSR1	BCDD-2	PERIPHERI	GODISAHI (RAMDAS	14247	11 KV MADHUBAN	14247201	RATAGARH PLAYGROUND	1234DT055	250	MIXED	AMI	Yes	100%	186	0.13240374	0.067462	0.06494174	49.05%
1260	TPCODL	BBSR1	BCDD-2	PERIPHERI	GODISAHI (RAMDAS	14247	11 KV MADHUBAN	14247201	RATAGHAR NUASAHI PLAYGROUND	1234DT181	100	MIXED	AMI	Yes	67%	49	0.0774491	0.029238	0.0482111	62.25%
1261	TPCODL	BBSR1	BCDD-2	PERIPHERI	GODISAHI (RAMDAS	14247	11 KV BIDYADHARPUIR	14247203	B-PUR-2	1234DT085	250	MIXED	AMI	Yes	100%	258	0.18708936	0.118879	0.06821036	36.46%
1262	TPCODL	BBSR1	BCDD-2	PERIPHERI	GODISAHI (RAMDAS	14247	11 KV BIDYADHARPUIR	14247203	ORISSA POWEE TRANSMISSION CORF	1234DT086	100	MIXED	AMI	Yes	100%	61	0.04761371	0.03876	0.00885371	18.59%
1263	TPCODL	BBSR1	BCDD-2	PERIPHERI	GODISAHI (RAMDAS	14247	11 KV BIDYADHARPUIR	14247203	PADMALAVANAGAR	1234DT109	100	MIXED	AMI	Yes	100%	55	0.0772133	0.025828	0.0513853	66.55%
1264	TPCODL	BBSR1	BCDD-2	PERIPHERI	GODISAHI (RAMDAS	14247	11 KV BIDYADHARPUIR	14247203	JANAUSADHI KENDRA 2	1234DT128	100	MIXED	AMI	Yes	0%	109	0.13170972	0.072914	0.05879572	44.64%
1265	TPCODL	BBSR1	BCDD-2	PERIPHERI	GODISAHI (RAMDAS	14247	11 KV TALAGARH	14247204	OPPOSITE SRI SIDHESWAR TEMPEL	1234DT041	100	MIXED	AMI	Yes	100%	102	0.06477787	0.046435	0.01834287	28.32%
1266	TPCODL	BBSR1	BCDD-2	PERIPHERI	GODISAHI (RAMDAS	14247	11 KV TALAGARH	14247204	NDRF ROAD LEFT SIDE	1234DT456	100	MIXED	AMI	Yes	100%	17	0.03301636	0.018694	0.01432236	43.38%
1267	TPCODL	BBSR1	BCDD-2	PERIPHERI	INFOCITY	14003	11 KV BANK	14003202	CHIUIUKOLI VILLAGE	1233DT589	100	MIXED	AMI	Yes	67%	126	0.06214064	0.050449	0.01169164	18.81%
1268	TPCODL	BBSR1	BCDD-2	PERIPHERI	INFOCITY	14003	11 KV NEW INDUSTRY-1	14003203	NEAR ASISH ENGINEERING PLOT NO 7	1233DT609	100	MIXED	AMI	Yes	100%	13	0.10162215	0.051816	0.04980615	49.01%
1269	TPCODL	BBSR1	BCDD-2	PERIPHERI	INFOCITY	14003	11 KV NEW INDUSTRY-1	14003203	FALCON RESIDENCY	1233DT656	500	MIXED	AMI	Yes	100%	51	0.12528904	0.075117	0.05017204	40.05%
1270	TPCODL	BBSR1	BCDD-2	PERIPHERI	INFOCITY	14003	11 KV NEW INDUSTRY-1	14003203	NEAR BY-GAYATRI MARBLE	1233DT658	250	MIXED	AMI	Yes	0%	23	0.19886204	0.108025	0.09083704	45.68%
1271	TPCODL	BBSR1	BCDD-2	PERIPHERI	INFOCITY	14003	11 KV POLYMER COMPLE	14003204	NILACHAL VIHAR PATHARAGADIA	1233DT336	100	MIXED	AMI	Yes	0%	6	0.0107455	0.003589	0.0071565	66.60%
1272	TPCODL	BBSR1	BCDD-2	PERIPHERI	INFOCITY	14003	11 KV POLYMER COMPLE	14003204	MICRO WORLD	1233DT726	250	MIXED	AMI	Yes	0%	7	0.099827	0.020254	0.079573	79.71%
1273	TPCODL	BBSR1	BCDD-2	PERIPHERI	INFOCITY	14003	11 KV POLYMER COMPLE	14003204	HEMANTA KUMAR MARTHA	1233DT792	100	MIXED	AMI	Yes	100%	51	0.08431896	0.06433	0.01998896	23.71%
1274	TPCODL	BBSR1	BCDD-2	PERIPHERI	INFOCITY	14003	11 KV POLYMER COMPLE	14003204	SAI PARADISE LANE-2	1233DT800	500	MIXED	AMI	Yes	0%	109	0.3752836	0.170912	0.2043716	54.46%
1275	TPCODL	BBSR1	BCDD-2	PERIPHERI	INFOCITY	14003	11 KV POLYMER COMPLE	14003204	CHITARANJAN VIHAR	1233DT801	250	MIXED	AMI	Yes	100%	34	0.05111428	0.042874	0.00824028	16.12%
1276	TPCODL	BBSR1	BCDD-2	PERIPHERI	INFOCITY	14003	11 KV POLYMER COMPLE	14003204	RACKPOOL HEIGHTS	1233DT821	500	MIXED	AMI	Yes	100%	37	0.08062224	0.053916	0.02670624	33.13%
1277	TPCODL	BBSR1	BCDD-2	PERIPHERI	INFOCITY	14003	11 KV POLYMER COMPLE	14003204	RACKPOOL HEIGHTS	1233DT822	250	MIXED	AMI	Yes	100%	17	0.05297136	0.029549	0.02342236	44.22%
1278	TPCODL	BBSR1	BCDD-2	PERIPHERI	INFOCITY	14003	11 KV POLYMER COMPLE	14003204	P NO 540/178 PALM EVENUE	1233DT859	500	MIXED	AMI	Yes	0%	36	0.07575896	0.039219	0.03653996	48.23%
1279	TPCODL	BBSR1	BCDD-2	PERIPHERI	INFOCITY	14003	11 KV RAJVATIKA	14003205	Near Rajabatika appartment, Patharg	1233DT662	100	MIXED	AMI	Yes	0%	10	0.0376511	0.033728	0.0039231	10.42%
1280	TPCODL	BBSR1	BCDD-2	PERIPHERI	INFOCITY	14003	11 KV RAJVATIKA	14003205	SISHU VIHAH CRICKT GRUUND	1233DT741	100	MIXED	AMI	Yes	0%	18	0.03851684	0.029379	0.00913784	23.72%
1281	TPCODL	BBSR1	BCDD-2	PERIPHERI	INFOCITY	14003	11 KV RAJVATIKA	14003205	SAI BIHAR JAGANATH ROAD PATHAR(	1233DT771	100	MIXED	AMI	Yes	0%	59	0.0593381	0.036749	0.0225891	38.07%
1282	TPCODL	BBSR1	BCDD-2	PERIPHERI	INFOCITY	14003	11 KV RAJVATIKA	14003205	KIIT GHODASALA	1233DT776	100	MIXED	AMI	Yes	0%	19	0.04989148	0.025134	0.02475748	49.62%
1283	TPCODL	BBSR1	BCDD-2	PERIPHERI	INFOCITY	14003	11 KV RAJVATIKA	14003205	AHALYA HILL RESORTS-1	1233DT779	500	MIXED	AMI	Yes	100%	13	0.0662018	0.031332	0.0348698	52.67%
1284	TPCODL	BBSR1	BCDD-2	PERIPHERI	INFOCITY	14003	11 KV NEW PATIA	14003206	AHALYA NAGAR	1235DT432	500	MIXED	AMI	Yes	100%	86	0.34091568	0.119176	0.22173968	65.04%
1285	TPCODL	BBSR1	BCDD-2	PERIPHERI	INFOCITY	14003	11 KV NEW PATIA	14003206	KHUSI REBORN	1235DT435	250	MIXED	AMI	Yes	100%	28	0.04072696	0.037774	0.00295296	7.25%
1286	TPCODL	BBSR1	BCDD-2	PERIPHERI	INFOCITY	14003	11 KV NEW PATIA	14003206	BJ RESIDENCY	1235DT436	250	MIXED	AMI	Yes	100%	18	0.02638384	0.02318	0.00320384	12.14%
1287	TPCODL	BBSR1	BCDD-2	PERIPHERI	INFOCITY	14003	11 KV NEW PATIA	14003206	ARYA BHUMI	1235DT439	250	MIXED	AMI	Yes	100%	39	0.05034276	0.041268	0.00907476	18.03%
1288	TPCODL	BBSR1	BCDD-2	PERIPHERI	INFOCITY	14003	11 KV NEW PATIA	14003206	LAXMI NAGAR	1235DT452	250	MIXED	AMI	Yes	100%	70	0.2069822	0.094233	0.1127492	54.47%
1289	TPCODL	BBSR1	BCDD-2	PERIPHERI	INFOCITY	14003	11 KV NEW PATIA	14003206	HIG-72	1235DT463	500	MIXED	AMI	Yes	67%	189	0.37253248	0.295856	0.07667648	20.58%
1290	TPCODL	BBSR1	BCDD-2	PERIPHERI	INFOCITY	14003	11 KV NEW PATIA	14003206	HIG-164	1235DT466	250	MIXED	AMI	Yes	100%	112	0.18735075	0.187142	0.00020875	0.11%
1291	TPCODL	BBSR1	BCDD-2	PERIPHERI	INFOCITY	14003	11 KV NEW PATIA	14003206	ZEN LIFE STYLE	1235DT617	250	MIXED	AMI	Yes	100%	23	0.0261724	0.022895	0.0032774	12.52%
1292	TPCODL	BBSR1	BCDD-2	PERIPHERI	INFOCITY	14003	11 KV NEW KIIT	14003207	SAPTARSHI	1235DT297	500	MIXED	AMI	Yes	100%	56	0.097816	0.090181	0.007635	7.81%
1293	TPCODL	BBSR1	BCDD-2	PERIPHERI	INFOCITY	14003	11 KV NEW KIIT	14003207	BASERA IMPRESSION	1235DT302	250	MIXED	AMI	Yes	100%	30	0.05242244	0.048653	0.00376944	7.19%
1294	TPCODL	BBSR1	BCDD-2	PERIPHERI	INFOCITY	14003	11 KV NEW KIIT	14003207	BASUDEV PLAZA 2	1235DT308	500	MIXED	AMI	Yes	100%	49	0.095576	0.087261	0.008315	8.70%
1295	TPCODL	BBSR1	BCDD-2	PERIPHERI	INFOCITY	14003	11 KV NEW KIIT	14003207	KALVIK SIPRA MAMORIAL	1235DT311	250	MIXED	AMI	Yes	100%	18	0.0370508	0.022517	0.0145338	39.23%
1296	TPCODL	BBSR1	BCDD-2	PERIPHERI	INFOCITY	14003	11 KV NEW KIIT	14003207	GOBINDA RESIDENCY	1235DT320	500	MIXED	AMI	Yes	100%	37	0.06478264	0.062989	0.00179364	2.77%
1297	TPCODL	BBSR1	BCDD-2	PERIPHERI	INFOCITY	14003	11 KV NEW KIIT	14003207	BAJRANGI VIHAR 1	1235DT324	500	MIXED	AMI	Yes	0%	243	0.48605152	0.363834	0.12221752	25.14%
1298	TPCODL	BBSR1	BCDD-2	PERIPHERI	INFOCITY	14003	11 KV NEW KIIT	14003207	BINAYAK	1235DT327	250	MIXED	AMI	Yes	100%	76	0.1338925	0.105329	0.0285635	21.33%
1299	TPCODL	BBSR1	BCDD-2	PERIPHERI	INFOCITY	14003	11 KV NEW SRI VIHAR	14003208	LOKANATH 1	1232DT159	250	MIXED	AMI	Yes	100%	43	0.1531808	0.04889	0.1042908	68.08%
1300	TPCODL	BBSR1	BCDD-2	PERIPHERI	INFOCITY	14003	11 KV NEW SRI VIHAR	14003208	LOKANATH 2	1232DT160	500	MIXED	AMI	Yes	67%	142	0.25073868	0.239431	0.01130768	4.51%
1301	TPCODL	BBSR1	BCDD-2	PERIPHERI	INFOCITY	14003	11 KV NEW SRI VIHAR	14003208	D HABITET 1	1232DT168	500	MIXED	AMI	Yes	100%	59	0.0867716	0.064502	0.0222696	25.66%
1302	TPCODL	BBSR1	BCDD-2	PERIPHERI	INFOCITY	14003	11 KV NEW SRI VIHAR	14003208	VARSHA VILLA	1232DT204	250	MIXED	AMI	Yes	100%	49	0.0814369	0.054518	0.0269189	33.05%
1303	TPCODL	BBSR1	BCDD-2	PERIPHERI	JATANI	14033	11 KV JATANI MEDICAL	14033206	KRUPASINDHU VIHAR	2144DT211	100	MIXED	AMI	Yes	100%	97	0.10129068	0.07672	0.02457068	24.26%
1304	TPCODL	BBSR1	BCDD-2	PERIPHERI	KALARAHANGA	14223	11 KV SIKHAR CHANDI	14223201	JAI GURU ORCHID	1235DT047	500	MIXED	AMI	Yes	100%	51	0.06575296	0.047599	0.01815396	27.61%
1305	TPCODL	BBSR1	BCDD-2	PERIPHERI	KALARAHANGA	14223	11 KV SIKHAR CHANDI	14223201	KLYANI NAGAR	1235DT204	100	MIXED	AMI	Yes	100%	16	0.04321824	0.023263	0.01995524	46.17%
1306	TPCODL	BBSR1	BCDD-2	PERIPHERI	KALARAHANGA	14223	11 KV SIKHAR CHANDI	14223201	SAIROSE APARTMENT	1235DT210	500	MIXED	AMI	Yes	100%	46	0.06995864	0.06535	0.00460864	6.59%
1307	TPCODL	BBSR1	BCDD-2	PERIPHERI	KALARAHANGA	14223	11 KV SIKHAR CHANDI	14223201	SAIROSE APARTMENT 2	1235DT342	250	MIXED	AMI	Yes	100%	23	0.04274356	0.038229	0.00451456	10.56%
1308	TPCODL	BBSR1	BCDD-2	PERIPHERI	KALARAHANGA	14223	11 KV SIKHAR CHANDI	14223201	SKYTECH INFINITY	1235DT343	500	MIXED	AMI	Yes	100%	52	0.17652008	0.110146	0.06637408	37.60%
1309	TPCODL	BBSR1	BCDD-2	PERIPHERI	KALARAHANGA	14223	11 KV SIKHAR CHANDI	14223201	SHIKHARCHANDI 1 NEAR SHIVA MAN	1235DT474	500	MIXED	AMI	Yes	100%	460	0.47728872	0.344656	0.13263272	27.79%
1310	TPCODL	BBSR1	BCDD-2	PERIPHERI	KALARAHANGA	14223	11 KV SIKHAR CHANDI	14223201	OM ENCLAVE	1235DT496	250	MIXED	AMI	Yes	100%	26	0.03919404	0.025518	0.01367604	34.89%
1311	TPCODL	BBSR1	BCDD-2	PERIPHERI	KALARAHANGA	14223	11 KV SIKHAR CHANDI	14223201	MANORAMA GREEN VIEW	1235DT497	250	MIXED	AMI	Yes	100%	34	0.06346448	0.053638	0.00982648	15.48%
1312	TPCODL	BBSR1	BCDD-2	PERIPHERI	KALARAHANGA	14223	11 KV SIKHAR CHANDI	14223201	AV RESIDENCY	1235DT498	250	MIXED	AMI	Yes	100%	76	0.10948	0.089371	0.020109	18.37%
1313	TPCODL	BBSR1	BCDD-2	PERIPHERI	KALARAHANGA	14223	11 KV SIKHAR CHANDI	14223201	JALLISAHI(RAPDRP)	1235DT502	100	MIXED	AMI	Yes	100%	99	0.09648109	0.072597	0.02388409	24.76%

Sl. No.	Zone Name	Circle name	Division name	Name of the Sub-division	Name of the Sub-station	Substation Code	Name of the 11 kV Feeder	Feeder Code	Name of the Location where DT situated	DT code	DT Capacity (kVA)	Predominant consumer type of DT (Domestic/Industrial/Agriculture/Mixed)	Type of metering AMR/AMI/ Communicable/Conventional metered/Unmetered	Status of Meter-whether Functional (Yes/No)	% of data received automatically (if AMR/AMI)	No. of Connected Consumers	Input Energy (MU) (A)	Billed Energy (MU) (B)	Loss (MU) (A-B)	% DT Loss (A-B)/A
1314	TPCODL	BBSR1	BCDD-2	PERIPHERI	KALARAHANGA	14223	11 KV SIKHAR CHANDI	14223201	STARCITY (SOUBHAGYA)	1235DT505	250	MIXED	AMI	Yes	100%	94	0.178228	0.151621	0.026607	14.93%
1315	TPCODL	BBSR1	BCDD-2	PERIPHERI	KALARAHANGA	14223	11 KV SIKHAR CHANDI	14223201	ANJALI ENCLAVE	1235DT510	250	MIXED	AMI	Yes	100%	18	0.0181358	0.01413	0.0040058	22.09%
1316	TPCODL	BBSR1	BCDD-2	PERIPHERI	KALARAHANGA	14223	11 KV SIKHAR CHANDI	14223201	PREMLATA APARTMENT	1235DT512	500	MIXED	AMI	Yes	0%	56	0.1210624	0.068803	0.0522594	43.17%
1317	TPCODL	BBSR1	BCDD-2	PERIPHERI	KALARAHANGA	14223	11 KV SIKHAR CHANDI	14223201	MANDAKINI 2	1235DT517	500	MIXED	AMI	Yes	100%	43	0.05730048	0.051144	0.00615648	10.74%
1318	TPCODL	BBSR1	BCDD-2	PERIPHERI	KALARAHANGA	14223	11 KV SIKHAR CHANDI	14223201	SUVAM 2	1235DT520	500	MIXED	AMI	Yes	100%	55	0.07993088	0.066363	0.01356788	16.97%
1319	TPCODL	BBSR1	BCDD-2	PERIPHERI	KALARAHANGA	14223	11 KV SIKHAR CHANDI	14223201	SAPPHIRE RESIDENCY	1235DT527	250	MIXED	AMI	Yes	100%	27	0.03709088	0.028534	0.00855688	23.07%
1320	TPCODL	BBSR1	BCDD-2	PERIPHERI	KALARAHANGA	14223	11 KV SIKHAR CHANDI	14223201	BINAYAK VILLA	1235DT601	250	MIXED	AMI	Yes	100%	16	0.05161412	0.021176	0.03043812	58.97%
1321	TPCODL	BBSR1	BCDD-2	PERIPHERI	KALARAHANGA	14223	11 KV NANDDANVIHAR	14223202	AROHAN TOWER	1235DT050	250	MIXED	AMI	Yes	0%	19	0.02719308	0.01868	0.00851308	31.31%
1322	TPCODL	BBSR1	BCDD-2	PERIPHERI	KALARAHANGA	14223	11 KV NANDDANVIHAR	14223202	JAGANATHA COMPLEX	1235DT347	500	MIXED	AMI	Yes	0%	50	0.07812584	0.03905	0.03907584	50.02%
1323	TPCODL	BBSR1	BCDD-2	PERIPHERI	KALARAHANGA	14223	11 KV NANDDANVIHAR	14223202	JAGANATHA C	1235DT348	250	MIXED	AMI	Yes	100%	25	0.04907158	0.026106	0.02296558	46.80%
1324	TPCODL	BBSR1	BCDD-2	PERIPHERI	KALARAHANGA	14223	11 KV NANDDANVIHAR	14223202	ARADHANA-2	1235DT352	500	MIXED	AMI	Yes	100%	13	0.0795512	0.019797	0.0597542	75.11%
1325	TPCODL	BBSR1	BCDD-2	PERIPHERI	KALARAHANGA	14223	11 KV NANDDANVIHAR	14223202	ASHIMA RESIDENCY	1235DT356	250	MIXED	AMI	Yes	100%	36	0.04312662	0.031251	0.01187562	27.54%
1326	TPCODL	BBSR1	BCDD-2	PERIPHERI	KALARAHANGA	14223	11 KV NANDDANVIHAR	14223202	SAI JYOTI	1235DT357	100	MIXED	AMI	Yes	100%	18	0.02914461	0.021481	0.00766361	26.30%
1327	TPCODL	BBSR1	BCDD-2	PERIPHERI	KALARAHANGA	14223	11 KV NANDDANVIHAR	14223202	D.N HOMES-1	1235DT360	500	MIXED	AMI	Yes	100%	62	0.12009304	0.115596	0.00449704	3.74%
1328	TPCODL	BBSR1	BCDD-2	PERIPHERI	KALARAHANGA	14223	11 KV NANDDANVIHAR	14223202	D.N HOMES-2	1235DT361	500	MIXED	AMI	Yes	100%	63	0.12065344	0.102274	0.01837944	15.23%
1329	TPCODL	BBSR1	BCDD-2	PERIPHERI	KALARAHANGA	14223	11 KV NANDDANVIHAR	14223202	D.N HOMES-3	1235DT362	500	MIXED	AMI	Yes	100%	60	0.10597784	0.075698	0.03027984	28.57%
1330	TPCODL	BBSR1	BCDD-2	PERIPHERI	KALARAHANGA	14223	11 KV NANDDANVIHAR	14223202	D.N HOMES-4	1235DT363	500	MIXED	AMI	Yes	100%	56	0.09557344	0.079462	0.01611144	16.86%
1331	TPCODL	BBSR1	BCDD-2	PERIPHERI	KALARAHANGA	14223	11 KV NANDDANVIHAR	14223202	ARADHANA (PADMINI ELCLAVE)	1235DT379	250	MIXED	AMI	Yes	0%	32	0.04588928	0.038411	0.00747828	16.30%
1332	TPCODL	BBSR1	BCDD-2	PERIPHERI	KANAN BIHAR	14217	11 KV ROYALTY SQUARE	14217201	BIJU NAGAR-3	1235DT221	100	MIXED	AMI	Yes	100%	22	0.0843837	0.074526	0.0098577	11.68%
1333	TPCODL	BBSR1	BCDD-2	PERIPHERI	KANAN BIHAR	14217	11 KV ROYALTY SQUARE	14217201	MAHABINAYAK PURAM	1235DT222	250	MIXED	AMI	Yes	100%	80	0.120975	0.104297	0.016678	13.79%
1334	TPCODL	BBSR1	BCDD-2	PERIPHERI	KANAN BIHAR	14217	11 KV ROYALTY SQUARE	14217201	SUBHAM-2	1235DT232	250	MIXED	AMI	Yes	0%	25	0.04527808	0.035863	0.00941508	20.79%
1335	TPCODL	BBSR1	BCDD-2	PERIPHERI	KANAN BIHAR	14217	11 KV ROYALTY SQUARE	14217201	TRISHNA RESORT	1235DT236	250	MIXED	AMI	Yes	100%	8	0.13370364	0.122689	0.01101464	8.24%
1336	TPCODL	BBSR1	BCDD-2	PERIPHERI	KANAN BIHAR	14217	11 KV ROYALTY SQUARE	14217201	GREEN FIELD RESIDENCY	1235DT242	250	MIXED	AMI	Yes	0%	40	0.06322088	0.06055	0.00267088	4.22%
1337	TPCODL	BBSR1	BCDD-2	PERIPHERI	KANAN BIHAR	14217	11 KV KALARAHANGA	14217202	ETHICS ORCHID(GOPINATH SAHOO)	1235DT065	500	MIXED	AMI	Yes	100%	29	0.13858348	0.035752	0.10283148	74.20%
1338	TPCODL	BBSR1	BCDD-2	PERIPHERI	KANAN BIHAR	14217	11 KV KALARAHANGA	14217202	PRIYADARSHINI ENCLAV	1235DT082	250	MIXED	AMI	Yes	100%	33	0.09456304	0.041854	0.05270904	55.74%
1339	TPCODL	BBSR1	BCDD-2	PERIPHERI	KANAN BIHAR	14217	11 KV KALARAHANGA	14217202	TAPASHRI VILLA	1235DT085	100	MIXED	AMI	Yes	0%	9	0.01420818	0.014071	0.00013718	0.97%
1340	TPCODL	BBSR1	BCDD-2	PERIPHERI	KANAN BIHAR	14217	11 KV KALARAHANGA	14217202	ELEGANCE APPT	1235DT086	500	MIXED	AMI	Yes	100%	18	0.0732276	0.02973	0.0434976	59.40%
1341	TPCODL	BBSR1	BCDD-2	PERIPHERI	KANAN BIHAR	14217	11 KV KALARAHANGA	14217202	DAS MOHAPATRA	1235DT088	250	MIXED	AMI	Yes	100%	13	0.12051492	0.032799	0.08771592	72.78%
1342	TPCODL	BBSR1	BCDD-2	PERIPHERI	KANAN BIHAR	14217	11 KV KALARAHANGA	14217202	REGUDY BASTY	1235DT113	500	MIXED	AMI	Yes	100%	198	0.25459936	0.216054	0.03854536	15.14%
1343	TPCODL	BBSR1	BCDD-2	PERIPHERI	KANAN BIHAR	14217	11 KV KALARAHANGA	14217202	GOLAK PURI	1235DT115	500	MIXED	AMI	Yes	100%	108	0.1495914	0.149537	5.44E-05	0.04%
1344	TPCODL	BBSR1	BCDD-2	PERIPHERI	KANAN BIHAR	14217	11 KV KALARAHANGA	14217202	ETHICS AMRIT	1235DT123	250	MIXED	AMI	Yes	100%	17	0.02932164	0.021803	0.00751864	25.64%
1345	TPCODL	BBSR1	BCDD-2	PERIPHERI	KANAN BIHAR	14217	11 KV KALARAHANGA	14217202	ODITECH GREEN	1235DT127	500	MIXED	AMI	Yes	100%	62	0.10038032	0.050445	0.04993532	49.75%
1346	TPCODL	BBSR1	BCDD-2	PERIPHERI	KANAN BIHAR	14217	11 KV KALARAHANGA	14217202	SUBHALAXMI APPT	1235DT136	500	MIXED	AMI	Yes	100%	46	0.05903624	0.055	0.00403624	6.84%
1347	TPCODL	BBSR1	BCDD-2	PERIPHERI	KANAN BIHAR	14217	11 KV KALARAHANGA	14217202	KHETRAMANI ENCLAV	1235DT157	250	MIXED	AMI	Yes	100%	24	0.03666616	0.030889	0.00577716	15.76%
1348	TPCODL	BBSR1	BCDD-2	PERIPHERI	KANAN BIHAR	14217	11 KV KALARAHANGA	14217202	SUNRISE ANULATA RESIDENCY	1235DT159	500	MIXED	AMI	Yes	100%	48	0.05998	0.057808	0.002172	3.62%
1349	TPCODL	BBSR1	BCDD-2	PERIPHERI	KANAN BIHAR	14217	11 KV KALARAHANGA	14217202	SHIVANI RESIDENCY	1235DT170	250	MIXED	AMI	Yes	100%	17	0.026005	0.024533	0.001472	5.66%
1350	TPCODL	BBSR1	BCDD-2	PERIPHERI	KANAN BIHAR	14217	11 KV KALARAHANGA	14217202	BAMANAL BASERA 1	1235DT172	250	MIXED	AMI	Yes	100%	45	0.07182256	0.041823	0.02999956	41.77%
1351	TPCODL	BBSR1	BCDD-2	PERIPHERI	KANAN BIHAR	14217	11 KV KALARAHANGA	14217202	BAMANAL BASERA 2	1235DT173	500	MIXED	AMI	Yes	100%	56	0.08590624	0.062407	0.02349924	27.35%
1352	TPCODL	BBSR1	BCDD-2	PERIPHERI	KANAN BIHAR	14217	11 KV KALARAHANGA	14217202	AROHAN TOWER-1	1235DT178	250	MIXED	AMI	Yes	33%	18	0.0214708	0.021417	5.38E-05	0.25%
1353	TPCODL	BBSR1	BCDD-2	PERIPHERI	KANAN BIHAR	14217	11 KV KALARAHANGA	14217202	ROYAL GARDEN 1	1235DT184	250	MIXED	AMI	Yes	100%	58	0.07599496	0.062108	0.01388696	18.27%
1354	TPCODL	BBSR1	BCDD-2	PERIPHERI	KANAN BIHAR	14217	11 KV KALARAHANGA	14217202	SANDHA CHAKK	1235DT190	500	MIXED	AMI	Yes	100%	194	0.5126764	0.286832	0.2258444	44.05%
1355	TPCODL	BBSR1	BCDD-2	PERIPHERI	KANAN BIHAR	14217	11 KV KALARAHANGA	14217202	ADITYA ENCLAVE 1	1235DT533	500	MIXED	AMI	Yes	100%	47	0.09772492	0.070974	0.02675092	27.37%
1356	TPCODL	BBSR1	BCDD-2	PERIPHERI	KANAN BIHAR	14217	11 KV KALARAHANGA	14217202	AYUSH RADIUM-1	1235DT534	250	MIXED	AMI	Yes	100%	49	0.0877825	0.068927	0.0188555	21.48%
1357	TPCODL	BBSR1	BCDD-2	PERIPHERI	KANAN BIHAR	14217	11 KV KALARAHANGA	14217202	RICHI RESIDENCY	1235DT538	250	MIXED	AMI	Yes	0%	29	0.05001784	0.049926	9.184E-05	0.18%
1358	TPCODL	BBSR1	BCDD-2	PERIPHERI	KANAN BIHAR	14217	11 KV KALARAHANGA	14217202	SOURYA	1235DT539	500	MIXED	AMI	Yes	0%	33	0.04550016	0.042739	0.00276116	6.07%
1359	TPCODL	BBSR1	BCDD-2	PERIPHERI	KANAN BIHAR	14217	11 KV KALARAHANGA	14217202	CHIRAG	1235DT542	100	MIXED	AMI	Yes	0%	17	0.0245813	0.019651	0.0049303	20.06%
1360	TPCODL	BBSR1	BCDD-2	PERIPHERI	KANAN BIHAR	14217	11 KV KALARAHANGA	14217202	ANGEL GREAT	1235DT543	250	MIXED	AMI	Yes	0%	9	0.03048592	0.009429	0.02105692	69.07%
1361	TPCODL	BBSR1	BCDD-2	PERIPHERI	KANAN BIHAR	14217	11 KV KALARAHANGA	14217202	REGAL DOV	1235DT544	250	MIXED	AMI	Yes	100%	39	0.0668894	0.059203	0.0076864	11.49%
1362	TPCODL	BBSR1	BCDD-2	PERIPHERI	KANAN BIHAR	14217	11 KV KALARAHANGA	14217202	11 KV SONSYRISE APARTMENT SUBST	1235DT609	500	MIXED	AMI	Yes	100%	62	0.06543976	0.049059	0.01638076	25.03%
1363	TPCODL	BBSR1	BCDD-2	PERIPHERI	KANAN BIHAR	14217	11 KV KALARAHANGA	14217202	RASHMI LIFESTYLE-1	1235DT612	500	MIXED	AMI	Yes	100%	73	0.0670692	0.052087	0.0149822	22.34%
1364	TPCODL	BBSR1	BCDD-2	PERIPHERI	KANAN BIHAR	14217	11 KV KALARAHANGA	14217202	RASHMI LIFESTYLE-2	1235DT613	500	MIXED	AMI	Yes	100%	70	0.06988288	0.06115	0.00873288	12.50%
1365	TPCODL	BBSR1	BCDD-2	PERIPHERI	KANAN BIHAR	14217	11 KV KALARAHANGA	14217202	S N CONSTRUCTION & DEVELOPERS	1235DT634	500	MIXED	AMI	Yes	100%	25	0.05364321	0.018796	0.03484721	64.96%
1366	TPCODL	BBSR1	BCDD-2	PERIPHERI	KANAN BIHAR	14217	11 KV PATIA	14217203	ODITECH PRIDE	1235DT388	500	MIXED	AMI	Yes	100%	44	0.07971016	0.077075	0.00263516	3.31%
1367	TPCODL	BBSR1	BCDD-2	PERIPHERI	KANAN BIHAR	14217	11 KV PATIA	14217203	SHREE JAYDEV SIKHYAKHENDRA	1235DT398	500	MIXED	AMI	Yes	0%	175	0.333904	0.289448	0.044456	13.31%
1368	TPCODL	BBSR1	BCDD-2	PERIPHERI	KANAN BIHAR	14217	11 KV PATIA	14217203	EAST VIEW 2	1235DT404	500	MIXED	AMI	Yes	0%	73	0.090236	0.085812	0.004424	4.90%
1369	TPCODL	BBSR1	BCDD-2	PERIPHERI	KANAN BIHAR	14217	11 KV PATIA	14217203	EAST VIEW 3	1235DT405	250	MIXED	AMI	Yes	100%	37	0.09329816	0.046709	0.04658916	49.94%
1370	TPCODL	BBSR1	BCDD-2	PERIPHERI	KANAN BIHAR	14217	11 KV PATIA	14217203	KHADIMS	1235DT413	500	MIXED	AMI	Yes	100%	63	0.22439168	0.189405	0.03498668	15.59%
1371	TPCODL	BBSR1	BCDD-2	PERIPHERI	KANAN BIHAR	14217	11 KV PATIA	14217203	BOI-1	1235DT418	500	MIXED	AMI	Yes	100%	153	0.27652392	0.184451	0.09207292	33.30%
1372	TPCODL	BBSR1	BCDD-2	PERIPHERI	KANAN BIHAR	14217	11 KV PATIA	14217203	KAILASH APPAT	1235DT457	250	MIXED	AMI	Yes	100%	29	0.03768396	0.037505	0.00017896	0.47%
1373	TPCODL	BBSR1	BCDD-2	PERIPHERI	KANAN BIHAR	14217	11 KV PATIA	14217203	ARUNU MAHARANA	1235DT460	250	MIXED	AMI	Yes	100%	19	0.02393432	0.016496	0.00743832	31.08%
1374	TPCODL	BBSR1	BCDD-2	PERIPHERI	KANAN BIHAR	14217	11 KV PKB	14217204	GOURA VIHAR-1	1235DT001	500	MIXED	AMI	Yes	100%	33	0.13881432	0.048847	0.08996732	64.81%
1375	TPCODL	BBSR1	BCDD-2	PERIPHERI	KANAN BIHAR	14217	11 KV PKB	14217204	BASANT KU DASH	1235DT007	100	MIXED	AMI	Yes	0%	11	0.0177062	0.015379	0.0023272	13.14%
1376	TPCODL	BBSR1	BCDD-2	PERIPHERI	KANAN BIHAR	14217	11 KV PKB	14217204	SILVER SPRING APPARTMENT	1235DT009	100	MIXED	AMI	Yes	0%	9	0.0123672	0.012109	0.0002582	2.09%
1377	TPCODL	BBSR1	BCDD-2	PERIPHERI	KANAN BIHAR	14217	11 KV PKB	14217204	AKRUTI ARCADE	1235DT013	250	MIXED	AMI	Yes	100%	27	0.03411164	0.023176	0.01093564	32.06%
1378	TPCODL	BBSR1	BCDD-2	PERIPHERI	KANAN BIHAR	14217	11 KV PKB	14217204	HB-1	1235DT018	250	MIXED	AMI	Yes	0%	116	0.15895632	0.137338	0.02161832	13.60%
1379	TPCODL	BBSR1	BCDD-2	PERIPHERI	KANAN BIHAR	14217	11 KV PKB	14217204	UPENDRA NATH MALLICK	1235DT019	100	MIXED	AMI	Yes	0%	13	0.02736006	0.027084	0.00027606	1.01%
1380	TPCODL	BBSR1	BCDD-2	PERIPHERI	KANAN BIHAR	14217	11 KV PKB	14217204	OMM PLAZA	1235DT025	250	MIXED	AMI	Yes	100%	21	0.02527572	0.02424	0.00103572	4.10%
1381	TPCODL	BBSR1	BCDD-2	PERIPHERI	KANAN BIHAR	14217	11 KV PKB	14217204	JAGANNATH RAJSEKHAR	1235DT026	250	MIXED	AMI	Yes	100%	31	0.03509524	0.034012	0.00108324	3.09%
1382	TPCODL	BBSR1	BCDD-2	PERIPHERI	KANAN BIHAR	14217	11 KV PKB	14217204	DWELL HIGHT APPARTMENT	1235DT027	250	MIXED	AMI	Yes	100%	44	0.05584276	0.036753	0.01908976	34.18%
1383	TPCODL	BBSR1	BCDD-2	PERIPHERI	KANAN BIHAR	14217	11 KV PKB	14217204	MANSOON APARTMENT	1235DT028	250	MIXED	AMI	Yes	100%	45	0.05166788	0.034423	0.01724488	33.38%
1384	TPCODL	BBSR1	BCDD-2	PERIPHERI	KANAN BIHAR	14217	11 KV PKB	14217204	SARALA BIHAR	1235DT029	100	MIXED	AMI	Yes	100%	32	0.06837952	0.056287	0.01209252	17.68%
1385	TPCODL	BBSR1	BCDD-2	PERIPHERI	KANAN BIHAR	14217	11 KV PKB	14217204	DRM	1235DT030	250	MIXED	AMI	Yes	100%	10	0.01496444	0.008535	0.00642944	42.96%
1386	TPCODL	BBSR1	BCDD-2	PERIPHERI	KANAN BIHAR	14217	11 KV PKB	14217204	SWADHIN BEHERA	1235DT031	250	MIXED	AMI	Yes	100%	25	0.04092274	0.036603	0.00431974	10.56%

Sl. No.	Zone Name	Circle name	Division name	Name of the Sub-division	Name of the Sub-station	Substation Code	Name of the 11 kV Feeder	Feeder Code	Name of the Location where DT situated	DT code	DT Capacity (kVA)	Predominant consumer type of DT (Domestic/Industrial/Agriculture/Mixed)	Type of metering AMR/AMI/ Communicable/Conventional metered/Unmetered	Status of Meter- whether Functional (Yes/No)	% of data received automatically (if AMR/AMI)	No. of Connected Consumers	Input Energy (MU) (A)	Billed Energy (MU) (B)	Loss (MU) (A-B)	% DT Loss (A-B)/A
1387	TPCODL	BBSR1	BCDD-2	PERIPHERI	KANAN BIHAR	14217	11 KV PKB	14217204	SUDHA BHABAN	1235DT034	100	MIXED	AMI	Yes	0%	11	0.01376166	0.01033	0.00343166	24.94%
1388	TPCODL	BBSR1	BCDD-2	PERIPHERI	KANAN BIHAR	14217	11 KV PKB	14217204	NAGESWAR -1	1235DT036	500	MIXED	AMI	Yes	100%	62	0.11970216	0.079747	0.03995516	33.38%
1389	TPCODL	BBSR1	BCDD-2	PERIPHERI	KANAN BIHAR	14217	11 KV PKB	14217204	NAGESWAR -2	1235DT037	500	MIXED	AMI	Yes	100%	67	0.08881016	0.087127	0.00168316	1.90%
1390	TPCODL	BBSR1	BCDD-2	PERIPHERI	KANAN BIHAR	14217	11 KV PKB	14217204	NAGESWAR -3	1235DT038	500	MIXED	AMI	Yes	100%	69	0.09576744	0.060559	0.03520844	36.76%
1391	TPCODL	BBSR1	BCDD-2	PERIPHERI	KANAN BIHAR	14217	11 KV PKB	14217204	MANJULATA MANSION	1235DT046	250	MIXED	AMI	Yes	100%	14	0.02104992	0.017818	0.00323192	15.35%
1392	TPCODL	BBSR1	BCDD-2	PERIPHERI	KHANDAGIRI	14222	11 KV KOLATHIA	14222201	PANI TANKI PH-1	1214DT246	500	MIXED	AMI	Yes	100%	173	0.25225028	0.211811	0.04043928	16.03%
1393	TPCODL	BBSR1	BCDD-2	PERIPHERI	KHANDAGIRI	14222	11 KV DHARMAVIHAR	14222202	ARCHITA RECIDENCY	1214DT147	250	MIXED	AMI	Yes	100%	15	0.0211738	0.020298	0.0008758	4.14%
1394	TPCODL	BBSR1	BCDD-2	PERIPHERI	KHANDAGIRI	14222	11 KV GANDMUNDA	14222203	MALLICK COMPLEX NO.-1	1214DT064	500	MIXED	AMI	Yes	100%	231	0.44086024	0.340881	0.09997924	22.68%
1395	TPCODL	BBSR1	BCDD-2	PERIPHERI	NEW BARANGA	14216	11 KV TRISULIA	14216201	MADHUBANA	1231DT089	100	MIXED	AMI	Yes	33%	55	0.10791404	0.065344	0.04257004	39.45%
1396	TPCODL	BBSR1	BCDD-2	PERIPHERI	NEW BARANGA	14216	11 KV TRISULIA	14216201	PHULAPOKHARI VILLAGE-2	1231DT098	100	MIXED	AMI	Yes	0%	218	0.11652824	0.114322	0.00220624	1.89%
1397	TPCODL	BBSR1	BCDD-2	PERIPHERI	NEW BARANGA	14216	11 KV ANDHARUA	14216202	DARUTHENGA VILLAGE 1	1231DT734	100	MIXED	AMI	Yes	0%	97	0.15651303	0.053277	0.10323603	65.96%
1398	TPCODL	BBSR1	BCDD-2	PERIPHERI	NEW BARANGA	14216	11 KV ANDHARUA	14216202	DARUTHENGA VILLAGE 2	1231DT735	100	MIXED	AMI	Yes	0%	152	0.15164168	0.080033	0.07160868	47.22%
1399	TPCODL	BBSR1	BCDD-2	PERIPHERI	NEW BARANGA	14216	11 KV ANDHARUA	14216202	PRADHAN SAHI NO-1	1231DT766	100	MIXED	AMI	Yes	67%	68	0.10376042	0.031135	0.07262542	69.99%
1400	TPCODL	BBSR1	BCDD-2	PERIPHERI	NEW BARANGA	14216	11 KV ANDHARUA	14216202	DARUTHENGA ROAD 7	1231DT770	100	MIXED	AMI	Yes	67%	44	0.12180736	0.026814	0.09499336	77.99%
1401	TPCODL	BBSR1	BCDD-2	PERIPHERI	NEW BARANGA	14216	11 KV SRIRAM BAZAAR	14216203	NEAR OLD BARANG SUBSTATION-SIT/	1231DT006	100	MIXED	AMI	Yes	100%	206	0.12247102	0.088045	0.03442602	28.11%
1402	TPCODL	BBSR1	BCDD-2	PERIPHERI	NEW BARANGA	14216	11 KV SRIRAM BAZAAR	14216203	STATION GADA	1231DT118	100	MIXED	AMI	Yes	67%	68	0.06046846	0.059583	0.00088546	1.46%
1403	TPCODL	BBSR1	BCDD-2	PERIPHERI	NEW BARANGA	14216	11 KV SRIRAM BAZAAR	14216203	N.K. BAZAR	1231DT121	250	MIXED	AMI	Yes	33%	171	0.226981	0.198957	0.028024	12.35%
1404	TPCODL	BBSR1	BCDD-2	PERIPHERI	NEW BARANGA	14216	11 KV SRIRAM BAZAAR	14216203	HAI MAX	1231DT131	100	MIXED	AMI	Yes	100%	29	0.05357972	0.046925	0.00665472	12.42%
1405	TPCODL	BBSR1	BCDD-2	PERIPHERI	NEW BARANGA	14216	11 KV SRIRAM BAZAAR	14216203	RAGHUNATHPUR JULADEI MANDIR	1231DT133	100	MIXED	AMI	Yes	100%	14	0.02442052	0.016464	0.00795652	32.58%
1406	TPCODL	BBSR1	BCDD-2	PERIPHERI	NEW BARANGA	14216	11 KV SRIRAM BAZAAR	14216203	GADA SAHI JATRA PADIA	1231DT136	63	MIXED	AMI	Yes	100%	6	0.02010059	0.007463	0.01263759	62.87%
1407	TPCODL	BBSR1	BCDD-2	PERIPHERI	NEW BARANGA	14216	11 KV SRIRAM BAZAAR	14216203	BSP GREEN GARDEN	1231DT155	100	MIXED	AMI	Yes	0%	6	0.0032385	0.002754	0.0004845	14.96%
1408	TPCODL	BBSR1	BCDD-2	PERIPHERI	NEW BARANGA	14216	11 KV SRIRAM BAZAAR	14216203	PLOT NUMBER-424	1231DT157	250	MIXED	AMI	Yes	100%	194	0.24477668	0.22973	0.01504668	6.15%
1409	TPCODL	BBSR1	BCDD-2	PERIPHERI	NEW BARANGA	14216	11 KV SRIRAM BAZAAR	14216203	RAGHUNATHPUR BHAGOBAT	1231DT182	500	MIXED	AMI	Yes	100%	251	0.39951048	0.191311	0.20819948	52.11%
1410	TPCODL	BBSR1	BCDD-2	PERIPHERI	NEW BARANGA	14216	11 KV SRIRAM BAZAAR	14216203	PANCHAMUKHI	1231DT183	100	MIXED	AMI	Yes	100%	16	0.02685022	0.014852	0.01199822	44.69%
1411	TPCODL	BBSR1	BCDD-2	PERIPHERI	NEW BARANGA	14216	11 KV SRIRAM BAZAAR	14216203	ODISHA BUILDERS	1231DT189	250	MIXED	AMI	Yes	100%	27	0.0392566	0.038756	0.0005006	1.28%
1412	TPCODL	BBSR1	BCDD-2	PERIPHERI	NEW BARANGA	14216	11 KV SRIRAM BAZAAR	14216203	MARUTI RESIDENCY-1	1231DT191	250	MIXED	AMI	Yes	100%	209	0.28884352	0.22894	0.05990352	20.74%
1413	TPCODL	BBSR1	BCDD-2	PERIPHERI	NEW BARANGA	14216	11 KV SRIRAM BAZAAR	14216203	VIVANI HOUSING PROJECT PVT LTD	1231DT193	250	MIXED	AMI	Yes	100%	106	0.16981528	0.128687	0.04112828	24.22%
1414	TPCODL	BBSR1	BCDD-2	PERIPHERI	NEW BARANGA	14216	11 KV SRIRAM BAZAAR	14216203	MARUTI RESIDENCY-3	1231DT194	500	MIXED	AMI	Yes	0%	116	0.17393688	0.151585	0.02235188	12.85%
1415	TPCODL	BBSR1	BCDD-2	PERIPHERI	NEW BARANGA	14216	11 KV SRIRAM BAZAAR	14216203	SUN ENCLAVE	1231DT200	250	MIXED	AMI	Yes	100%	17	0.01536924	0.015243	0.00012624	0.82%
1416	TPCODL	BBSR1	BCDD-2	PERIPHERI	NEW BARANGA	14216	11 KV SRIRAM BAZAAR	14216203	MARUTI RESIDENCY APPARTMENT	1231DT203	250	MIXED	AMI	Yes	100%	35	0.04172388	0.028726	0.01299788	31.15%
1417	TPCODL	BBSR1	BCDD-2	PERIPHERI	NEW BARANGA	14216	11 KV SRIRAM BAZAAR	14216203	RAINI RESIDENCY	1231DT215	500	MIXED	AMI	Yes	100%	32	0.09245792	0.034167	0.05829092	63.05%
1418	TPCODL	BBSR1	BCDD-2	PERIPHERI	NEW BARANGA	14216	11 KV SRIRAM BAZAAR	14216203	NEAR GDS TOWER	1231DT218	100	MIXED	AMI	Yes	67%	28	0.04088528	0.036129	0.00475628	11.63%
1419	TPCODL	BBSR1	BCDD-2	PERIPHERI	NEW BARANGA	14216	11 KV SRIRAM BAZAAR	14216203	BHAGABATI MANSON	1231DT244	250	MIXED	AMI	Yes	100%	23	0.03550564	0.03008	0.00542564	15.28%
1420	TPCODL	BBSR1	BCDD-2	PERIPHERI	NEW BARANGA	14216	11 KV SRIRAM BAZAAR	14216203	SBT1	1231DT245	250	MIXED	AMI	Yes	100%	13	0.03612228	0.027563	0.00855928	23.70%
1421	TPCODL	BBSR1	BCDD-2	PERIPHERI	NEW BARANGA	14216	11 KV SRIRAM BAZAAR	14216203	GDS TOWER 1	1231DT792	500	MIXED	AMI	Yes	100%	39	0.07996416	0.032334	0.04763016	59.56%
1422	TPCODL	BBSR1	BCDD-2	PERIPHERI	NEW BARANGA	14216	11 KV SRIRAM BAZAAR	14216203	GDS TOWER 2	1231DT793	250	MIXED	AMI	Yes	100%	21	0.0479203	0.01483	0.0330903	69.05%
1423	TPCODL	BBSR1	BCDD-2	PERIPHERI	NEW BARANGA	14216	11 KV SRIRAM BAZAAR	14216203	MARUTI VIHAR	1231DT857	250	MIXED	AMI	Yes	0%	107	0.17346902	0.125	0.04846902	27.94%
1424	TPCODL	BBSR1	BCDD-2	PERIPHERI	NEW BARANGA	14216	11 KV SRIRAM BAZAAR	14216203	NEAR HP	1231DT910	100	MIXED	AMI	Yes	33%	7	0.01636934	0.006204	0.01016534	62.10%
1425	TPCODL	BBSR1	BCDD-2	PERIPHERI	NEW BARANGA	14216	11 KV FEEDER-1	14216204	DHADA MARKET-1	1231DT001	500	MIXED	AMI	Yes	0%	364	0.3569048	0.281191	0.0757138	21.21%
1426	TPCODL	BBSR1	BCDD-2	PERIPHERI	NEW BARANGA	14216	11 KV FEEDER-1	14216204	DHADA MARKET-2	1231DT002	100	MIXED	AMI	Yes	0%	69	0.06932358	0.039879	0.02944458	42.47%
1427	TPCODL	BBSR1	BCDD-2	PERIPHERI	NEW BARANGA	14216	11 KV FEEDER-1	14216204	KENDUPATANA VILLAGE NEAR PUMP	1231DT011	100	MIXED	AMI	Yes	0%	119	0.09600632	0.072546	0.02346032	24.44%
1428	TPCODL	BBSR1	BCDD-2	PERIPHERI	NEW BARANGA	14216	11 KV FEEDER-1	14216204	KENDUPATANA-2 ANGANBADI KENDI	1231DT012	100	MIXED	AMI	Yes	0%	84	0.0908252	0.05735	0.0334752	36.86%
1429	TPCODL	BBSR1	BCDD-2	PERIPHERI	NEW BARANGA	14216	11 KV FEEDER-1	14216204	SANABALIPADA-2 NEAR MAA BUDHIS	1231DT014	63	MIXED	AMI	Yes	67%	73	0.08486018	0.048609	0.03625118	42.72%
1430	TPCODL	BBSR1	BCDD-2	PERIPHERI	NEW BARANGA	14216	11 KV FEEDER-1	14216204	BADABALIPADA 4POLE	1231DT015	100	MIXED	AMI	Yes	67%	50	0.04547337	0.021615	0.02385837	52.47%
1431	TPCODL	BBSR1	BCDD-2	PERIPHERI	NEW BARANGA	14216	11 KV FEEDER-1	14216204	DADHA	1231DT020	250	MIXED	AMI	Yes	0%	106	0.15121064	0.081314	0.06989664	46.22%
1432	TPCODL	BBSR1	BCDD-2	PERIPHERI	NEW BARANGA	14216	11 KV FEEDER-1	14216204	KENDUPATNA NEW DUPLEX	1231DT021	250	MIXED	AMI	Yes	67%	17	0.02432064	0.023936	0.00038464	1.58%
1433	TPCODL	BBSR1	BCDD-2	PERIPHERI	NEW BARANGA	14216	11 KV FEEDER-1	14216204	KHAIRAPADA-1	1231DT025	250	MIXED	AMI	Yes	0%	79	0.09927168	0.065357	0.03391468	34.16%
1434	TPCODL	BBSR1	BCDD-2	PERIPHERI	NEW BARANGA	14216	11 KV FEEDER-1	14216204	GANDHARPUR BRAMHAN SAHI	1231DT026	100	MIXED	AMI	Yes	0%	52	0.06961797	0.037353	0.03226497	46.35%
1435	TPCODL	BBSR1	BCDD-2	PERIPHERI	NEW BARANGA	14216	11 KV FEEDER-1	14216204	GANDHARPUR BRAMHAN SAHI 2	1231DT027	100	MIXED	AMI	Yes	67%	57	0.0754119	0.035103	0.0403089	53.45%
1436	TPCODL	BBSR1	BCDD-2	PERIPHERI	NEW BARANGA	14216	11 KV FEEDER-1	14216204	DHADA ITI	1231DT030	63	MIXED	AMI	Yes	67%	45	0.03729334	0.033368	0.00392534	10.53%
1437	TPCODL	BBSR1	BCDD-2	PERIPHERI	NEW BARANGA	14216	11 KV FEEDER-1	14216204	PADA SAHI-2-1	1231DT037	63	MIXED	AMI	Yes	67%	95	0.06384886	0.059683	0.00416586	6.52%
1438	TPCODL	BBSR1	BCDD-2	PERIPHERI	NEW BARANGA	14216	11 KV FEEDER-1	14216204	DREAM VILLA-1	1231DT040	250	MIXED	AMI	Yes	0%	94	0.15102592	0.141714	0.00931192	6.17%
1439	TPCODL	BBSR1	BCDD-2	PERIPHERI	NEW BARANGA	14216	11 KV FEEDER-1	14216204	KANTAPATNA	1231DT044	63	MIXED	AMI	Yes	0%	117	0.12531344	0.049489	0.07582444	60.51%
1440	TPCODL	BBSR1	BCDD-2	PERIPHERI	NEW BARANGA	14216	11 KV FEEDER-1	14216204	AMBABARI	1231DT058	100	MIXED	AMI	Yes	33%	118	0.08012334	0.058632	0.02149134	26.82%
1441	TPCODL	BBSR1	BCDD-2	PERIPHERI	NEW BARANGA	14216	11 KV FEEDER-1	14216204	AMBABAREI SCHOOL	1231DT064	100	MIXED	AMI	Yes	0%	54	0.04118354	0.030083	0.01110054	26.95%
1442	TPCODL	BBSR1	BCDD-2	PERIPHERI	NEW BARANGA	14216	11 KV FEEDER-1	14216204	MARICHIA VILLAGE	1231DT068	250	MIXED	AMI	Yes	33%	170	0.27722272	0.109297	0.16792572	60.57%
1443	TPCODL	BBSR1	BCDD-2	PERIPHERI	NEW BARANGA	14216	11 KV FEEDER-1	14216204	DELTA COLONY	1231DT070	100	MIXED	AMI	Yes	100%	170	0.09183499	0.083214	0.00862099	9.39%
1444	TPCODL	BBSR1	BCDD-2	PERIPHERI	NEW BARANGA	14216	11 KV FEEDER-1	14216204	KANAKA DURGA	1231DT071	100	MIXED	AMI	Yes	100%	127	0.09410014	0.060704	0.03339614	35.49%
1445	TPCODL	BBSR1	BCDD-2	PERIPHERI	NEW KALARAHANG	14251	11 KV PATIA STATION	14251201	SATYABADI RESIDENCY	1231DT451	500	MIXED	AMI	Yes	67%	58	0.07357336	0.066779	0.00679436	9.23%
1446	TPCODL	BBSR1	BCDD-2	PERIPHERI	NEW KALARAHANG	14251	11 KV PATIA STATION	14251201	P.K PUR NO-2	1231DT453	100	MIXED	AMI	Yes	100%	203	0.12540002	0.077335	0.04806502	38.33%
1447	TPCODL	BBSR1	BCDD-2	PERIPHERI	NEW KALARAHANG	14251	11 KV DHAWA	14251202	GURUDIBANIA NO-1	1231DT501	250	MIXED	AMI	Yes	100%	170	0.17819675	0.153078	0.02511875	14.10%
1448	TPCODL	BBSR1	BCDD-2	PERIPHERI	NEW KALARAHANG	14251	11 KV DHAWA	14251202	ARYANILAYA APARTMENT	1231DT504	500	MIXED	AMI	Yes	100%	54	0.07930608	0.041027	0.03827908	48.27%
1449	TPCODL	BBSR1	BCDD-2	PERIPHERI	NEW KALARAHANG	14251	11 KV DHAWA	14251202	MOHANTY GADIA	1231DT511	100	MIXED	AMI	Yes	100%	104	0.09813298	0.08876	0.00937298	9.55%
1450	TPCODL	BBSR1	BCDD-2	PERIPHERI	NEW KALARAHANG	14251	11 KV DHAWA	14251202	MOON LIFE CITY-1	1231DT514	250	MIXED	AMI	Yes	100%	55	0.09008792	0.058962	0.03112592	34.55%
1451	TPCODL	BBSR1	BCDD-2	PERIPHERI	NEW KALARAHANG	14251	11 KV DHAWA	14251202	MOON LIFE CITY-2	1231DT515	100	MIXED	AMI	Yes	100%	77	0.07132482	0.0622	0.00912482	12.79%
1452	TPCODL	BBSR1	BCDD-2	PERIPHERI	NEW KALARAHANG	14251	11 KV DHAWA	14251202	KALAJHARI-3	1231DT527	100	MIXED	AMI	Yes	100%	113	0.0795082	0.069091	0.0104172	13.10%
1453	TPCODL	BBSR1	BCDD-2	PERIPHERI	NEW KALARAHANG	14251	11 KV DHAWA	14251202	GANDARPUR NO-1	1231DT535	250	MIXED	AMI	Yes	100%	105	0.1104218	0.071953	0.0384688	34.84%
1454	TPCODL	BBSR1	BCDD-2	PERIPHERI	NEW KALARAHANG	14251	11 KV DHAWA	14251202	KALYANPUR NO-1(TOTA SAHI)	1231DT547	63	MIXED	AMI	Yes	67%	32	0.08467612	0.021498	0.06317812	74.61%
1455	TPCODL	BBSR1	BCDD-2	PERIPHERI	NEW KALARAHANG	14251	11 KV DHAWA	14251202	TANGIBANTA BELESWAR TEMPLE	1231DT567	100	MIXED	AMI	Yes	100%	109	0.11875426	0.064469	0.05428526	45.71%
1456	TPCODL	BBSR1	BCDD-2	PERIPHERI	NEW KALARAHANG	14251	11 KV TANGI BANTA	14251203	JALESWAR TEMPLE	1231DT495	250	MIXED	AMI	Yes	0%	177	0.17841064	0.136963	0.04144764	23.23%
1457	TPCODL	BBSR1	BCDD-2	PERIPHERI	NEW KALARAHANG	14251	11 KV TANGI BANTA	14251203	JENASAHI NO-2	1231DT497	100	MIXED	AMI	Yes	0%	117	0.09404636	0.065207	0.02883936	30.67%
1458	TPCODL	BBSR1	BCDD-2	PERIPHERI	NEW KALARAHANG	14251	11 KV TANGI BANTA	14251203	JARIPATRA NO-1	1231DT596	250	MIXED	AMI	Yes	67%	93	0.1256571	0.072332	0.0533251	42.44%
1459	TPCODL	BBSR1	BCDD-2	PERIPHERI	NEW KALARAHANG	14251	11 KV Injama	14251204	GURUDIBANIA NO-2	1231DT456	100	MIXED	AMI	Yes	0%	109	0.11103434	0.100438	0.01059634	9.54%

Sl. No.	Zone Name	Circle name	Division name	Name of the Sub-division	Name of the Sub-station	Substation Code	Name of the 11 kV Feeder	Feeder Code	Name of the Location where DT situated	DT code	DT Capacity (kVA)	Predominant consumer type of DT (Domestic/Industrial/Agriculture/Mixed)	Type of metering AMR/AMI/ Communicable/Conventional metered/Unmetered	Status of Meter-whether Functional (Yes/No)	% of data received automatically (if AMR/AMI)	No. of Connected Consumers	Input Energy (MU) (A)	Billed Energy (MU) (B)	Loss (MU) (A-B)	% DT Loss (A-B)/A
1460	TPCODL	BBSR1	BCDD-2	PERIPHERI	NEW KALARAHANG	14251	11 KV Injama	14251204	GAYATRI ENCLAVE	1231DT458	250	MIXED	AMI	Yes	100%	24	0.03112316	0.02863	0.00249316	8.01%
1461	TPCODL	BBSR1	BCDD-2	PERIPHERI	NEW KALARAHANG	14251	11 KV Injama	14251204	LDV DAITARI RESIDENCE	1231DT460	500	MIXED	AMI	Yes	100%	30	0.06137032	0.026946	0.03442432	56.09%
1462	TPCODL	BBSR1	BCDD-2	PERIPHERI	NEW KALARAHANG	14251	11 KV Injama	14251204	P.K PUR NO-3	1231DT468	100	MIXED	AMI	Yes	100%	44	0.03314615	0.019701	0.01344515	40.56%
1463	TPCODL	BBSR1	BCDD-2	PERIPHERI	NEW KALARAHANG	14251	11 KV Injama	14251204	SUBHALAXMI PALACE	1231DT470	250	MIXED	AMI	Yes	100%	28	0.03037866	0.026841	0.00353766	11.65%
1464	TPCODL	BBSR1	BCDD-2	PERIPHERI	NEW KALARAHANG	14251	11 KV Injama	14251204	BISHNU RESIDENCE APPARTMENT	1231DT473	250	MIXED	AMI	Yes	100%	40	0.04627824	0.038166	0.00811224	17.53%
1465	TPCODL	BBSR1	BCDD-2	PERIPHERI	NEW KALARAHANG	14251	11 KV Injama	14251204	PATIA TANGI NO-1	1231DT474	250	MIXED	AMI	Yes	100%	224	0.25965335	0.192745	0.06690835	25.77%
1466	TPCODL	BBSR1	BCDD-2	PERIPHERI	NEW KALARAHANG	14251	11 KV Injama	14251204	PATIA TANGI NO-3	1231DT476	100	MIXED	AMI	Yes	100%	111	0.1185131	0.087887	0.0306261	25.84%
1467	TPCODL	BBSR1	BCDD-2	PERIPHERI	NEW KALARAHANG	14251	11 KV Injama	14251204	SARADHAJALI RESIDENCE	1231DT477	250	MIXED	AMI	Yes	100%	15	0.02431716	0.010615	0.01370216	56.35%
1468	TPCODL	BBSR1	BCDD-2	PERIPHERI	NEW KALARAHANG	14251	11 KV Injama	14251204	P.K PUR (SCHOOL)	1231DT480	25	MIXED	AMI	Yes	100%	27	0.0349914	0.031966	0.0030254	8.65%
1469	TPCODL	BBSR1	BCDD-2	PERIPHERI	NEW KALARAHANG	14251	11 KV Injama	14251204	PATIA TANGI NO-2	1231DT482	100	MIXED	AMI	Yes	100%	74	0.08521264	0.067872	0.01734064	20.35%
1470	TPCODL	BBSR1	BCDD-2	PERIPHERI	NEW KALARAHANG	14251	11 KV Injama	14251204	INJANA NO.3	1231DT493	250	MIXED	AMI	Yes	100%	135	0.23631232	0.127479	0.10883332	46.05%
1471	TPCODL	BBSR1	BCDD-2	PERIPHERI	NEW KALARAHANG	14251	11 KV Injama	14251204	SKE/BTS(SRP-2)	1235DT606	250	MIXED	AMI	Yes	0%	24	0.01981088	0.017281	0.00252988	12.77%
1472	TPCODL	BBSR1	BCDD-2	PERIPHERI	SAINIK SCHOOL	14010	11 KV PRESS	14010203	C.S PUR I	1224DT115	100	MIXED	AMI	Yes	0%	51	0.13781883	0.079035	0.05878383	42.65%
1473	TPCODL	BBSR1	BCDD-2	PERIPHERI	TRISHULIA	14367	11 KV NARANPUR	14367201	GOTHPUR VILLAGE	1234DT263	100	MIXED	AMI	Yes	100%	29	0.02569744	0.011925	0.01377244	53.59%
1474	TPCODL	BBSR1	BCDD-2	PERIPHERI	TRISHULIA	14367	11 KV MUNDAMUHAN	14367203	MUNDAMOHAN	1234DT151	100	MIXED	AMI	Yes	0%	86	0.0776012	0.051385	0.0262162	33.78%
1475	TPCODL	BBSR1	BCDD-2	PERIPHERI	TRISHULIA	14367	11 KV MUNDAMUHAN	14367203	KUNHEIPARA 4	1234DT152	100	MIXED	AMI	Yes	0%	88	0.08523316	0.063781	0.02145216	25.17%
1476	TPCODL	BBSR1	BCDD-2	PERIPHERI	TRISHULIA	14367	11 KV MUNDAMUHAN	14367203	BACHU BANGALI AT FAKIRAPADA	1234DT480	100	MIXED	AMI	Yes	0%	19	0.01213106	0.006648	0.00548306	45.20%
1477	TPCODL	BBSR1	BCDD-2	PERIPHERI	TRISHULIA	14367	11 KV MADHUPUR	14367204	THE AANGAN BLUE OPPOSITE	1234DT276	400	MIXED	AMI	Yes	67%	82	0.07954756	0.062983	0.01656456	20.82%
1478	TPCODL	BBSR1	BCDD-2	PERIPHERI	TRISHULIA	14367	11 KV MADHUPUR	14367204	MADHUBANA VILLAGE(ANLAPATNA)	1234DT295	250	MIXED	AMI	Yes	0%	225	0.20061796	0.118123	0.08249496	41.12%
1479	TPCODL	BBSR1	BCDD-2	PERIPHERI	TRISHULIA	14367	11 KV MADHUPUR	14367204	PINKI PRADHANA	1234DT296	250	MIXED	AMI	Yes	100%	65	0.09103688	0.034302	0.05673488	62.32%
1480	TPCODL	BBSR1	BCDD-2	PERIPHERI	TRISHULIA	14367	11 KV MADHUPUR	14367204	DEULI	1234DT304	100	MIXED	AMI	Yes	0%	107	0.09128398	0.063226	0.02805798	30.74%
1481	TPCODL	BBSR1	BCDD-2	PERIPHERI	TRISHULIA	14367	11 KV MADHUPUR	14367204	GANAPATI SITE(BELGACCHIA)	1234DT311	100	MIXED	AMI	Yes	0%	52	0.08106928	0.029363	0.05170628	63.78%
1482	TPCODL	BBSR1	BCDD-2	PERIPHERI	TRISHULIA	14367	11 KV MADHUPUR	14367204	JAYAPURA	1234DT328	100	MIXED	AMI	Yes	0%	74	0.08426372	0.032698	0.05156572	61.20%
1483	TPCODL	BBSR1	BED	RASULGARH	KALPANA ODSSP	14245	11 KV KALPANA FLAT	14245201	M/S ESSEN CONSTN.(PRADEEP THAKI	1311DT006	100	MIXED	AMI	Yes	0%	16	0.02230994	0.018911	0.00339894	15.24%
1484	TPCODL	BBSR1	BED	RASULGARH	KALPANA ODSSP	14245	11 KV KALPANA FLAT	14245201	BIGYAN CHOUDHURY	1311DT021	100	MIXED	AMI	Yes	0%	14	0.0152681	0.010724	0.0045441	29.76%
1485	TPCODL	BBSR1	BED	RASULGARH	KALPANA ODSSP	14245	11 KV CUTTACK ROAD	14245202	NEAR VIVEKANAND PARK	1311DT032	100	MIXED	AMI	Yes	0%	25	0.08259836	0.039597	0.04300136	52.06%
1486	TPCODL	BBSR1	BED	RASULGARH	KALPANA ODSSP	14245	11 KV CUTTACK ROAD	14245202	BISWANATH NAGAR	1311DT038	100	MIXED	AMI	Yes	0%	27	0.04758282	0.037142	0.01044082	21.94%
1487	TPCODL	BBSR1	BED	RASULGARH	KALPANA ODSSP	14245	11 KV CUTTACK ROAD	14245202	SNIGHDA PRADHAN	1311DT043	100	MIXED	AMI	Yes	0%	8	0.0157887	0.013923	0.0018657	11.82%
1488	TPCODL	BBSR1	BED	RASULGARH	KALPANA ODSSP	14245	11 KV CUTTACK ROAD	14245202	NEAR SRIDEVI CHHAK	1311DT055	100	MIXED	AMI	Yes	0%	35	0.04726264	0.04726	2.64E-06	0.01%
1489	TPCODL	BBSR1	BED	RASULGARH	KALPANA ODSSP	14245	11 KV CUTTACK ROAD	14245202	IN FRONT OF GOPAL RESIDENCY	1311DT056	100	MIXED	AMI	Yes	0%	42	0.03852838	0.029639	0.00888938	23.07%
1490	TPCODL	BBSR1	BED	RASULGARH	KALPANA ODSSP	14245	11 KV CUTTACK ROAD	14245202	KALPANA FLAT 3R QTR FRONT	1311DT060	100	MIXED	AMI	Yes	0%	30	0.0898324	0.076629	0.0132034	14.70%
1491	TPCODL	BBSR1	BED	RASULGARH	KALPANA ODSSP	14245	11 KV CUTTACK ROAD	14245202	KALPANA FLAT 2RA QTR FRONT	1311DT063	100	MIXED	AMI	Yes	0%	32	0.033406	0.029335	0.004071	12.19%
1492	TPCODL	BBSR1	BED	RASULGARH	KALPANA ODSSP	14245	11 KV CUTTACK ROAD	14245202	M/S SHREE VIBYOR COLOUR LAB	1311DT064	100	MIXED	AMI	Yes	0%	88	0.08876952	0.07699	0.01177952	13.27%
1493	TPCODL	BBSR1	BED	RASULGARH	LAXMISAGAR	14020	11 kV RMU-16	14020209	SUMITRA RESIDENCY	1311DT071	100	MIXED	AMI	Yes	0%	13	0.01149014	0.011437	5.314E-05	0.46%
1494	TPCODL	BBSR1	BED	RASULGARH	LAXMISAGAR	14020	11 kV RMU-16	14020209	IN FRONT OF HOTEL SHATABDI	1311DT121	250	MIXED	AMI	Yes	0%	27	0.06458816	0.033344	0.03124416	48.37%
1495	TPCODL	BBSR1	BED	RASULGARH	LAXMISAGAR	14020	11 kV RMU-16	14020209	SBI FRONT	1311DT123	100	MIXED	AMI	Yes	0%	9	0.03554122	0.014314	0.02122722	59.73%
1496	TPCODL	BBSR1	BED	RASULGARH	LAXMISAGAR	14020	11 kV RMU-16	14020209	CHIEF ENGINEERS	1311DT129	500	MIXED	AMI	Yes	0%	68	0.15236728	0.124179	0.02818828	18.50%
1497	TPCODL	BBSR1	BED	RASULGARH	LAXMISAGAR	14020	11 kV RMU-16	14020209	BUDHANAGAR BASTI	1311DT131	200	MIXED	AMI	Yes	0%	179	0.16901532	0.13542	0.03359532	19.88%
1498	TPCODL	BBSR1	BED	RASULGARH	LAXMISAGAR	14020	11 kV RMU-6A	14020209	CHINTAMANISWAR ROAD 1	1311DT144	100	MIXED	AMI	Yes	0%	41	0.07624862	0.050279	0.02596962	34.06%
1499	TPCODL	BBSR1	BED	RASULGARH	LAXMISAGAR	14020	11 kV RMU-16	14020209	SRI KRISHNA HEIGHTS	1311DT155	250	MIXED	AMI	Yes	0%	20	0.039617	0.029832	0.009785	24.70%
1500	TPCODL	BBSR1	BED	RASULGARH	LAXMISAGAR	14020	11 kV RMU-16	14020209	CHINTAMANISWAR RAPDRP	1311DT156	100	MIXED	AMI	Yes	0%	85	0.12146836	0.106177	0.01529136	12.59%
1501	TPCODL	BBSR1	BED	RASULGARH	LAXMISAGAR	14020	11 kV RMU-16	14020209	FISHERY LANE NEAR TEMPLE	1311DT157	100	MIXED	AMI	Yes	0%	20	0.02743318	0.017012	0.01042118	37.99%
1502	TPCODL	BBSR1	BED	RASULGARH	LAXMISAGAR	14020	11 kV RMU-16	14020209	CHINTAMANISWAR TEMPLE BACK SI	1311DT159	500	MIXED	AMI	Yes	0%	169	0.3612348	0.196291	0.1649438	45.66%
1503	TPCODL	BBSR1	BED	RASULGARH	LAXMISAGAR	14020	11 kV RMU-16	14020209	SOMNATH SWAIN(MAHALAXMI)	1311DT165	100	MIXED	AMI	Yes	0%	12	0.01385532	0.007258	0.00659732	47.62%
1504	TPCODL	BBSR1	BED	RASULGARH	LAXMISAGAR	14020	11 kV RMU-16	14020209	RAMACHANDRA BISWAL	1311DT169	100	MIXED	AMI	Yes	0%	17	0.0136829	0.012825	0.0008579	6.27%
1505	TPCODL	BBSR1	BED	RASULGARH	LAXMISAGAR	14020	11 kV RMU-16	14020209	CHANYAKA TUTORIAL LANE	1311DT170	250	MIXED	AMI	Yes	0%	178	0.28917464	0.250497	0.03867764	13.38%
1506	TPCODL	BBSR1	BED	RASULGARH	LAXMISAGAR	14020	11 kV RMU-16	14020209	PANBARAJA BASTI	1311DT175	250	MIXED	AMI	Yes	100%	124	0.191317	0.16392	0.027397	14.32%
1507	TPCODL	BBSR1	BED	RASULGARH	LAXMISAGAR	14020	11 kV RMU-6A	14020207	CHAMPA PAKHURI 1	1311DT177	630	MIXED	AMI	Yes	100%	71	0.30522752	0.112518	0.19270952	63.14%
1508	TPCODL	BBSR1	BED	RASULGARH	KALPANA ODSSP	14245	11 kV CUTTACK ROAD	14245202	JONAL NEAR HOSPITAL(RAPDRP)	1311DT181	100	MIXED	AMI	Yes	0%	58	0.0398001	0.020266	0.0195341	49.08%
1509	TPCODL	BBSR1	BED	RASULGARH	LAXMISAGAR	14020	11 kV KALPANA-1	14020202	PLOT 104 BUDHESWARI	1312DT061	100	MIXED	AMI	Yes	0%	18	0.03298672	0.022901	0.01008572	30.58%
1510	TPCODL	BBSR1	BED	RASULGARH	LAXMISAGAR	14020	11 kV KALPANA-1	14020202	PHD,BUDHESWARI	1312DT071	500	MIXED	AMI	Yes	0%	183	0.40898352	0.228938	0.18004552	44.02%
1511	TPCODL	BBSR1	BED	RASULGARH	LAXMISAGAR	14020	11 kV LAXMISAGAR OH	14020212	STAGE 5	1313DT007	500	MIXED	AMI	Yes	0%	188	0.31282352	0.230207	0.08261652	26.41%
1512	TPCODL	BBSR1	BED	RASULGARH	LAXMISAGAR	14020	11 kV LAXMISAGAR OH	14020212	BAJARANGA NAGAR	1313DT045	250	MIXED	AMI	Yes	100%	84	0.18182856	0.115825	0.06600356	36.30%
1513	TPCODL	BBSR1	BED	RASULGARH	LAXMISAGAR	14020	11 KV LAXMISAGAR UG	14020201	ASS VILLA JAGANNATH NAGAR ROAD	1313DT076	100	MIXED	AMI	Yes	0%	9	0.0215159	0.007762	0.0137539	63.92%
1514	TPCODL	BBSR1	BED	RASULGARH	SBI KESURA	14183	11 kV KESURA	14183202	NEAR HOTEL JOY JAGANNATH	1313DT151	250	MIXED	AMI	Yes	100%	67	0.17041912	0.070401	0.10001812	58.69%
1515	TPCODL	BBSR1	BED	RASULGARH	LAXMISAGAR	14020	11 kV RMU-5	14020206	CSS 6	1313DT342	630	MIXED	AMI	Yes	100%	118	0.29487376	0.180925	0.11394876	38.64%
1516	TPCODL	BBSR1	BED	RASULGARH	LAXMISAGAR	14020	11 kV RMU-5	14020206	RATNA VILLAGE,BOMIKHAL	1313DT390	250	MIXED	AMI	Yes	0%	19	0.03798056	0.024146	0.01383456	36.43%
1517	TPCODL	BBSR1	BED	RASULGARH	LAXMISAGAR	14020	11 kV RMU-14	14020213	BOMIKHAL HIGH SCHOOL(DEVRAJ VI	1313DT405	100	MIXED	AMI	Yes	0%	39	0.04902368	0.046162	0.00286168	5.84%
1518	TPCODL	BBSR1	BED	RASULGARH	SBI KESURA	14183	11 kV KESURA	14183202	SBI COLONY NEAR FLAT	1313DT424	250	MIXED	AMI	Yes	100%	11	0.0264282	0.006699	0.0197292	74.65%
1519	TPCODL	BBSR1	BED	RASULGARH	LAXMISAGAR	14020	11 kV RMU-5	14020206	CSS 3	1313DT450	630	MIXED	AMI	Yes	100%	150	0.66924432	0.244574	0.42467032	63.46%
1520	TPCODL	BBSR1	BED	RASULGARH	LAXMISAGAR	14020	11 kV RMU-6	14020210	CSS-03A	1313DT451	630	MIXED	AMI	Yes	100%	269	0.4373296	0.427229	0.0101006	2.31%
1521	TPCODL	BBSR1	BED	RASULGARH	LAXMISAGAR	14020	11 kV RMU-6	14020210	CSS-04	1313DT452	630	MIXED	AMI	Yes	100%	179	0.5073568	0.246972	0.2603848	51.32%
1522	TPCODL	BBSR1	BED	RASULGARH	LAXMISAGAR	14020	11 kV RMU-5	14020206	CSS 5	1313DT453	630	MIXED	AMI	Yes	100%	107	0.59011664	0.203649	0.38646764	65.49%
1523	TPCODL	BBSR1	BED	RASULGARH	SBI KESURA	14183	11 kV KESURA	14183202	NEAR TIKOTAMA GHADEI	1313DT559	100	MIXED	AMI	Yes	0%	13	0.01575474	0.008048	0.00770674	48.92%
1524	TPCODL	BBSR1	BED	RASULGARH	MANCHESWAR	14022	11 kV MANCHESWAR-1	14022201	S K MECHINERY-1	1314DT022	500	MIXED	AMI	Yes	0%	25	0.26196632	0.079002	0.18296432	69.84%
1525	TPCODL	BBSR1	BED	RASULGARH	MANCHESWAR	14022	11 kV MANCHESWAR-3	14022203	SHIV MANDIR -2	1314DT142	250	MIXED	AMI	Yes	0%	102	0.20374712	0.121686	0.08206112	40.28%
1526	TPCODL	BBSR1	BED	RASULGARH	MANCHESWAR	14022	11 kV MANCHESWAR-3	14022203	UGALAMANI -2	1314DT157	500	MIXED	AMI	Yes	0%	147	0.40121216	0.205707	0.19550516	48.73%
1527	TPCODL	BBSR1	BED	RASULGARH	MANCHESWAR	14022	11 kV MANCHESWAR-3	14022203	SATYANANDA SAHOO	1314DT173	250	MIXED	AMI	Yes	0%	104	0.16618504	0.130659	0.03552604	21.38%
1528	TPCODL	BBSR1	BED	RASULGARH	CHAKEISIANI ODSSP	14243	11 kV BHATAPADA	14243203	BHOTAPADA CHHAKA	1314DT258	100	MIXED	AMI	Yes	0%	97	0.10632966	0.083598	0.02273166	21.38%
1529	TPCODL	BBSR1	BED	RASULGARH	CHAKEISIANI ODSSP	14243	11 kV RAJDHANI COLLEG	14243201	M/S AROOP NAGAR DEVELOPMENT	1314DT426	100	MIXED	AMI	Yes	0%	6	0.0045017	0.003551	0.0009507	21.12%
1530	TPCODL	BBSR1	BED	RASULGARH	BHINGARPUR	14224	11 kV BHINGARPUR UG	14224203	RAMCHANDRAPUR MANGALA SAHI	1315DT041	100	MIXED	AMI	Yes	0%	105	0.09294591	0.04493	0.04801591	51.66%
1531	TPCODL	BBSR1	BED	RASULGARH	BHINGARPUR	14224	11 kV BHINGARPUR UG	14224203	CHINGUDIA	1315DT057	100	MIXED	AMI	Yes	0%	87	0.06612494	0.039842	0.02628294	39.75%
1532	TPCODL	BBSR1	BED	RASULGARH	BHINGARPUR	14224	11 kV BHINGARPUR UG	14224203	PANDASAHI	1315DT067	100	MIXED	AMI	Yes	0%	94	0.0548381	0.03831802	0.01652008	30.13%

Sl. No.	Zone Name	Circle name	Division name	Name of the Sub-division	Name of the Sub-station	Substation Code	Name of the 11 kV Feeder	Feeder Code	Name of the Location where DT situated	DT code	DT Capacity (kVA)	Predominant consumer type of DT (Domestic/Industrial/Agriculture/Mixed)	Type of metering AMR/AMI/ Communicable/Conventional metered/Unmetered	Status of Meter-whether Functional (Yes/No)	% of data received automatically (if AMR/AMI)	No. of Connected Consumers	Input Energy (MU) (A)	Billed Energy (MU) (B)	Loss (MU) (A-B)	% DT Loss (A-B)/A
1533	TPCODL	BBSR1	BED	RASULGARH	BHINGARPUR	14224	11 kV BHINGARPUR UG	14224203	BENTAPUR BISWANATH TEMPLE	1315DT072	100	MIXED	AMI	Yes	0%	62	0.05180788	0.029143	0.02266488	43.75%
1534	TPCODL	BBSR1	BED	RASULGARH	NAHARKANTA	14180	11 kV NAHARKANTA	14180201	BASUNDHARA	1315DT108	500	MIXED	AMI	Yes	100%	240	0.33957456	0.285062	0.05451256	16.05%
1535	TPCODL	BBSR1	BED	RASULGARH	NAHARKANTA	14180	11 kV NAHARKANTA	14180201	SIDHI SAI	1315DT113	100	MIXED	AMI	Yes	100%	13	0.0073676	0.007266	0.0001016	1.38%
1536	TPCODL	BBSR1	BED	RASULGARH	NAHARKANTA	14180	11 kV ATALA	14180203	RUDRA BIHAR -2	1315DT251	25	MIXED	AMI	Yes	0%	20	0.08109082	0.017033	0.06405782	79.00%
1537	TPCODL	BBSR1	BED	RASULGARH	NAHARKANTA	14180	11 kV BALIANTA	14180202	MUSLIM SAHI	1315DT342	250	MIXED	AMI	Yes	0%	189	0.19214764	0.151535	0.04061264	21.14%
1538	TPCODL	BBSR1	BED	RASULGARH	NAKHARA	14023	11 kV PAHAL	14023203	BANGUARI 2	1315DT499	250	MIXED	AMI	Yes	100%	125	0.15352014	0.106234	0.04728614	30.80%
1539	TPCODL	BBSR1	BED	RASULGARH	NAKHARA	14023	11 kV GOBINDPUR RE	14023201	ANATPUR NATHASAHI	1315DT601	100	MIXED	AMI	Yes	67%	39	0.06881266	0.028649	0.04016366	58.37%
1540	TPCODL	BBSR1	BED	RASULGARH	NAKHARA	14023	11 KV TRINATH BAZAR U	14023206	JAIPUR SADANGI SAHI	1315DT736	250	MIXED	AMI	Yes	100%	91	0.09641124	0.06895	0.02746124	28.48%
1541	TPCODL	BBSR1	BED	RASULGARH	NAKHARA	14023	11 KV TRINATH BAZAR U	14023206	SUMPLAZA	1315DT769	100	MIXED	AMI	Yes	0%	15	0.01503194	0.008005	0.00702694	46.75%
1542	TPCODL	BBSR1	BED	RASULGARH	NAKHARA	14023	11 KV TRINATH BAZAR U	14023206	RASHMI RANJAN BEURA PROJECT	1315DT771	100	MIXED	AMI	Yes	0%	23	0.03291228	0.01771	0.01520228	46.19%
1543	TPCODL	BBSR1	BED	RASULGARH	NAKHARA	14023	11 kV TRINATH BAZAR	14023202	JAGANNATH PUR	1315DT775	200	MIXED	AMI	Yes	0%	37	0.07597938	0.032714	0.04326538	56.94%
1544	TPCODL	BBSR1	BED	RASULGARH	PANDRA	14370	11 kV PANDRA VILLAGE	14370203	GEETA KHETRA	1316DT002	100	MIXED	AMI	Yes	0%	88	0.09427122	0.086531	0.00774022	8.21%
1545	TPCODL	BBSR1	BED	RASULGARH	PANDRA	14370	11 kV JAGANNATH NAGA	14370202	BANKER ENCLAVE	1316DT039	500	MIXED	AMI	Yes	0%	82	0.11038568	0.08691	0.02347568	21.27%
1546	TPCODL	BBSR1	BED	RASULGARH	PANDRA	14370	11 KV JAGANNATH NAGA	14370208	MALAYA BIHAR	1316DT049	500	MIXED	AMI	Yes	0%	186	0.29835368	0.2435	0.05485368	18.39%
1547	TPCODL	BBSR1	BED	RASULGARH	PANDRA	14370	11 KV JAGANNATH NAGA	14370208	BRIGHT RESIDENCY	1316DT062	500	MIXED	AMI	Yes	0%	34	0.09478216	0.043422	0.05136016	54.19%
1548	TPCODL	BBSR1	BED	RASULGARH	PANDRA	14370	11 KV JAGANNATH NAGA	14370208	BRTGHT RESIDENCY	1316DT063	500	MIXED	AMI	Yes	0%	66	0.10528384	0.080023	0.02526084	23.99%
1549	TPCODL	BBSR1	BED	RASULGARH	PANDRA	14370	11 KV JAGANNATH NAGA	14370208	JAGANNATH NAGAR ROAD 8(2)	1316DT069	250	MIXED	AMI	Yes	0%	144	0.2186062	0.176802	0.0418042	19.12%
1550	TPCODL	BBSR1	BED	RASULGARH	PANDRA	14370	11 KV JAGANNATH NAGA	14370208	NN PLAZA	1316DT071	250	MIXED	AMI	Yes	0%	20	0.03859912	0.015304	0.02329512	60.35%
1551	TPCODL	BBSR1	BED	RASULGARH	PANDRA	14370	11 kV PRACHI	14370201	PLOT NO.53 NEAR D.MOHANTY	1316DT086	100	MIXED	AMI	Yes	0%	24	0.06349746	0.028618	0.03487946	54.93%
1552	TPCODL	BBSR1	BED	RASULGARH	PANDRA	14370	11 kV PRACHI	14370201	ISHAGADA	1316DT114	100	MIXED	AMI	Yes	100%	117	0.14930114	0.146185	0.00311614	2.09%
1553	TPCODL	BBSR1	BED	RASULGARH	PANDRA	14370	11 kV PRACHI	14370201	KHUSHI HARMONY	1316DT116	100	MIXED	AMI	Yes	100%	15	0.01769654	0.013239	0.00445754	25.19%
1554	TPCODL	BBSR1	BED	RASULGARH	RASULGARH	14021	11 kV RASULGARH	14021201	POLICE HOUSING	1316DT152	250	MIXED	AMI	Yes	0%	37	0.04404102	0.027018	0.01702302	38.65%
1555	TPCODL	BBSR1	BED	RASULGARH	RASULGARH	14021	11 kV PURI ROAD	14021202	RASULGARH SQUARE	1316DT286	630	MIXED	AMI	Yes	100%	221	0.6004424	0.371515	0.2289274	38.13%
1556	TPCODL	BBSR1	BED	RASULGARH	RASULGARH	14021	11 kV PURI ROAD	14021202	PATANJALI MEGA STORE (RASULGAR	1316DT287	630	MIXED	AMI	Yes	100%	141	0.18924352	0.175188	0.01405552	7.43%
1557	TPCODL	BBSR1	BED	RASULGARH	LAXMISAGAR	14020	11 KV JHARPADA OH	14020211	JENA BASTI(L&T)	1312DT168	100	MIXED	AMI	Yes	100%	60	0.09284104	0.06957	0.02327104	25.07%
1558	TPCODL	BBSR1	BED	RASULGARH	LAXMISAGAR	14020	11 KV JHARPADA OH	14020211	BASANTI VILLA	1312DT170	100	MIXED	AMI	Yes	0%	17	0.0153169	0.010527	0.0047899	31.27%
1559	TPCODL	BBSR1	BED	RASULGARH	LAXMISAGAR	14020	11 KV JHARPADA OH	14020211	MUSLIM BSTEE	1312DT172	500	MIXED	AMI	Yes	100%	252	0.3271796	0.239656	0.0875236	26.75%
1560	TPCODL	BBSR1	BED	RASULGARH	LAXMISAGAR	14020	11 KV JHARPADA OH	14020211	MEHER PALLI	1312DT173	200	MIXED	AMI	Yes	100%	49	0.15558516	0.105492	0.05009316	32.20%
1561	TPCODL	BBSR1	BED	RASULGARH	LAXMISAGAR	14020	11 KV JHARPADA OH	14020211	MIRZA RIAZ BAIG(FRMANZIL)	1312DT175	250	MIXED	AMI	Yes	100%	19	0.02273708	0.019347	0.00339008	14.91%
1562	TPCODL	BBSR1	BED	RASULGARH	LAXMISAGAR	14020	11 KV LAXMISAGAR OH	14020212	INSIDE JAIL	1313DT001	250	MIXED	AMI	Yes	100%	58	0.07953996	0.041398	0.03814196	47.95%
1563	TPCODL	BBSR1	BED	RASULGARH	LAXMISAGAR	14020	11 KV LAXMISAGAR OH	14020212	PLOT NO-HP-11,BDA COLONY-2	1313DT013	100	MIXED	AMI	Yes	100%	26	0.0345849	0.027593	0.0069919	20.22%
1564	TPCODL	BBSR1	BED	RASULGARH	LAXMISAGAR	14020	11 KV LAXMISAGAR OH	14020212	N.A.MAJESTIC APT,SANTI NAGAR	1313DT019	100	MIXED	AMI	Yes	100%	24	0.03021924	0.020778	0.00944124	31.24%
1565	TPCODL	BBSR1	BED	RASULGARH	LAXMISAGAR	14020	11 KV LAXMISAGAR OH	14020212	SHANTI NAGAR	1313DT026	250	MIXED	AMI	Yes	33%	130	0.21401081	0.19435	0.01966081	9.19%
1566	TPCODL	BBSR1	BED	RASULGARH	LAXMISAGAR	14020	11 KV LAXMISAGAR OH	14020212	ROAD NO-12,BASUDEV NAGAR	1313DT033	500	MIXED	AMI	Yes	100%	189	0.33151928	0.277201	0.05431828	16.38%
1567	TPCODL	BBSR1	BED	RASULGARH	LAXMISAGAR	14020	11 KV LAXMISAGAR OH	14020212	NEW BOMIKHAL	1313DT036	100	MIXED	AMI	Yes	0%	100	0.09601398	0.092628	0.00338598	3.53%
1568	TPCODL	BBSR1	BED	RASULGARH	LAXMISAGAR	14020	11 KV LAXMISAGAR OH	14020212	GANAPATI RECIDENCY APT	1313DT040	500	MIXED	AMI	Yes	100%	40	0.06748632	0.052155	0.01533132	22.72%
1569	TPCODL	BBSR1	BED	RASULGARH	LAXMISAGAR	14020	11 KV LAXMISAGAR OH	14020212	BARANGI NAGAR	1313DT042	500	MIXED	AMI	Yes	100%	151	0.24392512	0.198252	0.04567312	18.72%
1570	TPCODL	BBSR1	BED	RASULGARH	LAXMISAGAR	14020	11 KV LAXMISAGAR OH	14020212	ANANYA ENCLAVE	1313DT050	100	MIXED	AMI	Yes	0%	7	0.01001014	0.009399	0.00061114	6.11%
1571	TPCODL	BBSR1	BED	RASULGARH	LAXMISAGAR	14020	11 KV RMU-14	14020213	SATYAM TOWER	1313DT323	500	MIXED	AMI	Yes	100%	65	0.08655608	0.049707	0.03684908	42.57%
1572	TPCODL	BBSR1	BED	RASULGARH	LAXMISAGAR	14020	11 KV RMU-14	14020213	VAISAKHA ENCLAVE	1313DT324	500	MIXED	AMI	Yes	100%	136	0.15777352	0.111418	0.04635552	29.38%
1573	TPCODL	BBSR1	BED	RASULGARH	LAXMISAGAR	14020	11 KV RMU-14	14020213	ASHIRVAD APARTMENT	1313DT325	250	MIXED	AMI	Yes	100%	50	0.05569416	0.035236	0.02045816	36.73%
1574	TPCODL	BBSR1	BED	RASULGARH	LAXMISAGAR	14020	11 KV RMU-14	14020213	RATNA TOWER	1313DT328	250	MIXED	AMI	Yes	0%	17	0.03560872	0.024312	0.01129672	31.72%
1575	TPCODL	BBSR1	BED	RASULGARH	LAXMISAGAR	14020	11 KV RMU-14	14020213	RASHMI RANJAN SUBUDHI(UPAHAR	1313DT408	250	MIXED	AMI	Yes	100%	20	0.06285476	0.043592	0.01926276	30.65%
1576	TPCODL	BBSR1	BED	RASULGARH	LAXMISAGAR	14020	11 KV RMU-14	14020213	BACK SIDE BASANTA VILLA	1313DT410	100	MIXED	AMI	Yes	0%	25	0.06269678	0.044604	0.01809278	28.86%
1577	TPCODL	BBSR1	BED	RASULGARH	LAXMISAGAR	14020	11 KV RMU-14	14020213	BASANTA VILLA APARTMENT	1313DT411	250	MIXED	AMI	Yes	100%	63	0.08126668	0.058277	0.02298968	28.29%
1578	TPCODL	BBSR1	BED	RASULGARH	LAXMISAGAR	14020	11 KV RMU-14	14020213	RAMA BHRAMAR PALACE	1313DT413	500	MIXED	AMI	Yes	100%	63	0.1254808	0.067623	0.0578578	46.11%
1579	TPCODL	BBSR1	BED	RASULGARH	NAKHARA	14023	11 KV TRINATH BAZAR U	14023206	GOHALA 4 GHARIA	1315DT734	100	MIXED	AMI	Yes	100%	77	0.06552368	0.043496	0.02202768	33.62%
1580	TPCODL	BBSR1	BED	RASULGARH	NAKHARA	14023	11 KV TRINATH BAZAR U	14023206	JAIPUR ROUTRAY SAHI 1	1315DT738	63	MIXED	AMI	Yes	100%	31	0.09361948	0.021555	0.07206448	76.98%
1581	TPCODL	BBSR1	BED	RASULGARH	NAKHARA	14023	11 KV TRINATH BAZAR U	14023206	KASHYAP KUTIRA	1315DT743	500	MIXED	AMI	Yes	100%	18	0.03949944	0.020851	0.01864844	47.21%
1582	TPCODL	BBSR1	BED	RASULGARH	NAKHARA	14023	11 KV TRINATH BAZAR U	14023206	LAXMI ENCLAVE	1315DT750	250	MIXED	AMI	Yes	0%	26	0.04765096	0.0287	0.01895096	39.77%
1583	TPCODL	BBSR1	BED	RASULGARH	NAKHARA	14023	11 KV TRINATH BAZAR U	14023206	SWASTI GARDEN	1315DT757	500	MIXED	AMI	Yes	100%	34	0.0569936	0.022058	0.0349356	61.30%
1584	TPCODL	BBSR1	BED	RASULGARH	NAKHARA	14023	11 KV TRINATH BAZAR U	14023206	SHREE SAIRAINBOW	1315DT759	250	MIXED	AMI	Yes	100%	33	0.05847684	0.031325	0.02715184	46.43%
1585	TPCODL	BBSR1	BED	RASULGARH	NAKHARA	14023	11 KV TRINATH BAZAR U	14023206	ATALA	1315DT765	250	MIXED	AMI	Yes	0%	116	0.12864316	0.099926	0.02871716	22.32%
1586	TPCODL	BBSR1	BED	RASULGARH	NAKHARA	14023	11 KV TRINATH BAZAR U	14023206	SURTALOK	1315DT768	500	MIXED	AMI	Yes	100%	14	0.0245918	0.016807	0.0077848	31.66%
1587	TPCODL	BBSR1	BED	RASULGARH	NAKHARA	14023	11 KV TRINATH BAZAR U	14023206	M S SHREE INFRA PROPERTIES	1315DT860	100	MIXED	AMI	Yes	100%	21	0.01319984	0.009609	0.00359084	27.20%
1588	TPCODL	BBSR1	BED	RASULGARH	NAKHARA	14023	11 KV TRINATH BAZAR U	14023206	MANCHANATH VILLA 2	1315DT879	250	MIXED	AMI	Yes	100%	6	0.02907396	0.007797	0.02127696	73.18%
1589	TPCODL	BBSR1	BED	RASULGARH	NAKHARA	14023	11 KV PAHAL UG	14023207	BAIBHAV PROJECT PAHAL	1315DT543	100	MIXED	AMI	Yes	100%	14	0.03209358	0.012015	0.02007858	62.56%
1590	TPCODL	BBSR1	BED	RASULGARH	NAKHARA	14023	11 KV PAHAL UG	14023207	PARAGON CITY	1315DT557	250	MIXED	AMI	Yes	100%	107	0.1201852	0.087068	0.0331172	27.56%
1591	TPCODL	BBSR1	BED	RASULGARH	NAKHARA	14023	11 KV PAHAL UG	14023207	JOHAL CAPEX	1315DT565	100	MIXED	AMI	Yes	100%	46	0.06316936	0.030835	0.03233436	51.19%
1592	TPCODL	BBSR1	BED	RASULGARH	NAHARKANTA	14180	11 KV JAYDEV COLLEGE	14180204	SIRAJ NOURSURY	1315DT085	100	MIXED	AMI	Yes	67%	26	0.10763716	0.071127	0.03651016	33.92%
1593	TPCODL	BBSR1	BED	RASULGARH	NAHARKANTA	14180	11 KV JAYDEV COLLEGE	14180204	PRAVAT DASH	1315DT087	250	MIXED	AMI	Yes	0%	105	0.19519307	0.122261	0.07293207	37.36%
1594	TPCODL	BBSR1	BED	RASULGARH	NAHARKANTA	14180	11 KV JAYDEV COLLEGE	14180204	MAHADEV PADIA	1315DT094	250	MIXED	AMI	Yes	100%	66	0.18162688	0.073275	0.10835188	59.66%
1595	TPCODL	BBSR1	BED	RASULGARH	NAHARKANTA	14180	11 KV JAYDEV COLLEGE	14180204	MILAN SAHU	1315DT100	100	MIXED	AMI	Yes	100%	53	0.0760884	0.059117	0.0169714	22.30%
1596	TPCODL	BBSR1	BED	RASULGARH	NAHARKANTA	14180	11 KV JAYDEV COLLEGE	14180204	HANUMAN SAHI	1315DT101	100	MIXED	AMI	Yes	0%	119	0.12348315	0.092707	0.03077615	24.92%
1597	TPCODL	BBSR1	BED	RASULGARH	NAHARKANTA	14180	11 KV JAYDEV COLLEGE	14180204	BANDHA SAHI	1315DT103	100	MIXED	AMI	Yes	100%	59	0.03686906	0.020432	0.01643706	44.58%
1598	TPCODL	BBSR1	BED	RASULGARH	NAHARKANTA	14180	11 KV JAYDEV COLLEGE	14180204	PHULA BAGICHA	1315DT104	100	MIXED	AMI	Yes	100%	68	0.06388094	0.057402	0.00647894	10.14%
1599	TPCODL	BBSR1	BED	RASULGARH	BHINGARPUR	14224	11 KV GANGESWAR	14224201	ECHHADEI PATANA	1315DT001	100	MIXED	AMI	Yes	67%	65	0.05216092	0.031009	0.02115192	40.55%
1600	TPCODL	BBSR1	BED	RASULGARH	BHINGARPUR	14224	11 KV GANGESWAR	14224201	SMILE CITY ESCAPE	1315DT797	100	MIXED	AMI	Yes	33%	18	0.02007032	0.015178	0.00489232	24.38%
1601	TPCODL	BBSR1	BED	RASULGARH	BHINGARPUR	14224	11 KV GANGESWAR	14224201	SMILE GREEN CITY	1315DT820	250	MIXED	AMI	Yes	0%	29	0.03110348	0.022804	0.00829948	26.68%
1602	TPCODL	BBSR1	BED	RASULGARH	BHINGARPUR	14224	11 KV GANGESWAR	14224201	TATTAWAMASHI HOUSING SOCIETY	1315DT821	250	MIXED	AMI	Yes	100%	40	0.03787784	0.02815	0.00972784	25.68%
1603	TPCODL	BBSR1	BED	RASULGARH	BHINGARPUR	14224	11 KV BHINGARPUR	14224202	GOKUL DHAM APPARTMENT	1315DT004	100	MIXED	AMI	Yes	0%	24	0.02768652	0.006107	0.02157952	77.94%
1604	TPCODL	BBSR1	BED	RASULGARH	BHINGARPUR	14224	11 KV BHINGARPUR	14224202	BHINGARAPUR BHRAMARA SAHI	1315DT019	100	MIXED	AMI	Yes	100%	94	0.08528086	0.059434	0.02584686	30.31%
1605	TPCODL	BBSR1	BED	RASULGARH	BHINGARPUR	14224	11 KV BHINGARPUR	14224202	DELTA BAZZAR	1315DT049	100	MIXED	AMI	Yes	100%	85	0.07544054	0.04872	0.02672054	35.42%

Sl. No.	Zone Name	Circle name	Division name	Name of the Sub-division	Name of the Sub-station	Substation Code	Name of the 11 kV Feeder	Feeder Code	Name of the Location where DT situated	DT code	DT Capacity (kVA)	Predominant consumer type of DT (Domestic/Industrial/Agriculture/Mixed)	Type of metering AMR/AMI/ Communicable/Conventional metered/Unmetered	Status of Meter- whether Functional (Yes/No)	% of data received automatically (if AMR/AMI)	No. of Connected Consumers	Input Energy (MU) (A)	Billed Energy (MU) (B)	Loss (MU) (A-B)	% DT Loss (A-B)/A
1606	TPCODL	BBSR1	BED	RASULGARH	BHINGARPUR	14224	11 KV BHINGARPUR	14224202	DEWAN PATNA	1315DT050	100	MIXED	AMI	Yes	100%	85	0.06704354	0.04004	0.02700354	40.28%
1607	TPCODL	BBSR1	BED	RASULGARH	BHINGARPUR	14224	11 KV BHINGARPUR	14224202	PANDA SAHI	1315DT056	100	MIXED	AMI	Yes	100%	52	0.05252362	0.037824	0.01469962	27.99%
1608	TPCODL	BBSR1	BED	RASULGARH	BHINGARPUR	14224	11 KV BHINGARPUR	14224202	SASAN	1315DT060	250	MIXED	AMI	Yes	100%	238	0.16806928	0.103329	0.06474028	38.52%
1609	TPCODL	BBSR1	BED	RASULGARH	CHAKEISIANI ODSSP	14243	11 KV GYANA BHARATI	14243202	KABIRATNA SORA	1314DT303	100	MIXED	AMI	Yes	100%	20	0.06172822	0.018869	0.04285922	69.43%
1610	TPCODL	BBSR1	BED	RASULGARH	CHAKEISIANI ODSSP	14243	11 KV BHATAPADA	14243203	BHOTAPADA KHELA PADIA	1314DT262	250	MIXED	AMI	Yes	67%	76	0.10250312	0.054842	0.04766112	46.50%
1611	TPCODL	BBSR1	BED	RASULGARH	CHAKEISIANI ODSSP	14243	11 KV BHATAPADA	14243203	MEGHA BUILDERS	1314DT267	250	MIXED	AMI	Yes	100%	36	0.05970444	0.041506	0.01819844	30.48%
1612	TPCODL	BBSR1	BED	RASULGARH	CHAKEISIANI ODSSP	14243	11 KV BHATAPADA	14243203	RAJANARAYAN BEHERA	1314DT272	100	MIXED	AMI	Yes	100%	26	0.08842816	0.018264	0.07016416	79.35%
1613	TPCODL	BBSR1	BED	RASULGARH	CHAKEISIANI ODSSP	14243	11 KV BHATAPADA	14243203	HOTA	1314DT279	100	MIXED	AMI	Yes	100%	25	0.0565083	0.022935	0.0335733	59.41%
1614	TPCODL	BBSR1	BED	RASULGARH	CHAKEISIANI ODSSP	14243	11 KV BHATAPADA	14243203	RAY	1314DT286	100	MIXED	AMI	Yes	100%	29	0.03807122	0.025362	0.01270922	33.38%
1615	TPCODL	BBSR1	BED	RASULGARH	CHAKEISIANI ODSSP	14243	11 KV BHATAPADA	14243203	MEGHA BUILDERS-2 C	1314DT289	500	MIXED	AMI	Yes	100%	52	0.06272744	0.048872	0.01385544	22.09%
1616	TPCODL	BBSR1	BED	RASULGARH	CHAKEISIANI ODSSP	14243	11 KV BHATAPADA	14243203	OMM BIHAR -1	1314DT408	100	MIXED	AMI	Yes	100%	70	0.07094014	0.069222	0.00171814	2.42%
1617	TPCODL	BBSR1	BED	RASULGARH	KALPANA ODSSP	14245	11 KV KALPANA FLAT	14245201	SEKHAR FORCE CRISTAL APPARTMEN	1311DT003	250	MIXED	AMI	Yes	100%	13	0.01804396	0.017887	0.00015696	0.87%
1618	TPCODL	BBSR1	BED	RASULGARH	KALPANA ODSSP	14245	11 KV KALPANA FLAT	14245201	CANEL ROAD	1311DT008	250	MIXED	AMI	Yes	0%	51	0.10179254	0.077223	0.02456954	24.14%
1619	TPCODL	BBSR1	BED	RASULGARH	KALPANA ODSSP	14245	11 KV KALPANA FLAT	14245201	M/S BINAYAK SAISHREE	1311DT010	500	MIXED	AMI	Yes	100%	67	0.07096824	0.058508	0.01246024	17.56%
1620	TPCODL	BBSR1	BED	RASULGARH	KALPANA ODSSP	14245	11 KV KALPANA FLAT	14245201	BARAGADA CANEL ROAD RAPDRP RA	1311DT011	250	MIXED	AMI	Yes	0%	74	0.14140805	0.112771	0.02863705	20.25%
1621	TPCODL	BBSR1	BED	RASULGARH	KALPANA ODSSP	14245	11 KV KALPANA FLAT	14245201	RAMESH CH. MEHENA SUBSTATION	1311DT014	100	MIXED	AMI	Yes	33%	53	0.06981702	0.058881	0.01093602	15.66%
1622	TPCODL	BBSR1	BED	RASULGARH	KALPANA ODSSP	14245	11 KV KALPANA FLAT	14245201	PATITAPABAN 2	1311DT025	500	MIXED	AMI	Yes	100%	117	0.39430496	0.177974	0.21633096	54.86%
1623	TPCODL	BBSR1	BED	RASULGARH	KALPANA ODSSP	14245	11 KV CUTTACK ROAD	14245202	JB ASSETS PVT. LTD	1311DT033	250	MIXED	AMI	Yes	100%	12	0.02590648	0.018231	0.00767548	29.63%
1624	TPCODL	BBSR1	BED	RASULGARH	KALPANA ODSSP	14245	11 KV CUTTACK ROAD	14245202	BISWANATH NAGAR	1311DT034	250	MIXED	AMI	Yes	100%	86	0.2269288	0.123827	0.1031018	45.43%
1625	TPCODL	BBSR1	BED	RASULGARH	KALPANA ODSSP	14245	11 KV CUTTACK ROAD	14245202	BISWANATH NAGAR RAPDRP	1311DT039	100	MIXED	AMI	Yes	100%	54	0.09255274	0.080535	0.01201774	12.98%
1626	TPCODL	BBSR1	BED	RASULGARH	KALPANA ODSSP	14245	11 KV CUTTACK ROAD	14245202	SABARSAHI NEAR TARINI TEMPLE	1311DT047	500	MIXED	AMI	Yes	100%	144	0.25937976	0.147004	0.11237576	43.32%
1627	TPCODL	BBSR1	BED	RASULGARH	LAXMISAGAR	14020	11 KV LAXMISAGAR UG	14020201	ADITYA VIP ENCLAVE	1313DT018	100	MIXED	AMI	Yes	100%	34	0.06565864	0.05497	0.01068864	16.28%
1628	TPCODL	BBSR1	BED	RASULGARH	LAXMISAGAR	14020	11 KV LAXMISAGAR UG	14020201	JAGANNATH AVENUE	1313DT051	500	MIXED	AMI	Yes	100%	59	0.09607776	0.062925	0.03315276	34.51%
1629	TPCODL	BBSR1	BED	RASULGARH	LAXMISAGAR	14020	11 KV LAXMISAGAR UG	14020201	SAI VIHAR-1	1313DT063	100	MIXED	AMI	Yes	100%	77	0.11405746	0.095141	0.01891646	16.59%
1630	TPCODL	BBSR1	BED	RASULGARH	LAXMISAGAR	14020	11 KV LAXMISAGAR UG	14020201	BHAGABATI ENCLAVE	1313DT065	100	MIXED	AMI	Yes	100%	9	0.01319602	0.009179	0.00401702	30.44%
1631	TPCODL	BBSR1	BED	RASULGARH	LAXMISAGAR	14020	11 KV KALPANA-1	14020202	BHAGWAN TOWER CTC ROAD	1312DT051	250	MIXED	AMI	Yes	100%	62	0.09315168	0.048143	0.04500868	48.32%
1632	TPCODL	BBSR1	BED	RASULGARH	LAXMISAGAR	14020	11 KV KALPANA-1	14020202	NEAR ASHTA VINAYAK APPARTMENT	1312DT067	100	MIXED	AMI	Yes	100%	18	0.06751759	0.01894	0.04857759	71.95%
1633	TPCODL	BBSR1	BED	RASULGARH	LAXMISAGAR	14020	11 KV KALPANA-1	14020202	IN FRONT OF MEENAKSHI HEALTH AII	1312DT070	200	MIXED	AMI	Yes	100%	28	0.0856924	0.024897	0.0607954	70.95%
1634	TPCODL	BBSR1	BED	RASULGARH	LAXMISAGAR	14020	11 KV JHARAPADA UG	14020203	BACK SIDE HIGH SCHOOL	1312DT104	500	MIXED	AMI	Yes	100%	145	0.22240496	0.161553	0.06085196	27.36%
1635	TPCODL	BBSR1	BED	RASULGARH	LAXMISAGAR	14020	11 KV JHARAPADA UG	14020203	SM RESIDENCY	1312DT143	100	MIXED	AMI	Yes	100%	14	0.01483978	0.009852	0.00498778	33.61%
1636	TPCODL	BBSR1	BED	RASULGARH	LAXMISAGAR	14020	11 KV JHARAPADA UG	14020203	PRABHU KINJA APPATMENT	1312DT147	100	MIXED	AMI	Yes	0%	17	0.01915484	0.013247	0.00590784	30.84%
1637	TPCODL	BBSR1	BED	RASULGARH	LAXMISAGAR	14020	11 KV JHARAPADA UG	14020203	MAHABIR ENCLAVE-II	1312DT149	100	MIXED	AMI	Yes	100%	19	0.0249284	0.018577	0.0063514	25.48%
1638	TPCODL	BBSR1	BED	RASULGARH	LAXMISAGAR	14020	11 KV JHARAPADA UG	14020203	S VIHARI-III	1312DT150	500	MIXED	AMI	Yes	100%	191	0.35160344	0.265396	0.08620744	24.52%
1639	TPCODL	BBSR1	BED	RASULGARH	LAXMISAGAR	14020	11 KV JHARAPADA UG	14020203	MAHABIR ENCLAVE-I	1312DT151	100	MIXED	AMI	Yes	100%	21	0.02750822	0.018111	0.00939722	34.16%
1640	TPCODL	BBSR1	BED	RASULGARH	LAXMISAGAR	14020	11 KV JHARAPADA UG	14020203	R K HOME	1312DT155	250	MIXED	AMI	Yes	100%	28	0.04053032	0.033116	0.00741432	18.29%
1641	TPCODL	BBSR1	BED	RASULGARH	LAXMISAGAR	14020	11 KV JHARAPADA UG	14020203	CANAL ROAD(L&T)	1312DT162	100	MIXED	AMI	Yes	67%	47	0.07901957	0.061984	0.01703557	21.56%
1642	TPCODL	BBSR1	BED	RASULGARH	LAXMISAGAR	14020	11 KV JHARAPADA UG	14020203	LAXMINARAYANSAHI	1312DT163	250	MIXED	AMI	Yes	100%	96	0.23906044	0.149461	0.08959944	37.48%
1643	TPCODL	BBSR1	BED	RASULGARH	LAXMISAGAR	14020	11 KV JHARAPADA UG	14020203	M/S SANTOSHI REAL ESTATE	1312DT415	100	MIXED	AMI	Yes	100%	6	0.0020027	0.001042	0.0009607	47.97%
1644	TPCODL	BBSR1	BED	RASULGARH	LAXMISAGAR	14020	11 KV BOMIKHAL	14020204	IN FRONT OF GOOD WILL RESIDENCY	1313DT112	500	MIXED	AMI	Yes	100%	43	0.07814648	0.072908	0.00523848	6.70%
1645	TPCODL	BBSR1	BED	RASULGARH	LAXMISAGAR	14020	11 KV BOMIKHAL	14020204	BALAJI COMPLEX	1313DT428	500	MIXED	AMI	Yes	100%	56	0.12425336	0.053486	0.07076736	56.95%
1646	TPCODL	BBSR1	BED	RASULGARH	LAXMISAGAR	14020	11 KV KALPANA-2	14020205	INFRONT OF ROYAL OAK	1312DT010	250	MIXED	AMI	Yes	100%	22	0.047991	0.040274	0.007717	16.08%
1647	TPCODL	BBSR1	BED	RASULGARH	LAXMISAGAR	14020	11 KV KALPANA-2	14020205	INFRONT OF METRO ENCLAVE	1312DT011	250	MIXED	AMI	Yes	100%	246	0.18118828	0.154566	0.02662228	14.69%
1648	TPCODL	BBSR1	BED	RASULGARH	LAXMISAGAR	14020	11 KV KALPANA-2	14020205	EB-308	1312DT108	250	MIXED	AMI	Yes	100%	148	0.1964234	0.1542	0.0422234	21.50%
1649	TPCODL	BBSR1	BED	RASULGARH	LAXMISAGAR	14020	11 KV KALPANA-2	14020205	EB-308	1312DT109	100	MIXED	AMI	Yes	100%	34	0.03985512	0.02706	0.01279512	32.10%
1650	TPCODL	BBSR1	BED	RASULGARH	LAXMISAGAR	14020	11 KV KALPANA-2	14020205	MIG COLONY (L&T)	1312DT115	250	MIXED	AMI	Yes	100%	178	0.27290702	0.155243	0.11766402	43.12%
1651	TPCODL	BBSR1	BED	RASULGARH	LAXMISAGAR	14020	11 KV KALPANA-2	14020205	BSVY UPPER SAHI	1312DT116	100	MIXED	AMI	Yes	100%	36	0.06720144	0.057622	0.00957944	14.25%
1652	TPCODL	BBSR1	BED	RASULGARH	LAXMISAGAR	14020	11 KV KALPANA-2	14020205	MAHILA SAMITI	1312DT118	500	MIXED	AMI	Yes	100%	174	0.25350904	0.186163	0.06734604	26.57%
1653	TPCODL	BBSR1	BED	RASULGARH	LAXMISAGAR	14020	11 KV KALPANA-2	14020205	BSNL	1312DT119	100	MIXED	AMI	Yes	100%	20	0.0756008	0.020413	0.0551878	73.00%
1654	TPCODL	BBSR1	BED	RASULGARH	LAXMISAGAR	14020	11 KV KALPANA-2	14020205	EMRALAD	1312DT124	500	MIXED	AMI	Yes	100%	48	0.06711112	0.04668	0.02043112	30.44%
1655	TPCODL	BBSR1	BED	RASULGARH	LAXMISAGAR	14020	11 KV KALPANA-2	14020205	SARALANAGAR	1312DT129	100	MIXED	AMI	Yes	100%	45	0.10102564	0.062816	0.03820964	37.82%
1656	TPCODL	BBSR1	BED	RASULGARH	LAXMISAGAR	14020	11 KV KALPANA-2	14020205	UPER SAHI	1312DT131	100	MIXED	AMI	Yes	100%	48	0.0971317	0.062006	0.0351257	36.16%
1657	TPCODL	BBSR1	BED	RASULGARH	LAXMISAGAR	14020	11 KV KALPANA-2	14020205	CHOUDHRY COLONY	1312DT133	500	MIXED	AMI	Yes	100%	135	0.44782412	0.193737	0.25408712	56.74%
1658	TPCODL	BBSR1	BED	RASULGARH	LAXMISAGAR	14020	11 KV KALPANA-2	14020205	KALPANA BHOL	1312DT136	100	MIXED	AMI	Yes	100%	7	0.00611798	0.004597	0.00152098	24.86%
1659	TPCODL	BBSR1	BED	RASULGARH	LAXMISAGAR	14020	11 KV KALPANA-2	14020205	SRI KRUSHNA CHANDRA SAGARSREE	1312DT178	250	MIXED	AMI	Yes	100%	14	0.03662284	0.013047	0.02357584	64.37%
1660	TPCODL	BBSR1	BED	RASULGARH	LAXMISAGAR	14020	11 KV RMU-5	14020206	BAISHNAV VIHAR WEST	1313DT397	500	MIXED	AMI	Yes	100%	19	0.07582076	0.018066	0.05775476	76.17%
1661	TPCODL	BBSR1	BED	RASULGARH	LAXMISAGAR	14020	11 KV RMU-6A	14020207	NILACHAKRA APARTMENT 2	1311DT102	100	MIXED	AMI	Yes	0%	12	0.03569258	0.017503	0.01818958	50.96%
1662	TPCODL	BBSR1	BED	RASULGARH	LAXMISAGAR	14020	11 KV RMU-6A	14020207	NILACHAKRA APARTMENT 5	1311DT105	250	MIXED	AMI	Yes	0%	45	0.11173464	0.04322	0.06851464	61.32%
1663	TPCODL	BBSR1	BED	RASULGARH	LAXMISAGAR	14020	11 KV RMU-6A	14020207	CHINTA MONI GOVT GIRLS SCHOOL	1311DT112	250	MIXED	AMI	Yes	100%	208	0.28949168	0.254686	0.03480568	12.02%
1664	TPCODL	BBSR1	BED	RASULGARH	LAXMISAGAR	14020	11 KV RMU-6A	14020207	VISHVANATH DHAM	1311DT113	250	MIXED	AMI	Yes	0%	7	0.01578564	0.015644	0.00014164	0.90%
1665	TPCODL	BBSR1	BED	RASULGARH	LAXMISAGAR	14020	11 KV RMU-6A	14020207	METRO COTTAGE	1311DT147	250	MIXED	AMI	Yes	100%	37	0.08465236	0.062527	0.02212536	26.14%
1666	TPCODL	BBSR1	BED	RASULGARH	LAXMISAGAR	14020	11 KV RMU-6A	14020207	SHANU HAMLET APPT.	1311DT182	100	MIXED	AMI	Yes	0%	15	0.01765028	0.012775	0.00487528	27.62%
1667	TPCODL	BBSR1	BED	RASULGARH	LAXMISAGAR	14020	11 KV RMU-6A	14020207	KHUSHI UPAHAAR	1311DT183	150	MIXED	AMI	Yes	100%	19	0.01936728	0.017898	0.00146928	7.59%
1668	TPCODL	BBSR1	BED	RASULGARH	LAXMISAGAR	14020	11 KV RMU-6A	14020207	MANORAMA APPARTMENT 1	1312DT022	250	MIXED	AMI	Yes	100%	28	0.0672074	0.03056	0.0366474	54.53%
1669	TPCODL	BBSR1	BED	RASULGARH	LAXMISAGAR	14020	11 KV RMU-6A	14020207	MANORAMA APPARTMENT 2	1312DT023	250	MIXED	AMI	Yes	100%	39	0.0391098	0.022529	0.0165808	42.40%
1670	TPCODL	BBSR1	BED	RASULGARH	LAXMISAGAR	14020	11 KV RMU-15	14020208	PLOT NO 12 BUDHESWARI	1312DT075	200	MIXED	AMI	Yes	100%	142	0.18855168	0.150851	0.03770068	19.99%
1671	TPCODL	BBSR1	BED	RASULGARH	LAXMISAGAR	14020	11 KV RMU-15	14020208	PLOT NO 12 BUDHESWARI	1312DT076	500	MIXED	AMI	Yes	100%	79	0.1818052	0.080447	0.1013582	55.75%
1672	TPCODL	BBSR1	BED	RASULGARH	LAXMISAGAR	14020	11 KV RMU-15	14020208	THE IMPERIAL	1312DT078	250	MIXED	AMI	Yes	100%	22	0.03916236	0.038144	0.00101836	2.60%
1673	TPCODL	BBSR1	BED	RASULGARH	LAXMISAGAR	14020	11 KV RMU-16	14020209	APARJITA APARTMENT	1311DT072	100	MIXED	AMI	Yes	0%	12	0.01919724	0.019115	8.224E-05	0.43%
1674	TPCODL	BBSR1	BED	RASULGARH	LAXMISAGAR	14020	11 KV RMU-16	14020209	RAPDRP BUDHANAGAR BASTI	1311DT073	100	MIXED	AMI	Yes	0%	100	0.11620556	0.086688	0.02951756	25.40%
1675	TPCODL	BBSR1	BED	RASULGARH	LAXMISAGAR	14020	11 KV RMU-16	14020209	KUSUM PALACE	1311DT075	100	MIXED	AMI	Yes	100%	13	0.02252676	0.014718	0.00780876	34.66%
1676	TPCODL	BBSR1	BED	RASULGARH	LAXMISAGAR	14020	11 KV RMU-16	14020209	MUCHI SAHI BASTI	1311DT077	100	MIXED	AMI	Yes	0%	137	0.13729554	0.095934	0.04136154	30.13%
1677	TPCODL	BBSR1	BED	RASULGARH	LAXMISAGAR	14020	11 KV RMU-16	14020209	RIDDHI SIDDHI ENCLAVE	1311DT150	500	MIXED	AMI	Yes	100%	45	0.08122496	0.065329	0.01589596	19.57%
1678	TPCODL	BBSR1	BED	RASULGARH	LAXMISAGAR	14020	11 KV RMU-16	14020209	RASHMI ENCLAVE	1311DT160	100	MIXED	AMI	Yes	67%	23	0.03747002	0.020858	0.01661202	44.33%

Sl. No.	Zone Name	Circle name	Division name	Name of the Sub-division	Name of the Sub-station	Substation Code	Name of the 11 kV Feeder	Feeder Code	Name of the Location where DT situated	DT code	DT Capacity (kVA)	Predominant consumer type of DT (Domestic/Industrial/Agriculture/Mixed)	Type of metering AMR/AMI/ Communicable/Conventional metered/Unmetered	Status of Meter-whether Functional (Yes/No)	% of data received automatically (if AMR/AMI)	No. of Connected Consumers	Input Energy (MU) (A)	Billed Energy (MU) (B)	Loss (MU) (A-B)	% DT Loss (A-B)/A
1679	TPCODL	BBSR1	BED	RASULGARH	LAXMISAGAR	14020	11 KV RMU-16	14020209	RASHMI VIHAR	1311DT161	100	MIXED	AMI	Yes	0%	27	0.02220812	0.018093	0.00411512	18.53%
1680	TPCODL	BBSR1	BED	RASULGARH	LAXMISAGAR	14020	11 KV RMU-16	14020209	FISHERY LANE DHABATATHA	1311DT167	250	MIXED	AMI	Yes	100%	92	0.24623208	0.156156	0.09007608	36.58%
1681	TPCODL	BBSR1	BED	RASULGARH	LAXMISAGAR	14020	11 KV RMU-16	14020209	FISHERY LANE NEAR GOJABAYANI TE	1311DT174	250	MIXED	AMI	Yes	0%	107	0.32753464	0.143146	0.18438864	56.30%
1682	TPCODL	BBSR1	BED	RASULGARH	LAXMISAGAR	14020	11 KV RMU-6	14020210	JAYDURGA NAGAR NEAR PLOT NO-81	1313DT356	500	MIXED	AMI	Yes	100%	48	0.14588864	0.114225	0.03166364	21.70%
1683	TPCODL	BBSR1	BED	RASULGARH	LAXMISAGAR	14020	11 KV RMU-6	14020210	JAGANNATH BASANTI NIWAS APARTI	1313DT359	250	MIXED	AMI	Yes	100%	15	0.0267986	0.024155	0.0026436	9.86%
1684	TPCODL	BBSR1	BED	RASULGARH	LAXMISAGAR	14020	11 KV RMU-6	14020210	MAA BASUDHA HOME-02	1313DT364	100	MIXED	AMI	Yes	0%	11	0.0144092	0.011967	0.0024422	16.95%
1685	TPCODL	BBSR1	BED	RASULGARH	LAXMISAGAR	14020	11 KV RMU-6	14020210	MADHAV VIHAR APARTMENT	1313DT368	100	MIXED	AMI	Yes	100%	35	0.04384368	0.0318	0.01204368	27.47%
1686	TPCODL	BBSR1	BED	RASULGARH	LAXMISAGAR	14020	11 KV RMU-6	14020210	JAYDURGA NAGAR MASHANI	1313DT371	250	MIXED	AMI	Yes	100%	124	0.18072848	0.162524	0.01820448	10.07%
1687	TPCODL	BBSR1	BED	RASULGARH	LAXMISAGAR	14020	11 KV RMU-6	14020210	JAYDURGA NAGAR NEAR MASHANI(C	1313DT372	200	MIXED	AMI	Yes	100%	84	0.16437932	0.160944	0.00343532	2.09%
1688	TPCODL	BBSR1	BED	RASULGARH	LAXMISAGAR	14020	11 KV RMU-6	14020210	NEAR RASHMI HOUSE,BACK SIDE OF	1313DT373	250	MIXED	AMI	Yes	100%	69	0.13403344	0.089825	0.04420844	32.98%
1689	TPCODL	BBSR1	BED	RASULGARH	LAXMISAGAR	14020	11 KV RMU-6	14020210	JAYDURGA NAGAR PARK	1313DT376	250	MIXED	AMI	Yes	100%	81	0.24871592	0.111592	0.13712392	55.13%
1690	TPCODL	BBSR1	BED	RASULGARH	LAXMISAGAR	14020	11 KV RMU-6	14020210	JAYDURGA NAGAR SOUTH	1313DT377	100	MIXED	AMI	Yes	100%	55	0.120684	0.109155	0.011529	9.55%
1691	TPCODL	BBSR1	BED	RASULGARH	LAXMISAGAR	14020	11 KV RMU-6	14020210	MAA BASUDHA HOME-01 APARTMEI	1313DT378	100	MIXED	AMI	Yes	100%	9	0.01044286	0.008675	0.00176786	16.93%
1692	TPCODL	BBSR1	BED	RASULGARH	LAXMISAGAR	14020	11 KV RMU-6	14020210	GLIMSES PALACE APARTMENT	1313DT379	250	MIXED	AMI	Yes	100%	57	0.08098476	0.047972	0.03301276	40.76%
1693	TPCODL	BBSR1	BED	RASULGARH	LAXMISAGAR	14020	11 KV RMU-6	14020210	NORTH GAYATRI NAGAR	1313DT383	100	MIXED	AMI	Yes	100%	37	0.0768173	0.060398	0.0164193	21.37%
1694	TPCODL	BBSR1	BED	RASULGARH	LAXMISAGAR	14020	11 KV RMU-6	14020210	GAYATRI NAGAR APARTMENT	1313DT385	250	MIXED	AMI	Yes	0%	59	0.09711688	0.079674	0.01744288	17.96%
1695	TPCODL	BBSR1	BED	RASULGARH	LAXMISAGAR	14020	11 KV RMU-6	14020210	PURNA CHANDRA PLAZA	1313DT429	250	MIXED	AMI	Yes	100%	17	0.07308704	0.01672	0.05636704	77.12%
1696	TPCODL	BBSR1	BED	RASULGARH	MANCHESWAR	14022	11 KV MANCHESWAR-1	14022201	COLD FORZZ	1314DT009	500	MIXED	AMI	Yes	100%	156	0.37885664	0.224391	0.15446564	40.77%
1697	TPCODL	BBSR1	BED	RASULGARH	MANCHESWAR	14022	11 KV MANCHESWAR-1	14022201	MAA DURGA RUBBER	1314DT039	500	MIXED	AMI	Yes	0%	59	0.33073608	0.289747	0.04098908	12.39%
1698	TPCODL	BBSR1	BED	RASULGARH	MANCHESWAR	14022	11 KV MANCHESWAR-1	14022201	SAMAYA PRESS	1314DT044	250	MIXED	AMI	Yes	100%	7	0.0325672	0.022304	0.0102632	31.51%
1699	TPCODL	BBSR1	BED	RASULGARH	MANCHESWAR	14022	11 KV MANCHESWAR-2	14022202	SHIBALAYA	1314DT048	500	MIXED	AMI	Yes	100%	184	0.32843616	0.202837	0.12559916	38.24%
1700	TPCODL	BBSR1	BED	RASULGARH	MANCHESWAR	14022	11 KV MANCHESWAR-2	14022202	NICO INDIA	1314DT062	500	MIXED	AMI	Yes	100%	45	0.20161296	0.196556	0.00505696	2.51%
1701	TPCODL	BBSR1	BED	RASULGARH	MANCHESWAR	14022	11 KV MANCHESWAR-2	14022202	PHED	1314DT101	250	MIXED	AMI	Yes	0%	9	0.07147628	0.069946	0.00153028	2.14%
1702	TPCODL	BBSR1	BED	RASULGARH	MANCHESWAR	14022	11 KV MANCHESWAR-2	14022202	TELERINA	1314DT106	500	MIXED	AMI	Yes	100%	27	0.14535656	0.099067	0.04628956	31.85%
1703	TPCODL	BBSR1	BED	RASULGARH	MANCHESWAR	14022	11 KV MANCHESWAR-2	14022202	HI-TECH-2	1314DT112	100	MIXED	AMI	Yes	100%	122	0.11803504	0.06433	0.05370504	45.50%
1704	TPCODL	BBSR1	BED	RASULGARH	MANCHESWAR	14022	11 KV MANCHESWAR-2	14022202	HI-TECH-1	1314DT114	500	MIXED	AMI	Yes	100%	14	0.08316816	0.064571	0.01859716	22.36%
1705	TPCODL	BBSR1	BED	RASULGARH	MANCHESWAR	14022	11 KV MANCHESWAR-3	14022203	CHAKEISHIANI CLUB HOUSE	1314DT127	500	MIXED	AMI	Yes	100%	57	0.27296368	0.067478	0.20548568	75.28%
1706	TPCODL	BBSR1	BED	RASULGARH	MANCHESWAR	14022	11 KV MANCHESWAR-3	14022203	CHAKEISHIANI CLUB HOUSE -2	1314DT129	250	MIXED	AMI	Yes	100%	55	0.09612072	0.053576	0.04254472	44.26%
1707	TPCODL	BBSR1	BED	RASULGARH	MANCHESWAR	14022	11 KV MANCHESWAR-3	14022203	SRIRAM NAGAR	1314DT138	100	MIXED	AMI	Yes	100%	159	0.09559674	0.093862	0.00173474	1.81%
1708	TPCODL	BBSR1	BED	RASULGARH	MANCHESWAR	14022	11 KV MANCHESWAR-3	14022203	SHIV MANDIR -3	1314DT143	500	MIXED	AMI	Yes	100%	87	0.16708012	0.128001	0.03907912	23.39%
1709	TPCODL	BBSR1	BED	RASULGARH	MANCHESWAR	14022	11 KV MANCHESWAR-3	14022203	SRIRAM NAGAR CHHAKA -1	1314DT144	250	MIXED	AMI	Yes	100%	276	0.25846684	0.208792	0.04967484	19.22%
1710	TPCODL	BBSR1	BED	RASULGARH	MANCHESWAR	14022	11 KV MANCHESWAR-3	14022203	SRIRAM NAGAR -2	1314DT149	100	MIXED	AMI	Yes	100%	201	0.13388224	0.11522	0.01866224	13.94%
1711	TPCODL	BBSR1	BED	RASULGARH	MANCHESWAR	14022	11 KV MANCHESWAR-3	14022203	GANESH MOHANTY	1314DT154	200	MIXED	AMI	Yes	0%	198	0.2228572	0.209176	0.0136812	6.14%
1712	TPCODL	BBSR1	BED	RASULGARH	MANCHESWAR	14022	11 KV MANCHESWAR-3	14022203	SAMAYA GADIYA - 1	1314DT158	500	MIXED	AMI	Yes	100%	308	0.4461888	0.376439	0.0697498	15.63%
1713	TPCODL	BBSR1	BED	RASULGARH	MANCHESWAR	14022	11 KV MANCHESWAR-3	14022203	COAL FACTORY	1314DT160	100	MIXED	AMI	Yes	100%	47	0.0867952	0.069984	0.0168112	19.37%
1714	TPCODL	BBSR1	BED	RASULGARH	MANCHESWAR	14022	11 KV MANCHESWAR-3	14022203	RAO S/S -2	1314DT163	500	MIXED	AMI	Yes	100%	188	0.30574256	0.218256	0.08748656	28.61%
1715	TPCODL	BBSR1	BED	RASULGARH	MANCHESWAR	14022	11 KV MANCHESWAR-3	14022203	MOHANTY	1314DT176	200	MIXED	AMI	Yes	100%	136	0.26095304	0.181252	0.07970104	30.54%
1716	TPCODL	BBSR1	BED	RASULGARH	MANCHESWAR	14022	11 KV MANCHESWAR-3	14022203	BEHERA SAHI	1314DT178	250	MIXED	AMI	Yes	0%	90	0.15919604	0.111541	0.04765504	29.93%
1717	TPCODL	BBSR1	BED	RASULGARH	MANCHESWAR	14022	11 KV MANCHESWAR-3	14022203	SAMAYA GADIA CLUB	1314DT181	500	MIXED	AMI	Yes	100%	236	0.34516976	0.282373	0.06279676	18.19%
1718	TPCODL	BBSR1	BED	RASULGARH	MANCHESWAR	14022	11 KV VSS NAGAR	14022204	OMCAD	1314DT208	500	MIXED	AMI	Yes	100%	27	0.22113456	0.101088	0.12004656	54.29%
1719	TPCODL	BBSR1	BED	RASULGARH	MANCHESWAR	14022	11 KV VSS NAGAR	14022204	IDCO COLONY -1	1314DT225	250	MIXED	AMI	Yes	100%	38	0.05468212	0.032049	0.02263312	41.39%
1720	TPCODL	BBSR1	BED	RASULGARH	MANCHESWAR	14022	11 KV VSS NAGAR	14022204	IDCO COLONY - 2 PHED	1314DT227	250	MIXED	AMI	Yes	0%	45	0.05111752	0.040737	0.01038052	20.31%
1721	TPCODL	BBSR1	BED	RASULGARH	MANCHESWAR	14022	11 KV VSS NAGAR	14022204	KESAB CERAMIC	1314DT232	250	MIXED	AMI	Yes	0%	6	0.0833708	0.053063	0.0303078	36.35%
1722	TPCODL	BBSR1	BED	RASULGARH	MANCHESWAR	14022	11 KV VSS NAGAR	14022204	NEAR ALFA	1314DT237	500	MIXED	AMI	Yes	100%	130	0.17971192	0.138602	0.04110992	22.88%
1723	TPCODL	BBSR1	BED	RASULGARH	MANCHESWAR	14022	11 KV VSS NAGAR	14022204	ANNAPURNA CHEMICAL	1314DT247	250	MIXED	AMI	Yes	100%	26	0.13153816	0.129379	0.00215916	1.64%
1724	TPCODL	BBSR1	BED	RASULGARH	NAHARKANTA	14180	11 KV NAHARKANTA	14180201	GADA SAHI	1315DT109	500	MIXED	AMI	Yes	100%	303	0.24110736	0.238617	0.00249036	1.03%
1725	TPCODL	BBSR1	BED	RASULGARH	NAHARKANTA	14180	11 KV NAHARKANTA	14180201	BANIA SAHI	1315DT112	100	MIXED	AMI	Yes	0%	161	0.17330309	0.134005	0.03929809	22.68%
1726	TPCODL	BBSR1	BED	RASULGARH	NAHARKANTA	14180	11 KV NAHARKANTA	14180201	BEHERA SAHI	1315DT114	100	MIXED	AMI	Yes	100%	205	0.17943546	0.157522	0.02191346	12.21%
1727	TPCODL	BBSR1	BED	RASULGARH	NAHARKANTA	14180	11 KV NAHARKANTA	14180201	ROSHAN ELAGENT	1315DT118	250	MIXED	AMI	Yes	0%	53	0.03969384	0.035773	0.00392084	9.88%
1728	TPCODL	BBSR1	BED	RASULGARH	NAHARKANTA	14180	11 KV NAHARKANTA	14180201	SUREKHA NIBAS	1315DT122	500	MIXED	AMI	Yes	100%	51	0.05708896	0.03779	0.01929896	33.81%
1729	TPCODL	BBSR1	BED	RASULGARH	NAHARKANTA	14180	11 KV NAHARKANTA	14180201	SUREKHA NIBAS	1315DT123	500	MIXED	AMI	Yes	100%	23	0.05677416	0.023148	0.03362616	59.23%
1730	TPCODL	BBSR1	BED	RASULGARH	NAHARKANTA	14180	11 KV NAHARKANTA	14180201	MILENIUM 2	1315DT128	100	MIXED	AMI	Yes	100%	36	0.0639788	0.018909	0.0450698	70.44%
1731	TPCODL	BBSR1	BED	RASULGARH	NAHARKANTA	14180	11 KV NAHARKANTA	14180201	DHALIA GQDA	1315DT130	250	MIXED	AMI	Yes	100%	235	0.23078668	0.204964	0.02582268	11.19%
1732	TPCODL	BBSR1	BED	RASULGARH	NAHARKANTA	14180	11 KV NAHARKANTA	14180201	LAXMI PALACE	1315DT135	250	MIXED	AMI	Yes	0%	25	0.02058812	0.013574	0.00701412	34.07%
1733	TPCODL	BBSR1	BED	RASULGARH	NAHARKANTA	14180	11 KV NAHARKANTA	14180201	PATANA SAHI	1315DT137	250	MIXED	AMI	Yes	100%	140	0.1463652	0.102355	0.0440102	30.07%
1734	TPCODL	BBSR1	BED	RASULGARH	NAHARKANTA	14180	11 KV NAHARKANTA	14180201	ROYAL AVENUE	1315DT138	250	MIXED	AMI	Yes	0%	21	0.1192514	0.024367	0.0948844	79.57%
1735	TPCODL	BBSR1	BED	RASULGARH	NAHARKANTA	14180	11 KV NAHARKANTA	14180201	MUSLIM SAHI-2	1315DT140	100	MIXED	AMI	Yes	67%	19	0.02644872	0.020036	0.00641272	24.25%
1736	TPCODL	BBSR1	BED	RASULGARH	NAHARKANTA	14180	11 KV NAHARKANTA	14180201	MUSLIM SAHI 2	1315DT141	100	MIXED	AMI	Yes	0%	81	0.11836075	0.082996	0.03536475	29.88%
1737	TPCODL	BBSR1	BED	RASULGARH	NAHARKANTA	14180	11 KV NAHARKANTA	14180201	LAXMI RESIDENCY PHASE-3	1315DT836	500	MIXED	AMI	Yes	0%	52	0.05622056	0.050023	0.00619756	11.02%
1738	TPCODL	BBSR1	BED	RASULGARH	NAHARKANTA	14180	11 KV NAHARKANTA	14180201	LAXMI RESIDENCY PHASE-3	1315DT837	250	MIXED	AMI	Yes	0%	17	0.01684804	0.013031	0.00381704	22.66%
1739	TPCODL	BBSR1	BED	RASULGARH	NAHARKANTA	14180	11 KV NAHARKANTA	14180201	SWAGAT BIHAR	1315DT945	250	MIXED	AMI	Yes	100%	68	0.13479192	0.072691	0.06210092	46.07%
1740	TPCODL	BBSR1	BED	RASULGARH	NAHARKANTA	14180	11 KV BALIANTA	14180202	NEXA	1315DT313	500	MIXED	AMI	Yes	100%	195	0.3282328	0.219101	0.1091318	33.25%
1741	TPCODL	BBSR1	BED	RASULGARH	NAHARKANTA	14180	11 KV BALIANTA	14180202	HANPAL - 5	1315DT315	100	MIXED	AMI	Yes	100%	34	0.05354454	0.044885	0.00865954	16.17%
1742	TPCODL	BBSR1	BED	RASULGARH	NAHARKANTA	14180	11 KV BALIANTA	14180202	LILABATI 2	1315DT323	250	MIXED	AMI	Yes	100%	12	0.02119732	0.010791	0.01040632	49.09%
1743	TPCODL	BBSR1	BED	RASULGARH	NAHARKANTA	14180	11 KV BALIANTA	14180202	BHABANA RECIDENCY	1315DT326	250	MIXED	AMI	Yes	100%	13	0.020983	0.013545	0.007438	35.45%
1744	TPCODL	BBSR1	BED	RASULGARH	NAHARKANTA	14180	11 KV BALIANTA	14180202	KHUSI REALCON	1315DT328	500	MIXED	AMI	Yes	100%	34	0.05675488	0.040112	0.01664288	29.32%
1745	TPCODL	BBSR1	BED	RASULGARH	NAHARKANTA	14180	11 KV BALIANTA	14180202	SUNRISE SOROVER	1315DT330	500	MIXED	AMI	Yes	100%	51	0.04682312	0.046341	0.00048212	1.03%
1746	TPCODL	BBSR1	BED	RASULGARH	NAHARKANTA	14180	11 KV BALIANTA	14180202	USA ENCLAVE	1315DT331	100	MIXED	AMI	Yes	100%	21	0.02837952	0.023937	0.00444252	15.65%
1747	TPCODL	BBSR1	BED	RASULGARH	NAHARKANTA	14180	11 KV BALIANTA	14180202	BASANTA SAHOO	1315DT335	100	MIXED	AMI	Yes	100%	20	0.0150725	0.012628	0.0024445	16.22%
1748	TPCODL	BBSR1	BED	RASULGARH	NAHARKANTA	14180	11 KV BALIANTA	14180202	SAI PANCHHAKA	1315DT343	500	MIXED	AMI	Yes	67%	335	0.29609575	0.217027	0.07906875	26.70%
1749	TPCODL	BBSR1	BED	RASULGARH	NAHARKANTA	14180	11 KV BALIANTA	14180202	ANDILO KHA	1315DT344	100	MIXED	AMI	Yes	100%	87	0.09186181	0.054043	0.03781881	41.17%
1750	TPCODL	BBSR1	BED	RASULGARH	NAHARKANTA	14180	11 KV BALIANTA	14180202	MAHIMA TOWER	1315DT347	500	MIXED	AMI	Yes	0%	83	0.07085136	0.065373	0.00547836	7.73%
1751	TPCODL	BBSR1	BED	RASULGARH	NAHARKANTA	14180	11 KV BALIANTA	14180202	MRUTUNJAYA VIHAR	1315DT348	100	MIXED	AMI	Yes	33%	8	0.01011618	0.009459	0.00065718	6.50%

Sl. No.	Zone Name	Circle name	Division name	Name of the Sub-division	Name of the Sub-station	Substation Code	Name of the 11 kV Feeder	Feeder Code	Name of the Location where DT situated	DT code	DT Capacity (kVA)	Predominant consumer type of DT (Domestic/Industrial/Agriculture/Mixed)	Type of metering AMR/AMI/ Communicable/Conventional metered/Unmetered	Status of Meter- whether Functional (Yes/No)	% of data received automatically (if AMR/AMI)	No. of Connected Consumers	Input Energy (MU) (A)	Billed Energy (MU) (B)	Loss (MU) (A-B)	% DT Loss (A-B)/A
1752	TPCODL	BBSR1	BED	RASULGARH	NAHARKANTA	14180	11 KV BALIANTA	14180202	TALAGADA	1315DT354	250	MIXED	AMI	Yes	100%	200	0.2296898	0.127743	0.1019468	44.38%
1753	TPCODL	BBSR1	BED	RASULGARH	NAHARKANTA	14180	11 KV BALIANTA	14180202	DIVYALOK2	1315DT359	250	MIXED	AMI	Yes	100%	14	0.02991048	0.015897	0.01401348	46.85%
1754	TPCODL	BBSR1	BED	RASULGARH	NAHARKANTA	14180	11 KV BALIANTA	14180202	SAI MAHAVEER	1315DT363	63	MIXED	AMI	Yes	0%	13	0.06011	0.015147	0.044963	74.80%
1755	TPCODL	BBSR1	BED	RASULGARH	NAHARKANTA	14180	11 KV BALIANTA	14180202	MANCHANATH VILLA	1315DT364	100	MIXED	AMI	Yes	67%	22	0.01804804	0.01478	0.00326804	18.11%
1756	TPCODL	BBSR1	BED	RASULGARH	NAHARKANTA	14180	11 KV BALIANTA	14180202	SAI HOMES	1315DT376	500	MIXED	AMI	Yes	100%	24	0.0503836	0.024572	0.0258116	51.23%
1757	TPCODL	BBSR1	BED	RASULGARH	NAHARKANTA	14180	11 KV BALIANTA	14180202	BENUPUR GADA SAHI	1315DT383	63	MIXED	AMI	Yes	67%	42	0.06536916	0.038518	0.02685116	41.08%
1758	TPCODL	BBSR1	BED	RASULGARH	NAHARKANTA	14180	11 KV BALIANTA	14180202	NUA POKHARI BENUPUR	1315DT385	100	MIXED	AMI	Yes	67%	89	0.11646184	0.04859668	0.06786516	58.27%
1759	TPCODL	BBSR1	BED	RASULGARH	NAHARKANTA	14180	11 KV BALIANTA	14180202	SANTI VATIKA	1315DT387	250	MIXED	AMI	Yes	100%	17	0.02241732	0.013082	0.00933532	41.64%
1760	TPCODL	BBSR1	BED	RASULGARH	NAHARKANTA	14180	11 KV BALIANTA	14180202	BENUPUR RAMALILA CHHAKA -2	1315DT393	100	MIXED	AMI	Yes	0%	75	0.10454496	0.043208	0.06133696	58.67%
1761	TPCODL	BBSR1	BED	RASULGARH	NAHARKANTA	14180	11 KV BALIANTA	14180202	BENUPUR GUDIA SAHI	1315DT398	100	MIXED	AMI	Yes	67%	79	0.06228574	0.030912	0.03137374	50.37%
1762	TPCODL	BBSR1	BED	RASULGARH	NAHARKANTA	14180	11 KV BALIANTA	14180202	BENUPUR PURUNA PATANA	1315DT399	100	MIXED	AMI	Yes	0%	67	0.0862722	0.033913	0.0523592	60.69%
1763	TPCODL	BBSR1	BED	RASULGARH	NAHARKANTA	14180	11 KV BALIANTA	14180202	BALIKANTHIA	1315DT403	100	MIXED	AMI	Yes	67%	121	0.09272236	0.075786	0.01693636	18.27%
1764	TPCODL	BBSR1	BED	RASULGARH	NAHARKANTA	14180	11 KV BALIANTA	14180202	BHUBANPUR1	1315DT408	250	MIXED	AMI	Yes	0%	94	0.08840447	0.059782	0.02862247	32.38%
1765	TPCODL	BBSR1	BED	RASULGARH	NAHARKANTA	14180	11 KV BALIANTA	14180202	BHUBANPUR - 2	1315DT409	100	MIXED	AMI	Yes	67%	139	0.1289345	0.095045	0.0338895	26.28%
1766	TPCODL	BBSR1	BED	RASULGARH	NAHARKANTA	14180	11 KV BALIANTA	14180202	BHUBANPUR SOBHAGYA 1	1315DT410	100	MIXED	AMI	Yes	0%	35	0.03842912	0.020532	0.01789712	46.57%
1767	TPCODL	BBSR1	BED	RASULGARH	NAHARKANTA	14180	11 KV BALIANTA	14180202	BHUBANPUR SOBHAGYA -2	1315DT411	100	MIXED	AMI	Yes	67%	42	0.02921056	0.013539	0.01567156	53.65%
1768	TPCODL	BBSR1	BED	RASULGARH	NAHARKANTA	14180	11 KV BALIANTA	14180202	SAKTI PARADISE	1315DT429	500	MIXED	AMI	Yes	100%	83	0.10421944	0.090276	0.01394344	13.38%
1769	TPCODL	BBSR1	BED	RASULGARH	NAHARKANTA	14180	11 KV BALIANTA	14180202	KHUSI REALCON	1315DT922	500	MIXED	AMI	Yes	100%	34	0.07614728	0.038334	0.03781328	49.66%
1770	TPCODL	BBSR1	BED	RASULGARH	NAHARKANTA	14180	11 KV BALIANTA	14180202	OMM SRI PRIDE	1315DT941	250	MIXED	AMI	Yes	0%	21	0.01804692	0.008246	0.00980092	54.31%
1771	TPCODL	BBSR1	BED	RASULGARH	NAHARKANTA	14180	11 KV ATALA	14180203	M/S OMM CONTECH (P) LTD	1315DT0C3	500	MIXED	AMI	Yes	100%	17	0.02518576	0.018712	0.00647376	25.70%
1772	TPCODL	BBSR1	BED	RASULGARH	NAHARKANTA	14180	11 KV ATALA	14180203	SIBA SHAKTINAGAR-2	1315DT148	250	MIXED	AMI	Yes	100%	199	0.25881551	0.183446	0.07536951	29.12%
1773	TPCODL	BBSR1	BED	RASULGARH	NAHARKANTA	14180	11 KV ATALA	14180203	SUREKHA REGENCY	1315DT153	500	MIXED	AMI	Yes	33%	64	0.05102451	0.040077	0.01094751	21.46%
1774	TPCODL	BBSR1	BED	RASULGARH	NAHARKANTA	14180	11 KV ATALA	14180203	ANANTA BALIA	1315DT166	100	MIXED	AMI	Yes	100%	20	0.0127757	0.01163	0.0011457	8.97%
1775	TPCODL	BBSR1	BED	RASULGARH	NAHARKANTA	14180	11 KV ATALA	14180203	RK TECH CREATION	1315DT167	25	MIXED	AMI	Yes	100%	27	0.03019177	0.026815	0.00337677	11.18%
1776	TPCODL	BBSR1	BED	RASULGARH	NAHARKANTA	14180	11 KV ATALA	14180203	M.M ENCLOVE BALIANTA,-2	1315DT171	500	MIXED	AMI	Yes	100%	23	0.0537068	0.019861	0.0338458	63.02%
1777	TPCODL	BBSR1	BED	RASULGARH	NAHARKANTA	14180	11 KV ATALA	14180203	SINGHAM NAGAR	1315DT183	250	MIXED	AMI	Yes	100%	38	0.03346884	0.025394	0.00807484	24.13%
1778	TPCODL	BBSR1	BED	RASULGARH	NAHARKANTA	14180	11 KV ATALA	14180203	PANCHAMUKHI OKUDU -1	1315DT197	500	MIXED	AMI	Yes	0%	7	0.03031552	0.007903	0.02241252	73.93%
1779	TPCODL	BBSR1	BED	RASULGARH	NAHARKANTA	14180	11 KV ATALA	14180203	PANCHAMUKHI BIHAR	1315DT205	250	MIXED	AMI	Yes	100%	41	0.04463392	0.026859	0.01777492	39.82%
1780	TPCODL	BBSR1	BED	RASULGARH	NAHARKANTA	14180	11 KV ATALA	14180203	PANCHAMUKHI GREEN-1	1315DT207	500	MIXED	AMI	Yes	100%	51	0.06417392	0.052379	0.01179492	18.38%
1781	TPCODL	BBSR1	BED	RASULGARH	NAHARKANTA	14180	11 KV ATALA	14180203	PANCHAMUKHI GREEN-2	1315DT208	500	MIXED	AMI	Yes	100%	71	0.0678004	0.053815	0.0139854	20.63%
1782	TPCODL	BBSR1	BED	RASULGARH	NAHARKANTA	14180	11 KV ATALA	14180203	PANCHAMUKHI GREEN-3	1315DT209	500	MIXED	AMI	Yes	100%	63	0.06472456	0.045375	0.01934956	29.90%
1783	TPCODL	BBSR1	BED	RASULGARH	NAHARKANTA	14180	11 KV ATALA	14180203	PUNAM ENCLAVE	1315DT211	250	MIXED	AMI	Yes	0%	27	0.03111232	0.016861	0.01425132	45.81%
1784	TPCODL	BBSR1	BED	RASULGARH	NAHARKANTA	14180	11 KV ATALA	14180203	EMERALD VILLAS	1315DT217	100	MIXED	AMI	Yes	100%	15	0.01445724	0.010533	0.00392424	27.14%
1785	TPCODL	BBSR1	BED	RASULGARH	NAHARKANTA	14180	11 KV ATALA	14180203	EMENANCE CORAL -2	1315DT220	500	MIXED	AMI	Yes	100%	104	0.0885816	0.085739	0.0028426	3.21%
1786	TPCODL	BBSR1	BED	RASULGARH	NAHARKANTA	14180	11 KV ATALA	14180203	J.B VALLAY	1315DT226	500	MIXED	AMI	Yes	100%	61	0.12179536	0.083002	0.03879336	31.85%
1787	TPCODL	BBSR1	BED	RASULGARH	NAHARKANTA	14180	11 KV ATALA	14180203	METRO SATELIGHT CITY PH-2/A	1315DT228	500	MIXED	AMI	Yes	100%	53	0.07884904	0.062965	0.01588404	20.14%
1788	TPCODL	BBSR1	BED	RASULGARH	NAHARKANTA	14180	11 KV ATALA	14180203	METRO SATELIGHT CITY PH-1/B	1315DT231	500	MIXED	AMI	Yes	100%	102	0.15067672	0.132833	0.01784372	11.84%
1789	TPCODL	BBSR1	BED	RASULGARH	NAHARKANTA	14180	11 KV ATALA	14180203	METRO SATELIGHT CITY PH-1/A	1315DT232	500	MIXED	AMI	Yes	100%	64	0.11376096	0.095162	0.01859896	16.35%
1790	TPCODL	BBSR1	BED	RASULGARH	NAHARKANTA	14180	11 KV ATALA	14180203	METRO SATELIGHT CITY PH-3/C	1315DT235	500	MIXED	AMI	Yes	100%	68	0.05687104	0.03801	0.01886104	33.16%
1791	TPCODL	BBSR1	BED	RASULGARH	NAHARKANTA	14180	11 KV ATALA	14180203	BHARAT VILLA	1315DT238	500	MIXED	AMI	Yes	100%	369	0.58594914	0.382748	0.20320114	34.68%
1792	TPCODL	BBSR1	BED	RASULGARH	NAHARKANTA	14180	11 KV ATALA	14180203	DUTTA TRAYA BUILDERS	1315DT243	250	MIXED	AMI	Yes	100%	9	0.02520788	0.011675	0.01353288	53.69%
1793	TPCODL	BBSR1	BED	RASULGARH	NAHARKANTA	14180	11 KV ATALA	14180203	NEAR KALPATARU ASHRAM	1315DT252	100	MIXED	AMI	Yes	0%	8	0.0158029	0.009957	0.0058459	36.99%
1794	TPCODL	BBSR1	BED	RASULGARH	NAHARKANTA	14180	11 KV ATALA	14180203	HEMKUND TOWER -2	1315DT256	250	MIXED	AMI	Yes	0%	10	0.03543952	0.013211	0.02222852	62.72%
1795	TPCODL	BBSR1	BED	RASULGARH	NAHARKANTA	14180	11 KV ATALA	14180203	PANCHAM STUDIO	1315DT265	100	MIXED	AMI	Yes	100%	82	0.15369112	0.084931	0.06876012	44.74%
1796	TPCODL	BBSR1	BED	RASULGARH	NAHARKANTA	14180	11 KV ATALA	14180203	METRO SATELITE CITY	1315DT864	250	MIXED	AMI	Yes	100%	11	0.0399734	0.008761	0.0312124	78.08%
1797	TPCODL	BBSR1	BED	RASULGARH	NAKHARA	14023	11 KV GOBINDPUR RE	14023201	MIDLAND HEIGHT	1315DT595	250	MIXED	AMI	Yes	100%	15	0.0342509	0.012301	0.0219499	64.09%
1798	TPCODL	BBSR1	BED	RASULGARH	NAKHARA	14023	11 KV GOBINDPUR RE	14023201	DAINA INFRA TULASI RESIDENCY	1315DT597	250	MIXED	AMI	Yes	0%	18	0.01866184	0.013834	0.00482784	25.87%
1799	TPCODL	BBSR1	BED	RASULGARH	NAKHARA	14023	11 KV GOBINDPUR RE	14023201	BRAHMA KUMARI ENCLAVE	1315DT598	250	MIXED	AMI	Yes	33%	17	0.02613284	0.009362	0.01677084	64.18%
1800	TPCODL	BBSR1	BED	RASULGARH	NAKHARA	14023	11 KV GOBINDPUR RE	14023201	ETHIES ANEX	1315DT603	100	MIXED	AMI	Yes	100%	11	0.0148872	0.00605	0.0088372	59.36%
1801	TPCODL	BBSR1	BED	RASULGARH	NAKHARA	14023	11 KV GOBINDPUR RE	14023201	JAY JAGANNATH CONSTRUCTION	1315DT626	250	MIXED	AMI	Yes	100%	30	0.04650898	0.026505	0.02000398	43.01%
1802	TPCODL	BBSR1	BED	RASULGARH	NAKHARA	14023	11 KV GOBINDPUR RE	14023201	GROWING FLOW REGING	1315DT627	250	MIXED	AMI	Yes	100%	25	0.03479422	0.021161	0.01363322	39.18%
1803	TPCODL	BBSR1	BED	RASULGARH	NAKHARA	14023	11 KV GOBINDPUR RE	14023201	KHANDAGAR	1315DT635	250	MIXED	AMI	Yes	100%	105	0.16856848	0.08944243	0.07912605	46.94%
1804	TPCODL	BBSR1	BED	RASULGARH	NAKHARA	14023	11 KV GOBINDPUR RE	14023201	MAHIDHARAPADA	1315DT637	100	MIXED	AMI	Yes	0%	65	0.09201024	0.028854	0.06315624	68.64%
1805	TPCODL	BBSR1	BED	RASULGARH	NAKHARA	14023	11 KV GOBINDPUR RE	14023201	BALUNKESWAR	1315DT640	500	MIXED	AMI	Yes	0%	140	0.09078424	0.088141	0.00264324	2.91%
1806	TPCODL	BBSR1	BED	RASULGARH	NAKHARA	14023	11 KV GOBINDPUR RE	14023201	ETHIES ARPIT	1315DT648	250	MIXED	AMI	Yes	100%	55	0.04913284	0.040442	0.00869084	17.69%
1807	TPCODL	BBSR1	BED	RASULGARH	NAKHARA	14023	11 KV GOBINDPUR RE	14023201	BATAPURANA	1315DT649	100	MIXED	AMI	Yes	100%	48	0.05155118	0.025257	0.02629418	51.01%
1808	TPCODL	BBSR1	BED	RASULGARH	NAKHARA	14023	11 KV GOBINDPUR RE	14023201	BATAPURANA BPL	1315DT652	63	MIXED	AMI	Yes	100%	42	0.03936994	0.024145	0.01522494	38.67%
1809	TPCODL	BBSR1	BED	RASULGARH	NAKHARA	14023	11 KV GOBINDPUR RE	14023201	KALYANIFARM GAJANANA	1315DT856	250	MIXED	AMI	Yes	0%	92	0.09611156	0.09239	0.00372156	3.87%
1810	TPCODL	BBSR1	BED	RASULGARH	NAKHARA	14023	11 KV GOBINDPUR RE	14023201	SRI BANAMALI SAHOO	1315DT944	100	MIXED	AMI	Yes	100%	8	0.01112268	0.006109	0.00501368	45.08%
1811	TPCODL	BBSR1	BED	RASULGARH	NAKHARA	14023	11 KV TRINATH BAZAR	14023202	KHARABELA ESTATE	1315DT715	250	MIXED	AMI	Yes	33%	173	0.20168272	0.159396	0.04228672	20.97%
1812	TPCODL	BBSR1	BED	RASULGARH	NAKHARA	14023	11 KV TRINATH BAZAR	14023202	BHIMPUR	1315DT718	100	MIXED	AMI	Yes	100%	51	0.0859586	0.043148	0.0428106	49.80%
1813	TPCODL	BBSR1	BED	RASULGARH	NAKHARA	14023	11 KV TRINATH BAZAR	14023202	KALYANI HEIGHT	1315DT722	500	MIXED	AMI	Yes	100%	25	0.05217852	0.019097	0.03308152	63.40%
1814	TPCODL	BBSR1	BED	RASULGARH	NAKHARA	14023	11 KV TRINATH BAZAR	14023202	ABHILASH MOHANTY	1315DT725	250	MIXED	AMI	Yes	100%	17	0.01861404	0.018422	0.00019204	1.03%
1815	TPCODL	BBSR1	BED	RASULGARH	NAKHARA	14023	11 KV TRINATH BAZAR	14023202	KALIA NIBAS	1315DT799	250	MIXED	AMI	Yes	0%	27	0.01647412	0.011992	0.00448212	27.21%
1816	TPCODL	BBSR1	BED	RASULGARH	NAKHARA	14023	11 KV TRINATH BAZAR	14023202	MANDARIA 1	1315DT806	100	MIXED	AMI	Yes	67%	185	0.13360461	0.112566	0.02103861	15.75%
1817	TPCODL	BBSR1	BED	RASULGARH	NAKHARA	14023	11 KV TRINATH BAZAR	14023202	SAMPURNA PROJECT SRI JUDHISTIR F	1315DT884	250	MIXED	AMI	Yes	100%	7	0.02034916	0.005095	0.01525416	74.96%
1818	TPCODL	BBSR1	BED	RASULGARH	NAKHARA	14023	11 KV PAHAL	14023203	MADHUKUNJ	1315DT437	500	MIXED	AMI	Yes	100%	119	0.14961368	0.117809	0.03180468	21.26%
1819	TPCODL	BBSR1	BED	RASULGARH	NAKHARA	14023	11 KV PAHAL	14023203	KACHARAMALA 2	1315DT439	200	MIXED	AMI	Yes	100%	140	0.20067808	0.153395	0.04728308	23.56%
1820	TPCODL	BBSR1	BED	RASULGARH	NAKHARA	14023	11 KV PAHAL	14023203	JANMAJAY PUR	1315DT440	100	MIXED	AMI	Yes	100%	110	0.11623334	0.096142	0.02009134	17.29%
1821	TPCODL	BBSR1	BED	RASULGARH	NAKHARA	14023	11 KV PAHAL	14023203	KHUNKAR	1315DT446	100	MIXED	AMI	Yes	33%	109	0.10663615	0.091897	0.01473915	13.82%
1822	TPCODL	BBSR1	BED	RASULGARH	NAKHARA	14023	11 KV PAHAL	14023203	SAHABAZ 1	1315DT494	100	MIXED	AMI	Yes	0%	81	0.12553854	0.104861	0.02067754	16.47%
1823	TPCODL	BBSR1	BED	RASULGARH	NAKHARA	14023	11 KV PAHAL	14023203	NUAPATANA 1	1315DT507	100	MIXED	AMI	Yes	100%	117	0.10909587	0.080185	0.02891087	26.50%
1824	TPCODL	BBSR1	BED	RASULGARH	NAKHARA	14023	11 KV PAHAL	14023203	NUAPATANA 2	1315DT508	100	MIXED	AMI	Yes	100%	48	0.0683507	0.044876	0.0234747	34.34%

Sl. No.	Zone Name	Circle name	Division name	Name of the Sub-division	Name of the Sub-station	Substation Code	Name of the 11 kV Feeder	Feeder Code	Name of the Location where DT situated	DT code	DT Capacity (kVA)	Predominant consumer type of DT (Domestic/Industrial/Agriculture/Mixed)	Type of metering AMR/AMI/ Communicable/Conventional metered/Unmetered	Status of Meter-whether Functional (Yes/No)	% of data received automatically (if AMR/AMI)	No. of Connected Consumers	Input Energy (MU) (A)	Billed Energy (MU) (B)	Loss (MU) (A-B)	% DT Loss (A-B)/A
1825	TPCODL	BBSR1	BED	RASULGARH	NAKHARA	14023	11 KV PAHAL	14023203	JAGANNATH TEMPLE	1315DT518	250	MIXED	AMI	Yes	100%	83	0.14982136	0.146318	0.00350336	2.34%
1826	TPCODL	BBSR1	BED	RASULGARH	NAKHARA	14023	11 KV PAHAL	14023203	PRASANT PARIDA	1315DT954	100	MIXED	AMI	Yes	100%	20	0.0239366	0.010049	0.0138876	58.02%
1827	TPCODL	BBSR1	BED	RASULGARH	NAKHARA	14023	11 KV PAHAL	14023203	SOVAN DAS	1315DT955	100	MIXED	AMI	Yes	100%	28	0.01979444	0.01964	0.00015444	0.78%
1828	TPCODL	BBSR1	BED	RASULGARH	NAKHARA	14023	11 KV DPS	14023204	BHAGYA NAGAR	1315DT665	100	MIXED	AMI	Yes	100%	101	0.12874888	0.104381	0.02436788	18.93%
1829	TPCODL	BBSR1	BED	RASULGARH	NAKHARA	14023	11 KV DPS	14023204	FORTUNE VILLA	1315DT666	250	MIXED	AMI	Yes	0%	11	0.02984468	0.006022	0.02382268	79.82%
1830	TPCODL	BBSR1	BED	RASULGARH	NAKHARA	14023	11 KV DPS	14023204	JATRA PADIA	1315DT672	500	MIXED	AMI	Yes	67%	200	0.18682384	0.137556	0.04926784	26.37%
1831	TPCODL	BBSR1	BED	RASULGARH	NAKHARA	14023	11 KV DPS	14023204	MAHAVEER COLONY ADALIA	1315DT676	100	MIXED	AMI	Yes	100%	86	0.13848234	0.074499	0.06398334	46.20%
1832	TPCODL	BBSR1	BED	RASULGARH	NAKHARA	14023	11 KV DPS	14023204	CONVERT GARDEN 3	1315DT682	250	MIXED	AMI	Yes	100%	20	0.08263576	0.052334	0.03030176	36.67%
1833	TPCODL	BBSR1	BED	RASULGARH	NAKHARA	14023	11 KV DPS	14023204	JANASHAKTI RELCON	1315DT688	100	MIXED	AMI	Yes	100%	33	0.04610582	0.041507	0.00459882	9.97%
1834	TPCODL	BBSR1	BED	RASULGARH	NAKHARA	14023	11 KV DPS	14023204	AMANA	1315DT708	500	MIXED	AMI	Yes	100%	116	0.11097032	0.073416	0.03755432	33.84%
1835	TPCODL	BBSR1	BED	RASULGARH	PANDRA	14370	11 KV PRACHI	14370201	SETHY BABU (NEAR)	1316DT072	250	MIXED	AMI	Yes	100%	226	0.32195232	0.302032	0.01992032	6.19%
1836	TPCODL	BBSR1	BED	RASULGARH	PANDRA	14370	11 KV PRACHI	14370201	KHADESWARI CLUB	1316DT074	250	MIXED	AMI	Yes	0%	100	0.18115244	0.151139	0.03001344	16.57%
1837	TPCODL	BBSR1	BED	RASULGARH	PANDRA	14370	11 KV PRACHI	14370201	K.C. OJHA S/S	1316DT076	250	MIXED	AMI	Yes	33%	104	0.21862996	0.149144	0.06948596	31.78%
1838	TPCODL	BBSR1	BED	RASULGARH	PANDRA	14370	11 KV PRACHI	14370201	ARATI RESIDENCY	1316DT077	100	MIXED	AMI	Yes	100%	11	0.0185726	0.009637	0.0089356	48.11%
1839	TPCODL	BBSR1	BED	RASULGARH	PANDRA	14370	11 KV PRACHI	14370201	M.K. MOHANTY NEAR RAIMOHAN PA	1316DT082	250	MIXED	AMI	Yes	100%	79	0.16014084	0.090571	0.06956984	43.44%
1840	TPCODL	BBSR1	BED	RASULGARH	PANDRA	14370	11 KV PRACHI	14370201	ROSY VILLA(NEAR)	1316DT087	250	MIXED	AMI	Yes	100%	27	0.06158956	0.047217	0.01437256	23.34%
1841	TPCODL	BBSR1	BED	RASULGARH	PANDRA	14370	11 KV PRACHI	14370201	PRACHI VIHAR(NEAR POND)(BUDHI T	1316DT092	250	MIXED	AMI	Yes	100%	82	0.11930616	0.102336	0.01697016	14.22%
1842	TPCODL	BBSR1	BED	RASULGARH	PANDRA	14370	11 KV PRACHI	14370201	RUDRAKSHA RESIDENCY	1316DT095	100	MIXED	AMI	Yes	100%	6	0.01085656	0.005323	0.00553356	50.97%
1843	TPCODL	BBSR1	BED	RASULGARH	PANDRA	14370	11 KV PRACHI	14370201	PLOT NO 362(P.K. MISHRA)	1316DT098	200	MIXED	AMI	Yes	0%	147	0.28525848	0.200121	0.08513748	29.85%
1844	TPCODL	BBSR1	BED	RASULGARH	PANDRA	14370	11 KV PRACHI	14370201	KHUSHI HARMONY	1316DT115	500	MIXED	AMI	Yes	100%	35	0.16535254	0.038299	0.12705354	76.84%
1845	TPCODL	BBSR1	BED	RASULGARH	PANDRA	14370	11 KV PRACHI	14370201	KALINGA APARTMENT	1316DT336	500	MIXED	AMI	Yes	100%	46	0.05075632	0.04129	0.00946632	18.65%
1846	TPCODL	BBSR1	BED	RASULGARH	PANDRA	14370	11 KV PRACHI	14370201	SUBHADRA ENCLAVE	1316DT363	250	MIXED	AMI	Yes	100%	27	0.0409753	0.026712	0.0142633	34.81%
1847	TPCODL	BBSR1	BED	RASULGARH	PANDRA	14370	11 KV PRACHI	14370201	INFRONT OF DTDC OFFICE PALASUNI	1316DT365	250	MIXED	AMI	Yes	100%	160	0.2774202	0.270446	0.0069742	2.51%
1848	TPCODL	BBSR1	BED	RASULGARH	PANDRA	14370	11 KV PRACHI	14370201	PALASUN(INFRONT OF B.C SAHU)(CH	1316DT369	100	MIXED	AMI	Yes	100%	46	0.0911343	0.052644	0.0384903	42.23%
1849	TPCODL	BBSR1	BED	RASULGARH	PANDRA	14370	11 KV PRACHI	14370201	KAPILESWARI VIHAR LANE NO4(CAPE	1316DT370	250	MIXED	AMI	Yes	100%	90	0.1555987	0.116507	0.0390917	25.12%
1850	TPCODL	BBSR1	BED	RASULGARH	PANDRA	14370	11 KV PRACHI	14370201	L&T	1316DT371	250	MIXED	AMI	Yes	100%	100	0.16651684	0.119836	0.04668084	28.03%
1851	TPCODL	BBSR1	BED	RASULGARH	PANDRA	14370	11 KV JAGANNATH NAGA	14370202	NARENDRA RESIDENCY	1316DT033	250	MIXED	AMI	Yes	100%	19	0.04070396	0.023861	0.01684296	41.38%
1852	TPCODL	BBSR1	BED	RASULGARH	PANDRA	14370	11 KV JAGANNATH NAGA	14370202	GGP ENCLAVE	1316DT037	100	MIXED	AMI	Yes	100%	46	0.09574896	0.040591	0.05515796	57.61%
1853	TPCODL	BBSR1	BED	RASULGARH	PANDRA	14370	11 KV JAGANNATH NAGA	14370202	BANKER ENCLAVE	1316DT038	500	MIXED	AMI	Yes	100%	68	0.09209224	0.07226	0.01983224	21.54%
1854	TPCODL	BBSR1	BED	RASULGARH	PANDRA	14370	11 KV JAGANNATH NAGA	14370202	SRUTI VILLA	1316DT040	250	MIXED	AMI	Yes	33%	131	0.1691884	0.141239	0.0279494	16.52%
1855	TPCODL	BBSR1	BED	RASULGARH	PANDRA	14370	11 KV JAGANNATH NAGA	14370202	KUMBRIA BASTI	1316DT041	250	MIXED	AMI	Yes	100%	403	0.24254465	0.17963	0.06291465	25.94%
1856	TPCODL	BBSR1	BED	RASULGARH	PANDRA	14370	11 KV JAGANNATH NAGA	14370202	GOKUL RESIDENCY	1316DT043	500	MIXED	AMI	Yes	100%	27	0.05569744	0.033292	0.02240544	40.23%
1857	TPCODL	BBSR1	BED	RASULGARH	PANDRA	14370	11 KV JAGANNATH NAGA	14370202	AVANTIKA APPARENT	1316DT044	100	MIXED	AMI	Yes	100%	8	0.01477208	0.006885	0.00788708	53.39%
1858	TPCODL	BBSR1	BED	RASULGARH	PANDRA	14370	11 KV JAGANNATH NAGA	14370202	PRIYA ELITE	1316DT052	500	MIXED	AMI	Yes	0%	65	0.05819264	0.047899	0.01029364	17.69%
1859	TPCODL	BBSR1	BED	RASULGARH	PANDRA	14370	11 KV JAGANNATH NAGA	14370202	JAGANNATH ROAD 8	1316DT067	500	MIXED	AMI	Yes	0%	220	0.27086528	0.266125	0.00474028	1.75%
1860	TPCODL	BBSR1	BED	RASULGARH	PANDRA	14370	11 KV JAGANNATH NAGA	14370202	JAGANNATH NAGAR ROAD 8(5)	1316DT070	200	MIXED	AMI	Yes	100%	154	0.2156354	0.17093	0.0447054	20.73%
1861	TPCODL	BBSR1	BED	RASULGARH	PANDRA	14370	11 KV PANDRA VILLAGE	14370203	NEAR KALIA NAGAR , PANDRA	1316DT003	250	MIXED	AMI	Yes	100%	184	0.2666228	0.186042	0.0805808	30.22%
1862	TPCODL	BBSR1	BED	RASULGARH	PANDRA	14370	11 KV PANDRA VILLAGE	14370203	KANAKA MANJARE NAYAK	1316DT011	250	MIXED	AMI	Yes	100%	14	0.02993276	0.023953	0.00597976	19.98%
1863	TPCODL	BBSR1	BED	RASULGARH	PANDRA	14370	11 KV PANDRA VILLAGE	14370203	PANDRA BHATTA	1316DT015	100	MIXED	AMI	Yes	100%	36	0.09845176	0.0383	0.06015176	61.10%
1864	TPCODL	BBSR1	BED	RASULGARH	PANDRA	14370	11 KV MANGARAJ POINT	14370204	BANDANA MOHANTY(ARCHID MAPA	1313DT070	250	MIXED	AMI	Yes	100%	14	0.03213848	0.017973	0.01416548	44.08%
1865	TPCODL	BBSR1	BED	RASULGARH	PANDRA	14370	11 KV MANGARAJ POINT	14370204	SAHAYA REAL ESTATE APARTMENT	1313DT071	250	MIXED	AMI	Yes	100%	42	0.05759816	0.052115	0.00548316	9.52%
1866	TPCODL	BBSR1	BED	RASULGARH	PANDRA	14370	11 KV MANGARAJ POINT	14370204	VENKATSWAR PLAZA	1313DT073	250	MIXED	AMI	Yes	100%	14	0.06248204	0.012754	0.04972804	79.59%
1867	TPCODL	BBSR1	BED	RASULGARH	PANDRA	14370	11 KV MANGARAJ POINT	14370204	AVISKAR APARTMENT	1313DT074	500	MIXED	AMI	Yes	100%	42	0.08438984	0.060319	0.02407084	28.52%
1868	TPCODL	BBSR1	BED	RASULGARH	PANDRA	14370	11 KV MANGARAJ POINT	14370204	M.G. ENCLAVE	1313DT080	100	MIXED	AMI	Yes	0%	29	0.03475258	0.023798	0.01095458	31.52%
1869	TPCODL	BBSR1	BED	RASULGARH	PANDRA	14370	11 KV MANGARAJ POINT	14370204	N.C MANJIL APARTMENT	1313DT086	100	MIXED	AMI	Yes	100%	13	0.01441792	0.014376	4.192E-05	0.29%
1870	TPCODL	BBSR1	BED	RASULGARH	PANDRA	14370	11 KV MANGARAJ POINT	14370204	SNEHA COMPLEX	1313DT095	100	MIXED	AMI	Yes	0%	19	0.02895982	0.024021	0.00493882	17.05%
1871	TPCODL	BBSR1	BED	RASULGARH	PANDRA	14370	11 KV MANGARAJ POINT	14370204	PRAMOD KUMAR PATRA	1313DT211	250	MIXED	AMI	Yes	100%	18	0.0934222	0.052403	0.0410192	43.91%
1872	TPCODL	BBSR1	BED	RASULGARH	PANDRA	14370	11 KV MANGARAJ POINT	14370204	NILADRI NAGAR-01	1313DT266	250	MIXED	AMI	Yes	0%	83	0.20775456	0.100063	0.10769156	51.84%
1873	TPCODL	BBSR1	BED	RASULGARH	PANDRA	14370	11 KV MANGARAJ POINT	14370204	NILADRI NAGAR-02	1313DT267	250	MIXED	AMI	Yes	0%	126	0.21167624	0.134903	0.07677324	36.27%
1874	TPCODL	BBSR1	BED	RASULGARH	PANDRA	14370	11 KV MANGARAJ POINT	14370204	ADVE GIS	1313DT276	100	MIXED	AMI	Yes	100%	7	0.06030726	0.014376	0.04593126	76.16%
1875	TPCODL	BBSR1	BED	RASULGARH	PANDRA	14370	11 KV MANGARAJ POINT	14370204	PRAKASH JENA DUPLEX (OM ASHRAY	1313DT307	100	MIXED	AMI	Yes	100%	15	0.02800664	0.027195	0.00081164	2.90%
1876	TPCODL	BBSR1	BED	RASULGARH	PANDRA	14370	11 KV MANGARAJ POINT	14370204	TRIDHARA ENCLAVE	1313DT308	100	MIXED	AMI	Yes	0%	9	0.02508212	0.008807	0.01627512	64.89%
1877	TPCODL	BBSR1	BED	RASULGARH	PANDRA	14370	11 KV MANGARAJ POINT	14370204	GGP ENCLAVE(L & T)	1316DT145	100	MIXED	AMI	Yes	100%	32	0.056948	0.052659	0.004289	7.53%
1878	TPCODL	BBSR1	BED	RASULGARH	PRADHAN SAHI ODS	14253	11 kV HITECH-OH	14253204	SRUSTI RESIDENCE	1322DT417	500	MIXED	AMI	Yes	100%	50	0.05548912	0.027957	0.02753212	49.62%
1879	TPCODL	BBSR1	BED	RASULGARH	RASULGARH	14021	11 KV RASULGARH	14021201	OCC NEAR MUNDA BASTI	1316DT156	250	MIXED	AMI	Yes	100%	328	0.19426864	0.191907	0.00236164	1.22%
1880	TPCODL	BBSR1	BED	RASULGARH	RASULGARH	14021	11 KV RASULGARH	14021201	PHD COLONY,PALASUNI	1316DT162	250	MIXED	AMI	Yes	100%	91	0.1123726	0.07403	0.0383426	34.12%
1881	TPCODL	BBSR1	BED	RASULGARH	RASULGARH	14021	11 KV RASULGARH	14021201	PALASUNI NEW COLONY	1316DT170	250	MIXED	AMI	Yes	0%	107	0.24297992	0.172087	0.07089292	29.18%
1882	TPCODL	BBSR1	BED	RASULGARH	RASULGARH	14021	11 KV RASULGARH	14021201	BAIKHUNTHA NAGAR	1316DT182	250	MIXED	AMI	Yes	100%	91	0.16157108	0.107928	0.05364308	33.20%
1883	TPCODL	BBSR1	BED	RASULGARH	RASULGARH	14021	11 KV RASULGARH	14021201	SATYA ENCLAVE 2	1316DT192	500	MIXED	AMI	Yes	100%	63	0.0544496	0.037046	0.0174036	31.96%
1884	TPCODL	BBSR1	BED	RASULGARH	RASULGARH	14021	11 KV RASULGARH	14021201	SATYA ENCLAVE 4(L&T)	1316DT194	250	MIXED	AMI	Yes	100%	119	0.20628232	0.135206	0.07107632	34.46%
1885	TPCODL	BBSR1	BED	RASULGARH	RASULGARH	14021	11 KV RASULGARH	14021201	IN FRONT IMAGE COLLEGE	1316DT249	500	MIXED	AMI	Yes	0%	160	0.49033128	0.209749	0.28058228	57.22%
1886	TPCODL	BBSR1	BED	RASULGARH	RASULGARH	14021	11 KV RASULGARH	14021201	D. MOHANTY	1316DT250	100	MIXED	AMI	Yes	100%	99	0.14418096	0.120255	0.02392596	16.59%
1887	TPCODL	BBSR1	BED	RASULGARH	RASULGARH	14021	11 KV RASULGARH	14021201	SAPTASATI NAGAR 1	1316DT265	100	MIXED	AMI	Yes	100%	90	0.14688572	0.102178	0.04470772	30.44%
1888	TPCODL	BBSR1	BED	RASULGARH	RASULGARH	14021	11 KV RASULGARH	14021201	MANCHSWER CHAK	1316DT268	500	MIXED	AMI	Yes	100%	249	0.25133336	0.249022	0.00231136	0.92%
1889	TPCODL	BBSR1	BED	RASULGARH	RASULGARH	14021	11 KV RASULGARH	14021201	MANCHANATH APARTMENT	1316DT270	250	MIXED	AMI	Yes	100%	30	0.04440088	0.033956	0.01044488	23.52%
1890	TPCODL	BBSR1	BED	RASULGARH	RASULGARH	14021	11 KV RASULGARH	14021201	BHOI SAHI	1316DT276	100	MIXED	AMI	Yes	100%	113	0.1266418	0.084395	0.0422468	33.36%
1891	TPCODL	BBSR1	BED	RASULGARH	RASULGARH	14021	11 KV RASULGARH	14021201	PHD QUARTER	1316DT277	100	MIXED	AMI	Yes	100%	43	0.05264324	0.02732	0.02532324	48.10%
1892	TPCODL	BBSR1	BED	RASULGARH	RASULGARH	14021	11 KV RASULGARH	14021201	APALLO ASHIYAN	1316DT281	250	MIXED	AMI	Yes	100%	48	0.06940164	0.05151	0.01789164	25.78%
1893	TPCODL	BBSR1	BED	RASULGARH	RASULGARH	14021	11 KV RASULGARH	14021201	SATYA SAI ENCLAVE-2	1316DT401	250	MIXED	AMI	Yes	0%	103	0.18425216	0.117616	0.06663616	36.17%
1894	TPCODL	BBSR1	BED	RASULGARH	RASULGARH	14021	11 KV PURI ROAD	14021202	BESIDE ESPLANADE	1316DT123	500	MIXED	AMI	Yes	0%	47	0.17424448	0.116957	0.05728748	32.88%
1895	TPCODL	BBSR1	BED	RASULGARH	RASULGARH	14021	11 KV PURI ROAD	14021202	MADHUKUNJ ENCLAVE	1316DT128	250	MIXED	AMI	Yes	67%	83	0.08148788	0.069807	0.01168088	14.33%
1896	TPCODL	BBSR1	BED	RASULGARH	RASULGARH	14021	11 KV PURI ROAD	14021202	NETAJI VIHAR(PLOT NO-1022)SABAR	1316DT296	250	MIXED	AMI	Yes	100%	95	0.165368	0.125993	0.039375	23.81%
1897	TPCODL	BBSR1	BED	RASULGARH	RASULGARH	14021	11 KV PURI ROAD	14021202	BASUNDHARA APARTMENT	1316DT301	250	MIXED	AMI	Yes	0%	32	0.0677474	0.022291	0.0454564	67.10%

Sl. No.	Zone Name	Circle name	Division name	Name of the Sub-division	Name of the Sub-station	Substation Code	Name of the 11 kV Feeder	Feeder Code	Name of the Location where DT situated	DT code	DT Capacity (kVA)	Predominant consumer type of DT (Domestic/Industrial/Agriculture/Mixed)	Type of metering AMR/AMI/ Communicable/Conventional metered/Unmetered	Status of Meter-whether Functional (Yes/No)	% of data received automatically (if AMR/AMI)	No. of Connected Consumers	Input Energy (MU) (A)	Billed Energy (MU) (B)	Loss (MU) (A-B)	% DT Loss (A-B)/A
1898	TPCODL	BBSR1	BED	RASULGARH	RASULGARH	14021	11 KV PURI ROAD	14021202	GOMTI DEVI RESIDENCY	1316DT304	160	MIXED	AMI	Yes	0%	9	0.01714356	0.011643	0.00550056	32.09%
1899	TPCODL	BBSR1	BED	RASULGARH	RASULGARH	14021	11 KV PURI ROAD	14021202	RASULGARH PALA MANDAP	1316DT310	250	MIXED	AMI	Yes	100%	69	0.20735404	0.109958	0.09739604	46.97%
1900	TPCODL	BBSR1	BED	RASULGARH	RASULGARH	14021	11 KV PURI ROAD	14021202	RASULGARH PALA MANDAP	1316DT311	100	MIXED	AMI	Yes	100%	79	0.15965032	0.126627	0.03302332	20.68%
1901	TPCODL	BBSR1	BED	RASULGARH	RASULGARH	14021	11 KV PURI ROAD	14021202	MONORAMA ESTATE 1	1316DT314	250	MIXED	AMI	Yes	100%	109	0.15356206	0.138344	0.01521806	9.91%
1902	TPCODL	BBSR1	BED	RASULGARH	RASULGARH	14021	11 KV PURI ROAD	14021202	MANARAMA MANNER	1316DT318	250	MIXED	AMI	Yes	100%	46	0.08620112	0.064199	0.02200212	25.52%
1903	TPCODL	BBSR1	BED	RASULGARH	RASULGARH	14021	11 KV PURI ROAD	14021202	SWARNALATA APARTMENT	1316DT329	250	MIXED	AMI	Yes	100%	35	0.03766828	0.027156	0.01051228	27.91%
1904	TPCODL	BBSR1	BED	RASULGARH	RASULGARH	14021	11 KV KALPANA	14021203	NIGAMANANDA NAGAR LANE-02	1313DT456	250	MIXED	AMI	Yes	100%	100	0.20467548	0.140266	0.06440948	31.47%
1905	TPCODL	BBSR1	BED	RASULGARH	RASULGARH	14021	11 KV KALPANA	14021203	SURAKSHYA VILLA	1313DT457	100	MIXED	AMI	Yes	67%	25	0.02398408	0.018352	0.00563208	23.48%
1906	TPCODL	BBSR1	BED	RASULGARH	RASULGARH	14021	11 KV KALPANA	14021203	MUSHKAN APARTMENT	1313DT460	100	MIXED	AMI	Yes	100%	17	0.01884888	0.012832	0.00601688	31.92%
1907	TPCODL	BBSR1	BED	RASULGARH	RASULGARH	14021	11 KV KALPANA	14021203	LOPAMUDRA ENCLAVE	1313DT462	100	MIXED	AMI	Yes	100%	19	0.0233546	0.012231	0.0111236	47.63%
1908	TPCODL	BBSR1	BED	RASULGARH	RASULGARH	14021	11 KV KALPANA	14021203	ROYAL CHAND APARTMENT	1313DT467	100	MIXED	AMI	Yes	100%	8	0.0126229	0.012582	0.0000409	0.32%
1909	TPCODL	BBSR1	BED	RASULGARH	RASULGARH	14021	11 KV KALPANA	14021203	NIGAMANANDA NAGAR LANE-03	1313DT469	500	MIXED	AMI	Yes	100%	73	0.28099312	0.12375	0.15724312	55.96%
1910	TPCODL	BBSR1	BED	RASULGARH	RASULGARH	14021	11 KV KALPANA	14021203	STALWART PREMIUM-2	1313DT549	250	MIXED	AMI	Yes	100%	13	0.0235264	0.017425	0.0061014	25.93%
1911	TPCODL	BBSR1	BED	RASULGARH	RASULGARH	14021	11 KV KALPANA	14021203	STALWART PREMIUM-1	1313DT550	500	MIXED	AMI	Yes	100%	16	0.04815288	0.013487	0.03466588	71.99%
1912	TPCODL	BBSR1	BED	RASULGARH	RASULGARH	14021	11 KV KALPANA	14021203	SIVA TEMPLE-1	1316DT210	250	MIXED	AMI	Yes	100%	20	0.08170914	0.030925	0.05078414	62.15%
1913	TPCODL	BBSR1	BED	RASULGARH	RASULGARH	14021	11 KV KALPANA	14021203	SIVA TEMPLE-2	1316DT211	500	MIXED	AMI	Yes	0%	131	0.2702448	0.156553	0.1136918	42.07%
1914	TPCODL	BBSR1	BED	RASULGARH	RASULGARH	14021	11 KV KALPANA	14021203	UTKAL KAMALA VIHAR APPARTMENT	1316DT217	500	MIXED	AMI	Yes	100%	44	0.06877296	0.062757	0.00601596	8.75%
1915	TPCODL	BBSR1	BED	RASULGARH	RASULGARH	14021	11 KV KALPANA	14021203	OLD BANK COLONY-2	1316DT220	100	MIXED	AMI	Yes	100%	20	0.06524508	0.024219	0.04102608	62.88%
1916	TPCODL	BBSR1	BED	RASULGARH	RASULGARH	14021	11 KV KALPANA	14021203	MUDHI FACTORY S/S	1316DT225	100	MIXED	AMI	Yes	100%	33	0.06507942	0.036871	0.02820842	43.34%
1917	TPCODL	BBSR1	BED	RASULGARH	RASULGARH	14021	11 KV KALPANA	14021203	GGP HANUMAN TEMPLE-1	1316DT239	250	MIXED	AMI	Yes	0%	203	0.17288404	0.143528	0.02935604	16.98%
1918	TPCODL	BBSR1	BED	RASULGARH	RASULGARH	14021	11 KV KALPANA	14021203	GGP HANUMAN TEMPLE-2	1316DT240	200	MIXED	AMI	Yes	0%	137	0.11509008	0.092745	0.02234508	19.42%
1919	TPCODL	BBSR1	BED	RASULGARH	RASULGARH	14021	11 KV KALPANA	14021203	SAMBIT REDIDENCY	1316DT245	200	MIXED	AMI	Yes	100%	50	0.0806232	0.071703	0.0089202	11.06%
1920	TPCODL	BBSR1	BED	RASULGARH	RASULGARH	14021	11 KV KALPANA	14021203	CHAKRADHAR MANSION	1316DT340	250	MIXED	AMI	Yes	0%	13	0.04497752	0.022508	0.02246952	49.96%
1921	TPCODL	BBSR1	BED	RASULGARH	RASULGARH	14021	11 KV KALPANA	14021203	BHAGABAT SANDHAN COLONY	1316DT341	250	MIXED	AMI	Yes	100%	101	0.19302176	0.1379	0.05512176	28.56%
1922	TPCODL	BBSR1	BED	RASULGARH	RASULGARH	14021	11 KV KALPANA	14021203	BHAGABAT SANDHAN COLONY 3	1316DT342	250	MIXED	AMI	Yes	0%	130	0.21785012	0.199326	0.01852412	8.50%
1923	TPCODL	BBSR1	BED	RASULGARH	RASULGARH	14021	11 KV KALPANA	14021203	AMITI SAMAL APP	1316DT343	100	MIXED	AMI	Yes	100%	8	0.01399494	0.011755	0.00223994	16.01%
1924	TPCODL	BBSR1	BED	RASULGARH	RASULGARH	14021	11 KV KALPANA	14021203	FRIENDS COLONY	1316DT345	100	MIXED	AMI	Yes	100%	59	0.08630858	0.074155	0.01215358	14.08%
1925	TPCODL	BBSR1	BED	RASULGARH	RASULGARH	14021	11 KV KALPANA	14021203	M.J.ABHIMNYU RESIDENCY	1316DT357	100	MIXED	AMI	Yes	0%	9	0.01287866	0.009225	0.00365366	28.37%
1926	TPCODL	BBSR1	BED	RASULGARH	RASULGARH	14021	11 KV PRESS	14021204	TRISAKTI BUILDERS(VAISHNABA MAN	1316DT138	250	MIXED	AMI	Yes	0%	26	0.05399296	0.048409	0.00558396	10.34%
1927	TPCODL	BBSR1	BED	RASULGARH	RASULGARH	14021	11 KV PRESS	14021204	TRISAKTI BUILDERS(2)(VAISHNABA M	1316DT139	250	MIXED	AMI	Yes	67%	24	0.05386178	0.046421	0.00744078	13.81%
1928	TPCODL	BBSR1	BED	RASULGARH	RASULGARH	14021	11 KV PRESS	14021204	INDUSTRIAL ESTATE(1)	1316DT140	200	MIXED	AMI	Yes	100%	35	0.1526601	0.127223	0.0254371	16.66%
1929	TPCODL	BBSR1	BED	RASULGARH	RASULGARH	14021	11 KV PRESS	14021204	DHARITI	1316DT142	250	MIXED	AMI	Yes	100%	41	0.1864798	0.092783	0.0936968	50.25%
1930	TPCODL	BBSR1	BED	RASULGARH	RASULGARH	14021	11 KV CR RMU-12	14021205	GUNJAN PARIVAR	1316DT361	250	MIXED	AMI	Yes	0%	58	0.09838896	0.050152	0.04823696	49.03%
1931	TPCODL	BBSR1	BED	RASULGARH	RASULGARH	14021	11 KV CR RMU-12	14021205	SHANTI NIWAS	1316DT362	250	MIXED	AMI	Yes	100%	23	0.03470824	0.020196	0.01451224	41.81%
1932	TPCODL	BBSR1	BED	RASULGARH	SBI KESURA	14183	11 KV KESURA	14183202	NEAR SHANI TEMPLE	1313DT147	250	MIXED	AMI	Yes	100%	266	0.34259224	0.252819	0.08977324	26.20%
1933	TPCODL	BBSR1	BED	RASULGARH	SBI KESURA	14183	11 KV KESURA	14183202	NEAR SHAIKH SIRAJUDDIN (PLOT NO.	1313DT158	250	MIXED	AMI	Yes	100%	64	0.18627248	0.091848	0.09442448	50.69%
1934	TPCODL	BBSR1	BED	RASULGARH	SBI KESURA	14183	11 KV KESURA	14183202	NEAR P.J COLLEGE	1313DT169	100	MIXED	AMI	Yes	100%	93	0.13625096	0.076262	0.05998896	44.03%
1935	TPCODL	BBSR1	BED	RASULGARH	SBI KESURA	14183	11 KV KESURA	14183202	NEAR JIO & JTL TOWER	1313DT173	250	MIXED	AMI	Yes	100%	273	0.30821432	0.251489	0.05672532	18.40%
1936	TPCODL	BBSR1	BED	RASULGARH	SBI KESURA	14183	11 KV KESURA	14183202	7vcg+5w4 (GPS TAG POINT)	1313DT175	100	MIXED	AMI	Yes	100%	55	0.07685856	0.039804	0.03705456	48.21%
1937	TPCODL	BBSR1	BED	RASULGARH	SBI KESURA	14183	11 KV KESURA	14183202	PLOT NO 152/1856	1313DT176	100	MIXED	AMI	Yes	33%	136	0.13955864	0.107059	0.03249964	23.29%
1938	TPCODL	BBSR1	BED	RASULGARH	SBI KESURA	14183	11 KV KESURA	14183202	NEAR SAHOO GROCERY	1313DT177	150	MIXED	AMI	Yes	100%	146	0.17796524	0.133402	0.04456324	25.04%
1939	TPCODL	BBSR1	BED	RASULGARH	SBI KESURA	14183	11 KV KESURA	14183202	NEAR SHANI TEMPLE	1313DT181	100	MIXED	AMI	Yes	100%	117	0.19003362	0.101829	0.08820462	46.42%
1940	TPCODL	BBSR1	BED	RASULGARH	UTTARA	14026	11 KV SARDEIPUR	14026204	UTTRA CHAKKA	1326DT001	500	MIXED	AMI	Yes	100%	314	0.37252944	0.241801	0.13072844	35.09%
1941	TPCODL	BBSR1	BED	TEMPLE	BADAGADA	14019	11 KV MAUSIMA	14019203	HIRAK PATTANAYAK	1321DT060	250	MIXED	AMI	Yes	0%	10	0.02948352	0.016605	0.01287852	43.68%
1942	TPCODL	BBSR1	BED	TEMPLE	BADAGADA	14019	11 KV BADAGADA	14019205	BADAGADA POLICE STATION CAPEX	1321DT115	250	MIXED	AMI	Yes	0%	89	0.11889958	0.074831	0.04406858	37.06%
1943	TPCODL	BBSR1	BED	TEMPLE	BADAGADA	14019	11 kV BADAGADA	14019205	GHO PADIA	1321DT120	200	MIXED	AMI	Yes	0%	114	0.15539428	0.10242	0.05297428	34.09%
1944	TPCODL	BBSR1	BED	TEMPLE	BADAGADA	14019	11 kV BADAGADA	14019205	KALING BASTEE	1321DT131	100	MIXED	AMI	Yes	0%	64	0.08279236	0.060893	0.02189936	26.45%
1945	TPCODL	BBSR1	BED	TEMPLE	BADAGADA	14019	11 kV BRAHMESWAR	14019201	BIJAY LAXMI	1321DT164	100	MIXED	AMI	Yes	0%	33	0.03659984	0.024087	0.01251284	34.19%
1946	TPCODL	BBSR1	BED	TEMPLE	BADAGADA	14019	11 kV BRAHMESWAR	14019201	ANNAPURNA	1321DT180	250	MIXED	AMI	Yes	100%	34	0.04453268	0.039994	0.00453868	10.19%
1947	TPCODL	BBSR1	BED	TEMPLE	BADAGADA	14019	11 kV BRAHMESWAR	14019201	BRAHMESWAR VILLA	1321DT187	100	MIXED	AMI	Yes	0%	12	0.01597696	0.012385	0.00359196	22.48%
1948	TPCODL	BBSR1	BED	TEMPLE	LINGIPUR ODSSP	14244	11 kV KUAKHAI	14244202	SAI TEMPLE	1321DT243	100	MIXED	AMI	Yes	0%	62	0.09389448	0.071973	0.02192148	23.35%
1949	TPCODL	BBSR1	BED	TEMPLE	LINGIPUR ODSSP	14244	11 kV KUAKHAI	14244202	S K MOHANTY	1321DT246	63	MIXED	AMI	Yes	0%	99	0.14033788	0.10559	0.03474788	24.76%
1950	TPCODL	BBSR1	BED	TEMPLE	LINGIPUR ODSSP	14244	11 kV KUAKHAI	14244202	SAI VIHAR	1321DT249	250	MIXED	AMI	Yes	0%	132	0.14444272	0.137657	0.00678572	4.70%
1951	TPCODL	BBSR1	BED	TEMPLE	LINGIPUR ODSSP	14244	11 kV KUAKHAI	14244202	RWSS BANKUALA	1321DT306	100	MIXED	AMI	Yes	0%	66	0.0563127	0.041405	0.0149077	26.47%
1952	TPCODL	BBSR1	BED	TEMPLE	LINGIPUR ODSSP	14244	11 kV KUAKHAI	14244202	BHOI SAHI PROJECT	1321DT309	100	MIXED	AMI	Yes	100%	23	0.0286018	0.020959	0.0076428	26.72%
1953	TPCODL	BBSR1	BED	TEMPLE	LINGIPUR ODSSP	14244	11 kV KUAKHAI	14244202	PANCHAMANA BHOI SAHI	1321DT312	63	MIXED	AMI	Yes	0%	46	0.04451669	0.009766	0.03475069	78.06%
1954	TPCODL	BBSR1	BED	TEMPLE	LINGIPUR ODSSP	14244	11 kV KUAKHAI	14244202	STAR URBAN	1321DT329	100	MIXED	AMI	Yes	0%	12	0.0178912	0.012539	0.0053522	29.92%
1955	TPCODL	BBSR1	BED	TEMPLE	BADAGADA	14019	11 kV B.J.B NAGAR	14019206	NUASAHI PROJECT	1321DT388	100	MIXED	AMI	Yes	0%	16	0.0245339	0.010239	0.0142949	58.27%
1956	TPCODL	BBSR1	BED	TEMPLE	BHIMATANGI	14018	11 kV BHIMATANGI	14018203	BHIMESWAR TEMPLE	1322DT014	500	MIXED	AMI	Yes	0%	359	0.30971656	0.292707	0.01700956	5.49%
1957	TPCODL	BBSR1	BED	TEMPLE	BHIMATANGI	14018	11 kV LINGARAJ	14018202	BHATA BHOISAHI BGJY	1322DT053	100	MIXED	AMI	Yes	0%	56	0.15101152	0.032414	0.11859752	78.54%
1958	TPCODL	BBSR1	BED	TEMPLE	BHIMATANGI	14018	11 kV LINGARAJ	14018202	DEVI MANDAPA, RAPDRP	1322DT056	250	MIXED	AMI	Yes	0%	184	0.21191076	0.196064	0.01584676	7.48%
1959	TPCODL	BBSR1	BED	TEMPLE	BHIMATANGI	14018	11 kV LINGARAJ	14018202	OSHB COLONY (BHIMESWAR PATAN	1322DT062	500	MIXED	AMI	Yes	0%	400	0.3783447	0.34392	0.0344247	9.10%
1960	TPCODL	BBSR1	BED	TEMPLE	BHIMATANGI	14018	11 kV POKHARIPUT-1	14018201	RATNAMANI VILLA	1322DT083	100	MIXED	AMI	Yes	0%	6	0.00905703	0.008113	0.00094403	10.42%
1961	TPCODL	BBSR1	BED	TEMPLE	PRADHAN SAHI ODS	14253	11 kV HITECH-UG	14253205	HI-TECH PLAZA- 2	1322DT325	500	MIXED	AMI	Yes	0%	56	0.06570224	0.036253	0.02944924	44.82%
1962	TPCODL	BBSR1	BED	TEMPLE	PRADHAN SAHI ODS	14253	11 kV HITECH-UG	14253205	HI-TECH PLAZA- 9	1322DT331	500	MIXED	AMI	Yes	0%	111	0.11688168	0.064001	0.05288068	45.24%
1963	TPCODL	BBSR1	BED	TEMPLE	PRADHAN SAHI ODS	14253	11 kV HITECH-UG	14253205	HI-TECH PLAZA- 12	1322DT334	500	MIXED	AMI	Yes	0%	9	0.048204	0.010231	0.037973	78.78%
1964	TPCODL	BBSR1	BED	TEMPLE	PRADHAN SAHI ODS	14253	11 kV KALYANI PLAZA	14253201	SUBHASREE VILLA-3	1322DT360	500	MIXED	AMI	Yes	0%	15	0.0821294	0.022301	0.0598284	72.85%
1965	TPCODL	BBSR1	BED	TEMPLE	BHIMATANGI	14018	11 kV R.E JAMUKOLI	14018204	NABIN PATRA(BACK SIDE OF HT PLAZ	1322DT559	100	MIXED	AMI	Yes	0%	11	0.03129072	0.012645	0.01864572	59.59%
1966	TPCODL	BBSR1	BED	TEMPLE	LINGIPUR ODSSP	14244	11 kV GANGUA	14244204	JEMA DEI SCHOOL	1323DT046	250	MIXED	AMI	Yes	33%	90	0.2288374	0.090253	0.1385844	60.56%
1967	TPCODL	BBSR1	BED	TEMPLE	LINGIPUR ODSSP	14244	11 kV GANGUA	14244204	SISHUPAL CHHAKA	1323DT063	100	MIXED	AMI	Yes	0%	45	0.10084014	0.058758	0.04208214	41.73%
1968	TPCODL	BBSR1	BED	TEMPLE	LINGIPUR ODSSP	14244	11 kV INDIRA COLONY	14244207	NUAGRAM SOUBHAGRY	1323DT161	100	MIXED	AMI	Yes	0%	82	0.117511	0.065414	0.052097	44.33%
1969	TPCODL	BBSR1	BED	TEMPLE	LINGIPUR ODSSP	14244	11 kV INDIRA COLONY	14244207	RUDRAVIHAR	1323DT166	100	MIXED	AMI	Yes	100%	60	0.05623114	0.047147	0.00908414	16.15%
1970	TPCODL	BBSR1	BED	TEMPLE	LINGIPUR ODSSP	14244	11 kV GANGUA	14244204	DURGESWAR COMMUNITY CENTRE,	1323DT256	250	MIXED	AMI	Yes	0%	170	0.18051005	0.163105	0.01740505	9.64%

Sl. No.	Zone Name	Circle name	Division name	Name of the Sub-division	Name of the Sub-station	Substation Code	Name of the 11 kV Feeder	Feeder Code	Name of the Location where DT situated	DT code	DT Capacity (kVA)	Predominant consumer type of DT (Domestic/Industrial/Agriculture/Mixed)	Type of metering AMR/AMI/ Communicable/Conventional metered/Unmetered	Status of Meter-whether Functional (Yes/No)	% of data received automatically (if AMR/AMI)	No. of Connected Consumers	Input Energy (MU) (A)	Billed Energy (MU) (B)	Loss (MU) (A-B)	% DT Loss (A-B)/A
1971	TPCODL	BBSR1	BED	TEMPLE	BADAGADA	14019	11 kV BADAGADA LINGA	14019202	SIBANI BUILDER	1324DT089	100	MIXED	AMI	Yes	100%	29	0.05270594	0.04453	0.00817594	15.51%
1972	TPCODL	BBSR1	BED	TEMPLE	MULAPADIA ODSSP	14252	11 kV MULAPADIA	14252204	BARIK SAHI	1324DT101	100	MIXED	AMI	Yes	100%	85	0.11303426	0.075481	0.03755326	33.22%
1973	TPCODL	BBSR1	BED	TEMPLE	BADAGADA	14019	11 kV RAJARANI	14019208	MANMATHA NATH MOHAPATRA	1324DT142	100	MIXED	AMI	Yes	0%	6	0.0117697	0.003599	0.0081707	69.42%
1974	TPCODL	BBSR1	BED	TEMPLE	MULAPADIA ODSSP	14252	11 kV MAHAVIR COTTAG	14252202	OLD STATE BANK-2	1325DT053	250	MIXED	AMI	Yes	0%	114	0.28762212	0.120197	0.16742512	58.21%
1975	TPCODL	BBSR1	BED	TEMPLE	MULAPADIA ODSSP	14252	11 kV KAPILESWAR	14252201	KAKIGADIA MASANI	1325DT080	250	MIXED	AMI	Yes	100%	59	0.08269108	0.056855	0.02583608	31.24%
1976	TPCODL	BBSR1	BED	TEMPLE	SIULA ODSSP	14254	11 kV DAHISPATNA	14254203	POPARANGA TALA SAHI	1326DT222	100	MIXED	AMI	Yes	100%	74	0.08367514	0.029639	0.05403614	64.58%
1977	TPCODL	BBSR1	BED	TEMPLE	UTTARA	14026	11 kV KAUSHALYA	14026201	DELTA COLONY	1326DT252	100	MIXED	AMI	Yes	100%	98	0.11272048	0.083301	0.02941948	26.10%
1978	TPCODL	BBSR1	BED	TEMPLE	UTTARA	14026	11 kV KAUSHALYA	14026201	BISHAL GARDEEN	1326DT300	500	MIXED	AMI	Yes	0%	102	0.05662168	0.037067	0.01955468	34.54%
1979	TPCODL	BBSR1	BED	TEMPLE	SIULA ODSSP	14254	11 kV LAXMINARAYANPU	14254201	KUNJARA ATHARA MANA SAHI	1326DT382	100	MIXED	AMI	Yes	0%	49	0.04751708	0.027967	0.01955008	41.14%
1980	TPCODL	BBSR1	BED	TEMPLE	SIULA ODSSP	14254	11 kV LAXMINARAYANPU	14254201	TERABATIA	1326DT414	100	MIXED	AMI	Yes	0%	105	0.1162546	0.045566	0.0706886	60.80%
1981	TPCODL	BBSR1	BED	TEMPLE	BHIMATANGI	14018	11 KV STATION FDR	14018207	STAR RESIDENCY	1322DT034	250	MIXED	AMI	Yes	0%	27	0.03052416	0.028598	0.00192616	6.31%
1982	TPCODL	BBSR1	BED	TEMPLE	BHIMATANGI	14018	11 KV STATION FDR	14018207	SUNDARAPADA CAPEX	1322DT043	250	MIXED	AMI	Yes	100%	267	0.259679	0.24709	0.012589	4.85%
1983	TPCODL	BBSR1	BED	TEMPLE	BHIMATANGI	14018	11 KV STATION FDR	14018207	KABAR KHANA	1322DT045	100	MIXED	AMI	Yes	100%	102	0.1272313	0.096712	0.0305193	23.99%
1984	TPCODL	BBSR1	BED	TEMPLE	BHIMATANGI	14018	11 KV STATION FDR	14018207	SUNDARAPADA TALA SAHI -II ,RAPDR	1322DT046	100	MIXED	AMI	Yes	100%	90	0.096458	0.078082	0.018376	19.05%
1985	TPCODL	BBSR1	BED	TEMPLE	LINGIPUR ODSSP	14244	11 KV SHAKTI NAGAR	14244205	MANGALA BIHAR	1323DT015	250	MIXED	AMI	Yes	0%	124	0.17496884	0.116166	0.05880284	33.61%
1986	TPCODL	BBSR1	BED	TEMPLE	LINGIPUR ODSSP	14244	11 KV SHAKTI NAGAR	14244205	DALAKHAI	1323DT026	250	MIXED	AMI	Yes	100%	302	0.28274614	0.216922	0.06582414	23.28%
1987	TPCODL	BBSR1	BED	TEMPLE	LINGIPUR ODSSP	14244	11 KV SHAKTI NAGAR	14244205	PN PATTNAYAK	1323DT029	250	MIXED	AMI	Yes	100%	79	0.11370082	0.067356	0.04634482	40.76%
1988	TPCODL	BBSR1	BED	TEMPLE	LINGIPUR ODSSP	14244	11 KV SHAKTI NAGAR	14244205	BADATANGI	1323DT036	100	MIXED	AMI	Yes	0%	19	0.02375292	0.017465	0.00628792	26.47%
1989	TPCODL	BBSR1	BED	TEMPLE	LINGIPUR ODSSP	14244	11 KV SHAKTI NAGAR	14244205	RAGHUNATH NAGAR	1323DT039	500	MIXED	AMI	Yes	100%	356	0.39491208	0.333984	0.06092808	15.43%
1990	TPCODL	BBSR1	BED	TEMPLE	LINGIPUR ODSSP	14244	11 KV SHAKTI NAGAR	14244205	MAHAVIR NAGAR	1323DT040	500	MIXED	AMI	Yes	100%	201	0.43166328	0.229254	0.20240928	46.89%
1991	TPCODL	BBSR1	BED	TEMPLE	LINGIPUR ODSSP	14244	11 KV SHAKTI NAGAR	14244205	SUVRANSHU SEKHER SUNDARAY	1323DT264	100	MIXED	AMI	Yes	100%	12	0.02909438	0.009639	0.01945538	66.87%
1992	TPCODL	BBSR1	BED	TEMPLE	LINGIPUR ODSSP	14244	11 KV GANGOTRI NAGAR	14244206	MAHAVIR NAGAR 2	1323DT126	500	MIXED	AMI	Yes	100%	170	0.24661248	0.211824	0.03478848	14.11%
1993	TPCODL	BBSR1	BED	TEMPLE	LINGIPUR ODSSP	14244	11 KV GANGOTRI NAGAR	14244206	GANGOTRI NAGAR-1	1323DT133	500	MIXED	AMI	Yes	100%	208	0.28745616	0.216678	0.07077816	24.62%
1994	TPCODL	BBSR1	BED	TEMPLE	LINGIPUR ODSSP	14244	11 KV GANGOTRI NAGAR	14244206	RUDRA VIHAR	1323DT136	100	MIXED	AMI	Yes	0%	64	0.10518634	0.069343	0.03584334	34.08%
1995	TPCODL	BBSR1	BED	TEMPLE	LINGIPUR ODSSP	14244	11 KV GANGOTRI NAGAR	14244206	BIJAY BHIHAR LANE1	1323DT139	100	MIXED	AMI	Yes	100%	55	0.108915	0.057077	0.051838	47.59%
1996	TPCODL	BBSR1	BED	TEMPLE	LINGIPUR ODSSP	14244	11 KV GANGOTRI NAGAR	14244206	BIJAY BHIHAR LANE1	1323DT140	500	MIXED	AMI	Yes	100%	355	0.4487024	0.409608	0.0390944	8.71%
1997	TPCODL	BBSR1	BED	TEMPLE	LINGIPUR ODSSP	14244	11 KV GANGOTRI NAGAR	14244206	BIJAY BHIHAR LANE1	1323DT141	500	MIXED	AMI	Yes	100%	232	0.32689168	0.253223	0.07366868	22.54%
1998	TPCODL	BBSR1	BED	TEMPLE	LINGIPUR ODSSP	14244	11 KV GANGOTRI NAGAR	14244206	GOURI ENCLAVE	1323DT142	250	MIXED	AMI	Yes	0%	17	0.01636144	0.013917	0.00244444	14.94%
1999	TPCODL	BBSR1	BED	TEMPLE	LINGIPUR ODSSP	14244	11 KV GANGOTRI NAGAR	14244206	MARUTI NAGAR	1323DT143	250	MIXED	AMI	Yes	33%	211	0.27337928	0.199252	0.07412728	27.12%
2000	TPCODL	BBSR1	BED	TEMPLE	LINGIPUR ODSSP	14244	11 KV GANGOTRI NAGAR	14244206	MADWANI APARTMENT	1323DT144	250	MIXED	AMI	Yes	0%	24	0.02908956	0.026791	0.00229856	7.90%
2001	TPCODL	BBSR1	BED	TEMPLE	LINGIPUR ODSSP	14244	11 KV INDIRA COLONY	14244207	BASU DEV SAHOO	1323DT054	100	MIXED	AMI	Yes	100%	4	0.01193496	0.011487	0.00044796	3.75%
2002	TPCODL	BBSR1	BED	TEMPLE	LINGIPUR ODSSP	14244	11 KV INDIRA COLONY	14244207	SSB HOSPITAL	1323DT055	250	MIXED	AMI	Yes	0%	46	0.24369724	0.110126	0.13357124	54.81%
2003	TPCODL	BBSR1	BED	TEMPLE	LINGIPUR ODSSP	14244	11 KV INDIRA COLONY	14244207	OM SHASTIK APPARTMENT	1323DT056	250	MIXED	AMI	Yes	100%	38	0.04925794	0.0344	0.01485794	30.16%
2004	TPCODL	BBSR1	BED	TEMPLE	LINGIPUR ODSSP	14244	11 KV INDIRA COLONY	14244207	SWASTH SUDHAR VIHAR	1323DT057	100	MIXED	AMI	Yes	0%	136	0.16394522	0.129203	0.03474222	21.19%
2005	TPCODL	BBSR1	BED	TEMPLE	LINGIPUR ODSSP	14244	11 KV INDIRA COLONY	14244207	MUTRUYAYA VIHAR	1323DT069	500	MIXED	AMI	Yes	100%	366	0.40210248	0.369234	0.03286848	8.17%
2006	TPCODL	BBSR1	BED	TEMPLE	LINGIPUR ODSSP	14244	11 KV INDIRA COLONY	14244207	PANIGRAHI SUBSTATION	1323DT151	100	MIXED	AMI	Yes	0%	39	0.07107438	0.043603	0.02747138	38.65%
2007	TPCODL	BBSR1	BED	TEMPLE	LINGIPUR ODSSP	14244	11 KV INDIRA COLONY	14244207	INDRA COLONY	1323DT154	100	MIXED	AMI	Yes	0%	89	0.14969988	0.133672	0.01602788	10.71%
2008	TPCODL	BBSR1	BED	TEMPLE	LINGIPUR ODSSP	14244	11 KV INDIRA COLONY	14244207	NUAGRAM	1323DT164	100	MIXED	AMI	Yes	0%	86	0.08331162	0.052333	0.03097862	37.18%
2009	TPCODL	BBSR1	BED	TEMPLE	LINGIPUR ODSSP	14244	11 KV INDIRA COLONY	14244207	CAPEX NATHPUR	1323DT167	100	MIXED	AMI	Yes	0%	64	0.0581651	0.048933	0.0092321	15.87%
2010	TPCODL	BBSR1	BED	TEMPLE	BADAGADA	14019	11 KV BRAHMESWAR	14019201	RATNAKAR BAG	1321DT163	500	MIXED	AMI	Yes	0%	289	0.43010608	0.332542	0.09756408	22.68%
2011	TPCODL	BBSR1	BED	TEMPLE	BADAGADA	14019	11 KV BRAHMESWAR	14019201	RADHIKA TOWER	1321DT165	250	MIXED	AMI	Yes	0%	46	0.07940872	0.041173	0.03823572	48.15%
2012	TPCODL	BBSR1	BED	TEMPLE	BADAGADA	14019	11 KV BRAHMESWAR	14019201	PANDAB NAGAR	1321DT171	500	MIXED	AMI	Yes	67%	131	0.20584012	0.166598	0.03924212	19.06%
2013	TPCODL	BBSR1	BED	TEMPLE	BADAGADA	14019	11 KV BRAHMESWAR	14019201	PANDAB NAGAR	1321DT172	500	MIXED	AMI	Yes	100%	144	0.1749292	0.167518	0.0074112	4.24%
2014	TPCODL	BBSR1	BED	TEMPLE	BADAGADA	14019	11 KV BRAHMESWAR	14019201	RATNAKOR BAG-2	1321DT177	500	MIXED	AMI	Yes	100%	130	0.23571384	0.170999	0.06471484	27.45%
2015	TPCODL	BBSR1	BED	TEMPLE	BADAGADA	14019	11 KV BRAHMESWAR	14019201	BRAHMESWAR BAG	1321DT182	500	MIXED	AMI	Yes	100%	148	0.2737252	0.225853	0.0478722	17.49%
2016	TPCODL	BBSR1	BED	TEMPLE	BADAGADA	14019	11 KV BRAHMESWAR	14019201	RASHMI LAWN	1321DT185	100	MIXED	AMI	Yes	100%	13	0.0093821	0.008218	0.0011641	12.41%
2017	TPCODL	BBSR1	BED	TEMPLE	BADAGADA	14019	11 KV BRAHMESWAR	14019201	BRAMHESWAR PATANA HATO	1321DT186	500	MIXED	AMI	Yes	100%	292	0.41413584	0.363831	0.05030484	12.15%
2018	TPCODL	BBSR1	BED	TEMPLE	BADAGADA	14019	11 KV BRAHMESWAR	14019201	SANKALPA APARTMENT PHASE-2	1321DT189	250	MIXED	AMI	Yes	100%	6	0.02916548	0.008967	0.02019848	69.25%
2019	TPCODL	BBSR1	BED	TEMPLE	BADAGADA	14019	11 KV BRAHMESWAR	14019201	BRAHMESWAR TEMPLE	1321DT191	500	MIXED	AMI	Yes	0%	226	0.30730184	0.292498	0.01480384	4.82%
2020	TPCODL	BBSR1	BED	TEMPLE	BADAGADA	14019	11 KV BRAHMESWAR	14019201	BASANTA VIHAR DEVELOPMENT SOC	1321DT192	250	MIXED	AMI	Yes	100%	89	0.10864648	0.103015	0.00563148	5.18%
2021	TPCODL	BBSR1	BED	TEMPLE	BADAGADA	14019	11 KV BRAHMESWAR	14019201	GATIKRUSHNA VILLA-III	1321DT195	250	MIXED	AMI	Yes	100%	48	0.0881042	0.077183	0.0109212	12.40%
2022	TPCODL	BBSR1	BED	TEMPLE	BADAGADA	14019	11 KV BRAHMESWAR	14019201	GATIKRUSHNA VILLA LAGUN	1321DT196	500	MIXED	AMI	Yes	100%	60	0.13536496	0.116935	0.01842996	13.62%
2023	TPCODL	BBSR1	BED	TEMPLE	BADAGADA	14019	11 KV BRAHMESWAR	14019201	GASGODOMN-1	1321DT199	250	MIXED	AMI	Yes	100%	84	0.10180148	0.098384	0.00341748	3.36%
2024	TPCODL	BBSR1	BED	TEMPLE	BADAGADA	14019	11 KV BRAHMESWAR	14019201	GAS GODOMN-II	1321DT200	250	MIXED	AMI	Yes	100%	160	0.1948536	0.182874	0.0119796	6.15%
2025	TPCODL	BBSR1	BED	TEMPLE	BADAGADA	14019	11 KV BRAHMESWAR	14019201	BHOI SHAI, NEAR MENTRA HUB	1321DT215	100	MIXED	AMI	Yes	100%	19	0.05484364	0.019532	0.03531164	64.39%
2026	TPCODL	BBSR1	BED	TEMPLE	BADAGADA	14019	11 KV BRAHMESWAR	14019201	AASTA BINODINI RESIDENCE	1321DT218	250	MIXED	AMI	Yes	100%	25	0.04111876	0.025371	0.01574776	38.30%
2027	TPCODL	BBSR1	BED	TEMPLE	BADAGADA	14019	11 KV BRAHMESWAR	14019201	NC VILLA	1321DT223	250	MIXED	AMI	Yes	100%	9	0.02863284	0.015034	0.01359884	47.49%
2028	TPCODL	BBSR1	BED	TEMPLE	BADAGADA	14019	11 KV BADAGADA LINGA	14019202	SAUDAMININI ENCLAVE	1321DT089	100	MIXED	AMI	Yes	100%	14	0.00978918	0.008203	0.00158618	16.20%
2029	TPCODL	BBSR1	BED	TEMPLE	BADAGADA	14019	11 KV BADAGADA LINGA	14019202	BHARAT ENCLAVE	1321DT091	250	MIXED	AMI	Yes	0%	23	0.03732724	0.023826	0.01350124	36.17%
2030	TPCODL	BBSR1	BED	TEMPLE	BADAGADA	14019	11 KV BADAGADA LINGA	14019202	RAY PROJECT	1321DT092	250	MIXED	AMI	Yes	0%	127	0.14132636	0.061428	0.07989836	56.53%
2031	TPCODL	BBSR1	BED	TEMPLE	BADAGADA	14019	11 KV BADAGADA LINGA	14019202	RAJARANI COLONY	1321DT105	500	MIXED	AMI	Yes	0%	115	0.21109352	0.194884	0.01620952	7.68%
2032	TPCODL	BBSR1	BED	TEMPLE	BADAGADA	14019	11 KV BADAGADA LINGA	14019202	RAJARANI TEMPLE HATIASUNI	1321DT113	500	MIXED	AMI	Yes	100%	219	0.35277248	0.286697	0.06607548	18.73%
2033	TPCODL	BBSR1	BED	TEMPLE	BADAGADA	14019	11 KV BADAGADA LINGA	14019202	KANCHA BHOI SAHI	1323DT252	63	MIXED	AMI	Yes	100%	57	0.04035094	0.032512	0.00783894	19.43%
2034	TPCODL	BBSR1	BED	TEMPLE	BADAGADA	14019	11 KV BADAGADA LINGA	14019202	NEW MARKET	1323DT257	250	MIXED	AMI	Yes	0%	174	0.29681668	0.218131	0.07868568	26.51%
2035	TPCODL	BBSR1	BED	TEMPLE	BADAGADA	14019	11 KV BADAGADA LINGA	14019202	ASUTOSH VIHAR	1324DT083	250	MIXED	AMI	Yes	0%	45	0.06859956	0.041222	0.02737756	39.91%
2036	TPCODL	BBSR1	BED	TEMPLE	BADAGADA	14019	11 KV BADAGADA LINGA	14019202	GOURI NAGAR	1324DT093	500	MIXED	AMI	Yes	100%	181	0.27758608	0.221404	0.05618208	20.24%
2037	TPCODL	BBSR1	BED	TEMPLE	BADAGADA	14019	11 KV BADAGADA LINGA	14019202	GOURI NAGAR RAPDRP	1324DT094	250	MIXED	AMI	Yes	100%	52	0.10896988	0.054829	0.05414088	49.68%
2038	TPCODL	BBSR1	BED	TEMPLE	BADAGADA	14019	11 KV BADAGADA LINGA	14019202	GOURI NAGAR NH SITE	1324DT095	250	MIXED	AMI	Yes	0%	181	0.25413536	0.221776	0.03235936	12.73%
2039	TPCODL	BBSR1	BED	TEMPLE	BADAGADA	14019	11 KV BADAGADA LINGA	14019202	SEVA SADAN	1324DT144	100	MIXED	AMI	Yes	0%	36	0.05943264	0.044836	0.01459664	24.56%
2040	TPCODL	BBSR1	BED	TEMPLE	BADAGADA	14019	11 KV MAUSIMA	14019203	KULAMANI DEO	1321DT067	200	MIXED	AMI	Yes	0%	66	0.08901416	0.079456	0.00955816	10.74%
2041	TPCODL	BBSR1	BED	TEMPLE	BADAGADA	14019	11 KV MAUSIMA	14019203	BAULAGADA	1323DT181	100	MIXED	AMI	Yes	100%	17	0.05937859	0.039377	0.02000159	33.68%
2042	TPCODL	BBSR1	BED	TEMPLE	BADAGADA	14019	11 KV MAUSIMA	14019203	WEST BINDUSAGER	1323DT183	500	MIXED	AMI	Yes	100%	91	0.25954768	0.166679	0.09286868	35.78%
2043	TPCODL	BBSR1	BED	TEMPLE	BADAGADA	14019	11 KV MAUSIMA	14019203	SARUGADIA	1323DT184	250	MIXED	AMI	Yes	100%	40	0.0951708	0.077509	0.0176618	18.56%

Sl. No.	Zone Name	Circle name	Division name	Name of the Sub-division	Name of the Sub-station	Substation Code	Name of the 11 kV Feeder	Feeder Code	Name of the Location where DT situated	DT code	DT Capacity (kVA)	Predominant consumer type of DT (Domestic/Industrial/Agriculture/Mixed)	Type of metering AMR/AMI/ Communicable/Conventional metered/Unmetered	Status of Meter-whether Functional (Yes/No)	% of data received automatically (if AMR/AMI)	No. of Connected Consumers	Input Energy (MU) (A)	Billed Energy (MU) (B)	Loss (MU) (A-B)	% DT Loss (A-B)/A
2044	TPCODL	BBSR1	BED	TEMPLE	BADAGADA	14019	11 KV MAUSIMA	14019203	WEST BINDU SAGER	1323DT188	250	MIXED	AMI	Yes	100%	121	0.12645452	0.116491	0.00996352	7.88%
2045	TPCODL	BBSR1	BED	TEMPLE	BADAGADA	14019	11 KV MAUSIMA	14019203	RAJESH GUGUNANI	1324DT051	100	MIXED	AMI	Yes	0%	2	0.0078408	0.007676	0.0001648	2.10%
2046	TPCODL	BBSR1	BED	TEMPLE	BADAGADA	14019	11 KV MAUSIMA	14019203	SEVA SADAN	1324DT052	250	MIXED	AMI	Yes	0%	72	0.12950244	0.111559	0.01794344	13.86%
2047	TPCODL	BBSR1	BED	TEMPLE	BADAGADA	14019	11 KV MAUSIMA	14019203	DIVYA PRAVA APPT.	1324DT056	500	MIXED	AMI	Yes	0%	48	0.05720288	0.038968	0.01823488	31.88%
2048	TPCODL	BBSR1	BED	TEMPLE	BADAGADA	14019	11 KV MAUSIMA	14019203	NAGESWAR	1324DT064	500	MIXED	AMI	Yes	0%	92	0.2379568	0.132934	0.1050228	44.14%
2049	TPCODL	BBSR1	BED	TEMPLE	BADAGADA	14019	11 KV MAUSIMA	14019203	BEHERA S/S	1324DT066	250	MIXED	AMI	Yes	0%	51	0.14708452	0.087906	0.05917852	40.23%
2050	TPCODL	BBSR1	BED	TEMPLE	BADAGADA	14019	11 KV MAUSIMA	14019203	BALA KRUSHNA DAS	1324DT069	500	MIXED	AMI	Yes	100%	146	0.29774648	0.214856	0.08289048	27.84%
2051	TPCODL	BBSR1	BED	TEMPLE	BADAGADA	14019	11 KV MAUSIMA	14019203	VANDANA APPT.	1324DT071	500	MIXED	AMI	Yes	0%	50	0.0504104	0.035567	0.0148434	29.45%
2052	TPCODL	BBSR1	BED	TEMPLE	BADAGADA	14019	11 KV MAUSIMA	14019203	HARAPRIYA APPT.	1324DT072	500	MIXED	AMI	Yes	0%	40	0.06237704	0.043896	0.01848104	29.63%
2053	TPCODL	BBSR1	BED	TEMPLE	BADAGADA	14019	11 KV MAUSIMA	14019203	VISHWANATH VILLA	1324DT147	500	MIXED	AMI	Yes	0%	68	0.0876016	0.082762	0.0048396	5.52%
2054	TPCODL	BBSR1	BED	TEMPLE	BADAGADA	14019	11 KV MAUSIMA	14019203	KANHUPRIYA RESIDENCY	1324DT190	250	MIXED	AMI	Yes	100%	16	0.02204892	0.020192	0.00185692	8.42%
2055	TPCODL	BBSR1	BED	TEMPLE	BADAGADA	14019	11 KV WATER WORKS	14019204	KASALIVING	1323DT113	250	MIXED	AMI	Yes	100%	236	0.4526696	0.366784	0.0858856	18.97%
2056	TPCODL	BBSR1	BED	TEMPLE	BADAGADA	14019	11 KV WATER WORKS	14019204	JAGGANATH ENCLAVE	1323DT115	250	MIXED	AMI	Yes	0%	31	0.03400772	0.023491	0.01051672	30.92%
2057	TPCODL	BBSR1	BED	TEMPLE	BADAGADA	14019	11 KV WATER WORKS	14019204	UP SCHOOL SAMATARPUR	1323DT117	500	MIXED	AMI	Yes	100%	294	0.40119392	0.331082	0.07011192	17.48%
2058	TPCODL	BBSR1	BED	TEMPLE	BADAGADA	14019	11 KV WATER WORKS	14019204	VICHAL CITY	1323DT121	250	MIXED	AMI	Yes	100%	92	0.14941792	0.135001	0.01441692	9.65%
2059	TPCODL	BBSR1	BED	TEMPLE	BADAGADA	14019	11 KV WATER WORKS	14019204	APSANA GARDEN	1323DT122	250	MIXED	AMI	Yes	100%	166	0.1576292	0.128133	0.0294962	18.71%
2060	TPCODL	BBSR1	BED	TEMPLE	BADAGADA	14019	11 KV BADAGADA	14019205	MANGALA MANDIR	1321DT116	500	MIXED	AMI	Yes	100%	276	0.33062952	0.259832	0.07079752	21.41%
2061	TPCODL	BBSR1	BED	TEMPLE	BADAGADA	14019	11 KV BADAGADA	14019205	PANDAP GUMPHA	1321DT117	500	MIXED	AMI	Yes	100%	273	0.27850568	0.254151	0.02435468	8.74%
2062	TPCODL	BBSR1	BED	TEMPLE	BADAGADA	14019	11 KV BADAGADA	14019205	GHO PADIA, RAPDRP	1321DT121	250	MIXED	AMI	Yes	67%	198	0.2126122	0.180388	0.0322242	15.16%
2063	TPCODL	BBSR1	BED	TEMPLE	BADAGADA	14019	11 KV BADAGADA	14019205	NETRA	1321DT125	500	MIXED	AMI	Yes	100%	184	0.29480312	0.196771	0.09803212	33.25%
2064	TPCODL	BBSR1	BED	TEMPLE	BADAGADA	14019	11 KV BADAGADA	14019205	LENKA	1321DT128	250	MIXED	AMI	Yes	100%	84	0.20072756	0.079626	0.12110156	60.33%
2065	TPCODL	BBSR1	BED	TEMPLE	BADAGADA	14019	11 KV BADAGADA	14019205	NETAJI	1321DT130	500	MIXED	AMI	Yes	100%	126	0.3144064	0.08915	0.2252564	71.64%
2066	TPCODL	BBSR1	BED	TEMPLE	BADAGADA	14019	11 KV BADAGADA	14019205	JHARNA SHI	1321DT144	250	MIXED	AMI	Yes	100%	158	0.23177708	0.209915	0.02186208	9.43%
2067	TPCODL	BBSR1	BED	TEMPLE	BADAGADA	14019	11 KV BADAGADA	14019205	POST OFFICE, MB-LANE	1321DT145	100	MIXED	AMI	Yes	100%	61	0.10805756	0.06588	0.04217756	39.03%
2068	TPCODL	BBSR1	BED	TEMPLE	BADAGADA	14019	11 KV BADAGADA	14019205	MA BRIT COLONY	1321DT147	250	MIXED	AMI	Yes	0%	130	0.16738436	0.144427	0.02295736	13.72%
2069	TPCODL	BBSR1	BED	TEMPLE	BADAGADA	14019	11 KV BADAGADA	14019205	BHASKARSWAR TEMPLE	1321DT148	500	MIXED	AMI	Yes	33%	285	0.3196544	0.25514	0.0645144	20.18%
2070	TPCODL	BBSR1	BED	TEMPLE	BADAGADA	14019	11 KV BADAGADA	14019205	MASHANI	1321DT151	250	MIXED	AMI	Yes	0%	126	0.13805424	0.10527	0.03278424	23.75%
2071	TPCODL	BBSR1	BED	TEMPLE	BADAGADA	14019	11 KV BADAGADA	14019205	RAY PROJECT MAISHI KHALS	1321DT160	500	MIXED	AMI	Yes	0%	209	0.17405944	0.061988	0.11207144	64.39%
2072	TPCODL	BBSR1	BED	TEMPLE	BADAGADA	14019	11 KV B.J.B NAGAR	14019206	D-7 BJB NAGAR	1321DT008	250	MIXED	AMI	Yes	100%	12	0.0270986	0.018467	0.0086316	31.85%
2073	TPCODL	BBSR1	BED	TEMPLE	BADAGADA	14019	11 KV B.J.B NAGAR	14019206	AMBIKA EMERCLD	1321DT010	250	MIXED	AMI	Yes	100%	15	0.02892292	0.027692	0.00123092	4.26%
2074	TPCODL	BBSR1	BED	TEMPLE	BADAGADA	14019	11 KV B.J.B NAGAR	14019206	BARAGADA HIGH SCHOOL	1321DT043	500	MIXED	AMI	Yes	100%	276	0.50826264	0.33664	0.17162264	33.77%
2075	TPCODL	BBSR1	BED	TEMPLE	BADAGADA	14019	11 KV B.J.B NAGAR	14019206	BARAGADA NUASAHI	1321DT045	500	MIXED	AMI	Yes	100%	273	0.35290544	0.306771	0.04613444	13.07%
2076	TPCODL	BBSR1	BED	TEMPLE	BADAGADA	14019	11 KV B.J.B NAGAR	14019206	IRRIGATION COLONY BJB NAGAR	1321DT050	500	MIXED	AMI	Yes	100%	111	0.12490088	0.093138	0.03176288	25.43%
2077	TPCODL	BBSR1	BED	TEMPLE	BADAGADA	14019	11 KV SAI	14019207	WRCP COLONY	1321DT225	250	MIXED	AMI	Yes	100%	86	0.06242384	0.044038	0.01838584	29.45%
2078	TPCODL	BBSR1	BED	TEMPLE	BADAGADA	14019	11 KV SAI	14019207	BANK COLONY	1321DT229	250	MIXED	AMI	Yes	100%	87	0.164555	0.097641	0.066914	40.66%
2079	TPCODL	BBSR1	BED	TEMPLE	BADAGADA	14019	11 KV SAI	14019207	JAGANNATH ASHRAM	1321DT240	100	MIXED	AMI	Yes	0%	44	0.09683552	0.065855	0.03098052	31.99%
2080	TPCODL	BBSR1	BED	TEMPLE	BADAGADA	14019	11 KV RAJARANI	14019208	SOMYA ENCLAVE	1321DT070	250	MIXED	AMI	Yes	100%	22	0.04145364	0.035789	0.00566464	13.67%
2081	TPCODL	BBSR1	BED	TEMPLE	BADAGADA	14019	11 KV RAJARANI	14019208	TS MISHRA	1321DT078	200	MIXED	AMI	Yes	0%	16	0.05148076	0.01976	0.03172076	61.62%
2082	TPCODL	BBSR1	BED	TEMPLE	BADAGADA	14019	11 KV RAJARANI	14019208	BHOI SHAI	1324DT124	250	MIXED	AMI	Yes	100%	109	0.16831716	0.124779	0.04353816	25.87%
2083	TPCODL	BBSR1	BED	TEMPLE	BADAGADA	14019	11 KV RAJARANI	14019208	MACHHA HATA	1324DT127	500	MIXED	AMI	Yes	100%	77	0.28512672	0.155545	0.12958172	45.45%
2084	TPCODL	BBSR1	BED	TEMPLE	BADAGADA	14019	11 KV RAJARANI	14019208	KEDARGOURI VIHAR(MESCO STEEL)	1324DT141	500	MIXED	AMI	Yes	100%	165	0.31940184	0.278356	0.04104584	12.85%
2085	TPCODL	BBSR1	BED	TEMPLE	BADAGADA	14019	11 KV BHUASUNI	14019209	KEDARGOURI APARTMENT	1323DT202	500	MIXED	AMI	Yes	100%	266	0.2106048	0.200708	0.0098968	4.70%
2086	TPCODL	BBSR1	BED	TEMPLE	BADAGADA	14019	11 KV BHUASUNI	14019209	TULSHI VILLA	1323DT203	100	MIXED	AMI	Yes	100%	20	0.02812546	0.018572	0.00955346	33.97%
2087	TPCODL	BBSR1	BED	TEMPLE	BADAGADA	14019	11 KV BHUASUNI	14019209	BISAL ENCLAVE	1323DT206	250	MIXED	AMI	Yes	0%	32	0.08814556	0.023577	0.06456856	73.25%
2088	TPCODL	BBSR1	BED	TEMPLE	BADAGADA	14019	11 KV BHUASUNI	14019209	EKAMRA RESIDENCY	1323DT212	100	MIXED	AMI	Yes	0%	13	0.0170218	0.013792	0.0032298	18.97%
2089	TPCODL	BBSR1	BED	TEMPLE	BADAGADA	14019	11 KV BHUASUNI	14019209	EKAMRA RESIDENCY 2	1323DT213	250	MIXED	AMI	Yes	100%	27	0.05926408	0.041378	0.01788608	30.18%
2090	TPCODL	BBSR1	BED	TEMPLE	BADAGADA	14019	11 KV BHUASUNI	14019209	MAHAVIR NAGAR	1323DT219	250	MIXED	AMI	Yes	67%	246	0.31729124	0.297741	0.01955024	6.16%
2091	TPCODL	BBSR1	BED	TEMPLE	BADAGADA	14019	11 KV BHUASUNI	14019209	MAHAVIR NAGAR	1323DT220	500	MIXED	AMI	Yes	0%	263	0.38584824	0.31163	0.07421824	19.24%
2092	TPCODL	BBSR1	BED	TEMPLE	BADAGADA	14019	11 KV BHUASUNI	14019209	OPPOSIDE BOI	1323DT221	100	MIXED	AMI	Yes	100%	4	0.0105964	0.009895	0.0007014	6.62%
2093	TPCODL	BBSR1	BED	TEMPLE	BADAGADA	14019	11 KV BHUASUNI	14019209	GARAGE CHHAK	1323DT232	250	MIXED	AMI	Yes	100%	104	0.19614248	0.157723	0.03841948	19.59%
2094	TPCODL	BBSR1	BED	TEMPLE	BADAGADA	14019	11 KV GOUTAM NAGAR	14019210	UTKAL BUILDERS (A)	1324DT013	500	MIXED	AMI	Yes	0%	39	0.11592424	0.064906	0.05101824	44.01%
2095	TPCODL	BBSR1	BED	TEMPLE	BADAGADA	14019	11 KV GOUTAM NAGAR	14019210	PMU	1324DT022	250	MIXED	AMI	Yes	100%	62	0.15656304	0.094788	0.06177504	39.46%
2096	TPCODL	BBSR1	BED	TEMPLE	BADAGADA	14019	11 KV RMU-21	14019212	SATYA SAI APPT.	1324DT117	250	MIXED	AMI	Yes	0%	62	0.09929088	0.079607	0.01968388	19.82%
2097	TPCODL	BBSR1	BED	TEMPLE	BHIMATANGI	14018	11 KV POKHARIPUT-1	14018201	KALUNANDA NAGAR	1322DT078	100	MIXED	AMI	Yes	0%	50	0.06216733	0.045112	0.01705533	27.43%
2098	TPCODL	BBSR1	BED	TEMPLE	BHIMATANGI	14018	11 KV POKHARIPUT-1	14018201	KOKILA GARDEN PH-2 (B)	1322DT091	500	MIXED	AMI	Yes	0%	43	0.09663208	0.036488	0.06014408	62.24%
2099	TPCODL	BBSR1	BED	TEMPLE	BHIMATANGI	14018	11 KV POKHARIPUT-1	14018201	KOKILA GARDEN PH-2 (D)	1322DT093	500	MIXED	AMI	Yes	0%	44	0.072708	0.058266	0.014442	19.86%
2100	TPCODL	BBSR1	BED	TEMPLE	BHIMATANGI	14018	11 KV POKHARIPUT-1	14018201	PRESTINE GREEN-1	1322DT095	500	MIXED	AMI	Yes	0%	42	0.169164	0.127825	0.041339	24.44%
2101	TPCODL	BBSR1	BED	TEMPLE	BHIMATANGI	14018	11 KV POKHARIPUT-1	14018201	PRESTINE GREEN-2	1322DT096	500	MIXED	AMI	Yes	0%	34	0.10160184	0.071981	0.02962084	29.15%
2102	TPCODL	BBSR1	BED	TEMPLE	BHIMATANGI	14018	11 KV POKHARIPUT-1	14018201	POKHARIPUT MASANI	1322DT102	250	MIXED	AMI	Yes	100%	154	0.18290568	0.173091	0.00981468	5.37%
2103	TPCODL	BBSR1	BED	TEMPLE	BHIMATANGI	14018	11 KV POKHARIPUT-1	14018201	INDRAPRASTA PH 2 (A)	1322DT112	500	MIXED	AMI	Yes	100%	159	0.16475332	0.153685	0.01106832	6.72%
2104	TPCODL	BBSR1	BED	TEMPLE	BHIMATANGI	14018	11 KV POKHARIPUT-1	14018201	INDRAPRASTA PH 2 (B)	1322DT113	250	MIXED	AMI	Yes	100%	56	0.10686276	0.073892	0.03297076	30.85%
2105	TPCODL	BBSR1	BED	TEMPLE	BHIMATANGI	14018	11 KV POKHARIPUT-1	14018201	INDRAPRASTA PH 2 RAPDRP	1322DT114	250	MIXED	AMI	Yes	100%	112	0.18131304	0.139757	0.04155604	22.92%
2106	TPCODL	BBSR1	BED	TEMPLE	BHIMATANGI	14018	11 KV POKHARIPUT-1	14018201	KOKILA ENCLAVE PH-1	1322DT116	100	MIXED	AMI	Yes	100%	19	0.02633958	0.021993	0.00434658	16.50%
2107	TPCODL	BBSR1	BED	TEMPLE	BHIMATANGI	14018	11 KV POKHARIPUT-1	14018201	POKHARIPUT ITI	1322DT121	100	MIXED	AMI	Yes	100%	6	0.02771782	0.019577	0.00814082	29.37%
2108	TPCODL	BBSR1	BED	TEMPLE	BHIMATANGI	14018	11 KV POKHARIPUT-1	14018201	ANANTA VIHAR PH-2	1322DT126	500	MIXED	AMI	Yes	0%	81	0.23990944	0.104276	0.13563344	56.54%
2109	TPCODL	BBSR1	BED	TEMPLE	BHIMATANGI	14018	11 KV POKHARIPUT-1	14018201	BAISHNO VIHAR RAPDRP	1322DT128	250	MIXED	AMI	Yes	0%	69	0.13431112	0.061738	0.07257312	54.03%
2110	TPCODL	BBSR1	BED	TEMPLE	BHIMATANGI	14018	11 KV POKHARIPUT-1	14018201	LINGARAJ VIHAR -1	1322DT158	500	MIXED	AMI	Yes	0%	92	0.1960318	0.0886	0.1074318	54.80%
2111	TPCODL	BBSR1	BED	TEMPLE	BHIMATANGI	14018	11 KV LINGARAJ	14018202	NANDA ENCLAVE	1322DT030	250	MIXED	AMI	Yes	100%	24	0.03641688	0.023666	0.01275088	35.01%
2112	TPCODL	BBSR1	BED	TEMPLE	BHIMATANGI	14018	11 KV LINGARAJ	14018202	SUNDARAPADA CANAL CHHAKA	1322DT049	500	MIXED	AMI	Yes	100%	541	0.56719816	0.490673	0.07652516	13.49%
2113	TPCODL	BBSR1	BED	TEMPLE	BHIMATANGI	14018	11 KV LINGARAJ	14018202	FOOT BALL FIELD RAPDRP	1322DT071	100	MIXED	AMI	Yes	67%	75	0.06485627	0.046431	0.01842527	28.41%
2114	TPCODL	BBSR1	BED	TEMPLE	BHIMATANGI	14018	11 KV BHIMATANGI	14018203	BDA SQUARE RAPDRP	1322DT008	100	MIXED	AMI	Yes	0%	112	0.1479002	0.103146	0.0447542	30.26%
2115	TPCODL	BBSR1	BED	TEMPLE	BHIMATANGI	14018	11 KV BHIMATANGI	14018203	OSHB COLONY (ROLL PALACE)	1322DT009	500	MIXED	AMI	Yes	100%	235	0.30165304	0.241712	0.05994104	19.87%
2116	TPCODL	BBSR1	BED	TEMPLE	BHIMATANGI	14018	11 KV BHIMATANGI	14018203	KELU MOHAPATRA LANE	1322DT010	100	MIXED	AMI	Yes	0%	39	0.09636252	0.048672	0.04769052	49.49%

Sl. No.	Zone Name	Circle name	Division name	Name of the Sub-division	Name of the Sub-station	Substation Code	Name of the 11 kV Feeder	Feeder Code	Name of the Location where DT situated	DT code	DT Capacity (kVA)	Predominant consumer type of DT (Domestic/Industrial/Agriculture/Mixed)	Type of metering AMR/AMI/ Communicable/Conventional metered/Unmetered	Status of Meter-whether Functional (Yes/No)	% of data received automatically (if AMR/AMI)	No. of Connected Consumers	Input Energy (MU) (A)	Billed Energy (MU) (B)	Loss (MU) (A-B)	% DT Loss (A-B)/A
2117	TPCODL	BBSR1	BED	TEMPLE	BHIMATANGI	14018	11 KV BHIMATANGI	14018203	TANTIKATA-Ãi	1322DT018	500	MIXED	AMI	Yes	100%	240	0.3262996	0.238668	0.0876316	26.86%
2118	TPCODL	BBSR1	BED	TEMPLE	BHIMATANGI	14018	11 KV BHIMATANGI	14018203	BAUNSAKHANI-1	1322DT020	250	MIXED	AMI	Yes	0%	155	0.21157804	0.161683	0.04989504	23.58%
2119	TPCODL	BBSR1	BED	TEMPLE	BHIMATANGI	14018	11 KV BHIMATANGI	14018203	BAUNSAKHANI-2	1322DT021	250	MIXED	AMI	Yes	67%	117	0.18535448	0.130559	0.05479548	29.56%
2120	TPCODL	BBSR1	BED	TEMPLE	BHIMATANGI	14018	11 KV BHIMATANGI	14018203	ALAKA DAS(ALAKA DAS LANE)	1322DT025	500	MIXED	AMI	Yes	100%	176	0.33105952	0.192047	0.13901252	41.99%
2121	TPCODL	BBSR1	BED	TEMPLE	BHIMATANGI	14018	11 KV BHIMATANGI	14018203	OSHB PUNAMA GATE	1322DT027	250	MIXED	AMI	Yes	0%	140	0.25286004	0.15758	0.09528004	37.68%
2122	TPCODL	BBSR1	BED	TEMPLE	BHIMATANGI	14018	11 KV R.E JAMUKOLI	14018204	TRILOCHAN VIHAR	1322DT173	100	MIXED	AMI	Yes	0%	93	0.18776955	0.10645	0.08131955	43.31%
2123	TPCODL	BBSR1	BED	TEMPLE	BHIMATANGI	14018	11 KV R.E JAMUKOLI	14018204	JAGANATH VILLA -2	1322DT176	100	MIXED	AMI	Yes	100%	110	0.1129467	0.090789	0.0221577	19.62%
2124	TPCODL	BBSR1	BED	TEMPLE	BHIMATANGI	14018	11 KV R.E JAMUKOLI	14018204	GOURI DHAM	1322DT177	250	MIXED	AMI	Yes	100%	129	0.16534068	0.122566	0.04277468	25.87%
2125	TPCODL	BBSR1	BED	TEMPLE	BHIMATANGI	14018	11 KV R.E JAMUKOLI	14018204	SEFALI APARTMENT	1322DT186	250	MIXED	AMI	Yes	0%	17	0.0181954	0.0114	0.0067954	37.35%
2126	TPCODL	BBSR1	BED	TEMPLE	BHIMATANGI	14018	11 KV R.E JAMUKOLI	14018204	GAYATRI VIHAR RAPDRP	1322DT196	250	MIXED	AMI	Yes	100%	212	0.1912258	0.178043	0.0131828	6.89%
2127	TPCODL	BBSR1	BED	TEMPLE	BHIMATANGI	14018	11 KV R.E JAMUKOLI	14018204	SURYATAPA APARTMENT	1322DT201	500	MIXED	AMI	Yes	0%	45	0.05279068	0.047584	0.00520668	9.86%
2128	TPCODL	BBSR1	BED	TEMPLE	BHIMATANGI	14018	11 KV R.E JAMUKOLI	14018204	M.F TAFAZUL	1322DT208	100	MIXED	AMI	Yes	0%	15	0.01284996	0.008921	0.00392896	30.58%
2129	TPCODL	BBSR1	BED	TEMPLE	BHIMATANGI	14018	11 KV R.E JAMUKOLI	14018204	JAGANNATH RESIDENCY	1322DT220	500	MIXED	AMI	Yes	0%	17	0.05137248	0.020904	0.03046848	59.31%
2130	TPCODL	BBSR1	BED	TEMPLE	BHIMATANGI	14018	11 KV R.E JAMUKOLI	14018204	ROYAL VILLA DUPLEX	1322DT223	250	MIXED	AMI	Yes	100%	10	0.04270272	0.019247	0.02345572	54.93%
2131	TPCODL	BBSR1	BED	TEMPLE	BHIMATANGI	14018	11 KV R.E JAMUKOLI	14018204	BALABHADRA TOWER	1322DT224	500	MIXED	AMI	Yes	0%	29	0.04516712	0.022787	0.02238012	49.55%
2132	TPCODL	BBSR1	BED	TEMPLE	BHIMATANGI	14018	11 KV R.E JAMUKOLI	14018204	NV HEIGHTS	1322DT225	500	MIXED	AMI	Yes	0%	60	0.04753048	0.036079	0.01145148	24.09%
2133	TPCODL	BBSR1	BED	TEMPLE	BHIMATANGI	14018	11 KV R.E JAMUKOLI	14018204	BISWAJAYA ARYAN NAGAR	1322DT228	100	MIXED	AMI	Yes	67%	100	0.13241696	0.081388	0.05102896	38.54%
2134	TPCODL	BBSR1	BED	TEMPLE	BHIMATANGI	14018	11 KV R.E JAMUKOLI	14018204	THE PRESTIGE -2	1322DT233	500	MIXED	AMI	Yes	100%	16	0.02963264	0.020091	0.00954164	32.20%
2135	TPCODL	BBSR1	BED	TEMPLE	BHIMATANGI	14018	11 KV R.E JAMUKOLI	14018204	BESIDE OF BABU SINGH CONSTRUCTI	1322DT239	100	MIXED	AMI	Yes	0%	34	0.11183868	0.034731	0.07710768	68.95%
2136	TPCODL	BBSR1	BED	TEMPLE	BHIMATANGI	14018	11 KV R.E JAMUKOLI	14018204	BAISHNO MATA GREEN HOME	1322DT246	500	MIXED	AMI	Yes	100%	36	0.0465842	0.033963	0.0126212	27.09%
2137	TPCODL	BBSR1	BED	TEMPLE	BHIMATANGI	14018	11 KV R.E JAMUKOLI	14018204	BAJRANG BIHAR MP LAD	1322DT249	100	MIXED	AMI	Yes	100%	47	0.05735914	0.04444	0.01291914	22.52%
2138	TPCODL	BBSR1	BED	TEMPLE	BHIMATANGI	14018	11 KV R.E JAMUKOLI	14018204	HAREKRISHNA VILLA	1322DT252	250	MIXED	AMI	Yes	0%	48	0.06098048	0.037279	0.02370148	38.87%
2139	TPCODL	BBSR1	BED	TEMPLE	BHIMATANGI	14018	11 KV R.E JAMUKOLI	14018204	PRAMOD KU SAHU	1322DT262	100	MIXED	AMI	Yes	100%	15	0.01350064	0.008786	0.00471464	34.92%
2140	TPCODL	BBSR1	BED	TEMPLE	BHIMATANGI	14018	11 KV R.E JAMUKOLI	14018204	SAI KRISHNA VIHAR	1322DT265	100	MIXED	AMI	Yes	100%	11	0.01374222	0.006635	0.00710722	51.72%
2141	TPCODL	BBSR1	BED	TEMPLE	BHIMATANGI	14018	11 KV R.E JAMUKOLI	14018204	RAJEEV BISWAL (LAXMI BIHAR)	1322DT270	100	MIXED	AMI	Yes	100%	34	0.04166954	0.027541	0.01412854	33.91%
2142	TPCODL	BBSR1	BED	TEMPLE	BHIMATANGI	14018	11 KV R.E JAMUKOLI	14018204	GANGA JAMUNA	1322DT277	500	MIXED	AMI	Yes	100%	80	0.08294872	0.053999	0.02894972	34.90%
2143	TPCODL	BBSR1	BED	TEMPLE	BHIMATANGI	14018	11 KV R.E JAMUKOLI	14018204	MONSOON VALLY -1	1322DT288	500	MIXED	AMI	Yes	0%	84	0.0906942	0.049051	0.0416432	45.92%
2144	TPCODL	BBSR1	BED	TEMPLE	BHIMATANGI	14018	11 KV R.E JAMUKOLI	14018204	MONSOON VALLY -2	1322DT289	500	MIXED	AMI	Yes	100%	51	0.06175372	0.034211	0.02754272	44.60%
2145	TPCODL	BBSR1	BED	TEMPLE	BHIMATANGI	14018	11 KV R.E JAMUKOLI	14018204	JUTHI COTAGE	1322DT344	100	MIXED	AMI	Yes	100%	7	0.00740396	0.003795	0.00360896	48.74%
2146	TPCODL	BBSR1	BED	TEMPLE	BHIMATANGI	14018	11 KV R.E JAMUKOLI	14018204	ARADHANA NAGAR -2	1322DT543	250	MIXED	AMI	Yes	0%	221	0.25929552	0.204221	0.05507452	21.24%
2147	TPCODL	BBSR1	BED	TEMPLE	BHIMATANGI	14018	11 KV R.E JAMUKOLI	14018204	HATA SAHI BOTANDA	1322DT556	100	MIXED	AMI	Yes	100%	8	0.0155339	0.004827	0.0107069	68.93%
2148	TPCODL	BBSR1	BED	TEMPLE	BHIMATANGI	14018	11 KV R.E JAMUKOLI	14018204	SAI GREEN EX	1322DT558	100	MIXED	AMI	Yes	100%	20	0.02537768	0.007389	0.01798868	70.88%
2149	TPCODL	BBSR1	BED	TEMPLE	BHIMATANGI	14018	11 KV R.E JAMUKOLI	14018204	HITECH RECIDENCY	1322DT561	500	MIXED	AMI	Yes	100%	66	0.03941352	0.029432	0.00998152	25.33%
2150	TPCODL	BBSR1	BED	TEMPLE	BHIMATANGI	14018	11 KV R.E JAMUKOLI	14018204	None	1322DT562	500	MIXED	AMI	Yes	100%	36	0.03164696	0.015751	0.01589596	50.23%
2151	TPCODL	BBSR1	BED	TEMPLE	BHIMATANGI	14018	11 KV R.E JAMUKOLI	14018204	MR PRIYABRAT SWAIN	1322DT609	100	MIXED	AMI	Yes	67%	50	0.04897004	0.031943	0.01702704	34.77%
2152	TPCODL	BBSR1	BED	TEMPLE	BHIMATANGI	14018	11 KV R.E JAMUKOLI	14018204	ASHOKA VATIKA	1322DT639	500	MIXED	AMI	Yes	100%	6	0.02005464	0.00471	0.01534464	76.51%
2153	TPCODL	BBSR1	BED	TEMPLE	BHIMATANGI	14018	11 KV POKHARIPUT-2	14018205	LINGARA VIHAR RAPDRP	1322DT144	250	MIXED	AMI	Yes	0%	108	0.10691524	0.07722	0.02969524	27.77%
2154	TPCODL	BBSR1	BED	TEMPLE	BHIMATANGI	14018	11 KV POKHARIPUT-2	14018205	LINGARAJ VIHAR 4	1322DT146	250	MIXED	AMI	Yes	0%	196	0.2212785	0.171441	0.0498375	22.52%
2155	TPCODL	BBSR1	BED	TEMPLE	BHIMATANGI	14018	11 KV POKHARIPUT-2	14018205	KARGIL BASTI (MAHAVIR SAHI SOUBH	1322DT152	100	MIXED	AMI	Yes	0%	95	0.06242898	0.040717	0.02171198	34.78%
2156	TPCODL	BBSR1	BED	TEMPLE	BHIMATANGI	14018	11 KV POKHARIPUT-2	14018205	KARGIL ROAD	1322DT154	100	MIXED	AMI	Yes	0%	37	0.05858682	0.036998	0.02158882	36.85%
2157	TPCODL	BBSR1	BED	TEMPLE	BHIMATANGI	14018	11 KV POKHARIPUT-2	14018205	KARGIL ROAD RAPDRP	1322DT156	100	MIXED	AMI	Yes	0%	107	0.07013744	0.051482	0.01865544	26.60%
2158	TPCODL	BBSR1	BED	TEMPLE	BHIMATANGI	14018	11 KV POKHARIPUT-2	14018205	POKHIRIPUT BDA PH-1 (B)	1322DT162	250	MIXED	AMI	Yes	100%	60	0.17935768	0.071746	0.10761168	60.00%
2159	TPCODL	BBSR1	BED	TEMPLE	BHIMATANGI	14018	11 KV POKHARIPUT-2	14018205	ANANTA VIHAR MARKET COMPLEX	1322DT166	100	MIXED	AMI	Yes	100%	17	0.05248754	0.013063	0.03942454	75.11%
2160	TPCODL	BBSR1	BED	TEMPLE	BHIMATANGI	14018	11 KV POKHARIPUT-2	14018205	POKHIRIPUT VILLAGE	1322DT167	250	MIXED	AMI	Yes	100%	40	0.13310304	0.07317	0.05993304	45.03%
2161	TPCODL	BBSR1	BED	TEMPLE	BHIMATANGI	14018	11 KV POKHARIPUT-2	14018205	ANANTA VIHAR PH-2 (DUPLEX A)	1322DT168	250	MIXED	AMI	Yes	67%	58	0.12515168	0.066983	0.05816868	46.48%
2162	TPCODL	BBSR1	BED	TEMPLE	LINGIPUR ODSSP	14244	11 KV SISHUPALA GADA	14244201	SAKTI NAGAR	1323DT020	250	MIXED	AMI	Yes	100%	177	0.23059712	0.150926	0.07967112	34.55%
2163	TPCODL	BBSR1	BED	TEMPLE	LINGIPUR ODSSP	14244	11 KV KUAKHAI	14244202	MAHULAGADA	1321DT304	100	MIXED	AMI	Yes	0%	108	0.08943136	0.060277	0.02915436	32.60%
2164	TPCODL	BBSR1	BED	TEMPLE	LINGIPUR ODSSP	14244	11 KV KUAKHAI	14244202	SAMNTARAY NEAR BRIDGE	1321DT328	100	MIXED	AMI	Yes	100%	12	0.02423824	0.015739	0.00849924	35.07%
2165	TPCODL	BBSR1	BED	TEMPLE	LINGIPUR ODSSP	14244	11 KV KUAKHAI	14244202	KALPANA RIVERVIEW1	1321DT331	500	MIXED	AMI	Yes	0%	96	0.07095744	0.050799	0.02015844	28.41%
2166	TPCODL	BBSR1	BED	TEMPLE	LINGIPUR ODSSP	14244	11 KV KUAKHAI	14244202	KALPANA RIVER VIEW2	1321DT332	250	MIXED	AMI	Yes	0%	36	0.01860572	0.015235	0.00337072	18.12%
2167	TPCODL	BBSR1	BED	TEMPLE	LINGIPUR ODSSP	14244	11 KV KUAKHAI	14244202	LAXMIVIHAR2	1321DT334	100	MIXED	AMI	Yes	100%	17	0.02129628	0.011704	0.00959228	45.04%
2168	TPCODL	BBSR1	BED	TEMPLE	LINGIPUR ODSSP	14244	11 KV KUAKHAI	14244202	BADADHANPUR	1321DT339	250	MIXED	AMI	Yes	100%	85	0.09318472	0.058295	0.03488972	37.44%
2169	TPCODL	BBSR1	BED	TEMPLE	LINGIPUR ODSSP	14244	11 KV KUAKHAI	14244202	ELEGANCE VILLA	1321DT358	250	MIXED	AMI	Yes	100%	116	0.15210371	0.124798	0.02730571	17.95%
2170	TPCODL	BBSR1	BED	TEMPLE	LINGIPUR ODSSP	14244	11 KV CIFA	14244203	SANTHA BIHAR	1323DT098	500	MIXED	AMI	Yes	100%	297	0.32587848	0.263289	0.06258948	19.21%
2171	TPCODL	BBSR1	BED	TEMPLE	LINGIPUR ODSSP	14244	11 KV CIFA	14244203	LINGIPUR CANEL BAANDHA	1323DT101	100	MIXED	AMI	Yes	100%	29	0.04033906	0.031948	0.00839106	20.80%
2172	TPCODL	BBSR1	BED	TEMPLE	LINGIPUR ODSSP	14244	11 KV GANGUA	14244204	JANANI HOSPITAL	1323DT049	250	MIXED	AMI	Yes	100%	19	0.02105524	0.011225	0.00983024	46.69%
2173	TPCODL	BBSR1	BED	TEMPLE	LINGIPUR ODSSP	14244	11 KV GANGUA	14244204	NELCO COLONY	1323DT062	100	MIXED	AMI	Yes	100%	18	0.0365573	0.03396	0.0025973	7.10%
2174	TPCODL	BBSR1	BED	TEMPLE	LINGIPUR ODSSP	14244	11 KV GANGUA	14244204	GANGOTRI NAGAR2	1323DT075	200	MIXED	AMI	Yes	100%	119	0.18901448	0.137583	0.05143148	27.21%
2175	TPCODL	BBSR1	BED	TEMPLE	LINGIPUR ODSSP	14244	11 KV GANGUA	14244204	GANGOTRI NAGAR LANE32	1323DT077	500	MIXED	AMI	Yes	100%	219	0.37521972	0.211529	0.16369072	43.63%
2176	TPCODL	BBSR1	BED	TEMPLE	LINGIPUR ODSSP	14244	11 KV GANGUA	14244204	SISHUPAL PANCHAYAT	1323DT082	500	MIXED	AMI	Yes	100%	199	0.27621368	0.180896	0.09531768	34.51%
2177	TPCODL	BBSR1	BED	TEMPLE	LINGIPUR ODSSP	14244	11 KV GANGUA	14244204	L T	1323DT083	100	MIXED	AMI	Yes	67%	56	0.0913636	0.059467	0.0318966	34.91%
2178	TPCODL	BBSR1	BED	TEMPLE	LINGIPUR ODSSP	14244	11 KV GANGUA	14244204	ANU VIHAR	1323DT085	100	MIXED	AMI	Yes	0%	27	0.03425848	0.026993	0.00726548	21.21%
2179	TPCODL	BBSR1	BED	TEMPLE	MULAPADIA ODSSP	14252	11 KV KAPILESWAR	14252201	KUMBIHAR SANI	1325DT002	250	MIXED	AMI	Yes	100%	123	0.19596992	0.114336	0.08163392	41.66%
2180	TPCODL	BBSR1	BED	TEMPLE	MULAPADIA ODSSP	14252	11 KV KAPILESWAR	14252201	KAPILASWAR TEMPLE	1325DT007	100	MIXED	AMI	Yes	100%	26	0.06221804	0.026891	0.03532704	56.78%
2181	TPCODL	BBSR1	BED	TEMPLE	MULAPADIA ODSSP	14252	11 KV KAPILESWAR	14252201	KAPILASWAR CANEL-2	1325DT009	250	MIXED	AMI	Yes	100%	170	0.22173832	0.199197	0.02254132	10.17%
2182	TPCODL	BBSR1	BED	TEMPLE	MULAPADIA ODSSP	14252	11 KV KAPILESWAR	14252201	VETNARY SUB-2	1325DT012	250	MIXED	AMI	Yes	100%	170	0.24320755	0.155788	0.08741955	35.94%
2183	TPCODL	BBSR1	BED	TEMPLE	MULAPADIA ODSSP	14252	11 KV KAPILESWAR	14252201	GURUSANGA MATHA-2	1325DT016	250	MIXED	AMI	Yes	100%	135	0.17419804	0.167006	0.00719204	4.13%
2184	TPCODL	BBSR1	BED	TEMPLE	MULAPADIA ODSSP	14252	11 KV KAPILESWAR	14252201	RUCHIKA	1325DT017	500	MIXED	AMI	Yes	100%	131	0.27776112	0.181973	0.09578812	34.49%
2185	TPCODL	BBSR1	BED	TEMPLE	MULAPADIA ODSSP	14252	11 KV KAPILESWAR	14252201	NIGAM VIHAR	1325DT022	100	MIXED	AMI	Yes	100%	51	0.07165914	0.059432	0.01222714	17.06%
2186	TPCODL	BBSR1	BED	TEMPLE	MULAPADIA ODSSP	14252	11 KV MAHAVIR COTTAG	14252202	OLD STATE BANK-1	1325DT052	500	MIXED	AMI	Yes	100%	230	0.31580888	0.307895	0.00791388	2.51%
2187	TPCODL	BBSR1	BED	TEMPLE	MULAPADIA ODSSP	14252	11 KV MAHAVIR COTTAG	14252202	HARIHAR LIFE STYLE	1325DT054	250	MIXED	AMI	Yes	0%	14	0.022257	0.018943	0.003314	14.89%
2188	TPCODL	BBSR1	BED	TEMPLE	MULAPADIA ODSSP	14252	11 KV MAHAVIR COTTAG	14252202	BARSA	1325DT057	100	MIXED	AMI	Yes	100%	7	0.02649726	0.008362	0.01813526	68.44%
2189	TPCODL	BBSR1	BED	TEMPLE	MULAPADIA ODSSP	14252	11 KV MAHAVIR COTTAG	14252202	NANI SUB	1325DT059	250	MIXED	AMI	Yes	100%	64	0.22073972	0.089738	0.13100172	59.35%

Sl. No.	Zone Name	Circle name	Division name	Name of the Sub-division	Name of the Sub-station	Substation Code	Name of the 11 kV Feeder	Feeder Code	Name of the Location where DT situated	DT code	DT Capacity (kVA)	Predominant consumer type of DT (Domestic/Industrial/Agriculture/Mixed)	Type of metering AMR/AMI/ Communicable/Conventional metered/Unmetered	Status of Meter-whether Functional (Yes/No)	% of data received automatically (if AMR/AMI)	No. of Connected Consumers	Input Energy (MU) (A)	Billed Energy (MU) (B)	Loss (MU) (A-B)	% DT Loss (A-B)/A
2190	TPCODL	BBSR1	BED	TEMPLE	MULAPADIA ODSSP	14252	11 KV MAHAVIR COTTAG	14252202	ARCHID RUDREHYA APPT.	1325DT061	100	MIXED	AMI	Yes	0%	12	0.0162791	0.011569	0.0047101	28.93%
2191	TPCODL	BBSR1	BED	TEMPLE	MULAPADIA ODSSP	14252	11 KV MAHAVIR COTTAG	14252202	JAGAWATH NATH	1325DT066	250	MIXED	AMI	Yes	100%	124	0.22462044	0.155075	0.06954544	30.96%
2192	TPCODL	BBSR1	BED	TEMPLE	MULAPADIA ODSSP	14252	11 KV MAHAVIR COTTAG	14252202	T S ROAD	1325DT072	500	MIXED	AMI	Yes	100%	221	0.32887512	0.278594	0.05028112	15.29%
2193	TPCODL	BBSR1	BED	TEMPLE	MULAPADIA ODSSP	14252	11 KV RATHA ROAD	14252203	BLOOD BANK	1323DT193	100	MIXED	AMI	Yes	0%	2	0.05899416	0.053694	0.00530016	8.98%
2194	TPCODL	BBSR1	BED	TEMPLE	MULAPADIA ODSSP	14252	11 KV RATHA ROAD	14252203	HATA SAHI	1323DT196	250	MIXED	AMI	Yes	0%	125	0.23650224	0.149852	0.08665024	36.64%
2195	TPCODL	BBSR1	BED	TEMPLE	MULAPADIA ODSSP	14252	11 KV RATHA ROAD	14252203	KEDAR LANE	1325DT068	250	MIXED	AMI	Yes	0%	49	0.12513032	0.054101	0.07102932	56.76%
2196	TPCODL	BBSR1	BED	TEMPLE	MULAPADIA ODSSP	14252	11 KV MULAPADIA	14252204	M/S STALWART PALACE	1324DT167	500	MIXED	AMI	Yes	0%	56	0.0702848	0.06854	0.0017448	2.48%
2197	TPCODL	BBSR1	BED	TEMPLE	MULAPADIA ODSSP	14252	11 KV MULAPADIA	14252204	LINGARAJ NAGAR-2	1325DT037	200	MIXED	AMI	Yes	0%	156	0.24085736	0.188473	0.05238436	21.75%
2198	TPCODL	BBSR1	BED	TEMPLE	MULAPADIA ODSSP	14252	11 KV MULAPADIA	14252204	MULAPADIA-2	1325DT039	500	MIXED	AMI	Yes	100%	188	0.23729488	0.165144	0.07215088	30.41%
2199	TPCODL	BBSR1	BED	TEMPLE	MULAPADIA ODSSP	14252	11 KV MULAPADIA	14252204	DAKA BANGALA(ROSHAN)-3	1325DT044	100	MIXED	AMI	Yes	100%	46	0.14917045	0.068124	0.08104645	54.33%
2200	TPCODL	BBSR1	BED	TEMPLE	MULAPADIA ODSSP	14252	11 KV MULAPADIA	14252204	PUNAMA GATE	1325DT048	500	MIXED	AMI	Yes	0%	369	0.41252744	0.369097	0.04343044	10.53%
2201	TPCODL	BBSR1	BED	TEMPLE	MULAPADIA ODSSP	14252	11 KV MULAPADIA	14252204	G.MASANI	1325DT049	500	MIXED	AMI	Yes	100%	77	0.39773864	0.104587	0.29315164	73.70%
2202	TPCODL	BBSR1	BED	TEMPLE	MULAPADIA ODSSP	14252	11 KV MULAPADIA	14252204	BANK COLONY-1	1325DT050	500	MIXED	AMI	Yes	0%	176	0.23454712	0.206342	0.02820512	12.03%
2203	TPCODL	BBSR1	BED	TEMPLE	MULAPADIA ODSSP	14252	11 KV MULAPADIA	14252204	BANK COLONY-2	1325DT075	250	MIXED	AMI	Yes	100%	93	0.25429624	0.116415	0.13788124	54.22%
2204	TPCODL	BBSR1	BED	TEMPLE	PRADHAN SAHI ODS	14253	11 kV KALYANI PLAZA	14253201	KALYANI PLAZA -1	1322DT354	500	MIXED	AMI	Yes	100%	185	0.10291288	0.058869	0.04404388	42.80%
2205	TPCODL	BBSR1	BED	TEMPLE	PRADHAN SAHI ODS	14253	11 kV KALYANI PLAZA	14253201	KALYANI VIHAR	1322DT356	250	MIXED	AMI	Yes	0%	345	0.32306536	0.265514	0.05755136	17.81%
2206	TPCODL	BBSR1	BED	TEMPLE	PRADHAN SAHI ODS	14253	11 kV KALYANI PLAZA	14253201	KALYANI PLAZA -I	1322DT361	250	MIXED	AMI	Yes	100%	234	0.1578548	0.121784	0.0360708	22.85%
2207	TPCODL	BBSR1	BED	TEMPLE	PRADHAN SAHI ODS	14253	11 kV KALYANI PLAZA	14253201	KANTILO	1322DT505	100	MIXED	AMI	Yes	100%	7	0.01617086	0.010416	0.00575486	35.59%
2208	TPCODL	BBSR1	BED	TEMPLE	PRADHAN SAHI ODS	14253	11 kV KALYANI PLAZA	14253201	TRAHI JAGANATH ENCLAVE -1	1322DT507	500	MIXED	AMI	Yes	0%	57	0.05924368	0.022861	0.03638268	61.41%
2209	TPCODL	BBSR1	BED	TEMPLE	PRADHAN SAHI ODS	14253	11 kV KALYANI PLAZA	14253201	SAMPURNA ELITE HOMES	1322DT508	500	MIXED	AMI	Yes	0%	97	0.0770416	0.072789	0.0042526	5.52%
2210	TPCODL	BBSR1	BED	TEMPLE	PRADHAN SAHI ODS	14253	11 kV PRADHANSHAI	14253202	BARAKUDA VILLAGE	1322DT469	100	MIXED	AMI	Yes	100%	130	0.10022694	0.067949	0.03227794	32.20%
2211	TPCODL	BBSR1	BED	TEMPLE	PRADHAN SAHI ODS	14253	11 kV PRADHANSHAI	14253202	LADIES HOSTEL-BARAKUDA	1322DT471	100	MIXED	AMI	Yes	0%	99	0.06382498	0.024061	0.03976398	62.30%
2212	TPCODL	BBSR1	BED	TEMPLE	PRADHAN SAHI ODS	14253	11 kV PRADHANSHAI	14253202	OMM SWASTIK	1322DT479	250	MIXED	AMI	Yes	33%	16	0.02619216	0.011111	0.01508116	57.58%
2213	TPCODL	BBSR1	BED	TEMPLE	PRADHAN SAHI ODS	14253	11 kV PRADHANSHAI	14253202	LI POINT-JAMUKOLI	1322DT490	100	MIXED	AMI	Yes	0%	7	0.01447238	0.004329	0.01014338	70.09%
2214	TPCODL	BBSR1	BED	TEMPLE	PRADHAN SAHI ODS	14253	11 kV PRADHANSHAI	14253202	SHREE VILLA-1	1322DT534	500	MIXED	AMI	Yes	100%	17	0.03218728	0.009142	0.02304528	71.60%
2215	TPCODL	BBSR1	BED	TEMPLE	PRADHAN SAHI ODS	14253	11 kV PANCHA GAON	14253203	ORCHID RESIDENCY	1322DT456	250	MIXED	AMI	Yes	100%	40	0.02506134	0.012889	0.01217234	48.57%
2216	TPCODL	BBSR1	BED	TEMPLE	PRADHAN SAHI ODS	14253	11 kV PANCHA GAON	14253203	SUBHADRA VILLA-1	1322DT459	500	MIXED	AMI	Yes	100%	26	0.06148448	0.022859	0.03862548	62.82%
2217	TPCODL	BBSR1	BED	TEMPLE	PRADHAN SAHI ODS	14253	11 kV PANCHA GAON	14253203	SUBHADRA VILLA-2	1322DT460	250	MIXED	AMI	Yes	100%	17	0.0318112	0.016961	0.0148502	46.68%
2218	TPCODL	BBSR1	BED	TEMPLE	PRADHAN SAHI ODS	14253	11 kV PANCHA GAON	14253203	PANCHAGAON	1322DT525	250	MIXED	AMI	Yes	100%	342	0.13081504	0.129667	0.00114804	0.88%
2219	TPCODL	BBSR1	BED	TEMPLE	PRADHAN SAHI ODS	14253	11 kV HITECH-OH	14253204	SRUSTI ELITE -1	1322DT300	500	MIXED	AMI	Yes	100%	37	0.04423376	0.030275	0.01395876	31.56%
2220	TPCODL	BBSR1	BED	TEMPLE	PRADHAN SAHI ODS	14253	11 kV HITECH-OH	14253204	SRUSTI ELITE -3	1322DT302	500	MIXED	AMI	Yes	0%	32	0.03948832	0.017297	0.02219132	56.20%
2221	TPCODL	BBSR1	BED	TEMPLE	PRADHAN SAHI ODS	14253	11 kV HITECH-OH	14253204	INSIDE OF SAI ANNEX	1322DT318	100	MIXED	AMI	Yes	100%	28	0.0319204	0.018965	0.0129554	40.59%
2222	TPCODL	BBSR1	BED	TEMPLE	PRADHAN SAHI ODS	14253	11 kV HITECH-OH	14253204	VINAYAK ENCLAVE	1322DT345	500	MIXED	AMI	Yes	0%	37	0.09537432	0.04908	0.04629432	48.54%
2223	TPCODL	BBSR1	BED	TEMPLE	PRADHAN SAHI ODS	14253	11 kV HITECH-OH	14253204	LANDMARK -1	1322DT378	500	MIXED	AMI	Yes	100%	45	0.06536776	0.033981	0.03138676	48.02%
2224	TPCODL	BBSR1	BED	TEMPLE	PRADHAN SAHI ODS	14253	11 kV HITECH-OH	14253204	LANDMARK -2 (C)	1322DT383	500	MIXED	AMI	Yes	0%	22	0.05026824	0.027692	0.02257624	44.91%
2225	TPCODL	BBSR1	BED	TEMPLE	PRADHAN SAHI ODS	14253	11 kV HITECH-OH	14253204	LANDMARK -2 (D)	1322DT384	500	MIXED	AMI	Yes	100%	10	0.04034715	0.009993	0.03035415	75.23%
2226	TPCODL	BBSR1	BED	TEMPLE	PRADHAN SAHI ODS	14253	11 kV HITECH-OH	14253204	SRUSTI PLAZA	1322DT389	500	MIXED	AMI	Yes	100%	83	0.07232554	0.035898	0.03642754	50.37%
2227	TPCODL	BBSR1	BED	TEMPLE	PRADHAN SAHI ODS	14253	11 kV HITECH-OH	14253204	ASIS DAS	1322DT402	25	MIXED	AMI	Yes	100%	9	0.01063508	0.003605	0.00703008	66.10%
2228	TPCODL	BBSR1	BED	TEMPLE	PRADHAN SAHI ODS	14253	11 kV HITECH-OH	14253204	NEAR SWAPNESWAR SENAPATI	1322DT407	100	MIXED	AMI	Yes	100%	15	0.01675976	0.015929	0.00083076	4.96%
2229	TPCODL	BBSR1	BED	TEMPLE	PRADHAN SAHI ODS	14253	11 kV HITECH-OH	14253204	SAMRIDHI VIHAR-1	1322DT409	500	MIXED	AMI	Yes	0%	20	0.01894444	0.018642	0.00030244	1.60%
2230	TPCODL	BBSR1	BED	TEMPLE	PRADHAN SAHI ODS	14253	11 kV HITECH-OH	14253204	JYOSHNA VILLA	1322DT412	250	MIXED	AMI	Yes	0%	54	0.00933528	0.008236	0.00109928	11.78%
2231	TPCODL	BBSR1	BED	TEMPLE	PRADHAN SAHI ODS	14253	11 kV HITECH-OH	14253204	KUHA VILLAGE	1322DT413	200	MIXED	AMI	Yes	100%	267	0.17156044	0.17017	0.00139044	0.81%
2232	TPCODL	BBSR1	BED	TEMPLE	PRADHAN SAHI ODS	14253	11 kV HITECH-OH	14253204	SRUSTI RESIDENCE	1322DT416	500	MIXED	AMI	Yes	0%	12	0.02481404	0.00749	0.01732404	69.82%
2233	TPCODL	BBSR1	BED	TEMPLE	PRADHAN SAHI ODS	14253	11 kV HITECH-OH	14253204	KOKILA COTTAGE	1322DT437	500	MIXED	AMI	Yes	100%	50	0.067185	0.063094	0.004091	6.09%
2234	TPCODL	BBSR1	BED	TEMPLE	PRADHAN SAHI ODS	14253	11 kV HITECH-OH	14253204	SAISHREE VILLA-1	1322DT439	250	MIXED	AMI	Yes	0%	36	0.03238368	0.018942	0.01344168	41.51%
2235	TPCODL	BBSR1	BED	TEMPLE	PRADHAN SAHI ODS	14253	11 kV HITECH-OH	14253204	SAISHREE VILLA-2	1322DT440	250	MIXED	AMI	Yes	0%	6	0.01798432	0.003748	0.01423632	79.16%
2236	TPCODL	BBSR1	BED	TEMPLE	PRADHAN SAHI ODS	14253	11 kV HITECH-OH	14253204	M/S RAJDHANI SYSTEM&ESTATE PVT	1322DT610	500	MIXED	AMI	Yes	100%	39	0.04111384	0.030613	0.01050084	25.54%
2237	TPCODL	BBSR1	BED	TEMPLE	PRADHAN SAHI ODS	14253	11 kV HITECH-OH	14253204	M/S RAJDHANI SYSTEM&ESTATE PVT	1322DT611	500	MIXED	AMI	Yes	67%	14	0.02816048	0.010906	0.01725448	61.27%
2238	TPCODL	BBSR1	BED	TEMPLE	PRADHAN SAHI ODS	14253	11 kV HITECH-OH	14253204	M/S RAJDHANI SYSTEM&ESTATE PVT	1322DT614	500	MIXED	AMI	Yes	100%	17	0.06108888	0.016064	0.04502488	73.70%
2239	TPCODL	BBSR1	BED	TEMPLE	PRADHAN SAHI ODS	14253	11 kV HITECH-OH	14253204	ANSU INFRA (TULASI KHETRA)	1322DT650	500	MIXED	AMI	Yes	0%	23	0.0120022	0.005232	0.0067702	56.41%
2240	TPCODL	BBSR1	BED	TEMPLE	SBI KESURA	14183	11 KV KESURA	14183202	NEAR PLOT NO.326/1308	1313DT180	250	MIXED	AMI	Yes	100%	112	0.16942184	0.077485	0.09193684	54.27%
2241	TPCODL	BBSR1	BED	TEMPLE	SIULA ODSSP	14254	11 KV LAXMINARAYANPU	14254201	HI-TECH PEARL	1326DT369	500	MIXED	AMI	Yes	100%	57	0.02956992	0.018739	0.01083092	36.63%
2242	TPCODL	BBSR1	BED	TEMPLE	SIULA ODSSP	14254	11 KV LAXMINARAYANPU	14254201	(HI TACH PEARL)	1326DT370	500	MIXED	AMI	Yes	0%	54	0.03679128	0.018488	0.01830328	49.75%
2243	TPCODL	BBSR1	BED	TEMPLE	SIULA ODSSP	14254	11 KV LAXMINARAYANPU	14254201	BADACHANDI CONSTRUCTION	1326DT375	500	MIXED	AMI	Yes	100%	62	0.06396632	0.035848	0.02811832	43.96%
2244	TPCODL	BBSR1	BED	TEMPLE	SIULA ODSSP	14254	11 KV LAXMINARAYANPU	14254201	LAXMINARAYANPUR,RATAHA SAHI	1326DT394	100	MIXED	AMI	Yes	0%	40	0.02811396	0.014364	0.01374996	48.91%
2245	TPCODL	BBSR1	BED	TEMPLE	SIULA ODSSP	14254	11 KV LAXMINARAYANPU	14254201	LAXMINARAYANPUR	1326DT396	100	MIXED	AMI	Yes	0%	42	0.04907968	0.024627	0.02445268	49.82%
2246	TPCODL	BBSR1	BED	TEMPLE	SIULA ODSSP	14254	11 KV LAXMINARAYANPU	14254201	KHARIJAPATNA	1326DT411	100	MIXED	AMI	Yes	100%	121	0.10543216	0.055621	0.04981116	47.24%
2247	TPCODL	BBSR1	BED	TEMPLE	SIULA ODSSP	14254	11 KV LAXMINARAYANPU	14254201	MOGOLPUR	1326DT412	100	MIXED	AMI	Yes	67%	54	0.02860936	0.018257	0.01035236	36.19%
2248	TPCODL	BBSR1	BED	TEMPLE	SIULA ODSSP	14254	11 KV LAXMINARAYANPU	14254201	SUDHIRA CHAMPATI	1326DT574	63	MIXED	AMI	Yes	0%	7	0.02227116	0.009766	0.01250516	56.15%
2249	TPCODL	BBSR1	BED	TEMPLE	SIULA ODSSP	14254	11 KV PATASAINIPUR	14254202	SIULA,TALA SAHI	1326DT427	100	MIXED	AMI	Yes	0%	63	0.09107966	0.031168	0.05991166	65.78%
2250	TPCODL	BBSR1	BED	TEMPLE	SIULA ODSSP	14254	11 KV PATASAINIPUR	14254202	KHANDIA MATAPADA	1326DT436	100	MIXED	AMI	Yes	0%	42	0.05212824	0.010876	0.04125224	79.14%
2251	TPCODL	BBSR1	BED	TEMPLE	SIULA ODSSP	14254	11 KV PATASAINIPUR	14254202	SKYPANOROMA	1326DT441	500	MIXED	AMI	Yes	100%	73	0.04038864	0.017221	0.02316764	57.36%
2252	TPCODL	BBSR1	BED	TEMPLE	SIULA ODSSP	14254	11 KV PATASAINIPUR	14254202	GOBINDAPUR HIGH SCHOOL	1326DT445	100	MIXED	AMI	Yes	100%	39	0.04816046	0.022894	0.02526646	52.46%
2253	TPCODL	BBSR1	BED	TEMPLE	SIULA ODSSP	14254	11 KV PATASAINIPUR	14254202	GOBINDAPUR MOHANTY SAHI	1326DT447	100	MIXED	AMI	Yes	100%	58	0.05567932	0.034866	0.02081332	37.38%
2254	TPCODL	BBSR1	BED	TEMPLE	SIULA ODSSP	14254	11 KV PATASAINIPUR	14254202	TALAU	1326DT450	100	MIXED	AMI	Yes	67%	41	0.046477	0.022552	0.023925	51.48%
2255	TPCODL	BBSR1	BED	TEMPLE	SIULA ODSSP	14254	11 KV PATASAINIPUR	14254202	KUNJAR MELANA PADIA	1326DT452	100	MIXED	AMI	Yes	100%	43	0.05015402	0.013767	0.03638702	72.55%
2256	TPCODL	BBSR1	BED	TEMPLE	SIULA ODSSP	14254	11 KV PATASAINIPUR	14254202	KUNJAR MUDULI SAHI	1326DT459	100	MIXED	AMI	Yes	0%	75	0.0689847	0.025072	0.0439127	63.66%
2257	TPCODL	BBSR1	BED	TEMPLE	SIULA ODSSP	14254	11 KV PATASAINIPUR	14254202	KANTAPADA	1326DT460	100	MIXED	AMI	Yes	100%	38	0.06238774	0.013489	0.04889874	78.38%
2258	TPCODL	BBSR1	BED	TEMPLE	SIULA ODSSP	14254	11 KV PATASAINIPUR	14254202	PATSANIPUR BALI SAHI	1326DT467	100	MIXED	AMI	Yes	0%	53	0.0606461	0.016477	0.0441691	72.83%
2259	TPCODL	BBSR1	BED	TEMPLE	SIULA ODSSP	14254	11 KV PATASAINIPUR	14254202	PATASANIPUR I	1326DT471	100	MIXED	AMI	Yes	100%	79	0.11145532	0.023981	0.08747432	78.48%
2260	TPCODL	BBSR1	BED	TEMPLE	SIULA ODSSP	14254	11 KV PATASAINIPUR	14254202	ARUHA MAJHI SAHI	1326DT507	100	MIXED	AMI	Yes	0%	57	0.05717032	0.015841	0.04132932	72.29%
2261	TPCODL	BBSR1	BED	TEMPLE	SIULA ODSSP	14254	11 KV DAHISPATNA	14254203	BINDHA	1326DT224	100	MIXED	AMI	Yes	0%	58	0.08594454	0.020651	0.06529354	75.97%
2262	TPCODL	BBSR1	BED	TEMPLE	SIULA ODSSP	14254	11 KV DAHISPATNA	14254203	GUDIAPOKHARI BALIGADIA	1326DT337	100	MIXED	AMI	Yes	0%	143	0.28113077	0.106858	0.17427277	61.99%

Sl. No.	Zone Name	Circle name	Division name	Name of the Sub-division	Name of the Sub-station	Substation Code	Name of the 11 kV Feeder	Feeder Code	Name of the Location where DT situated	DT code	DT Capacity (kVA)	Predominant consumer type of DT (Domestic/Industrial/Agriculture/Mixed)	Type of metering AMR/AMI/ Communicable/Conventional metered/Unmetered	Status of Meter-whether Functional (Yes/No)	% of data received automatically (if AMR/AMI)	No. of Connected Consumers	Input Energy (MU) (A)	Billed Energy (MU) (B)	Loss (MU) (A-B)	% DT Loss (A-B)/A
2263	TPCODL	BBSR1	BED	TEMPLE	SIULA ODSSP	14254	11 KV DAHISPATNA	14254203	SIULA UPPER SAHI 1	1326DT481	100	MIXED	AMI	Yes	0%	100	0.14520398	0.047216	0.09798798	67.48%
2264	TPCODL	BBSR1	BED	TEMPLE	SIULA ODSSP	14254	11 KV DAHISPATNA	14254203	PADMA BUILD TECH	1326DT493	250	MIXED	AMI	Yes	0%	24	0.0256406	0.024058	0.0015826	6.17%
2265	TPCODL	BBSR1	BED	TEMPLE	SIULA ODSSP	14254	11 KV DAHISPATNA	14254203	THIKKIRI MALA-1	1326DT512	100	MIXED	AMI	Yes	100%	39	0.0333714	0.01429	0.0190814	57.18%
2266	TPCODL	BBSR1	BED	TEMPLE	SIULA ODSSP	14254	11 KV DAHISPATNA	14254203	JAISIPATANA	1326DT513	250	MIXED	AMI	Yes	0%	155	0.18512761	0.101072	0.08405561	45.40%
2267	TPCODL	BBSR1	BED	TEMPLE	SIULA ODSSP	14254	11 KV DAHISPATNA	14254203	GOBARDHANPUR SULTAN NAGAR	1326DT517	100	MIXED	AMI	Yes	100%	41	0.04482226	0.019001	0.02582126	57.61%
2268	TPCODL	BBSR1	BED	TEMPLE	SIULA ODSSP	14254	11 KV DAHISPATNA	14254203	LORDSWAY APPARTMENT -4	1326DT591	250	MIXED	AMI	Yes	0%	28	0.02438232	0.024216	0.00016632	0.68%
2269	TPCODL	BBSR1	BED	TEMPLE	UTTARA	14026	11 KV KAUSHALYA	14026201	UTTARA SASANA-1	1326DT234	100	MIXED	AMI	Yes	0%	153	0.10549834	0.099912	0.00558634	5.30%
2270	TPCODL	BBSR1	BED	TEMPLE	UTTARA	14026	11 KV KAUSHALYA	14026201	UTTARA SASANA - 2	1326DT245	100	MIXED	AMI	Yes	0%	91	0.09739272	0.061152	0.03624072	37.21%
2271	TPCODL	BBSR1	BED	TEMPLE	UTTARA	14026	11 KV KAUSHALYA	14026201	SRIRAM NAGAR-2 RAPDRP	1326DT249	100	MIXED	AMI	Yes	0%	111	0.12210186	0.08876	0.03334186	27.31%
2272	TPCODL	BBSR1	BED	TEMPLE	UTTARA	14026	11 KV KAUSHALYA	14026201	PATELITUDA	1326DT260	100	MIXED	AMI	Yes	0%	48	0.0596211	0.023761	0.0358601	60.15%
2273	TPCODL	BBSR1	BED	TEMPLE	UTTARA	14026	11 KV KAUSHALYA	14026201	WHITE ROSE DUPLEX I	1326DT276	250	MIXED	AMI	Yes	100%	51	0.06518892	0.033939	0.03124992	47.94%
2274	TPCODL	BBSR1	BED	TEMPLE	UTTARA	14026	11 KV KAUSHALYA	14026201	GANDHI GARDEN	1326DT277	250	MIXED	AMI	Yes	67%	25	0.02055333	0.017654	0.00289933	14.11%
2275	TPCODL	BBSR1	BED	TEMPLE	UTTARA	14026	11 KV KAUSHALYA	14026201	PUBASASANA	1326DT279	250	MIXED	AMI	Yes	100%	177	0.18092254	0.137601	0.04332154	23.94%
2276	TPCODL	BBSR1	BED	TEMPLE	UTTARA	14026	11 KV KAUSHALYA	14026201	SANKAR RAY	1326DT298	100	MIXED	AMI	Yes	0%	10	0.00937954	0.008731	0.00064854	6.91%
2277	TPCODL	BBSR1	BED	TEMPLE	UTTARA	14026	11 KV KAUSHALYA	14026201	LOUSE SAHOO,EKCHALIYA	1326DT313	100	MIXED	AMI	Yes	0%	20	0.01510142	0.014737	0.00036442	2.41%
2278	TPCODL	BBSR1	BED	TEMPLE	UTTARA	14026	11 KV KAUSHALYA	14026201	EKCHALIYA-2	1326DT314	100	MIXED	AMI	Yes	100%	64	0.06574576	0.050822	0.01492376	22.70%
2279	TPCODL	BBSR1	BED	TEMPLE	UTTARA	14026	11 KV KAUSHALYA	14026201	REETA VALLY	1326DT330	500	MIXED	AMI	Yes	100%	46	0.03646104	0.021082	0.01537904	42.18%
2280	TPCODL	BBSR1	BED	TEMPLE	UTTARA	14026	11 KV KAUSHALYA	14026201	GANESH PRASAD MEHER(PRASANTI A	1326DT334	100	MIXED	AMI	Yes	0%	15	0.0113523	0.009795	0.0015573	13.72%
2281	TPCODL	BBSR1	BED	TEMPLE	UTTARA	14026	11 KV DHAULI	14026202	SAMAL SAHI,UTTARA	1326DT048	100	MIXED	AMI	Yes	100%	38	0.05090904	0.042447	0.00846204	16.62%
2282	TPCODL	BBSR1	BED	TEMPLE	UTTARA	14026	11 KV DHAULI	14026202	HANUMAN MANDIR	1326DT061	100	MIXED	AMI	Yes	100%	56	0.04808872	0.02689953	0.02118919	44.06%
2283	TPCODL	BBSR1	BED	TEMPLE	UTTARA	14026	11 KV DHAULI	14026202	KHATUA PADA	1326DT065	100	MIXED	AMI	Yes	100%	102	0.09052442	0.061533	0.02899142	32.03%
2284	TPCODL	BBSR1	BED	TEMPLE	UTTARA	14026	11 KV DHAULI	14026202	GHODA PADIA	1326DT070	100	MIXED	AMI	Yes	100%	43	0.04587748	0.036755	0.00912248	19.88%
2285	TPCODL	BBSR1	BED	TEMPLE	UTTARA	14026	11 KV DHAULI	14026202	KALIGA ASHOK BIHAR	1326DT076	250	MIXED	AMI	Yes	100%	146	0.17623696	0.127194	0.04904296	27.83%
2286	TPCODL	BBSR1	BED	TEMPLE	UTTARA	14026	11 KV DHAULI	14026202	MANGALA MANDIR	1326DT092	100	MIXED	AMI	Yes	100%	56	0.043748	0.036594	0.007154	16.35%
2287	TPCODL	BBSR1	BED	TEMPLE	UTTARA	14026	11 KV DHAULI	14026202	BIKIPUR	1326DT102	100	MIXED	AMI	Yes	33%	144	0.08291222	0.080453	0.00245922	2.97%
2288	TPCODL	BBSR1	BED	TEMPLE	UTTARA	14026	11 KV DHAULI	14026202	JAIPUR	1326DT109	250	MIXED	AMI	Yes	0%	192	0.15926544	0.103328	0.05593744	35.12%
2289	TPCODL	BBSR1	BED	TEMPLE	UTTARA	14026	11 KV DHAULI	14026202	ITIPUR, BALISAHI	1326DT117	100	MIXED	AMI	Yes	100%	146	0.09314214	0.083071	0.01007114	10.81%
2290	TPCODL	BBSR1	BED	TEMPLE	UTTARA	14026	11 KV DHAULI	14026202	ANEIGAHURI, ITIPUR	1326DT119	100	MIXED	AMI	Yes	100%	100	0.06609044	0.03977	0.02632044	39.82%
2291	TPCODL	BBSR1	BED	TEMPLE	UTTARA	14026	11 KV DHAULI	14026202	PALASHPUR	1326DT126	100	MIXED	AMI	Yes	100%	116	0.08115	0.06061	0.02054	25.31%
2292	TPCODL	BBSR1	BED	TEMPLE	UTTARA	14026	11 KV DHAULI	14026202	BASANTPUR,DAKHINA HARIJANA SAH	1326DT134	250	MIXED	AMI	Yes	100%	153	0.14066316	0.090804	0.04985916	35.45%
2293	TPCODL	BBSR1	BED	TEMPLE	UTTARA	14026	11 KV DHAULI	14026202	GANGESWAR PUR	1326DT143	100	MIXED	AMI	Yes	100%	125	0.09766814	0.065697	0.03197114	32.73%
2294	TPCODL	BBSR1	BED	TEMPLE	UTTARA	14026	11 KV DHAULI	14026202	BALISAHI 3 BABU MOHANTY	1326DT159	100	MIXED	AMI	Yes	100%	41	0.05129466	0.037493	0.01380166	26.91%
2295	TPCODL	BBSR1	BED	TEMPLE	UTTARA	14026	11 KV DHAULI	14026202	DHAULI CHAAK,	1326DT163	100	MIXED	AMI	Yes	67%	69	0.1001091	0.085723	0.0143861	14.37%
2296	TPCODL	BBSR1	BED	TEMPLE	UTTARA	14026	11 KV DHAULI	14026202	BALISAHI 1	1326DT187	100	MIXED	AMI	Yes	100%	67	0.06993668	0.051384	0.01855268	26.53%
2297	TPCODL	BBSR1	BED	TEMPLE	UTTARA	14026	11 KV DHAULI	14026202	KAUSHALYA PUR DHIA SAHI	1326DT195	100	MIXED	AMI	Yes	100%	32	0.0402749	0.022382	0.0178929	44.43%
2298	TPCODL	BBSR1	BED	TEMPLE	UTTARA	14026	11 KV DHAULI	14026202	KAUSHALYA PUR	1326DT196	100	MIXED	AMI	Yes	100%	108	0.10858538	0.03887	0.06971538	64.20%
2299	TPCODL	BBSR1	BED	TEMPLE	UTTARA	14026	11 KV DHAULI	14026202	BHOULA	1326DT203	100	MIXED	AMI	Yes	100%	75	0.14674532	0.033418	0.11332732	77.23%
2300	TPCODL	BBSR1	BED	TEMPLE	UTTARA	14026	11 KV DHAULI	14026202	KAIRI PADHI SAHI	1326DT210	63	MIXED	AMI	Yes	0%	36	0.04454082	0.015115	0.02942582	66.06%
2301	TPCODL	BBSR1	BED	TEMPLE	UTTARA	14026	11 KV DHAULI	14026202	PAMASARA	1326DT213	100	MIXED	AMI	Yes	0%	68	0.11260662	0.026167	0.08643962	76.76%
2302	TPCODL	BBSR1	BED	TEMPLE	UTTARA	14026	11 KV SARDEIPUR	14026204	PRODECHO REALISTIC	1326DT010	250	MIXED	AMI	Yes	0%	26	0.03896332	0.023403	0.01556032	39.94%
2303	TPCODL	BBSR1	BED	TEMPLE	UTTARA	14026	11 KV SARDEIPUR	14026204	SARADIPUR I	1326DT017	100	MIXED	AMI	Yes	0%	98	0.08930206	0.052539	0.03676306	41.17%
2304	TPCODL	BBSR1	BED	TEMPLE	UTTARA	14026	11 KV SARDEIPUR	14026204	BAPUJI HEIGHTS	1326DT027	500	MIXED	AMI	Yes	0%	75	0.05809264	0.044941	0.01315164	22.64%
2305	TPCODL	BBSR1	BED	TEMPLE	UTTARA	14026	11 KV SARDEIPUR	14026204	IMARAT PLAZA	1326DT038	100	MIXED	AMI	Yes	0%	19	0.01741752	0.013925	0.00349252	20.05%
2306	TPCODL	BBSR1	NED	KAKATPUR	ASTARANGA	14029	11 KV ASTARANGA	14029201	NAGARA LENKA SAHI	1411DT093	63	MIXED	AMI	Yes	67%	70	0.02870356	0.012735	0.01596856	55.63%
2307	TPCODL	BBSR1	NED	KAKATPUR	PATALDA ODSSP	14256	11 KV PATALADA	14256202	MANDUKI	1411DT431	63	MIXED	AMI	Yes	67%	53	0.0155014	0.010868	0.0046334	29.89%
2308	TPCODL	BBSR1	NED	KAKATPUR	ASTARANGA	14029	11 KV ASTARANGA	14029201	UKULEI	1411DT007	100	MIXED	AMI	Yes	67%	90	0.04419096	0.038692	0.00549896	12.44%
2309	TPCODL	BBSR1	NED	KAKATPUR	ASTARANGA	14029	11 KV ASTARANGA	14029201	BASTA DIHA	1411DT011	250	MIXED	AMI	Yes	67%	111	0.08705744	0.068748	0.01830944	21.03%
2310	TPCODL	BBSR1	NED	KAKATPUR	ASTARANGA	14029	11 KV ASTARANGA	14029201	GOPALPUR	1411DT027	100	MIXED	AMI	Yes	67%	162	0.04533912	0.039649	0.00569012	12.55%
2311	TPCODL	BBSR1	NED	KAKATPUR	ASTARANGA	14029	11 KV ASTARANGA	14029201	BARAPADA 1	1411DT035	100	MIXED	AMI	Yes	67%	42	0.02837156	0.010176	0.01819556	64.13%
2312	TPCODL	BBSR1	NED	KAKATPUR	ASTARANGA	14029	11 KV ASTARANGA	14029201	ATHATIRA MAIN ROAD	1411DT039	100	MIXED	AMI	Yes	0%	116	0.0604595	0.030543	0.0299165	49.48%
2313	TPCODL	BBSR1	NED	KAKATPUR	ASTARANGA	14029	11 KV ASTARANGA	14029201	ATHATIRA POKHARI	1411DT040	100	MIXED	AMI	Yes	67%	63	0.04425264	0.014974	0.02927864	66.16%
2314	TPCODL	BBSR1	NED	KAKATPUR	ASTARANGA	14029	11 KV ASTARANGA	14029201	ALASAHI	1411DT055	100	MIXED	AMI	Yes	0%	106	0.05369816	0.029529	0.02416916	45.01%
2315	TPCODL	BBSR1	NED	KAKATPUR	ASTARANGA	14029	11 KV ASTARANGA	14029201	ANATA	1411DT065	100	MIXED	AMI	Yes	100%	156	0.05459811	0.029508	0.02509011	45.95%
2316	TPCODL	BBSR1	NED	KAKATPUR	ASTARANGA	14029	11 KV ASTARANGA	14029201	NAGARA	1411DT102	100	MIXED	AMI	Yes	100%	110	0.05215954	0.02447	0.02768954	53.09%
2317	TPCODL	BBSR1	NED	KAKATPUR	ASTARANGA	14029	11 KV ASTARANGA	14029201	ALANGAPUR 2	1411DT122	100	MIXED	AMI	Yes	67%	97	0.04840008	0.031375	0.01702508	35.18%
2318	TPCODL	BBSR1	NED	KAKATPUR	ASTARANGA	14029	11 KV ASTARANGA	14029201	ASTARANAG 1 NO WORD	1411DT128	100	MIXED	AMI	Yes	0%	64	0.07520994	0.020615	0.05459494	72.59%
2319	TPCODL	BBSR1	NED	KAKATPUR	ASTARANGA	14029	11 KV JIUNTY	14029202	JUINTY TEMPLE	1411DT221	100	MIXED	AMI	Yes	67%	103	0.05264968	0.025036	0.02761368	52.45%
2320	TPCODL	BBSR1	NED	KAKATPUR	ASTARANGA	14029	11 KV JIUNTY	14029202	NAIGUAN 2	1411DT253	250	MIXED	AMI	Yes	0%	75	0.02322	0.01312	0.0101	43.50%
2321	TPCODL	BBSR1	NED	KAKATPUR	ASTARANGA	14029	11 KV JIUNTY	14029202	NAIGUAN 1	1411DT261	100	MIXED	AMI	Yes	100%	83	0.05285702	0.025254	0.02760302	52.22%
2322	TPCODL	BBSR1	NED	KAKATPUR	ASTARANGA	14029	11 KV JIUNTY	14029202	JIOLA	1411DT269	100	MIXED	AMI	Yes	67%	20	0.01921696	0.0071	0.01211696	63.05%
2323	TPCODL	BBSR1	NED	KAKATPUR	ASTARANGA	14029	11 KV JIUNTY	14029202	NAMARO	1411DT281	100	MIXED	AMI	Yes	67%	71	0.03407854	0.018919	0.01515954	44.48%
2324	TPCODL	BBSR1	NED	KAKATPUR	ASTARANGA	14029	11 KV JIUNTY	14029202	MUNDUGALA	1411DT289	100	MIXED	AMI	Yes	0%	122	0.04474356	0.032403	0.01234056	27.58%
2325	TPCODL	BBSR1	NED	KAKATPUR	ASTARANGA	14029	11 KV JIUNTY	14029202	UDAYAPUR MACHHA GAIN	1411DT310	100	MIXED	AMI	Yes	67%	92	0.0353967	0.020462	0.0149347	42.19%
2326	TPCODL	BBSR1	NED	KAKATPUR	ASTARANGA	14029	11 KV JIUNTY	14029202	OLARA	1411DT330	100	MIXED	AMI	Yes	67%	95	0.04828336	0.025174	0.02310936	47.86%
2327	TPCODL	BBSR1	NED	KAKATPUR	ASTARANGA	14029	11 KV JIUNTY	14029202	BANTILO VILLAGE	1411DT337	100	MIXED	AMI	Yes	67%	111	0.04140288	0.030284	0.01111888	26.86%
2328	TPCODL	BBSR1	NED	KAKATPUR	ASTARANGA	14029	11 KV JIUNTY	14029202	GOSINGA	1411DT344	63	MIXED	AMI	Yes	0%	80	0.02872258	0.017767	0.01095558	38.14%
2329	TPCODL	BBSR1	NED	KAKATPUR	ASTARANGA	14029	11 KV JIUNTY	14029202	TIRIKANA	1411DT348	100	MIXED	AMI	Yes	100%	73	0.03401077	0.021621	0.01238977	36.43%
2330	TPCODL	BBSR1	NED	KAKATPUR	ASTARANGA	14029	11 KV JIUNTY	14029202	OSTAPUR	1411DT361	100	MIXED	AMI	Yes	67%	79	0.01986588	0.01786	0.00200588	10.10%
2331	TPCODL	BBSR1	NED	KAKATPUR	ASTARANGA	14029	11 KV JIUNTY	14029202	KANDHA SAHI NO1	1411DT371	100	MIXED	AMI	Yes	0%	133	0.04448702	0.037919	0.00656802	14.76%
2332	TPCODL	BBSR1	NED	KAKATPUR	ASTARANGA	14029	11 KV JIUNTY	14029202	MALADA	1411DT378	100	MIXED	AMI	Yes	0%	108	0.03392562	0.023378	0.01054762	31.09%
2333	TPCODL	BBSR1	NED	KAKATPUR	ASTARANGA	14029	11 KV SUNDARA (Astarar	14029203	SB9	1411DT388	250	MIXED	AMI	Yes	67%	54	0.10140736	0.038582	0.06282536	61.95%
2334	TPCODL	BBSR1	NED	KAKATPUR	BANGURIGAON ODS	14262	11 KV Bangurigaon	14262201	HANUMAN TEMPLE	1412DT289	100	MIXED	AMI	Yes	67%	102	0.05280841	0.02561	0.02719841	51.50%
2335	TPCODL	BBSR1	NED	KAKATPUR	BANGURIGAON ODS	14262	11 KV Bangurigaon	14262201	BANGORI BAAZAR	1413DT196	250	MIXED	AMI	Yes	100%	189	0.14162122	0.081246	0.06037522	42.63%

Sl. No.	Zone Name	Circle name	Division name	Name of the Sub-division	Name of the Sub-station	Substation Code	Name of the 11 kV Feeder	Feeder Code	Name of the Location where DT situated	DT code	DT Capacity (kVA)	Predominant consumer type of DT (Domestic/Industrial/Agriculture/Mixed)	Type of metering AMR/AMI/ Communicable/Conventional metered/Unmetered	Status of Meter-whether Functional (Yes/No)	% of data received automatically (if AMR/AMI)	No. of Connected Consumers	Input Energy (MU) (A)	Billed Energy (MU) (B)	Loss (MU) (A-B)	% DT Loss (A-B)/A
2336	TPCODL	BBSR1	NED	KAKATPUR	BANGURIGAON OD	14262	11 KV Bangurigaon	14262201	NARENDRAPUR 1	1413DT236	100	MIXED	AMI	Yes	67%	132	0.05072986	0.035873	0.01485686	29.29%
2337	TPCODL	BBSR1	NED	KAKATPUR	BANGURIGAON OD	14262	11 KV Bangurigaon	14262201	MAHADEV DHAKINESHWAR TEMPLE	1413DT246	100	MIXED	AMI	Yes	0%	136	0.05642562	0.041993	0.01443262	25.58%
2338	TPCODL	BBSR1	NED	KAKATPUR	BANGURIGAON OD	14262	11 KV TIKARPADA	14262202	CHALI BERUA	1413DT285	63	MIXED	AMI	Yes	67%	54	0.02463054	0.013384	0.01124654	45.66%
2339	TPCODL	BBSR1	NED	KAKATPUR	BANGURIGAON OD	14262	11 KV TIKARPADA	14262202	KARUNA	1413DT289	100	MIXED	AMI	Yes	0%	85	0.04753811	0.021701	0.02583711	54.35%
2340	TPCODL	BBSR1	NED	KAKATPUR	BANGURIGAON OD	14262	11 KV TIKARPADA	14262202	BALISIRIYA	1413DT316	100	MIXED	AMI	Yes	0%	64	0.02764157	0.011705	0.01593657	57.65%
2341	TPCODL	BBSR1	NED	KAKATPUR	BANGURIGAON OD	14262	11 KV TIKARPADA	14262202	SORAVA(PRIMARY SCHOOL)	1413DT338	100	MIXED	AMI	Yes	0%	86	0.02986828	0.021934	0.00793428	26.56%
2342	TPCODL	BBSR1	NED	KAKATPUR	BANGURIGAON OD	14262	11 KV TIKARPADA	14262202	SORAVA PAIKA SAHI	1413DT339	100	MIXED	AMI	Yes	0%	72	0.02004183	0.017119	0.00292283	14.58%
2343	TPCODL	BBSR1	NED	KAKATPUR	JOGESWARPUR (GA	14263	11 KV Binispur	14263201	AMARPRASAD	1413DT440	100	MIXED	AMI	Yes	67%	95	0.05719876	0.034339	0.02285976	39.97%
2344	TPCODL	BBSR1	NED	KAKATPUR	JOGESWARPUR (GA	14263	11 KV Binispur	14263201	BICHULIPODA	1413DT459	100	MIXED	AMI	Yes	67%	148	0.0711961	0.051668	0.0195281	27.43%
2345	TPCODL	BBSR1	NED	KAKATPUR	JOGESWARPUR (GA	14263	11 KV Binispur	14263201	JORAKULA-1	1413DT473	100	MIXED	AMI	Yes	67%	77	0.02679512	0.016865	0.00993012	37.06%
2346	TPCODL	BBSR1	NED	KAKATPUR	JOGESWARPUR (GA	14263	11 KV Binispur	14263201	TITINGAPADA,MOHAN SAHI	1413DT475	100	MIXED	AMI	Yes	0%	24	0.01994828	0.005849	0.01409928	70.68%
2347	TPCODL	BBSR1	NED	KAKATPUR	JOGESWARPUR (GA	14263	11 KV Binispur	14263201	KHANTIPUR-1	1413DT478	200	MIXED	AMI	Yes	0%	194	0.10337236	0.072769	0.03060336	29.60%
2348	TPCODL	BBSR1	NED	KAKATPUR	JOGESWARPUR (GA	14263	11 KV Binispur	14263201	BINISHPUR	1413DT483	500	MIXED	AMI	Yes	67%	149	0.13424256	0.08029	0.05395256	40.19%
2349	TPCODL	BBSR1	NED	KAKATPUR	JOGESWARPUR (GA	14263	11 KV Binispur	14263201	KUDAPATANA,BINISHPUR CHAK	1413DT484	250	MIXED	AMI	Yes	0%	133	0.10484088	0.043977	0.06086388	58.05%
2350	TPCODL	BBSR1	NED	KAKATPUR	JOGESWARPUR (GA	14263	11 KV Binispur	14263201	NUAPATANA	1413DT487	100	MIXED	AMI	Yes	0%	115	0.06164332	0.051093	0.01055032	17.12%
2351	TPCODL	BBSR1	NED	KAKATPUR	JOGESWARPUR (GA	14263	11 KV Binispur	14263201	AMBAPADA	1413DT491	100	MIXED	AMI	Yes	0%	56	0.03408426	0.021959	0.01212526	35.57%
2352	TPCODL	BBSR1	NED	KAKATPUR	JOGESWARPUR (GA	14263	11 KV Binispur	14263201	AMBAPADA,MISHRA SAHI	1413DT493	100	MIXED	AMI	Yes	67%	154	0.05915954	0.044433	0.01472654	24.89%
2353	TPCODL	BBSR1	NED	KAKATPUR	JOGESWARPUR (GA	14263	11 KV Binispur	14263201	JOGESWARPUR-1	1413DT503	100	MIXED	AMI	Yes	67%	134	0.06336488	0.045809	0.01755588	27.71%
2354	TPCODL	BBSR1	NED	KAKATPUR	JOGESWARPUR (GA	14263	11 KV Nayhata	14263202	MOHATAPARI-2	1413DT527	63	MIXED	AMI	Yes	0%	64	0.04884393	0.018275	0.03056893	62.58%
2355	TPCODL	BBSR1	NED	KAKATPUR	JOGESWARPUR (GA	14263	11 KV Nayhata	14263202	NUABATENDA,BUDHIANI TEMPLE	1413DT529	100	MIXED	AMI	Yes	0%	109	0.0382146	0.029964	0.0082506	21.59%
2356	TPCODL	BBSR1	NED	KAKATPUR	JOGESWARPUR (GA	14263	11 KV Nayhata	14263202	NIJA GADA-2	1413DT537	100	MIXED	AMI	Yes	0%	26	0.0242888	0.007425	0.0168638	69.43%
2357	TPCODL	BBSR1	NED	KAKATPUR	JOGESWARPUR (GA	14263	11 KV Nayhata	14263202	NIVARANA-1	1413DT551	100	MIXED	AMI	Yes	0%	104	0.03625696	0.025502	0.01075496	29.66%
2358	TPCODL	BBSR1	NED	KAKATPUR	JOGESWARPUR (GA	14263	11 KV GadaAmarprasad	14263203	AMERASWARA	1413DT370	250	MIXED	AMI	Yes	67%	94	0.10591192	0.023884	0.08202792	77.45%
2359	TPCODL	BBSR1	NED	KAKATPUR	JOGESWARPUR (GA	14263	11 KV GadaAmarprasad	14263203	CHHABATI	1413DT376	100	MIXED	AMI	Yes	67%	27	0.01411464	0.009702	0.00441264	31.26%
2360	TPCODL	BBSR1	NED	KAKATPUR	JOGESWARPUR (GA	14263	11 KV GadaAmarprasad	14263203	CHAHATA	1413DT378	100	MIXED	AMI	Yes	0%	37	0.03452658	0.014943	0.01958358	56.72%
2361	TPCODL	BBSR1	NED	KAKATPUR	JOGESWARPUR (GA	14263	11 KV GadaAmarprasad	14263203	BHAINCHIGORODI	1413DT389	250	MIXED	AMI	Yes	0%	198	0.1043076	0.067509	0.0367986	35.28%
2362	TPCODL	BBSR1	NED	KAKATPUR	JOGESWARPUR (GA	14263	11 KV GadaAmarprasad	14263203	MAINSIGOTHA	1413DT393	100	MIXED	AMI	Yes	0%	48	0.04690854	0.018192	0.02871654	61.22%
2363	TPCODL	BBSR1	NED	KAKATPUR	JOGESWARPUR (GA	14263	11 KV GadaAmarprasad	14263203	TULASIPUR SCHOOL	1413DT401	100	MIXED	AMI	Yes	67%	113	0.07957668	0.052425	0.02715168	34.12%
2364	TPCODL	BBSR1	NED	KAKATPUR	JOGESWARPUR (GA	14263	11 KV GadaAmarprasad	14263203	BHANAPUR	1413DT402	100	MIXED	AMI	Yes	67%	30	0.0270602	0.015206	0.0118542	43.81%
2365	TPCODL	BBSR1	NED	KAKATPUR	JOGESWARPUR (GA	14263	11 KV GadaAmarprasad	14263203	TULASIPURA MAHAJANA SAHI	1413DT409	100	MIXED	AMI	Yes	0%	115	0.04857923	0.043047	0.00553223	11.39%
2366	TPCODL	BBSR1	NED	KAKATPUR	KAKATPUR	14030	11 KV KAKATPUR-1 ISO	14030201	CHANDAN BAZAR-1	1412DT005	250	MIXED	AMI	Yes	67%	80	0.200023	0.051331	0.148692	74.34%
2367	TPCODL	BBSR1	NED	KAKATPUR	KAKATPUR	14030	11 KV KAKATPUR-1 ISO	14030201	MANGAL COLLEGE,PRACHI VIHAR	1412DT009	250	MIXED	AMI	Yes	0%	190	0.15275888	0.11073	0.04202888	27.51%
2368	TPCODL	BBSR1	NED	KAKATPUR	KAKATPUR	14030	11 KV KAKATPUR-1 ISO	14030201	BLOCK CHHAKA	1412DT010	250	MIXED	AMI	Yes	100%	98	0.06677922	0.054923	0.01185622	17.75%
2369	TPCODL	BBSR1	NED	KAKATPUR	KAKATPUR	14030	11 KV NILAKANTHAPUR	14030203	GOKULPUR	1412DT017	63	MIXED	AMI	Yes	0%	79	0.04273828	0.019973	0.02276528	53.27%
2370	TPCODL	BBSR1	NED	KAKATPUR	KAKATPUR	14030	11 KV NILAKANTHAPUR	14030203	NILAKANTHAPUR	1412DT018	100	MIXED	AMI	Yes	67%	37	0.05613404	0.015837	0.04029704	71.79%
2371	TPCODL	BBSR1	NED	KAKATPUR	KAKATPUR	14030	11 KV NILAKANTHAPUR	14030203	TUKAMALA	1412DT021	63	MIXED	AMI	Yes	0%	50	0.04612384	0.021793	0.02433084	52.75%
2372	TPCODL	BBSR1	NED	KAKATPUR	KAKATPUR	14030	11 KV NILAKANTHAPUR	14030203	GAMBHARIPADA	1412DT033	100	MIXED	AMI	Yes	67%	102	0.05091746	0.032141	0.01877646	36.88%
2373	TPCODL	BBSR1	NED	KAKATPUR	KAKATPUR	14030	11 KV NILAKANTHAPUR	14030203	FAKIRSAHI	1412DT039	250	MIXED	AMI	Yes	0%	171	0.16561928	0.072262	0.09335728	56.37%
2374	TPCODL	BBSR1	NED	KAKATPUR	KAKATPUR	14030	11 KV NILAKANTHAPUR	14030203	FAKIRSAHI PATANA	1412DT044	100	MIXED	AMI	Yes	0%	116	0.0660176	0.036649	0.0293686	44.49%
2375	TPCODL	BBSR1	NED	KAKATPUR	KAKATPUR	14030	11 KV NILAKANTHAPUR	14030203	FAKIRSAHI BASTI CANAL	1412DT055	100	MIXED	AMI	Yes	67%	70	0.05812168	0.040729	0.01739268	29.92%
2376	TPCODL	BBSR1	NED	KAKATPUR	KAKATPUR	14030	11 KV NILAKANTHAPUR	14030203	BADAKANA	1412DT062	100	MIXED	AMI	Yes	67%	177	0.07885494	0.046519	0.03233594	41.01%
2377	TPCODL	BBSR1	NED	KAKATPUR	KAKATPUR	14030	11 KV NILAKANTHAPUR	14030203	MAHADEBASTA	1412DT065	250	MIXED	AMI	Yes	67%	156	0.0813476	0.038225	0.0431226	53.01%
2378	TPCODL	BBSR1	NED	KAKATPUR	KAKATPUR	14030	11 KV NILAKANTHAPUR	14030203	PATHARAPAKA	1412DT089	100	MIXED	AMI	Yes	67%	242	0.09411334	0.069337	0.02477634	26.33%
2379	TPCODL	BBSR1	NED	KAKATPUR	KAKATPUR	14030	11 KV NILAKANTHAPUR	14030203	SADANSHA	1412DT090	100	MIXED	AMI	Yes	67%	71	0.02997404	0.021393	0.00858104	28.63%
2380	TPCODL	BBSR1	NED	KAKATPUR	KAKATPUR	14030	11 KV NILAKANTHAPUR	14030203	BIBHUTIPUR	1412DT096	100	MIXED	AMI	Yes	67%	130	0.06283586	0.03809	0.02474586	39.38%
2381	TPCODL	BBSR1	NED	KAKATPUR	KAKATPUR	14030	11 KV NILAKANTHAPUR	14030203	BIBHUTI PUR MUDLI SAHI	1412DT097	100	MIXED	AMI	Yes	67%	52	0.04461676	0.027532	0.01708476	38.29%
2382	TPCODL	BBSR1	NED	KAKATPUR	KAKATPUR	14030	11 KV NAYAHAT-2	14030204	MEDICAL PATAPUR	1413DT025	100	MIXED	AMI	Yes	67%	126	0.0566682	0.03572344	0.02094476	36.96%
2383	TPCODL	BBSR1	NED	KAKATPUR	KAKATPUR	14030	11 KV NAYAHAT-2	14030204	MADUBAN	1413DT061	63	MIXED	AMI	Yes	67%	63	0.03921046	0.02151	0.01770046	45.14%
2384	TPCODL	BBSR1	NED	KAKATPUR	KAKATPUR	14030	11 KV NAYAHAT-2	14030204	GOPIKANTAPUR	1413DT064	100	MIXED	AMI	Yes	67%	50	0.05363788	0.013615	0.04002288	74.62%
2385	TPCODL	BBSR1	NED	KAKATPUR	KAKATPUR	14030	11 KV NAYAHAT-2	14030204	KADAM PATNA	1413DT085	63	MIXED	AMI	Yes	100%	93	0.03277371	0.022126	0.01064771	32.49%
2386	TPCODL	BBSR1	NED	KAKATPUR	KAKATPUR	14030	11 KV NAYAHAT-2	14030204	BHARBALA	1413DT091	100	MIXED	AMI	Yes	0%	63	0.03602998	0.016627	0.01940298	53.85%
2387	TPCODL	BBSR1	NED	KAKATPUR	KAKATPUR	14030	11 KV NAYAHAT-2	14030204	ANAPADA	1413DT095	100	MIXED	AMI	Yes	67%	39	0.01741804	0.008683	0.00873504	50.15%
2388	TPCODL	BBSR1	NED	KAKATPUR	KAKATPUR	14030	11 KV NAYAHAT-2	14030204	KORUAL	1413DT134	100	MIXED	AMI	Yes	0%	90	0.04210258	0.023801	0.01830158	43.47%
2389	TPCODL	BBSR1	NED	KAKATPUR	KAKATPUR	14030	11 KV NAYAHAT-2	14030204	DURGESWAR AGROW	1413DT191	100	MIXED	AMI	Yes	0%	7	0.00251632	0.001076	0.00144032	57.24%
2390	TPCODL	BBSR1	NED	KAKATPUR	KAKATPUR	14030	11 KV KAKATPUR-2	14030205	MEDICAL CHHAKA	1412DT109	500	MIXED	AMI	Yes	0%	304	0.3124272	0.218634	0.0937932	30.02%
2391	TPCODL	BBSR1	NED	KAKATPUR	KAKATPUR	14030	11 KV KAKATPUR-2	14030205	JUNGLE MOHALA	1412DT112	250	MIXED	AMI	Yes	0%	10	0.08358788	0.048994	0.03459388	41.39%
2392	TPCODL	BBSR1	NED	KAKATPUR	KAKATPUR	14030	11 KV KAKATPUR-2	14030205	MOHANTY SAHI ITAPADA	1412DT118	100	MIXED	AMI	Yes	67%	63	0.0850962	0.048902	0.0361942	42.53%
2393	TPCODL	BBSR1	NED	KAKATPUR	KAKATPUR	14030	11 KV KAKATPUR-2	14030205	SAMIA	1412DT120	250	MIXED	AMI	Yes	0%	120	0.18308288	0.06901	0.11407288	62.31%
2394	TPCODL	BBSR1	NED	KAKATPUR	KAKATPUR	14030	11 KV KAKATPUR-2	14030205	TAHASHIL	1412DT126	250	MIXED	AMI	Yes	67%	130	0.10538164	0.066484	0.03889764	36.91%
2395	TPCODL	BBSR1	NED	KAKATPUR	KAKATPUR	14030	11 KV KAKATPUR-2	14030205	BAJAPUR-1	1412DT137	250	MIXED	AMI	Yes	33%	165	0.1043534	0.094524	0.0098294	9.42%
2396	TPCODL	BBSR1	NED	KAKATPUR	KAKATPUR	14030	11 KV KAKATPUR-2	14030205	BAJAPUR-2	1412DT138	250	MIXED	AMI	Yes	67%	187	0.09563144	0.074165	0.02146644	22.45%
2397	TPCODL	BBSR1	NED	KAKATPUR	KAKATPUR	14030	11 KV KAKATPUR-2	14030205	MOCHI SAHI PRACHIVIHAR	1412DT160	250	MIXED	AMI	Yes	0%	184	0.1375938	0.111586	0.0260078	18.90%
2398	TPCODL	BBSR1	NED	KAKATPUR	KAKATPUR	14030	11 KV KAKATPUR-2	14030205	PITAMBERPUR	1412DT162	100	MIXED	AMI	Yes	67%	77	0.02771788	0.021327	0.00639088	23.06%
2399	TPCODL	BBSR1	NED	KAKATPUR	KAKATPUR	14030	11 KV KAKATPUR-2	14030205	CHAKIAMATHA	1412DT164	100	MIXED	AMI	Yes	67%	55	0.0228817	0.016221	0.0066607	29.11%
2400	TPCODL	BBSR1	NED	KAKATPUR	KAKATPUR	14030	11 KV KAKATPUR-2	14030205	KUNDHEI HATA SCHOOL	1412DT183	100	MIXED	AMI	Yes	67%	81	0.04464461	0.0305	0.01414461	31.68%
2401	TPCODL	BBSR1	NED	KAKATPUR	KAKATPUR	14030	11 KV KAKATPUR-2	14030205	KOILIPUR	1412DT189	100	MIXED	AMI	Yes	0%	58	0.0392526	0.017277	0.0219756	55.99%
2402	TPCODL	BBSR1	NED	KAKATPUR	KAKATPUR	14030	11 KV KAKATPUR-2	14030205	KUNDESWAR	1412DT193	250	MIXED	AMI	Yes	67%	87	0.04508112	0.028402	0.01667912	37.00%
2403	TPCODL	BBSR1	NED	KAKATPUR	KAKATPUR	14030	11 KV KAKATPUR-2	14030205	KACHAHRI BADI-1	1412DT202	250	MIXED	AMI	Yes	67%	143	0.15813096	0.091949	0.06618196	41.85%
2404	TPCODL	BBSR1	NED	KAKATPUR	KAKATPUR	14030	11 KV KAKATPUR-2	14030205	KACHAHRI BADI-2	1412DT203	250	MIXED	AMI	Yes	0%	82	0.14187716	0.066471	0.07540616	53.15%
2405	TPCODL	BBSR1	NED	KAKATPUR	KAKATPUR	14030	11 KV KAKATPUR-2	14030205	MALASAHI	1412DT218	250	MIXED	AMI	Yes	0%	128	0.11224468	0.085128	0.02711668	24.16%
2406	TPCODL	BBSR1	NED	KAKATPUR	KAKATPUR	14030	11 KV KAKATPUR-2	14030205	DHURJANG	1412DT227	100	MIXED	AMI	Yes	67%	55	0.02960098	0.014816	0.01478498	49.95%
2407	TPCODL	BBSR1	NED	KAKATPUR	KAKATPUR	14030	11 KV KAKATPUR-2	14030205	LATAHARAN BASTI	1412DT228	250	MIXED	AMI	Yes	0%	127	0.10077098	0.059233	0.04153798	41.22%
2408	TPCODL	BBSR1	NED	KAKATPUR	KAKATPUR	14030	11 KV KAKATPUR-2	14030205	LATAHARAN HIGH SCHOOL	1412DT231	100	MIXED	AMI	Yes	100%	136	0.10653752	0.045508	0.06102952	57.28%

Sl. No.	Zone Name	Circle name	Division name	Name of the Sub-division	Name of the Sub-station	Substation Code	Name of the 11 kV Feeder	Feeder Code	Name of the Location where DT situated	DT code	DT Capacity (kVA)	Predominant consumer type of DT (Domestic/Industrial/Agriculture/Mixed)	Type of metering AMR/AMI/ Communicable/Conventional metered/Unmetered	Status of Meter- whether Functional (Yes/No)	% of data received automatically (if AMR/AMI)	No. of Connected Consumers	Input Energy (MU) (A)	Billed Energy (MU) (B)	Loss (MU) (A-B)	% DT Loss (A-B)/A
2409	TPCODL	BBSR1	NED	KAKATPUR	KAKATPUR	14030	11 KV KAKATPUR-2	14030205	AMBHUNIA PATNA-2	1412DT237	100	MIXED	AMI	Yes	0%	212	0.07022284	0.052127	0.01809584	25.77%
2410	TPCODL	BBSR1	NED	KAKATPUR	KAKATPUR	14030	11 KV KAKATPUR-2	14030205	BAURIAKANA	1412DT241	100	MIXED	AMI	Yes	0%	81	0.02014432	0.015984	0.00416032	20.65%
2411	TPCODL	BBSR1	NED	KAKATPUR	KAKATPUR	14030	11 KV KAKATPUR-2	14030205	PATHARAPAKA,MAHAVIR	1412DT245	100	MIXED	AMI	Yes	0%	88	0.04570704	0.022566	0.02314104	50.63%
2412	TPCODL	BBSR1	NED	KAKATPUR	KAKATPUR	14030	11 KV KAKATPUR-2	14030205	BANKESWAR	1412DT246	100	MIXED	AMI	Yes	0%	83	0.02063034	0.015646	0.00498434	24.16%
2413	TPCODL	BBSR1	NED	KAKATPUR	KAKATPUR	14030	11 KV KAKATPUR-2	14030205	RAJIPUR	1412DT247	100	MIXED	AMI	Yes	0%	67	0.0634648	0.033977	0.0294878	46.46%
2414	TPCODL	BBSR1	NED	KAKATPUR	KAKATPUR	14030	11 KV KAKATPUR-2	14030205	RASULPUR,KARTIA SAHI	1412DT255	100	MIXED	AMI	Yes	0%	95	0.0615351	0.045403	0.0161321	26.22%
2415	TPCODL	BBSR1	NED	KAKATPUR	KAKATPUR	14030	11 KV KAKATPUR-2	14030205	KHANPUR BASTI	1412DT258	100	MIXED	AMI	Yes	0%	33	0.06232772	0.014831	0.04749672	76.20%
2416	TPCODL	BBSR1	NED	KAKATPUR	KAKATPUR	14030	11 KV KAKATPUR-2	14030205	KHANPUR	1412DT259	100	MIXED	AMI	Yes	0%	50	0.04385188	0.025476	0.01837588	41.90%
2417	TPCODL	BBSR1	NED	KAKATPUR	KAKATPUR	14030	11 KV KAKATPUR-2	14030205	MALA MACHHA	1412DT271	100	MIXED	AMI	Yes	67%	94	0.04132342	0.030343	0.01098042	26.57%
2418	TPCODL	BBSR1	NED	KAKATPUR	PATALDA ODSSP	14256	11 kV NUAGADA	14256201	BAURIDHIA	1411DT168	63	MIXED	AMI	Yes	0%	72	0.05033718	0.019571	0.03076618	61.12%
2419	TPCODL	BBSR1	NED	KAKATPUR	PATALDA ODSSP	14256	11 kV NUAGADA	14256201	BADA JHALIG	1411DT174	100	MIXED	AMI	Yes	0%	67	0.0374092	0.017148	0.0202612	54.16%
2420	TPCODL	BBSR1	NED	KAKATPUR	PATALDA ODSSP	14256	11 kV NUAGADA	14256201	NUAGADA LODHANI	1411DT193	100	MIXED	AMI	Yes	0%	94	0.11819024	0.024102	0.09408824	79.61%
2421	TPCODL	BBSR1	NED	KAKATPUR	PATALDA ODSSP	14256	11 kV NUAGADA	14256201	DALAKHAI	1411DT206	100	MIXED	AMI	Yes	100%	85	0.05001602	0.0233	0.02671602	53.41%
2422	TPCODL	BBSR1	NED	KAKATPUR	PATALDA ODSSP	14256	11 kV PATALADA	14256202	PATALDA	1411DT410	100	MIXED	AMI	Yes	0%	54	0.02990088	0.021571	0.00832988	27.86%
2423	TPCODL	BBSR1	NED	KAKATPUR	PATALDA ODSSP	14256	11 kV PATALADA	14256202	SILARI	1411DT422	100	MIXED	AMI	Yes	67%	114	0.06096256	0.028031	0.03293156	54.02%
2424	TPCODL	BBSR1	NED	KAKATPUR	PATALDA ODSSP	14256	11 kV PATALADA	14256202	ANISINIA	1411DT438	100	MIXED	AMI	Yes	0%	74	0.02162144	0.021203	0.00041844	1.94%
2425	TPCODL	BBSR1	NED	KAKATPUR	PATALDA ODSSP	14256	11 kV PATALADA	14256202	RAIBENUHAN	1411DT503	100	MIXED	AMI	Yes	67%	60	0.02971172	0.01783	0.01188172	39.99%
2426	TPCODL	BBSR1	NED	KAKATPUR	PATALDA ODSSP	14256	11 kV PATALADA	14256202	SUNDARA	1411DT539	100	MIXED	AMI	Yes	67%	72	0.0372309	0.035401	0.0018299	4.92%
2427	TPCODL	BBSR1	NED	KAKATPUR	PATALDA ODSSP	14256	KANAMANA	14256203	KANAMARA	1411DT448	100	MIXED	AMI	Yes	67%	26	0.03231686	0.008967	0.02334986	72.25%
2428	TPCODL	BBSR1	NED	KAKATPUR	PATALDA ODSSP	14256	KANAMANA	14256203	BALABHADRAPUR	1411DT461	100	MIXED	AMI	Yes	67%	42	0.02375828	0.009307	0.01445128	60.83%
2429	TPCODL	BBSR1	NED	KAKATPUR	PATALDA ODSSP	14256	KANAMANA	14256203	SUDHIKESWARA	1411DT464	100	MIXED	AMI	Yes	67%	46	0.03532324	0.009386	0.02593724	73.43%
2430	TPCODL	BBSR1	NED	KAKATPUR	PATALDA ODSSP	14256	KANAMANA	14256203	SAHANA	1411DT468	100	MIXED	AMI	Yes	67%	114	0.04407036	0.023789	0.02028136	46.02%
2431	TPCODL	BBSR1	NED	KAKATPUR	PATALDA ODSSP	14256	KANAMANA	14256203	GUNDALABA	1411DT476	63	MIXED	AMI	Yes	67%	43	0.01999568	0.012102	0.00789368	39.48%
2432	TPCODL	BBSR1	NED	KAKATPUR	RAHAMA	14177	11 KV RAHAMA	14177201	NEAR BY M BAZAR	5413DT040	250	MIXED	AMI	Yes	100%	203	0.1722634	0.16053	0.0117334	6.81%
2433	TPCODL	BBSR1	NED	KAKATPUR	TRILOCHANPUR OD	14342	11 KV SANDHAKUDA	14342203	NALIA SAHI 3	5422DT363	250	MIXED	AMI	Yes	67%	854	0.19921048	0.13192	0.06729048	33.78%
2434	TPCODL	BBSR1	NED	NIMAPARA	PATALDA ODSSP	14256	11 kV NUAGADA	14256201	SAN JHALING	1411DT212	100	MIXED	AMI	Yes	67%	86	0.03434602	0.020984	0.01336202	38.90%
2435	TPCODL	BBSR1	NED	NIMAPARA	ASTARANGA	14029	11 KV JIUNTY	14029202	KENDRAPATI	1411DT321	100	MIXED	AMI	Yes	0%	105	0.04503045	0.022019	0.02301145	51.10%
2436	TPCODL	BBSR1	NED	NIMAPARA	BALIPATNA	14024	11 KV NARADA	14024204	MAHAVEER CHHAKA NARADA	1432DT444	100	MIXED	AMI	Yes	67%	132	0.08324154	0.059348	0.02389354	28.70%
2437	TPCODL	BBSR1	NED	NIMAPARA	BAMANAL ODSSP	14257	11 KV NUASANTHA	14257201	BAMANAL-1	1424DT334	100	MIXED	AMI	Yes	100%	104	0.07396992	0.030481	0.04348892	58.79%
2438	TPCODL	BBSR1	NED	NIMAPARA	BAMANAL ODSSP	14257	11 KV NUASANTHA	14257201	BAMANAL-2	1424DT335	100	MIXED	AMI	Yes	0%	90	0.0333701	0.024885	0.0084851	25.43%
2439	TPCODL	BBSR1	NED	NIMAPARA	BAMANAL ODSSP	14257	11 KV NUASANTHA	14257201	BANDHAMUNDA	1424DT395	100	MIXED	AMI	Yes	67%	54	0.04413954	0.020297	0.02384254	54.02%
2440	TPCODL	BBSR1	NED	NIMAPARA	BAMANAL ODSSP	14257	11 KV VBHNTI	14257202	OHAL MV	1424DT298	100	MIXED	AMI	Yes	100%	39	0.04264682	0.009894	0.03275282	76.80%
2441	TPCODL	BBSR1	NED	NIMAPARA	BAMANAL ODSSP	14257	11 KV VBHNTI	14257202	BAMADEIPUR-1	1424DT324	100	MIXED	AMI	Yes	100%	124	0.05246066	0.048274	0.00418666	7.98%
2442	TPCODL	BBSR1	NED	NIMAPARA	BAMANAL ODSSP	14257	11 KV DAVAR	14257203	SALANGA	1424DT412	100	MIXED	AMI	Yes	0%	112	0.1182503	0.035951	0.0822993	69.60%
2443	TPCODL	BBSR1	NED	NIMAPARA	BAMANAL ODSSP	14257	11 KV DAVAR	14257203	OLAMARA	1424DT427	100	MIXED	AMI	Yes	67%	80	0.0432443	0.020736	0.0225083	52.05%
2444	TPCODL	BBSR1	NED	NIMAPARA	BAMANAL ODSSP	14257	11 KV DAVAR	14257203	KHANDA SAHI	1424DT435	100	MIXED	AMI	Yes	67%	174	0.052571	0.04182453	0.01074647	20.44%
2445	TPCODL	BBSR1	NED	NIMAPARA	BAMANAL ODSSP	14257	11 KV DAVAR	14257203	ADHENA	1424DT438	100	MIXED	AMI	Yes	67%	85	0.05927238	0.017124	0.04214838	71.11%
2446	TPCODL	BBSR1	NED	NIMAPARA	BASANTAMAL (ABH	14260	11 KV ABHAYAMUKHI	14260201	RANGA MATHA CHHAKA	1423DT114	100	MIXED	AMI	Yes	67%	105	0.07243336	0.028085	0.04434836	61.23%
2447	TPCODL	BBSR1	NED	NIMAPARA	BASANTAMAL (ABH	14260	11 KV ABHAYAMUKHI	14260201	BANTU GRAM	1423DT117	100	MIXED	AMI	Yes	67%	83	0.06953358	0.037221	0.03231258	46.47%
2448	TPCODL	BBSR1	NED	NIMAPARA	BASANTAMAL (ABH	14260	11 KV ABHAYAMUKHI	14260201	KANTA SAHI NO-1	1423DT143	100	MIXED	AMI	Yes	67%	84	0.11369898	0.025083	0.08861598	77.94%
2449	TPCODL	BBSR1	NED	NIMAPARA	BASANTAMAL (ABH	14260	11 KV ABHAYAMUKHI	14260201	ABHAYA MUKHI SASANA	1423DT147	100	MIXED	AMI	Yes	67%	116	0.10620496	0.049665	0.05653996	53.24%
2450	TPCODL	BBSR1	NED	NIMAPARA	BASANTAMAL (ABH	14260	11 KV ABHAYAMUKHI	14260201	ADHINCHA NO-2	1423DT149	100	MIXED	AMI	Yes	67%	131	0.14803238	0.034172	0.11386038	76.92%
2451	TPCODL	BBSR1	NED	NIMAPARA	BASANTAMAL (ABH	14260	11 KV BASANTAMLA	14260202	BADALA CHHAKA	1423DT053	100	MIXED	AMI	Yes	0%	15	0.02035722	0.004197	0.01616022	79.38%
2452	TPCODL	BBSR1	NED	NIMAPARA	BASANTAMAL (ABH	14260	11 KV BASANTAMLA	14260202	BASANTAMALA CHHAKA NO-2	1423DT073	250	MIXED	AMI	Yes	67%	87	0.10945632	0.04103	0.06842632	62.51%
2453	TPCODL	BBSR1	NED	NIMAPARA	BASANTAMAL (ABH	14260	11 KV BASANTAMLA	14260202	ODAKHANDA GADA SAHI	1423DT161	100	MIXED	AMI	Yes	0%	44	0.03413434	0.014538	0.01959634	57.41%
2454	TPCODL	BBSR1	NED	NIMAPARA	BASANTAMAL (ABH	14260	11 KV BASANTAMLA	14260202	ORISA NO-1	1423DT165	63	MIXED	AMI	Yes	67%	130	0.10810266	0.037172	0.07093066	65.61%
2455	TPCODL	BBSR1	NED	NIMAPARA	BASANTAMAL (ABH	14260	11 KV CHENUA	14260203	ALIPINGALA KARA SAHI	1423DT086	100	MIXED	AMI	Yes	100%	52	0.06287396	0.022842	0.04003196	63.67%
2456	TPCODL	BBSR1	NED	NIMAPARA	BASANTAMAL (ABH	14260	11 KV CHENUA	14260203	PADMAPUR	1423DT092	63	MIXED	AMI	Yes	33%	78	0.0459387	0.037363	0.0085757	18.67%
2457	TPCODL	BBSR1	NED	NIMAPARA	BASANTAMAL (ABH	14260	11 KV CHENUA	14260203	KANDAL MUDULI SAHI	1423DT106	100	MIXED	AMI	Yes	100%	67	0.0626866	0.02108	0.0416066	66.37%
2458	TPCODL	BBSR1	NED	NIMAPARA	CHARICHHAKA DDU	14373	11 KV SAILO	14373201	JUNU PUR	1423DT277	100	MIXED	AMI	Yes	100%	84	0.06403548	0.027811	0.03622448	56.57%
2459	TPCODL	BBSR1	NED	NIMAPARA	CHHAITANA	14032	11 KV CHARISHREE FEED	14032201	ITI BHUAN	1421DT578	63	MIXED	AMI	Yes	0%	107	0.06704476	0.04615	0.02089476	31.17%
2460	TPCODL	BBSR1	NED	NIMAPARA	CHHAITANA	14032	11 KV CHARISHREE FEED	14032201	NUAPADA-2	1421DT611	100	MIXED	AMI	Yes	0%	52	0.01549885	0.010657	0.00484185	31.24%
2461	TPCODL	BBSR1	NED	NIMAPARA	CHHAITANA	14032	11 KV CHARISHREE FEED	14032201	BARANA-1	1421DT614	100	MIXED	AMI	Yes	67%	96	0.04065272	0.016556	0.02409672	59.27%
2462	TPCODL	BBSR1	NED	NIMAPARA	CHHAITANA	14032	11 KV CHARISHREE FEED	14032201	TARANA	1421DT655	100	MIXED	AMI	Yes	67%	134	0.06617408	0.036746	0.02942808	44.47%
2463	TPCODL	BBSR1	NED	NIMAPARA	CHHAITANA	14032	11 KV CHARISHREE FEED	14032201	JAULI POKHARI	1421DT661	100	MIXED	AMI	Yes	67%	56	0.05488964	0.013407	0.04148264	75.57%
2464	TPCODL	BBSR1	NED	NIMAPARA	CHHAITANA	14032	11 KV CHARISHREE FEED	14032201	CHHAITANA	1421DT671	250	MIXED	AMI	Yes	0%	124	0.10254404	0.032091	0.07045304	68.71%
2465	TPCODL	BBSR1	NED	NIMAPARA	CHHAITANA	14032	11 KV DALANAI FEEDER A	14032202	CHATOLA	1421DT511	63	MIXED	AMI	Yes	67%	53	0.0316261	0.010425	0.0212011	67.04%
2466	TPCODL	BBSR1	NED	NIMAPARA	CHHAITANA	14032	11 KV DALANAI FEEDER A	14032202	BAIRIPUR	1421DT541	100	MIXED	AMI	Yes	67%	65	0.0704851	0.021026	0.0494591	70.17%
2467	TPCODL	BBSR1	NED	NIMAPARA	CHHAITANA	14032	11 KV DALANAI FEEDER A	14032202	DALANAI BAZAR	1421DT543	100	MIXED	AMI	Yes	67%	88	0.05171802	0.023109	0.02860902	55.32%
2468	TPCODL	BBSR1	NED	NIMAPARA	CHHAITANA	14032	11 KV DALANAI FEEDER A	14032202	UCHHUPUR	1421DT547	100	MIXED	AMI	Yes	67%	86	0.06286802	0.01819	0.04467802	71.07%
2469	TPCODL	BBSR1	NED	NIMAPARA	CHHAITANA	14032	11 KV DALANAI FEEDER A	14032202	BALI GHAI	1421DT553	100	MIXED	AMI	Yes	67%	96	0.07110988	0.024452	0.04665788	65.61%
2470	TPCODL	BBSR1	NED	NIMAPARA	DANDIPUR ODSSP	14379	11 KV KALIAPADA	14379201	DURGAPUR(DAKHINA SAHI)	1424DT086	100	MIXED	AMI	Yes	100%	56	0.0458041	0.016991	0.0288131	62.91%
2471	TPCODL	BBSR1	NED	NIMAPARA	DANDIPUR ODSSP	14379	11 KV KALIAPADA	14379201	BERA BOI	1424DT097	100	MIXED	AMI	Yes	0%	80	0.04326512	0.020641	0.02262412	52.29%
2472	TPCODL	BBSR1	NED	NIMAPARA	DANDIPUR ODSSP	14379	11 KV KALIAPADA	14379201	KALIA PADA	1424DT216	63	MIXED	AMI	Yes	100%	52	0.03479088	0.017865	0.01692588	48.65%
2473	TPCODL	BBSR1	NED	NIMAPARA	DANDIPUR ODSSP	14379	11 KV ALANDA	14379202	KUMAR PADA	1424DT034	100	MIXED	AMI	Yes	67%	130	0.07941886	0.040965	0.03845386	48.42%
2474	TPCODL	BBSR1	NED	NIMAPARA	DANDIPUR ODSSP	14379	11 KV ALANDA	14379202	JAGARI	1424DT042	100	MIXED	AMI	Yes	0%	75	0.06750638	0.024709	0.04279738	63.40%
2475	TPCODL	BBSR1	NED	NIMAPARA	DANDIPUR ODSSP	14379	11 KV ALANDA	14379202	MANI JANGA	1424DT044	100	MIXED	AMI	Yes	67%	99	0.06528466	0.026232	0.03905266	59.82%
2476	TPCODL	BBSR1	NED	NIMAPARA	DANDIPUR ODSSP	14379	11 KV ALANDA	14379202	TORIHAN BANDHA(TELI SAHI)	1424DT048	100	MIXED	AMI	Yes	67%	64	0.03554456	0.025093	0.01045156	29.40%
2477	TPCODL	BBSR1	NED	NIMAPARA	DANDIPUR ODSSP	14379	11 KV ALANDA	14379202	TORABANGA	1424DT051	100	MIXED	AMI	Yes	0%	73	0.03055217	0.01553	0.01502217	49.17%
2478	TPCODL	BBSR1	NED	NIMAPARA	DANDIPUR ODSSP	14379	11 KV ALANDA	14379202	TORIHANAN BANDHA(PRADHAN SAH	1424DT067	100	MIXED	AMI	Yes	67%	35	0.018565	0.006283	0.012282	66.16%
2479	TPCODL	BBSR1	NED	NIMAPARA	DANDIPUR ODSSP	14379	11 KV DHANUA	14379203	BHAGWAN SUNDRA	1424DT113	100	MIXED	AMI	Yes	67%	56	0.0408395	0.009839	0.0310005	75.91%
2480	TPCODL	BBSR1	NED	NIMAPARA	DANDIPUR ODSSP	14379	11 KV DHANUA	14379203	KOLAHANA	1424DT141	100	MIXED	AMI	Yes	0%	107	0.04736646	0.029981	0.01738546	36.70%
2481	TPCODL	BBSR1	NED	NIMAPARA	GOP	14051	11 KV GOP	14051201	BAYAKUDA	1421DT126	63	MIXED	AMI	Yes	0%	72	0.03627788	0.030806	0.00547188	15.08%

Sl. No.	Zone Name	Circle name	Division name	Name of the Sub-division	Name of the Sub-station	Substation Code	Name of the 11 kV Feeder	Feeder Code	Name of the Location where DT situated	DT code	DT Capacity (kVA)	Predominant consumer type of DT (Domestic/Industrial/Agriculture/Mixed)	Type of metering AMR/AMI/ Communicable/Conventional metered/Unmetered	Status of Meter-whether Functional (Yes/No)	% of data received automatically (if AMR/AMI)	No. of Connected Consumers	Input Energy (MU) (A)	Billed Energy (MU) (B)	Loss (MU) (A-B)	% DT Loss (A-B)/A
2482	TPCODL	BBSR1	NED	NIMAPARA	GOP	14051	11 KV GOP	14051201	BANIA SAHI	1421DT146	100	MIXED	AMI	Yes	100%	104	0.07603254	0.052094	0.02393854	31.48%
2483	TPCODL	BBSR1	NED	NIMAPARA	GOP	14051	11 KV GOP	14051201	GOP BASTI	1421DT151	250	MIXED	AMI	Yes	0%	142	0.18243496	0.091724	0.09071096	49.72%
2484	TPCODL	BBSR1	NED	NIMAPARA	GOP	14051	11 KV GOP	14051201	KUSUPUR HATA-2	1421DT159	100	MIXED	AMI	Yes	100%	124	0.0760893	0.04458817	0.03150113	41.40%
2485	TPCODL	BBSR1	NED	NIMAPARA	GOP	14051	11 KV GOP	14051201	KUSUPUR GAON MUNDA	1421DT166	100	MIXED	AMI	Yes	33%	104	0.14401334	0.047498	0.09651534	67.02%
2486	TPCODL	BBSR1	NED	NIMAPARA	GOP	14051	11 KV GOP	14051201	BENIPUR ROUT SAHI	1421DT173	63	MIXED	AMI	Yes	0%	56	0.04942944	0.01034	0.03908944	79.08%
2487	TPCODL	BBSR1	NED	NIMAPARA	GOP	14051	11 KV NAGAPUR	14051202	GANESWARPUR-1	1421DT410	250	MIXED	AMI	Yes	0%	84	0.155466	0.035792	0.119674	76.98%
2488	TPCODL	BBSR1	NED	NIMAPARA	GOP	14051	11 KV NAGAPUR	14051202	SUBARNAPUR-3	1421DT419	250	MIXED	AMI	Yes	100%	93	0.1096042	0.064595	0.0450092	41.07%
2489	TPCODL	BBSR1	NED	NIMAPARA	GOP	14051	11 KV NAGAPUR	14051202	ODAMBA-1	1421DT474	100	MIXED	AMI	Yes	0%	60	0.04100398	0.019034	0.02196998	53.58%
2490	TPCODL	BBSR1	NED	NIMAPARA	GOP	14051	11 KV NAGAPUR	14051202	POITARA	1421DT481	100	MIXED	AMI	Yes	100%	112	0.06466664	0.039647	0.02501964	38.69%
2491	TPCODL	BBSR1	NED	NIMAPARA	GOP	14051	11 KV NAGAPUR	14051202	ALICHAR-1	1421DT490	100	MIXED	AMI	Yes	100%	61	0.04182364	0.018068	0.02375564	56.80%
2492	TPCODL	BBSR1	NED	NIMAPARA	GOP	14051	11 KV NAGAPUR	14051202	SANKHARIA	1421DT494	100	MIXED	AMI	Yes	100%	132	0.04404302	0.042366	0.00167702	3.81%
2493	TPCODL	BBSR1	NED	NIMAPARA	GOP	14051	11 KV BEGUNAI	14051203	BALISAHI	1421DT184	100	MIXED	AMI	Yes	0%	92	0.06585372	0.041031	0.02482272	37.69%
2494	TPCODL	BBSR1	NED	NIMAPARA	GOP	14051	11 KV BEGUNAI	14051203	BAYALISI BATIA-1	1421DT197	100	MIXED	AMI	Yes	0%	94	0.0459103	0.033286	0.0126243	27.50%
2495	TPCODL	BBSR1	NED	NIMAPARA	GOP	14051	11 KV BEGUNAI	14051203	BEGUNIA CHHAK-4	1421DT202	16	MIXED	AMI	Yes	67%	166	0.06973504	0.060644	0.00909104	13.04%
2496	TPCODL	BBSR1	NED	NIMAPARA	GOP	14051	11 KV BEGUNAI	14051203	BALI KANDAL	1421DT204	100	MIXED	AMI	Yes	67%	138	0.0615336	0.048688	0.0128456	20.88%
2497	TPCODL	BBSR1	NED	NIMAPARA	GOP	14051	11 KV BEGUNAI	14051203	BEDAPUR	1421DT207	250	MIXED	AMI	Yes	0%	200	0.122554	0.075699	0.046855	38.23%
2498	TPCODL	BBSR1	NED	NIMAPARA	GOP	14051	11 KV BEGUNAI	14051203	BEDAPUR SASAN	1421DT211	100	MIXED	AMI	Yes	67%	101	0.0474838	0.035683	0.0118008	24.85%
2499	TPCODL	BBSR1	NED	NIMAPARA	GOP	14051	11 KV BEGUNAI	14051203	BIRTUNGA-2	1421DT245	100	MIXED	AMI	Yes	33%	109	0.05417224	0.039701	0.01447124	26.71%
2500	TPCODL	BBSR1	NED	NIMAPARA	GOP	14051	11 KV BEGUNAI	14051203	BIRTUNGA ASHRAM	1421DT246	63	MIXED	AMI	Yes	67%	27	0.04718806	0.032494	0.01469406	31.14%
2501	TPCODL	BBSR1	NED	NIMAPARA	GOP	14051	11 KV BEGUNAI	14051203	GIRIMA DANDA	1421DT281	63	MIXED	AMI	Yes	67%	96	0.06782428	0.02078543	0.04703885	69.35%
2502	TPCODL	BBSR1	NED	NIMAPARA	GOP	14051	11 KV BEGUNAI	14051203	PATELA	1421DT290	100	MIXED	AMI	Yes	0%	76	0.04310918	0.02047	0.02263918	52.52%
2503	TPCODL	BBSR1	NED	NIMAPARA	GOP	14051	11 KV BEGUNAI	14051203	KUNDISHA	1421DT303	100	MIXED	AMI	Yes	67%	86	0.05022234	0.03179272	0.01842962	36.70%
2504	TPCODL	BBSR1	NED	NIMAPARA	GOP	14051	11 KV BEGUNAI	14051203	KUNDURA-1	1421DT305	100	MIXED	AMI	Yes	67%	30	0.01978726	0.010495	0.00929226	46.96%
2505	TPCODL	BBSR1	NED	NIMAPARA	GOP	14051	11 KV PAYARA	14051204	HAPPY COLONY TOWER	1421DT313	100	MIXED	AMI	Yes	100%	97	0.09596464	0.03885	0.05711464	59.52%
2506	TPCODL	BBSR1	NED	NIMAPARA	GOP	14051	11 KV PAYARA	14051204	SORISA PADA	1421DT320	100	MIXED	AMI	Yes	100%	78	0.03793992	0.022589	0.01535092	40.46%
2507	TPCODL	BBSR1	NED	NIMAPARA	GOP	14051	11 KV PAYARA	14051204	HELARI 2	1421DT331	100	MIXED	AMI	Yes	100%	46	0.0256518	0.008883	0.0167688	65.37%
2508	TPCODL	BBSR1	NED	NIMAPARA	GOP	14051	11 KV PAYARA	14051204	BASUDEIPUR HARIJANSAHI 2	1421DT355	100	MIXED	AMI	Yes	100%	68	0.03967778	0.014832	0.02484578	62.62%
2509	TPCODL	BBSR1	NED	NIMAPARA	KONARK	14031	11 KV KONARK O/H (CHA	14031201	VIVEKANANDA SCHOOL	1422DT117	100	MIXED	AMI	Yes	100%	125	0.09739816	0.059161	0.03823716	39.26%
2510	TPCODL	BBSR1	NED	NIMAPARA	KONARK	14031	11 KV KONARK O/H (CHA	14031201	NOLIA SAHI-II	1422DT129	100	MIXED	AMI	Yes	100%	197	0.11486308	0.077998	0.03686508	32.09%
2511	TPCODL	BBSR1	NED	NIMAPARA	KONARK	14031	11 KV KONARK O/H (CHA	14031201	LAVANYA LODGE	1422DT133	500	MIXED	AMI	Yes	0%	226	0.32993104	0.153222	0.17670904	53.56%
2512	TPCODL	BBSR1	NED	NIMAPARA	KONARK	14031	11 KV KONARK O/H (CHA	14031201	DALIMBA GORADI-I	1422DT139	250	MIXED	AMI	Yes	0%	192	0.12553336	0.096889	0.02864436	22.82%
2513	TPCODL	BBSR1	NED	NIMAPARA	KONARK	14031	11 KV KONARK O/H (CHA	14031201	DALIMBA GORADI-II	1422DT140	100	MIXED	AMI	Yes	100%	33	0.0276236	0.012354	0.0152696	55.28%
2514	TPCODL	BBSR1	NED	NIMAPARA	KONARK	14031	11 KV KONARK O/H (CHA	14031201	BALISAHI (KARA MANGA)	1422DT423	250	MIXED	AMI	Yes	100%	65	0.09048872	0.046576	0.04391272	48.53%
2515	TPCODL	BBSR1	NED	NIMAPARA	KONARK	14031	11 KV KONARK O/H (CHA	14031201	KARAMANGA	1422DT424	100	MIXED	AMI	Yes	100%	110	0.08994548	0.046915	0.04303048	47.84%
2516	TPCODL	BBSR1	NED	NIMAPARA	KONARK	14031	11 KV BALIDOKAN	14031202	TALASAHI	1422DT005	100	MIXED	AMI	Yes	100%	50	0.0474469	0.020217	0.0272299	57.39%
2517	TPCODL	BBSR1	NED	NIMAPARA	KONARK	14031	11 KV BALIDOKAN	14031202	KURAJANGA	1422DT073	100	MIXED	AMI	Yes	100%	89	0.05231302	0.034233	0.01808002	34.56%
2518	TPCODL	BBSR1	NED	NIMAPARA	KONARK	14031	11 KV BALIDOKAN	14031202	TALASUNA-I	1422DT077	100	MIXED	AMI	Yes	100%	158	0.05112184	0.040576	0.01054584	20.63%
2519	TPCODL	BBSR1	NED	NIMAPARA	KONARK	14031	11 KV BALIDOKAN	14031202	ADHULA	1422DT088	100	MIXED	AMI	Yes	100%	33	0.02462888	0.005931	0.01869788	75.92%
2520	TPCODL	BBSR1	NED	NIMAPARA	KONARK	14031	11 KV KONARK U/G	14031204	SBI	1422DT208	250	MIXED	AMI	Yes	100%	109	0.109922	0.078792	0.03113	28.32%
2521	TPCODL	BBSR1	NED	NIMAPARA	KONARK	14031	11 KV KONARK U/G	14031204	GOCHHAYAT SAHI	1422DT210	100	MIXED	AMI	Yes	100%	182	0.12688202	0.078777	0.04810502	37.91%
2522	TPCODL	BBSR1	NED	NIMAPARA	KONARK	14031	11 KV KONARK U/G	14031204	MADHIPUR BAZAR	1422DT211	100	MIXED	AMI	Yes	100%	81	0.07878414	0.075229	0.00355514	4.51%
2523	TPCODL	BBSR1	NED	NIMAPARA	KONARK	14031	11 KV KONARK U/G	14031204	PADHI SAHI	1422DT212	250	MIXED	AMI	Yes	0%	91	0.09095792	0.046411	0.04454692	48.98%
2524	TPCODL	BBSR1	NED	NIMAPARA	KONARK	14031	11 KV KONARK U/G	14031204	ROAD DEVELOPMENT DEPARTMENT	1422DT213	100	MIXED	AMI	Yes	100%	61	0.04981552	0.0331	0.01671552	33.55%
2525	TPCODL	BBSR1	NED	NIMAPARA	KONARK	14031	11 KV ANASARA	14031205	KHARAGAON	1422DT228	100	MIXED	AMI	Yes	0%	194	0.0543309	0.051152	0.0031789	5.85%
2526	TPCODL	BBSR1	NED	NIMAPARA	KONARK	14031	11 KV ANASARA	14031205	JUNEI-I	1422DT238	100	MIXED	AMI	Yes	67%	132	0.08346452	0.05041	0.03305452	39.60%
2527	TPCODL	BBSR1	NED	NIMAPARA	KONARK	14031	11 KV ANASARA	14031205	NUAGAON-III	1422DT243	100	MIXED	AMI	Yes	67%	108	0.04828756	0.029914	0.01837356	38.05%
2528	TPCODL	BBSR1	NED	NIMAPARA	KONARK	14031	11 KV DASABATIA	14031206	JUNEI BAZAR	1422DT269	250	MIXED	AMI	Yes	67%	113	0.16707292	0.060831	0.10624192	63.59%
2529	TPCODL	BBSR1	NED	NIMAPARA	KONARK	14031	11 KV DASABATIA	14031206	MANKARA GORADI-I	1422DT273	100	MIXED	AMI	Yes	67%	94	0.10676484	0.021369	0.08539584	79.98%
2530	TPCODL	BBSR1	NED	NIMAPARA	KONARK	14031	11 KV DASABATIA	14031206	DASABATIA CHHAK	1422DT286	100	MIXED	AMI	Yes	67%	51	0.03467046	0.016768	0.01790246	51.64%
2531	TPCODL	BBSR1	NED	NIMAPARA	KONARK	14031	11 KV DASABATIA	14031206	OREI ETA FACTORY-II	1422DT303	100	MIXED	AMI	Yes	0%	60	0.04589602	0.01887	0.02702602	58.89%
2532	TPCODL	BBSR1	NED	NIMAPARA	KONARK	14031	11 KV DASABATIA	14031206	TARAKARA	1422DT321	100	MIXED	AMI	Yes	67%	92	0.04200772	0.024659	0.01734872	41.30%
2533	TPCODL	BBSR1	NED	NIMAPARA	KONARK	14031	11 KV DASABATIA	14031206	NARUO	1422DT373	100	MIXED	AMI	Yes	67%	73	0.02994244	0.012775	0.01716744	57.33%
2534	TPCODL	BBSR1	NED	NIMAPARA	KONARK	14031	11 KV DASABATIA	14031206	SUTANA	1422DT387	100	MIXED	AMI	Yes	67%	130	0.08173002	0.039854	0.04187602	51.24%
2535	TPCODL	BBSR1	NED	NIMAPARA	KONARK	14031	11 KV DASABATIA	14031206	KUSABHADRA RIVER SIDE POND	1422DT429	100	MIXED	AMI	Yes	67%	3	0.07911232	0.077008	0.00210432	2.66%
2536	TPCODL	BBSR1	NED	NIMAPARA	KONARK	14031	11 KV SIRIPUR (KONARK)	14031207	ROULA PATNA	1422DT143	63	MIXED	AMI	Yes	0%	144	0.07413936	0.051203	0.02293636	30.94%
2537	TPCODL	BBSR1	NED	NIMAPARA	KONARK	14031	11 KV SIRIPUR (KONARK)	14031207	KUNJA MATHA-I	1422DT144	100	MIXED	AMI	Yes	0%	57	0.04237746	0.025649	0.01672846	39.47%
2538	TPCODL	BBSR1	NED	NIMAPARA	KONARK	14031	11 KV SIRIPUR (KONARK)	14031207	SIRIPUR	1422DT150	100	MIXED	AMI	Yes	100%	125	0.06734602	0.033353	0.03399302	50.48%
2539	TPCODL	BBSR1	NED	NIMAPARA	KONARK	14031	11 KV SIRIPUR (KONARK)	14031207	BOBUA-II	1422DT176	100	MIXED	AMI	Yes	67%	88	0.06449428	0.015156	0.04933828	76.50%
2540	TPCODL	BBSR1	NED	NIMAPARA	KUMARESWAR	14208	11 KV BALANGA	14208201	NARUDA MV	1424DT459	100	MIXED	AMI	Yes	0%	69	0.08270906	0.016945	0.06576406	79.51%
2541	TPCODL	BBSR1	NED	NIMAPARA	MADARANG (NAGA	14266	11 KV MALLAGRAM	14266201	GOLAPUR NO-1	1421DT058	100	MIXED	AMI	Yes	100%	88	0.04579912	0.033168	0.01263112	27.58%
2542	TPCODL	BBSR1	NED	NIMAPARA	MADARANG (NAGA	14266	11 KV MALLAGRAM	14266201	MALLAGRAM	1421DT063	100	MIXED	AMI	Yes	0%	117	0.05133717	0.036356	0.01498117	29.18%
2543	TPCODL	BBSR1	NED	NIMAPARA	MADARANG (NAGA	14266	11 KV MALLAGRAM	14266201	SOLAPUR NO II	1421DT091	100	MIXED	AMI	Yes	100%	119	0.06921688	0.036842	0.03237488	46.77%
2544	TPCODL	BBSR1	NED	NIMAPARA	MADARANG (NAGA	14266	11 KV NAGAPUR BAZAR	14266202	NAGAPUR SAHI	1421DT097	250	MIXED	AMI	Yes	100%	186	0.12451216	0.105142	0.01937016	15.56%
2545	TPCODL	BBSR1	NED	NIMAPARA	MADARANG (NAGA	14266	11 KV NAGAPUR BAZAR	14266202	NAGAPUR BAZAR NO-7	1421DT104	500	MIXED	AMI	Yes	0%	221	0.1830538	0.110799	0.0722548	39.47%
2546	TPCODL	BBSR1	NED	NIMAPARA	MADARANG (NAGA	14266	11 KV NAGAPUR BAZAR	14266202	KHARIJA SAHI NO-2	1421DT106	63	MIXED	AMI	Yes	100%	66	0.03725604	0.024376	0.01288004	34.57%
2547	TPCODL	BBSR1	NED	NIMAPARA	MADARANG (NAGA	14266	11 KV NAGAPUR BAZAR	14266202	NAGAPUR-MALI SAHI	1421DT113	63	MIXED	AMI	Yes	0%	67	0.04027304	0.025142	0.01513104	37.57%
2548	TPCODL	BBSR1	NED	NIMAPARA	MADARANG (NAGA	14266	11 KV NAGAPUR BAZAR	14266202	TELIPADA	1421DT685	63	MIXED	AMI	Yes	0%	22	0.01574866	0.005897	0.00985166	62.56%
2549	TPCODL	BBSR1	NED	NIMAPARA	MADARANG (NAGA	14266	11 KV MADARANGA	14266203	BANTULIGAON	1421DT011	250	MIXED	AMI	Yes	67%	135	0.08294412	0.036578	0.04636612	55.90%
2550	TPCODL	BBSR1	NED	NIMAPARA	MADARANG (NAGA	14266	11 KV MADARANGA	14266203	MADARANGA	1421DT023	100	MIXED	AMI	Yes	67%	23	0.03844968	0.014326	0.02412368	62.74%
2551	TPCODL	BBSR1	NED	NIMAPARA	MADARANG (NAGA	14266	11 KV MADARANGA	14266203	SUJANAGAR NO II	1421DT026	100	MIXED	AMI	Yes	67%	76	0.0255354	0.016765	0.0087704	34.35%
2552	TPCODL	BBSR1	NED	NIMAPARA	MADARANG (NAGA	14266	11 KV MADARANGA	14266203	ORUALI	1421DT038	100	MIXED	AMI	Yes	0%	112	0.0796868	0.035232	0.0444548	55.79%
2553	TPCODL	BBSR1	NED	NIMAPARA	NIMAPARA	14027	11 KV CHARICHHAKA	14027201	BADHARIKILO 1	1423DT190	100	MIXED	AMI	Yes	67%	95	0.07141366	0.027057	0.04435666	62.11%
2554	TPCODL	BBSR1	NED	NIMAPARA	NIMAPARA	14027	11 KV CHARICHHAKA	14027201	KHADARPUR VILLEDGE-II	1423DT196	63	MIXED	AMI	Yes	33%	59	0.04238281	0.024087	0.01829581	43.17%

Sl. No.	Zone Name	Circle name	Division name	Name of the Sub-division	Name of the Sub-station	Substation Code	Name of the 11 kV Feeder	Feeder Code	Name of the Location where DT situated	DT code	DT Capacity (kVA)	Predominant consumer type of DT (Domestic/Industrial/Agriculture/Mixed)	Type of metering AMR/AMI/ Communicable/Conventional metered/Unmetered	Status of Meter-whether Functional (Yes/No)	% of data received automatically (if AMR/AMI)	No. of Connected Consumers	Input Energy (MU) (A)	Billed Energy (MU) (B)	Loss (MU) (A-B)	% DT Loss (A-B)/A
2555	TPCODL	BBSR1	NED	NIMAPARA	NIMAPARA	14027	11 KV CHARICHHAKA	14027201	VILLI SASAN	1423DT201	100	MIXED	AMI	Yes	67%	31	0.02502362	0.015043	0.00998062	39.88%
2556	TPCODL	BBSR1	NED	NIMAPARA	NIMAPARA	14027	11 KV CHARICHHAKA	14027201	SAILO CHOWK	1423DT224	100	MIXED	AMI	Yes	67%	42	0.03301572	0.013605	0.01941072	58.79%
2557	TPCODL	BBSR1	NED	NIMAPARA	NIMAPARA	14027	11 KV CHARICHHAKA	14027201	NADHANA	1423DT226	100	MIXED	AMI	Yes	67%	72	0.0612914	0.024095	0.0371964	60.69%
2558	TPCODL	BBSR1	NED	NIMAPARA	NIMAPARA	14027	11 KV CHARICHHAKA	14027201	BISIMATRI	1423DT272	100	MIXED	AMI	Yes	100%	98	0.04153234	0.038079	0.00345334	8.31%
2559	TPCODL	BBSR1	NED	NIMAPARA	NIMAPARA	14027	11 KV CHARICHHAKA	14027201	CHARICHHAK BAZAR	1423DT302	500	MIXED	AMI	Yes	0%	376	0.2712096	0.244609	0.0266006	9.81%
2560	TPCODL	BBSR1	NED	NIMAPARA	NIMAPARA	14027	11 KV CHARICHHAKA	14027201	MEDICAL CHHAK	1423DT314	250	MIXED	AMI	Yes	0%	138	0.13082288	0.098151	0.03267188	24.97%
2561	TPCODL	BBSR1	NED	NIMAPARA	NIMAPARA	14027	11 KV CHARICHHAKA	14027201	CHARICHHAK MEDICAL	1423DT315	100	MIXED	AMI	Yes	33%	35	0.01857752	0.018057	0.00052052	2.80%
2562	TPCODL	BBSR1	NED	NIMAPARA	NIMAPARA	14027	11 KV CHARICHHAKA	14027201	KANTIA	1423DT329	100	MIXED	AMI	Yes	67%	106	0.07145214	0.03089	0.04056214	56.77%
2563	TPCODL	BBSR1	NED	NIMAPARA	NIMAPARA	14027	11 KV CHARICHHAKA	14027201	ATEIHUDA	1423DT553	100	MIXED	AMI	Yes	100%	70	0.04712522	0.018873	0.02825222	59.95%
2564	TPCODL	BBSR1	NED	NIMAPARA	NIMAPARA	14027	11 KV CHARICHHAKA	14027201	BHARANA	1423DT559	100	MIXED	AMI	Yes	100%	113	0.0569967	0.046743	0.0102537	17.99%
2565	TPCODL	BBSR1	NED	NIMAPARA	NIMAPARA	14027	11 KV CHARICHHAKA	14027201	DENAILO	1423DT563	63	MIXED	AMI	Yes	100%	79	0.02904984	0.022856	0.00619384	21.32%
2566	TPCODL	BBSR1	NED	NIMAPARA	NIMAPARA	14027	11 KV CHARICHHAKA	14027201	TAMPALO CHHAK	1423DT588	100	MIXED	AMI	Yes	0%	27	0.01467958	0.00887	0.00580958	39.58%
2567	TPCODL	BBSR1	NED	NIMAPARA	NIMAPARA	14027	11 KV DANDIPUR	14027203	DHALESWAR	1424DT019	100	MIXED	AMI	Yes	67%	107	0.08991577	0.032937	0.05697877	63.37%
2568	TPCODL	BBSR1	NED	NIMAPARA	NIMAPARA	14027	11 KV DANDIPUR	14027203	NAHANTARA-1	1424DT027	100	MIXED	AMI	Yes	67%	99	0.07446244	0.036066	0.03839644	51.56%
2569	TPCODL	BBSR1	NED	NIMAPARA	NIMAPARA	14027	11 KV DANDIPUR	14027203	RATILO-II	1424DT150	100	MIXED	AMI	Yes	67%	140	0.0868501	0.040044	0.0468061	53.89%
2570	TPCODL	BBSR1	NED	NIMAPARA	NIMAPARA	14027	11 KV DANDIPUR	14027203	RATILO RWSS POINT-I	1424DT151	25	MIXED	AMI	Yes	67%	130	0.06447734	0.037349	0.02712834	42.07%
2571	TPCODL	BBSR1	NED	NIMAPARA	NIMAPARA	14027	11 KV DANDIPUR	14027203	SIRIMUKHA-2	1424DT157	100	MIXED	AMI	Yes	0%	80	0.07766106	0.022884	0.05477706	70.53%
2572	TPCODL	BBSR1	NED	NIMAPARA	NIMAPARA	14027	11 KV DANDIPUR	14027203	KUSHIKONA-1	1424DT174	100	MIXED	AMI	Yes	67%	88	0.04076786	0.03078	0.00998786	24.50%
2573	TPCODL	BBSR1	NED	NIMAPARA	NIMAPARA	14027	11 KV DANDIPUR	14027203	SAGADA MV	1424DT195	100	MIXED	AMI	Yes	0%	61	0.04681666	0.019193	0.02762366	59.00%
2574	TPCODL	BBSR1	NED	NIMAPARA	NIMAPARA	14027	11 KV DANDIPUR	14027203	BARAHAGORADA	1424DT222	100	MIXED	AMI	Yes	0%	109	0.08324536	0.034212	0.04903336	58.90%
2575	TPCODL	BBSR1	NED	NIMAPARA	NIMAPARA	14027	11 KV DANDIPUR	14027203	DEKHATA-1	1424DT240	100	MIXED	AMI	Yes	67%	83	0.04816304	0.021458	0.02670504	55.45%
2576	TPCODL	BBSR1	NED	NIMAPARA	NIMAPARA	14027	11 KV DANDIPUR	14027203	RAID BAZAR-1	1424DT251	100	MIXED	AMI	Yes	0%	65	0.09880862	0.023164	0.07564462	76.56%
2577	TPCODL	BBSR1	NED	NIMAPARA	NIMAPARA	14027	11 KV DANDIPUR	14027203	BADA PALA SAHI-2	1424DT262	63	MIXED	AMI	Yes	67%	61	0.02870302	0.014186	0.01451702	50.58%
2578	TPCODL	BBSR1	NED	NIMAPARA	NIMAPARA	14027	11 KV DANDIPUR	14027203	TALAHADIA	1424DT503	250	MIXED	AMI	Yes	0%	89	0.08741464	0.025613	0.06180164	70.70%
2579	TPCODL	BBSR1	NED	NIMAPARA	NIMAPARA	14027	11 KV DANDIPUR	14027203	RENGHALA-4	1424DT513	100	MIXED	AMI	Yes	0%	80	0.09812794	0.029966	0.06816194	69.46%
2580	TPCODL	BBSR1	NED	NIMAPARA	NIMAPARA	14027	11 KV DANDIPUR	14027203	RENGALO-3	1424DT517	100	MIXED	AMI	Yes	67%	28	0.04034676	0.012318	0.02802876	69.47%
2581	TPCODL	BBSR1	NED	NIMAPARA	NIMAPARA	14027	11 KV OMFED	14027204	NIMAPADA STRUCTURE NO 4	1423DT481	250	MIXED	AMI	Yes	0%	178	0.15362956	0.129989	0.02364056	15.39%
2582	TPCODL	BBSR1	NED	NIMAPARA	NIMAPARA	14027	11 KV OMFED	14027204	NIMAPADA GOUTAM NAGAR NO I	1423DT488	500	MIXED	AMI	Yes	100%	115	0.2511136	0.072598	0.1785156	71.09%
2583	TPCODL	BBSR1	NED	NIMAPARA	NIMAPARA	14027	11 KV OMFED	14027204	NIMAPADA GANESH BAZAR	1423DT489	500	MIXED	AMI	Yes	100%	223	0.30599776	0.200578	0.10541976	34.45%
2584	TPCODL	BBSR1	NED	NIMAPARA	NIMAPARA	14027	11 KV OMFED	14027204	ANDHIA SITHA SAHI	1423DT490	100	MIXED	AMI	Yes	100%	88	0.12048598	0.039825	0.08066098	66.95%
2585	TPCODL	BBSR1	NED	NIMAPARA	NIMAPARA	14027	11 KV OMFED	14027204	ANDHIA OJHA SAHI	1423DT491	100	MIXED	AMI	Yes	100%	103	0.11729356	0.045986	0.07130756	60.79%
2586	TPCODL	BBSR1	NED	NIMAPARA	NIMAPARA	14027	11 KV OMFED	14027204	ANDHIA BANIA SAHI	1423DT492	100	MIXED	AMI	Yes	100%	58	0.05823354	0.029274	0.02895954	49.73%
2587	TPCODL	BBSR1	NED	NIMAPARA	NIMAPARA	14027	11 KV OMFED	14027204	ANDHA SASANA	1423DT494	100	MIXED	AMI	Yes	100%	42	0.05319194	0.021285	0.03190694	59.98%
2588	TPCODL	BBSR1	NED	NIMAPARA	NIMAPARA	14027	11 KV OMFED	14027204	SIDHEWAR MADAP	1423DT500	63	MIXED	AMI	Yes	0%	46	0.08993088	0.041448	0.04848288	53.91%
2589	TPCODL	BBSR1	NED	NIMAPARA	NIMAPARA	14027	11 KV OMFED	14027204	BISHNUPUR	1423DT507	250	MIXED	AMI	Yes	100%	135	0.16305052	0.048938	0.11411252	69.99%
2590	TPCODL	BBSR1	NED	NIMAPARA	NIMAPARA	14027	11 KV OMFED	14027204	BISHNUPUR NEWPADA SAHI	1423DT510	250	MIXED	AMI	Yes	0%	101	0.08376068	0.030362	0.05339868	63.75%
2591	TPCODL	BBSR1	NED	NIMAPARA	NIMAPARA	14027	11 KV OMFED	14027204	GADAANDHIA	1423DT517	250	MIXED	AMI	Yes	100%	143	0.10461628	0.059573	0.04504328	43.06%
2592	TPCODL	BBSR1	NED	NIMAPARA	NIMAPARA	14027	11 KV OMFED	14027204	NIMAPARA NEW COLONY	1423DT518	100	MIXED	AMI	Yes	0%	63	0.06623208	0.045998	0.02023408	30.55%
2593	TPCODL	BBSR1	NED	NIMAPARA	NIMAPARA	14027	11 KV OMFED	14027204	NIMAPADA LIC CHHACK	1423DT521	250	MIXED	AMI	Yes	100%	184	0.14780076	0.133125	0.01467576	9.93%
2594	TPCODL	BBSR1	NED	NIMAPARA	NIMAPARA	14027	11 KV OMFED	14027204	NIMAPADA NEW BUS STAND	1423DT527	250	MIXED	AMI	Yes	100%	13	0.14111272	0.054457	0.08665572	61.41%
2595	TPCODL	BBSR1	NED	NIMAPARA	NIMAPARA	14027	11 KV OMFED	14027204	PETAGHAI CHHACK	1423DT528	200	MIXED	AMI	Yes	0%	134	0.15161392	0.120275	0.03133892	20.67%
2596	TPCODL	BBSR1	NED	NIMAPARA	NIMAPARA	14027	11 KV OMFED	14027204	DIFFENCE COLONY	1423DT531	100	MIXED	AMI	Yes	100%	53	0.05038858	0.031447	0.01894158	37.59%
2597	TPCODL	BBSR1	NED	NIMAPARA	NIMAPARA	14027	11 KV PATAPUR	14027205	PATIAPABAN PATNA	1423DT340	100	MIXED	AMI	Yes	67%	133	0.16031042	0.076218	0.08409242	52.46%
2598	TPCODL	BBSR1	NED	NIMAPARA	NIMAPARA	14027	11 KV PATAPUR	14027205	AMUNIA PATNA(TINARTH TEMPLE)	1423DT341	100	MIXED	AMI	Yes	100%	83	0.08998308	0.035302	0.05468108	60.77%
2599	TPCODL	BBSR1	NED	NIMAPARA	NIMAPARA	14027	11 KV PATAPUR	14027205	JHAPLADUDA I.P SCHOOL	1423DT345	100	MIXED	AMI	Yes	67%	81	0.08356736	0.026462	0.05710536	68.33%
2600	TPCODL	BBSR1	NED	NIMAPARA	NIMAPARA	14027	11 KV PATAPUR	14027205	DHAIROPUR CHAKA	1423DT351	100	MIXED	AMI	Yes	67%	90	0.05718654	0.032555	0.02463154	43.07%
2601	TPCODL	BBSR1	NED	NIMAPARA	NIMAPARA	14027	11 KV PATAPUR	14027205	GUHALA PADA NO I	1423DT411	100	MIXED	AMI	Yes	100%	109	0.10319452	0.072002	0.03119252	30.23%
2602	TPCODL	BBSR1	NED	NIMAPARA	NIMAPARA	14027	11 KV PATAPUR	14027205	MAHAVIR COLONY	1423DT420	100	MIXED	AMI	Yes	0%	93	0.0715694	0.062911	0.0086584	12.10%
2603	TPCODL	BBSR1	NED	NIMAPARA	NIMAPARA	14027	11 KV PATAPUR	14027205	DIPIRENTA	1423DT423	100	MIXED	AMI	Yes	100%	120	0.09066862	0.042558	0.04811062	53.06%
2604	TPCODL	BBSR1	NED	NIMAPARA	NIMAPARA	14027	11 KV PATAPUR	14027205	JAIL	1423DT425	100	MIXED	AMI	Yes	0%	16	0.02657044	0.023148	0.00342244	12.88%
2605	TPCODL	BBSR1	NED	NIMAPARA	NIMAPARA	14027	11 KV PATAPUR	14027205	GANESH TAKIES	1423DT444	500	MIXED	AMI	Yes	0%	267	0.30383552	0.166497	0.13733852	45.20%
2606	TPCODL	BBSR1	NED	NIMAPARA	NIMAPARA	14027	11 KV PATAPUR	14027205	BLOCK CHHACK PHD	1423DT447	250	MIXED	AMI	Yes	100%	138	0.09589188	0.082581	0.01331088	13.88%
2607	TPCODL	BBSR1	NED	NIMAPARA	NIMAPARA	14027	11 KV PATAPUR	14027205	AMUNIA PATANA NO I	1423DT451	100	MIXED	AMI	Yes	0%	64	0.05255092	0.031402	0.02114892	40.24%
2608	TPCODL	BBSR1	NED	NIMAPARA	NIMAPARA	14027	11 KV PATAPUR	14027205	MALLICK SAHI NO II	1423DT456	250	MIXED	AMI	Yes	100%	147	0.22578484	0.072391	0.15339384	67.94%
2609	TPCODL	BBSR1	NED	NIMAPARA	NIMAPARA	14027	11 KV PATAPUR	14027205	PATAPUR BASUDEV TEMPLE	1423DT465	100	MIXED	AMI	Yes	33%	60	0.0581358	0.020501	0.0376348	64.74%
2610	TPCODL	BBSR1	NED	NIMAPARA	NIMAPARA	14027	11 KV PATAPUR	14027205	PATAPUR NO I	1423DT468	100	MIXED	AMI	Yes	100%	101	0.1012576	0.037105	0.0641526	63.36%
2611	TPCODL	BBSR1	NED	NIMAPARA	NIMAPARA	14027	11 KV PATAPUR	14027205	PATAPUR NO III	1423DT470	100	MIXED	AMI	Yes	100%	139	0.09835366	0.057635	0.04071866	41.40%
2612	TPCODL	BBSR1	NED	NIMAPARA	NIMAPARA	14027	11 KV PATAPUR	14027205	KUAKOTA	1423DT477	63	MIXED	AMI	Yes	0%	26	0.01023426	0.007305	0.00292926	28.62%
2613	TPCODL	BBSR1	NED	NIMAPARA	NIMAPARA	14027	11 KV BASANT MALA	14027206	DENUA BASTA	1423DT002	100	MIXED	AMI	Yes	100%	147	0.1206838	0.051852	0.0688318	57.03%
2614	TPCODL	BBSR1	NED	NIMAPARA	NIMAPARA	14027	11 KV BASANT MALA	14027206	DENUA PANCHAYAT OFFICE	1423DT005	100	MIXED	AMI	Yes	100%	56	0.03641395	0.021062	0.01535195	42.16%
2615	TPCODL	BBSR1	NED	NIMAPARA	NIMAPARA	14027	11 KV BASANT MALA	14027206	DIHABARI NO-2	1423DT014	100	MIXED	AMI	Yes	67%	55	0.0428604	0.016628	0.0262324	61.20%
2616	TPCODL	BBSR1	NED	NIMAPARA	NIMAPARA	14027	11 KV BASANT MALA	14027206	HANSAPADA SASANA	1423DT023	100	MIXED	AMI	Yes	67%	73	0.05179386	0.022512	0.02928186	56.54%
2617	TPCODL	BBSR1	NED	NIMAPARA	NUAPADA	14195	11 KV PITEIPUR	14195201	DEDHASAR DEULI	5323DT154	250	MIXED	AMI	Yes	100%	277	0.1817258	0.121956	0.0597698	32.89%
2618	TPCODL	BBSR1	NED	NIMAPARA	NUAPADA	14195	11 KV ICHHAPUR	14195203	SADAI DUR	5323DT325	100	MIXED	AMI	Yes	67%	132	0.05936253	0.0454	0.01396253	23.52%
2619	TPCODL	BBSR1	NED	NIMAPARA	NUAPOLA / NABAPA	14181	11 KV TARIKUNDA	14181201	KANTAPADA 2	5331DT368	100	MIXED	AMI	Yes	100%	57	0.02907884	0.009451	0.01962784	67.50%
2620	TPCODL	BBSR1	NED	PIPILI	BALAKATI	14025	11 kV BALAKATI	14025201	BADA BHOI SAHI	1431DT018	200	MIXED	AMI	Yes	0%	94	0.14779744	0.056156	0.09164144	62.00%
2621	TPCODL	BBSR1	NED	PIPILI	BALAKATI	14025	11 kV BALAKATI	14025201	CHARIMANA	1431DT041	250	MIXED	AMI	Yes	0%	76	0.16628116	0.058311	0.10797016	64.93%
2622	TPCODL	BBSR1	NED	PIPILI	BALAKATI	14025	11 kV SATYABHAMAPUR	14025202	NUAPATNA UPER SAHI	1431DT195	100	MIXED	AMI	Yes	0%	83	0.18853056	0.060514	0.12801656	67.90%
2623	TPCODL	BBSR1	NED	PIPILI	BALAKATI	14025	11 kV SATYABHAMAPUR	14025202	MAHALA SAHI	1431DT198	250	MIXED	AMI	Yes	0%	219	0.24083328	0.15541	0.08542328	35.47%
2624	TPCODL	BBSR1	NED	PIPILI	BALAKATI	14025	11 kV SATYABHAMAPUR	14025202	PRAFUL KUMAR SAHOO	1431DT293	100	MIXED	AMI	Yes	0%	8	0.01146632	0.008827	0.00263932	23.02%
2625	TPCODL	BBSR1	NED	PIPILI	PIPILI	14028	11 kV PIPILI	14028201	OLD NAC MARKET1	1434DT303	200	MIXED	AMI	Yes	0%	112	0.34659144	0.109958	0.23663344	68.27%
2626	TPCODL	BBSR1	NED	PIPILI	PIPILI	14028	11 kV MANGALAPUR-2	14028204	UTTAR BADA HJ SAHI	1435DT077	250	MIXED	AMI	Yes	100%	108	0.0757084	0.05221	0.0234984	31.04%
2627	TPCODL	BBSR1	NED	PIPILI	PIPILI	14028	11 kV MANGALAPUR-2	14028204	NUASASANA UTARA SAHI 2	1435DT128	100	MIXED	AMI	Yes	0%	87	0.06766812	0.038506	0.02916212	43.10%

Sl. No.	Zone Name	Circle name	Division name	Name of the Sub-division	Name of the Sub-station	Substation Code	Name of the 11 kV Feeder	Feeder Code	Name of the Location where DT situated	DT code	DT Capacity (kVA)	Predominant consumer type of DT (Domestic/Industrial/Agriculture/Mixed)	Type of metering AMR/AMI/ Communicable/Conventional metered/Unmetered	Status of Meter-whether Functional (Yes/No)	% of data received automatically (if AMR/AMI)	No. of Connected Consumers	Input Energy (MU) (A)	Billed Energy (MU) (B)	Loss (MU) (A-B)	% DT Loss (A-B)/A
2628	TPCODL	BBSR1	NED	PIPILI	PIPILI	14028	11 kV MANGALAPUR-2	14028204	DIHA SAHI_RGGVY	1435DT158	100	MIXED	AMI	Yes	0%	68	0.04715385	0.030788	0.01636585	34.71%
2629	TPCODL	BBSR1	NED	PIPILI	BALAKATI	14025	11 KV BALAKATI	14025201	BASANTPEDI(CANNEL ROAD)	1431DT032	100	MIXED	AMI	Yes	100%	83	0.0632106	0.047936	0.0152746	24.16%
2630	TPCODL	BBSR1	NED	PIPILI	BALAKATI	14025	11 KV BALAKATI	14025201	PANASPATANA	1431DT046	100	MIXED	AMI	Yes	100%	39	0.08331114	0.030677	0.05263414	63.18%
2631	TPCODL	BBSR1	NED	PIPILI	BALAKATI	14025	11 KV BALAKATI	14025201	CHADEIBARA	1431DT062	100	MIXED	AMI	Yes	100%	59	0.05513734	0.021666	0.03347134	60.71%
2632	TPCODL	BBSR1	NED	PIPILI	BALAKATI	14025	11 KV SATYABHAMAPUR	14025202	HIRIPUR, UPAR SAHI	1431DT110	100	MIXED	AMI	Yes	100%	116	0.132479	0.091467	0.041012	30.96%
2633	TPCODL	BBSR1	NED	PIPILI	BALAKATI	14025	11 KV SATYABHAMAPUR	14025202	GADA SRIRAMPUR	1431DT127	100	MIXED	AMI	Yes	100%	74	0.12811492	0.055663	0.07245192	56.55%
2634	TPCODL	BBSR1	NED	PIPILI	BALAKATI	14025	11 KV SATYABHAMAPUR	14025202	SRIRAM BHATIKA	1431DT128	250	MIXED	AMI	Yes	67%	28	0.0303214	0.028386	0.0019354	6.38%
2635	TPCODL	BBSR1	NED	PIPILI	BALAKATI	14025	11 KV SATYABHAMAPUR	14025202	GOTALA BINDHA	1431DT155	100	MIXED	AMI	Yes	67%	44	0.03646778	0.029997	0.00647078	17.74%
2636	TPCODL	BBSR1	NED	PIPILI	BALAKATI	14025	11 KV SATYABHAMAPUR	14025202	INDRAPAL	1431DT179	100	MIXED	AMI	Yes	67%	107	0.07856262	0.076279	0.00228362	2.91%
2637	TPCODL	BBSR1	NED	PIPILI	BALAKATI	14025	11 KV SATYABHAMAPUR	14025202	INDRAPAL	1431DT181	63	MIXED	AMI	Yes	67%	12	0.03060144	0.009329	0.02127244	69.51%
2638	TPCODL	BBSR1	NED	PIPILI	BALAKATI	14025	11 KV SATYABHAMAPUR	14025202	GOTALA GRAMA	1431DT220	63	MIXED	AMI	Yes	100%	17	0.02945606	0.005942	0.02351406	79.83%
2639	TPCODL	BBSR1	NED	PIPILI	BALAKATI	14025	11 KV SATYABHAMAPUR	14025202	VARSHA RIVER 1	1431DT277	250	MIXED	AMI	Yes	100%	77	0.05265636	0.050268	0.00238836	4.54%
2640	TPCODL	BBSR1	NED	PIPILI	BALAKATI	14025	11 KV SATYABHAMAPUR	14025202	M G VILLA	1431DT298	100	MIXED	AMI	Yes	0%	32	0.0436715	0.017616	0.0260555	59.66%
2641	TPCODL	BBSR1	NED	PIPILI	BALAKATI	14025	11 KV SATYABHAMAPUR	14025202	REGENCY COURT	1431DT316	500	MIXED	AMI	Yes	100%	24	0.04713192	0.026626	0.02050592	43.51%
2642	TPCODL	BBSR1	NED	PIPILI	BALAKATI	14025	11 KV SATYABHAMAPUR	14025202	UMESH PATTANAYAK	1431DT571	500	MIXED	AMI	Yes	100%	23	0.0399912	0.014623	0.0253682	63.43%
2643	TPCODL	BBSR1	NED	PIPILI	BALAKATI	14025	11 KV BAINCHUA	14025203	KANTAGOTHA	1431DT184	100	MIXED	AMI	Yes	100%	101	0.07503328	0.05643	0.01860328	24.79%
2644	TPCODL	BBSR1	NED	PIPILI	BALAKATI	14025	11 KV BAINCHUA	14025203	9 GHARA SAHI-II	1431DT188	100	MIXED	AMI	Yes	100%	79	0.07751906	0.050519	0.02700006	34.83%
2645	TPCODL	BBSR1	NED	PIPILI	BALAKATI	14025	11 KV BAINCHUA	14025203	DHABALAHARA	1431DT191	63	MIXED	AMI	Yes	100%	39	0.03095006	0.016592	0.01435806	46.39%
2646	TPCODL	BBSR1	NED	PIPILI	BALAKATI	14025	11 KV BAINCHUA	14025203	MOHANTY SAHI	1431DT202	63	MIXED	AMI	Yes	100%	50	0.03347042	0.027147	0.00632342	18.89%
2647	TPCODL	BBSR1	NED	PIPILI	BALAKATI	14025	11 KV BAINCHUA	14025203	MOHANTY SAHI (JENA SAHI)	1431DT203	100	MIXED	AMI	Yes	100%	103	0.0705261	0.052007	0.0185191	26.26%
2648	TPCODL	BBSR1	NED	PIPILI	BALAKATI	14025	11 KV BAINCHUA	14025203	Chittaranjan Behera	1431DT620	500	MIXED	AMI	Yes	0%	14	0.0101388	0.009076	0.0010628	10.48%
2649	TPCODL	BBSR1	NED	PIPILI	BALIPATNA	14024	11 KV BALIPATNA	14024201	GIRINGO-I	1432DT017	100	MIXED	AMI	Yes	100%	50	0.041398	0.041377	2.1E-05	0.05%
2650	TPCODL	BBSR1	NED	PIPILI	BALIPATNA	14024	11 KV BALIPATNA	14024201	BALIPATNA COLLEGE	1432DT027	100	MIXED	AMI	Yes	100%	64	0.07405538	0.059351	0.01470438	19.86%
2651	TPCODL	BBSR1	NED	PIPILI	BALIPATNA	14024	11 KV BALIPATNA	14024201	GORUHATA PADIA BALIPATNA	1432DT034	250	MIXED	AMI	Yes	100%	107	0.1169008	0.077224	0.0396768	33.94%
2652	TPCODL	BBSR1	NED	PIPILI	BALIPATNA	14024	11 KV BALIPATNA	14024201	SISUMATHA -II	1432DT035	100	MIXED	AMI	Yes	100%	105	0.0894951	0.0562	0.0332951	37.20%
2653	TPCODL	BBSR1	NED	PIPILI	BALIPATNA	14024	11 KV BALIPATNA	14024201	FIRIKA PATNA-I	1432DT044	100	MIXED	AMI	Yes	0%	62	0.04527622	0.032996	0.01228022	27.12%
2654	TPCODL	BBSR1	NED	PIPILI	BALIPATNA	14024	11 KV BALIPATNA	14024201	CHAMPABASTA-I	1432DT054	100	MIXED	AMI	Yes	0%	38	0.02364872	0.019082	0.00456672	19.31%
2655	TPCODL	BBSR1	NED	PIPILI	BALIPATNA	14024	11 KV BALIPATNA	14024201	KAKARUDRAPUR SANI MANDIR	1432DT076	100	MIXED	AMI	Yes	67%	101	0.09456702	0.037223	0.05734402	60.64%
2656	TPCODL	BBSR1	NED	PIPILI	BALIPATNA	14024	11 KV BALIPATNA	14024201	KAKARUDRAPUR PURUNAGADA	1432DT077	250	MIXED	AMI	Yes	0%	79	0.1299625	0.028374	0.1015885	78.17%
2657	TPCODL	BBSR1	NED	PIPILI	BALIPATNA	14024	11 KV BALIPATNA	14024201	JAGANNATHPUR -I	1432DT089	100	MIXED	AMI	Yes	100%	119	0.07359342	0.049014	0.02457942	33.40%
2658	TPCODL	BBSR1	NED	PIPILI	BALIPATNA	14024	11 KV BALIPATNA	14024201	GANDILO VILLAGE- II	1432DT098	100	MIXED	AMI	Yes	100%	105	0.05377256	0.042778	0.01099456	20.45%
2659	TPCODL	BBSR1	NED	PIPILI	BALIPATNA	14024	11 KV BALIPATNA	14024201	RADPADA CHHAKA	1432DT101	100	MIXED	AMI	Yes	100%	110	0.06809342	0.045458	0.02263542	33.24%
2660	TPCODL	BBSR1	NED	PIPILI	BALIPATNA	14024	11 KV BUDHIPADA	14024202	SAHANISAHI VILLAGE	1431DT324	100	MIXED	AMI	Yes	0%	72	0.06072768	0.027163	0.03356468	55.27%
2661	TPCODL	BBSR1	NED	PIPILI	BALIPATNA	14024	11 KV BUDHIPADA	14024202	BISWANATHPUR HARIJANA SAHI	1431DT353	100	MIXED	AMI	Yes	0%	43	0.05554822	0.012302	0.04324622	77.85%
2662	TPCODL	BBSR1	NED	PIPILI	BALIPATNA	14024	11 KV BUDHIPADA	14024202	SATKABAD -I	1431DT364	100	MIXED	AMI	Yes	100%	41	0.04357034	0.013912	0.02965834	68.07%
2663	TPCODL	BBSR1	NED	PIPILI	BALIPATNA	14024	11 KV BUDHIPADA	14024202	BISWANATHPUR CHHAKA -I	1431DT368	100	MIXED	AMI	Yes	0%	145	0.0977964	0.073858	0.0239384	24.48%
2664	TPCODL	BBSR1	NED	PIPILI	BALIPATNA	14024	11 KV BUDHIPADA	14024202	SISILO BAZAR-II	1431DT391	100	MIXED	AMI	Yes	0%	33	0.02485684	0.010031	0.01482584	59.64%
2665	TPCODL	BBSR1	NED	PIPILI	BALIPATNA	14024	11 KV BUDHIPADA	14024202	SISILO BAZAR-I	1431DT392	100	MIXED	AMI	Yes	67%	35	0.03183384	0.012099	0.01973484	61.99%
2666	TPCODL	BBSR1	NED	PIPILI	BALIPATNA	14024	11 KV BUDHIPADA	14024202	ANJIRA VILLAGE -I	1431DT393	100	MIXED	AMI	Yes	67%	46	0.03184198	0.013587	0.01825498	57.33%
2667	TPCODL	BBSR1	NED	PIPILI	BALIPATNA	14024	11 KV BUDHIPADA	14024202	SISILO VILLAGE-I	1431DT396	100	MIXED	AMI	Yes	67%	68	0.08511072	0.024817	0.06029372	70.84%
2668	TPCODL	BBSR1	NED	PIPILI	BALIPATNA	14024	11 KV BUDHIPADA	14024202	BODHAKHANDI -II	1431DT404	63	MIXED	AMI	Yes	67%	27	0.02543882	0.011702	0.01373682	54.00%
2669	TPCODL	BBSR1	NED	PIPILI	BALIPATNA	14024	11 KV BUDHIPADA	14024202	BODHAKHANDI-I	1431DT405	100	MIXED	AMI	Yes	0%	78	0.043545	0.031011	0.012534	28.78%
2670	TPCODL	BBSR1	NED	PIPILI	BALIPATNA	14024	11 KV BUDHIPADA	14024202	NEAR SATKABAD SCHOOL	1431DT417	100	MIXED	AMI	Yes	67%	50	0.03850646	0.01592	0.02258646	58.66%
2671	TPCODL	BBSR1	NED	PIPILI	BALIPATNA	14024	11 KV BUDHIPADA	14024202	BARADIHI SAHI-I	1431DT423	100	MIXED	AMI	Yes	67%	19	0.02421714	0.013329	0.01088814	44.96%
2672	TPCODL	BBSR1	NED	PIPILI	BALIPATNA	14024	11 KV BUDHIPADA	14024202	NAIKULA SAHI -II (BUDHIPADA)	1431DT437	100	MIXED	AMI	Yes	0%	77	0.0556826	0.02619	0.0294926	52.97%
2673	TPCODL	BBSR1	NED	PIPILI	BALIPATNA	14024	11 KV BUDHIPADA	14024202	BISUNIAPADA	1431DT443	100	MIXED	AMI	Yes	0%	81	0.07520682	0.034045	0.04116182	54.73%
2674	TPCODL	BBSR1	NED	PIPILI	BALIPATNA	14024	11 KV BUDHIPADA	14024202	PURANA CHHAKA MAHAVEER	1431DT446	100	MIXED	AMI	Yes	0%	63	0.053293	0.027581	0.025712	48.25%
2675	TPCODL	BBSR1	NED	PIPILI	BALIPATNA	14024	11 KV BUDHIPADA	14024202	BUDHIPADA BEHERA SAHI	1431DT448	100	MIXED	AMI	Yes	67%	164	0.09061534	0.078546	0.01206934	13.32%
2676	TPCODL	BBSR1	NED	PIPILI	BALIPATNA	14024	11 KV BUDHIPADA	14024202	BUDHIPADA JENA SAHI	1431DT449	100	MIXED	AMI	Yes	67%	69	0.05982226	0.019883	0.03993926	66.76%
2677	TPCODL	BBSR1	NED	PIPILI	BALIPATNA	14024	11 KV BUDHIPADA	14024202	PURANA SASANA -II (PRADHAN SAHI)	1431DT455	100	MIXED	AMI	Yes	67%	59	0.03578444	0.022279	0.01350544	37.74%
2678	TPCODL	BBSR1	NED	PIPILI	BALIPATNA	14024	11 KV BUDHIPADA	14024202	SARAKANA G.P	1431DT460	100	MIXED	AMI	Yes	67%	101	0.0657857	0.042308	0.0234777	35.69%
2679	TPCODL	BBSR1	NED	PIPILI	BALIPATNA	14024	11 KV BUDHIPADA	14024202	SARAKANA SASANA	1431DT470	100	MIXED	AMI	Yes	33%	79	0.0586222	0.03609	0.0225322	38.44%
2680	TPCODL	BBSR1	NED	PIPILI	BALIPATNA	14024	11 KV BUDHIPADA	14024202	SARAKANA PANDA/DIKHIT SAHI	1431DT475	100	MIXED	AMI	Yes	67%	56	0.06497848	0.031407	0.03357148	51.67%
2681	TPCODL	BBSR1	NED	PIPILI	BALIPATNA	14024	11 KV BUDHIPADA	14024202	SARAKANA BHAGABATI	1431DT477	100	MIXED	AMI	Yes	67%	84	0.07254732	0.042124	0.03042332	41.94%
2682	TPCODL	BBSR1	NED	PIPILI	BALIPATNA	14024	11 KV BUDHIPADA	14024202	BALIGUNDI BISWAL SAHI	1431DT492	100	MIXED	AMI	Yes	0%	18	0.03436968	0.008423	0.02594668	75.49%
2683	TPCODL	BBSR1	NED	PIPILI	BALIPATNA	14024	11 KV BUDHIPADA	14024202	BARIJANGA-II	1431DT503	100	MIXED	AMI	Yes	0%	77	0.0722625	0.031945	0.0403175	55.79%
2684	TPCODL	BBSR1	NED	PIPILI	BALIPATNA	14024	11 KV BUDHIPADA	14024202	JHINTI BRAMHAN SAHI	1431DT516	100	MIXED	AMI	Yes	33%	51	0.07363262	0.027397	0.04623562	62.79%
2685	TPCODL	BBSR1	NED	PIPILI	BALIPATNA	14024	11 KV BUDHIPADA	14024202	BALIPATANA BAZAR -II (TVS SHOWR	1432DT111	100	MIXED	AMI	Yes	67%	81	0.06086334	0.046396	0.01446734	23.77%
2686	TPCODL	BBSR1	NED	PIPILI	BALIPATNA	14024	11 KV BUDHIPADA	14024202	GAREDIPANCHANA -II	1432DT112	100	MIXED	AMI	Yes	67%	64	0.05152992	0.040081	0.01144892	22.22%
2687	TPCODL	BBSR1	NED	PIPILI	BALIPATNA	14024	11 KV BUDHIPADA	14024202	BALABHADRAPUR	1432DT115	100	MIXED	AMI	Yes	67%	60	0.07250846	0.065285	0.00722346	9.96%
2688	TPCODL	BBSR1	NED	PIPILI	BALIPATNA	14024	11 KV BUDHIPADA	14024202	RANAPUR SAMANTARA SAHI	1432DT298	100	MIXED	AMI	Yes	67%	76	0.06075842	0.035181	0.02557742	42.10%
2689	TPCODL	BBSR1	NED	PIPILI	BALIPATNA	14024	11 KV BANAMALIPUR	14024203	ATHANTER BAZAR	1432DT357	100	MIXED	AMI	Yes	0%	70	0.05320756	0.028875	0.02433256	45.73%
2690	TPCODL	BBSR1	NED	PIPILI	BALIPATNA	14024	11 KV BANAMALIPUR	14024203	ATHANTER MEDICAL BAZAR	1432DT359	100	MIXED	AMI	Yes	33%	88	0.0781374	0.035883	0.0422544	54.08%
2691	TPCODL	BBSR1	NED	PIPILI	BALIPATNA	14024	11 KV BANAMALIPUR	14024203	ATHANTER BEHERA SAHI	1432DT364	100	MIXED	AMI	Yes	100%	75	0.0690011	0.040349	0.0286521	41.52%
2692	TPCODL	BBSR1	NED	PIPILI	BALIPATNA	14024	11 KV BANAMALIPUR	14024203	BENGABATI DAKHINA MAHALA	1432DT372	100	MIXED	AMI	Yes	0%	33	0.04647872	0.032048	0.01443072	31.05%
2693	TPCODL	BBSR1	NED	PIPILI	BALIPATNA	14024	11 KV BANAMALIPUR	14024203	DHANAHARA BAZAR	1432DT382	100	MIXED	AMI	Yes	100%	90	0.08965122	0.033429	0.05622222	62.71%
2694	TPCODL	BBSR1	NED	PIPILI	BALIPATNA	14024	11 KV NARADA	14024204	CHANAHATA CHHAKA	1432DT383	250	MIXED	AMI	Yes	100%	104	0.15503612	0.090629	0.06440712	41.54%
2695	TPCODL	BBSR1	NED	PIPILI	BALIPATNA	14024	11 KV NARADA	14024204	SARAT SASAN	1432DT391	100	MIXED	AMI	Yes	100%	107	0.0762276	0.037043	0.0391846	51.40%
2696	TPCODL	BBSR1	NED	PIPILI	BALIPATNA	14024	11 KV NARADA	14024204	KULANTIRA GRAM	1432DT402	100	MIXED	AMI	Yes	67%	106	0.0787079	0.058144	0.0205639	26.13%
2697	TPCODL	BBSR1	NED	PIPILI	BALIPATNA	14024	11 KV NARADA	14024204	AITALANGA TRIPATHY SAHI	1432DT406	100	MIXED	AMI	Yes	67%	43	0.04354838	0.022921	0.02062738	47.37%
2698	TPCODL	BBSR1	NED	PIPILI	BALIPATNA	14024	11 KV NARADA	14024204	GOPAGARADA	1432DT412	100	MIXED	AMI	Yes	67%	38	0.03000794	0.0131	0.01690794	56.34%
2699	TPCODL	BBSR1	NED	PIPILI	BALIPATNA	14024	11 KV NARADA	14024204	GUAPUR - II	1432DT419	100	MIXED	AMI	Yes	67%	107	0.07780532	0.043988	0.03381732	43.46%
2700	TPCODL	BBSR1	NED	PIPILI	BALIPATNA	14024	11 KV NARADA	14024204	OLIC TURINTIRA	1432DT429	100	MIXED	AMI	Yes	0%	7	0.0002172	0.000176	0.0000412	18.97%

Sl. No.	Zone Name	Circle name	Division name	Name of the Sub-division	Name of the Sub-station	Substation Code	Name of the 11 kV Feeder	Feeder Code	Name of the Location where DT situated	DT code	DT Capacity (kVA)	Predominant consumer type of DT (Domestic/Industrial/Agriculture/Mixed)	Type of metering AMR/AMI/ Communicable/Conventional metered/Unmetered	Status of Meter-whether Functional (Yes/No)	% of data received automatically (if AMR/AMI)	No. of Connected Consumers	Input Energy (MU) (A)	Billed Energy (MU) (B)	Loss (MU) (A-B)	% DT Loss (A-B)/A
2701	TPCODL	BBSR1	NED	PIPILI	BALIPATNA	14024	11 KV NARADA	14024204	SIDHAKUTILA	1432DT435	100	MIXED	AMI	Yes	67%	40	0.03012202	0.012862	0.01726002	57.30%
2702	TPCODL	BBSR1	NED	PIPILI	BALIPATNA	14024	11 KV NARADA	14024204	HANSUANI - I	1432DT447	100	MIXED	AMI	Yes	67%	74	0.06331638	0.049367	0.01394938	22.03%
2703	TPCODL	BBSR1	NED	PIPILI	BALIPATNA	14024	11 KV NARADA	14024204	BAGALPUR - II	1432DT452	100	MIXED	AMI	Yes	67%	86	0.04376182	0.031409	0.01235282	28.23%
2704	TPCODL	BBSR1	NED	PIPILI	BALIPATNA	14024	11 KV NARADA	14024204	NARADA GHUSURIPADIA - I	1432DT468	100	MIXED	AMI	Yes	67%	67	0.06518402	0.026961	0.03822302	58.64%
2705	TPCODL	BBSR1	NED	PIPILI	BALIPATNA	14024	11 KV NARADA	14024204	NARADA ANGARPADA - II	1432DT476	100	MIXED	AMI	Yes	67%	72	0.03424532	0.017678	0.01656732	48.38%
2706	TPCODL	BBSR1	NED	PIPILI	BALIPATNA	14024	11 KV NARADA	14024204	NISCHINTAPUR MAIN VILLAGE	1432DT479	100	MIXED	AMI	Yes	67%	62	0.04932162	0.019461	0.02986062	60.54%
2707	TPCODL	BBSR1	NED	PIPILI	BALIPATNA	14024	11 KV NARADA	14024204	INDOLKUSIARY	1432DT491	100	MIXED	AMI	Yes	67%	51	0.03363758	0.009267	0.02437058	72.45%
2708	TPCODL	BBSR1	NED	PIPILI	BALIPATNA	14024	11 KV NARADA	14024204	NARADA JAGULEI	1432DT500	100	MIXED	AMI	Yes	67%	98	0.0525748	0.045152	0.0074228	14.12%
2709	TPCODL	BBSR1	NED	PIPILI	BALIPATNA	14024	11 KV NARADA	14024204	PUBAGARH - I	1432DT508	100	MIXED	AMI	Yes	67%	109	0.08255395	0.042031	0.04052295	49.09%
2710	TPCODL	BBSR1	NED	PIPILI	BANAMALIPUR ODS	14255	11 KV BANAMALIPUR NE	14255201	NUAPATANA -I	1432DT517	100	MIXED	AMI	Yes	67%	60	0.16156244	0.03257	0.12899244	79.84%
2711	TPCODL	BBSR1	NED	PIPILI	BANAMALIPUR ODS	14255	11 KV BANAMALIPUR NE	14255201	BAGHABAREI PATNA - I	1432DT519	100	MIXED	AMI	Yes	0%	57	0.07442352	0.02405	0.05037352	67.68%
2712	TPCODL	BBSR1	NED	PIPILI	BANAMALIPUR ODS	14255	11 KV BANAMALIPUR NE	14255201	LAXMIJANARDHAN PATNA - I	1432DT521	100	MIXED	AMI	Yes	0%	42	0.05090624	0.01196	0.03894624	76.51%
2713	TPCODL	BBSR1	NED	PIPILI	BANAMALIPUR ODS	14255	11 KV BANAMALIPUR NE	14255201	BALIKUDA PATNA - I	1432DT523	250	MIXED	AMI	Yes	67%	79	0.1077502	0.037454	0.0702962	65.24%
2714	TPCODL	BBSR1	NED	PIPILI	BANAMALIPUR ODS	14255	11 KV BANAMALIPUR NE	14255201	BANAMALIPUR BAZAR - I	1432DT525	250	MIXED	AMI	Yes	67%	155	0.1684276	0.070284	0.0981436	58.27%
2715	TPCODL	BBSR1	NED	PIPILI	BANAMALIPUR ODS	14255	11 KV BANAMALIPUR NE	14255201	PRADHAN PATNA - I	1432DT526	100	MIXED	AMI	Yes	0%	79	0.06909778	0.025016	0.04408178	63.80%
2716	TPCODL	BBSR1	NED	PIPILI	BANAMALIPUR ODS	14255	11 KV BANAMALIPUR NE	14255201	DEWANPATNA PRUSTI SAHI	1432DT529	100	MIXED	AMI	Yes	67%	110	0.12472704	0.041946	0.08278104	66.37%
2717	TPCODL	BBSR1	NED	PIPILI	BANAMALIPUR ODS	14255	11 KV BANAMALIPUR NE	14255201	DEWANPATNA MAJHI SAHI	1432DT534	100	MIXED	AMI	Yes	67%	150	0.08026046	0.049329	0.03093146	38.54%
2718	TPCODL	BBSR1	NED	PIPILI	BANAMALIPUR ODS	14255	11 KV BANAMALIPUR NE	14255201	SANA NUAPATNA	1432DT551	100	MIXED	AMI	Yes	67%	91	0.12228418	0.045196	0.07708818	63.04%
2719	TPCODL	BBSR1	NED	PIPILI	BANAMALIPUR ODS	14255	11 KV BANAMALIPUR NE	14255201	ANANDAPUR	1432DT553	250	MIXED	AMI	Yes	67%	111	0.11911988	0.056804	0.06231588	52.31%
2720	TPCODL	BBSR1	NED	PIPILI	BANAMALIPUR ODS	14255	11 KV BANAMALIPUR NE	14255201	KAKARUDRAPUR	1432DT554	100	MIXED	AMI	Yes	0%	57	0.055209	0.022333	0.032876	59.55%
2721	TPCODL	BBSR1	NED	PIPILI	BANAMALIPUR ODS	14255	11 KV BANAMALIPUR NE	14255201	SEKH PATNA - II	1432DT559	100	MIXED	AMI	Yes	67%	88	0.09071746	0.03933	0.05138746	56.65%
2722	TPCODL	BBSR1	NED	PIPILI	BANAMALIPUR ODS	14255	11 KV BANAMALIPUR NE	14255201	HADA SAHI	1432DT565	100	MIXED	AMI	Yes	67%	47	0.06662078	0.022986	0.04363478	65.50%
2723	TPCODL	BBSR1	NED	PIPILI	BANAMALIPUR ODS	14255	11 KV BANAMALIPUR NE	14255201	POUHARA - I	1432DT585	100	MIXED	AMI	Yes	67%	49	0.09392902	0.03145	0.06247902	66.52%
2724	TPCODL	BBSR1	NED	PIPILI	BANAMALIPUR ODS	14255	11 KV BANAMALIPUR NE	14255201	RAYAT PATNA - II	1432DT599	100	MIXED	AMI	Yes	67%	101	0.09211648	0.044274	0.04784248	51.94%
2725	TPCODL	BBSR1	NED	PIPILI	BANAMALIPUR ODS	14255	11 KV BANAMALIPUR NE	14255201	MUNDAHANA PATNA	1432DT601	100	MIXED	AMI	Yes	67%	128	0.08258404	0.053802	0.02878204	34.85%
2726	TPCODL	BBSR1	NED	PIPILI	BANAMALIPUR ODS	14255	11 KV BANAMALIPUR NE	14255201	NUASAHI	1432DT604	100	MIXED	AMI	Yes	67%	88	0.09283362	0.037711	0.05512262	59.38%
2727	TPCODL	BBSR1	NED	PIPILI	BANAMALIPUR ODS	14255	11 KV BANAMALIPUR NE	14255201	DANDASAHI BAZAR	1432DT605	100	MIXED	AMI	Yes	67%	131	0.12982104	0.060587	0.06923404	53.33%
2728	TPCODL	BBSR1	NED	PIPILI	BANAMALIPUR ODS	14255	11 KV BANAMALIPUR NE	14255201	MAJHIHARA	1432DT614	100	MIXED	AMI	Yes	67%	76	0.07132826	0.030727	0.04060126	56.92%
2729	TPCODL	BBSR1	NED	PIPILI	BANAMALIPUR ODS	14255	11 KV BANAMALIPUR NE	14255201	GUAPUR VILLAGE	1432DT620	100	MIXED	AMI	Yes	67%	61	0.06788022	0.021568	0.04631222	68.23%
2730	TPCODL	BBSR1	NED	PIPILI	BANAMALIPUR ODS	14255	11 KV BANAMALIPUR NE	14255201	MUNDAHANA PATNA - II	1432DT623	100	MIXED	AMI	Yes	67%	88	0.07289436	0.036463	0.03643136	49.98%
2731	TPCODL	BBSR1	NED	PIPILI	BANAMALIPUR ODS	14255	11 KV BANAMALIPUR NE	14255201	MARTHAPUR - I	1432DT643	100	MIXED	AMI	Yes	67%	56	0.0532573	0.015335	0.0379223	71.21%
2732	TPCODL	BBSR1	NED	PIPILI	BANAMALIPUR ODS	14255	11 KV BANAMALIPUR NE	14255201	ALOI - I (PRADHAN SAHI)	1432DT649	100	MIXED	AMI	Yes	67%	63	0.08542802	0.017239	0.06818902	79.82%
2733	TPCODL	BBSR1	NED	PIPILI	BANAMALIPUR ODS	14255	11 KV BANAMALIPUR NE	14255201	ALOI - II (MAHAJAN SAHI)	1432DT654	100	MIXED	AMI	Yes	67%	91	0.06163222	0.0199	0.04173222	67.71%
2734	TPCODL	BBSR1	NED	PIPILI	BANAMALIPUR ODS	14255	11 KV JAYADEV	14255203	MAHUKHANDA BEHERA SAHI	1432DT691	100	MIXED	AMI	Yes	0%	52	0.04802722	0.016994	0.03103322	64.62%
2735	TPCODL	BBSR1	NED	PIPILI	BANAMALIPUR ODS	14255	11 KV JAYADEV	14255203	MAHUKHANDA TRIPATHY SAHI	1432DT693	100	MIXED	AMI	Yes	67%	116	0.08573238	0.034773	0.05095938	59.44%
2736	TPCODL	BBSR1	NED	PIPILI	BANAMALIPUR ODS	14255	11 KV JAYADEV	14255203	GIRINGA VILLAGE	1432DT701	100	MIXED	AMI	Yes	67%	57	0.06125504	0.019683	0.04157204	67.87%
2737	TPCODL	BBSR1	NED	PIPILI	BANAMALIPUR ODS	14255	11 KV JAYADEV	14255203	SAHEBNAGAR MINABAZAR - I	1432DT707	100	MIXED	AMI	Yes	67%	73	0.08200548	0.03366	0.04834548	58.95%
2738	TPCODL	BBSR1	NED	PIPILI	BANAMALIPUR ODS	14255	11 KV JAYADEV	14255203	NUASAHI SETHI SAHI	1432DT712	100	MIXED	AMI	Yes	67%	18	0.01437378	0.007924	0.00644978	44.87%
2739	TPCODL	BBSR1	NED	PIPILI	BANAMALIPUR ODS	14255	11 KV JAYADEV	14255203	BARABATI BASTI - I	1432DT716	100	MIXED	AMI	Yes	0%	25	0.05754018	0.016197	0.04134318	71.85%
2740	TPCODL	BBSR1	NED	PIPILI	BANAMALIPUR ODS	14255	11 KV JAYADEV	14255203	DEULI	1432DT721	100	MIXED	AMI	Yes	67%	116	0.07608466	0.040917	0.03516766	46.22%
2741	TPCODL	BBSR1	NED	PIPILI	BANAMALIPUR ODS	14255	11 KV JAYADEV	14255203	KULASAHI	1432DT730	100	MIXED	AMI	Yes	67%	82	0.06182674	0.034712	0.02711474	43.86%
2742	TPCODL	BBSR1	NED	PIPILI	BANAMALIPUR ODS	14255	11 KV JAYADEV	14255203	PRATAPRUDRAPUR - I	1432DT736	100	MIXED	AMI	Yes	67%	59	0.05016076	0.024102	0.02605876	51.95%
2743	TPCODL	BBSR1	NED	PIPILI	BANAMALIPUR ODS	14255	11 KV JAYADEV	14255203	AKHANDALESWAR TEMPLE	1432DT741	63	MIXED	AMI	Yes	0%	20	0.02155162	0.007895	0.01365662	63.37%
2744	TPCODL	BBSR1	NED	PIPILI	BANAMALIPUR ODS	14255	11 KV JAYADEV	14255203	UPARSAHI	1432DT745	100	MIXED	AMI	Yes	67%	69	0.0612905	0.038008	0.0232825	37.99%
2745	TPCODL	BBSR1	NED	PIPILI	BANAMALIPUR ODS	14255	11 KV JAYADEV	14255203	JAYDEV PITHA	1432DT755	100	MIXED	AMI	Yes	67%	1	0.00216616	0.002123	0.00004316	1.99%
2746	TPCODL	BBSR1	NED	PIPILI	BANAMALIPUR ODS	14255	11 KV JAYADEV	14255203	PARIBASUDEIPUR - I	1432DT768	100	MIXED	AMI	Yes	67%	56	0.0539039	0.031478	0.0224259	41.60%
2747	TPCODL	BBSR1	NED	PIPILI	BHARATIPUR ODSSP	14258	11 KV Sadamgoi	14258201	SUNAMUNHI1	1433DT112	100	MIXED	AMI	Yes	0%	51	0.03085318	0.009776	0.02107718	68.31%
2748	TPCODL	BBSR1	NED	PIPILI	BHARATIPUR ODSSP	14258	11 KV Sadamgoi	14258201	SANDANGOI UTARAGADA	1433DT129	250	MIXED	AMI	Yes	0%	105	0.105156	0.023675	0.081481	77.49%
2749	TPCODL	BBSR1	NED	PIPILI	BHARATIPUR ODSSP	14258	11 KV Sadamgoi	14258201	SINGHA BERAMPUR	1433DT152	250	MIXED	AMI	Yes	67%	75	0.12840188	0.036281	0.09212088	71.74%
2750	TPCODL	BBSR1	NED	PIPILI	BHARATIPUR ODSSP	14258	11 KV Sadamgoi	14258201	NEEPUR 1	1433DT156	250	MIXED	AMI	Yes	100%	174	0.06529224	0.055265	0.01002724	15.36%
2751	TPCODL	BBSR1	NED	PIPILI	BHARATIPUR ODSSP	14258	11 KV Sadamgoi	14258201	MALIGAON(MAIN VILLAGE)	1433DT163	100	MIXED	AMI	Yes	0%	73	0.04981168	0.018801	0.03101068	62.26%
2752	TPCODL	BBSR1	NED	PIPILI	BHARATIPUR ODSSP	14258	11 KV Sadamgoi	14258201	SINGARKERI 1	1433DT181	100	MIXED	AMI	Yes	67%	66	0.02670529	0.014061	0.01264429	47.35%
2753	TPCODL	BBSR1	NED	PIPILI	BHINGARPUR	14224	11 KV BHINGARPUR	14224202	PATUPADA RWSS	1431DT101	25	MIXED	AMI	Yes	100%	47	0.02923588	0.022576	0.00665988	22.78%
2754	TPCODL	BBSR1	NED	PIPILI	BHINGARPUR	14224	11 KV BHINGARPUR	14224202	BENTAPUR -III	1432DT010	100	MIXED	AMI	Yes	0%	86	0.06270614	0.049189	0.01351714	21.56%
2755	TPCODL	BBSR1	NED	PIPILI	BHINGARPUR	14224	11 KV BHINGARPUR	14224202	PARIYA PATAPUR -II	1432DT763	100	MIXED	AMI	Yes	0%	95	0.06403	0.042878	0.021152	33.03%
2756	TPCODL	BBSR1	NED	PIPILI	DANDIPUR ODSSP	14379	11 KV KALIAPADA	14379201	TARABOI(BEHERA SAHI)	1424DT079	100	MIXED	AMI	Yes	100%	91	0.06134922	0.032123	0.02922622	47.64%
2757	TPCODL	BBSR1	NED	PIPILI	HARIRAJPUR	14035	11 KV KAKUDIA	14035202	TIGIRIA	1433DT013	100	MIXED	AMI	Yes	67%	53	0.03206312	0.019778	0.01228512	38.32%
2758	TPCODL	BBSR1	NED	PIPILI	HARIRAJPUR	14035	11 KV KAKUDIA	14035202	DAKHINA NUA GAON	1433DT028	250	MIXED	AMI	Yes	67%	35	0.03554376	0.007634	0.02790976	78.52%
2759	TPCODL	BBSR1	NED	PIPILI	KHELAR ODSSP	14264	11 KV Chingudiakanta	14264202	KUARPUR BHARATI SAHI	1434DT168	63	MIXED	AMI	Yes	0%	23	0.02400541	0.008399	0.01560641	65.01%
2760	TPCODL	BBSR1	NED	PIPILI	KHELAR ODSSP	14264	11 KV Khelar Bazaar	14264203	BHANAPUR 1	1434DT141	100	MIXED	AMI	Yes	0%	127	0.08345462	0.080134	0.00332062	3.98%
2761	TPCODL	BBSR1	NED	PIPILI	KHELAR ODSSP	14264	11 KV Khelar Bazaar	14264203	RENCH SASANA	1434DT153	100	MIXED	AMI	Yes	67%	74	0.06397434	0.034735	0.02923934	45.70%
2762	TPCODL	BBSR1	NED	PIPILI	KHELAR ODSSP	14264	11 KV Khelar Bazaar	14264203	SISHU MANDIRA (KHELAR)	1434DT161	100	MIXED	AMI	Yes	67%	58	0.05086058	0.025848	0.02501258	49.18%
2763	TPCODL	BBSR1	NED	PIPILI	KHELAR ODSSP	14264	11 KV Khelar Bazaar	14264203	GARAPADA-1	1434DT171	100	MIXED	AMI	Yes	67%	66	0.02116728	0.01958	0.00158728	7.50%
2764	TPCODL	BBSR1	NED	PIPILI	KHELAR ODSSP	14264	11 KV Khelar Bazaar	14264203	KAURPUR MAHADEVA SAHI	1434DT193	100	MIXED	AMI	Yes	67%	69	0.05326686	0.021531	0.03173586	59.58%
2765	TPCODL	BBSR1	NED	PIPILI	KHELAR ODSSP	14264	11 KV Khelar Bazaar	14264203	BHAGABATIPUR BRAHMANA SASAN	1434DT206	100	MIXED	AMI	Yes	0%	141	0.06643236	0.051082	0.01535036	23.11%
2766	TPCODL	BBSR1	NED	PIPILI	KHELAR ODSSP	14264	11 KV Khelar Bazaar	14264203	SAINSASAN PRADHAN SAHI	1434DT208	100	MIXED	AMI	Yes	0%	95	0.05550898	0.025542	0.02996698	53.99%
2767	TPCODL	BBSR1	NED	PIPILI	KHELAR ODSSP	14264	11 KV Khelar Bazaar	14264203	BISWALPADA HARIJANSAHI	1434DT245	100	MIXED	AMI	Yes	33%	80	0.04845342	0.024229	0.02422442	50.00%
2768	TPCODL	BBSR1	NED	PIPILI	KONARK	14031	11 KV SIRIPUR (KONARK)	14031207	AMBILIGAON -2	1422DT162	100	MIXED	AMI	Yes	67%	115	0.07694256	0.036477	0.04046556	52.59%
2769	TPCODL	BBSR1	NED	PIPILI	MANGALPUR ODSS	14265	11 KV MANGALPUR	14265201	MANGALPUR BAZAR	1435DT202	250	MIXED	AMI	Yes	100%	131	0.12532636	0.061065	0.06426136	51.28%
2770	TPCODL	BBSR1	NED	PIPILI	MANGALPUR ODSS	14265	11 KV MANGALPUR	14265201	MANGALPUR UTTERBAR	1435DT210	100	MIXED	AMI	Yes	0%	41	0.0432338	0.021021	0.0222128	51.38%
2771	TPCODL	BBSR1	NED	PIPILI	MANGALPUR ODSS	14265	11 KV MANGALPUR	14265201	SUNSARAGAILO	1435DT216	100	MIXED	AMI	Yes	0%	52	0.04157186	0.016371	0.02520086	60.62%
2772	TPCODL	BBSR1	NED	PIPILI	MANGALPUR ODSS	14265	11 KV MANGALPUR	14265201	MADHUBAN DHABA 2	1435DT228	100	MIXED	AMI	Yes	0%	67	0.03458217	0.021388	0.01319417	38.15%
2773	TPCODL	BBSR1	NED	PIPILI	MANGALPUR ODSS	14265	11 KV MANGALPUR	14265201	NUYAGHORI 1	1435DT231	63	MIXED	AMI	Yes	0%	132	0.08604552	0.057987	0.02805852	32.61%

Sl. No.	Zone Name	Circle name	Division name	Name of the Sub-division	Name of the Sub-station	Substation Code	Name of the 11 kV Feeder	Feeder Code	Name of the Location where DT situated	DT code	DT Capacity (kVA)	Predominant consumer type of DT (Domestic/Industrial/Agriculture/Mixed)	Type of metering AMR/AMI/ Communicable/Conventional metered/Unmetered	Status of Meter-whether Functional (Yes/No)	% of data received automatically (if AMR/AMI)	No. of Connected Consumers	Input Energy (MU) (A)	Billed Energy (MU) (B)	Loss (MU) (A-B)	% DT Loss (A-B)/A
2774	TPCODL	BBSR1	NED	PIPILI	MANGALPUR ODSSI	14265	11 KV MANGALPUR	14265201	SENAPATI CHHUDA MILL	1435DT235	250	MIXED	AMI	Yes	0%	19	0.02519476	0.009355	0.01583976	62.87%
2775	TPCODL	BBSR1	NED	PIPILI	MANGALPUR ODSSI	14265	11 KV MANGALPUR	14265201	NUAGODI RGGVY	1435DT237	25	MIXED	AMI	Yes	67%	93	0.05793674	0.021394	0.03654274	63.07%
2776	TPCODL	BBSR1	NED	PIPILI	MANGALPUR ODSSI	14265	11 KV MANGALPUR	14265201	NIRMALA P.U.P	1435DT238	63	MIXED	AMI	Yes	67%	68	0.04644676	0.013864	0.03258276	70.15%
2777	TPCODL	BBSR1	NED	PIPILI	MANGALPUR ODSSI	14265	11 KV MANGALPUR	14265201	DASPATNA	1435DT297	100	MIXED	AMI	Yes	33%	89	0.07357842	0.029322	0.04425642	60.15%
2778	TPCODL	BBSR1	NED	PIPILI	MANGALPUR ODSSI	14265	11 KV MANGALPUR	14265201	JAJPUR	1435DT313	100	MIXED	AMI	Yes	0%	73	0.07937594	0.023784	0.05559194	70.04%
2779	TPCODL	BBSR1	NED	PIPILI	MANGALPUR ODSSI	14265	11 KV RAHAGIRIPUR	14265202	JANADARPU	1435DT325	100	MIXED	AMI	Yes	0%	43	0.0421794	0.014517	0.0276624	65.58%
2780	TPCODL	BBSR1	NED	PIPILI	MANGALPUR ODSSI	14265	11 KV RAHAGIRIPUR	14265202	PAIKOPADA	1435DT328	100	MIXED	AMI	Yes	0%	37	0.02621134	0.010402	0.01580934	60.31%
2781	TPCODL	BBSR1	NED	PIPILI	MANGALPUR ODSSI	14265	11 KV RAHAGIRIPUR	14265202	JANARDHANPUR	1435DT331	100	MIXED	AMI	Yes	0%	22	0.01946282	0.005087	0.01437582	73.86%
2782	TPCODL	BBSR1	NED	PIPILI	MANGALPUR ODSSI	14265	11 KV RAHAGIRIPUR	14265202	CHANDAN MAHARANA	1435DT341	25	MIXED	AMI	Yes	0%	51	0.02984532	0.01161	0.01823532	61.10%
2783	TPCODL	BBSR1	NED	PIPILI	MANGALPUR ODSSI	14265	11 KV RAHAGIRIPUR	14265202	SAHAJPUR HARI JANA SAHI	1435DT342	63	MIXED	AMI	Yes	100%	112	0.06230724	0.030432	0.03187524	51.16%
2784	TPCODL	BBSR1	NED	PIPILI	MANGALPUR ODSSI	14265	11 KV RAHAGIRIPUR	14265202	MANOHARA	1435DT344	100	MIXED	AMI	Yes	0%	32	0.01890966	0.01351	0.00539966	28.56%
2785	TPCODL	BBSR1	NED	PIPILI	MANGALPUR ODSSI	14265	11 KV RAHAGIRIPUR	14265202	MURDHUNIPUR	1435DT345	100	MIXED	AMI	Yes	0%	18	0.02944964	0.011205	0.01824464	61.95%
2786	TPCODL	BBSR1	NED	PIPILI	MANGALPUR ODSSI	14265	11 KV RAHAGIRIPUR	14265202	ABALPUR	1435DT347	100	MIXED	AMI	Yes	0%	42	0.02254914	0.010458	0.01209114	53.62%
2787	TPCODL	BBSR1	NED	PIPILI	MANGALPUR ODSSI	14265	11 KV RAHAGIRIPUR	14265202	ABALPUR MAIN VILLAGE	1435DT349	100	MIXED	AMI	Yes	0%	51	0.03352332	0.01394	0.01958332	58.42%
2788	TPCODL	BBSR1	NED	PIPILI	NIMAPARA	14027	11 KV DANDIPUR	14027203	LOKEIGORADA	1424DT252	100	MIXED	AMI	Yes	0%	67	0.06956394	0.02006	0.04950394	71.16%
2789	TPCODL	BBSR1	NED	PIPILI	NIMAPARA	14027	11 KV PATAPUR	14027205	JAINABADA	1423DT464	100	MIXED	AMI	Yes	100%	102	0.08642798	0.055606	0.03082198	35.66%
2790	TPCODL	BBSR1	NED	PIPILI	PANDUA ODSSP	14313	11 KV SOGAR	14313201	SOGARA PURUNA SAHI	4146DT039	250	MIXED	AMI	Yes	67%	118	0.05803268	0.042562	0.01547068	26.66%
2791	TPCODL	BBSR1	NED	PIPILI	PIPILI	14028	11 KV PIPILI	14028201	MUSTAFA NAGAR3(DANAGOHIRI)	1433DT065	250	MIXED	AMI	Yes	0%	32	0.05913496	0.021689	0.03744596	63.32%
2792	TPCODL	BBSR1	NED	PIPILI	PIPILI	14028	11 KV PIPILI	14028201	HATASAHI(BEHERASAHI1)	1433DT074	100	MIXED	AMI	Yes	0%	56	0.0294221	0.01249	0.0169321	57.55%
2793	TPCODL	BBSR1	NED	PIPILI	PIPILI	14028	11 KV PIPILI	14028201	BHARATIPUR BAZAR	1433DT115	250	MIXED	AMI	Yes	100%	95	0.07354432	0.046691	0.02685332	36.51%
2794	TPCODL	BBSR1	NED	PIPILI	PIPILI	14028	11 KV PIPILI	14028201	TOTAPADA NAYAK SAHI	1433DT117	250	MIXED	AMI	Yes	0%	99	0.03671552	0.023064	0.01365152	37.18%
2795	TPCODL	BBSR1	NED	PIPILI	PIPILI	14028	11 KV PIPILI	14028201	BAGESWARPUR	1433DT121	250	MIXED	AMI	Yes	100%	86	0.11042976	0.032551	0.07787876	70.52%
2796	TPCODL	BBSR1	NED	PIPILI	PIPILI	14028	11 KV PIPILI	14028201	PANDA BAZAR PIPILI	1434DT299	250	MIXED	AMI	Yes	0%	118	0.18791572	0.088448	0.09946772	52.93%
2797	TPCODL	BBSR1	NED	PIPILI	PIPILI	14028	11 KV PIPILI	14028201	OLD NAC MARKET	1434DT301	250	MIXED	AMI	Yes	0%	137	0.17217748	0.105268	0.06690948	38.86%
2798	TPCODL	BBSR1	NED	PIPILI	PIPILI	14028	11 KV PIPILI	14028201	PIPILI SASANA	1434DT302	100	MIXED	AMI	Yes	100%	56	0.05023368	0.02463	0.02560368	50.97%
2799	TPCODL	BBSR1	NED	PIPILI	PIPILI	14028	11 KV PIPILI	14028201	TRAINING SCHOOL 1NEAR PWD IB)	1434DT306	100	MIXED	AMI	Yes	0%	100	0.13740768	0.075733	0.06167468	44.88%
2800	TPCODL	BBSR1	NED	PIPILI	PIPILI	14028	11 KV PIPILI	14028201	HASANPUR BANIASAHI 1	1434DT311	100	MIXED	AMI	Yes	100%	29	0.10781906	0.02165	0.08616906	79.92%
2801	TPCODL	BBSR1	NED	PIPILI	PIPILI	14028	11 KV PIPILI	14028201	HASANPUR MUSLIM SAHI	1434DT315	100	MIXED	AMI	Yes	100%	71	0.09828116	0.03776968	0.06051148	61.57%
2802	TPCODL	BBSR1	NED	PIPILI	PIPILI	14028	11 KV PIPILI	14028201	NARSINGHPUR 1	1434DT330	200	MIXED	AMI	Yes	0%	87	0.10464744	0.073961	0.03068644	29.32%
2803	TPCODL	BBSR1	NED	PIPILI	PIPILI	14028	11 KV PIPILI	14028201	SRIRAM NAGAR 1	1434DT331	250	MIXED	AMI	Yes	67%	81	0.10684991	0.075116	0.03173391	29.70%
2804	TPCODL	BBSR1	NED	PIPILI	PIPILI	14028	11 KV PIPILI	14028201	NARSINGHPUR	1434DT339	100	MIXED	AMI	Yes	100%	71	0.07458654	0.029509	0.04507754	60.44%
2805	TPCODL	BBSR1	NED	PIPILI	PIPILI	14028	11 KV PIPILI	14028201	NARSINGHPUR 3	1434DT340	250	MIXED	AMI	Yes	100%	90	0.12821088	0.046848	0.08136288	63.46%
2806	TPCODL	BBSR1	NED	PIPILI	PIPILI	14028	11 KV PIPILI	14028201	BASTU VIHAR	1434DT354	250	MIXED	AMI	Yes	100%	85	0.04728356	0.047083	0.00020056	0.42%
2807	TPCODL	BBSR1	NED	PIPILI	PIPILI	14028	11 KV PIPILI	14028201	BADHEISAHI	1434DT435	100	MIXED	AMI	Yes	100%	27	0.02671156	0.010891	0.01582056	59.23%
2808	TPCODL	BBSR1	NED	PIPILI	PIPILI	14028	11 KV PIPILI	14028201	NARSING PUR	1435DT359	100	MIXED	AMI	Yes	0%	30	0.0316174	0.025359	0.0062584	19.79%
2809	TPCODL	BBSR1	NED	PIPILI	PIPILI	14028	11 KV PIPILI	14028201	DELANGA CHOWK	1435DT369	500	MIXED	AMI	Yes	0%	136	0.22664816	0.076249	0.15039916	66.36%
2810	TPCODL	BBSR1	NED	PIPILI	PIPILI	14028	11 KV PIPILI	14028201	HASANPUR	1435DT374	100	MIXED	AMI	Yes	0%	103	0.0693964	0.052646	0.0167504	24.14%
2811	TPCODL	BBSR1	NED	PIPILI	PIPILI	14028	11 KV RAJAS	14028202	DAGARA SAHI 1	1434DT104	100	MIXED	AMI	Yes	0%	81	0.10132178	0.029322	0.07199978	71.06%
2812	TPCODL	BBSR1	NED	PIPILI	PIPILI	14028	11 KV RAJAS	14028202	DIHA SAHI	1434DT108	100	MIXED	AMI	Yes	0%	107	0.09547636	0.039092	0.05638436	59.06%
2813	TPCODL	BBSR1	NED	PIPILI	PIPILI	14028	11 KV RAJAS	14028202	SUNAPADA	1434DT112	100	MIXED	AMI	Yes	0%	62	0.03302431	0.023608	0.00941631	28.51%
2814	TPCODL	BBSR1	NED	PIPILI	PIPILI	14028	11 KV RAJAS	14028202	KANTUNIA	1434DT127	100	MIXED	AMI	Yes	67%	98	0.05888686	0.035034	0.02385286	40.51%
2815	TPCODL	BBSR1	NED	PIPILI	PIPILI	14028	11 KV RAJAS	14028202	GODIMALA	1434DT130	100	MIXED	AMI	Yes	0%	119	0.08391509	0.048671	0.03524409	42.00%
2816	TPCODL	BBSR1	NED	PIPILI	PIPILI	14028	11 KV RAJAS	14028202	TIGHIRIA	1434DT233	100	MIXED	AMI	Yes	0%	44	0.03116056	0.016182	0.01497856	48.07%
2817	TPCODL	BBSR1	NED	PIPILI	PIPILI	14028	11 KV RAJAS	14028202	NAHALA-1	1434DT234	100	MIXED	AMI	Yes	0%	64	0.06033947	0.024746	0.03559347	58.99%
2818	TPCODL	BBSR1	NED	PIPILI	PIPILI	14028	11 KV RAJAS	14028202	JAGANNATHPUR BEHERA SAHI	1434DT249	100	MIXED	AMI	Yes	0%	97	0.08544796	0.036635	0.04881296	57.13%
2819	TPCODL	BBSR1	NED	PIPILI	PIPILI	14028	11 KV RAJAS	14028202	JAGANNATHPUR	1434DT251	250	MIXED	AMI	Yes	100%	168	0.16729136	0.059901	0.10739036	64.19%
2820	TPCODL	BBSR1	NED	PIPILI	PIPILI	14028	11 KV RAJAS	14028202	BILIPADA BARIK SAHI	1434DT255	100	MIXED	AMI	Yes	0%	57	0.06281331	0.018532	0.04428131	70.50%
2821	TPCODL	BBSR1	NED	PIPILI	PIPILI	14028	11 KV RAJAS	14028202	RATHA SAHI	1434DT260	100	MIXED	AMI	Yes	0%	33	0.02213916	0.011238	0.01090116	49.24%
2822	TPCODL	BBSR1	NED	PIPILI	PIPILI	14028	11 KV RAJAS	14028202	BILIPADA BAZAR	1434DT263	63	MIXED	AMI	Yes	0%	21	0.02829412	0.012204	0.01609012	56.87%
2823	TPCODL	BBSR1	NED	PIPILI	PIPILI	14028	11 KV RAJAS	14028202	KUSHANGA MOHANTY SAHI	1434DT270	100	MIXED	AMI	Yes	0%	69	0.0706227	0.044298	0.0263247	37.28%
2824	TPCODL	BBSR1	NED	PIPILI	PIPILI	14028	11 KV RAJAS	14028202	HARIPUR	1434DT281	500	MIXED	AMI	Yes	0%	331	0.32360824	0.150979	0.17262924	53.35%
2825	TPCODL	BBSR1	NED	PIPILI	PIPILI	14028	11 KV MANGALAPUR-1	14028203	GOLAPOKHARI_IPDS	1435DT001	100	MIXED	AMI	Yes	67%	53	0.1278506	0.031544	0.0963066	75.33%
2826	TPCODL	BBSR1	NED	PIPILI	PIPILI	14028	11 KV MANGALAPUR-1	14028203	TEACHERS COLONY	1435DT003	250	MIXED	AMI	Yes	0%	119	0.12905396	0.084332	0.04472196	34.65%
2827	TPCODL	BBSR1	NED	PIPILI	PIPILI	14028	11 KV MANGALAPUR-1	14028203	POST OFFICE CHHAKA	1435DT007	500	MIXED	AMI	Yes	0%	206	0.2722756	0.203213	0.0690626	25.36%
2828	TPCODL	BBSR1	NED	PIPILI	PIPILI	14028	11 KV MANGALAPUR-1	14028203	JATANI CHHAKA	1435DT010	500	MIXED	AMI	Yes	0%	357	0.27278328	0.252627	0.02015628	7.39%
2829	TPCODL	BBSR1	NED	PIPILI	PIPILI	14028	11 KV MANGALAPUR-1	14028203	MADHIALI_IPDS	1435DT017	100	MIXED	AMI	Yes	0%	43	0.01520372	0.007528	0.00767572	50.49%
2830	TPCODL	BBSR1	NED	PIPILI	PIPILI	14028	11 KV MANGALAPUR-1	14028203	DIHA SAHI	1435DT025	250	MIXED	AMI	Yes	100%	97	0.11937404	0.050188	0.06918604	57.96%
2831	TPCODL	BBSR1	NED	PIPILI	PIPILI	14028	11 KV MANGALAPUR-1	14028203	COLLEGE CHHAK-1	1435DT048	250	MIXED	AMI	Yes	0%	161	0.22780244	0.109862	0.11794044	51.77%
2832	TPCODL	BBSR1	NED	PIPILI	PIPILI	14028	11 KV MANGALAPUR-1	14028203	COLLEGE CHHAK-3	1435DT049	250	MIXED	AMI	Yes	0%	121	0.10241476	0.088458	0.01395676	13.63%
2833	TPCODL	BBSR1	NED	PIPILI	PIPILI	14028	11 KV MANGALAPUR-1	14028203	JAYPUR HAT	1435DT054	250	MIXED	AMI	Yes	0%	137	0.1267692	0.072275	0.0544942	42.99%
2834	TPCODL	BBSR1	NED	PIPILI	PIPILI	14028	11 KV MANGALAPUR-1	14028203	PIPILI MEDICAL-I	1435DT108	100	MIXED	AMI	Yes	0%	3	0.02344864	0.021121	0.00232764	9.93%
2835	TPCODL	BBSR1	NED	PIPILI	PIPILI	14028	11 KV MANGALAPUR-1	14028203	SULTAN NAGAR SCHOOL	1435DT161	250	MIXED	AMI	Yes	0%	130	0.24316666	0.055736	0.18743066	77.08%
2836	TPCODL	BBSR1	NED	PIPILI	PIPILI	14028	11 KV MANGALAPUR-2	14028204	VIP COLONY(PONDA BAZAR)	1434DT408	250	MIXED	AMI	Yes	100%	30	0.05355648	0.031881	0.02167548	40.47%
2837	TPCODL	BBSR1	NED	PIPILI	PIPILI	14028	11 KV MANGALAPUR-2	14028204	ASHRAM PATANA(PONDA BAZAR)	1434DT409	100	MIXED	AMI	Yes	100%	72	0.04351386	0.035917	0.00759686	17.46%
2838	TPCODL	BBSR1	NED	PIPILI	PIPILI	14028	11 KV MANGALAPUR-2	14028204	TESMILE CHHAK	1435DT059	100	MIXED	AMI	Yes	100%	24	0.0278525	0.013375	0.0144775	51.98%
2839	TPCODL	BBSR1	NED	PIPILI	PIPILI	14028	11 KV MANGALAPUR-2	14028204	DM PUR 1ST PART NO1	1435DT070	100	MIXED	AMI	Yes	0%	105	0.08558126	0.042347	0.04323426	50.52%
2840	TPCODL	BBSR1	NED	PIPILI	PIPILI	14028	11 KV MANGALAPUR-2	14028204	DM PUR BAZAR	1435DT072	100	MIXED	AMI	Yes	100%	84	0.06796982	0.053191	0.01477882	21.74%
2841	TPCODL	BBSR1	NED	PIPILI	PIPILI	14028	11 KV MANGALAPUR-2	14028204	KULASEKHARAPATANA 2	1435DT084	100	MIXED	AMI	Yes	100%	111	0.10461012	0.037097	0.06751312	64.54%
2842	TPCODL	BBSR1	NED	PIPILI	PIPILI	14028	11 KV MANGALAPUR-2	14028204	SAMPUR 1	1435DT092	100	MIXED	AMI	Yes	67%	47	0.06007584	0.014077	0.04599884	76.57%
2843	TPCODL	BBSR1	NED	PIPILI	PIPILI	14028	11 KV MANGALAPUR-2	14028204	DM PUR 3RD PART	1435DT113	250	MIXED	AMI	Yes	0%	90	0.10601504	0.046229	0.05978604	56.39%
2844	TPCODL	BBSR1	NED	PIPILI	PIPILI	14028	11 KV MANGALAPUR-2	14028204	NUASASANA DAKHINA SAHI	1435DT124	100	MIXED	AMI	Yes	0%	124	0.09443746	0.062063	0.03237446	34.28%
2845	TPCODL	BBSR1	NED	PIPILI	PIPILI	14028	11 KV MANGALAPUR-2	14028204	CHAUDAMANA 1	1435DT131	100	MIXED	AMI	Yes	0%	125	0.0780145	0.055437	0.0225775	28.94%
2846	TPCODL	BBSR1	NED	PIPILI	PIPILI	14028	11 KV MANGALAPUR-2	14028204	NUASASANA UTARA SAHI 1	1435DT135	100	MIXED	AMI	Yes	0%	66	0.0722305	0.028082	0.0441485	61.12%

Sl. No.	Zone Name	Circle name	Division name	Name of the Sub-division	Name of the Sub-station	Substation Code	Name of the 11 kV Feeder	Feeder Code	Name of the Location where DT situated	DT code	DT Capacity (kVA)	Predominant consumer type of DT (Domestic/Industrial/Agriculture/Mixed)	Type of metering AMR/AMI/ Communicable/Conventional metered/Unmetered	Status of Meter-whether Functional (Yes/No)	% of data received automatically (if AMR/AMI)	No. of Connected Consumers	Input Energy (MU) (A)	Billed Energy (MU) (B)	Loss (MU) (A-B)	% DT Loss (A-B)/A
2847	TPCODL	BBSR1	NED	PIPILI	PIPILI	14028	11 KV MANGALAPUR-2	14028204	NUASASANA LAXMINRUSINGHATEMI	1435DT137	100	MIXED	AMI	Yes	0%	83	0.09456884	0.03934	0.05522884	58.40%
2848	TPCODL	BBSR1	NED	PIPILI	PIPILI	14028	11 KV MANGALAPUR-2	14028204	JHUNUPADIA	1435DT151	100	MIXED	AMI	Yes	100%	74	0.05031166	0.032746	0.01756566	34.91%
2849	TPCODL	BBSR1	NED	PIPILI	PIPILI	14028	11 KV MANGALAPUR-2	14028204	DM PUR 1ST PART NO2	1435DT177	100	MIXED	AMI	Yes	100%	68	0.07773268	0.04136	0.03637268	46.79%
2850	TPCODL	BBSR1	NED	PIPILI	PIPILI	14028	11 KV MANGALAPUR-2	14028204	RANAPUR	1435DT180	100	MIXED	AMI	Yes	100%	40	0.04881514	0.015735	0.03308014	67.77%
2851	TPCODL	BBSR1	NED	PIPILI	PIPILI	14028	11 KV MANGALAPUR-2	14028204	SAMPUR CHUDA MILL	1435DT182	100	MIXED	AMI	Yes	67%	47	0.06251632	0.02815	0.03436632	54.97%
2852	TPCODL	BBSR1	NED	PIPILI	PIPILI	14028	11 KV MANGALAPUR-2	14028204	MANGALPUR 2	1435DT250	100	MIXED	AMI	Yes	0%	83	0.1006339	0.044461	0.0561729	55.82%
2853	TPCODL	BBSR1	NED	PIPILI	PIPILI	14028	11 KV MANGALAPUR-2	14028204	MANGALPUR 2	1435DT253	63	MIXED	AMI	Yes	67%	58	0.04515422	0.021287	0.02386722	52.86%
2854	TPCODL	BBSR1	NED	PIPILI	PIPILI	14028	11 KV MANGALAPUR-2	14028204	THANTHANA	1435DT260	100	MIXED	AMI	Yes	0%	117	0.0794108	0.058195	0.0212158	26.72%
2855	TPCODL	BBSR1	NED	PIPILI	PIPILI	14028	11 KV MANGALAPUR-2	14028204	SORENPONDOR	1435DT266	100	MIXED	AMI	Yes	0%	44	0.02670216	0.015081	0.01162116	43.52%
2856	TPCODL	BBSR1	NED	PIPILI	PIPILI	14028	11 KV MANGALAPUR-2	14028204	SOLONA	1435DT277	100	MIXED	AMI	Yes	67%	69	0.04217828	0.020585	0.02159328	51.20%
2857	TPCODL	BBSR1	NED	PIPILI	PIPILI	14028	11 KV MANGALAPUR-2	14028204	MURDHUNIPUR SCHOOL SIDE RGGVY	1435DT311	25	MIXED	AMI	Yes	67%	48	0.0179871	0.009556	0.0084311	46.87%
2858	TPCODL	BBSR1	NED	PIPILI	RAHAMA	14177	11 KV BEHEDA	14177203	SAILO	5413DT113	100	MIXED	AMI	Yes	67%	110	0.06057152	0.049415	0.01115652	18.42%
2859	TPCODL	BBSR1	NED	PIPILI	SIULA ODSSP	14254	11 KV PATASAINIPUR	14254202	PAIKA SAHI	1434DT419	100	MIXED	AMI	Yes	67%	36	0.04532274	0.01584	0.02948274	65.05%
2860	TPCODL	BBSR1	NED	PIPILI	SIULA ODSSP	14254	11 KV PATASAINIPUR	14254202	ADONGAPADA	1434DT420	100	MIXED	AMI	Yes	67%	67	0.06033816	0.018237	0.04210116	69.78%
2861	TPCODL	BBSR1	NED	PIPILI	SIULA ODSSP	14254	11 KV PATASAINIPUR	14254202	HARIANTA	1434DT428	250	MIXED	AMI	Yes	67%	79	0.07965008	0.025138	0.05451208	68.44%
2862	TPCODL	BBSR1	NED	PIPILI	SIULA ODSSP	14254	11 KV PATASAINIPUR	14254202	HARIANTA PATNA	1434DT430	63	MIXED	AMI	Yes	0%	42	0.03230495	0.015776	0.01652895	51.17%
2863	TPCODL	BBSR1	NED	PIPILI	TRAHI ACHYUTA NA	14259	11 KV TRAHI ACHYUTA N	14259201	DEULIPOKHARI	1434DT379	100	MIXED	AMI	Yes	67%	48	0.02576234	0.019188	0.00657434	25.52%
2864	TPCODL	BBSR1	NED	PIPILI	TRAHI ACHYUTA NA	14259	11 KV MUKUNDADASPU	14259202	ADALABAD-2	1434DT015	100	MIXED	AMI	Yes	0%	101	0.0432832	0.03965	0.0036332	8.39%
2865	TPCODL	BBSR1	NED	PIPILI	TRAHI ACHYUTA NA	14259	11 KV MUKUNDADASPU	14259202	MUKUNDDASPUR	1434DT016	100	MIXED	AMI	Yes	67%	115	0.06563136	0.062756	0.00287536	4.38%
2866	TPCODL	BBSR1	NED	PIPILI	TRAHI ACHYUTA NA	14259	11 KV MUKUNDADASPU	14259202	KALABUNA	1434DT029	63	MIXED	AMI	Yes	67%	18	0.02182878	0.005051	0.01677778	76.86%
2867	TPCODL	BBSR1	NED	PIPILI	TRAHI ACHYUTA NA	14259	11 KV MUKUNDADASPU	14259202	BARADAPADA	1434DT032	100	MIXED	AMI	Yes	33%	89	0.06352496	0.033673	0.02985196	46.99%
2868	TPCODL	BBSR1	NED	PIPILI	TRAHI ACHYUTA NA	14259	11 KV MUKUNDADASPU	14259202	BIANAL	1434DT035	100	MIXED	AMI	Yes	67%	28	0.0193048	0.00573	0.0135748	70.32%
2869	TPCODL	BBSR1	NED	PIPILI	TRAHI ACHYUTA NA	14259	11 KV MUKUNDADASPU	14259202	BRAHMANA PADA	1434DT042	100	MIXED	AMI	Yes	100%	52	0.04049342	0.017152	0.02334142	57.64%
2870	TPCODL	BBSR1	NED	PIPILI	TRAHI ACHYUTA NA	14259	11 KV MUKUNDADASPU	14259202	MUKUNDDASPUR-5	1434DT049	100	MIXED	AMI	Yes	0%	71	0.05853416	0.032742	0.02579216	44.06%
2871	TPCODL	BBSR1	NED	PIPILI	TRAHI ACHYUTA NA	14259	11 KV RAJAS(TRAHI ACHY	14259203	SONA BHAJRAPUR	1434DT056	100	MIXED	AMI	Yes	67%	53	0.03554958	0.030112	0.00543758	15.30%
2872	TPCODL	BBSR1	NED	PIPILI	TRAHI ACHYUTA NA	14259	11 KV RAJAS(TRAHI ACHY	14259203	RAJAS MOHANTY SAHI-1	1434DT064	100	MIXED	AMI	Yes	67%	76	0.04949508	0.027111	0.02238408	45.22%
2873	TPCODL	BBSR1	NED	PIPILI	TRAHI ACHYUTA NA	14259	11 KV RAJAS(TRAHI ACHY	14259203	BARAHALA HINDU SAHI	1434DT071	100	MIXED	AMI	Yes	67%	65	0.04984198	0.020387	0.02945498	59.10%
2874	TPCODL	BBSR2	BAED	BALUGAON	ANKULAPADAR	14204	11 kV PANCHUGAON	14204204	GAMBHARI MUNDA VILLAGE	2315DT468	100	MIXED	AMI	Yes	100%	103	0.05729946	0.04344	0.01385946	24.19%
2875	TPCODL	BBSR2	BAED	BALUGAON	ANKULAPADAR	14204	11 KV TOWN	14204201	BADA HANTUAD MAHI SAHI	2314DT026	100	MIXED	AMI	Yes	100%	84	0.07769992	0.04021	0.03748992	48.25%
2876	TPCODL	BBSR2	BAED	BALUGAON	ANKULAPADAR	14204	11 KV TOWN	14204201	SANAHATUAD VILLAGE	2314DT033	100	MIXED	AMI	Yes	33%	62	0.04446152	0.023633	0.02082852	46.85%
2877	TPCODL	BBSR2	BAED	BALUGAON	ANKULAPADAR	14204	11 KV TOWN	14204201	MATIA POKHARI	2314DT036	100	MIXED	AMI	Yes	100%	149	0.09120943	0.063743	0.02746643	30.11%
2878	TPCODL	BBSR2	BAED	BALUGAON	ANKULAPADAR	14204	11 KV TOWN	14204201	SHYAM SUNDARPUR	2314DT042	250	MIXED	AMI	Yes	100%	161	0.1130438	0.05215	0.0608938	53.87%
2879	TPCODL	BBSR2	BAED	BALUGAON	ANKULAPADAR	14204	11 KV TOWN	14204201	MATIA POKHARI	2314DT043	100	MIXED	AMI	Yes	100%	134	0.074985	0.058106	0.016879	22.51%
2880	TPCODL	BBSR2	BAED	BALUGAON	ANKULAPADAR	14204	11 KV TOWN	14204201	NARENDRAPUR	2314DT061	100	MIXED	AMI	Yes	100%	173	0.06952798	0.051258	0.01826998	26.28%
2881	TPCODL	BBSR2	BAED	BALUGAON	ANKULAPADAR	14204	11 KV TOWN	14204201	BHAPUR	2314DT093	100	MIXED	AMI	Yes	100%	82	0.02412652	0.018229	0.00589752	24.44%
2882	TPCODL	BBSR2	BAED	BALUGAON	ANKULAPADAR	14204	11 KV TOWN	14204201	BRANDABANAPUR (BHAPUR)	2314DT101	100	MIXED	AMI	Yes	33%	134	0.05500952	0.049545	0.00546452	9.93%
2883	TPCODL	BBSR2	BAED	BALUGAON	ANKULAPADAR	14204	11 KV TOWN	14204201	HALANDA	2314DT105	100	MIXED	AMI	Yes	100%	155	0.04177118	0.029313	0.01245818	29.82%
2884	TPCODL	BBSR2	BAED	BALUGAON	ANKULAPADAR	14204	11 KV TOWN	14204201	ARAKHADIHA	2314DT107	100	MIXED	AMI	Yes	100%	98	0.0322688	0.024453	0.0078158	24.22%
2885	TPCODL	BBSR2	BAED	BALUGAON	ANKULAPADAR	14204	11 KV TOWN	14204201	MANECHHAPUR	2314DT117	100	MIXED	AMI	Yes	67%	47	0.01412518	0.011899	0.00222618	15.76%
2886	TPCODL	BBSR2	BAED	BALUGAON	ANKULAPADAR	14204	11 KV TOWN	14204201	BANCHANIDHIPUR	2314DT118	100	MIXED	AMI	Yes	100%	65	0.02275934	0.018118	0.00464134	20.39%
2887	TPCODL	BBSR2	BAED	BALUGAON	ANKULAPADAR	14204	11 KV TOWN	14204201	SAHASPUR	2314DT137	100	MIXED	AMI	Yes	33%	79	0.03194048	0.024654	0.00728648	22.81%
2888	TPCODL	BBSR2	BAED	BALUGAON	ANKULAPADAR	14204	11 KV TOWN	14204201	SAHASPUR	2314DT138	100	MIXED	AMI	Yes	67%	63	0.02879748	0.014408	0.01438948	49.97%
2889	TPCODL	BBSR2	BAED	BALUGAON	ANKULAPADAR	14204	11 KV TOWN	14204201	NUA SAHI BANTEI	2314DT142	100	MIXED	AMI	Yes	33%	91	0.05273664	0.027807	0.02492964	47.27%
2890	TPCODL	BBSR2	BAED	BALUGAON	ANKULAPADAR	14204	11 KV TOWN	14204201	GANGADHARPUR	2314DT151	100	MIXED	AMI	Yes	33%	56	0.0178925	0.010753	0.0071395	39.90%
2891	TPCODL	BBSR2	BAED	BALUGAON	ANKULAPADAR	14204	11 KV TOWN	14204201	BORI GAON	2314DT154	100	MIXED	AMI	Yes	33%	99	0.04562304	0.027835	0.01778804	38.99%
2892	TPCODL	BBSR2	BAED	BALUGAON	ANKULAPADAR	14204	11 KV TOWN	14204201	VETESWAR ROAD	2314DT155	100	MIXED	AMI	Yes	33%	85	0.0485614	0.036746	0.0118154	24.33%
2893	TPCODL	BBSR2	BAED	BALUGAON	ANKULAPADAR	14204	11 KV TOWN	14204201	VETESWAR	2314DT163	100	MIXED	AMI	Yes	100%	85	0.02843112	0.024071	0.00436012	15.34%
2894	TPCODL	BBSR2	BAED	BALUGAON	ANKULAPADAR	14204	11 KV TOWN	14204201	JENA SAHI	2314DT166	100	MIXED	AMI	Yes	100%	74	0.03558654	0.031605	0.00398154	11.19%
2895	TPCODL	BBSR2	BAED	BALUGAON	ANKULAPADAR	14204	11 KV TOWN	14204201	GUPTESHWAR	2314DT183	100	MIXED	AMI	Yes	33%	40	0.02240314	0.012621	0.00978214	43.66%
2896	TPCODL	BBSR2	BAED	BALUGAON	ANKULAPADAR	14204	11 KV TOWN	14204201	MUSLIM SAHI	2314DT185	250	MIXED	AMI	Yes	67%	149	0.12143684	0.10198	0.01945684	16.02%
2897	TPCODL	BBSR2	BAED	BALUGAON	ANKULAPADAR	14204	11 KV TOWN	14204201	PARK BAZAR	2314DT189	100	MIXED	AMI	Yes	100%	72	0.0993183	0.038092	0.0612263	61.65%
2898	TPCODL	BBSR2	BAED	BALUGAON	ANKULAPADAR	14204	11 KV TOWN	14204201	GALUA	2314DT198	100	MIXED	AMI	Yes	100%	103	0.0753482	0.044739	0.0306092	40.62%
2899	TPCODL	BBSR2	BAED	BALUGAON	ANKULAPADAR	14204	11 KV TOWN	14204201	BANLEI	2314DT199	100	MIXED	AMI	Yes	33%	71	0.02799026	0.021493	0.00649726	23.21%
2900	TPCODL	BBSR2	BAED	BALUGAON	ANKULAPADAR	14204	11 KV NILADRI	14204203	SANSIREIPUR	2314DT214	100	MIXED	AMI	Yes	100%	132	0.0609751	0.032546	0.0284291	46.62%
2901	TPCODL	BBSR2	BAED	BALUGAON	ANKULAPADAR	14204	11 KV PANCHUGAON	14204204	BHATAPADA	2315DT456	100	MIXED	AMI	Yes	100%	35	0.00956192	0.009443	0.00011892	1.24%
2902	TPCODL	BBSR2	BAED	BALUGAON	ANKULAPADAR	14204	11 KV PANCHUGAON	14204204	GAMBHARI MUNDA VILLAGE	2315DT471	100	MIXED	AMI	Yes	100%	54	0.04885386	0.020369	0.02848486	58.31%
2903	TPCODL	BBSR2	BAED	BALUGAON	ANKULAPADAR	14204	11 KV PANCHUGAON	14204204	PADAMPUR	2315DT473	100	MIXED	AMI	Yes	100%	112	0.05097548	0.048247	0.00272848	5.35%
2904	TPCODL	BBSR2	BAED	BALUGAON	ANKULAPADAR	14204	11 KV PANCHUGAON	14204204	PADAMPUR	2315DT474	200	MIXED	AMI	Yes	100%	170	0.09994184	0.068686	0.03125584	31.27%
2905	TPCODL	BBSR2	BAED	BALUGAON	ANKULAPADAR	14204	11 KV PANCHUGAON	14204204	TOTA	2315DT489	100	MIXED	AMI	Yes	0%	70	0.06353998	0.015805	0.04773498	75.13%
2906	TPCODL	BBSR2	BAED	BALUGAON	ANKULAPADAR	14204	11 KV PANCHUGAON	14204204	AYATPUR VILLAGE	2315DT495	200	MIXED	AMI	Yes	100%	179	0.0985146	0.058008	0.0405066	41.12%
2907	TPCODL	BBSR2	BAED	BALUGAON	ANKULAPADAR	14204	11 KV PANCHUGAON	14204204	DEOGAON	2315DT516	100	MIXED	AMI	Yes	100%	76	0.03842502	0.024203	0.01422202	37.01%
2908	TPCODL	BBSR2	BAED	BALUGAON	ANKULAPADAR	14204	11 KV PANCHUGAON	14204204	DEOGAON	2315DT517	100	MIXED	AMI	Yes	100%	115	0.0521579	0.043396	0.0087619	16.80%
2909	TPCODL	BBSR2	BAED	BALUGAON	ANKULAPADAR	14204	11 KV PANCHUGAON	14204204	PANKAL	2315DT537	100	MIXED	AMI	Yes	100%	119	0.03601354	0.029319	0.00669454	18.59%
2910	TPCODL	BBSR2	BAED	BALUGAON	ANKULAPADAR	14204	11 KV PANCHUGAON	14204204	KHAJURIA	2315DT568	100	MIXED	AMI	Yes	100%	10	0.02137712	0.009168	0.01220912	57.11%
2911	TPCODL	BBSR2	BAED	BALUGAON	ANKULAPADAR	14204	11 KV PANCHUGAON	14204204	OLIC	2315DT574	63	MIXED	AMI	Yes	100%	153	0.05298462	0.043432	0.00955262	18.03%
2912	TPCODL	BBSR2	BAED	BALUGAON	BALUGAON	14075	11 KV BALUGAON	14075201	RAMPUR SAHOO	2311DT031	100	MIXED	AMI	Yes	100%	77	0.0567413	0.046826	0.0099153	17.47%
2913	TPCODL	BBSR2	BAED	BALUGAON	BALUGAON	14075	11 KV BALUGAON	14075201	PATANA SAHI	2311DT033	250	MIXED	AMI	Yes	0%	243	0.22190152	0.152059	0.06984252	31.47%
2914	TPCODL	BBSR2	BAED	BALUGAON	BALUGAON	14075	11 KV BALUGAON	14075201	BISWAL SAHI	2311DT037	250	MIXED	AMI	Yes	33%	139	0.1291902	0.082184	0.0470062	36.39%
2915	TPCODL	BBSR2	BAED	BALUGAON	BALUGAON	14075	11 KV BALUGAON	14075201	KOUTA PAKHRI 1	2311DT046	250	MIXED	AMI	Yes	100%	270	0.1864056	0.123095	0.0633106	33.96%
2916	TPCODL	BBSR2	BAED	BALUGAON	BALUGAON	14075	11 KV BALUGAON	14075201	SRI RAM NAGAR	2311DT057	100	MIXED	AMI	Yes	100%	74	0.03958944	0.032286	0.00730344	18.45%
2917	TPCODL	BBSR2	BAED	BALUGAON	BALUGAON	14075	11 KV BALUGAON	14075201	SUJA NAGAR	2311DT059	100	MIXED	AMI	Yes	67%	136	0.08884336	0.082968	0.00587536	6.61%
2918	TPCODL	BBSR2	BAED	BALUGAON	BALUGAON	14075	11 KV BALUGAON	14075201	GANDHI NAGAR 2	2311DT063	100	MIXED	AMI	Yes	100%	53	0.03076774	0.023926	0.00684174	22.24%
2919	TPCODL	BBSR2	BAED	BALUGAON	BALUGAON	14075	11 KV BALUGAON	14075201	SAMANTRAPUR	2311DT067	250	MIXED	AMI	Yes	100%	132	0.0937726	0.07852	0.0152526	16.27%

Sl. No.	Zone Name	Circle name	Division name	Name of the Sub-division	Name of the Sub-station	Substation Code	Name of the 11 kV Feeder	Feeder Code	Name of the Location where DT situated	DT code	DT Capacity (kVA)	Predominant consumer type of DT (Domestic/Industrial/Agriculture/Mixed)	Type of metering AMR/AMI/ Communicable/Conventional metered/Unmetered	Status of Meter-whether Functional (Yes/No)	% of data received automatically (if AMR/AMI)	No. of Connected Consumers	Input Energy (MU) (A)	Billed Energy (MU) (B)	Loss (MU) (A-B)	% DT Loss (A-B)/A
2920	TPCODL	BBSR2	BAED	BALUGAON	BALUGAON	14075	11 KV BALUGAON	14075201	SANYASI NAGAR	2311DT076	100	MIXED	AMI	Yes	0%	30	0.02051902	0.008846	0.01167302	56.89%
2921	TPCODL	BBSR2	BAED	BALUGAON	BALUGAON	14075	11 KV BALUGAON	14075201	MARIENE	2311DT091	500	MIXED	AMI	Yes	100%	358	0.34355376	0.327157	0.01639676	4.77%
2922	TPCODL	BBSR2	BAED	BALUGAON	BALUGAON	14075	11 KV BALUGAON	14075201	BHILURI	2312DT118	100	MIXED	AMI	Yes	67%	81	0.04096208	0.02845	0.01251208	30.55%
2923	TPCODL	BBSR2	BAED	BALUGAON	BALUGAON	14075	11 KV BALUGAON	14075201	INJANPUR 1	2312DT119	100	MIXED	AMI	Yes	67%	70	0.0279936	0.026018	0.0019756	7.06%
2924	TPCODL	BBSR2	BAED	BALUGAON	BALUGAON	14075	11 KV BALUGAON	14075201	CHHEDAPUR 1	2312DT127	100	MIXED	AMI	Yes	33%	109	0.06099562	0.038051	0.02294462	37.62%
2925	TPCODL	BBSR2	BAED	BALUGAON	BALUGAON	14075	11 KV BALUGAON	14075201	CHANDRAPUT ATHARA BATIA 3	2312DT136	100	MIXED	AMI	Yes	0%	130	0.03394026	0.022897	0.01104326	32.54%
2926	TPCODL	BBSR2	BAED	BALUGAON	BALUGAON	14075	11 KV BALUGAON	14075201	BADKUL 5	2312DT161	100	MIXED	AMI	Yes	100%	163	0.06429246	0.055429	0.00886346	13.79%
2927	TPCODL	BBSR2	BAED	BALUGAON	BALUGAON	14075	11 KV BALUGAON	14075201	BADKUL KUNDA SAHI	2312DT165	100	MIXED	AMI	Yes	67%	83	0.02961206	0.019717	0.00989506	33.42%
2928	TPCODL	BBSR2	BAED	BALUGAON	BALUGAON	14075	11 KV BALUGAON	14075201	PANTHA NIWAS ROAD	2312DT169	100	MIXED	AMI	Yes	67%	88	0.06244582	0.051552	0.01089382	17.45%
2929	TPCODL	BBSR2	BAED	BALUGAON	BALUGAON	14075	11 KV BALUGAON	14075201	PANTHA NIWAS	2312DT170	100	MIXED	AMI	Yes	67%	32	0.03939316	0.020354	0.01903916	48.33%
2930	TPCODL	BBSR2	BAED	BALUGAON	BALUGAON	14075	11 KV BALUGAON	14075201	KHARIBANDHA 1	2312DT180	100	MIXED	AMI	Yes	0%	78	0.05383676	0.016439	0.03739776	69.47%
2931	TPCODL	BBSR2	BAED	BALUGAON	BALUGAON	14075	11 KV BALUGAON	14075201	CHHATRAGARH 2	2312DT193	100	MIXED	AMI	Yes	67%	142	0.07241938	0.03666	0.03575938	49.38%
2932	TPCODL	BBSR2	BAED	BALUGAON	BALUGAON	14075	11 KV BANPUR-1	14075202	GOPINATHPUR PURNA SAHI	2311DT096	100	MIXED	AMI	Yes	100%	87	0.0626998	0.046613	0.0160868	25.66%
2933	TPCODL	BBSR2	BAED	BALUGAON	BALUGAON	14075	11 KV BANPUR-1	14075202	ALADIHA	2311DT101	100	MIXED	AMI	Yes	100%	57	0.04287548	0.021638	0.02123748	49.53%
2934	TPCODL	BBSR2	BAED	BALUGAON	BALUGAON	14075	11 KV BANPUR-1	14075202	RE	2311DT107	100	MIXED	AMI	Yes	100%	11	0.05926606	0.041294	0.01797206	30.32%
2935	TPCODL	BBSR2	BAED	BALUGAON	BALUGAON	14075	11 KV BANPUR-1	14075202	BHESRI	2311DT122	100	MIXED	AMI	Yes	100%	73	0.06514936	0.030241	0.03490836	53.58%
2936	TPCODL	BBSR2	BAED	BALUGAON	BALUGAON	14075	11 KV BANPUR-1	14075202	NIMIKETA	2311DT130	250	MIXED	AMI	Yes	100%	156	0.08093068	0.066134	0.01479668	18.28%
2937	TPCODL	BBSR2	BAED	BALUGAON	BALUGAON	14075	11 KV BANPUR-1	14075202	NIMIKETA (SAITEMPLE)	2311DT133	100	MIXED	AMI	Yes	100%	119	0.0647835	0.045818	0.0189655	29.28%
2938	TPCODL	BBSR2	BAED	BALUGAON	BALUGAON	14075	11 KV BANPUR-1	14075202	BISUNDI	2312DT201	100	MIXED	AMI	Yes	67%	92	0.0451051	0.026994	0.0181111	40.15%
2939	TPCODL	BBSR2	BAED	BALUGAON	BALUGAON	14075	11 KV BANPUR-1	14075202	DHUANLO	2312DT212	100	MIXED	AMI	Yes	67%	188	0.06267102	0.055728	0.00694302	11.08%
2940	TPCODL	BBSR2	BAED	BALUGAON	BALUGAON	14075	11 KV BANPUR-1	14075202	K ANKULA	2312DT265	100	MIXED	AMI	Yes	67%	107	0.03988094	0.035335	0.00454594	11.40%
2941	TPCODL	BBSR2	BAED	BALUGAON	BALUGAON	14075	11 KV BANPUR-1	14075202	K ANKULA	2312DT266	100	MIXED	AMI	Yes	67%	33	0.01778406	0.009076	0.00870806	48.97%
2942	TPCODL	BBSR2	BAED	BALUGAON	BALUGAON	14075	11 KV BANPUR-1	14075202	NIMAIMALL	2312DT272	100	MIXED	AMI	Yes	67%	107	0.04442666	0.029492	0.01493466	33.62%
2943	TPCODL	BBSR2	BAED	BALUGAON	BALUGAON	14075	11 KV BANPUR-1	14075202	RAUTRA PALI	2312DT278	63	MIXED	AMI	Yes	67%	48	0.02992464	0.018331	0.01159364	38.74%
2944	TPCODL	BBSR2	BAED	BALUGAON	BALUGAON	14075	11 KV BANPUR-1	14075202	BOURI SAHI	2312DT288	100	MIXED	AMI	Yes	67%	65	0.02794204	0.017931	0.01001104	35.83%
2945	TPCODL	BBSR2	BAED	BALUGAON	BALUGAON	14075	11 KV BANPUR-1	14075202	RAJPALE	2312DT294	100	MIXED	AMI	Yes	67%	108	0.05892176	0.031922	0.02699976	45.82%
2946	TPCODL	BBSR2	BAED	BALUGAON	BALUGAON	14075	11 KV BANPUR-1	14075202	NUAGARH	2312DT313	100	MIXED	AMI	Yes	100%	80	0.021211	0.020685	0.000526	2.48%
2947	TPCODL	BBSR2	BAED	BALUGAON	BALUGAON	14075	11 KV BANPUR-1	14075202	KHADANT	2312DT314	100	MIXED	AMI	Yes	100%	102	0.04380729	0.031327	0.01248029	28.49%
2948	TPCODL	BBSR2	BAED	BALUGAON	BALUGAON	14075	11 KV BANPUR-1	14075202	PARIKANSARI	2312DT323	100	MIXED	AMI	Yes	67%	54	0.02488134	0.019884	0.00499734	20.08%
2949	TPCODL	BBSR2	BAED	BALUGAON	BALUGAON	14075	11 KV BANPUR-1	14075202	KOTARI	2312DT328	100	MIXED	AMI	Yes	67%	49	0.06758438	0.018129	0.04945538	73.18%
2950	TPCODL	BBSR2	BAED	BALUGAON	BALUGAON	14075	11 KV BANPUR-1	14075202	PARIK ANSARI	2312DT331	100	MIXED	AMI	Yes	100%	100	0.04625546	0.033293	0.01296246	28.02%
2951	TPCODL	BBSR2	BAED	BALUGAON	BALUGAON	14075	11 KV BANPUR-1	14075202	PAIKOSADI	2312DT338	100	MIXED	AMI	Yes	100%	39	0.0270134	0.017776	0.0092374	34.20%
2952	TPCODL	BBSR2	BAED	BALUGAON	BALUGAON	14075	11 KV BANPUR-1	14075202	BRAHAMAN KOSADI	2312DT351	100	MIXED	AMI	Yes	33%	71	0.03853018	0.021329	0.01720118	44.64%
2953	TPCODL	BBSR2	BAED	BALUGAON	BALUGAON	14075	11 KV BANPUR-1	14075202	BALIPADAR	2313DT022	100	MIXED	AMI	Yes	67%	117	0.05464813	0.040118	0.01453013	26.59%
2954	TPCODL	BBSR2	BAED	BALUGAON	BALUGAON	14075	11 KV BANPUR-1	14075202	RANAKNATH PATARA NUAGAON	2313DT024	100	MIXED	AMI	Yes	100%	56	0.02677318	0.019129	0.00764418	28.55%
2955	TPCODL	BBSR2	BAED	BALUGAON	BALUGAON	14075	11 KV BANPUR-2	14075203	GOPINATHPUR ROAD	2311DT136	100	MIXED	AMI	Yes	100%	158	0.09749516	0.08369	0.01380516	14.16%
2956	TPCODL	BBSR2	BAED	BALUGAON	BALUGAON	14075	11 KV BANPUR-2	14075203	PADANPUR	2311DT141	100	MIXED	AMI	Yes	100%	111	0.08609872	0.052653	0.03344572	38.85%
2957	TPCODL	BBSR2	BAED	BALUGAON	BALUGAON	14075	11 KV BANPUR-2	14075203	BHARAT NAGAR	2311DT143	63	MIXED	AMI	Yes	100%	124	0.08221526	0.064374	0.01784126	21.70%
2958	TPCODL	BBSR2	BAED	BALUGAON	BALUGAON	14075	11 KV BANPUR-2	14075203	ALADI CHHAK	2311DT145	100	MIXED	AMI	Yes	100%	122	0.07335764	0.052085	0.02127264	29.00%
2959	TPCODL	BBSR2	BAED	BALUGAON	BALUGAON	14075	11 KV BANPUR-2	14075203	ANTRAKIYARI	2311DT148	250	MIXED	AMI	Yes	100%	213	0.11733224	0.089962	0.02737024	23.33%
2960	TPCODL	BBSR2	BAED	BALUGAON	BALUGAON	14075	11 KV BANPUR-2	14075203	DANDAGARIA	2312DT369	100	MIXED	AMI	Yes	33%	101	0.04067708	0.024767	0.01591008	39.11%
2961	TPCODL	BBSR2	BAED	BALUGAON	BALUGAON	14075	11 KV BANPUR-2	14075203	MEDICAL	2313DT065	250	MIXED	AMI	Yes	100%	79	0.1269642	0.036583	0.0903812	71.19%
2962	TPCODL	BBSR2	BAED	BALUGAON	BALUGAON	14075	11 KV BANPUR-2	14075203	DASHRATHPUR	2313DT070	100	MIXED	AMI	Yes	0%	108	0.04483248	0.039435	0.00539748	12.04%
2963	TPCODL	BBSR2	BAED	BALUGAON	BALUGAON	14075	11 KV BANPUR-2	14075203	PANDRI PADAR	2313DT093	100	MIXED	AMI	Yes	0%	63	0.04332287	0.032387	0.01093587	25.24%
2964	TPCODL	BBSR2	BAED	BALUGAON	BALUGAON	14075	11 KV BANPUR-2	14075203	GODI PADAR BIDHAR	2313DT095	100	MIXED	AMI	Yes	100%	156	0.0884633	0.070876	0.0175873	19.88%
2965	TPCODL	BBSR2	BAED	BALUGAON	BALUGAON	14075	11 KV BANPUR-2	14075203	PAIKSAHI	2313DT097	100	MIXED	AMI	Yes	100%	49	0.0484639	0.035616	0.0128479	26.51%
2966	TPCODL	BBSR2	BAED	BALUGAON	BALUGAON	14075	11 KV BANPUR-2	14075203	MUKTA DEIPUR	2313DT123	100	MIXED	AMI	Yes	0%	115	0.0396641	0.034186	0.0054781	13.81%
2967	TPCODL	BBSR2	BAED	BALUGAON	BALUGAON	14075	11 KV BANPUR-2	14075203	BALADI	2313DT138	100	MIXED	AMI	Yes	67%	219	0.07598464	0.055631	0.02035364	26.79%
2968	TPCODL	BBSR2	BAED	BALUGAON	BALUGAON	14075	11 KV BANPUR-2	14075203	TUMBRA PVT	2313DT143	100	MIXED	AMI	Yes	100%	102	0.02913151	0.024477	0.00465451	15.98%
2969	TPCODL	BBSR2	BAED	BALUGAON	BALUGAON	14075	11 KV BANPUR-2	14075203	PRATAP	2313DT161	100	MIXED	AMI	Yes	67%	88	0.0336163	0.021822	0.0117943	35.09%
2970	TPCODL	BBSR2	BAED	BALUGAON	BALUGAON	14075	11 KV BANPUR-2	14075203	PRATAP	2313DT162	100	MIXED	AMI	Yes	100%	161	0.06303696	0.050867	0.01216996	19.31%
2971	TPCODL	BBSR2	BAED	BALUGAON	BALUGAON	14075	11 KV BANPUR-2	14075203	PRATAP	2313DT166	100	MIXED	AMI	Yes	67%	123	0.03249886	0.026065	0.00643386	19.80%
2972	TPCODL	BBSR2	BAED	BALUGAON	BALUGAON	14075	11 KV BANPUR-2	14075203	LATHIPADA	2313DT224	100	MIXED	AMI	Yes	67%	67	0.0112655	0.00912	0.0021455	19.04%
2973	TPCODL	BBSR2	BAED	BALUGAON	BALUGAON	14075	11 KV BANPUR-2	14075203	PUNJIRAMA SASAN	2313DT231	100	MIXED	AMI	Yes	67%	97	0.0537477	0.043623	0.0101247	18.84%
2974	TPCODL	BBSR2	BAED	BALUGAON	BALUGAON	14075	11 KV BANPUR-2	14075203	KUMARANG ROAD	2313DT255	100	MIXED	AMI	Yes	67%	49	0.02816716	0.021767	0.00640016	22.72%
2975	TPCODL	BBSR2	BAED	BALUGAON	BALUGAON	14075	11 KV BANPUR-2	14075203	GADA SAHI	2313DT270	100	MIXED	AMI	Yes	0%	158	0.09804932	0.087749	0.01030032	10.51%
2976	TPCODL	BBSR2	BAED	BALUGAON	BALUGAON	14075	11 KV BANPUR-2	14075203	MALI GOBINDPUR	2313DT279	100	MIXED	AMI	Yes	100%	96	0.03473404	0.027218	0.00751604	21.64%
2977	TPCODL	BBSR2	BAED	BALUGAON	BALUGAON	14075	11 KV BANPUR-2	14075203	EKDALIA	2313DT282	100	MIXED	AMI	Yes	67%	89	0.03978476	0.030008	0.00977676	24.57%
2978	TPCODL	BBSR2	BAED	BALUGAON	BALUGAON	14075	11 KV BANPUR-2	14075203	DULANI	2313DT285	100	MIXED	AMI	Yes	67%	127	0.0435199	0.036553	0.0069669	16.01%
2979	TPCODL	BBSR2	BAED	BALUGAON	BALUGAON	14075	11 KV BANPUR-2	14075203	RANKNATH PATANA	2313DT299	250	MIXED	AMI	Yes	100%	97	0.20864525	0.078016	0.13062925	62.61%
2980	TPCODL	BBSR2	BAED	BALUGAON	BALUGAON	14075	11 KV SINGHESWAR	14075204	ASHOK NAGAR LANE 1	2311DT001	250	MIXED	AMI	Yes	100%	92	0.08705158	0.054671	0.03238058	37.20%
2981	TPCODL	BBSR2	BAED	BALUGAON	BALUGAON	14075	11 KV SINGHESWAR	14075204	BALUGAON SUB STATION	2311DT002	250	MIXED	AMI	Yes	0%	203	0.18246924	0.121543	0.06092624	33.39%
2982	TPCODL	BBSR2	BAED	BALUGAON	BALUGAON	14075	11 KV SINGHESWAR	14075204	ASHOK NAGAR LANE 1	2311DT003	200	MIXED	AMI	Yes	100%	75	0.06346834	0.038549	0.02491934	39.26%
2983	TPCODL	BBSR2	BAED	BALUGAON	BALUGAON	14075	11 KV SINGHESWAR	14075204	SARALA PADAR	2311DT004	250	MIXED	AMI	Yes	100%	228	0.19300692	0.08841	0.10459692	54.19%
2984	TPCODL	BBSR2	BAED	BALUGAON	BALUGAON	14075	11 KV SINGHESWAR	14075204	GHUMUSARA PADAR	2311DT012	100	MIXED	AMI	Yes	100%	83	0.04607516	0.033863	0.01221216	26.50%
2985	TPCODL	BBSR2	BAED	BALUGAON	BALUGAON	14075	11 KV SINGHESWAR	14075204	GHIKHALA1	2311DT018	100	MIXED	AMI	Yes	100%	74	0.07452532	0.029474	0.04505132	60.45%
2986	TPCODL	BBSR2	BAED	BALUGAON	BALUGAON	14075	11 KV SINGHESWAR	14075204	GOBARDHANPUR	2312DT003	100	MIXED	AMI	Yes	100%	140	0.07654452	0.046933	0.02961152	38.69%
2987	TPCODL	BBSR2	BAED	BALUGAON	BALUGAON	14075	11 KV SINGHESWAR	14075204	LAMBO DHAR PUR 1	2312DT010	100	MIXED	AMI	Yes	0%	48	0.02435872	0.01381	0.01054872	43.31%
2988	TPCODL	BBSR2	BAED	BALUGAON	BALUGAON	14075	11 KV SINGHESWAR	14075204	KIMBHIRI PADA 2	2312DT014	100	MIXED	AMI	Yes	100%	83	0.06256236	0.031483	0.03107936	49.68%
2989	TPCODL	BBSR2	BAED	BALUGAON	BALUGAON	14075	11 KV SINGHESWAR	14075204	BANKIA PALLI2	2312DT025	100	MIXED	AMI	Yes	100%	84	0.01783366	0.014076	0.00375766	21.07%
2990	TPCODL	BBSR2	BAED	BALUGAON	BALUGAON	14075	11 KV SINGHESWAR	14075204	ANKULA CHATTI2	2312DT036	100	MIXED	AMI	Yes	100%	73	0.05712808	0.016609	0.04051908	70.93%
2991	TPCODL	BBSR2	BAED	BALUGAON	BALUGAON	14075	11 KV SINGHESWAR	14075204	KHETRA PALA REHAN BALLI 2	2312DT048	100	MIXED	AMI	Yes	67%	45	0.03457698	0.009677	0.02489998	72.01%
2992	TPCODL	BBSR2	BAED	BALUGAON	BALUGAON	14075	11 KV SINGHESWAR	14075204	SAMANT SINGHARPUR 1	2312DT051	100	MIXED	AMI	Yes	67%	60	0.02522542	0.020105	0.00512042	20.30%

Sl. No.	Zone Name	Circle name	Division name	Name of the Sub-division	Name of the Sub-station	Substation Code	Name of the 11 kV Feeder	Feeder Code	Name of the Location where DT situated	DT code	DT Capacity (kVA)	Predominant consumer type of DT (Domestic/Industrial/Agriculture/Mixed)	Type of metering AMR/AMI/ Communicable/Conventional metered/Unmetered	Status of Meter-whether Functional (Yes/No)	% of data received automatically (if AMR/AMI)	No. of Connected Consumers	Input Energy (MU) (A)	Billed Energy (MU) (B)	Loss (MU) (A-B)	% DT Loss (A-B)/A
2993	TPCODL	BBSR2	BAED	BALUGAON	BALUGAON	14075	11 KV SINGHESWAR	14075204	RAHAN BALLI 2	2312DT054	100	MIXED	AMI	Yes	67%	38	0.03953468	0.008154	0.03138068	79.38%
2994	TPCODL	BBSR2	BAED	BALUGAON	BALUGAON	14075	11 KV SINGHESWAR	14075204	RAHAN BALLI 3	2312DT056	100	MIXED	AMI	Yes	100%	26	0.02811816	0.008567	0.01955116	69.53%
2995	TPCODL	BBSR2	BAED	BALUGAON	BALUGAON	14075	11 KV SINGHESWAR	14075204	KARADI1	2312DT075	100	MIXED	AMI	Yes	67%	100	0.05863996	0.028212	0.03042796	51.89%
2996	TPCODL	BBSR2	BAED	BALUGAON	GANGADHARAPUR	14286	11 KV HATABARADI	14286201	HARIPUR MILLSAHI1	2315DT330	100	MIXED	AMI	Yes	0%	26	0.03050124	0.011426	0.01907524	62.54%
2997	TPCODL	BBSR2	BAED	BALUGAON	GANGADHARAPUR	14286	11 KV HATABARADI	14286201	NUA PATMA GODI SAHI	2315DT343	100	MIXED	AMI	Yes	67%	30	0.0132811	0.008633	0.0046481	35.00%
2998	TPCODL	BBSR2	BAED	BALUGAON	GANGADHARAPUR	14286	11 KV HATABARADI	14286201	BEGUNIA 2	2315DT345	250	MIXED	AMI	Yes	33%	97	0.03906876	0.025336	0.01373276	35.15%
2999	TPCODL	BBSR2	BAED	BALUGAON	GANGADHARAPUR	14286	11 KV HATABARADI	14286201	HATTA BARADI PANCHAYAT	2315DT377	100	MIXED	AMI	Yes	67%	129	0.08003782	0.037268	0.04276982	53.44%
3000	TPCODL	BBSR2	BAED	BALUGAON	GANGADHARAPUR	14286	11 KV HATABARADI	14286201	SANDHA SAHI HATTA BARADI	2315DT385	100	MIXED	AMI	Yes	67%	52	0.05225448	0.01718	0.03507448	67.12%
3001	TPCODL	BBSR2	BAED	BALUGAON	GANGADHARAPUR	14286	11 KV HATABARADI	14286201	NAHA SAHI MILL HATTA BARADI	2315DT387	100	MIXED	AMI	Yes	67%	49	0.02310398	0.013223	0.00988098	42.77%
3002	TPCODL	BBSR2	BAED	BALUGAON	GANGADHARAPUR	14286	11 KV HATABARADI	14286201	JAYANTPUR SAHI	2315DT411	100	MIXED	AMI	Yes	100%	112	0.03565828	0.029614	0.00604428	16.95%
3003	TPCODL	BBSR2	BAED	BALUGAON	GANGADHARAPUR	14286	11 KV HATABARADI	14286201	HARIPUR 250 KV	2315DT432	250	MIXED	AMI	Yes	100%	132	0.14529728	0.042156	0.10314128	70.99%
3004	TPCODL	BBSR2	BAED	BALUGAON	GANGADHARAPUR	14286	11 KV BAULABANDHA	14286202	BRAHAMAN SAHI TALA BAULABANDH	2315DT263	250	MIXED	AMI	Yes	67%	143	0.06875148	0.042088	0.02666348	38.78%
3005	TPCODL	BBSR2	BAED	BALUGAON	GANGADHARAPUR	14286	11 KV BAULABANDHA	14286202	BALU BANDA SAHI KHARUDA SAHI1	2315DT268	250	MIXED	AMI	Yes	67%	214	0.07229728	0.070119	0.00217828	3.01%
3006	TPCODL	BBSR2	BAED	BALUGAON	GANGADHARAPUR	14286	11 KV BAULABANDHA	14286202	BADA NAIRI	2315DT292	100	MIXED	AMI	Yes	100%	136	0.04939557	0.039569	0.00982657	19.89%
3007	TPCODL	BBSR2	BAED	BALUGAON	GANGADHARAPUR	14286	11 KV BAULABANDHA	14286202	NAIRI BADA SAHI(NEAR RASING CLUB	2315DT323	200	MIXED	AMI	Yes	0%	203	0.09872144	0.094467	0.00425444	4.31%
3008	TPCODL	BBSR2	BAED	BALUGAON	GANGADHARAPUR	14286	11 KV BAULABANDHA	14286202	CHHATRAY PUR VILLAGE1	2315DT327	100	MIXED	AMI	Yes	67%	82	0.06030196	0.032603	0.02769896	45.93%
3009	TPCODL	BBSR2	BAED	BALUGAON	NACHUNI	14078	11 KV KAITHAPALLA	14078201	COLLEGE ROAD	2315DT141	100	MIXED	AMI	Yes	100%	145	0.0759854	0.067563	0.0084224	11.08%
3010	TPCODL	BBSR2	BAED	BALUGAON	NACHUNI	14078	11 KV KAITHAPALLA	14078201	KAITHA PALLA NUA SAHI	2315DT189	100	MIXED	AMI	Yes	67%	134	0.05246832	0.043105	0.00936332	17.85%
3011	TPCODL	BBSR2	BAED	BALUGAON	NACHUNI	14078	11 KV KAITHAPALLA	14078201	BIRIBARI NUA SAHI	2315DT191	63	MIXED	AMI	Yes	100%	113	0.04944481	0.029962	0.01948281	39.40%
3012	TPCODL	BBSR2	BAED	BALUGAON	NACHUNI	14078	11 KV GAMBHARIMUND	14078202	NAYAKOTA 3	2315DT008	100	MIXED	AMI	Yes	67%	57	0.04055498	0.017886	0.02266898	55.90%
3013	TPCODL	BBSR2	BAED	BALUGAON	NACHUNI	14078	11 KV GAMBHARIMUND	14078202	JAGABANDHUPUR	2315DT030	100	MIXED	AMI	Yes	67%	98	0.0665994	0.034573	0.0320264	48.09%
3014	TPCODL	BBSR2	BAED	BALUGAON	NACHUNI	14078	11 KV GAMBHARIMUND	14078202	AMBAJARA 6	2315DT033	100	MIXED	AMI	Yes	67%	43	0.01556772	0.012952	0.00261572	16.80%
3015	TPCODL	BBSR2	BAED	BALUGAON	NACHUNI	14078	11 KV GAMBHARIMUND	14078202	AMBAJHAR 7	2315DT042	100	MIXED	AMI	Yes	67%	40	0.02355884	0.012984	0.01057484	44.89%
3016	TPCODL	BBSR2	BAED	BALUGAON	NACHUNI	14078	11 KV GAMBHARIMUND	14078202	KULEI 2	2315DT065	100	MIXED	AMI	Yes	33%	136	0.07298624	0.046334	0.02665224	36.52%
3017	TPCODL	BBSR2	BAED	BALUGAON	NACHUNI	14078	11 KV GAMBHARIMUND	14078202	SUNAKHELA 3	2315DT097	100	MIXED	AMI	Yes	67%	97	0.04868434	0.030897	0.01778734	36.54%
3018	TPCODL	BBSR2	BAED	BALUGAON	NACHUNI	14078	11 KV GAMBHARIMUND	14078202	H K BARADI 3	2315DT121	100	MIXED	AMI	Yes	0%	182	0.09689357	0.0606007	0.03629287	37.46%
3019	TPCODL	BBSR2	BAED	BALUGAON	NACHUNI	14078	11 KV GAMBHARIMUND	14078202	H K BARADI 4	2315DT123	100	MIXED	AMI	Yes	100%	185	0.07200842	0.056829	0.01517942	21.08%
3020	TPCODL	BBSR2	BAED	BALUGAON	NACHUNI	14078	11 KV NAIRI	14078203	NACHUNI 5	2315DT221	100	MIXED	AMI	Yes	100%	54	0.09884218	0.039175	0.05966718	60.37%
3021	TPCODL	BBSR2	BAED	BALUGAON	NACHUNI	14078	11 KV NAIRI	14078203	NACHUNI 4	2315DT222	100	MIXED	AMI	Yes	100%	140	0.08080092	0.06169	0.01911092	23.65%
3022	TPCODL	BBSR2	BAED	BALUGAON	NACHUNI	14078	11 KV NAIRI	14078203	NACHUNI (BAZAR) 1	2315DT227	100	MIXED	AMI	Yes	100%	97	0.11525612	0.048985	0.06627112	57.50%
3023	TPCODL	BBSR2	BAED	BALUGAON	NACHUNI	14078	11 KV NAIRI	14078203	BADAPADAR 1	2315DT229	100	MIXED	AMI	Yes	100%	124	0.09199154	0.04270707	0.04928447	53.58%
3024	TPCODL	BBSR2	BAED	BALUGAON	NACHUNI	14078	11 KV NAIRI	14078203	GANGADHARPUR	2315DT243	100	MIXED	AMI	Yes	67%	52	0.01874782	0.017054	0.00169382	9.03%
3025	TPCODL	BBSR2	BAED	BALUGAON	NACHUNI	14078	11 KV NAIRI	14078203	BLOCK	2315DT251	100	MIXED	AMI	Yes	100%	37	0.05010862	0.026582	0.02352662	46.95%
3026	TPCODL	BBSR2	BAED	BALUGAON	RAJANAGAR	14160	11 KV KEREDAGADA	14160203	SHIV MANDIR EKMANIA	5141DT173	100	MIXED	AMI	Yes	67%	124	0.04827696	0.033184	0.01509296	31.26%
3027	TPCODL	BBSR2	BAED	BALUGAON	RANAPUR	14077	11 KV HANSARA	14077204	ICCHAPUR 23	2323DT534	63	MIXED	AMI	Yes	0%	32	0.01719866	0.008989	0.00820966	47.73%
3028	TPCODL	BBSR2	BAED	TANGI	NAYAGARH	17011	33 kV RANAPUR	17011401	33/11 KV DARPANARAYANPUR (TANG	2323DT901	100	MIXED	AMI	Yes	100%	1	0.0012676	0.001267	6E-07	0.05%
3029	TPCODL	BBSR2	BAED	TANGI	CHANDPUR	17016	33 kV TANGICHANDPUR	17016402	BADAPARI	2324DT901	100	MIXED	AMI	Yes	100%	185	0.14251084	0.071134	0.07137684	50.09%
3030	TPCODL	BBSR2	BAED	TANGI	BHUSANDAPUR	14206	11 KV BHUSANDAPUR	14206201	UJALA GOPINATHPUR 2	2321DT130	100	MIXED	AMI	Yes	100%	102	0.0488874	0.030179	0.0187084	38.27%
3031	TPCODL	BBSR2	BAED	TANGI	BHUSANDAPUR	14206	11 KV BHUSANDAPUR	14206201	JHANSI PATANA RAM MANDIR	2321DT156	100	MIXED	AMI	Yes	100%	81	0.03496484	0.02339	0.01157484	33.10%
3032	TPCODL	BBSR2	BAED	TANGI	BHUSANDAPUR	14206	11 KV BHUSANDAPUR	14206201	GEDEISUNE PATANA 2	2321DT158	100	MIXED	AMI	Yes	100%	63	0.0250034	0.017568	0.0074354	29.74%
3033	TPCODL	BBSR2	BAED	TANGI	BHUSANDAPUR	14206	11 KV BHUSANDAPUR	14206201	BALI PATPUR COLONY 1	2321DT162	100	MIXED	AMI	Yes	100%	100	0.06422622	0.027568	0.03665822	57.08%
3034	TPCODL	BBSR2	BAED	TANGI	BHUSANDAPUR	14206	11 KV BHUSANDAPUR	14206201	BALI PATPUR COLONY 7	2321DT163	100	MIXED	AMI	Yes	100%	189	0.06771812	0.057686	0.01003212	14.81%
3035	TPCODL	BBSR2	BAED	TANGI	BHUSANDAPUR	14206	11 KV BHUSANDAPUR	14206201	CHANDANSAHI AND DAWALA SAHI 1	2321DT175	100	MIXED	AMI	Yes	100%	121	0.06101248	0.050441	0.01057148	17.33%
3036	TPCODL	BBSR2	BAED	TANGI	BHUSANDAPUR	14206	11 KV BHUSANDAPUR	14206201	KUSUMI ROUT PADA 2	2321DT182	100	MIXED	AMI	Yes	67%	46	0.06193038	0.018715	0.04321538	69.78%
3037	TPCODL	BBSR2	BAED	TANGI	BHUSANDAPUR	14206	11 KV BHUSANDAPUR	14206201	MORMOR SINGH 2	2321DT193	100	MIXED	AMI	Yes	33%	44	0.02192117	0.012087	0.00983417	44.86%
3038	TPCODL	BBSR2	BAED	TANGI	BHUSANDAPUR	14206	11 KV BHUSANDAPUR	14206201	BALI PATPUR PANCHAYAT 2	2321DT198	100	MIXED	AMI	Yes	100%	157	0.06486884	0.04869	0.01617884	24.94%
3039	TPCODL	BBSR2	BAED	TANGI	BHUSANDAPUR	14206	11 KV BHUSANDAPUR	14206201	BALI PATPUR PANCHAYAT 1	2321DT199	100	MIXED	AMI	Yes	100%	157	0.07400638	0.051254	0.02275238	30.74%
3040	TPCODL	BBSR2	BAED	TANGI	BHUSANDAPUR	14206	11 KV BHUSANDAPUR	14206201	BIDHARPUR 2	2321DT233	100	MIXED	AMI	Yes	0%	119	0.03407512	0.033406	0.00066912	1.96%
3041	TPCODL	BBSR2	BAED	TANGI	BHUSANDAPUR	14206	11 KV BHUSANDAPUR	14206201	JAGANNATHPUR 2	2321DT239	100	MIXED	AMI	Yes	100%	82	0.05207978	0.026662	0.02541778	48.81%
3042	TPCODL	BBSR2	BAED	TANGI	BHUSANDAPUR	14206	11 KV HARIPUR	14206202	UGRA TARA TEMPLE	2321DT072	100	MIXED	AMI	Yes	100%	33	0.04995573	0.025965	0.02399073	48.02%
3043	TPCODL	BBSR2	BAED	TANGI	BHUSANDAPUR	14206	11 KV HARIPUR	14206202	MULIJHARA	2321DT081	250	MIXED	AMI	Yes	100%	105	0.10183301	0.060726	0.04110701	40.37%
3044	TPCODL	BBSR2	BAED	TANGI	BHUSANDAPUR	14206	11 KV HARIPUR	14206202	HARIPURBATASAHI1	2321DT092	100	MIXED	AMI	Yes	100%	83	0.06913112	0.025777	0.04335412	62.71%
3045	TPCODL	BBSR2	BAED	TANGI	BHUSANDAPUR	14206	11 KV HARIPUR	14206202	HARIPUR3	2321DT093	100	MIXED	AMI	Yes	100%	95	0.05072722	0.03654	0.01418722	27.97%
3046	TPCODL	BBSR2	BAED	TANGI	BHUSANDAPUR	14206	11 KV HARIPUR	14206202	HARIPUR PATNA	2321DT102	100	MIXED	AMI	Yes	100%	61	0.04753818	0.019835	0.02770318	58.28%
3047	TPCODL	BBSR2	BAED	TANGI	CHANDPUR	14185	11 KV KAMAGURU	14185201	DHABA	2325DT006	100	MIXED	AMI	Yes	67%	28	0.0281508	0.016454	0.0116968	41.55%
3048	TPCODL	BBSR2	BAED	TANGI	CHANDPUR	14185	11 KV KAMAGURU	14185201	MUKHAPUR RWSS3	2325DT018	100	MIXED	AMI	Yes	67%	86	0.04646222	0.022331	0.02413122	51.94%
3049	TPCODL	BBSR2	BAED	TANGI	CHANDPUR	14185	11 KV KAMAGURU	14185201	JANKIA1	2325DT020	100	MIXED	AMI	Yes	33%	77	0.05415642	0.019362	0.03479442	64.25%
3050	TPCODL	BBSR2	BAED	TANGI	CHANDPUR	14185	11 KV KAMAGURU	14185201	KRISHNA CHANDPUR3	2325DT039	100	MIXED	AMI	Yes	67%	47	0.01883798	0.012601	0.00623698	33.11%
3051	TPCODL	BBSR2	BAED	TANGI	CHANDPUR	14185	11 KV KAMAGURU	14185201	KAMAGURU2	2325DT050	100	MIXED	AMI	Yes	67%	68	0.02291936	0.014342	0.00857736	37.42%
3052	TPCODL	BBSR2	BAED	TANGI	CHANDPUR	14185	11 KV KAMAGURU	14185201	BENTA MAJI SAHI1	2325DT084	100	MIXED	AMI	Yes	67%	52	0.0385324	0.023036	0.0154964	40.22%
3053	TPCODL	BBSR2	BAED	TANGI	CHANDPUR	14185	11 KV CHANDAPUR	14185202	BARA PATRA	2325DT127	250	MIXED	AMI	Yes	100%	211	0.35470756	0.110179	0.24452856	68.94%
3054	TPCODL	BBSR2	BAED	TANGI	CHANDPUR	14185	11 KV CHANDAPUR	14185202	MEDICAL COLONY2	2325DT134	100	MIXED	AMI	Yes	100%	36	0.02013458	0.015396	0.00473858	23.53%
3055	TPCODL	BBSR2	BAED	TANGI	CHANDPUR	14185	11 KV CHANDAPUR	14185202	PUJA MANDAP	2325DT136	250	MIXED	AMI	Yes	0%	149	0.1450404	0.081758	0.0632824	43.63%
3056	TPCODL	BBSR2	BAED	TANGI	CHANDPUR	14185	11 KV CHANDAPUR	14185202	MADHUBAN SAHI2	2325DT138	100	MIXED	AMI	Yes	100%	83	0.05772574	0.046098	0.01162774	20.14%
3057	TPCODL	BBSR2	BAED	TANGI	CHANDPUR	14185	11 KV CHANDAPUR	14185202	GOPA BANDHU NAGAR	2325DT141	100	MIXED	AMI	Yes	100%	56	0.04027534	0.033804	0.00647134	16.07%
3058	TPCODL	BBSR2	BAED	TANGI	DARPANARANPUR	14205	11 KV DARPANARANPUR	14205201	HARIPUR	2323DT128	100	MIXED	AMI	Yes	67%	50	0.0170565	0.014383	0.0026735	15.67%
3059	TPCODL	BBSR2	BAED	TANGI	DARPANARANPUR	14205	11 KV DARPANARANPUR	14205201	SANAGADA	2323DT135	100	MIXED	AMI	Yes	67%	85	0.0254161	0.020517	0.0048991	19.28%
3060	TPCODL	BBSR2	BAED	TANGI	DARPANARANPUR	14205	11 KV DARPANARANPUR	14205201	SANAGADA	2323DT138	100	MIXED	AMI	Yes	67%	106	0.05031732	0.034017	0.01630032	32.40%
3061	TPCODL	BBSR2	BAED	TANGI	DARPANARANPUR	14205	11 KV DARPANARANPUR	14205201	SANAGADA	2323DT139	100	MIXED	AMI	Yes	67%	109	0.05630608	0.036008	0.02029808	36.05%
3062	TPCODL	BBSR2	BAED	TANGI	DARPANARANPUR	14205	11 KV DARPANARANPUR	14205201	JADUPUR	2323DT141	100	MIXED	AMI	Yes	67%	80	0.02034458	0.019225	0.00111958	5.50%
3063	TPCODL	BBSR2	BAED	TANGI	DARPANARANPUR	14205	11 KV DARPANARANPUR	14205201	GAURANGAPUR	2323DT149	100	MIXED	AMI	Yes	0%	137	0.04499458	0.036238	0.00875658	19.46%
3064	TPCODL	BBSR2	BAED	TANGI	DARPANARANPUR	14205	11 KV DARPANARANPUR	14205201	KANKIA	2323DT162	100	MIXED	AMI	Yes	67%	110	0.03732144	0.02423	0.01309144	35.08%
3065	TPCODL	BBSR2	BAED	TANGI	DARPANARANPUR	14205	11 KV DARPANARAYANP	14205202	KHATIA 1	2323DT032	100	MIXED	AMI	Yes	100%	182	0.05349322	0.039639	0.01385422	25.90%

Sl. No.	Zone Name	Circle name	Division name	Name of the Sub-division	Name of the Sub-station	Substation Code	Name of the 11 kV Feeder	Feeder Code	Name of the Location where DT situated	DT code	DT Capacity (kVA)	Predominant consumer type of DT (Domestic/Industrial/Agriculture/Mixed)	Type of metering AMR/AMI/ Communicable/Conventional metered/Unmetered	Status of Meter-whether Functional (Yes/No)	% of data received automatically (if AMR/AMI)	No. of Connected Consumers	Input Energy (MU) (A)	Billed Energy (MU) (B)	Loss (MU) (A-B)	% DT Loss (A-B)/A
3066	TPCODL	BBSR2	BAED	TANGI	DARPANARANPUR	14205	11 KV DARPANARAYANP	14205202	MAHULIA 1	2323DT044	100	MIXED	AMI	Yes	67%	80	0.03242456	0.018785	0.01363956	42.07%
3067	TPCODL	BBSR2	BAED	TANGI	DARPANARANPUR	14205	11 KV DARPANARAYANP	14205202	BEGUNIA PATNA 3	2323DT047	100	MIXED	AMI	Yes	67%	26	0.01260092	0.005049	0.00755192	59.93%
3068	TPCODL	BBSR2	BAED	TANGI	DARPANARANPUR	14205	11 KV DARPANARAYANP	14205202	KENDHUDHIPI 1	2323DT062	100	MIXED	AMI	Yes	67%	159	0.06682144	0.047387	0.01943444	29.08%
3069	TPCODL	BBSR2	BAED	TANGI	DARPANARANPUR	14205	11 KV DARPANARAYANP	14205202	GOPINATHPUR	2323DT063	100	MIXED	AMI	Yes	67%	150	0.09531312	0.067062	0.02825112	29.64%
3070	TPCODL	BBSR2	BAED	TANGI	DARPANARANPUR	14205	11 KV DARPANARAYANP	14205202	BAPUJIPILLI 2	2323DT066	100	MIXED	AMI	Yes	67%	57	0.0279689	0.022533	0.0054359	19.44%
3071	TPCODL	BBSR2	BAED	TANGI	KHANDISI ODSSP	14287	11 KV MAHATPALLA	14287201	LAXMI NARAYANPUR	2325DT265	100	MIXED	AMI	Yes	67%	98	0.03130662	0.021364	0.00994262	31.76%
3072	TPCODL	BBSR2	BAED	TANGI	KHANDISI ODSSP	14287	11 KV MAYURJHALIA	14287202	NEAR MAYUR JHALIA MEDICAL PRIM	2325DT356	100	MIXED	AMI	Yes	0%	60	0.03580862	0.017297	0.01851162	51.70%
3073	TPCODL	BBSR2	BAED	TANGI	KHANDISI ODSSP	14287	11 KV MAYURJHALIA	14287202	HARIHARPUR	2325DT358	100	MIXED	AMI	Yes	100%	169	0.0685224	0.048007	0.0205154	29.94%
3074	TPCODL	BBSR2	BAED	TANGI	KHANDISI ODSSP	14287	11 KV NATIM	14287203	NATIMI	2325DT369	100	MIXED	AMI	Yes	67%	61	0.02676666	0.0145	0.01226666	45.83%
3075	TPCODL	BBSR2	BAED	TANGI	KUHUDI	14202	11 KV KUHUDI	14202201	LAXMIDHARPUR 2	2322DT002	100	MIXED	AMI	Yes	0%	126	0.07521704	0.049865	0.02535204	33.71%
3076	TPCODL	BBSR2	BAED	TANGI	KUHUDI	14202	11 KV KUHUDI	14202201	PATNASAHI	2322DT008	100	MIXED	AMI	Yes	100%	66	0.08312442	0.025425	0.05769942	69.41%
3077	TPCODL	BBSR2	BAED	TANGI	KUHUDI	14202	11 KV KUHUDI	14202201	PATNA HARIZAN SAHI	2322DT009	100	MIXED	AMI	Yes	100%	44	0.04860446	0.018331	0.03027346	62.29%
3078	TPCODL	BBSR2	BAED	TANGI	KUHUDI	14202	11 KV KUHUDI	14202201	BAGHEI SAHI	2322DT018	100	MIXED	AMI	Yes	100%	143	0.07381276	0.054947	0.01886576	25.56%
3079	TPCODL	BBSR2	BAED	TANGI	KUHUDI	14202	11 KV KUHUDI	14202201	PRATAP NAGAR SAHI	2322DT021	100	MIXED	AMI	Yes	0%	94	0.06777018	0.028973	0.03879718	57.25%
3080	TPCODL	BBSR2	BAED	TANGI	KUHUDI	14202	11 KV KUHUDI	14202201	DINBAHADUR	2322DT028	100	MIXED	AMI	Yes	33%	85	0.03378016	0.02351	0.01027016	30.40%
3081	TPCODL	BBSR2	BAED	TANGI	KUHUDI	14202	11 KV KUHUDI	14202201	GOPINATHPUR NEW	2322DT044	100	MIXED	AMI	Yes	100%	69	0.0563695	0.026853	0.0295165	52.36%
3082	TPCODL	BBSR2	BAED	TANGI	KUHUDI	14202	11 KV CHANDESWAR	14202202	ARADE 2	2322DT099	250	MIXED	AMI	Yes	100%	115	0.07927228	0.05219	0.02708228	34.16%
3083	TPCODL	BBSR2	BAED	TANGI	KUHUDI	14202	11 KV CHANDESWAR	14202202	CHANDLESWAR 2	2322DT108	100	MIXED	AMI	Yes	100%	128	0.07713512	0.044987	0.03214812	41.68%
3084	TPCODL	BBSR2	BAED	TANGI	KUHUDI	14202	11 KV CHANDESWAR	14202202	BHASMA CHANDLESHWAR	2322DT112	63	MIXED	AMI	Yes	100%	59	0.0538901	0.019926	0.0339641	63.02%
3085	TPCODL	BBSR2	BAED	TANGI	KUHUDI	14202	11 KV CHANDESWAR	14202202	DIXITPADA MUSLIM SAHI 4	2322DT139	100	MIXED	AMI	Yes	67%	39	0.07358912	0.019082	0.05450712	74.07%
3086	TPCODL	BBSR2	BAED	TANGI	KUHUDI	14202	11 KV CHANDESWAR	14202202	PARIOROLA UPPER SAHI	2322DT144	100	MIXED	AMI	Yes	100%	110	0.0535903	0.038129	0.0154613	28.85%
3087	TPCODL	BBSR2	BAED	TANGI	KUHUDI	14202	11 KV CHANDESWAR	14202202	TUTUMBER PALLI	2322DT147	100	MIXED	AMI	Yes	67%	62	0.07011242	0.016761	0.05335142	76.09%
3088	TPCODL	BBSR2	BAED	TANGI	KUHUDI	14202	11 KV CHANDESWAR	14202202	DOMONI CHANDESHWAR BAZAR	2322DT156	100	MIXED	AMI	Yes	100%	72	0.0541436	0.032122	0.0220216	40.67%
3089	TPCODL	BBSR2	BAED	TANGI	KUHUDI	14202	11 KV CHANDESWAR	14202202	LAXMIDHOLPUR	2322DT159	100	MIXED	AMI	Yes	67%	102	0.0546555	0.034131	0.0205245	37.55%
3090	TPCODL	BBSR2	BAED	TANGI	KUHUDI	14202	11 KV CHANDESWAR	14202202	BINDHANIA 2	2322DT166	100	MIXED	AMI	Yes	67%	46	0.03517208	0.010998	0.02417408	68.73%
3091	TPCODL	BBSR2	BAED	TANGI	RANAPUR	14077	11 KV GOPALPUR	14077201	PAMPADA CHHAKA	2323DT567	100	MIXED	AMI	Yes	67%	82	0.06555072	0.027788	0.03776272	57.61%
3092	TPCODL	BBSR2	BAED	TANGI	RANAPUR	14077	11 KV GOPALPUR	14077201	BHANTA SAHI	2323DT584	100	MIXED	AMI	Yes	67%	89	0.0386734	0.028914	0.0097594	25.24%
3093	TPCODL	BBSR2	BAED	TANGI	RANAPUR	14077	11 KV GOPALPUR	14077201	BHANTA SAHI	2323DT585	100	MIXED	AMI	Yes	67%	25	0.0353819	0.007295	0.0280869	79.38%
3094	TPCODL	BBSR2	BAED	TANGI	RANAPUR	14077	11 KV GOPALPUR	14077201	RAMACHANDRAPUR	2323DT588	100	MIXED	AMI	Yes	67%	117	0.08969852	0.032793	0.05690552	63.44%
3095	TPCODL	BBSR2	BAED	TANGI	RANAPUR	14077	11 KV GOPALPUR	14077201	MOHABIRI PATANA SAHI (GOPALPUR	2323DT591	100	MIXED	AMI	Yes	33%	34	0.01325326	0.01203	0.00122326	9.23%
3096	TPCODL	BBSR2	BAED	TANGI	RANAPUR	14077	11 KV GOPALPUR	14077201	GOPALPUR BANGASAHG ROAD	2323DT596	100	MIXED	AMI	Yes	67%	74	0.0442251	0.031656	0.0125691	28.42%
3097	TPCODL	BBSR2	BAED	TANGI	RANAPUR	14077	11 KV GOPALPUR	14077201	GOPALPUR PHATEPUR SAGH KHETEP	2323DT597	100	MIXED	AMI	Yes	0%	124	0.06439234	0.041281	0.02311134	35.89%
3098	TPCODL	BBSR2	BAED	TANGI	RANAPUR	14077	11 KV GOPALPUR	14077201	G.PUR CHANDRASEKHERPUR POKHAR	2323DT605	25	MIXED	AMI	Yes	67%	38	0.01528226	0.013188	0.00209426	13.70%
3099	TPCODL	BBSR2	BAED	TANGI	RANAPUR	14077	11 KV GOPALPUR	14077201	GOPALPUR GODIPATANA SAHI	2323DT607	100	MIXED	AMI	Yes	67%	71	0.03920086	0.02599	0.01321086	33.70%
3100	TPCODL	BBSR2	BAED	TANGI	RANAPUR	14077	11 KV GOPALPUR	14077201	PATHARAPUNJI	2323DT615	100	MIXED	AMI	Yes	100%	58	0.0233174	0.021365	0.0019524	8.37%
3101	TPCODL	BBSR2	BAED	TANGI	RANAPUR	14077	11 KV GOPALPUR	14077201	MEDICAL CHHAKA TARIPATANA	2323DT627	100	MIXED	AMI	Yes	67%	84	0.03889906	0.036988	0.00191106	4.91%
3102	TPCODL	BBSR2	BAED	TANGI	RANAPUR	14077	11 KV GOPALPUR	14077201	MADHUPUR BAJAR	2323DT633	100	MIXED	AMI	Yes	0%	97	0.03140378	0.028831	0.00257278	8.19%
3103	TPCODL	BBSR2	BAED	TANGI	RANAPUR	14077	11 KV GOPALPUR	14077201	TELIPATANA BAJAR	2323DT634	100	MIXED	AMI	Yes	67%	81	0.04318622	0.02013	0.02305622	53.39%
3104	TPCODL	BBSR2	BAED	TANGI	RANAPUR	14077	11 KV GOPALPUR	14077201	MADHUPUR TALA SAHI	2323DT646	100	MIXED	AMI	Yes	67%	26	0.0099094	0.00758	0.0023294	23.51%
3105	TPCODL	BBSR2	BAED	TANGI	RANAPUR	14077	11 KV GOPALPUR	14077201	KALAMATIA	2323DT694	100	MIXED	AMI	Yes	67%	52	0.01028238	0.008403	0.00187938	18.28%
3106	TPCODL	BBSR2	BAED	TANGI	RANAPUR	14077	11 KV GOPALPUR	14077201	JOSADAPUR	2323DT707	100	MIXED	AMI	Yes	67%	61	0.02706278	0.018388	0.00867478	32.05%
3107	TPCODL	BBSR2	BAED	TANGI	RANAPUR	14077	11 KV GOPALPUR	14077201	KARADAPALA	2323DT721	100	MIXED	AMI	Yes	67%	75	0.02358142	0.016449	0.00713242	30.25%
3108	TPCODL	BBSR2	BAED	TANGI	RANAPUR	14077	11 KV GOPALPUR	14077201	KANDARASING	2323DT731	100	MIXED	AMI	Yes	67%	82	0.0341809	0.026271	0.0079099	23.14%
3109	TPCODL	BBSR2	BAED	TANGI	RANAPUR	14077	11 KV GOPALPUR	14077201	DEULI	2323DT733	100	MIXED	AMI	Yes	100%	75	0.02915322	0.022086	0.00706722	24.24%
3110	TPCODL	BBSR2	BAED	TANGI	RANAPUR	14077	11 KV RANAPUR	14077202	MANGARAJPUR 2	2323DT435	100	MIXED	AMI	Yes	67%	41	0.03169504	0.023684	0.00801104	25.28%
3111	TPCODL	BBSR2	BAED	TANGI	RANAPUR	14077	11 KV RANAPUR	14077202	MANGARAJPUR 3	2323DT437	100	MIXED	AMI	Yes	67%	96	0.06630064	0.03638	0.02992064	45.13%
3112	TPCODL	BBSR2	BAED	TANGI	RANAPUR	14077	11 KV RANAPUR	14077202	RTALASADAKA	2323DT439	100	MIXED	AMI	Yes	67%	100	0.0943878	0.053352	0.0410358	43.48%
3113	TPCODL	BBSR2	BAED	TANGI	RANAPUR	14077	11 KV RANAPUR	14077202	SUANSIA SAHI 1	2323DT445	100	MIXED	AMI	Yes	67%	96	0.08031182	0.047042	0.03326982	41.43%
3114	TPCODL	BBSR2	BAED	TANGI	RANAPUR	14077	11 KV RANAPUR	14077202	DANDA SAHI 90	2323DT448	100	MIXED	AMI	Yes	67%	90	0.13031096	0.059806	0.07050496	54.11%
3115	TPCODL	BBSR2	BAED	TANGI	RANAPUR	14077	11 KV RANAPUR	14077202	CHANDESHWARA SAHI 104	2323DT459	100	MIXED	AMI	Yes	67%	151	0.11711602	0.073667	0.04344902	37.10%
3116	TPCODL	BBSR2	BAED	TANGI	RANAPUR	14077	11 KV RANAPUR	14077202	BADHI HUDA 108	2323DT462	100	MIXED	AMI	Yes	67%	62	0.0735885	0.036886	0.0367025	49.88%
3117	TPCODL	BBSR2	BAED	TANGI	RANAPUR	14077	11 KV RANAPUR	14077202	HATASAHI 1 111	2323DT465	100	MIXED	AMI	Yes	67%	29	0.05343098	0.012298	0.04113298	76.98%
3118	TPCODL	BBSR2	BAED	TANGI	RANAPUR	14077	11 KV RANAPUR	14077202	HATASAHI 2 112	2323DT466	100	MIXED	AMI	Yes	67%	81	0.12015972	0.052126	0.06803372	56.62%
3119	TPCODL	BBSR2	BAED	TANGI	RANAPUR	14077	11 KV RANAPUR	14077202	HARIJAN BASTI 116	2323DT470	100	MIXED	AMI	Yes	100%	69	0.0594654	0.032549	0.0269164	45.26%
3120	TPCODL	BBSR2	BAED	TANGI	RANAPUR	14077	11 KV RANAPUR	14077202	MI OFFICE	2323DT476	100	MIXED	AMI	Yes	0%	18	0.02715472	0.012352	0.01480272	54.51%
3121	TPCODL	BBSR2	BAED	TANGI	RANAPUR	14077	11 KV RANAPUR	14077202	JAMUBILAS SAHI 143	2323DT483	100	MIXED	AMI	Yes	67%	67	0.05838858	0.030632	0.02775658	47.54%
3122	TPCODL	BBSR2	BAED	TANGI	RANAPUR	14077	11 KV RANAPUR	14077202	RAJABATI SAHI 2	2323DT485	100	MIXED	AMI	Yes	67%	92	0.05223484	0.039331	0.01290384	24.70%
3123	TPCODL	BBSR2	BAED	TANGI	RANAPUR	14077	11 KV RANAPUR	14077202	B C HIGH SCHOOL 157	2323DT489	100	MIXED	AMI	Yes	67%	73	0.08615398	0.027414	0.05873998	68.18%
3124	TPCODL	BBSR2	BAED	TANGI	RANAPUR	14077	11 KV RANAPUR	14077202	NUAGAON 4	2323DT494	100	MIXED	AMI	Yes	67%	89	0.03963894	0.031314	0.00832494	21.00%
3125	TPCODL	BBSR2	BAED	TANGI	RANAPUR	14077	11 KV RANAPUR	14077202	RAGHUNATHPUR NUA SAHI	2323DT503	63	MIXED	AMI	Yes	67%	63	0.03124696	0.02214	0.00910696	29.15%
3126	TPCODL	BBSR2	BAED	TANGI	RANAPUR	14077	11 KV RANAPUR	14077202	NUAGAON 2	2323DT507	100	MIXED	AMI	Yes	67%	94	0.05230456	0.038782	0.01352256	25.85%
3127	TPCODL	BBSR2	BAED	TANGI	RANAPUR	14077	11 KV RE	14077203	BANKAPUR 225	2323DT218	100	MIXED	AMI	Yes	100%	73	0.04187398	0.027237	0.01463698	34.95%
3128	TPCODL	BBSR2	BAED	TANGI	RANAPUR	14077	11 KV RE	14077203	GOLA POKHARI 243	2323DT225	63	MIXED	AMI	Yes	67%	85	0.02341071	0.020771	0.00263971	11.28%
3129	TPCODL	BBSR2	BAED	TANGI	RANAPUR	14077	11 KV RE	14077203	KUNJABANA 292	2323DT239	63	MIXED	AMI	Yes	67%	42	0.02141936	0.017237	0.00418236	19.53%
3130	TPCODL	BBSR2	BAED	TANGI	RANAPUR	14077	11 KV RE	14077203	BANAKILO 313	2323DT253	100	MIXED	AMI	Yes	67%	84	0.02749128	0.022045	0.00544628	19.81%
3131	TPCODL	BBSR2	BAED	TANGI	RANAPUR	14077	11 KV RE	14077203	AAMBAJHARA 315	2323DT255	100	MIXED	AMI	Yes	67%	45	0.01602818	0.013333	0.00269518	16.82%
3132	TPCODL	BBSR2	BAED	TANGI	RANAPUR	14077	11 KV RE	14077203	GODAKILO 324	2323DT264	100	MIXED	AMI	Yes	67%	103	0.04257368	0.02375	0.01882368	44.21%
3133	TPCODL	BBSR2	BAED	TANGI	RANAPUR	14077	11 KV RE	14077203	BADABHOI 331	2323DT271	100	MIXED	AMI	Yes	67%	73	0.02767176	0.019962	0.00770976	27.86%
3134	TPCODL	BBSR2	BAED	TANGI	RANAPUR	14077	11 KV RE	14077203	TARIA BAJAR	2323DT272	100	MIXED	AMI	Yes	67%	51	0.02808598	0.019578	0.00850798	30.29%
3135	TPCODL	BBSR2	BAED	TANGI	RANAPUR	14077	11 KV RE	14077203	BALIA PURANASAHI 337	2323DT277	100	MIXED	AMI	Yes	0%	80	0.04366796	0.021774	0.02189396	50.14%
3136	TPCODL	BBSR2	BAED	TANGI	RANAPUR	14077	11 KV RE	14077203	CHANDRAMADEVPUR 357	2323DT290	63	MIXED	AMI	Yes	67%	31	0.01328027	0.009674	0.00360627	27.16%
3137	TPCODL	BBSR2	BAED	TANGI	RANAPUR	14077	11 KV RE	14077203	BYAMAGHANAPUR 359	2323DT292	63	MIXED	AMI	Yes	67%	52	0.02319871	0.016717	0.00648171	27.94%
3138	TPCODL	BBSR2	BAED	TANGI	RANAPUR	14077	11 KV RE	14077203	CHAMPATIPUR 360	2323DT293	100	MIXED	AMI	Yes	100%	88	0.0273277	0.025744	0.0015837	5.80%

Sl. No.	Zone Name	Circle name	Division name	Name of the Sub-division	Name of the Sub-station	Substation Code	Name of the 11 kV Feeder	Feeder Code	Name of the Location where DT situated	DT code	DT Capacity (kVA)	Predominant consumer type of DT (Domestic/Industrial/Agriculture/Mixed)	Type of metering AMR/AMI/ Communicable/Conventional metered/Unmetered	Status of Meter- whether Functional (Yes/No)	% of data received automatically (if AMR/AMI)	No. of Connected Consumers	Input Energy (MU) (A)	Billed Energy (MU) (B)	Loss (MU) (A-B)	% DT Loss (A-B)/A
3139	TPCODL	BBSR2	BAED	TANGI	RANAPUR	14077	11 KV RE	14077203	LODHACHUA 2	2323DT298	100	MIXED	AMI	Yes	67%	61	0.06793858	0.020073	0.04786558	70.45%
3140	TPCODL	BBSR2	BAED	TANGI	RANAPUR	14077	11 KV RE	14077203	BAGALA NUAGAON 379	2323DT307	100	MIXED	AMI	Yes	33%	106	0.04874698	0.032852	0.01589498	32.61%
3141	TPCODL	BBSR2	BAED	TANGI	RANAPUR	14077	11 KV RE	14077203	ADALA 442	2323DT337	100	MIXED	AMI	Yes	67%	104	0.03672022	0.022805	0.01391522	37.90%
3142	TPCODL	BBSR2	BAED	TANGI	RANAPUR	14077	11 KV RE	14077203	BADAPATHURIA 521	2323DT377	100	MIXED	AMI	Yes	67%	67	0.02150722	0.014544	0.00696322	32.38%
3143	TPCODL	BBSR2	BAED	TANGI	RANAPUR	14077	11 KV RE	14077203	SARANGADHARPUR	2323DT385	100	MIXED	AMI	Yes	67%	57	0.0874303	0.02977	0.0576603	65.95%
3144	TPCODL	BBSR2	BAED	TANGI	RANAPUR	14077	11 KV RE	14077203	LEKHANPUR 451	2323DT395	100	MIXED	AMI	Yes	67%	104	0.0343833	0.032696	0.0016873	4.91%
3145	TPCODL	BBSR2	BAED	TANGI	RANAPUR	14077	11 KV HANSARA	14077204	BALARAMPUR 1	2323DT513	100	MIXED	AMI	Yes	67%	107	0.069893	0.036357	0.033536	47.98%
3146	TPCODL	BBSR2	BAED	TANGI	RANAPUR	14077	11 KV HANSARA	14077204	HANSARA NUASAHI 6	2323DT518	100	MIXED	AMI	Yes	67%	90	0.04226574	0.031735	0.01053074	24.92%
3147	TPCODL	BBSR2	BAED	TANGI	RANAPUR	14077	11 KV HANSARA	14077204	HANSARA PURANASAHI 11	2323DT523	100	MIXED	AMI	Yes	67%	80	0.04400478	0.032544	0.01146078	26.04%
3148	TPCODL	BBSR2	BAED	TANGI	RANAPUR	14077	11 KV HANSARA	14077204	NUASAHI KARADAPALLI	2323DT527	100	MIXED	AMI	Yes	67%	71	0.03965278	0.03279	0.00686278	17.31%
3149	TPCODL	BBSR2	BAED	TANGI	RANAPUR	14077	11 KV HANSARA	14077204	NARSINGHPUR PURANA SAHI	2323DT545	100	MIXED	AMI	Yes	67%	154	0.05478346	0.040658	0.01412546	25.78%
3150	TPCODL	BBSR2	BAED	TANGI	RANAPUR	14077	11 KV HANSARA	14077204	NARSINGHPUR NUASAHI 1	2323DT548	100	MIXED	AMI	Yes	100%	162	0.05267243	0.05009	0.00258243	4.90%
3151	TPCODL	BBSR2	BAED	TANGI	TANGI	14076	11 KV BADAPARI	14076201	BRAHMUNDI1	2322DT282	100	MIXED	AMI	Yes	100%	96	0.0433014	0.029707	0.0135944	31.39%
3152	TPCODL	BBSR2	BAED	TANGI	TANGI	14076	11 KV BADAPARI	14076201	BLOCK OFFICE	2324DT190	100	MIXED	AMI	Yes	100%	8	0.02643066	0.020454	0.00597666	22.61%
3153	TPCODL	BBSR2	BAED	TANGI	TANGI	14076	11 KV BADAPARI	14076201	BADPARI CHAKKA JUNGLE CEMMUIT	2324DT207	100	MIXED	AMI	Yes	100%	47	0.02500452	0.015838	0.00916652	36.66%
3154	TPCODL	BBSR2	BAED	TANGI	TANGI	14076	11 KV BADAPARI	14076201	BADAPARI BIDHAR SAHI	2324DT212	100	MIXED	AMI	Yes	100%	86	0.06427472	0.027187	0.03708772	57.70%
3155	TPCODL	BBSR2	BAED	TANGI	TANGI	14076	11 KV BADAPARI	14076201	RATNAWALI SAHI	2324DT214	250	MIXED	AMI	Yes	100%	195	0.14814604	0.123668	0.02447804	16.52%
3156	TPCODL	BBSR2	BAED	TANGI	TANGI	14076	11 KV BADAPARI	14076201	BHO BARA	2324DT256	100	MIXED	AMI	Yes	67%	92	0.05685058	0.032939	0.02391158	42.06%
3157	TPCODL	BBSR2	BAED	TANGI	TANGI	14076	11 KV BADAPARI	14076201	PANASPUR 2	2324DT261	100	MIXED	AMI	Yes	100%	102	0.04727338	0.025261	0.02201238	46.56%
3158	TPCODL	BBSR2	BAED	TANGI	TANGI	14076	11 KV BADAPARI	14076201	SINGRAMA	2324DT278	100	MIXED	AMI	Yes	67%	66	0.02549536	0.018974	0.00652136	25.58%
3159	TPCODL	BBSR2	BAED	TANGI	TANGI	14076	11 KV BADAPARI	14076201	GODI SAHI 3	2324DT281	100	MIXED	AMI	Yes	67%	64	0.03357672	0.017587	0.01598972	47.62%
3160	TPCODL	BBSR2	BAED	TANGI	TANGI	14076	11 KV BADAPARI	14076201	PAIKA SAHI 3	2324DT326	100	MIXED	AMI	Yes	67%	47	0.00784314	0.004512	0.00333114	42.47%
3161	TPCODL	BBSR2	BAED	TANGI	TANGI	14076	11 KV BADAPARI	14076201	NARAMANABI TALA SAHI	2324DT347	100	MIXED	AMI	Yes	67%	25	0.00851468	0.005754	0.00276068	32.42%
3162	TPCODL	BBSR2	BAED	TANGI	TANGI	14076	11 KV BADAPARI	14076201	NARAMANABI 4	2324DT358	100	MIXED	AMI	Yes	67%	64	0.02154342	0.015793	0.00575042	26.69%
3163	TPCODL	BBSR2	BAED	TANGI	TANGI	14076	11 KV TANGI CHANDAPU	14076202	MANGLA JODI	2321DT016	100	MIXED	AMI	Yes	100%	158	0.07461944	0.055848	0.01877144	25.16%
3164	TPCODL	BBSR2	BAED	TANGI	TANGI	14076	11 KV TANGI CHANDAPU	14076202	MANGLA JODI	2321DT030	200	MIXED	AMI	Yes	0%	147	0.15219644	0.042548	0.10964844	72.04%
3165	TPCODL	BBSR2	BAED	TANGI	TANGI	14076	11 KV TANGI CHANDAPU	14076202	MANGLA JODI	2321DT031	100	MIXED	AMI	Yes	100%	139	0.06975758	0.032708	0.03704958	53.11%
3166	TPCODL	BBSR2	BAED	TANGI	TANGI	14076	11 KV TANGI CHANDAPU	14076202	SUNDER PUR BADA SAHI	2321DT055	100	MIXED	AMI	Yes	67%	36	0.03442238	0.011254	0.02316838	67.31%
3167	TPCODL	BBSR2	BAED	TANGI	TANGI	14076	11 KV TANGI CHANDAPU	14076202	UDUGIRI	2321DT060	100	MIXED	AMI	Yes	67%	79	0.05085182	0.0261	0.02475182	48.67%
3168	TPCODL	BBSR2	BAED	TANGI	TANGI	14076	11 KV TANGI CHANDAPU	14076202	KATALGOTO	2321DT065	100	MIXED	AMI	Yes	67%	142	0.05197624	0.037023	0.01495324	28.77%
3169	TPCODL	BBSR2	BAED	TANGI	TANGI	14076	11 KV TANGI CHANDAPU	14076202	PANASPUR PATNA	2324DT167	100	MIXED	AMI	Yes	67%	119	0.08008064	0.054543	0.02553764	31.89%
3170	TPCODL	BBSR2	BAED	TANGI	TANGI	14076	11 KV TANGI CHANDAPU	14076202	PATNAYAK SAHI	2324DT173	100	MIXED	AMI	Yes	100%	63	0.09059456	0.036415	0.05417956	59.80%
3171	TPCODL	BBSR2	BAED	TANGI	TANGI	14076	11 KV TANGI CHANDAPU	14076202	SHASTRI NAGAR 2	2324DT378	100	MIXED	AMI	Yes	100%	88	0.07306776	0.052117	0.02095076	28.67%
3172	TPCODL	BBSR2	BAED	TANGI	TANGI	14076	11 KV TANGI CHANDAPU	14076202	BATA SAHI	2325DT216	100	MIXED	AMI	Yes	100%	103	0.07464548	0.057015	0.01763048	23.62%
3173	TPCODL	BBSR2	BAED	TANGI	TANGI	14076	11 KV TANGI CHANDAPU	14076202	BRAHMIN SAHI	2325DT218	100	MIXED	AMI	Yes	67%	51	0.04800516	0.021436	0.02656916	55.35%
3174	TPCODL	BBSR2	BAED	TANGI	TANGI	14076	11 KV TANGI CHANDAPU	14076202	TANGI SAHI	2325DT221	100	MIXED	AMI	Yes	100%	86	0.09030716	0.039719	0.05058816	56.02%
3175	TPCODL	BBSR2	BAED	TANGI	TANGI	14076	11 KV KALUPADA	14076203	HANSHARODI	2322DT179	100	MIXED	AMI	Yes	67%	36	0.03013104	0.012176	0.01795504	59.59%
3176	TPCODL	BBSR2	BAED	TANGI	TANGI	14076	11 KV KALUPADA	14076203	RAJA PADIA	2322DT203	100	MIXED	AMI	Yes	67%	16	0.01455226	0.00521	0.00934226	64.20%
3177	TPCODL	BBSR2	BAED	TANGI	TANGI	14076	11 KV KALUPADA	14076203	BADHI SAHI 1	2322DT206	100	MIXED	AMI	Yes	67%	140	0.06829006	0.046924	0.02136606	31.29%
3178	TPCODL	BBSR2	BAED	TANGI	TANGI	14076	11 KV KALUPADA	14076203	CHHELIA SAHI	2322DT228	100	MIXED	AMI	Yes	67%	58	0.05800806	0.028723	0.02928506	50.48%
3179	TPCODL	BBSR2	BAED	TANGI	TANGI	14076	11 KV KALUPADA	14076203	GOPINATH SAHI	2322DT236	100	MIXED	AMI	Yes	0%	75	0.07461016	0.029608	0.04500216	60.32%
3180	TPCODL	BBSR2	BAED	TANGI	TANGI	14076	11 KV KALUPADA	14076203	BANAGADIA SAHI	2322DT244	250	MIXED	AMI	Yes	67%	58	0.06429052	0.021781	0.04250952	66.12%
3181	TPCODL	BBSR2	BAED	TANGI	TANGI	14076	11 KV KALUPADA	14076203	CHIANGA SAHI	2322DT245	200	MIXED	AMI	Yes	67%	122	0.12863528	0.039929	0.08870628	68.96%
3182	TPCODL	BBSR2	BAED	TANGI	TANGI	14076	11 KV KALUPADA	14076203	DAMANI SAHI MANSINGHPUR	2322DT257	100	MIXED	AMI	Yes	67%	112	0.04223256	0.03729	0.00494256	11.70%
3183	TPCODL	BBSR2	BAED	TANGI	TANGI	14076	11 KV KALUPADA	14076203	RAGHUNATH	2322DT258	100	MIXED	AMI	Yes	0%	143	0.05952076	0.055558	0.00396276	6.66%
3184	TPCODL	BBSR2	BAED	TANGI	TANGI	14076	11 KV KALUPADA	14076203	KALIJAI SCHOOL SAHI	2322DT263	100	MIXED	AMI	Yes	67%	53	0.02047238	0.018453	0.00201938	9.86%
3185	TPCODL	BBSR2	BAED	TANGI	TANGI	14076	11 KV KALUPADA	14076203	TARAPI	2322DT275	100	MIXED	AMI	Yes	67%	123	0.06975802	0.033187	0.03657102	52.43%
3186	TPCODL	BBSR2	BAED	TANGI	TANGI	14076	11 KV KALUPADA	14076203	BADA PAIKA SAHI 1	2324DT003	100	MIXED	AMI	Yes	100%	84	0.0489295	0.042396	0.0065335	13.35%
3187	TPCODL	BBSR2	BAED	TANGI	TANGI	14076	11 KV KALUPADA	14076203	SANDHA SAHI 1	2324DT015	100	MIXED	AMI	Yes	100%	120	0.08095836	0.053586	0.02737236	33.81%
3188	TPCODL	BBSR2	BAED	TANGI	TANGI	14076	11 KV KALUPADA	14076203	RAJENDERPUR 1	2324DT045	100	MIXED	AMI	Yes	67%	94	0.04564526	0.041508	0.00413726	9.06%
3189	TPCODL	BBSR2	BAED	TANGI	TANGI	14076	11 KV KALUPADA	14076203	CHADHE GAON	2324DT056	100	MIXED	AMI	Yes	67%	43	0.03404128	0.016098	0.01794328	52.71%
3190	TPCODL	BBSR2	BAED	TANGI	TANGI	14076	11 KV KALUPADA	14076203	WASH PADAR	2324DT060	100	MIXED	AMI	Yes	67%	59	0.0556782	0.038486	0.0171922	30.88%
3191	TPCODL	BBSR2	BAED	TANGI	TANGI	14076	11 KV KALUPADA	14076203	JATIA PATNA	2324DT072	100	MIXED	AMI	Yes	67%	79	0.03675338	0.024472	0.01228138	33.42%
3192	TPCODL	BBSR2	BAED	TANGI	TANGI	14076	11 KV KALUPADA	14076203	CHILIKA SAHI	2324DT074	100	MIXED	AMI	Yes	67%	62	0.02703386	0.022841	0.00419286	15.51%
3193	TPCODL	BBSR2	BAED	TANGI	TANGI	14076	11 KV KALUPADA	14076203	JARIPADA HARIZAN SAHI	2324DT075	250	MIXED	AMI	Yes	0%	58	0.02655552	0.020872	0.00568352	21.40%
3194	TPCODL	BBSR2	BAED	TANGI	TANGI	14076	11 KV KALUPADA	14076203	JAGANNATHPUR	2324DT108	100	MIXED	AMI	Yes	67%	113	0.04539692	0.027175	0.01822192	40.14%
3195	TPCODL	BBSR2	BAED	TANGI	TANGI	14076	11 KV KALUPADA	14076203	BALINASI 3	2324DT119	100	MIXED	AMI	Yes	67%	59	0.03935796	0.01689	0.02246796	57.09%
3196	TPCODL	BBSR2	BAED	TANGI	TANGI	14076	11 KV KALUPADA	14076203	SUBSTATION DT	2324DT375	250	MIXED	AMI	Yes	100%	82	0.12766176	0.076949	0.05071276	39.72%
3197	TPCODL	BBSR2	KHD	BANKI	SUNADEIMUNDIA	14047	33 KV MAIN INCOMER (T	14047401	33/11 kV JATAMUNDIA SS ST	2113DT950	100	MIXED	AMI	Yes	100%	1	0.00144898	0.001449	-2E-08	0.00%
3198	TPCODL	BBSR2	KHD	BANKI	JATAMUNDIA	14049	11 KV TALABASTA	14049201	HALADIPADA VILLAGE	2113DT307	100	MIXED	AMI	Yes	67%	65	0.03353666	0.017731	0.01580566	47.13%
3199	TPCODL	BBSR2	KHD	BANKI	JATAMUNDIA	14049	11 KV TALABASTA	14049201	BADAHAMARA VILLAGE	2113DT335	25	MIXED	AMI	Yes	0%	19	0.0093898	0.002233	0.0071568	76.22%
3200	TPCODL	BBSR2	KHD	BANKI	JATAMUNDIA	14049	11 KV TALABASTA	14049201	TALABASTA CHECK GATE CHHACK	2113DT350	100	MIXED	AMI	Yes	0%	139	0.11027274	0.042122	0.06815074	61.80%
3201	TPCODL	BBSR2	KHD	BANKI	JATAMUNDIA	14049	11 KV TALABASTA	14049201	BIDYADHARPUR, MATHA SAHI	2113DT359	100	MIXED	AMI	Yes	0%	59	0.04862308	0.021555	0.02706808	55.67%
3202	TPCODL	BBSR2	KHD	BANKI	JATAMUNDIA	14049	11 KV TALABASTA	14049201	CHAMPATIPUR VILLAGE-1	2113DT405	100	MIXED	AMI	Yes	0%	29	0.03086526	0.012644	0.01822126	59.03%
3203	TPCODL	BBSR2	KHD	BANKI	JATAMUNDIA	14049	11 KV RAMACHANDI	14049203	JATAMUNDIA RMC	2113DT150	100	MIXED	AMI	Yes	100%	23	0.01347782	0.007094	0.00638382	47.37%
3204	TPCODL	BBSR2	KHD	BANKI	JATAMUNDIA	14049	11 KV RAMACHANDI	14049203	TALAPATHAPUR VILLAGE-1	2113DT165	100	MIXED	AMI	Yes	67%	58	0.06976694	0.025253	0.04451394	63.80%
3205	TPCODL	BBSR2	KHD	BANKI	JATAMUNDIA	14049	11 KV RAMACHANDI	14049203	UPARAPATHAPUR VILLAGE-1	2113DT170	250	MIXED	AMI	Yes	0%	131	0.13293688	0.037232	0.09570488	71.99%
3206	TPCODL	BBSR2	KHD	BANKI	JATAMUNDIA	14049	11 KV RAMACHANDI	14049203	RAMACHANDI VILLAGE	2113DT208	250	MIXED	AMI	Yes	0%	165	0.14252652	0.051643	0.09088352	63.77%
3207	TPCODL	BBSR2	KHD	BANKI	JATAMUNDIA	14049	11 KV GADAJIT	14049205	DAMAPADA BAUTI	2113DT056	100	MIXED	AMI	Yes	67%	123	0.06220476	0.042593	0.01961176	31.53%
3208	TPCODL	BBSR2	KHD	BANKI	JATAMUNDIA	14049	11 KV GADAJIT	14049205	BRAMHANIA VILLAGE-1	2113DT059	100	MIXED	AMI	Yes	0%	98	0.02263274	0.014107	0.00852574	37.67%
3209	TPCODL	BBSR2	KHD	BANKI	JATAMUNDIA	14049	11 KV GADAJIT	14049205	MADANMOHAN CHHAKA-1,DAMAPA	2113DT069	100	MIXED	AMI	Yes	67%	60	0.04943452	0.02059	0.02884452	58.35%
3210	TPCODL	BBSR2	KHD	BANKI	JATAMUNDIA	14049	11 KV GADAJIT	14049205	SASANA SAHI , DAMAPADA	2113DT071	100	MIXED	AMI	Yes	0%	66	0.06250734	0.028046	0.03446134	55.13%
3211	TPCODL	BBSR2	KHD	BANKI	JATAMUNDIA	14049	11 KV GADAJIT	14049205	NISTIPUR NEAR COLD STORE	2113DT083	100	MIXED	AMI	Yes	67%	36	0.02767612	0.011536	0.01614012	58.32%

Sl. No.	Zone Name	Circle name	Division name	Name of the Sub-division	Name of the Sub-station	Substation Code	Name of the 11 kV Feeder	Feeder Code	Name of the Location where DT situated	DT code	DT Capacity (kVA)	Predominant consumer type of DT (Domestic/Industrial/Agriculture/Mixed)	Type of metering AMR/AMI/ Communicable/Conventional metered/Unmetered	Status of Meter-whether Functional (Yes/No)	% of data received automatically (if AMR/AMI)	No. of Connected Consumers	Input Energy (MU) (A)	Billed Energy (MU) (B)	Loss (MU) (A-B)	% DT Loss (A-B)/A
3212	TPCODL	BBSR2	KHD	BANKI	JATAMUNDIA	14049	11 KV GADAJIT	14049205	KUSUPANGI VILLAGE-1	2113DT096	250	MIXED	AMI	Yes	67%	227	0.09746004	0.0536099	0.04385014	44.99%
3213	TPCODL	BBSR2	KHD	BANKI	KANDARPUR	14093	11 KV PARAMAHANSA	14093203	PARAMHANS-2	3224DT257	63	MIXED	AMI	Yes	100%	58	0.05722714	0.028682	0.02854514	49.88%
3214	TPCODL	BBSR2	KHD	BANKI	SUNADEIMUNDIA	14047	11 KV BANKI TOWN	14047201	DHUDHA-2	2111DT005	100	MIXED	AMI	Yes	0%	35	0.01698214	0.016855	0.00012714	0.75%
3215	TPCODL	BBSR2	KHD	BANKI	SUNADEIMUNDIA	14047	11 KV BANKI TOWN	14047201	RANAPUR-2	2111DT015	100	MIXED	AMI	Yes	67%	104	0.07242328	0.046186	0.02623728	36.23%
3216	TPCODL	BBSR2	KHD	BANKI	SUNADEIMUNDIA	14047	11 KV BANKI TOWN	14047201	RANAPUR BANDHA ROAD	2111DT017	100	MIXED	AMI	Yes	67%	100	0.07654028	0.023969	0.05257128	68.68%
3217	TPCODL	BBSR2	KHD	BANKI	SUNADEIMUNDIA	14047	11 KV BANKI TOWN	14047201	SAHADAPADA-1	2111DT030	250	MIXED	AMI	Yes	0%	40	0.03490232	0.016028	0.01887432	54.08%
3218	TPCODL	BBSR2	KHD	BANKI	SUNADEIMUNDIA	14047	11 KV BANKI TOWN	14047201	SATHI THAKURANI	2111DT040	100	MIXED	AMI	Yes	67%	143	0.06296446	0.038527	0.02443746	38.81%
3219	TPCODL	BBSR2	KHD	BANKI	SUNADEIMUNDIA	14047	11 KV BANKI TOWN	14047201	DANGIPITA	2111DT042	100	MIXED	AMI	Yes	67%	167	0.07946934	0.046221	0.03324834	41.84%
3220	TPCODL	BBSR2	KHD	BANKI	SUNADEIMUNDIA	14047	11 KV BANKI TOWN	14047201	JORAKUL OLD	2111DT044	100	MIXED	AMI	Yes	67%	70	0.03319018	0.021117	0.01207318	36.38%
3221	TPCODL	BBSR2	KHD	BANKI	SUNADEIMUNDIA	14047	11 KV BANKI TOWN	14047201	HANUMAN PATAPUR-2	2111DT072	200	MIXED	AMI	Yes	67%	256	0.13854108	0.087287	0.05125408	37.00%
3222	TPCODL	BBSR2	KHD	BANKI	SUNADEIMUNDIA	14047	11 KV BANKI TOWN	14047201	GOPALPUR BAYANIBARA	2111DT079	250	MIXED	AMI	Yes	67%	192	0.11156324	0.06420839	0.04735485	42.45%
3223	TPCODL	BBSR2	KHD	BANKI	SUNADEIMUNDIA	14047	11 KV BANKI TOWN	14047201	GOPALPUR PANCHAYAT OFFICE	2111DT080	63	MIXED	AMI	Yes	0%	63	0.03265648	0.016316	0.01634048	50.04%
3224	TPCODL	BBSR2	KHD	BANKI	SUNADEIMUNDIA	14047	11 KV BANKI TOWN	14047201	NILAPOKHARI,RAGADI	2111DT084	250	MIXED	AMI	Yes	67%	204	0.08083984	0.072462	0.00837784	10.36%
3225	TPCODL	BBSR2	KHD	BANKI	SUNADEIMUNDIA	14047	11 KV BANKI TOWN	14047201	TPCODL OFFICE FRONT	2111DT094	500	MIXED	AMI	Yes	67%	326	0.25607144	0.185432	0.07063944	27.59%
3226	TPCODL	BBSR2	KHD	BANKI	SUNADEIMUNDIA	14047	11 KV BANKI TOWN	14047201	RC MESS LANE	2111DT096	100	MIXED	AMI	Yes	0%	59	0.08517508	0.029364	0.05581108	65.53%
3227	TPCODL	BBSR2	KHD	BANKI	SUNADEIMUNDIA	14047	11 KV BANKI TOWN	14047201	B.K. BIDYAPITHA PLAYGROUND	2111DT097	250	MIXED	AMI	Yes	67%	83	0.11020324	0.042488	0.06771524	61.45%
3228	TPCODL	BBSR2	KHD	BANKI	SUNADEIMUNDIA	14047	11 KV BANKI TOWN	14047201	JAMUNDIHI	2112DT306	100	MIXED	AMI	Yes	67%	127	0.05355314	0.03792	0.01563314	29.19%
3229	TPCODL	BBSR2	KHD	BANKI	SUNADEIMUNDIA	14047	11 KV RAJIB	14047202	KURUMCHANI	2112DT062	100	MIXED	AMI	Yes	67%	57	0.04522756	0.009333	0.03589456	79.36%
3230	TPCODL	BBSR2	KHD	BANKI	SUNADEIMUNDIA	14047	11 KV RAJIB	14047202	ANDHURA-2	2112DT090	100	MIXED	AMI	Yes	67%	189	0.06360022	0.047595	0.01600522	25.17%
3231	TPCODL	BBSR2	KHD	BANKI	SUNADEIMUNDIA	14047	11 KV RAJIB	14047202	RAJIB-1	2112DT105	100	MIXED	AMI	Yes	33%	75	0.07517296	0.019806	0.05536696	73.65%
3232	TPCODL	BBSR2	KHD	BANKI	SUNADEIMUNDIA	14047	11 KV RAJIB	14047202	RAMANATH HP GAS,KOTA	2112DT121	100	MIXED	AMI	Yes	0%	83	0.03506188	0.027324	0.00773788	22.07%
3233	TPCODL	BBSR2	KHD	BANKI	SUNADEIMUNDIA	14047	11 KV RAJIB	14047202	CHADHEIBANDHA-1	2112DT149	100	MIXED	AMI	Yes	0%	65	0.0209658	0.016893	0.0040728	19.43%
3234	TPCODL	BBSR2	KHD	BANKI	SUNADEIMUNDIA	14047	11 KV CHAKAPADA	14047204	SISUA BALI SAHI	2111DT166	200	MIXED	AMI	Yes	67%	77	0.06390339	0.032035	0.03186839	49.87%
3235	TPCODL	BBSR2	KHD	BANKI	SUNADEIMUNDIA	14047	11 KV CHAKAPADA	14047204	CHAKAPADA, NEHUR NAGAR	2111DT169	63	MIXED	AMI	Yes	67%	72	0.04651846	0.028859	0.01765946	37.96%
3236	TPCODL	BBSR2	KHD	BANKI	SUNADEIMUNDIA	14047	11 KV CHAKAPADA	14047204	SIMILIPUR NADIKULA SAHI	2111DT184	250	MIXED	AMI	Yes	67%	116	0.0663291	0.03672	0.0296091	44.64%
3237	TPCODL	BBSR2	KHD	BANKI	SUNADEIMUNDIA	14047	11 KV RWSS	14047205	PANCHAYAT SAHI RAGADI	2111DT153	63	MIXED	AMI	Yes	67%	56	0.0328538	0.00681203	0.02604177	79.27%
3238	TPCODL	BBSR2	KHD	BANKI	SUNADEIMUNDIA	14047	11 KV RWSS	14047205	TOWER	2112DT103	25	MIXED	AMI	Yes	67%	41	0.01623443	0.008969	0.00726543	44.75%
3239	TPCODL	BBSR2	KHD	BANKI	TULASIPUR	14045	11 KV TULASIPUR FEEDE	14045201	NARGANGA HADISAHI-1	2112DT345	250	MIXED	AMI	Yes	100%	64	0.06454016	0.020352	0.04418816	68.47%
3240	TPCODL	BBSR2	KHD	BEGUNIA	BAGHAMARI	14040	11 KV SARUA (Baghamar	14040201	BAGHAMARI NO2 HANUMANSAHI	2121DT015	100	MIXED	AMI	Yes	0%	117	0.05983919	0.043376	0.01646319	27.51%
3241	TPCODL	BBSR2	KHD	BEGUNIA	BAGHAMARI	14040	11 KV SARUA (Baghamar	14040201	BAGHAMARI MEDICAL NO-3	2121DT016	100	MIXED	AMI	Yes	100%	155	0.09472948	0.066342	0.02838748	29.97%
3242	TPCODL	BBSR2	KHD	BEGUNIA	BAGHAMARI	14040	11 KV PODADHIA	14040202	GANPUR 1	2121DT052	100	MIXED	AMI	Yes	67%	167	0.08062044	0.05234419	0.02827625	35.07%
3243	TPCODL	BBSR2	KHD	BEGUNIA	BAGHAMARI	14040	11 KV PODADHIA	14040202	KUTAPALLA	2121DT065	100	MIXED	AMI	Yes	0%	111	0.0473158	0.026167	0.0211488	44.70%
3244	TPCODL	BBSR2	KHD	BEGUNIA	BAGHAMARI	14040	11 KV PODADHIA	14040202	PODADIHA BRAMHANSAHI	2121DT078	100	MIXED	AMI	Yes	67%	84	0.06496616	0.027073	0.03789316	58.33%
3245	TPCODL	BBSR2	KHD	BEGUNIA	BAGHAMARI	14040	11 KV PODADHIA	14040202	PANGGARSING	2121DT096	100	MIXED	AMI	Yes	100%	70	0.04182962	0.019388	0.02244162	53.65%
3246	TPCODL	BBSR2	KHD	BEGUNIA	BAGHAMARI	14040	11 KV PODADHIA	14040202	DINIARY	2121DT113	100	MIXED	AMI	Yes	67%	144	0.0529772	0.041475	0.0115022	21.71%
3247	TPCODL	BBSR2	KHD	BEGUNIA	BAGHAMARI	14040	11 KV PODADHIA	14040202	BHOGADA NO-1	2121DT117	100	MIXED	AMI	Yes	67%	66	0.03071958	0.019589	0.01113058	36.23%
3248	TPCODL	BBSR2	KHD	BEGUNIA	BAGHAMARI	14040	11 KV PODADHIA	14040202	SIMOR NO-2	2121DT132	100	MIXED	AMI	Yes	67%	94	0.03703448	0.031275	0.00575948	15.55%
3249	TPCODL	BBSR2	KHD	BEGUNIA	BAGHAMARI	14040	11 KV ATRI	14040203	ATRI	2121DT021	100	MIXED	AMI	Yes	100%	169	0.0908764	0.052918	0.0379584	41.77%
3250	TPCODL	BBSR2	KHD	BEGUNIA	BAGHAMARI	14040	11 KV ATRI	14040203	KARADAGADIA NO 1	2121DT034	100	MIXED	AMI	Yes	100%	147	0.07126266	0.045767	0.02549566	35.78%
3251	TPCODL	BBSR2	KHD	BEGUNIA	BAGHAMARI	14040	11 KV ATRI	14040203	BAMAADIHA NO 1	2121DT047	100	MIXED	AMI	Yes	100%	86	0.04074096	0.026708	0.01403296	34.44%
3252	TPCODL	BBSR2	KHD	BEGUNIA	BAGHAMARI	14040	11 KV ATRI	14040203	SARADHAPUR NO 1	2121DT150	100	MIXED	AMI	Yes	100%	84	0.07731452	0.035175	0.04213952	54.50%
3253	TPCODL	BBSR2	KHD	BEGUNIA	BAGHAMARI	14040	11 KV ATRI	14040203	GODI NO-1	2121DT162	100	MIXED	AMI	Yes	0%	102	0.04146578	0.029332	0.01213378	29.26%
3254	TPCODL	BBSR2	KHD	BEGUNIA	BAGHAMARI	14040	11 KV ATRI	14040203	BARAPADA NO-1	2121DT177	100	MIXED	AMI	Yes	100%	110	0.0549284	0.035753	0.0191754	34.91%
3255	TPCODL	BBSR2	KHD	BEGUNIA	BAGHAMARI	14040	11 KV ATRI	14040203	KUNJURI NO-1	2121DT179	100	MIXED	AMI	Yes	100%	85	0.02485914	0.022326	0.00253314	10.19%
3256	TPCODL	BBSR2	KHD	BEGUNIA	BAGHAMARI	14040	11 KV ATRI	14040203	PODAPATNA	2121DT184	100	MIXED	AMI	Yes	100%	42	0.0452948	0.011552	0.0337428	74.50%
3257	TPCODL	BBSR2	KHD	BEGUNIA	BAGHAMARI	14040	11 KV ATRI	14040203	LEHENGA NO-1	2121DT190	100	MIXED	AMI	Yes	100%	118	0.04963136	0.045368	0.00426336	8.59%
3258	TPCODL	BBSR2	KHD	BEGUNIA	BEGUNIA	14182	11 KV BEGUNIA	14182201	HOSPITAL,BEGUNIA	2122DT007	100	MIXED	AMI	Yes	100%	102	0.07464934	0.060052	0.01459734	19.55%
3259	TPCODL	BBSR2	KHD	BEGUNIA	BEGUNIA	14182	11 KV BEGUNIA	14182201	DASAGADIA 2	2122DT011	100	MIXED	AMI	Yes	100%	80	0.06293268	0.061437	0.00149568	2.38%
3260	TPCODL	BBSR2	KHD	BEGUNIA	BEGUNIA	14182	11 KV BEGUNIA	14182201	MASANI	2122DT018	100	MIXED	AMI	Yes	100%	63	0.05103012	0.044263	0.00676712	13.26%
3261	TPCODL	BBSR2	KHD	BEGUNIA	BEGUNIA	14182	11 KV BEGUNIA	14182201	GURUHATA	2122DT024	100	MIXED	AMI	Yes	100%	44	0.03115266	0.018578	0.01257466	40.36%
3262	TPCODL	BBSR2	KHD	BEGUNIA	BEGUNIA	14182	11 KV BEGUNIA	14182201	NH SIDE	2122DT032	100	MIXED	AMI	Yes	0%	75	0.04476226	0.033579	0.01118326	24.98%
3263	TPCODL	BBSR2	KHD	BEGUNIA	BEGUNIA	14182	11 KV BEGUNIA	14182201	TARINI CHHACK	2122DT039	100	MIXED	AMI	Yes	100%	89	0.0665352	0.045467	0.0210682	31.66%
3264	TPCODL	BBSR2	KHD	BEGUNIA	BEGUNIA	14182	11 KV BEGUNIA	14182201	JAGANNATHPUR PRIMERY SCHOOL	2122DT100	100	MIXED	AMI	Yes	100%	89	0.0552239	0.033895	0.0213289	38.62%
3265	TPCODL	BBSR2	KHD	BEGUNIA	BEGUNIA	14182	11 KV DINGAR	14182202	CHAKAPADA NO-2	2122DT056	100	MIXED	AMI	Yes	0%	121	0.0462794	0.041526	0.0047534	10.27%
3266	TPCODL	BBSR2	KHD	BEGUNIA	BEGUNIA	14182	11 KV DINGAR	14182202	KADAB ODIA SAHI	2122DT087	100	MIXED	AMI	Yes	100%	182	0.06461084	0.051257	0.01335384	20.67%
3267	TPCODL	BBSR2	KHD	BEGUNIA	BEGUNIA	14182	11 KV DINGAR	14182202	NUAGAON,KADAB	2122DT089	100	MIXED	AMI	Yes	100%	46	0.02102772	0.013233	0.00779472	37.07%
3268	TPCODL	BBSR2	KHD	BEGUNIA	BEGUNIA	14182	11 KV DINGAR	14182202	CHATUA LI POINT	2122DT111	100	MIXED	AMI	Yes	100%	1	0.00021005	0.00021	5E-08	0.02%
3269	TPCODL	BBSR2	KHD	BEGUNIA	BEGUNIA	14182	11 KV DINGAR	14182202	DINGAR TARINI MANDIRA NO-2	2122DT365	100	MIXED	AMI	Yes	67%	38	0.03652828	0.021013	0.01551528	42.47%
3270	TPCODL	BBSR2	KHD	BEGUNIA	BEGUNIA	14182	11 KV DINGAR	14182202	DINGAR PATARA SAHI NO-1	2122DT374	100	MIXED	AMI	Yes	67%	47	0.02977212	0.016409	0.01336312	44.88%
3271	TPCODL	BBSR2	KHD	BEGUNIA	BEGUNIA	14182	11 KV DINGAR	14182202	DINGAR SUBUDHI SAHI	2122DT381	100	MIXED	AMI	Yes	0%	80	0.04343534	0.025054	0.01838134	42.32%
3272	TPCODL	BBSR2	KHD	BEGUNIA	GEDIAPALI ODSSP	14269	11 KV KADHAMALLA	14269201	KADHAMALLA-2	2123DT202	100	MIXED	AMI	Yes	67%	65	0.05941858	0.022312	0.03710658	62.45%
3273	TPCODL	BBSR2	KHD	BEGUNIA	GEDIAPALI ODSSP	14269	11 KV KADHAMALLA	14269201	USHA GADIA	2123DT224	250	MIXED	AMI	Yes	0%	168	0.09091952	0.082484	0.00843552	9.28%
3274	TPCODL	BBSR2	KHD	BEGUNIA	GEDIAPALI ODSSP	14269	11 KV KADHAMALLA	14269201	SRIRAMPUR	2123DT281	100	MIXED	AMI	Yes	0%	66	0.0354922	0.02062	0.0148722	41.90%
3275	TPCODL	BBSR2	KHD	BEGUNIA	GEDIAPALI ODSSP	14269	11 KV KADHAMALLA	14269201	THANAPALLI	2123DT287	100	MIXED	AMI	Yes	33%	138	0.0778914	0.047588	0.0303034	38.90%
3276	TPCODL	BBSR2	KHD	BEGUNIA	GEDIAPALI ODSSP	14269	11 KV GEDIAPALLI	14269203	KANTABADA	2121DT367	100	MIXED	AMI	Yes	0%	149	0.0473358	0.041426	0.0059098	12.48%
3277	TPCODL	BBSR2	KHD	BEGUNIA	GEDIAPALI ODSSP	14269	11 KV GEDIAPALLI	14269203	MAKUNDAPUR	2121DT370	100	MIXED	AMI	Yes	33%	136	0.07488706	0.04135	0.03353706	44.78%
3278	TPCODL	BBSR2	KHD	BEGUNIA	GEDIAPALI ODSSP	14269	11 KV GEDIAPALLI	14269203	MALIPADAR	2121DT392	100	MIXED	AMI	Yes	33%	104	0.04572684	0.025257	0.02046984	44.77%
3279	TPCODL	BBSR2	KHD	BEGUNIA	GEDIAPALI ODSSP	14269	11 KV GEDIAPALLI	14269203	PANDALAM NO1	2121DT394	250	MIXED	AMI	Yes	33%	240	0.08700228	0.061724	0.02527828	29.05%
3280	TPCODL	BBSR2	KHD	BEGUNIA	GEDIAPALI ODSSP	14269	11 KV GEDIAPALLI	14269203	PANIKORADA	2121DT397	100	MIXED	AMI	Yes	33%	135	0.07577012	0.041824	0.03394612	44.80%
3281	TPCODL	BBSR2	KHD	BEGUNIA	GEDIAPALI ODSSP	14269	11 KV GEDIAPALLI	14269203	KUSUPALLA TANGI SAHI NO-2	2121DT423	100	MIXED	AMI	Yes	33%	102	0.08084154	0.036244	0.04459754	55.17%
3282	TPCODL	BBSR2	KHD	BEGUNIA	GEDIAPALI ODSSP	14269	11 KV GEDIAPALLI	14269203	KUSUPALLA NO-2	2121DT425	100	MIXED	AMI	Yes	33%	79	0.0451539	0.037833	0.0073209	16.21%
3283	TPCODL	BBSR2	KHD	BEGUNIA	GEDIAPALI ODSSP	14269	11 KV GEDIAPALLI	14269203	KUSUPALLA NUA BHOI SAHI	2121DT434	100	MIXED	AMI	Yes	33%	36	0.04634646	0.019391	0.02695546	58.16%
3284	TPCODL	BBSR2	KHD	BEGUNIA	GEDIAPALI ODSSP	14269	11 KV GEDIAPALLI	14269203	BADASAHI BADABEN	2123DT415	63	MIXED	AMI	Yes	33%	93	0.06585688	0.016043	0.04981388	75.64%

Sl. No.	Zone Name	Circle name	Division name	Name of the Sub-division	Name of the Sub-station	Substation Code	Name of the 11 kV Feeder	Feeder Code	Name of the Location where DT situated	DT code	DT Capacity (kVA)	Predominant consumer type of DT (Domestic/Industrial/Agriculture/Mixed)	Type of metering AMR/AMI/ Communicable/Conventional metered/Unmetered	Status of Meter- whether Functional (Yes/No)	% of data received automatically (if AMR/AMI)	No. of Connected Consumers	Input Energy (MU) (A)	Billed Energy (MU) (B)	Loss (MU) (A-B)	% DT Loss (A-B)/A
3285	TPCODL	BBSR2	KHD	BEGUNIA	GEDIAPALI ODSSP	14269	11 KV GEDIAPALLI	14269203	NUA SHAI BADABEN	2123DT420	100	MIXED	AMI	Yes	67%	84	0.02840196	0.023431	0.00497096	17.50%
3286	TPCODL	BBSR2	KHD	BEGUNIA	HATABASTA DDUGJ	14374	11 KV Hatabasta Feeder	14374201	HATABASTA	2124DT461	100	MIXED	AMI	Yes	67%	63	0.05593956	0.020815	0.03512456	62.79%
3287	TPCODL	BBSR2	KHD	BEGUNIA	HATABASTA DDUGJ	14374	11 KV Hatabasta Feeder	14374201	HARIKESWAR	2124DT467	100	MIXED	AMI	Yes	0%	58	0.02800988	0.012935	0.01507488	53.82%
3288	TPCODL	BBSR2	KHD	BEGUNIA	HATABASTA DDUGJ	14374	11 KV Hatabasta Feeder	14374201	BANKOI MEDICAL CHHACK	2124DT484	100	MIXED	AMI	Yes	67%	65	0.0381526	0.022334	0.0158186	41.46%
3289	TPCODL	BBSR2	KHD	BEGUNIA	HATABASTA DDUGJ	14374	11 KV Hatabasta Feeder	14374201	SAHAJAPUR	2124DT498	100	MIXED	AMI	Yes	67%	78	0.05069982	0.025954	0.02474582	48.81%
3290	TPCODL	BBSR2	KHD	BEGUNIA	HATABASTA DDUGJ	14374	11 KV Hatabasta Feeder	14374201	BENAGADIA	2124DT514	100	MIXED	AMI	Yes	67%	72	0.03055136	0.021992	0.00855936	28.02%
3291	TPCODL	BBSR2	KHD	BEGUNIA	HATABASTA DDUGJ	14374	11 KV KUMBHARI	14374202	BADAKUMARI NEAR SANI TEMPLE	2124DT579	100	MIXED	AMI	Yes	67%	73	0.06753996	0.02542	0.04211996	62.36%
3292	TPCODL	BBSR2	KHD	BEGUNIA	KALAPATHAR	14048	11 KV BAIDESWAR	14048201	PURUNAPANI	2123DT107	100	MIXED	AMI	Yes	33%	47	0.01089222	0.010373	0.00051922	4.77%
3293	TPCODL	BBSR2	KHD	BEGUNIA	KALAPATHAR	14048	11 KV BAIDESWAR	14048201	NANDA HATAPALI	2123DT112	250	MIXED	AMI	Yes	33%	96	0.03977408	0.022401	0.01737308	43.68%
3294	TPCODL	BBSR2	KHD	BEGUNIA	KALAPATHAR	14048	11 KV BAIDESWAR	14048201	GOPINATHPUR	2123DT137	100	MIXED	AMI	Yes	33%	186	0.05257636	0.047669	0.00490736	9.33%
3295	TPCODL	BBSR2	KHD	BEGUNIA	KALAPATHAR	14048	11 KV BAIDESWAR	14048201	MANAPUR	2123DT139	100	MIXED	AMI	Yes	33%	40	0.04312946	0.010799	0.03233046	74.96%
3296	TPCODL	BBSR2	KHD	BEGUNIA	KALAPATHAR	14048	11 KV BAIDESWAR	14048201	KENDUPALI ADIBASISAHI	2123DT145	100	MIXED	AMI	Yes	33%	53	0.02406378	0.011766	0.01229778	51.10%
3297	TPCODL	BBSR2	KHD	BEGUNIA	KALAPATHAR	14048	11 KV BAIDESWAR	14048201	GOPABANDHU NAGAR	2123DT151	100	MIXED	AMI	Yes	33%	51	0.03680614	0.014777	0.02202914	59.85%
3298	TPCODL	BBSR2	KHD	BEGUNIA	KALAPATHAR	14048	11 KV BAIDESWAR	14048201	GOPABANDHU NAGAR	2123DT152	100	MIXED	AMI	Yes	0%	60	0.0512498	0.019861	0.0313888	61.25%
3299	TPCODL	BBSR2	KHD	BEGUNIA	KALAPATHAR	14048	11 KV BAIDESWAR	14048201	HARIJANSAHI KENDUPALI	2123DT155	100	MIXED	AMI	Yes	0%	145	0.04908816	0.034745	0.01434316	29.22%
3300	TPCODL	BBSR2	KHD	BEGUNIA	KALAPATHAR	14048	11 KV BAIDESWAR	14048201	NUASAHI	2123DT157	100	MIXED	AMI	Yes	100%	69	0.03508026	0.012214	0.02286626	65.18%
3301	TPCODL	BBSR2	KHD	BEGUNIA	KALAPATHAR	14048	11 KV BAIDESWAR	14048201	BALA BADHRA PUR	2123DT163	100	MIXED	AMI	Yes	33%	68	0.04007272	0.020133	0.01993972	49.76%
3302	TPCODL	BBSR2	KHD	BEGUNIA	KALAPATHAR	14048	11 KV BAIDESWAR	14048201	MALISAHI	2123DT175	100	MIXED	AMI	Yes	0%	92	0.03950256	0.023475	0.01602756	40.57%
3303	TPCODL	BBSR2	KHD	BEGUNIA	KALAPATHAR	14048	11 KV BAIDESWAR	14048201	KOTHAPATNA	2123DT183	100	MIXED	AMI	Yes	0%	85	0.04054494	0.021221	0.01932394	47.66%
3304	TPCODL	BBSR2	KHD	BEGUNIA	KALAPATHAR	14048	11 KV BAIDESWAR	14048201	BAIDESWAR BAZAR	2123DT193	100	MIXED	AMI	Yes	0%	69	0.04726424	0.032109	0.01515524	32.06%
3305	TPCODL	BBSR2	KHD	BEGUNIA	KALAPATHAR	14048	11 KV BAIDESWAR	14048201	COLLEGE	2123DT195	100	MIXED	AMI	Yes	0%	61	0.05304414	0.029075	0.02396914	45.19%
3306	TPCODL	BBSR2	KHD	BEGUNIA	KALAPATHAR	14048	11 KV BAIDESWAR	14048201	ALASUA	2123DT275	100	MIXED	AMI	Yes	0%	76	0.04409794	0.022523	0.02157494	48.93%
3307	TPCODL	BBSR2	KHD	BEGUNIA	KALAPATHAR	14048	11 KV KALAPATHAR	14048203	KAPILESWAR -1 ADIBASI SAHI	2123DT008	250	MIXED	AMI	Yes	0%	91	0.13401844	0.057153	0.07686544	57.35%
3308	TPCODL	BBSR2	KHD	BEGUNIA	KALAPATHAR	14048	11 KV KALAPATHAR	14048203	KAPILESWAR -2 HARIRAM CHOWK	2123DT009	250	MIXED	AMI	Yes	67%	107	0.10117004	0.040815	0.06035504	59.66%
3309	TPCODL	BBSR2	KHD	BEGUNIA	KALAPATHAR	14048	11 KV KALAPATHAR	14048203	KALAPATHARA TALASAHI	2123DT013	250	MIXED	AMI	Yes	67%	97	0.12964456	0.046828	0.08281656	63.88%
3310	TPCODL	BBSR2	KHD	BEGUNIA	KALAPATHAR	14048	11 KV KALAPATHAR	14048203	ANKUR GADIA KALAPATHARA	2123DT020	250	MIXED	AMI	Yes	100%	163	0.12941712	0.065138	0.06427912	49.67%
3311	TPCODL	BBSR2	KHD	BEGUNIA	KALAPATHAR	14048	11 KV KALAPATHAR	14048203	ANKURGADIA MADHUPALLI	2123DT021	250	MIXED	AMI	Yes	67%	178	0.10839032	0.041033	0.06735732	62.14%
3312	TPCODL	BBSR2	KHD	BEGUNIA	KALAPATHAR	14048	11 KV KALAPATHAR	14048203	LUHAGODI	2123DT024	100	MIXED	AMI	Yes	67%	86	0.0457279	0.028956	0.0167719	36.68%
3313	TPCODL	BBSR2	KHD	BEGUNIA	KALAPATHAR	14048	11 KV KALAPATHAR	14048203	KRUSHNAPALLI SHIVMANDIR -1	2123DT034	100	MIXED	AMI	Yes	0%	78	0.04047602	0.019309	0.02116702	52.30%
3314	TPCODL	BBSR2	KHD	BEGUNIA	KALAPATHAR	14048	11 KV KALAPATHAR	14048203	KRUSHANA PALL	2123DT036	100	MIXED	AMI	Yes	67%	129	0.05385266	0.036162	0.01769066	32.85%
3315	TPCODL	BBSR2	KHD	BEGUNIA	KALAPATHAR	14048	11 KV KALAPATHAR	14048203	KRUSHANA PALLI-3	2123DT038	100	MIXED	AMI	Yes	67%	22	0.02571334	0.007109	0.01860434	72.35%
3316	TPCODL	BBSR2	KHD	BEGUNIA	KALAPATHAR	14048	11 KV KALAPATHAR	14048203	PATAPUR SASAN	2123DT055	100	MIXED	AMI	Yes	67%	37	0.02266942	0.010874	0.01179542	52.03%
3317	TPCODL	BBSR2	KHD	BEGUNIA	KALAPATHAR	14048	11 KV KALAPATHAR	14048203	KADUAPADA	2123DT056	100	MIXED	AMI	Yes	67%	57	0.02872212	0.01317	0.01555212	54.15%
3318	TPCODL	BBSR2	KHD	BEGUNIA	KALAPATHAR	14048	11 KV KALAPATHAR	14048203	MADHUPALLI	2123DT081	100	MIXED	AMI	Yes	67%	77	0.0386837	0.020404	0.0182797	47.25%
3319	TPCODL	BBSR2	KHD	BEGUNIA	PARICHHAL	14041	11 KV GADAMANITRI	14041201	LOKIPUR NO-1	2122DT167	100	MIXED	AMI	Yes	100%	82	0.04531934	0.029739	0.01558034	34.38%
3320	TPCODL	BBSR2	KHD	BEGUNIA	PARICHHAL	14041	11 KV PATANAHAT	14041204	PATNA HATA	2122DT209	250	MIXED	AMI	Yes	67%	184	0.09608648	0.058373	0.03771348	39.25%
3321	TPCODL	BBSR2	KHD	BEGUNIA	PARICHHAL	14041	11 KV PATANAHAT	14041204	HIRAPUR MAIN VILLAGE	2122DT264	100	MIXED	AMI	Yes	33%	123	0.04699184	0.031825	0.01516684	32.28%
3322	TPCODL	BBSR2	KHD	BEGUNIA	PARICHHAL	14041	11 KV PATANAHAT	14041204	GOUDIAPADA MAIN VILLAGE	2122DT272	100	MIXED	AMI	Yes	0%	69	0.01655542	0.015288	0.00126742	7.66%
3323	TPCODL	BBSR2	KHD	BEGUNIA	PARICHHAL	14041	11 KV PATANAHAT	14041204	CHATRAPADA MAIN VILLAGE	2122DT293	100	MIXED	AMI	Yes	67%	130	0.0665758	0.04321	0.0233658	35.10%
3324	TPCODL	BBSR2	KHD	BEGUNIA	RAJSUNAKHALA	14042	11 KV BAYAPALLI	14042201	UASHAPATANA	2124DT006	100	MIXED	AMI	Yes	100%	141	0.05787658	0.044035	0.01384158	23.92%
3325	TPCODL	BBSR2	KHD	BEGUNIA	RAJSUNAKHALA	14042	11 KV KADABA	14042202	CHAMPAILO	2124DT090	100	MIXED	AMI	Yes	67%	76	0.05422968	0.02463	0.02959968	54.58%
3326	TPCODL	BBSR2	KHD	BEGUNIA	RAJSUNAKHALA	14042	11 KV KADABA	14042202	JOGAMAYA CHHACK NO-1	2124DT110	100	MIXED	AMI	Yes	33%	139	0.03535444	0.029562	0.00579244	16.38%
3327	TPCODL	BBSR2	KHD	BEGUNIA	RAJSUNAKHALA	14042	11 KV KADABA	14042202	ARIKAMA PRIMERY SCHOOL	2124DT150	100	MIXED	AMI	Yes	33%	60	0.03432392	0.015193	0.01913092	55.74%
3328	TPCODL	BBSR2	KHD	BEGUNIA	RAJSUNAKHALA	14042	11 KV KADABA	14042202	GODI POKHARI NO-2	2124DT155	100	MIXED	AMI	Yes	33%	77	0.05932386	0.020733	0.03859086	65.05%
3329	TPCODL	BBSR2	KHD	BEGUNIA	RAJSUNAKHALA	14042	11 KV KADABA	14042202	PATANA SAHI PICHUKOLI	2124DT179	100	MIXED	AMI	Yes	100%	90	0.08864526	0.037638	0.05100726	57.54%
3330	TPCODL	BBSR2	KHD	BEGUNIA	RAJSUNAKHALA	14042	11 KV SUNAKHELA	14042203	DIHAGAON COLONY	2124DT201	100	MIXED	AMI	Yes	100%	106	0.1134892	0.07251	0.0409792	36.11%
3331	TPCODL	BBSR2	KHD	BEGUNIA	RAJSUNAKHALA	14042	11 KV SUNAKHELA	14042203	JOSHI SAHI	2124DT206	100	MIXED	AMI	Yes	100%	79	0.08396572	0.030533	0.05343272	63.64%
3332	TPCODL	BBSR2	KHD	BEGUNIA	RAJSUNAKHALA	14042	11 KV SUNAKHELA	14042203	RAJSHUNAKALA BUS STAND	2124DT214	500	MIXED	AMI	Yes	0%	163	0.31498176	0.145178	0.16980376	53.91%
3333	TPCODL	BBSR2	KHD	BEGUNIA	RAJSUNAKHALA	14042	11 KV SUNAKHELA	14042203	ANKULAPATANA SAHI	2124DT235	100	MIXED	AMI	Yes	0%	148	0.10157324	0.063685	0.03788824	37.30%
3334	TPCODL	BBSR2	KHD	BEGUNIA	RAJSUNAKHALA	14042	11 KV SUNAKHELA	14042203	GANESH BAZAR NO-1	2124DT266	500	MIXED	AMI	Yes	100%	274	0.467632	0.142852	0.32478	69.45%
3335	TPCODL	BBSR2	KHD	BEGUNIA	RAJSUNAKHALA	14042	11 KV SUNAKHELA	14042203	MUSLIM SAHI	2124DT268	100	MIXED	AMI	Yes	33%	30	0.045049	0.010633	0.034416	76.40%
3336	TPCODL	BBSR2	KHD	BEGUNIA	RAJSUNAKHALA	14042	11 KV BANKOI	14042204	RAMABILA BRAMHAN SAHI	2124DT609	100	MIXED	AMI	Yes	0%	109	0.05929168	0.04076008	0.0185316	31.25%
3337	TPCODL	BBSR2	KHD	BEGUNIA	RAJSUNAKHALA	14042	11 KV BANKOI	14042204	GOPALIPADA NO-1	2124DT658	100	MIXED	AMI	Yes	33%	24	0.01724146	0.004524	0.01271746	73.76%
3338	TPCODL	BBSR2	KHD	BEGUNIA	RAJSUNAKHALA	14042	11 KV BANKOI	14042204	KASANDA	2124DT683	100	MIXED	AMI	Yes	0%	117	0.02922804	0.027797	0.00143104	4.90%
3339	TPCODL	BBSR2	KHD	BEGUNIA	RAJSUNAKHALA	14042	11 KV BANKOI	14042204	SURKABADI	2124DT697	100	MIXED	AMI	Yes	67%	109	0.0348918	0.025611	0.0092808	26.60%
3340	TPCODL	BBSR2	KHD	BEGUNIA	RAJSUNAKHALA	14042	11 KV BANKOI	14042204	SURKABADI VILLAGE	2124DT700	100	MIXED	AMI	Yes	33%	92	0.04738352	0.028448	0.01893552	39.96%
3341	TPCODL	BBSR2	KHD	BEGUNIA	RAJSUNAKHALA	14042	11 KV SANA PADAR	14042205	SUNAPADAR NO-3	2124DT324	100	MIXED	AMI	Yes	100%	118	0.05982524	0.021924	0.03790124	63.35%
3342	TPCODL	BBSR2	KHD	BEGUNIA	RAJSUNAKHALA	14042	11 KV SANA PADAR	14042205	SUNAPADAR NO-4	2124DT326	100	MIXED	AMI	Yes	100%	94	0.04583008	0.021412	0.02441808	53.28%
3343	TPCODL	BBSR2	KHD	BEGUNIA	RAJSUNAKHALA	14042	11 KV SANA PADAR	14042205	NAYAPALLI	2124DT352	100	MIXED	AMI	Yes	100%	53	0.0262714	0.01505	0.0112214	42.71%
3344	TPCODL	BBSR2	KHD	BEGUNIA	RAJSUNAKHALA	14042	11 KV SANA PADAR	14042205	DEULI ROAD SAHI	2124DT356	63	MIXED	AMI	Yes	67%	44	0.02024136	0.016453	0.00378836	18.72%
3345	TPCODL	BBSR2	KHD	BEGUNIA	RAJSUNAKHALA	14042	11 KV SANA PADAR	14042205	SIMAPALLI	2124DT368	100	MIXED	AMI	Yes	0%	61	0.0215514	0.01918	0.0023714	11.00%
3346	TPCODL	BBSR2	KHD	BEGUNIA	RAJSUNAKHALA	14042	11 KV SANA PADAR	14042205	BARABATI	2124DT413	100	MIXED	AMI	Yes	0%	135	0.05456324	0.03111837	0.02344487	42.97%
3347	TPCODL	BBSR2	KHD	BEGUNIA	RAJSUNAKHALA	14042	11 KV SANA PADAR	14042205	SANAPADAR NO-1	2124DT420	100	MIXED	AMI	Yes	100%	123	0.0725715	0.05407099	0.01850051	25.49%
3348	TPCODL	BBSR2	KHD	BEGUNIA	TIRIMAL	14050	11 KV TARABOI	14050202	DEULABASTA S/S NO-4	2153DT452	100	MIXED	AMI	Yes	0%	69	0.07049082	0.035836	0.03465482	49.16%
3349	TPCODL	BBSR2	KHD	JANKIA	(ATHATIRA) BALIPAI	14272	SAHUPADA	14272201	BHATAPADA	2133DT060	100	MIXED	AMI	Yes	67%	102	0.05229546	0.031897	0.02039846	39.01%
3350	TPCODL	BBSR2	KHD	JANKIA	(ATHATIRA) BALIPAI	14272	KHUNTIABANPUR	14272202	ADAL POKHARI_01	2133DT106	100	MIXED	AMI	Yes	67%	41	0.03685215	0.011227	0.02562515	69.54%
3351	TPCODL	BBSR2	KHD	JANKIA	(ATHATIRA) BALIPAI	14272	BALIPADA	14272203	MAITRA TRILOCHANPUR	2133DT174	100	MIXED	AMI	Yes	67%	88	0.03721196	0.030879	0.00633296	17.02%
3352	TPCODL	BBSR2	KHD	JANKIA	CHHANAGIRI ODSSP	14273	11 KV CHHANAGIRI	14273201	CHANAGIRI NO-3	2131DT203	100	MIXED	AMI	Yes	67%	152	0.13063176	0.055432	0.07519976	57.57%
3353	TPCODL	BBSR2	KHD	JANKIA	CHHANAGIRI ODSSP	14273	11 KV CHHANAGIRI	14273201	BHOI SAHI	2131DT207	63	MIXED	AMI	Yes	100%	105	0.05150623	0.032837	0.01866923	36.25%
3354	TPCODL	BBSR2	KHD	JANKIA	CHHANAGIRI ODSSP	14273	11 KV CHHANAGIRI	14273201	CHNAGIRI NO-4	2131DT211	100	MIXED	AMI	Yes	100%	89	0.05791274	0.03049	0.02742274	47.35%
3355	TPCODL	BBSR2	KHD	JANKIA	CHHANAGIRI ODSSP	14273	11 KV CHHANAGIRI	14273201	CHANAGIRI NO-2	2131DT220	100	MIXED	AMI	Yes	100%	137	0.10969536	0.04373	0.06596536	60.14%
3356	TPCODL	BBSR2	KHD	JANKIA	CHHANAGIRI ODSSP	14273	11 KV HAJA(Chhanagiri P	14273202	KALARAJHARA	2131DT343	100	MIXED	AMI	Yes	67%	133	0.06906762	0.03434458	0.03472304	50.27%
3357	TPCODL	BBSR2	KHD	JANKIA	CHHANAGIRI ODSSP	14273	11 KV HAJA(Chhanagiri P	14273202	HAJA NO -1	2131DT347	100	MIXED	AMI	Yes	67%	86	0.04807182	0.033041	0.01503082	31.27%

Sl. No.	Zone Name	Circle name	Division name	Name of the Sub-division	Name of the Sub-station	Substation Code	Name of the 11 kV Feeder	Feeder Code	Name of the Location where DT situated	DT code	DT Capacity (kVA)	Predominant consumer type of DT (Domestic/Industrial/Agriculture/Mixed)	Type of metering AMR/AMI/ Communicable/Conventional metered/Unmetered	Status of Meter-whether Functional (Yes/No)	% of data received automatically (if AMR/AMI)	No. of Connected Consumers	Input Energy (MU) (A)	Billed Energy (MU) (B)	Loss (MU) (A-B)	% DT Loss (A-B)/A
3358	TPCODL	BBSR2	KHD	JANKIA	CHHANAGIRI ODSSP	14273	11 KV HAJA(Chhanagiri P	14273202	HAJA MEDICAL	2131DT350	100	MIXED	AMI	Yes	0%	126	0.05139476	0.050417	0.00097776	1.90%
3359	TPCODL	BBSR2	KHD	JANKIA	CHHANAGIRI ODSSP	14273	11 KV HAJA(Chhanagiri P	14273202	HAJA GODISAHI	2131DT352	100	MIXED	AMI	Yes	67%	81	0.0276749	0.026671	0.0010039	3.63%
3360	TPCODL	BBSR2	KHD	JANKIA	CHHANAGIRI ODSSP	14273	11 KV HAJA(Chhanagiri P	14273202	NALSINGH-1	2131DT396	100	MIXED	AMI	Yes	67%	136	0.06917864	0.029673	0.03950564	57.11%
3361	TPCODL	BBSR2	KHD	JANKIA	CHHANAGIRI ODSSP	14273	11 KV HAJA(Chhanagiri P	14273202	TANKOLA NO-1	2131DT399	100	MIXED	AMI	Yes	100%	75	0.05357882	0.01769	0.03588882	66.98%
3362	TPCODL	BBSR2	KHD	JANKIA	CHHANAGIRI ODSSP	14273	11 KV HAJA(Chhanagiri P	14273202	TANKOLA NO-2	2131DT401	100	MIXED	AMI	Yes	67%	77	0.0527479	0.021176	0.0315719	59.85%
3363	TPCODL	BBSR2	KHD	JANKIA	CHHANAGIRI ODSSP	14273	11 KV SARAPARI	14273203	SARAPARI NO-2	2131DT087	100	MIXED	AMI	Yes	67%	96	0.04171244	0.040536	0.00117644	2.82%
3364	TPCODL	BBSR2	KHD	JANKIA	CHHANAGIRI ODSSP	14273	11 KV SARAPARI	14273203	SARAPARI NO-1	2131DT099	100	MIXED	AMI	Yes	0%	116	0.11173878	0.033008	0.07873078	70.46%
3365	TPCODL	BBSR2	KHD	JANKIA	CHHANAGIRI ODSSP	14273	11 KV SIKO	14273204	EKADALIA NO-1	2131DT412	100	MIXED	AMI	Yes	67%	113	0.06131256	0.03241861	0.02889395	47.13%
3366	TPCODL	BBSR2	KHD	JANKIA	CHHANAGIRI ODSSP	14273	11 KV SIKO	14273204	SIKO NO-4	2131DT421	63	MIXED	AMI	Yes	0%	142	0.05416435	0.047219	0.00694535	12.82%
3367	TPCODL	BBSR2	KHD	JANKIA	CHHANAGIRI ODSSP	14273	11 KV SIKO	14273204	SIKO NO-1	2131DT429	250	MIXED	AMI	Yes	67%	143	0.08076076	0.044612	0.03614876	44.76%
3368	TPCODL	BBSR2	KHD	JANKIA	CHHANAGIRI ODSSP	14273	11 KV SIKO	14273204	SIKO NO -3	2131DT435	250	MIXED	AMI	Yes	67%	108	0.10988644	0.050743	0.05914344	53.82%
3369	TPCODL	BBSR2	KHD	JANKIA	CHHANAGIRI ODSSP	14273	11 KV SIKO	14273204	KHADIPADAR NO-1	2131DT444	100	MIXED	AMI	Yes	67%	103	0.04721442	0.028033	0.01918142	40.63%
3370	TPCODL	BBSR2	KHD	JANKIA	JANKIA	14037	11 KV OLASINGH	14037201	NUAGAON	2131DT008	100	MIXED	AMI	Yes	67%	104	0.08433374	0.069565	0.01476874	17.51%
3371	TPCODL	BBSR2	KHD	JANKIA	JANKIA	14037	11 KV OLASINGH	14037201	RAMBHABILI-2	2131DT016	63	MIXED	AMI	Yes	0%	155	0.04770073	0.039346	0.00835473	17.51%
3372	TPCODL	BBSR2	KHD	JANKIA	JANKIA	14037	11 KV OLASINGH	14037201	RAMBHABILI-1	2131DT017	100	MIXED	AMI	Yes	67%	181	0.11196236	0.048061	0.06390136	57.07%
3373	TPCODL	BBSR2	KHD	JANKIA	JANKIA	14037	11 KV OLASINGH	14037201	GAYABANDHA	2131DT039	100	MIXED	AMI	Yes	67%	46	0.09564682	0.021661	0.07398582	77.35%
3374	TPCODL	BBSR2	KHD	JANKIA	JANKIA	14037	11 KV OLASINGH	14037201	KAMALA BIMALA NO-1	2131DT047	100	MIXED	AMI	Yes	67%	112	0.0501496	0.035104	0.0150456	30.00%
3375	TPCODL	BBSR2	KHD	JANKIA	JANKIA	14037	11 KV OLASINGH	14037201	OLASINGH NO-3	2131DT054	100	MIXED	AMI	Yes	33%	49	0.05363296	0.019701	0.03393196	63.27%
3376	TPCODL	BBSR2	KHD	JANKIA	JANKIA	14037	11 KV OLASINGH	14037201	OLASING NO-4	2131DT060	100	MIXED	AMI	Yes	100%	129	0.05848968	0.037746	0.02074368	35.47%
3377	TPCODL	BBSR2	KHD	JANKIA	JANKIA	14037	11 KV OLASINGH	14037201	DEULI	2131DT065	100	MIXED	AMI	Yes	67%	82	0.04264298	0.022226	0.02041698	47.88%
3378	TPCODL	BBSR2	KHD	JANKIA	JANKIA	14037	11 KV OLASINGH	14037201	OGALAPUR	2131DT075	100	MIXED	AMI	Yes	0%	55	0.05991926	0.012816	0.04710326	78.61%
3379	TPCODL	BBSR2	KHD	JANKIA	JANKIA	14037	11 KV GOLABAI	14037202	JANKIA BAZAR -1	2131DT101	250	MIXED	AMI	Yes	100%	138	0.20142948	0.055536	0.14589348	72.43%
3380	TPCODL	BBSR2	KHD	JANKIA	JANKIA	14037	11 KV GOLABAI	14037202	MOTA	2131DT128	100	MIXED	AMI	Yes	0%	139	0.11980568	0.06954722	0.05025846	41.95%
3381	TPCODL	BBSR2	KHD	JANKIA	JANKIA	14037	11 KV NIRAKARPUR-2	14037203	KHAJURIPADA ODIA TANGI SAHI	2133DT222	100	MIXED	AMI	Yes	67%	19	0.03760284	0.009202	0.02840084	75.53%
3382	TPCODL	BBSR2	KHD	JANKIA	JANKIA	14037	11 KV NIRAKARPUR-2	14037203	NANAPADA SAHI-2	2133DT251	100	MIXED	AMI	Yes	67%	41	0.04734658	0.022076	0.02527058	53.37%
3383	TPCODL	BBSR2	KHD	JANKIA	JANKIA	14037	11 KV NIRAKARPUR-2	14037203	BADURABAR ROAD SIDE	2133DT278	63	MIXED	AMI	Yes	0%	83	0.04698107	0.03045	0.01653107	35.19%
3384	TPCODL	BBSR2	KHD	JANKIA	JANKIA	14037	11 KV NIRAKARPUR-2	14037203	BADURABAR VILLAGE	2133DT279	100	MIXED	AMI	Yes	0%	126	0.0489773	0.038116	0.0108613	22.18%
3385	TPCODL	BBSR2	KHD	JANKIA	JANKIA	14037	11 KV NIRAKARPUR-2	14037203	NANAPADA SAHI-1	2133DT309	100	MIXED	AMI	Yes	67%	117	0.08604664	0.04927	0.03677664	42.74%
3386	TPCODL	BBSR2	KHD	JANKIA	JANKIA	14037	11 KV NIRAKARPUR-2	14037203	NIRAKARPUR MARKET	2133DT310	500	MIXED	AMI	Yes	0%	185	0.29001864	0.139464	0.15055464	51.91%
3387	TPCODL	BBSR2	KHD	JANKIA	JANKIA	14037	11 KV BADAPOKHARIA	14037204	KANTHAPUR	2131DT302	100	MIXED	AMI	Yes	100%	101	0.08086714	0.017976	0.06289114	77.77%
3388	TPCODL	BBSR2	KHD	JANKIA	JANKIA	14037	11 KV BADAPOKHARIA	14037204	TOTAPADA	2131DT319	100	MIXED	AMI	Yes	100%	90	0.03332378	0.02252	0.01080378	32.42%
3389	TPCODL	BBSR2	KHD	JANKIA	JANLA	14034	11 KV OIL MILL-1	14034202	BHATAKHUDI-1	2142DT317	250	MIXED	AMI	Yes	100%	118	0.1053836	0.062673	0.0427106	40.53%
3390	TPCODL	BBSR2	KHD	JANKIA	MALIPADA	14038	11 KV NARANGARH-1	14038201	ROAD SIDE	2132DT452	100	MIXED	AMI	Yes	100%	79	0.11199946	0.023332	0.08866746	79.17%
3391	TPCODL	BBSR2	KHD	JANKIA	MALIPADA	14038	11 KV NARANGARH-1	14038201	HANUMAN TEMPLE	2132DT453	250	MIXED	AMI	Yes	0%	251	0.36762132	0.095853	0.27176832	73.93%
3392	TPCODL	BBSR2	KHD	JANKIA	MALIPADA	14038	11 KV NARANGARH-1	14038201	HARIJANA SAHI	2132DT454	100	MIXED	AMI	Yes	100%	104	0.11887414	0.037021	0.08185314	68.86%
3393	TPCODL	BBSR2	KHD	JANKIA	MALIPADA	14038	11 KV NARANGARH-1	14038201	ADIBASI SAHI	2132DT455	100	MIXED	AMI	Yes	0%	81	0.092897	0.019289	0.073608	79.24%
3394	TPCODL	BBSR2	KHD	JANKIA	MALIPADA	14038	11 KV NARANGARH-1	14038201	MATHA SAHI-1	2132DT457	100	MIXED	AMI	Yes	100%	121	0.07142386	0.052935	0.01848886	25.89%
3395	TPCODL	BBSR2	KHD	JANKIA	MALIPADA	14038	11 KV NARANGARH-1	14038201	MATHA SAHI-2	2132DT458	100	MIXED	AMI	Yes	100%	93	0.0869806	0.029032	0.0579486	66.62%
3396	TPCODL	BBSR2	KHD	JANKIA	MALIPADA	14038	11 KV NARANGARH-1	14038201	CHAMPAJHARA	2132DT461	100	MIXED	AMI	Yes	33%	117	0.12969646	0.042933	0.08676346	66.90%
3397	TPCODL	BBSR2	KHD	JANKIA	MALIPADA	14038	11 KV NARANGARH-1	14038201	PANICHATRA NEW	2132DT473	100	MIXED	AMI	Yes	100%	122	0.05503292	0.042094	0.01293892	23.51%
3398	TPCODL	BBSR2	KHD	JANKIA	MALIPADA	14038	11 KV NARANGARH-1	14038201	PANICHATRA OLD	2132DT475	100	MIXED	AMI	Yes	100%	104	0.09017424	0.04505	0.04512424	50.04%
3399	TPCODL	BBSR2	KHD	JANKIA	MALIPADA	14038	11 KV NARANGARH-1	14038201	DURGAPRASAD	2132DT479	100	MIXED	AMI	Yes	100%	88	0.0355648	0.02535	0.0102148	28.72%
3400	TPCODL	BBSR2	KHD	JANKIA	MALIPADA	14038	11 KV NARANGARH-1	14038201	NARANGARH BAZAR	2132DT490	100	MIXED	AMI	Yes	0%	55	0.06182172	0.028947	0.03287472	53.18%
3401	TPCODL	BBSR2	KHD	JANKIA	MALIPADA	14038	11 KV MALIPADA TAPAN	14038202	JAY GURU	2132DT305	100	MIXED	AMI	Yes	100%	44	0.03650772	0.027292	0.00921572	25.24%
3402	TPCODL	BBSR2	KHD	JANKIA	MALIPADA	14038	11 KV MALIPADA TAPAN	14038202	BEHERA SS	2132DT314	100	MIXED	AMI	Yes	100%	9	0.0094751	0.006827	0.0026481	27.95%
3403	TPCODL	BBSR2	KHD	JANKIA	MALIPADA	14038	11 KV MALIPADA TAPAN	14038202	AHOK RAY SUBSTATION OCC CHHAK	2132DT322	100	MIXED	AMI	Yes	100%	31	0.02091176	0.011218	0.00969376	46.36%
3404	TPCODL	BBSR2	KHD	JANKIA	MALIPADA	14038	11 KV MALIPADA TAPAN	14038202	JHINKIJHARI MELANA PADIA	2132DT345	100	MIXED	AMI	Yes	100%	97	0.0805296	0.045263	0.0352666	43.79%
3405	TPCODL	BBSR2	KHD	JANKIA	MALIPADA	14038	11 KV CHATARAMA	14038204	OCC CHHAKA SUBSTATION	2132DT108	100	MIXED	AMI	Yes	0%	11	0.00911542	0.003146	0.00596942	65.49%
3406	TPCODL	BBSR2	KHD	JANKIA	MALIPADA	14038	11 KV CHATARAMA	14038204	CHHATRAMA VILLAGE	2132DT399	100	MIXED	AMI	Yes	0%	69	0.0593397	0.042828	0.0165117	27.83%
3407	TPCODL	BBSR2	KHD	JANKIA	NARANGARH	14039	11 KV NIRAKARPUR-1	14039201	KRUSHNAPUR	2132DT005	100	MIXED	AMI	Yes	100%	206	0.08047158	0.052306	0.02816558	35.00%
3408	TPCODL	BBSR2	KHD	JANKIA	NARANGARH	14039	11 KV NIRAKARPUR-1	14039201	DIBYASINGH PUR	2133DT011	63	MIXED	AMI	Yes	67%	135	0.0583044	0.041175	0.0171294	29.38%
3409	TPCODL	BBSR2	KHD	JANKIA	NARANGARH	14039	11 KV NIRAKARPUR-1	14039201	PATAJOSHIPUR	2133DT027	100	MIXED	AMI	Yes	67%	75	0.03564364	0.020405	0.01523864	42.75%
3410	TPCODL	BBSR2	KHD	JANKIA	NARANGARH	14039	11 KV NIRAKARPUR-1	14039201	MAHINDPUR	2133DT044	100	MIXED	AMI	Yes	67%	114	0.0581235	0.037544	0.0205795	35.41%
3411	TPCODL	BBSR2	KHD	JANKIA	NARANGARH	14039	11 KV NIRAKARPUR-1	14039201	JHAMPARPUR	2133DT046	100	MIXED	AMI	Yes	67%	77	0.03141204	0.01846227	0.01294977	41.23%
3412	TPCODL	BBSR2	KHD	JANKIA	NARANGARH	14039	11 KV NIRAKARPUR-1	14039201	GOPINATHPUR NR SCHOOL	2133DT169	100	MIXED	AMI	Yes	67%	107	0.03927164	0.035993	0.00327864	8.35%
3413	TPCODL	BBSR2	KHD	JANKIA	NARANGARH	14039	11 KV NIRAKARPUR-1	14039201	RENGETA	2133DT193	63	MIXED	AMI	Yes	67%	63	0.04950806	0.01688	0.03262806	65.90%
3414	TPCODL	BBSR2	KHD	JANKIA	NARANGARH	14039	11 KV MANDARBASTA	14039202	JAIPUR	2132DT030	100	MIXED	AMI	Yes	67%	31	0.06392574	0.01358	0.05034574	78.76%
3415	TPCODL	BBSR2	KHD	JANKIA	NARANGARH	14039	11 KV MANDARBASTA	14039202	MANDARBASTA	2132DT034	100	MIXED	AMI	Yes	67%	154	0.11082078	0.059746	0.05107478	46.09%
3416	TPCODL	BBSR2	KHD	JANKIA	NARANGARH	14039	11 KV MANDARBASTA	14039202	GADASANAPUT NEW JAGULISAHI	2132DT042	100	MIXED	AMI	Yes	67%	72	0.0530462	0.020734	0.0323122	60.91%
3417	TPCODL	BBSR2	KHD	JANKIA	NARANGARH	14039	11 KV MANDARBASTA	14039202	KANTABANIA	2132DT049	100	MIXED	AMI	Yes	67%	146	0.07716122	0.053453	0.02370822	30.73%
3418	TPCODL	BBSR2	KHD	JANKIA	NARANGARH	14039	11 KV MANDARBASTA	14039202	DHOLPATNA	2132DT062	100	MIXED	AMI	Yes	0%	82	0.04599062	0.022146	0.02384462	51.85%
3419	TPCODL	BBSR2	KHD	JANKIA	NARANGARH	14039	11 KV MANPUR	14039204	KRUMAPADA	2132DT209	100	MIXED	AMI	Yes	100%	110	0.10059352	0.042674	0.05791952	57.58%
3420	TPCODL	BBSR2	KHD	JANKIA	NARANGARH	14039	11 KV MANPUR	14039204	HADAPADA -1	2132DT212	100	MIXED	AMI	Yes	100%	151	0.10228758	0.047481	0.05480658	53.58%
3421	TPCODL	BBSR2	KHD	JANKIA	NARANGARH	14039	11 KV MANPUR	14039204	HADAPADA-2	2132DT213	100	MIXED	AMI	Yes	100%	70	0.0769049	0.022821	0.0540839	70.33%
3422	TPCODL	BBSR2	KHD	JANKIA	NARANGARH	14039	11 KV MANPUR	14039204	DIHAKHALA	2132DT242	100	MIXED	AMI	Yes	67%	86	0.0504332	0.024803	0.0256302	50.82%
3423	TPCODL	BBSR2	KHD	JANKIA	NARANGARH	14039	11 KV MANPUR	14039204	RAIPUR	2132DT243	100	MIXED	AMI	Yes	67%	200	0.07810524	0.044302	0.03380324	43.28%
3424	TPCODL	BBSR2	KHD	JANKIA	NARANGARH	14039	11 KV MANPUR	14039204	ORABARASINGH	2132DT247	100	MIXED	AMI	Yes	67%	30	0.04042516	0.009854	0.03057116	75.62%
3425	TPCODL	BBSR2	KHD	JANKIA	NARANGARH	14039	11 KV MANPUR	14039204	TANTULIMULA	2132DT253	100	MIXED	AMI	Yes	67%	177	0.04350118	0.039537	0.00396418	9.11%
3426	TPCODL	BBSR2	KHD	JANKIA	NARANGARH	14039	11 KV MANPUR	14039204	SABALANGA	2132DT256	100	MIXED	AMI	Yes	100%	97	0.07584296	0.02079596	0.055047	72.58%
3427	TPCODL	BBSR2	KHD	JANKIA	NARANGARH	14039	11 KV MANPUR	14039204	LAKHANPUR	2132DT261	100	MIXED	AMI	Yes	67%	36	0.01306888	0.008048	0.00502088	38.42%
3428	TPCODL	BBSR2	KHD	JANKIA	NARANGARH	14039	11 KV NARANGARH VILL	14039205	NARANGARH VILLAGE	2132DT135	100	MIXED	AMI	Yes	100%	123	0.08199504	0.049408	0.03258704	39.74%
3429	TPCODL	BBSR2	KHD	JANKIA	SANARAJUA (MEND	14268	11 KV MENDHASAL-2	14268202	MENDHASALA-1	2142DT514	250	MIXED	AMI	Yes	0%	401	0.21600528	0.210586	0.00541928	2.51%
3430	TPCODL	BBSR2	KHD	JATANI	CHHATABAR ODSSP	14270	11 KV JAMUJHARI	14270201	ARISOL	2142DT370	100	MIXED	AMI	Yes	100%	125	0.12761955	0.073537	0.05408255	42.38%

Sl. No.	Zone Name	Circle name	Division name	Name of the Sub-division	Name of the Sub-station	Substation Code	Name of the 11 kV Feeder	Feeder Code	Name of the Location where DT situated	DT code	DT Capacity (kVA)	Predominant consumer type of DT (Domestic/Industrial/Agriculture/Mixed)	Type of metering AMR/AMI/ Communicable/Conventional metered/Unmetered	Status of Meter-whether Functional (Yes/No)	% of data received automatically (if AMR/AMI)	No. of Connected Consumers	Input Energy (MU) (A)	Billed Energy (MU) (B)	Loss (MU) (A-B)	% DT Loss (A-B)/A
3431	TPCODL	BBSR2	KHD	JATANI	CHHATABAR ODSSP	14270	11 KV JAMUJHARI	14270201	DURGAPUR	2142DT374	100	MIXED	AMI	Yes	100%	101	0.0832073	0.066118	0.0170893	20.54%
3432	TPCODL	BBSR2	KHD	JATANI	CHHATABAR ODSSP	14270	11 KV JAMUJHARI	14270201	HAREKRUSHNA PUR	2142DT375	100	MIXED	AMI	Yes	100%	37	0.0720346	0.022055	0.0499796	69.38%
3433	TPCODL	BBSR2	KHD	JATANI	CHHATABAR ODSSP	14270	11 KV JAMUJHARI	14270201	DURGAPUR SCHOOL	2142DT379	100	MIXED	AMI	Yes	100%	123	0.0825881	0.070653	0.0119351	14.45%
3434	TPCODL	BBSR2	KHD	JATANI	CHHATABAR ODSSP	14270	11 KV PANIORA	14270202	CHHATABARA MANGAL MANDIR	2142DT409	250	MIXED	AMI	Yes	100%	201	0.16787092	0.125903	0.04196792	25.00%
3435	TPCODL	BBSR2	KHD	JATANI	CHHATABAR ODSSP	14270	11 KV PANIORA	14270202	PANIORA UPARSAHI	2142DT426	100	MIXED	AMI	Yes	100%	45	0.08524944	0.037667	0.04758244	55.82%
3436	TPCODL	BBSR2	KHD	JATANI	HARIRAJPUR	14035	11 KV KANTIA	14035201	RATHIPUR GOPINATH TEMPLE	2141DT014	100	MIXED	AMI	Yes	100%	89	0.0803782	0.039382	0.0409962	51.00%
3437	TPCODL	BBSR2	KHD	JATANI	HARIRAJPUR	14035	11 KV KANTIA	14035201	RATHIPUR GOPINATH TEMPLE	2141DT015	100	MIXED	AMI	Yes	100%	111	0.12658826	0.046115	0.08047326	63.57%
3438	TPCODL	BBSR2	KHD	JATANI	HARIRAJPUR	14035	11 KV KANTIA	14035201	RATHIPUR MUSLIM TANGI SAHAI	2141DT023	100	MIXED	AMI	Yes	100%	85	0.10029474	0.042215	0.05807974	57.91%
3439	TPCODL	BBSR2	KHD	JATANI	HARIRAJPUR	14035	11 KV KAKUDIA	14035202	BUBHAPADA VILLAGE	2141DT042	63	MIXED	AMI	Yes	33%	74	0.05206342	0.022983	0.02908042	55.86%
3440	TPCODL	BBSR2	KHD	JATANI	HARIRAJPUR	14035	11 KV KAKUDIA	14035202	KAKUDIYA VILLAGE	2141DT050	250	MIXED	AMI	Yes	100%	187	0.19325708	0.09070504	0.10255204	53.07%
3441	TPCODL	BBSR2	KHD	JATANI	HARIRAJPUR	14035	11 KV KUDIARY	14035203	BONGO PRY SCHOOL	2141DT082	100	MIXED	AMI	Yes	0%	56	0.07683678	0.022803	0.05403378	70.32%
3442	TPCODL	BBSR2	KHD	JATANI	HARIRAJPUR	14035	11 KV KUDIARY	14035203	HARIRAJPUR VILLAGE	2141DT084	250	MIXED	AMI	Yes	100%	122	0.14661872	0.057653	0.08896572	60.68%
3443	TPCODL	BBSR2	KHD	JATANI	HARIRAJPUR	14035	11 KV KUDIARY	14035203	LOCO POLLY UP SCHOOL	2141DT106	100	MIXED	AMI	Yes	0%	35	0.01654484	0.009104	0.00744084	44.97%
3444	TPCODL	BBSR2	KHD	JATANI	HARIRAJPUR	14035	11 KV KUDIARY	14035203	BHAGBATI NAGAR	2141DT108	100	MIXED	AMI	Yes	100%	55	0.05192846	0.040268	0.01166046	22.45%
3445	TPCODL	BBSR2	KHD	JATANI	HARIRAJPUR	14035	11 KV KUDIARY	14035203	BAPUJI COLONY	2141DT111	250	MIXED	AMI	Yes	100%	163	0.22835764	0.141049	0.08730864	38.23%
3446	TPCODL	BBSR2	KHD	JATANI	HARIRAJPUR	14035	11 KV GOLAPADA	14035204	NAIBHANASARA VILLAGE	2141DT142	100	MIXED	AMI	Yes	33%	55	0.09112448	0.024223	0.06690148	73.42%
3447	TPCODL	BBSR2	KHD	JATANI	HARIRAJPUR	14035	11 KV BAHILIPADA	14035205	NIRONJONPUR DEBI MANDIR	2141DT161	100	MIXED	AMI	Yes	0%	90	0.0685657	0.03207209	0.03649361	53.22%
3448	TPCODL	BBSR2	KHD	JATANI	HARIRAJPUR	14035	11 KV BAHILIPADA	14035205	MUNDARA VILLAGE(TALLASAHI)	2141DT163	100	MIXED	AMI	Yes	100%	95	0.08496828	0.04709537	0.03787291	44.57%
3449	TPCODL	BBSR2	KHD	JATANI	HARIRAJPUR	14035	11 KV BAHILIPADA	14035205	NIJIGARAH KHURKI MADHUBHABAN	2141DT185	100	MIXED	AMI	Yes	100%	66	0.05024636	0.037586	0.01266036	25.20%
3450	TPCODL	BBSR2	KHD	JATANI	JANLA	14034	11 KV MENDHASAL	14034201	LEOPORSY COLONY	2142DT011	100	MIXED	AMI	Yes	100%	86	0.05082046	0.049365	0.00145546	2.86%
3451	TPCODL	BBSR2	KHD	JATANI	JANLA	14034	11 KV OIL MILL-1	14034202	OGALAPADA SCHOOL	2142DT059	100	MIXED	AMI	Yes	100%	237	0.15028901	0.112328	0.03796101	25.26%
3452	TPCODL	BBSR2	KHD	JATANI	JANLA	14034	11 KV JANALA	14034203	NEAR MITS SCHOOL ENGINEERING	2142DT156	100	MIXED	AMI	Yes	100%	55	0.07182142	0.041508	0.03031342	42.21%
3453	TPCODL	BBSR2	KHD	JATANI	JANLA	14034	11 KV JANALA	14034203	ANKULEI TEMPLE	2142DT161	100	MIXED	AMI	Yes	100%	57	0.05122536	0.03814	0.01308536	25.54%
3454	TPCODL	BBSR2	KHD	JATANI	JANLA	14034	11 KV JANALA	14034203	APOLO INFRASTRUCTURE	2142DT164	250	MIXED	AMI	Yes	0%	37	0.03710096	0.029774	0.00732696	19.75%
3455	TPCODL	BBSR2	KHD	JATANI	JANLA	14034	11 KV JANALA	14034203	RADHA DAS	2142DT168	250	MIXED	AMI	Yes	100%	172	0.15827056	0.116498	0.04177256	26.39%
3456	TPCODL	BBSR2	KHD	JATANI	JANLA	14034	11 KV MADANPUR	14034204	JANLA MARKET	2142DT101	100	MIXED	AMI	Yes	100%	188	0.1243393	0.09945191	0.02488739	20.02%
3457	TPCODL	BBSR2	KHD	JATANI	JANLA	14034	11 KV MADANPUR	14034204	HARAPUR NEW	2142DT107	63	MIXED	AMI	Yes	0%	55	0.04848116	0.024447	0.02403416	49.57%
3458	TPCODL	BBSR2	KHD	JATANI	JANLA	14034	11 KV MADANPUR	14034204	EKATA NAGAR BADA RAGHUNATHPU	2142DT207	100	MIXED	AMI	Yes	100%	134	0.1221783	0.113731	0.0084473	6.91%
3459	TPCODL	BBSR2	KHD	JATANI	JANLA	14034	11 KV MADANPUR	14034204	SUNCITY BADARAGHUNATHPUR	2142DT211	250	MIXED	AMI	Yes	100%	40	0.03295592	0.030169	0.00278692	8.46%
3460	TPCODL	BBSR2	KHD	JATANI	JANLA	14034	11 KV MADANPUR	14034204	MADANPUR VILLAGE NEW	2142DT230	250	MIXED	AMI	Yes	0%	227	0.2290596	0.191712	0.0373476	16.30%
3461	TPCODL	BBSR2	KHD	JATANI	JANLA	14034	11 KV MADANPUR	14034204	MADANPUR VILLAGE	2142DT231	250	MIXED	AMI	Yes	100%	181	0.157001	0.129151	0.02785	17.74%
3462	TPCODL	BBSR2	KHD	JATANI	JANLA	14034	11 KV MADANPUR	14034204	DEULIAPATANA OLD	2142DT251	100	MIXED	AMI	Yes	100%	98	0.0572329	0.055627	0.0016059	2.81%
3463	TPCODL	BBSR2	KHD	JATANI	JANLA	14034	11 KV MADANPUR	14034204	G NEXT VELLY	2142DT262	500	MIXED	AMI	Yes	0%	173	0.1176604	0.111732	0.0059284	5.04%
3464	TPCODL	BBSR2	KHD	JATANI	JANLA	14034	11 KV MADANPUR	14034204	KAIMATIA SCHOOL	2142DT276	100	MIXED	AMI	Yes	100%	119	0.11026094	0.067805	0.04245594	38.50%
3465	TPCODL	BBSR2	KHD	JATANI	JANLA	14034	11 KV MADANPUR	14034204	SUNCITY PAIKARAYPUR	2142DT287	100	MIXED	AMI	Yes	100%	21	0.01139592	0.01025	0.00114592	10.06%
3466	TPCODL	BBSR2	KHD	JATANI	JANLA	14034	11 KV MADANPUR	14034204	JAGASARA HARIJANA SAHI	2142DT288	100	MIXED	AMI	Yes	0%	69	0.02753862	0.016356	0.01118262	40.61%
3467	TPCODL	BBSR2	KHD	JATANI	JANLA	14034	11 KV MADANPUR	14034204	GRAMESWAR NAGAR NEW	2142DT297	100	MIXED	AMI	Yes	100%	100	0.10050188	0.096512	0.00398988	3.97%
3468	TPCODL	BBSR2	KHD	JATANI	JANLA	14034	11 KV MADANPUR	14034204	K2	2142DT298	500	MIXED	AMI	Yes	100%	39	0.03782448	0.032711	0.00511348	13.52%
3469	TPCODL	BBSR2	KHD	JATANI	JATANI	14033	11 KV BACHHARA	14033201	CHARCH	2143DT009	100	MIXED	AMI	Yes	100%	155	0.11840946	0.117784	0.00062546	0.53%
3470	TPCODL	BBSR2	KHD	JATANI	JATANI	14033	11 KV BACHHARA	14033201	RAJESH KHANNA - 1	2143DT013	250	MIXED	AMI	Yes	0%	70	0.12875576	0.054857	0.07389876	57.39%
3471	TPCODL	BBSR2	KHD	JATANI	JATANI	14033	11 KV BACHHARA	14033201	BACHHARA GHADEI SAHI	2143DT016	100	MIXED	AMI	Yes	100%	80	0.0439321	0.033181	0.0107511	24.47%
3472	TPCODL	BBSR2	KHD	JATANI	JATANI	14033	11 KV BACHHARA	14033201	BATUA HOUSE	2143DT017	100	MIXED	AMI	Yes	100%	61	0.08635166	0.042243	0.04410866	51.08%
3473	TPCODL	BBSR2	KHD	JATANI	JATANI	14033	11 KV BACHHARA	14033201	BHUANI TEMPLE	2143DT018	500	MIXED	AMI	Yes	0%	80	0.12982496	0.073684	0.05614096	43.24%
3474	TPCODL	BBSR2	KHD	JATANI	JATANI	14033	11 KV BACHHARA	14033201	ASA KIRAN GOPINATHPUR	2143DT020	250	MIXED	AMI	Yes	100%	271	0.2458209	0.185009	0.0608119	24.74%
3475	TPCODL	BBSR2	KHD	JATANI	JATANI	14033	11 KV BACHHARA	14033201	GOURI SINGH - 2	2143DT022	250	MIXED	AMI	Yes	100%	284	0.19510706	0.185761	0.00934606	4.79%
3476	TPCODL	BBSR2	KHD	JATANI	JATANI	14033	11 KV BACHHARA	14033201	HATA BAZAR SISU MANDIR	2143DT023	250	MIXED	AMI	Yes	67%	208	0.12609894	0.103877	0.02222194	17.62%
3477	TPCODL	BBSR2	KHD	JATANI	JATANI	14033	11 KV BACHHARA	14033201	DOLABEDI	2143DT025	200	MIXED	AMI	Yes	100%	254	0.1922789	0.174102	0.0181769	9.45%
3478	TPCODL	BBSR2	KHD	JATANI	JATANI	14033	11 KV BACHHARA	14033201	HATA BAZAR MELAN PADIA-2	2143DT028	25	MIXED	AMI	Yes	100%	30	0.04732782	0.016673	0.03065482	64.77%
3479	TPCODL	BBSR2	KHD	JATANI	JATANI	14033	11 KV BACHHARA	14033201	PATRAPADA MANGALA MANDIR	2143DT032	100	MIXED	AMI	Yes	100%	33	0.08993344	0.028666	0.06126744	68.13%
3480	TPCODL	BBSR2	KHD	JATANI	JATANI	14033	11 KV BACHHARA	14033201	ARGUL TANGISAHI	2143DT054	100	MIXED	AMI	Yes	100%	39	0.0550096	0.019654	0.0353556	64.27%
3481	TPCODL	BBSR2	KHD	JATANI	JATANI	14033	11 KV BACHHARA	14033201	HARIPUR	2143DT056	100	MIXED	AMI	Yes	100%	56	0.09988204	0.030544	0.06933804	69.42%
3482	TPCODL	BBSR2	KHD	JATANI	JATANI	14033	11 KV BACHHARA	14033201	PODAPADA	2143DT061	100	MIXED	AMI	Yes	100%	32	0.05818648	0.015769	0.04241748	72.90%
3483	TPCODL	BBSR2	KHD	JATANI	JATANI	14033	11 KV RAJA BAZAR	14033202	STATION	2143DT081	500	MIXED	AMI	Yes	0%	279	0.29457216	0.294481	9.116E-05	0.03%
3484	TPCODL	BBSR2	KHD	JATANI	JATANI	14033	11 KV RAJA BAZAR	14033202	MAIN ROAD	2143DT087	500	MIXED	AMI	Yes	0%	305	0.43501928	0.361612	0.07340728	16.87%
3485	TPCODL	BBSR2	KHD	JATANI	JATANI	14033	11 KV RAJA BAZAR	14033202	FANDI	2143DT110	100	MIXED	AMI	Yes	100%	65	0.07808926	0.055089	0.02300026	29.45%
3486	TPCODL	BBSR2	KHD	JATANI	JATANI	14033	11 KV RAJA BAZAR	14033202	RAJA KACHERI	2143DT111	250	MIXED	AMI	Yes	0%	152	0.17507264	0.119412	0.05566064	31.79%
3487	TPCODL	BBSR2	KHD	JATANI	JATANI	14033	11 KV KUSUMATI	14033203	SWEEPER COLONY	2143DT121	100	MIXED	AMI	Yes	0%	90	0.13362622	0.040369	0.09325722	69.79%
3488	TPCODL	BBSR2	KHD	JATANI	JATANI	14033	11 KV KUSUMATI	14033203	BISHNU MANDIR - 1	2143DT123	100	MIXED	AMI	Yes	100%	72	0.10243222	0.069909	0.03252322	31.75%
3489	TPCODL	BBSR2	KHD	JATANI	JATANI	14033	11 KV KUSUMATI	14033203	BISHNU MANDIR - 2	2143DT124	100	MIXED	AMI	Yes	0%	106	0.15054768	0.069209	0.08133868	54.03%
3490	TPCODL	BBSR2	KHD	JATANI	JATANI	14033	11 KV KUSUMATI	14033203	BISHNU MANDIR	2143DT127	250	MIXED	AMI	Yes	100%	169	0.2072456	0.122666	0.0845796	40.81%
3491	TPCODL	BBSR2	KHD	JATANI	JATANI	14033	11 KV KUSUMATI	14033203	TARINI MANDIR	2143DT131	63	MIXED	AMI	Yes	100%	72	0.08264424	0.0514	0.03124424	37.81%
3492	TPCODL	BBSR2	KHD	JATANI	JATANI	14033	11 KV KUSUMATI	14033203	MOHANTY SAHI	2143DT139	100	MIXED	AMI	Yes	0%	55	0.09319674	0.033741	0.05945574	63.80%
3493	TPCODL	BBSR2	KHD	JATANI	JATANI	14033	11 KV KUSUMATI	14033203	ALIAGADA	2143DT141	250	MIXED	AMI	Yes	0%	113	0.14464056	0.042593	0.10204756	70.55%
3494	TPCODL	BBSR2	KHD	JATANI	JATANI	14033	11 KV KUSUMATI	14033203	HANUMAN MANDIR	2143DT143	100	MIXED	AMI	Yes	0%	31	0.0222778	0.020335	0.0019428	8.72%
3495	TPCODL	BBSR2	KHD	JATANI	JATANI	14033	11 KV KUSUMATI	14033203	KALIKA MANDIR	2143DT144	100	MIXED	AMI	Yes	67%	107	0.10114285	0.055014	0.04612885	45.61%
3496	TPCODL	BBSR2	KHD	JATANI	JATANI	14033	11 KV KUSUMATI	14033203	CHANAGHARA SOUBHAGYA	2143DT145	100	MIXED	AMI	Yes	67%	29	0.03358658	0.018192	0.01539458	45.84%
3497	TPCODL	BBSR2	KHD	JATANI	JATANI	14033	11 KV KUSUMATI	14033203	CHANDI MANDIR	2143DT148	250	MIXED	AMI	Yes	67%	117	0.16005576	0.053695	0.10636076	66.45%
3498	TPCODL	BBSR2	KHD	JATANI	JATANI	14033	11 KV KUSUMATI	14033203	HARIJANA SAHI	2143DT149	100	MIXED	AMI	Yes	67%	148	0.11006502	0.048938	0.06112702	55.54%
3499	TPCODL	BBSR2	KHD	JATANI	JATANI	14033	11 KV KUSUMATI	14033203	KUSUMATI PANCHAYAT OFFICE	2143DT151	250	MIXED	AMI	Yes	67%	147	0.18400356	0.07274	0.11126356	60.47%
3500	TPCODL	BBSR2	KHD	JATANI	JATANI	14033	11 KV JATNI TOWN	14033204	ORTEL OFFICE FRONT	2144DT105	100	MIXED	AMI	Yes	100%	49	0.06528786	0.044118	0.02116986	32.43%
3501	TPCODL	BBSR2	KHD	JATANI	JATANI	14033	11 KV JATNI TOWN	14033204	BISWANATH TEMPLE	2144DT112	100	MIXED	AMI	Yes	100%	123	0.14459312	0.09961	0.04498312	31.11%
3502	TPCODL	BBSR2	KHD	JATANI	JATANI	14033	11 KV JATANI MEDICAL	14033206	BACK SIDE OF MEDICAL	2144DT206	200	MIXED	AMI	Yes	100%	72	0.09446964	0.084584	0.00988564	10.46%
3503	TPCODL	BBSR2	KHD	JATANI	JATANI	14033	11 KV JATANI MEDICAL	14033206	GOPINATHPUR SCHOOL	2144DT237	100	MIXED	AMI	Yes	100%	27	0.009416	0.005415	0.004001	42.49%

Sl. No.	Zone Name	Circle name	Division name	Name of the Sub-division	Name of the Sub-station	Substation Code	Name of the 11 kV Feeder	Feeder Code	Name of the Location where DT situated	DT code	DT Capacity (kVA)	Predominant consumer type of DT (Domestic/Industrial/Agriculture/Mixed)	Type of metering AMR/AMI/ Communicable/Conventional metered/Unmetered	Status of Meter-whether Functional (Yes/No)	% of data received automatically (if AMR/AMI)	No. of Connected Consumers	Input Energy (MU) (A)	Billed Energy (MU) (B)	Loss (MU) (A-B)	% DT Loss (A-B)/A
3504	TPCODL	BBSR2	KHD	JATANI	JATANI	14033	11 KV JATANI MEDICAL	14033206	GOPINATH PUR VILLAGE	2144DT242	100	MIXED	AMI	Yes	100%	124	0.09944479	0.070401	0.02904379	29.21%
3505	TPCODL	BBSR2	KHD	JATANI	JATANI	14033	11 KV JATANI MEDICAL	14033206	Tamala Residency	2144DT252	250	MIXED	AMI	Yes	100%	27	0.0251182	0.018775	0.0063432	25.25%
3506	TPCODL	BBSR2	KHD	JATANI	JATANI	14033	11 KV GAJAPATI NAGAR	14033207	MARWADI ANGANBADI	2143DT276	100	MIXED	AMI	Yes	100%	67	0.0344069	0.032304	0.0021029	6.11%
3507	TPCODL	BBSR2	KHD	JATANI	JATANI	14033	11 KV GAJAPATI NAGAR	14033207	MANGALA MANDIR	2143DT277	500	MIXED	AMI	Yes	100%	243	0.33214864	0.189936	0.14221264	42.82%
3508	TPCODL	BBSR2	KHD	JATANI	JATANI	14033	11 KV GAJAPATI NAGAR	14033207	BRIGEDIAR SCHOOL	2143DT279	500	MIXED	AMI	Yes	0%	298	0.43489148	0.225112	0.20977948	48.24%
3509	TPCODL	BBSR2	KHD	JATANI	JATANI	14033	11 KV GAJAPATI NAGAR	14033207	MADHUSUDAN NAGAR STAFF QUART	2143DT282	250	MIXED	AMI	Yes	100%	156	0.14694484	0.124549	0.02239584	15.24%
3510	TPCODL	BBSR2	KHD	JATANI	JATANI	14033	11 KV GAJAPATI NAGAR	14033207	NALI MATHA	2143DT283	250	MIXED	AMI	Yes	0%	112	0.11518264	0.109631	0.00555164	4.82%
3511	TPCODL	BBSR2	KHD	JATANI	JATANI	14033	11 KV GAJAPATI NAGAR	14033207	CENTRAL SCHOOL-1	2143DT285	250	MIXED	AMI	Yes	100%	101	0.23344048	0.075507	0.15793348	67.65%
3512	TPCODL	BBSR2	KHD	JATANI	JATANI NUAGAON (	14271	11 KV Nuagaon	14271201	BIKASH NAGAR -1 NEAR JAIBHAI	2144DT002	100	MIXED	AMI	Yes	100%	116	0.1035607	0.069386	0.0341747	33.00%
3513	TPCODL	BBSR2	KHD	JATANI	JATANI NUAGAON (	14271	11 KV Nuagaon	14271201	SAI MANDIR	2144DT012	250	MIXED	AMI	Yes	100%	83	0.10539728	0.074612	0.03078528	29.21%
3514	TPCODL	BBSR2	KHD	JATANI	JATANI NUAGAON (	14271	11 KV Nuagaon	14271201	LAXMINURSHINGA MANDIR	2144DT019	100	MIXED	AMI	Yes	100%	97	0.09664708	0.064933	0.03171408	32.81%
3515	TPCODL	BBSR2	KHD	JATANI	JATANI NUAGAON (	14271	11 KV Nuagaon	14271201	NUAGAON NILAKANTHESWAR TEMPI	2144DT126	100	MIXED	AMI	Yes	0%	82	0.07191068	0.039968	0.03194268	44.42%
3516	TPCODL	BBSR2	KHD	JATANI	JATANI NUAGAON (	14271	11 KV BIKASH NAGAR-1	14271202	BIKSH NAGAR	2144DT021	250	MIXED	AMI	Yes	0%	116	0.20770216	0.086015	0.12168716	58.59%
3517	TPCODL	BBSR2	KHD	JATANI	JATANI NUAGAON (	14271	11 KV BIKASH NAGAR-1	14271202	BIKASH NAGAR SIDHA CHIKISHALAYA	2144DT025	250	MIXED	AMI	Yes	67%	185	0.1756232	0.127135	0.0484882	27.61%
3518	TPCODL	BBSR2	KHD	JATANI	JATANI NUAGAON (	14271	11 KV BIKASH NAGAR-1	14271202	RAGHUNATH NAGAR GATE	2144DT027	100	MIXED	AMI	Yes	100%	88	0.0671229	0.041221	0.0259019	38.59%
3519	TPCODL	BBSR2	KHD	JATANI	JATANI NUAGAON (	14271	11 KV BIKASH NAGAR-1	14271202	BHIMPUR MELANA PADIA-1	2144DT034	100	MIXED	AMI	Yes	100%	73	0.04533276	0.030262	0.01507076	33.24%
3520	TPCODL	BBSR2	KHD	JATANI	JATANI NUAGAON (	14271	11 KV Badatota	14271203	BATYA AASRAYA STALI PAIKARAIPUR	2144DT051	100	MIXED	AMI	Yes	0%	168	0.1152836	0.088159	0.0271246	23.53%
3521	TPCODL	BBSR2	KHD	JATANI	JATANI NUAGAON (	14271	11 KV Badatota	14271203	BELAPADA SCHOOL	2144DT076	250	MIXED	AMI	Yes	100%	222	0.16533195	0.126303	0.03902895	23.61%
3522	TPCODL	BBSR2	KHD	JATANI	JATANI NUAGAON (	14271	11 KV Badatota	14271203	BADATOTA TANGI SAHI-1	2144DT083	100	MIXED	AMI	Yes	100%	75	0.06649084	0.036321	0.03016984	45.37%
3523	TPCODL	BBSR2	KHD	JATANI	JATANI NUAGAON (	14271	11 KV Badatota	14271203	BADATOTA TANGI SAHI-2	2144DT084	100	MIXED	AMI	Yes	100%	49	0.08369158	0.028239	0.05545258	66.26%
3524	TPCODL	BBSR2	KHD	JATANI	JATANI NUAGAON (	14271	11 KV Badatota	14271203	BADATOTA, MISHRA SAHI	2144DT096	100	MIXED	AMI	Yes	100%	55	0.05106168	0.043289	0.00777268	15.22%
3525	TPCODL	BBSR2	KHD	JATANI	JATANI NUAGAON (	14271	11 KV Badatota	14271203	BADATOTA PANCHAYAT OFFICE	2144DT097	250	MIXED	AMI	Yes	100%	127	0.11790348	0.047905	0.06999848	59.37%
3526	TPCODL	BBSR2	KHD	JATANI	JATANI NUAGAON (	14271	11 KV Badatota	14271203	PADANPUR NEAR MANGALA MANDIF	2144DT099	100	MIXED	AMI	Yes	100%	91	0.08036044	0.054738	0.02562244	31.88%
3527	TPCODL	BBSR2	KHD	JATANI	JATANI NUAGAON (	14271	11 KV Badatota	14271203	PADANPUR BAGHA HARIJANA SAHI	2144DT246	100	MIXED	AMI	Yes	100%	99	0.08640758	0.05187	0.03453758	39.97%
3528	TPCODL	BBSR2	KHD	JATANI	JATANI NUAGAON (	14271	11 KV Badatota	14271203	RAGHUNATH MANDIR(NEAR BESAN F	2144DT249	100	MIXED	AMI	Yes	100%	94	0.06467984	0.041737	0.02294284	35.47%
3529	TPCODL	BBSR2	KHD	JATANI	SANARAJUA (MEND	14268	11 KV DERAS	14268201	OMM SHANTI ASHRAM	2142DT464	100	MIXED	AMI	Yes	100%	11	0.00798316	0.00631	0.00167316	20.96%
3530	TPCODL	BBSR2	KHD	JATANI	SANARAJUA (MEND	14268	11 KV MENDHASAL-2	14268202	SUNRISE INDUSTIES NEAR	2142DT504	100	MIXED	AMI	Yes	100%	44	0.09126435	0.059812	0.03145235	34.46%
3531	TPCODL	BBSR2	KHD	JATANI	SANARAJUA (MEND	14268	11 KV MENDHASAL-2	14268202	MUSLIM SAHI	2142DT507	100	MIXED	AMI	Yes	100%	65	0.11029252	0.034161	0.07613152	69.03%
3532	TPCODL	BBSR2	KHD	JATANI	SANARAJUA (MEND	14268	11 KV MENDHASAL-2	14268202	BALUNKESWAR SHIV TEMPLE	2142DT510	63	MIXED	AMI	Yes	67%	46	0.06635105	0.044923	0.02142805	32.29%
3533	TPCODL	BBSR2	KHD	JATANI	SANARAJUA (MEND	14268	11 KV MENDHASAL-2	14268202	MENDHASALA-2	2142DT515	250	MIXED	AMI	Yes	0%	123	0.20080468	0.05221	0.14859468	74.00%
3534	TPCODL	BBSR2	KHD	KHURDA	10-POLE	14044	11 KV KHORDHA TOWN -	14044201	DIVISION OFFICE FRONT TLC ROAD	2151DT150	100	MIXED	AMI	Yes	100%	81	0.09778626	0.087894	0.00989226	10.12%
3535	TPCODL	BBSR2	KHD	KHURDA	10-POLE	14044	11 KV KHORDHA TOWN -	14044201	BDA COLONY NALAKUPA	2151DT151	500	MIXED	AMI	Yes	0%	361	0.32143808	0.313212	0.00822608	2.56%
3536	TPCODL	BBSR2	KHD	KHURDA	10-POLE	14044	11 KV KHORDHA TOWN -	14044201	MANGALA NAGAR 5TH LANE	2151DT158	100	MIXED	AMI	Yes	0%	80	0.0809917	0.077544	0.0034477	4.26%
3537	TPCODL	BBSR2	KHD	KHURDA	10-POLE	14044	11 KV KHORDHA TOWN -	14044201	BDA COLONY KHANI	2151DT159	250	MIXED	AMI	Yes	100%	137	0.22428064	0.113224	0.11105664	49.52%
3538	TPCODL	BBSR2	KHD	KHURDA	10-POLE	14044	11 KV KHORDHA TOWN -	14044201	mangala nagar	2151DT163	250	MIXED	AMI	Yes	100%	109	0.16916995	0.119802	0.04936795	29.18%
3539	TPCODL	BBSR2	KHD	KHURDA	10-POLE	14044	11 KV KHORDHA TOWN -	14044201	NEAR INCOME TAX OFFICE	2151DT164	100	MIXED	AMI	Yes	0%	71	0.08433388	0.076689	0.00764488	9.07%
3540	TPCODL	BBSR2	KHD	KHURDA	10-POLE	14044	11 KV KHORDHA TOWN -	14044201	VEGITABLE MARKET	2151DT173	100	MIXED	AMI	Yes	100%	26	0.03694972	0.031683	0.00526672	14.25%
3541	TPCODL	BBSR2	KHD	KHURDA	10-POLE	14044	11 KV KHORDHA TOWN -	14044201	KALPANA PLAZA	2151DT175	250	MIXED	AMI	Yes	100%	31	0.03466236	0.030731	0.00393136	11.34%
3542	TPCODL	BBSR2	KHD	KHURDA	10-POLE	14044	11 KV KHORDHA TOWN -	14044201	CHRISHTIAN SAHI-2	2151DT183	250	MIXED	AMI	Yes	100%	106	0.13518464	0.101953	0.03323164	24.58%
3543	TPCODL	BBSR2	KHD	KHURDA	10-POLE	14044	11 KV KHORDHA TOWN -	14044201	CHRISHTIAN SAHI-1	2151DT184	250	MIXED	AMI	Yes	100%	99	0.25581832	0.080129	0.17568932	68.68%
3544	TPCODL	BBSR2	KHD	KHURDA	10-POLE	14044	11 KV KHORDHA TOWN -	14044201	MODEL POLICE STATION	2151DT193	250	MIXED	AMI	Yes	100%	18	0.03614214	0.018469	0.01767314	48.90%
3545	TPCODL	BBSR2	KHD	KHURDA	10-POLE	14044	11 KV PANABARAJ	14044203	TOTAPADA	2153DT004	500	MIXED	AMI	Yes	100%	212	0.50813304	0.118682	0.38945104	76.64%
3546	TPCODL	BBSR2	KHD	KHURDA	10-POLE	14044	11 KV PANABARAJ	14044203	KALYANPUR	2153DT018	100	MIXED	AMI	Yes	100%	81	0.05161144	0.038315	0.01329644	25.76%
3547	TPCODL	BBSR2	KHD	KHURDA	10-POLE	14044	11 KV PANABARAJ	14044203	JARIPUT NO-1	2153DT023	100	MIXED	AMI	Yes	100%	92	0.05429232	0.039195	0.01509732	27.81%
3548	TPCODL	BBSR2	KHD	KHURDA	10-POLE	14044	11 KV PANABARAJ	14044203	DURGAPUR	2153DT049	100	MIXED	AMI	Yes	100%	77	0.07705464	0.02625	0.05080464	65.93%
3549	TPCODL	BBSR2	KHD	KHURDA	10-POLE	14044	11 KV PANABARAJ	14044203	GUDUM (MANAGOBINDAPUR) NO-4	2153DT072	100	MIXED	AMI	Yes	100%	72	0.03249329	0.02755	0.00494329	15.21%
3550	TPCODL	BBSR2	KHD	KHURDA	10-POLE	14044	11 KV PANABARAJ	14044203	BHATAPADA	2153DT081	100	MIXED	AMI	Yes	0%	68	0.0435187	0.019061	0.0244577	56.20%
3551	TPCODL	BBSR2	KHD	KHURDA	10-POLE	14044	11 KV PANABARAJ	14044203	BHATAPADA NO-2	2153DT084	100	MIXED	AMI	Yes	0%	64	0.05604671	0.018108	0.03793871	67.69%
3552	TPCODL	BBSR2	KHD	KHURDA	10-POLE	14044	11 KV PANABARAJ	14044203	BANGIDA MANGALA SAHI NO-1	2153DT085	100	MIXED	AMI	Yes	0%	84	0.05191956	0.039734	0.01218556	23.47%
3553	TPCODL	BBSR2	KHD	KHURDA	10-POLE	14044	11 KV PANABARAJ	14044203	ADAKHANDIA MAIN VILLAGE	2153DT097	100	MIXED	AMI	Yes	100%	30	0.01625242	0.005922	0.01033042	63.56%
3554	TPCODL	BBSR2	KHD	KHURDA	10-POLE	14044	11 KV PANABARAJ	14044203	GUDUM NO-1 NEAR LAXMI BAZAR	2153DT100	100	MIXED	AMI	Yes	100%	65	0.04407084	0.026069	0.01800184	40.85%
3555	TPCODL	BBSR2	KHD	KHURDA	10-POLE	14044	11 KV PANABARAJ	14044203	GUDUM NEAR LAXMI BAZAR NO-4	2153DT101	100	MIXED	AMI	Yes	100%	107	0.05277184	0.041888	0.01088384	20.62%
3556	TPCODL	BBSR2	KHD	KHURDA	10-POLE	14044	11 KV KHORDHA TOWN-	14044204	TLC BACK SIDE	2151DT070	250	MIXED	AMI	Yes	0%	202	0.1327216	0.099712	0.0330096	24.87%
3557	TPCODL	BBSR2	KHD	KHURDA	10-POLE	14044	11 KV KHORDHA TOWN-	14044204	BHALIBADI PLAY GROUND	2151DT073	250	MIXED	AMI	Yes	100%	203	0.16541368	0.13923	0.02618368	15.83%
3558	TPCODL	BBSR2	KHD	KHURDA	10-POLE	14044	11 KV KHORDHA TOWN-	14044204	NEAR BHALIABADI SCHOOL	2151DT074	250	MIXED	AMI	Yes	100%	197	0.253595	0.120473	0.133122	52.49%
3559	TPCODL	BBSR2	KHD	KHURDA	10-POLE	14044	11 KV KHORDHA TOWN-	14044204	GANDHI PADIA	2151DT084	250	MIXED	AMI	Yes	100%	132	0.17107492	0.098087	0.07298792	42.66%
3560	TPCODL	BBSR2	KHD	KHURDA	10-POLE	14044	11 KV KHORDHA TOWN-	14044204	SANTI KALYANI MANDAP, GANDHI PA	2151DT085	63	MIXED	AMI	Yes	0%	41	0.060052	0.03146	0.028592	47.61%
3561	TPCODL	BBSR2	KHD	KHURDA	10-POLE	14044	11 KV KHORDHA TOWN-	14044204	GADA KHORDHA SADAK SAHI 1	2151DT088	250	MIXED	AMI	Yes	100%	185	0.23288584	0.107889	0.12499684	53.67%
3562	TPCODL	BBSR2	KHD	KHURDA	10-POLE	14044	11 KV KHORDHA TOWN-	14044204	GADA KHORDHA KUNJA BIHARI PATA	2151DT090	100	MIXED	AMI	Yes	0%	32	0.08213232	0.02031	0.06182232	75.27%
3563	TPCODL	BBSR2	KHD	KHURDA	10-POLE	14044	11 KV KHORDHA TOWN-	14044204	BATA MANGALA LEFT	2151DT092	100	MIXED	AMI	Yes	100%	30	0.05437824	0.021623	0.03275524	60.24%
3564	TPCODL	BBSR2	KHD	KHURDA	10-POLE	14044	11 KV KHORDHA TOWN-	14044204	BATA MANGALA RIGHT	2151DT093	100	MIXED	AMI	Yes	100%	62	0.13096372	0.064565	0.06639872	50.70%
3565	TPCODL	BBSR2	KHD	KHURDA	10-POLE	14044	11 KV KHORDHA TOWN-	14044204	NABINA BAG 4 POLE-2	2151DT098	250	MIXED	AMI	Yes	67%	88	0.22612393	0.084293	0.14183093	62.72%
3566	TPCODL	BBSR2	KHD	KHURDA	10-POLE	14044	11 KV KHORDHA TOWN-	14044204	ANJUSHREE KALYAN MANDAP BACK S	2151DT103	100	MIXED	AMI	Yes	100%	51	0.08259618	0.066924	0.01567218	18.97%
3567	TPCODL	BBSR2	KHD	KHURDA	10-POLE	14044	11 KV KHORDHA TOWN-	14044204	ATAL HOUSE	2151DT138	100	MIXED	AMI	Yes	100%	113	0.1120115	0.090738	0.0212735	18.99%
3568	TPCODL	BBSR2	KHD	KHURDA	10-POLE	14044	11 KV KHORDHA TOWN-	14044204	SAMANTARAPUR DHOBA SAHI	2151DT144	100	MIXED	AMI	Yes	100%	103	0.10074292	0.061224	0.03951892	39.23%
3569	TPCODL	BBSR2	KHD	KHURDA	10-POLE	14044	11 KV KHORDHA TOWN-	14044204	OLD DRDA-2	2151DT145	100	MIXED	AMI	Yes	100%	73	0.08860132	0.061718	0.02688332	30.34%
3570	TPCODL	BBSR2	KHD	KHURDA	10-POLE	14044	11 KV KHORDHA TOWN-	14044204	SAGUAN BAGICHA-1	2151DT148	100	MIXED	AMI	Yes	100%	43	0.0568163	0.026165	0.0306513	53.95%
3571	TPCODL	BBSR2	KHD	KHURDA	10-POLE	14044	11 KV KHORDHA TOWN-	14044204	VETNARRY CHHAKA	2151DT155	250	MIXED	AMI	Yes	100%	82	0.14518474	0.0823	0.06288474	43.31%
3572	TPCODL	BBSR2	KHD	KHURDA	10-POLE	14044	11 KV KHORDHA TOWN-	14044204	HABELI PADIA-2	2151DT157	250	MIXED	AMI	Yes	100%	92	0.17826556	0.114024	0.06424156	36.04%
3573	TPCODL	BBSR2	KHD	KHURDA	10-POLE	14044	11 KV KHORDHA TOWN-	14044204	GADADWAR SAHI	2151DT197	100	MIXED	AMI	Yes	100%	159	0.12590364	0.084595	0.04130864	32.81%
3574	TPCODL	BBSR2	KHD	KHURDA	10-POLE	14044	11 KV KHORDHA TOWN-	14044204	PALLA VILLAGE	2151DT218	100	MIXED	AMI	Yes	100%	43	0.04172444	0.037037	0.00468744	11.23%
3575	TPCODL	BBSR2	KHD	KHURDA	10-POLE	14044	11 KV KHORDHA TOWN-	14044204	PALLA BARUNEI TEMPLE	2151DT240	250	MIXED	AMI	Yes	100%	104	0.19625316	0.08922	0.10703316	54.54%
3576	TPCODL	BBSR2	KHD	KHURDA	10-POLE	14044	11 KV KHORDHA TOWN-	14044204	ISKAN TEMPLE FRONT	2151DT241	100	MIXED	AMI	Yes	100%	22	0.06079484	0.031002	0.02979284	49.01%

Sl. No.	Zone Name	Circle name	Division name	Name of the Sub-division	Name of the Sub-station	Substation Code	Name of the 11 kV Feeder	Feeder Code	Name of the Location where DT situated	DT code	DT Capacity (kVA)	Predominant consumer type of DT (Domestic/Industrial/Agriculture/Mixed)	Type of metering AMR/AMI/ Communicable/Conventional metered/Unmetered	Status of Meter-whether Functional (Yes/No)	% of data received automatically (if AMR/AMI)	No. of Connected Consumers	Input Energy (MU) (A)	Billed Energy (MU) (B)	Loss (MU) (A-B)	% DT Loss (A-B)/A
3577	TPCODL	BBSR2	KHD	KHURDA	10-POLE	14044	11 KV GURUJANGA	14044205	DIET CAMPUS	2151DT010	100	MIXED	AMI	Yes	100%	53	0.07105554	0.061442	0.00961354	13.53%
3578	TPCODL	BBSR2	KHD	KHURDA	10-POLE	14044	11 KV GURUJANGA	14044205	PALTON POKHARI	2151DT014	100	MIXED	AMI	Yes	0%	28	0.03130988	0.031187	0.00012288	0.39%
3579	TPCODL	BBSR2	KHD	KHURDA	10-POLE	14044	11 KV GURUJANGA	14044205	MONDAP GROUND	2151DT024	100	MIXED	AMI	Yes	0%	63	0.11237594	0.084483	0.02789294	24.82%
3580	TPCODL	BBSR2	KHD	KHURDA	10-POLE	14044	11 KV GURUJANGA	14044205	LAXMINA RAYANA	2151DT027	250	MIXED	AMI	Yes	100%	66	0.10124544	0.06942	0.03182544	31.43%
3581	TPCODL	BBSR2	KHD	KHURDA	10-POLE	14044	11 KV GURUJANGA	14044205	KALI CHHAKA	2151DT041	250	MIXED	AMI	Yes	100%	122	0.2052554	0.092199	0.1130564	55.08%
3582	TPCODL	BBSR2	KHD	KHURDA	10-POLE	14044	11 KV GURUJANGA	14044205	BHOI SAHI	2151DT048	100	MIXED	AMI	Yes	100%	213	0.1471168	0.097443	0.0496738	33.76%
3583	TPCODL	BBSR2	KHD	KHURDA	10-POLE	14044	11 KV GURUJANGA	14044205	HOUSING BOARD 1	2151DT052	100	MIXED	AMI	Yes	67%	96	0.08043926	0.058255	0.02218426	27.58%
3584	TPCODL	BBSR2	KHD	KHURDA	10-POLE	14044	11 KV GURUJANGA	14044205	KOCHI LAKAN 2	2151DT056	250	MIXED	AMI	Yes	67%	179	0.22274652	0.106801	0.11594552	52.05%
3585	TPCODL	BBSR2	KHD	KHURDA	10-POLE	14044	11 KV GURUJANGA	14044205	BRIGADIER SCHOOL	2151DT058	250	MIXED	AMI	Yes	67%	82	0.06821	0.047612	0.020598	30.20%
3586	TPCODL	BBSR2	KHD	KHURDA	10-POLE	14044	11 KV GURUJANGA	14044205	DWARIKA NAGAR	2151DT062	100	MIXED	AMI	Yes	0%	186	0.1255319	0.100302	0.0252299	20.10%
3587	TPCODL	BBSR2	KHD	KHURDA	10-POLE	14044	11 KV TARATUA	14044206	SANTOSHI LANE	2151DT106	100	MIXED	AMI	Yes	100%	89	0.13466386	0.091546	0.04311786	32.02%
3588	TPCODL	BBSR2	KHD	KHURDA	10-POLE	14044	11 KV TARATUA	14044206	SUNDAR SAHI 1	2151DT112	100	MIXED	AMI	Yes	100%	55	0.07962598	0.060007	0.01961898	24.64%
3589	TPCODL	BBSR2	KHD	KHURDA	10-POLE	14044	11 KV TARATUA	14044206	PALIEI SAHI	2151DT114	100	MIXED	AMI	Yes	100%	47	0.0951356	0.06245	0.0326856	34.36%
3590	TPCODL	BBSR2	KHD	KHURDA	10-POLE	14044	11 KV TARATUA	14044206	PALIEI SAHI 1	2151DT115	100	MIXED	AMI	Yes	100%	77	0.12805306	0.087881	0.04017206	31.37%
3591	TPCODL	BBSR2	KHD	KHURDA	10-POLE	14044	11 KV TARATUA	14044206	NEW HOSPITAL BACK	2151DT118	100	MIXED	AMI	Yes	100%	34	0.09069426	0.046466	0.04422826	48.77%
3592	TPCODL	BBSR2	KHD	KHURDA	10-POLE	14044	11 KV TARATUA	14044206	ARMY COLONY	2151DT124	100	MIXED	AMI	Yes	0%	46	0.11266402	0.055046	0.05761802	51.14%
3593	TPCODL	BBSR2	KHD	KHURDA	10-POLE	14044	11 KV TARATUA	14044206	SRDHAPUR ODIA SAHI	2152DT014	100	MIXED	AMI	Yes	0%	76	0.15192438	0.034383	0.11754138	77.37%
3594	TPCODL	BBSR2	KHD	KHURDA	10-POLE	14044	11 KV TARATUA	14044206	SRADHAPUR TOTA SAI	2152DT017	63	MIXED	AMI	Yes	0%	51	0.07574082	0.017454	0.05828682	76.96%
3595	TPCODL	BBSR2	KHD	KHURDA	10-POLE	14044	11 KV TARATUA	14044206	SRDHAPUR PENSION PADIA	2152DT022	100	MIXED	AMI	Yes	0%	53	0.01804086	0.016638	0.00140286	7.78%
3596	TPCODL	BBSR2	KHD	KHURDA	DADHIMACHAGADI	14203	11 KV KAIPADAR	14203201	KURADHAMALA NUASAHI	2154DT307	100	MIXED	AMI	Yes	100%	65	0.05400138	0.037155	0.01684638	31.20%
3597	TPCODL	BBSR2	KHD	KHURDA	DADHIMACHAGADI	14203	11 KV KAIPADAR	14203201	DADHIMACHA GADIA	2154DT344	63	MIXED	AMI	Yes	100%	109	0.06750101	0.04253	0.02497101	36.99%
3598	TPCODL	BBSR2	KHD	KHURDA	DADHIMACHAGADI	14203	11 KV KAIPADAR	14203201	TANGINI	2154DT356	100	MIXED	AMI	Yes	100%	24	0.0298149	0.020207	0.0096079	32.23%
3599	TPCODL	BBSR2	KHD	KHURDA	DADHIMACHAGADI	14203	11 KV KAIPADAR	14203201	DEULATANGI VILLAGE 1	2154DT366	63	MIXED	AMI	Yes	100%	68	0.04548298	0.037618	0.00786498	17.29%
3600	TPCODL	BBSR2	KHD	KHURDA	DADHIMACHAGADI	14203	11 KV KAIPADAR	14203201	KAIPADR NO 3	2154DT371	100	MIXED	AMI	Yes	100%	69	0.08162276	0.029629	0.05199376	63.70%
3601	TPCODL	BBSR2	KHD	KHURDA	DADHIMACHAGADI	14203	11 KV DADHIMACHHAGA	14203202	BHAMARA	2154DT404	100	MIXED	AMI	Yes	67%	16	0.0214401	0.014129	0.0073111	34.10%
3602	TPCODL	BBSR2	KHD	KHURDA	DADHIMACHAGADI	14203	11 KV BAJPUR	14203203	BANAPUR SAHI	2154DT534	100	MIXED	AMI	Yes	0%	36	0.03683208	0.015113	0.02171908	58.97%
3603	TPCODL	BBSR2	KHD	KHURDA	DADHIMACHAGADI	14203	11 KV BAJPUR	14203203	BAJAPUR	2154DT546	250	MIXED	AMI	Yes	67%	177	0.1323974	0.061989	0.0704084	53.18%
3604	TPCODL	BBSR2	KHD	KHURDA	DADHIMACHAGADI	14203	11 KV DALEIPUT	14203204	DALEIPUT MODRN PRIMARY SCHOOL	2154DT457	100	MIXED	AMI	Yes	100%	60	0.05639598	0.035872	0.02052398	36.39%
3605	TPCODL	BBSR2	KHD	KHURDA	DADHIMACHAGADI	14203	11 KV DALEIPUT	14203204	DALEIPUT POKHARI	2154DT460	100	MIXED	AMI	Yes	100%	121	0.09376556	0.060946	0.03281956	35.00%
3606	TPCODL	BBSR2	KHD	KHURDA	GURUJANGA	14036	11 KV HALADIA	14036201	KUMBHAR BASTI MANGALA MANDIR	2152DT073	200	MIXED	AMI	Yes	0%	117	0.09943376	0.053786	0.04564776	45.91%
3607	TPCODL	BBSR2	KHD	KHURDA	GURUJANGA	14036	11 KV HALADIA	14036201	KUMAR BAST MANGALA MANDIR 2	2152DT074	100	MIXED	AMI	Yes	67%	96	0.05553396	0.046572	0.00896196	16.14%
3608	TPCODL	BBSR2	KHD	KHURDA	GURUJANGA	14036	11 KV HALADIA	14036201	PAIK TIGIRIA BAJAR	2152DT150	100	MIXED	AMI	Yes	67%	145	0.0636108	0.042379	0.0212318	33.38%
3609	TPCODL	BBSR2	KHD	KHURDA	GURUJANGA	14036	11 KV HALADIA	14036201	KUNDILO MAHAVIR MANDIR	2152DT164	100	MIXED	AMI	Yes	67%	107	0.05076664	0.04265	0.00811664	15.99%
3610	TPCODL	BBSR2	KHD	KHURDA	GURUJANGA	14036	11 KV HALADIA	14036201	KERENGA NO 3	2152DT175	250	MIXED	AMI	Yes	67%	193	0.36247964	0.081752	0.28072764	77.45%
3611	TPCODL	BBSR2	KHD	KHURDA	GURUJANGA	14036	11 KV HALADIA	14036201	KERANG NO 4	2152DT190	200	MIXED	AMI	Yes	0%	147	0.16439728	0.061516	0.10288128	62.58%
3612	TPCODL	BBSR2	KHD	KHURDA	GURUJANGA	14036	11 KV HALADIA	14036201	NIALA BAJAR	2152DT214	100	MIXED	AMI	Yes	100%	114	0.042404	0.040567	0.001837	4.33%
3613	TPCODL	BBSR2	KHD	KHURDA	GURUJANGA	14036	11 KV HALADIA	14036201	MUKTAPUR NUA SHAI	2152DT249	100	MIXED	AMI	Yes	100%	76	0.04247562	0.03126	0.01121562	26.40%
3614	TPCODL	BBSR2	KHD	KHURDA	GURUJANGA	14036	11 KV HALADIA	14036201	MUKTAPUR BAZAR NEAR SCHOOL	2152DT256	250	MIXED	AMI	Yes	100%	81	0.07144488	0.027299	0.04414588	61.79%
3615	TPCODL	BBSR2	KHD	KHURDA	GURUJANGA	14036	11 KV HALADIA	14036201	KACHRA SAHI 2 MUKTA PUR	2152DT259	100	MIXED	AMI	Yes	100%	65	0.09056472	0.040475	0.05008972	55.31%
3616	TPCODL	BBSR2	KHD	KHURDA	GURUJANGA	14036	11 KV HALADIA	14036201	MAA MANGLA TEMPLE BAGHEITINGI	2152DT272	100	MIXED	AMI	Yes	0%	150	0.07726566	0.0509	0.02636566	34.12%
3617	TPCODL	BBSR2	KHD	KHURDA	GURUJANGA	14036	11 KV HALADIA	14036201	HALADIA HATA CHOWK	2152DT285	100	MIXED	AMI	Yes	67%	67	0.053764	0.035703	0.018061	33.59%
3618	TPCODL	BBSR2	KHD	KHURDA	GURUJANGA	14036	11 KV HALADIA	14036201	KUAPUT	2152DT306	100	MIXED	AMI	Yes	0%	136	0.06391404	0.055998	0.00791604	12.39%
3619	TPCODL	BBSR2	KHD	KHURDA	JATANI	14033	11 KV KUSUMATI	14033203	MAJURI KUNDA - 1	2143DT132	100	MIXED	AMI	Yes	100%	84	0.08146147	0.058292	0.02316947	28.44%
3620	TPCODL	BBSR2	KHD	KHURDA	OIL MILL	14043	11 KV MUKUNDAPRASAD	14043202	SPINNING MILL	2154DT086	100	MIXED	AMI	Yes	100%	43	0.02307958	0.017963	0.00511658	22.17%
3621	TPCODL	BBSR2	KHD	KHURDA	OIL MILL	14043	11 KV MUKUNDAPRASAD	14043202	JHARATANGI -1	2154DT087	250	MIXED	AMI	Yes	100%	151	0.14442036	0.144266	0.00015436	0.11%
3622	TPCODL	BBSR2	KHD	KHURDA	OIL MILL	14043	11 KV MUKUNDAPRASAD	14043202	JHARATANGI -2	2154DT088	100	MIXED	AMI	Yes	100%	63	0.07978022	0.054948	0.02483222	31.13%
3623	TPCODL	BBSR2	KHD	KHURDA	OIL MILL	14043	11 KV MUKUNDAPRASAD	14043202	FARM	2154DT090	100	MIXED	AMI	Yes	100%	53	0.10532024	0.041956	0.06336424	60.16%
3624	TPCODL	BBSR2	KHD	KHURDA	OIL MILL	14043	11 KV MUKUNDAPRASAD	14043202	BIBHAB VIHAR	2154DT092	100	MIXED	AMI	Yes	100%	21	0.07084986	0.024266	0.04658386	65.75%
3625	TPCODL	BBSR2	KHD	KHURDA	OIL MILL	14043	11 KV MUKUNDAPRASAD	14043202	CHACHARA SAHI	2154DT093	100	MIXED	AMI	Yes	100%	154	0.10412492	0.0767	0.02742492	26.34%
3626	TPCODL	BBSR2	KHD	KHURDA	OIL MILL	14043	11 KV MUKUNDAPRASAD	14043202	BADHEI SAHI	2154DT097	100	MIXED	AMI	Yes	100%	61	0.0585415	0.036554	0.0219875	37.56%
3627	TPCODL	BBSR2	KHD	KHURDA	OIL MILL	14043	11 KV MUKUNDAPRASAD	14043202	JEMADEI ROAD-1	2154DT104	250	MIXED	AMI	Yes	0%	213	0.3062684	0.148392	0.1578764	51.55%
3628	TPCODL	BBSR2	KHD	KHURDA	OIL MILL	14043	11 KV MUKUNDAPRASAD	14043202	EIDKA PADIA(LECTURE COLONY)	2154DT106	100	MIXED	AMI	Yes	33%	64	0.13389684	0.065743	0.06815384	50.90%
3629	TPCODL	BBSR2	KHD	KHURDA	OIL MILL	14043	11 KV MUKUNDAPRASAD	14043202	MELAN PADIA-2	2154DT123	100	MIXED	AMI	Yes	0%	135	0.16303276	0.104421	0.05861176	35.95%
3630	TPCODL	BBSR2	KHD	KHURDA	OIL MILL	14043	11 KV MUKUNDAPRASAD	14043202	KANJIAMA	2154DT133	100	MIXED	AMI	Yes	67%	49	0.05721092	0.046084	0.01112692	19.45%
3631	TPCODL	BBSR2	KHD	KHURDA	OIL MILL	14043	11 KV MUKUNDAPRASAD	14043202	VISWASS COLLEGE BACK SIDE	2154DT145	100	MIXED	AMI	Yes	0%	25	0.0428826	0.037443	0.0054396	12.68%
3632	TPCODL	BBSR2	KHD	KHURDA	OIL MILL	14043	11 KV MUKUNDAPRASAD	14043202	MUKUNDPRASAD BAZAR	2154DT149	500	MIXED	AMI	Yes	67%	156	0.19950424	0.105808	0.09369624	46.96%
3633	TPCODL	BBSR2	KHD	KHURDA	OIL MILL	14043	11 KV MUKUNDAPRASAD	14043202	JAMADEI HB COLONY NEAR NH	2154DT298	100	MIXED	AMI	Yes	0%	22	0.0348762	0.01845	0.0164262	47.10%
3634	TPCODL	BBSR2	KHD	KHURDA	OIL MILL	14043	11 KV INDUSTRIAL-1	14043204	ANIMESH FOOD	2154DT003	100	MIXED	AMI	Yes	0%	9	0.04004854	0.028828	0.01122054	28.02%
3635	TPCODL	BBSR2	KHD	KHURDA	OIL MILL	14043	11 KV INDUSTRIAL-1	14043204	JAGANNATH ICECREAM	2154DT010	250	MIXED	AMI	Yes	100%	17	0.0209436	0.01712	0.0038236	18.26%
3636	TPCODL	BBSR2	KHD	KHURDA	OIL MILL	14043	11 KV TAPANG	14043205	MAA BARUNEI HOTEL OPPOSIT	2154DT193	100	MIXED	AMI	Yes	100%	38	0.05609886	0.027901	0.02819786	50.26%
3637	TPCODL	BBSR2	KHD	KHURDA	OIL MILL	14043	11 KV TAPANG	14043205	GADAKHORDHA HOUSHING BOARD	2154DT199	250	MIXED	AMI	Yes	100%	87	0.09836984	0.055569	0.04280084	43.51%
3638	TPCODL	BBSR2	KHD	KHURDA	OIL MILL	14043	11 KV TAPANG	14043205	PALLA NIUSA NIBARAN	2154DT248	63	MIXED	AMI	Yes	0%	39	0.0524705	0.033568	0.0189025	36.03%
3639	TPCODL	BBSR2	KHD	KHURDA	OIL MILL	14043	11 KV TAPANG	14043205	KADALIBADI SCHOOL	2154DT253	63	MIXED	AMI	Yes	0%	52	0.03073504	0.018895	0.01184004	38.52%
3640	TPCODL	BBSR2	KHD	KHURDA	OIL MILL	14043	11 KV TAPANG	14043205	KADALIBADI VILLAGE	2154DT261	100	MIXED	AMI	Yes	0%	67	0.05464964	0.034108	0.02054164	37.59%
3641	TPCODL	BBSR2	KHD	KHURDA	OIL MILL	14043	11 KV TAPANG	14043205	KALLIKA	2154DT266	250	MIXED	AMI	Yes	100%	56	0.09748644	0.057196	0.04029044	41.33%
3642	TPCODL	BBSR2	KHD	KHURDA	OIL MILL	14043	11 KV TAPANG	14043205	GRAM PANCHAYET OFFICE PALLA TO	2154DT270	250	MIXED	AMI	Yes	0%	112	0.08443076	0.066167	0.01826376	21.63%
3643	TPCODL	BBSR2	KHD	KHURDA	OIL MILL	14043	11 KV OTPL	14043206	HATCHERI	2154DT098	500	MIXED	AMI	Yes	100%	24	0.10812184	0.100284	0.00783784	7.25%
3644	TPCODL	BBSR2	KHD	KHURDA	PARICHHAL	14041	11 KV GUDDUM	14041202	DALATOLA NO-1 CHATARA	2153DT262	100	MIXED	AMI	Yes	67%	132	0.06287884	0.050868	0.01201084	19.10%
3645	TPCODL	BBSR2	KHD	KHURDA	PARICHHAL	14041	11 KV GUDDUM	14041202	NIAMUHA RWSS	2153DT272	25	MIXED	AMI	Yes	67%	99	0.0687223	0.044501	0.0242213	35.25%
3646	TPCODL	BBSR2	KHD	KHURDA	PARICHHAL	14041	11 KV PARICHHAL	14041203	SAMANTARAPUR NO-1	2153DT116	100	MIXED	AMI	Yes	100%	39	0.04340462	0.011705	0.03169962	73.03%
3647	TPCODL	BBSR2	KHD	KHURDA	PARICHHAL	14041	11 KV PARICHHAL	14041203	JAMUSAI NO-1	2153DT130	100	MIXED	AMI	Yes	33%	85	0.023159	0.01693	0.006229	26.90%
3648	TPCODL	BBSR2	KHD	KHURDA	PARICHHAL	14041	11 KV PARICHHAL	14041203	PARICHHALA DURGAR MANDAP NO-	2153DT167	100	MIXED	AMI	Yes	0%	21	0.03438652	0.010857	0.02352952	68.43%
3649	TPCODL	BBSR2	KHD	KHURDA	PARICHHAL	14041	11 KV ROUTPADA	14041205	ROUTAPADA MUSLIM SAHI NO2	2153DT213	100	MIXED	AMI	Yes	100%	105	0.09791242	0.038419	0.05949342	60.76%

Sl. No.	Zone Name	Circle name	Division name	Name of the Sub-division	Name of the Sub-station	Substation Code	Name of the 11 kV Feeder	Feeder Code	Name of the Location where DT situated	DT code	DT Capacity (kVA)	Predominant consumer type of DT (Domestic/Industrial/Agriculture/Mixed)	Type of metering AMR/AMI/ Communicable/Conventional metered/Unmetered	Status of Meter-whether Functional (Yes/No)	% of data received automatically (if AMR/AMI)	No. of Connected Consumers	Input Energy (MU) (A)	Billed Energy (MU) (B)	Loss (MU) (A-B)	% DT Loss (A-B)/A
3650	TPCODL	BBSR2	KHD	KHURDA	SARUA ODSSP	14267	11 KV Kathakhuntia	14267201	NEAR PATANIBARA SAPANESWARA M	2152DT355	100	MIXED	AMI	Yes	0%	109	0.09578466	0.035218	0.06056666	63.23%
3651	TPCODL	BBSR2	KHD	KHURDA	SARUA ODSSP	14267	11 KV Kathakhuntia	14267201	NEAR PATANIBARA SAPANESWARA M	2152DT356	63	MIXED	AMI	Yes	67%	98	0.04239592	0.028563	0.01383292	32.63%
3652	TPCODL	BBSR2	KHD	KHURDA	SARUA ODSSP	14267	11 KV SARUA (Sarua)	14267202	GOPAL SAHI	2152DT451	100	MIXED	AMI	Yes	100%	109	0.08028856	0.043788	0.03650056	45.46%
3653	TPCODL	BBSR2	KHD	KHURDA	SARUA ODSSP	14267	11 KV SARUA (Sarua)	14267202	SARUA MILL	2152DT452	100	MIXED	AMI	Yes	100%	88	0.05178052	0.04266	0.00912052	17.61%
3654	TPCODL	BBSR2	KHD	KHURDA	SARUA ODSSP	14267	11 KV SARUA (Sarua)	14267202	SARUA BAJAR	2152DT467	100	MIXED	AMI	Yes	100%	195	0.10398804	0.09139	0.01259804	12.11%
3655	TPCODL	BBSR2	KHD	KHURDA	SARUA ODSSP	14267	11 KV PUBUSAHI	14267203	SOCAITY OFFICE	2152DT411	100	MIXED	AMI	Yes	100%	83	0.06975584	0.039054	0.03070184	44.01%
3656	TPCODL	BBSR2	KHD	KHURDA	SARUA ODSSP	14267	11 KV PUBUSAHI	14267203	BENAGADIA	2152DT419	100	MIXED	AMI	Yes	100%	116	0.19207244	0.04444	0.14763244	76.86%
3657	TPCODL	BBSR2	KHD	KHURDA	TIRIMAL	14050	11 KV TIRUMALLA	14050201	TIRIMAL KAMAR SAHI	2153DT308	100	MIXED	AMI	Yes	100%	83	0.0364678	0.028583	0.0078848	21.62%
3658	TPCODL	BBSR2	KHD	KHURDA	TIRIMAL	14050	11 KV TARABOI	14050202	ANAL JODI S/S NO2	2153DT403	100	MIXED	AMI	Yes	67%	107	0.06330633	0.046807	0.01649933	26.06%
3659	TPCODL	BBSR2	KHD	KHURDA	TIRIMAL	14050	11 KV TARABOI	14050202	BISIAPADA N0-1	2153DT446	100	MIXED	AMI	Yes	67%	107	0.07571314	0.040349	0.03536414	46.71%
3660	TPCODL	BBSR2	KHD	KHURDA	TIRIMAL	14050	11 KV TARABOI	14050202	DEULABASTA S/S NO-3	2153DT453	100	MIXED	AMI	Yes	0%	62	0.06050438	0.027702	0.03280238	54.21%
3661	TPCODL	BBSR2	KHD	KHURDA	TIRIMAL	14050	11 KV TARABOI	14050202	KORANGA(BALIAR SING SAHI) NO-3	2153DT475	100	MIXED	AMI	Yes	100%	58	0.07377954	0.016984	0.05679554	76.98%
3662	TPCODL	BBSR2	KHD	KHURDA	TIRIMAL	14050	11 KV TARABOI	14050202	TARABOI PATHARA CHAKADA	2153DT479	100	MIXED	AMI	Yes	100%	73	0.07113872	0.024687	0.04645172	65.30%
3663	TPCODL	BBSR2	KHD	KHURDA	TIRIMAL	14050	11 KV TARABOI	14050202	KORANGA OLD NO-1	2153DT480	100	MIXED	AMI	Yes	100%	85	0.07800406	0.023706	0.05429806	69.61%
3664	TPCODL	BBSR2	KHD	KHURDA	TIRIMAL	14050	11 KV TARABOI	14050202	TARABOI PATARA SAHI	2153DT489	250	MIXED	AMI	Yes	100%	130	0.05170184	0.047982	0.00371984	7.19%
3665	TPCODL	BBSR2	KHD	KHURDA	TIRIMAL	14050	11 KV TARABOI	14050202	HARIDAMADA NO-1	2153DT491	100	MIXED	AMI	Yes	100%	88	0.11722712	0.025935	0.09129212	77.88%
3666	TPCODL	BBSR2	NYD	DASPALLA	GANIA	14057	11 KV GANIA	14057201	33/11 kV GANIA SS ST-01	2212DT951	100	MIXED	AMI	Yes	67%	1	0.00380904	0.00376	4.904E-05	1.29%
3667	TPCODL	BBSR2	NYD	DASPALLA	BANIGOCHA(TAKUD	14281	11KV KULURUKUMPA	14281201	JAMUSAHI VILLAGE	2211DT683	100	MIXED	AMI	Yes	0%	36	0.02205288	0.00802	0.01403288	63.63%
3668	TPCODL	BBSR2	NYD	DASPALLA	CHAMUNDIA ODSSI	14277	11 KV CHHAMUNDIA	14277201	CHHAMUNDIA BAZAR	2212DT163	100	MIXED	AMI	Yes	33%	99	0.0314644	0.028333	0.0031314	9.95%
3669	TPCODL	BBSR2	NYD	DASPALLA	CHAMUNDIA ODSSI	14277	11 KV ISWARAPUR	14277202	ISWARPUR-1	2212DT107	100	MIXED	AMI	Yes	33%	106	0.02961132	0.021941	0.00767032	25.90%
3670	TPCODL	BBSR2	NYD	DASPALLA	CHHENDIPADA	14136	11 KV PIPALA BAHALA	14136206	NUAGAON	4231DT553	100	MIXED	AMI	Yes	67%	153	0.0751148	0.032347	0.0427678	56.94%
3671	TPCODL	BBSR2	NYD	DASPALLA	DASPALLA	14059	11 KV DASPALLA TOWN	14059201	TRINATH BAZAR	2211DT001	100	MIXED	AMI	Yes	67%	47	0.0754642	0.033166	0.0422982	56.05%
3672	TPCODL	BBSR2	NYD	DASPALLA	DASPALLA	14059	11 KV DASPALLA TOWN	14059201	IRRIGATION COLONY	2211DT004	250	MIXED	AMI	Yes	67%	292	0.11352052	0.101762	0.01175852	10.36%
3673	TPCODL	BBSR2	NYD	DASPALLA	DASPALLA	14059	11 KV DASPALLA TOWN	14059201	K.C.PURPATANA -2	2211DT010	100	MIXED	AMI	Yes	67%	78	0.03650054	0.032186	0.00431454	11.82%
3674	TPCODL	BBSR2	NYD	DASPALLA	DASPALLA	14059	11 KV DASPALLA TOWN	14059201	PATAPUR PATANA ROAD	2211DT013	100	MIXED	AMI	Yes	67%	138	0.07871506	0.070031	0.00868406	11.03%
3675	TPCODL	BBSR2	NYD	DASPALLA	DASPALLA	14059	11 KV DASPALLA TOWN	14059201	BLOCK OFFICE	2211DT014	250	MIXED	AMI	Yes	0%	114	0.12518888	0.071129	0.05405988	43.18%
3676	TPCODL	BBSR2	NYD	DASPALLA	DASPALLA	14059	11 KV DASPALLA TOWN	14059201	CESU OLD OFFICE	2211DT017	500	MIXED	AMI	Yes	67%	198	0.18290096	0.121046	0.06185496	33.82%
3677	TPCODL	BBSR2	NYD	DASPALLA	DASPALLA	14059	11 KV DASPALLA TOWN	14059201	MAHADEV TEMPLE DEULAMALISAHI	2211DT021	100	MIXED	AMI	Yes	67%	111	0.06301198	0.050414	0.01259798	19.99%
3678	TPCODL	BBSR2	NYD	DASPALLA	DASPALLA	14059	11 KV DASPALLA TOWN	14059201	SRADHAPUR SCHOOL	2211DT073	100	MIXED	AMI	Yes	0%	34	0.01810276	0.004661	0.01344176	74.25%
3679	TPCODL	BBSR2	NYD	DASPALLA	DASPALLA	14059	11 KV DASPALLA TOWN	14059201	OFFICE OF THE SUBREGISTAR DASPAI	2211DT111	100	MIXED	AMI	Yes	67%	72	0.0590831	0.057763	0.0013201	2.23%
3680	TPCODL	BBSR2	NYD	DASPALLA	DASPALLA	14059	11 KV DASPALLA TOWN	14059201	BARAPURKIA-A	2211DT130	63	MIXED	AMI	Yes	0%	119	0.0893506	0.055311	0.0340396	38.10%
3681	TPCODL	BBSR2	NYD	DASPALLA	DASPALLA	14059	11 KV DASPALLA TOWN	14059201	BARAPURKIA-B	2211DT131	100	MIXED	AMI	Yes	67%	131	0.07017642	0.069619	0.00055742	0.79%
3682	TPCODL	BBSR2	NYD	DASPALLA	DASPALLA	14059	11 KV DASPALLA TOWN	14059201	MEDICAL CAMPUS-1	2211DT141	250	MIXED	AMI	Yes	67%	152	0.10638032	0.104389	0.00199132	1.87%
3683	TPCODL	BBSR2	NYD	DASPALLA	DASPALLA	14059	11 KV DASPALLA TOWN	14059201	DASPALLA HIGH SCHOOL	2211DT144	100	MIXED	AMI	Yes	67%	137	0.09879892	0.07324	0.02555892	25.87%
3684	TPCODL	BBSR2	NYD	DASPALLA	DASPALLA	14059	11 KV DASPALLA TOWN	14059201	DASPALLA RAJBATI	2211DT146	100	MIXED	AMI	Yes	67%	116	0.09340038	0.069244	0.02415638	25.86%
3685	TPCODL	BBSR2	NYD	DASPALLA	DASPALLA	14059	11 KV DASPALLA TOWN	14059201	UTTAR KABAT SAHI-2	2211DT151	100	MIXED	AMI	Yes	67%	40	0.03353488	0.024428	0.00910688	27.16%
3686	TPCODL	BBSR2	NYD	DASPALLA	DASPALLA	14059	11 KV DASPALLA TOWN	14059201	MAHAVEER SAHI	2211DT152	100	MIXED	AMI	Yes	67%	119	0.06719546	0.049335	0.01786046	26.58%
3687	TPCODL	BBSR2	NYD	DASPALLA	DASPALLA	14059	11 KV DASPALLA TOWN	14059201	MOHANTY SAHI	2211DT153	100	MIXED	AMI	Yes	67%	59	0.05280744	0.029457	0.02335044	44.22%
3688	TPCODL	BBSR2	NYD	DASPALLA	DASPALLA	14059	11 KV DASPALLA TOWN	14059201	NAHAKAPADA-1	2211DT154	100	MIXED	AMI	Yes	67%	127	0.04634606	0.039611	0.00673506	14.53%
3689	TPCODL	BBSR2	NYD	DASPALLA	DASPALLA	14059	11 KV DASPALLA TOWN	14059201	NAHAKAPADA-2	2211DT155	100	MIXED	AMI	Yes	67%	122	0.07207138	0.035844	0.03622738	50.27%
3690	TPCODL	BBSR2	NYD	DASPALLA	DASPALLA	14059	11 KV MADHYAKHANDA	14059202	SASANASAHI	2211DT310	100	MIXED	AMI	Yes	67%	38	0.03053078	0.010987	0.01954378	64.01%
3691	TPCODL	BBSR2	NYD	DASPALLA	DASPALLA	14059	11 KV MADHYAKHANDA	14059202	MARDA BADI SAHI BARA	2211DT330	250	MIXED	AMI	Yes	67%	228	0.17932784	0.045991	0.13333684	74.35%
3692	TPCODL	BBSR2	NYD	DASPALLA	DASPALLA	14059	11 KV MADHYAKHANDA	14059202	GOBINDPUR PATANA VILLAGE	2211DT349	250	MIXED	AMI	Yes	67%	139	0.03404788	0.023754	0.01029388	30.23%
3693	TPCODL	BBSR2	NYD	DASPALLA	DASPALLA	14059	11 KV MADHYAKHANDA	14059202	GOUDA PATNA	2212DT032	100	MIXED	AMI	Yes	0%	77	0.02504452	0.011593	0.01345152	53.71%
3694	TPCODL	BBSR2	NYD	DASPALLA	DASPALLA	14059	11 KV MADHYAKHANDA	14059202	JAGAN NATH PRASAD JENA SAHI	2212DT083	100	MIXED	AMI	Yes	33%	120	0.04440424	0.037564	0.00684024	15.40%
3695	TPCODL	BBSR2	NYD	DASPALLA	DASPALLA	14059	11 KV MADHYAKHANDA	14059202	JAGAN NATH PRASAD	2212DT086	200	MIXED	AMI	Yes	33%	164	0.05416208	0.036594	0.01756808	32.44%
3696	TPCODL	BBSR2	NYD	DASPALLA	DASPALLA	14059	11 KV POIBARI	14059203	SIMILI SAI VILLAGE	2213DT010	100	MIXED	AMI	Yes	0%	270	0.06960331	0.067616	0.00198731	2.86%
3697	TPCODL	BBSR2	NYD	DASPALLA	DASPALLA	14059	11 KV POIBARI	14059203	KAIMA VILLAGE SCHOOL	2213DT026	100	MIXED	AMI	Yes	67%	71	0.02296848	0.017701	0.00526748	22.93%
3698	TPCODL	BBSR2	NYD	DASPALLA	DASPALLA	14059	11 KV KUANRIA	14059204	DYRGA BAZAR COLONY-2 (Q.I VILLAG	2211DT403	100	MIXED	AMI	Yes	67%	90	0.07365352	0.057307	0.01634652	22.19%
3699	TPCODL	BBSR2	NYD	DASPALLA	DASPALLA	14059	11 KV KUANRIA	14059204	SARIGANDA NEW BRIDGE -3	2211DT425	100	MIXED	AMI	Yes	67%	93	0.04177558	0.03635	0.00542558	12.99%
3700	TPCODL	BBSR2	NYD	DASPALLA	DASPALLA	14059	11 KV KUANRIA	14059204	NILIGUDA HAJAN SAHI-1	2211DT437	100	MIXED	AMI	Yes	67%	98	0.01190858	0.009334	0.00257458	21.62%
3701	TPCODL	BBSR2	NYD	DASPALLA	DASPALLA	14059	11 KV KHAMARSAHI	14059205	DAMAHANDI	2213DT224	250	MIXED	AMI	Yes	67%	178	0.07686468	0.057628	0.01923668	25.03%
3702	TPCODL	BBSR2	NYD	DASPALLA	DASPALLA	14059	11 KV KHAMARSAHI	14059205	PURUNADASAPALLA	2213DT247	100	MIXED	AMI	Yes	33%	61	0.05604644	0.012822	0.04322444	77.12%
3703	TPCODL	BBSR2	NYD	DASPALLA	GANIA	14057	11 KV GANIA	14057201	BALI SAHI	2212DT500	63	MIXED	AMI	Yes	0%	121	0.05780024	0.041648	0.01615224	27.94%
3704	TPCODL	BBSR2	NYD	DASPALLA	GANIA	14057	11 KV GANIA	14057201	GANIA VILLAGE	2212DT506	500	MIXED	AMI	Yes	67%	604	0.35240568	0.269664	0.08274168	23.48%
3705	TPCODL	BBSR2	NYD	DASPALLA	GANIA	14057	11 KV GANIA	14057201	TOTASAHI GANIA	2212DT510	250	MIXED	AMI	Yes	33%	188	0.09476026	0.079923	0.01483726	15.66%
3706	TPCODL	BBSR2	NYD	DASPALLA	GANIA	14057	11 KV GANIA	14057201	BIJAY NAGAR VILLAGE	2212DT513	100	MIXED	AMI	Yes	33%	167	0.07765802	0.05978	0.01787802	23.02%
3707	TPCODL	BBSR2	NYD	DASPALLA	GANIA	14057	11 KV GANIA	14057201	BIJAY NAGAR VILLAGE	2212DT514	250	MIXED	AMI	Yes	33%	172	0.08032512	0.04604845	0.03427667	42.67%
3708	TPCODL	BBSR2	NYD	DASPALLA	GANIA	14057	11 KV GANIA	14057201	BELAPADA VILLAGE	2212DT517	250	MIXED	AMI	Yes	33%	242	0.07848804	0.058319	0.02016904	25.70%
3709	TPCODL	BBSR2	NYD	DASPALLA	GANIA	14057	11 KV GANIA	14057201	WALLIPUR VILLAGE	2212DT521	63	MIXED	AMI	Yes	0%	170	0.0459188	0.026656	0.0192628	41.95%
3710	TPCODL	BBSR2	NYD	DASPALLA	GANIA	14057	11 KV GANIA	14057201	BELAPADA VILLAGE	2212DT523	100	MIXED	AMI	Yes	33%	64	0.02779602	0.020132	0.00766402	27.57%
3711	TPCODL	BBSR2	NYD	DASPALLA	GANIA	14057	11 KV GANIA	14057201	ROUTPADA VILLAGE	2212DT529	100	MIXED	AMI	Yes	0%	122	0.0268941	0.020399	0.0064951	24.15%
3712	TPCODL	BBSR2	NYD	DASPALLA	GANIA	14057	11 KV GANIA	14057201	MALATIPUT VILLAGE	2212DT537	100	MIXED	AMI	Yes	0%	98	0.01998364	0.017279	0.00270464	13.53%
3713	TPCODL	BBSR2	NYD	DASPALLA	GANIA	14057	11 KV GANIA	14057201	MALATIPUT VILLAGE	2212DT538	100	MIXED	AMI	Yes	67%	76	0.02301666	0.010804	0.01221266	53.06%
3714	TPCODL	BBSR2	NYD	DASPALLA	GANIA	14057	11 KV GANIA	14057201	RASANGA GOSALA	2212DT539	100	MIXED	AMI	Yes	0%	86	0.02360746	0.018208	0.00539946	22.87%
3715	TPCODL	BBSR2	NYD	DASPALLA	GANIA	14057	11 KV GANIA	14057201	RASANGA VILLAGE	2212DT540	250	MIXED	AMI	Yes	0%	177	0.03447572	0.033114	0.00136172	3.95%
3716	TPCODL	BBSR2	NYD	DASPALLA	GANIA	14057	11 KV GANIA	14057201	KADUA VILLAGE	2212DT544	100	MIXED	AMI	Yes	0%	107	0.03853978	0.023871	0.01466878	38.06%
3717	TPCODL	BBSR2	NYD	DASPALLA	GANIA	14057	11 KV GANIA	14057201	HATIA PALLI VILLAGE	2212DT549	100	MIXED	AMI	Yes	0%	70	0.0129868	0.011951	0.0010358	7.98%
3718	TPCODL	BBSR2	NYD	DASPALLA	GANIA	14057	11 KV GANIA	14057201	BASANTAPUR VILLAGE	2212DT551	250	MIXED	AMI	Yes	67%	101	0.0283462	0.018339	0.0100072	35.30%
3719	TPCODL	BBSR2	NYD	DASPALLA	GANIA	14057	11 KV KUSKA	14057202	GANIA BLOCK COLONY	2212DT618	100	MIXED	AMI	Yes	33%	102	0.05576442	0.052666	0.00309842	5.56%
3720	TPCODL	BBSR2	NYD	DASPALLA	GANIA	14057	11 KV KUSKA	14057202	GANIA COLLEGE ROAD	2212DT621	100	MIXED	AMI	Yes	0%	32	0.01982012	0.01165	0.00817012	41.22%
3721	TPCODL	BBSR2	NYD	DASPALLA	GANIA	14057	11 KV KUSKA	14057202	KARADAPADA	2212DT633	250	MIXED	AMI	Yes	33%	216	0.05849224	0.047242	0.01125024	19.23%
3722	TPCODL	BBSR2	NYD	DASPALLA	GANIA	14057	11 KV KUSKA	14057202	KUMBHARAPADA TEMPLE	2212DT665	250	MIXED	AMI	Yes	33%	109	0.03337908	0.023183	0.01019608	30.55%

Sl. No.	Zone Name	Circle name	Division name	Name of the Sub-division	Name of the Sub-station	Substation Code	Name of the 11 kV Feeder	Feeder Code	Name of the Location where DT situated	DT code	DT Capacity (kVA)	Predominant consumer type of DT (Domestic/Industrial/Agriculture/Mixed)	Type of metering AMR/AMI/ Communicable/Conventional metered/Unmetered	Status of Meter-whether Functional (Yes/No)	% of data received automatically (if AMR/AMI)	No. of Connected Consumers	Input Energy (MU) (A)	Billed Energy (MU) (B)	Loss (MU) (A-B)	% DT Loss (A-B)/A
3723	TPCODL	BBSR2	NYD	DASPALLA	GANIA	14057	11 KV KUSKA	14057202	KUMBHARAPADA	2212DT675	100	MIXED	AMI	Yes	33%	130	0.03097032	0.020694	0.01027632	33.18%
3724	TPCODL	BBSR2	NYD	DASPALLA	GANIA	14057	11 KV KUSKA	14057202	DHOLAMARA MAHANTI SHI	2212DT679	100	MIXED	AMI	Yes	33%	50	0.03150062	0.009098	0.02240262	71.12%
3725	TPCODL	BBSR2	NYD	DASPALLA	GANIA	14057	11 KV KUSKA	14057202	ANLAPATA	2212DT688	100	MIXED	AMI	Yes	33%	83	0.03541114	0.018196	0.01721514	48.62%
3726	TPCODL	BBSR2	NYD	DASPALLA	GANIA	14057	11 KV KUSKA	14057202	KOSKA	2212DT724	250	MIXED	AMI	Yes	33%	246	0.05222528	0.049425	0.00280028	5.36%
3727	TPCODL	BBSR2	NYD	DASPALLA	GANIA	14057	11 KV KUSKA	14057202	KOSKA ROAD	2212DT727	100	MIXED	AMI	Yes	33%	11	0.00581176	0.003737	0.00207476	35.70%
3728	TPCODL	BBSR2	NYD	DASPALLA	GANIA	14057	11 KV BALARAM	14057203	PATANDA -3	2212DT805	100	MIXED	AMI	Yes	33%	60	0.02917016	0.012135	0.01703516	58.40%
3729	TPCODL	BBSR2	NYD	DASPALLA	GANIA	14057	11 KV BALARAM	14057203	KISHORE PRASAD-2	2212DT815	100	MIXED	AMI	Yes	33%	104	0.033622	0.020129	0.013493	40.13%
3730	TPCODL	BBSR2	NYD	DASPALLA	GANIA	14057	11 KV BALARAM	14057203	INDIPATA-1	2212DT818	100	MIXED	AMI	Yes	33%	73	0.04257144	0.016	0.02657144	62.42%
3731	TPCODL	BBSR2	NYD	DASPALLA	GANIA	14057	11 KV BALARAM	14057203	INDHIPATTA TEMPLE-2	2212DT822	100	MIXED	AMI	Yes	0%	49	0.0228577	0.011118	0.0117397	51.36%
3732	TPCODL	BBSR2	NYD	DASPALLA	GANIA	14057	11 KV BALARAM	14057203	PATURIA-6	2212DT832	100	MIXED	AMI	Yes	33%	80	0.03192946	0.011057	0.02087246	65.37%
3733	TPCODL	BBSR2	NYD	DASPALLA	GANIA	14057	11 KV BALARAM	14057203	BALARAM PRASAD VILLAGE	2212DT845	250	MIXED	AMI	Yes	33%	373	0.0899774	0.066219	0.0237584	26.40%
3734	TPCODL	BBSR2	NYD	DASPALLA	GANIA	14057	11 KV BALARAM	14057203	RAJAKIARI VILLAGE	2212DT852	100	MIXED	AMI	Yes	33%	193	0.0833014	0.041819	0.0414824	49.80%
3735	TPCODL	BBSR2	NYD	DASPALLA	GANIA	14057	11 KV BALARAM	14057203	PANCHAYAT OFFICE FRONT SIDHAMU	2212DT857	100	MIXED	AMI	Yes	33%	91	0.03731412	0.025494	0.01182012	31.68%
3736	TPCODL	BBSR2	NYD	DASPALLA	KANTILO	14055	11 KV BANAPUR	14055202	BADABANPUR NO-1	2233DT133	100	MIXED	AMI	Yes	33%	85	0.03271218	0.022914	0.00979818	29.95%
3737	TPCODL	BBSR2	NYD	DASPALLA	MAHIPUR	14061	11 KV MAHIPUR	14061201	KRUSHNA CHANDRAPUR ROAD SIDE	2244DT808	100	MIXED	AMI	Yes	67%	93	0.02670666	0.015032	0.01167466	43.71%
3738	TPCODL	BBSR2	NYD	DASPALLA	MAHIPUR	14061	11 KV VIRUDA	14061202	CHALAHI VILLAGE 1	2244DT223	250	MIXED	AMI	Yes	0%	137	0.04055212	0.035375	0.00517712	12.77%
3739	TPCODL	BBSR2	NYD	DASPALLA	NUAGAON	14060	11 KV NUAGAON	14060201	KACHA PALLI-2	2213DT141	100	MIXED	AMI	Yes	0%	137	0.06619174	0.05612	0.01007174	15.22%
3740	TPCODL	BBSR2	NYD	DASPALLA	NUAGAON	14060	11 KV NUAGAON	14060201	NUAGAON TOWN	2213DT150	100	MIXED	AMI	Yes	0%	151	0.08974886	0.072325	0.01742386	19.41%
3741	TPCODL	BBSR2	NYD	DASPALLA	NUAGAON	14060	11 KV MAHITAMA	14060203	KARADA-04	2213DT589	100	MIXED	AMI	Yes	67%	221	0.07233342	0.050321	0.02201242	30.43%
3742	TPCODL	BBSR2	NYD	DASPALLA	NUAGAON	14060	11 KV MAHITAMA	14060203	MAHITAMA-08	2213DT601	100	MIXED	AMI	Yes	0%	134	0.03884734	0.029062	0.00978534	25.19%
3743	TPCODL	BBSR2	NYD	DASPALLA	NUAGAON	14060	11 KV MAHITAMA	14060203	MAHITAMA-07	2213DT603	100	MIXED	AMI	Yes	33%	94	0.04437426	0.030429	0.01394526	31.43%
3744	TPCODL	BBSR2	NYD	ITAMATI	BOLAGARH	14052	11 kV DIBYASINGHPUR	14052205	DALI SAHI 2	2221DT335	63	MIXED	AMI	Yes	67%	119	0.0752999	0.043842	0.0314579	41.78%
3745	TPCODL	BBSR2	NYD	ITAMATI	ITAMATI	14053	33 kV BULAGARH	14053401	33/11 kV BOLAGARH SS ST	2221DT950	100	MIXED	AMI	Yes	100%	1	0.00191332	0.001913	3.2E-07	0.02%
3746	TPCODL	BBSR2	NYD	ITAMATI	ITAMATI	14053	11 kV LATHIPADA-1	14053202	GHADUAL & NUA GHADUAL	2222DT112	250	MIXED	AMI	Yes	100%	250	0.19814032	0.163319	0.03482132	17.57%
3747	TPCODL	BBSR2	NYD	ITAMATI	BOLAGARH	14052	11 KV BOLOGARH	14052201	BOLAGARH THANA CHAKA-2	2221DT010	500	MIXED	AMI	Yes	67%	157	0.15142416	0.079946	0.07147816	47.20%
3748	TPCODL	BBSR2	NYD	ITAMATI	BOLAGARH	14052	11 KV BOLOGARH	14052201	BOLAGARH TAHASIL OFFICE-1	2221DT012	250	MIXED	AMI	Yes	0%	105	0.08181686	0.050991	0.03082586	37.68%
3749	TPCODL	BBSR2	NYD	ITAMATI	BOLAGARH	14052	11 KV BOLOGARH	14052201	BOLAGARH NADI HASSON	2221DT019	63	MIXED	AMI	Yes	0%	74	0.0827961	0.02949	0.0533061	64.38%
3750	TPCODL	BBSR2	NYD	ITAMATI	BOLAGARH	14052	11 KV BOLOGARH	14052201	BOLAGARH FIRE STATION NEAR BLOC	2221DT021	100	MIXED	AMI	Yes	67%	81	0.06965522	0.057682	0.01197322	17.19%
3751	TPCODL	BBSR2	NYD	ITAMATI	BOLAGARH	14052	11 KV BOLOGARH	14052201	BOLAGARH CHC	2221DT026	100	MIXED	AMI	Yes	67%	1	0.01861876	0.017846	0.00077276	4.15%
3752	TPCODL	BBSR2	NYD	ITAMATI	BOLAGARH	14052	11 KV BOLOGARH	14052201	BOLAGARH FUSE CELL-1	2221DT028	500	MIXED	AMI	Yes	0%	253	0.11829456	0.113378	0.00491656	4.16%
3753	TPCODL	BBSR2	NYD	ITAMATI	BOLAGARH	14052	11 KV KAPASIA	14052202	GHORORIA 3	2221DT054	250	MIXED	AMI	Yes	33%	105	0.05779708	0.034162	0.02363508	40.89%
3754	TPCODL	BBSR2	NYD	ITAMATI	BOLAGARH	14052	11 KV KAPASIA	14052202	KHALI PATNA	2221DT056	100	MIXED	AMI	Yes	67%	125	0.08721272	0.042762	0.04445072	50.97%
3755	TPCODL	BBSR2	NYD	ITAMATI	BOLAGARH	14052	11 KV KAPASIA	14052202	AROKHAPALLI 1	2221DT059	250	MIXED	AMI	Yes	0%	214	0.11824656	0.064377	0.05386956	45.56%
3756	TPCODL	BBSR2	NYD	ITAMATI	BOLAGARH	14052	11 KV KAPASIA	14052202	ASAN PALLI	2221DT064	100	MIXED	AMI	Yes	67%	114	0.07021592	0.026871	0.04334492	61.73%
3757	TPCODL	BBSR2	NYD	ITAMATI	BOLAGARH	14052	11 KV KAPASIA	14052202	CHUDA 4	2221DT073	100	MIXED	AMI	Yes	67%	145	0.09625001	0.047832	0.04841801	50.30%
3758	TPCODL	BBSR2	NYD	ITAMATI	BOLAGARH	14052	11 KV KAPASIA	14052202	CHUDA MUSLIM SAHI 2	2221DT083	100	MIXED	AMI	Yes	67%	52	0.10959222	0.028063	0.08152922	74.39%
3759	TPCODL	BBSR2	NYD	ITAMATI	BOLAGARH	14052	11 KV KAPASIA	14052202	DABOUR DHOYA 2	2221DT091	100	MIXED	AMI	Yes	67%	76	0.0350022	0.0224	0.0126022	36.00%
3760	TPCODL	BBSR2	NYD	ITAMATI	BOLAGARH	14052	11 KV KAPASIA	14052202	KAPASIA 3	2221DT096	100	MIXED	AMI	Yes	33%	118	0.04094164	0.03586	0.00508164	12.41%
3761	TPCODL	BBSR2	NYD	ITAMATI	BOLAGARH	14052	11 KV KAPASIA	14052202	ROLOSING 3	2221DT098	100	MIXED	AMI	Yes	67%	185	0.05719407	0.048826	0.00836807	14.63%
3762	TPCODL	BBSR2	NYD	ITAMATI	BOLAGARH	14052	11 KV SHYAMSUNDARPU	14052203	BARHAMPURA VILLAGE	2221DT211	100	MIXED	AMI	Yes	67%	69	0.02401838	0.021316	0.00270238	11.25%
3763	TPCODL	BBSR2	NYD	ITAMATI	BOLAGARH	14052	11 KV SHYAMSUNDARPU	14052203	PANCHUKOTA VILLAGE -1	2221DT219	100	MIXED	AMI	Yes	67%	103	0.03335718	0.023502	0.00985518	29.54%
3764	TPCODL	BBSR2	NYD	ITAMATI	BOLAGARH	14052	11 KV SHYAMSUNDARPU	14052203	TANGI SAHI ROAD VILLAGE	2221DT230	250	MIXED	AMI	Yes	67%	415	0.14155768	0.112218	0.02933968	20.73%
3765	TPCODL	BBSR2	NYD	ITAMATI	BOLAGARH	14052	11 KV SHYAMSUNDARPU	14052203	BHIMPADA VILLAGE-1	2221DT235	100	MIXED	AMI	Yes	67%	144	0.0959001	0.060995	0.0349051	36.40%
3766	TPCODL	BBSR2	NYD	ITAMATI	BOLAGARH	14052	11 KV SHYAMSUNDARPU	14052203	DIGHIRI VILLAGE -1	2221DT244	100	MIXED	AMI	Yes	67%	201	0.0918891	0.071586	0.0203031	22.10%
3767	TPCODL	BBSR2	NYD	ITAMATI	BOLAGARH	14052	11 KV SHYAMSUNDARPU	14052203	MANDAL SINGH-1 VILLAGE	2221DT248	100	MIXED	AMI	Yes	100%	173	0.05917068	0.044352	0.01481868	25.04%
3768	TPCODL	BBSR2	NYD	ITAMATI	BOLAGARH	14052	11 KV SHYAMSUNDARPU	14052203	OLD BIJIPUR VILLAGE	2221DT256	100	MIXED	AMI	Yes	67%	124	0.041363	0.032228	0.009135	22.08%
3769	TPCODL	BBSR2	NYD	ITAMATI	BOLAGARH	14052	11 KV SHYAMSUNDARPU	14052203	MARADABADI VILLAGE -4	2221DT265	100	MIXED	AMI	Yes	67%	174	0.05931808	0.049135	0.01018308	17.17%
3770	TPCODL	BBSR2	NYD	ITAMATI	BOLAGARH	14052	11 KV KHANGURIA	14052204	SIKHARA PADA VILLAGE-1	2221DT139	100	MIXED	AMI	Yes	67%	135	0.03489574	0.024177	0.01071874	30.72%
3771	TPCODL	BBSR2	NYD	ITAMATI	BOLAGARH	14052	11 KV KHANGURIA	14052204	NAU PADA VILLAGE	2221DT149	100	MIXED	AMI	Yes	33%	125	0.06940626	0.029091	0.04031526	58.09%
3772	TPCODL	BBSR2	NYD	ITAMATI	BOLAGARH	14052	11 KV KHANGURIA	14052204	GODAVAGA VILLAGE	2221DT155	100	MIXED	AMI	Yes	67%	114	0.07216402	0.025951	0.04621302	64.04%
3773	TPCODL	BBSR2	NYD	ITAMATI	BOLAGARH	14052	11 KV KHANGURIA	14052204	GABADHI PUANIA	2221DT161	100	MIXED	AMI	Yes	67%	50	0.01554156	0.01205	0.00349156	22.47%
3774	TPCODL	BBSR2	NYD	ITAMATI	BOLAGARH	14052	11 KV KHANGURIA	14052204	JODAPADA VILLAGE-1	2221DT168	100	MIXED	AMI	Yes	67%	110	0.0409666	0.030855	0.0101116	24.68%
3775	TPCODL	BBSR2	NYD	ITAMATI	BOLAGARH	14052	11 KV DIBYASINGHPUR	14052205	TINIDOLA JATRA FIELD MALI SAHI 1	2221DT302	100	MIXED	AMI	Yes	67%	148	0.05824125	0.045159	0.01308225	22.46%
3776	TPCODL	BBSR2	NYD	ITAMATI	BOLAGARH	14052	11 KV DIBYASINGHPUR	14052205	MANIKAGODA HEALTH CARE 2	2221DT315	200	MIXED	AMI	Yes	67%	196	0.13609364	0.06109	0.07500364	55.11%
3777	TPCODL	BBSR2	NYD	ITAMATI	BOLAGARH	14052	11 KV DIBYASINGHPUR	14052205	RAMA CHANDRA PUR PATANA 3	2221DT318	100	MIXED	AMI	Yes	67%	47	0.02528386	0.019609	0.00567486	22.44%
3778	TPCODL	BBSR2	NYD	ITAMATI	BOLAGARH	14052	11 KV DIBYASINGHPUR	14052205	RAM CHANDRA PATNA 1	2221DT325	100	MIXED	AMI	Yes	67%	85	0.04108442	0.023255	0.01782942	43.40%
3779	TPCODL	BBSR2	NYD	ITAMATI	BOLAGARH	14052	11 KV DIBYASINGHPUR	14052205	RAM CHANDRA PATNA 2	2221DT326	100	MIXED	AMI	Yes	67%	23	0.00783932	0.00476	0.00307932	39.28%
3780	TPCODL	BBSR2	NYD	ITAMATI	BOLAGARH	14052	11 KV DIBYASINGHPUR	14052205	MANIKAGODA VILLAGE CHANDI PATI	2221DT328	100	MIXED	AMI	Yes	67%	56	0.0432114	0.022748	0.0204634	47.36%
3781	TPCODL	BBSR2	NYD	ITAMATI	BOLAGARH	14052	11 KV DIBYASINGHPUR	14052205	MANIKAGODA VILLAGE KUMUTI SAH	2221DT329	200	MIXED	AMI	Yes	67%	289	0.15061864	0.052244	0.09837464	65.31%
3782	TPCODL	BBSR2	NYD	ITAMATI	BOLAGARH	14052	11 KV DIBYASINGHPUR	14052205	DIBYA SINGH PUR 2	2221DT332	100	MIXED	AMI	Yes	33%	118	0.05723172	0.035851	0.02138072	37.36%
3783	TPCODL	BBSR2	NYD	ITAMATI	BOLAGARH	14052	11 KV DIBYASINGHPUR	14052205	DALI SAHI 3	2221DT336	100	MIXED	AMI	Yes	100%	139	0.08253174	0.045821	0.03671074	44.48%
3784	TPCODL	BBSR2	NYD	ITAMATI	BOLAGARH	14052	11 KV DIBYASINGHPUR	14052205	HATA SAHI 1	2221DT337	250	MIXED	AMI	Yes	67%	131	0.09234716	0.048159	0.04418816	47.85%
3785	TPCODL	BBSR2	NYD	ITAMATI	BOLAGARH	14052	11 KV DIBYASINGHPUR	14052205	KALANGA VILLAGE 1	2221DT343	100	MIXED	AMI	Yes	100%	136	0.0773186	0.042841	0.0344776	44.59%
3786	TPCODL	BBSR2	NYD	ITAMATI	ITAMATI	14053	11 KV ITAMATI	14053201	NARAJANI PATANA_1	2222DT002	100	MIXED	AMI	Yes	0%	120	0.09510202	0.052548	0.04255402	44.75%
3787	TPCODL	BBSR2	NYD	ITAMATI	ITAMATI	14053	11 KV ITAMATI	14053201	NARAJANI PATANA_2	2222DT003	100	MIXED	AMI	Yes	0%	161	0.06945892	0.069249	0.00020992	0.30%
3788	TPCODL	BBSR2	NYD	ITAMATI	ITAMATI	14053	11 KV ITAMATI	14053201	BADATANGI PATANA_1	2222DT005	500	MIXED	AMI	Yes	0%	469	0.62408736	0.255683	0.36840436	59.03%
3789	TPCODL	BBSR2	NYD	ITAMATI	ITAMATI	14053	11 KV ITAMATI	14053201	PRIJHAN SANI	2222DT012	100	MIXED	AMI	Yes	0%	150	0.0831629	0.057176	0.0259869	31.25%
3790	TPCODL	BBSR2	NYD	ITAMATI	ITAMATI	14053	11 KV ITAMATI	14053201	PAIKA SAHI	2222DT013	100	MIXED	AMI	Yes	67%	125	0.05194492	0.039395	0.01254992	24.16%
3791	TPCODL	BBSR2	NYD	ITAMATI	ITAMATI	14053	11 KV ITAMATI	14053201	EKADALIA SAHI_1	2222DT016	100	MIXED	AMI	Yes	100%	97	0.04131216	0.038002	0.00331016	8.01%
3792	TPCODL	BBSR2	NYD	ITAMATI	ITAMATI	14053	11 KV ITAMATI	14053201	KRUSHAN PRASAD	2222DT018	100	MIXED	AMI	Yes	67%	106	0.04557914	0.033242	0.01233714	27.07%
3793	TPCODL	BBSR2	NYD	ITAMATI	ITAMATI	14053	11 KV ITAMATI	14053201	KRUSHAN PRASAD_1	2222DT019	100	MIXED	AMI	Yes	67%	116	0.0470253	0.035589	0.0114363	24.32%
3794	TPCODL	BBSR2	NYD	ITAMATI	ITAMATI	14053	11 KV ITAMATI	14053201	PANCHYAT PARIA	2222DT028	500	MIXED	AMI	Yes	67%	264	0.19153054	0.093776	0.09775454	51.04%
3795	TPCODL	BBSR2	NYD	ITAMATI	ITAMATI	14053	11 KV ITAMATI	14053201	KHATIYA SAHI_1	2222DT030	100	MIXED	AMI	Yes	67%	138	0.07678222	0.058362	0.01842022	23.99%

Sl. No.	Zone Name	Circle name	Division name	Name of the Sub-division	Name of the Sub-station	Substation Code	Name of the 11 kV Feeder	Feeder Code	Name of the Location where DT situated	DT code	DT Capacity (kVA)	Predominant consumer type of DT (Domestic/Industrial/Agriculture/Mixed)	Type of metering AMR/AMI/ Communicable/Conventional metered/Unmetered	Status of Meter- whether Functional (Yes/No)	% of data received automatically (if AMR/AMI)	No. of Connected Consumers	Input Energy (MU) (A)	Billed Energy (MU) (B)	Loss (MU) (A-B)	% DT Loss (A-B)/A
3796	TPCODL	BBSR2	NYD	ITAMATI	ITAMATI	14053	11 KV ITAMATI	14053201	BABAJI KAYAN MANDA	2222DT032	100	MIXED	AMI	Yes	0%	16	0.01300502	0.007407	0.00559802	43.05%
3797	TPCODL	BBSR2	NYD	ITAMATI	ITAMATI	14053	11 KV ITAMATI	14053201	TATI SAHI_1	2222DT034	100	MIXED	AMI	Yes	67%	105	0.05610244	0.0411	0.01500244	26.74%
3798	TPCODL	BBSR2	NYD	ITAMATI	ITAMATI	14053	11 KV ITAMATI	14053201	DELULA SAHI	2222DT045	63	MIXED	AMI	Yes	100%	118	0.06023368	0.049455	0.01077868	17.89%
3799	TPCODL	BBSR2	NYD	ITAMATI	ITAMATI	14053	11 KV ITAMATI	14053201	BADA HARI JAN SAHI_1	2222DT047	100	MIXED	AMI	Yes	0%	204	0.13605674	0.126738	0.00931874	6.85%
3800	TPCODL	BBSR2	NYD	ITAMATI	ITAMATI	14053	11 KV ITAMATI	14053201	MAIN ROAD PUJA DHABA	2222DT049	250	MIXED	AMI	Yes	0%	176	0.14785804	0.141955	0.00590304	3.99%
3801	TPCODL	BBSR2	NYD	ITAMATI	ITAMATI	14053	11 KV ITAMATI	14053201	JAGA NATH SAHI-1	2222DT050	100	MIXED	AMI	Yes	67%	69	0.07533116	0.030834	0.04449716	59.07%
3802	TPCODL	BBSR2	NYD	ITAMATI	ITAMATI	14053	11 KV ITAMATI	14053201	JAGA NATH SAHI-2	2222DT051	100	MIXED	AMI	Yes	100%	128	0.0784	0.058505	0.019895	25.38%
3803	TPCODL	BBSR2	NYD	ITAMATI	ITAMATI	14053	11 KV ITAMATI	14053201	KRUSHAN PRASAD_5	2223DT352	100	MIXED	AMI	Yes	0%	76	0.03670608	0.018661	0.01804508	49.16%
3804	TPCODL	BBSR2	NYD	ITAMATI	ITAMATI	14053	11 KV ITAMATI	14053201	NUAGAON	2223DT355	250	MIXED	AMI	Yes	67%	102	0.0352806	0.026165	0.0091156	25.84%
3805	TPCODL	BBSR2	NYD	ITAMATI	ITAMATI	14053	11 KV LATHIPADA-1	14053202	BALI KUDIA PURUNA NUASAHI -2	2222DT087	100	MIXED	AMI	Yes	67%	70	0.0268021	0.017249	0.0095531	35.64%
3806	TPCODL	BBSR2	NYD	ITAMATI	ITAMATI	14053	11 KV LATHIPADA-1	14053202	PRATAP PRASAD NUASAHI -1	2222DT094	100	MIXED	AMI	Yes	0%	102	0.09267384	0.030987	0.06168684	66.56%
3807	TPCODL	BBSR2	NYD	ITAMATI	ITAMATI	14053	11 KV LATHIPADA-1	14053202	PRATAP PRASAD VILLAGE	2222DT095	100	MIXED	AMI	Yes	0%	138	0.10141712	0.05718	0.04423712	43.62%
3808	TPCODL	BBSR2	NYD	ITAMATI	ITAMATI	14053	11 KV LATHIPADA-1	14053202	GHADUAL MAIN ROAD	2222DT114	100	MIXED	AMI	Yes	100%	125	0.09984826	0.073189	0.02665926	26.70%
3809	TPCODL	BBSR2	NYD	ITAMATI	ITAMATI	14053	11 KV BADA PANDUSARA	14053203	ON. MEIN ROAR	2223DT107	100	MIXED	AMI	Yes	67%	49	0.03408105	0.019084	0.01499705	44.00%
3810	TPCODL	BBSR2	NYD	ITAMATI	ITAMATI	14053	11 KV BADA PANDUSARA	14053203	POST OFFICE	2223DT109	250	MIXED	AMI	Yes	67%	368	0.14403132	0.117462	0.02656932	18.45%
3811	TPCODL	BBSR2	NYD	ITAMATI	ITAMATI	14053	11 KV BADA PANDUSARA	14053203	BADAPANDUSAR SCHOOL -3	2223DT123	100	MIXED	AMI	Yes	33%	128	0.05417632	0.050006	0.00417032	7.70%
3812	TPCODL	BBSR2	NYD	ITAMATI	ITAMATI	14053	11 KV BADA PANDUSARA	14053203	HAREKRISHNA PUR TEMPLE 3	2223DT146	100	MIXED	AMI	Yes	33%	123	0.03269916	0.026871	0.00582816	17.82%
3813	TPCODL	BBSR2	NYD	ITAMATI	ITAMATI	14053	11 KV BADA PANDUSARA	14053203	PUJA LADIES CORNER -2	2223DT154	100	MIXED	AMI	Yes	0%	69	0.04290948	0.027704	0.01520548	35.44%
3814	TPCODL	BBSR2	NYD	ITAMATI	ITAMATI	14053	11 KV BADA PANDUSARA	14053203	PANDERI PATNA	2223DT184	100	MIXED	AMI	Yes	67%	123	0.04172133	0.032711	0.00901033	21.60%
3815	TPCODL	BBSR2	NYD	ITAMATI	ITAMATI	14053	11 KV BADA PANDUSARA	14053203	BIRUDA GADAVITARA SAHI	2223DT186	100	MIXED	AMI	Yes	0%	128	0.04744982	0.040781	0.00666882	14.05%
3816	TPCODL	BBSR2	NYD	ITAMATI	ITAMATI	14053	11 KV BADA PANDUSARA	14053203	KHAIRA PATI PRIMARY SCHOOL -1	2223DT203	63	MIXED	AMI	Yes	67%	85	0.02054792	0.015763	0.00478492	23.29%
3817	TPCODL	BBSR2	NYD	ITAMATI	ITAMATI	14053	11 KV BADA PANDUSARA	14053203	BAGHARA -1	2223DT208	100	MIXED	AMI	Yes	67%	83	0.04381758	0.020994	0.02282358	52.09%
3818	TPCODL	BBSR2	NYD	ITAMATI	ITAMATI	14053	11 KV BADA PANDUSARA	14053203	PURUSHOTTAM PUR MAIN ROAD -2	2223DT222	100	MIXED	AMI	Yes	0%	133	0.06372802	0.031231	0.03249702	50.99%
3819	TPCODL	BBSR2	NYD	ITAMATI	ITAMATI	14053	11 KV BADA PANDUSARA	14053203	BAUSIAPADA -1, NEAR RAIL LINE	2223DT246	100	MIXED	AMI	Yes	67%	7	0.00935939	0.002194	0.00716539	76.56%
3820	TPCODL	BBSR2	NYD	ITAMATI	ITAMATI	14053	11 KV CHAMPATIPUR	14053204	GADHAR PRASAD 100 KV	2223DT015	100	MIXED	AMI	Yes	33%	102	0.0376675	0.023946	0.0137215	36.43%
3821	TPCODL	BBSR2	NYD	ITAMATI	ITAMATI	14053	11 KV CHAMPATIPUR	14053204	GOBINDAPUR 250KV	2223DT018	250	MIXED	AMI	Yes	67%	108	0.0516224	0.039039	0.0125834	24.38%
3822	TPCODL	BBSR2	NYD	ITAMATI	ITAMATI	14053	11 KV CHAMPATIPUR	14053204	GOBINDAPUR	2223DT020	100	MIXED	AMI	Yes	33%	85	0.04529804	0.02924	0.01605804	35.45%
3823	TPCODL	BBSR2	NYD	ITAMATI	ITAMATI	14053	11 KV CHAMPATIPUR	14053204	SARADHAPUR	2223DT024	250	MIXED	AMI	Yes	67%	152	0.06464696	0.03449	0.03015696	46.65%
3824	TPCODL	BBSR2	NYD	ITAMATI	ITAMATI	14053	11 KV CHAMPATIPUR	14053204	SARADHAPUR PANASPATNA	2223DT027	100	MIXED	AMI	Yes	0%	60	0.0244308	0.01404	0.0103908	42.53%
3825	TPCODL	BBSR2	NYD	ITAMATI	ITAMATI	14053	11 KV CHAMPATIPUR	14053204	SARADHAPURA PATNA SAHI	2223DT029	100	MIXED	AMI	Yes	0%	142	0.04027802	0.0292	0.01107802	27.50%
3826	TPCODL	BBSR2	NYD	ITAMATI	ITAMATI	14053	11 KV CHAMPATIPUR	14053204	ARASALI	2223DT030	100	MIXED	AMI	Yes	33%	106	0.03259306	0.024585	0.00800806	24.57%
3827	TPCODL	BBSR2	NYD	ITAMATI	ITAMATI	14053	11 KV CHAMPATIPUR	14053204	PATNA SAHI	2223DT038	100	MIXED	AMI	Yes	67%	123	0.0719379	0.029364	0.0425739	59.18%
3828	TPCODL	BBSR2	NYD	ITAMATI	ITAMATI	14053	11 KV CHAMPATIPUR	14053204	BESIDE PONDS	2223DT050	100	MIXED	AMI	Yes	0%	121	0.0255782	0.021827	0.0037512	14.67%
3829	TPCODL	BBSR2	NYD	ITAMATI	ITAMATI	14053	11 KV CHAMPATIPUR	14053204	SANA PANDUSAR VILLAGE-2	2223DT055	100	MIXED	AMI	Yes	0%	156	0.04709742	0.037797	0.00930042	19.75%
3830	TPCODL	BBSR2	NYD	ITAMATI	ITAMATI	14053	11 KV CHAMPATIPUR	14053204	SALUNI	2223DT060	100	MIXED	AMI	Yes	33%	60	0.03617022	0.017522	0.01864822	51.56%
3831	TPCODL	BBSR2	NYD	ITAMATI	ITAMATI	14053	11 KV CHAMPATIPUR	14053204	GUNTHUNI-1	2223DT083	100	MIXED	AMI	Yes	33%	196	0.0676652	0.035862	0.0318032	47.00%
3832	TPCODL	BBSR2	NYD	ITAMATI	ITAMATI	14053	11 KV CHAMPATIPUR	14053204	SAJANAPADA-2	2223DT096	100	MIXED	AMI	Yes	100%	67	0.03182108	0.015305	0.01651608	51.90%
3833	TPCODL	BBSR2	NYD	ITAMATI	ITAMATI	14053	11 KV CHAMPATIPUR	14053204	MELAMBA-2	2223DT312	100	MIXED	AMI	Yes	33%	66	0.05549108	0.012036	0.04345508	78.31%
3834	TPCODL	BBSR2	NYD	ITAMATI	ITAMATI	14053	11 KV LATHIPADA-2 (Not	14053205	NARASINGHA PRASAD_2	2222DT255	100	MIXED	AMI	Yes	67%	153	0.07805064	0.053532	0.02451864	31.41%
3835	TPCODL	BBSR2	NYD	ITAMATI	ITAMATI	14053	11 KV LATHIPADA-2 (Not	14053205	NARASINGHA PRASAD SCHOOL	2222DT257	100	MIXED	AMI	Yes	0%	62	0.03780694	0.016287	0.02151994	56.92%
3836	TPCODL	BBSR2	NYD	ITAMATI	LATHIPADA ODSSP	14283	11 KV LATHIPADA	14283201	KADUA SAHI_2	2222DT265	100	MIXED	AMI	Yes	67%	69	0.04907836	0.019198	0.02988036	60.88%
3837	TPCODL	BBSR2	NYD	ITAMATI	LATHIPADA ODSSP	14283	11 KV LATHIPADA	14283201	TELI SAHI_1	2222DT269	100	MIXED	AMI	Yes	0%	114	0.08562002	0.031253	0.05436702	63.50%
3838	TPCODL	BBSR2	NYD	ITAMATI	LATHIPADA ODSSP	14283	11 KV LATHIPADA	14283201	BANKSALA VILLAGE	2222DT283	100	MIXED	AMI	Yes	67%	94	0.05206402	0.02439	0.02767402	53.15%
3839	TPCODL	BBSR2	NYD	ITAMATI	LATHIPADA ODSSP	14283	11 KV LATHIPADA	14283201	PAREK SAHI	2222DT508	250	MIXED	AMI	Yes	67%	180	0.07601572	0.055979	0.02003672	26.36%
3840	TPCODL	BBSR2	NYD	ITAMATI	LATHIPADA ODSSP	14283	11 KV NOTAR	14283202	IKIRI VILLAGE 1	2222DT350	100	MIXED	AMI	Yes	67%	109	0.03092266	0.024204	0.00671866	21.73%
3841	TPCODL	BBSR2	NYD	ITAMATI	LATHIPADA ODSSP	14283	11 KV NOTAR	14283202	IKIRI VILLAGE 2	2222DT351	100	MIXED	AMI	Yes	67%	145	0.03305748	0.030693	0.00236448	7.15%
3842	TPCODL	BBSR2	NYD	ITAMATI	LATHIPADA ODSSP	14283	11 KV NOTAR	14283202	SAHKAN VILLAGE 5	2222DT379	100	MIXED	AMI	Yes	33%	98	0.0645139	0.025161	0.0393529	61.00%
3843	TPCODL	BBSR2	NYD	ITAMATI	LATHIPADA ODSSP	14283	11 KV NOTAR	14283202	GADIMADA VILLAGE 3	2222DT431	100	MIXED	AMI	Yes	67%	21	0.01044864	0.003265	0.00718364	68.75%
3844	TPCODL	BBSR2	NYD	ITAMATI	LATHIPADA ODSSP	14283	11 KV RAJPATANA	14283203	LAUSENA VILLAGE -2	2222DT138	100	MIXED	AMI	Yes	33%	64	0.02698226	0.022038	0.00494426	18.32%
3845	TPCODL	BBSR2	NYD	ITAMATI	LATHIPADA ODSSP	14283	11 KV RAJPATANA	14283203	RAJA PATANA -2	2222DT150	100	MIXED	AMI	Yes	0%	21	0.02143384	0.006563	0.01487084	69.38%
3846	TPCODL	BBSR2	NYD	ITAMATI	LATHIPADA ODSSP	14283	11 KV RAJPATANA	14283203	MANDHATAPUR VILLAGE -1	2222DT154	100	MIXED	AMI	Yes	0%	73	0.02586162	0.020556	0.00530562	20.52%
3847	TPCODL	BBSR2	NYD	ITAMATI	LATHIPADA ODSSP	14283	11 KV RAJPATANA	14283203	BEGUNI PATANA VILLAGE -2	2222DT161	100	MIXED	AMI	Yes	0%	99	0.04465992	0.029335	0.01532492	34.31%
3848	TPCODL	BBSR2	NYD	ITAMATI	LATHIPADA ODSSP	14283	11 KV RAJPATANA	14283203	CHINARA VILLAGE -3	2222DT167	100	MIXED	AMI	Yes	67%	91	0.03604692	0.024497	0.01154992	32.04%
3849	TPCODL	BBSR2	NYD	ITAMATI	LATHIPADA ODSSP	14283	11 KV RAJPATANA	14283203	KALIKA PRASAD_1	2222DT168	100	MIXED	AMI	Yes	67%	116	0.03085648	0.026067	0.00478948	15.52%
3850	TPCODL	BBSR2	NYD	ITAMATI	LATHIPADA ODSSP	14283	11 KV RAJPATANA	14283203	KALIKA PRASAD VILLAGE-2	2222DT178	100	MIXED	AMI	Yes	67%	116	0.04590232	0.029781	0.01612132	35.12%
3851	TPCODL	BBSR2	NYD	ITAMATI	LATHIPADA ODSSP	14283	11 KV RAJPATANA	14283203	MANAPUR VILLAGE -1	2222DT189	100	MIXED	AMI	Yes	33%	118	0.0339266	0.026836	0.0070906	20.90%
3852	TPCODL	BBSR2	NYD	ITAMATI	LATHIPADA ODSSP	14283	11 KV GAMBHAIDIHI	14283204	KRISHNA DEIPUR-1	2222DT308	100	MIXED	AMI	Yes	33%	21	0.0089977	0.007416	0.0015817	17.58%
3853	TPCODL	BBSR2	NYD	ITAMATI	LATHIPADA ODSSP	14283	11 KV GAMBHAIDIHI	14283204	BHUTADTHI OLIC 1	2222DT322	100	MIXED	AMI	Yes	0%	203	0.10656874	0.041196	0.06537274	61.34%
3854	TPCODL	BBSR2	NYD	ITAMATI	LATHIPADA ODSSP	14283	11 KV GAMBHAIDIHI	14283204	NANDAPUR & SAMANTAPUR VILLAGI	2222DT337	100	MIXED	AMI	Yes	67%	142	0.0590993	0.054566	0.0045333	7.67%
3855	TPCODL	BBSR2	NYD	ITAMATI	LATHIPADA ODSSP	14283	11 KV GAMBHAIDIHI	14283204	CHANDA SHEKARPUR VILLAGE	2222DT346	100	MIXED	AMI	Yes	67%	93	0.03078946	0.021294	0.00949546	30.84%
3856	TPCODL	BBSR2	NYD	ITAMATI	NAYAGARH	14058	11 KV BARABATI	14058204	HARIPUR PUMP HOUSE -1	2223DT003	100	MIXED	AMI	Yes	33%	95	0.03399626	0.030722	0.00327426	9.63%
3857	TPCODL	BBSR2	NYD	ITAMATI	NAYAGARH	14058	11 KV BARABATI	14058204	HARIPUR PUMP HOUSE -2	2223DT004	100	MIXED	AMI	Yes	33%	66	0.03057076	0.022616	0.00795476	26.02%
3858	TPCODL	BBSR2	NYD	ITAMATI	NAYAGARH	14058	11 KV BARABATI	14058204	ENTRANCE OF HARIPUR	2223DT007	100	MIXED	AMI	Yes	33%	20	0.01669034	0.003958	0.01273234	76.29%
3859	TPCODL	BBSR2	NYD	KHANDAPADA	KHANDAPADA	14054	33 kV FATEGARAH	14054401	33/11 KV FATEGARH SS ST	2232DT950	100	MIXED	AMI	Yes	100%	1	0.00297134	0.002971	3.4E-07	0.01%
3860	TPCODL	BBSR2	NYD	KHANDAPADA	KHANDAPADA	14054	33 kV FATEGARAH	14054401	33/11 kV BIJIPUR SS ST	2232DT951	100	MIXED	AMI	Yes	100%	1	0.00899481	0.008994	8.1E-07	0.01%
3861	TPCODL	BBSR2	NYD	KHANDAPADA	KHANDAPADA	14054	33 kV KANTILO	14054402	33/11 kV BARAKOLI (KOTAPOKHARI)	2233DT951	100	MIXED	AMI	Yes	67%	1	0.01258882	0.012456	0.00013282	1.06%
3862	TPCODL	BBSR2	NYD	KHANDAPADA	BARAKOLI (KOTAPO	14282	11 KV KHALISAHI	14282201	KOTAPOKHORI NUA SAHI	2233DT241	100	MIXED	AMI	Yes	0%	99	0.04873272	0.024463	0.02426972	49.80%
3863	TPCODL	BBSR2	NYD	KHANDAPADA	BARAKOLI (KOTAPO	14282	11 KV KHALISAHI	14282201	MARDARAJPUR VITARA SAHI	2233DT246	100	MIXED	AMI	Yes	67%	108	0.04956692	0.028349	0.02121792	42.81%
3864	TPCODL	BBSR2	NYD	KHANDAPADA	BARAKOLI (KOTAPO	14282	11 KV KHALISAHI	14282201	KHALI SAHI BADA SAHI	2233DT247	100	MIXED	AMI	Yes	33%	183	0.06917676	0.056844	0.01233276	17.83%
3865	TPCODL	BBSR2	NYD	KHANDAPADA	BARAKOLI (KOTAPO	14282	11 KV KHALISAHI	14282201	KOTAPOKHARI HARDABADI	2233DT264	500	MIXED	AMI	Yes	0%	387	0.57893376	0.135265	0.44366876	76.64%
3866	TPCODL	BBSR2	NYD	KHANDAPADA	BARAKOLI (KOTAPO	14282	11 KV KHALISAHI	14282201	KHALI SAHI NELIA CHAKA	2233DT271	100	MIXED	AMI	Yes	67%	182	0.08670422	0.071544	0.01516022	17.48%
3867	TPCODL	BBSR2	NYD	KHANDAPADA	BARAKOLI (KOTAPO	14282	11 KV MARDARAJPUR	14282202	BORAKALI 1	2233DT291	100	MIXED	AMI	Yes	33%	114	0.03584638	0.023186	0.01266038	35.32%
3868	TPCODL	BBSR2	NYD	KHANDAPADA	BARAKOLI (KOTAPO	14282	11 KV MARDARAJPUR	14282202	MARDARAJPUR 1	2233DT296	100	MIXED	AMI	Yes	33%	74	0.06385238	0.025226	0.03862638	60.49%

Sl. No.	Zone Name	Circle name	Division name	Name of the Sub-division	Name of the Sub-station	Substation Code	Name of the 11 kV Feeder	Feeder Code	Name of the Location where DT situated	DT code	DT Capacity (kVA)	Predominant consumer type of DT (Domestic/Industrial/Agriculture/Mixed)	Type of metering AMR/AMI/ Communicable/Conventional metered/Unmetered	Status of Meter-whether Functional (Yes/No)	% of data received automatically (if AMR/AMI)	No. of Connected Consumers	Input Energy (MU) (A)	Billed Energy (MU) (B)	Loss (MU) (A-B)	% DT Loss (A-B)/A
3869	TPCODL	BBSR2	NYD	KHANDAPADA	BARAKOLI (KOTAPO	14282	11 KV MARDARAJPUR	14282202	HARICHANDARPUR	2233DT302	100	MIXED	AMI	Yes	0%	128	0.0450779	0.04131	0.0037679	8.36%
3870	TPCODL	BBSR2	NYD	KHANDAPADA	BARAKOLI (KOTAPO	14282	11 KV MARDARAJPUR	14282202	BODOSA GOLASAHI 3	2233DT309	100	MIXED	AMI	Yes	0%	66	0.05177122	0.012826	0.03894522	75.23%
3871	TPCODL	BBSR2	NYD	KHANDAPADA	BARAKOLI (KOTAPO	14282	11 KV MARDARAJPUR	14282202	BADA BODASA 1	2233DT310	100	MIXED	AMI	Yes	67%	69	0.0583535	0.01676212	0.04159138	71.27%
3872	TPCODL	BBSR2	NYD	KHANDAPADA	BARAKOLI (KOTAPO	14282	11 KV SINGHAPADA	14282203	PATTHAR GANDA -1	2233DT423	100	MIXED	AMI	Yes	67%	121	0.03441274	0.029439	0.00497374	14.45%
3873	TPCODL	BBSR2	NYD	KHANDAPADA	BARAKOLI (KOTAPO	14282	11 KV SINGHAPADA	14282203	SAMAR BINDHA - 3	2233DT466	100	MIXED	AMI	Yes	0%	51	0.02343242	0.006126	0.01730642	73.86%
3874	TPCODL	BBSR2	NYD	KHANDAPADA	BIJIPUR ODSSP	14280	11 KV MARADA	14280201	RAKAMA	2232DT061	100	MIXED	AMI	Yes	67%	193	0.05624346	0.046104	0.01013946	18.03%
3875	TPCODL	BBSR2	NYD	KHANDAPADA	BIJIPUR ODSSP	14280	11 KV MARADA	14280201	CHHELIA-1	2232DT065	100	MIXED	AMI	Yes	67%	81	0.04628314	0.024086	0.02219714	47.96%
3876	TPCODL	BBSR2	NYD	KHANDAPADA	BIJIPUR ODSSP	14280	11 KV MARADA	14280201	RAKAMA 2	2232DT070	100	MIXED	AMI	Yes	0%	96	0.03222032	0.027771	0.00444932	13.81%
3877	TPCODL	BBSR2	NYD	KHANDAPADA	BIJIPUR ODSSP	14280	11 KV MARADA	14280201	NATABARPUR -1	2232DT077	100	MIXED	AMI	Yes	0%	164	0.06707698	0.033633	0.03344398	49.86%
3878	TPCODL	BBSR2	NYD	KHANDAPADA	BIJIPUR ODSSP	14280	11 KV MARADA	14280201	PODASAHI 3	2232DT083	100	MIXED	AMI	Yes	67%	69	0.01754846	0.010327	0.00722146	41.15%
3879	TPCODL	BBSR2	NYD	KHANDAPADA	BIJIPUR ODSSP	14280	11 KV MARADA	14280201	ADIPADA	2232DT085	100	MIXED	AMI	Yes	67%	101	0.02178978	0.017465	0.00432478	19.85%
3880	TPCODL	BBSR2	NYD	KHANDAPADA	BIJIPUR ODSSP	14280	11 KV KARA BARA	14280202	NANDABARA-4 BALISAHI	2232DT208	100	MIXED	AMI	Yes	67%	94	0.0329566	0.023914	0.0090426	27.44%
3881	TPCODL	BBSR2	NYD	KHANDAPADA	BIJIPUR ODSSP	14280	11 KV KARA BARA	14280202	KARABARA-3	2232DT217	100	MIXED	AMI	Yes	0%	75	0.05814323	0.023628	0.03451523	59.36%
3882	TPCODL	BBSR2	NYD	KHANDAPADA	BIJIPUR ODSSP	14280	11 KV KARA BARA	14280202	KARABARA-5 KANDARA SAHI	2232DT219	100	MIXED	AMI	Yes	0%	173	0.04411432	0.043067	0.00104732	2.37%
3883	TPCODL	BBSR2	NYD	KHANDAPADA	BIJIPUR ODSSP	14280	11 KV KARA BARA	14280202	KARABARA-6 KARABAN SUA SAHI	2232DT220	100	MIXED	AMI	Yes	33%	160	0.04215414	0.032883	0.00927114	21.99%
3884	TPCODL	BBSR2	NYD	KHANDAPADA	BIJIPUR ODSSP	14280	11 KV BIJIPUR	14280203	BIJIPUR BAZAR	2232DT123	100	MIXED	AMI	Yes	67%	25	0.04172026	0.013364	0.02835626	67.97%
3885	TPCODL	BBSR2	NYD	KHANDAPADA	BIJIPUR ODSSP	14280	11 KV BIJIPUR	14280203	BIJIPUR-2	2232DT124	100	MIXED	AMI	Yes	0%	177	0.06731185	0.04961	0.01770185	26.30%
3886	TPCODL	BBSR2	NYD	KHANDAPADA	BIJIPUR ODSSP	14280	11 KV BIJIPUR	14280203	SUNAKHELA-2	2232DT126	100	MIXED	AMI	Yes	0%	83	0.0308444	0.028853	0.0019914	6.46%
3887	TPCODL	BBSR2	NYD	KHANDAPADA	BIJIPUR ODSSP	14280	11 KV BIJIPUR	14280203	BIJIPUR KALIKE SAHI	2232DT166	100	MIXED	AMI	Yes	0%	142	0.04140532	0.032405	0.00900032	21.74%
3888	TPCODL	BBSR2	NYD	KHANDAPADA	BIJIPUR ODSSP	14280	11 KV BIJIPUR	14280203	JHALIAPOLLI	2232DT171	100	MIXED	AMI	Yes	0%	57	0.03609552	0.016059	0.02003652	55.51%
3889	TPCODL	BBSR2	NYD	KHANDAPADA	DHALABANDHA OD	14276	11 KV RANICHELI	14276201	JAGANNATPUR	2231DT003	100	MIXED	AMI	Yes	33%	100	0.04474264	0.029618	0.01512464	33.80%
3890	TPCODL	BBSR2	NYD	KHANDAPADA	DHALABANDHA OD	14276	11 KV RANICHELI	14276201	GOHIRIAPADA	2231DT009	100	MIXED	AMI	Yes	33%	150	0.04882326	0.029013	0.01981026	40.58%
3891	TPCODL	BBSR2	NYD	KHANDAPADA	DHALABANDHA OD	14276	11 KV RANICHELI	14276201	NATABARA PRASAD HATIBARI SAHI	2231DT036	100	MIXED	AMI	Yes	0%	39	0.0166928	0.007146	0.0095468	57.19%
3892	TPCODL	BBSR2	NYD	KHANDAPADA	DHALABANDHA OD	14276	11 KV RANICHELI	14276201	KALAPANGI	2231DT039	100	MIXED	AMI	Yes	0%	98	0.04422182	0.017942	0.02627982	59.43%
3893	TPCODL	BBSR2	NYD	KHANDAPADA	DHALABANDHA OD	14276	11 KV RANICHELI	14276201	MARDARAJ PRASAD	2231DT043	100	MIXED	AMI	Yes	0%	133	0.02429478	0.023598	0.00069678	2.87%
3894	TPCODL	BBSR2	NYD	KHANDAPADA	DHALABANDHA OD	14276	11 KV BADASAHARA	14276202	BADASAHARA	2231DT133	500	MIXED	AMI	Yes	0%	206	0.07408936	0.050127	0.02396236	32.34%
3895	TPCODL	BBSR2	NYD	KHANDAPADA	DHALABANDHA OD	14276	11 KV BADASAHARA	14276202	KHUNTUPADA 2	2231DT152	100	MIXED	AMI	Yes	0%	75	0.02137632	0.015574	0.00580232	27.14%
3896	TPCODL	BBSR2	NYD	KHANDAPADA	DHALABANDHA OD	14276	11 KV BADASAHARA	14276202	SUAMADHIPI 1	2231DT154	100	MIXED	AMI	Yes	0%	75	0.01950824	0.01531	0.00419824	21.52%
3897	TPCODL	BBSR2	NYD	KHANDAPADA	DHALABANDHA OD	14276	11 KV BADASAHARA	14276202	KUNJABANPRASAD 2	2231DT159	100	MIXED	AMI	Yes	0%	47	0.02202378	0.014059	0.00796478	36.16%
3898	TPCODL	BBSR2	NYD	KHANDAPADA	DHALABANDHA OD	14276	11 KV SALAPADA	14276203	BARABATI 2	2231DT112	100	MIXED	AMI	Yes	0%	94	0.0395178	0.02211	0.0174078	44.05%
3899	TPCODL	BBSR2	NYD	KHANDAPADA	DHALABANDHA OD	14276	11 KV SALAPADA	14276203	JAMUSAHI 6	2231DT120	100	MIXED	AMI	Yes	0%	202	0.07244516	0.065355	0.00709016	9.79%
3900	TPCODL	BBSR2	NYD	KHANDAPADA	FATEGARH	14056	11 KV FATEGARH	14056201	MUNDIGADIA ROAD SIDE , FATHEGA	2232DT033	100	MIXED	AMI	Yes	0%	163	0.0642643	0.045327	0.0189373	29.47%
3901	TPCODL	BBSR2	NYD	KHANDAPADA	FATEGARH	14056	11 KV FATEGARH	14056201	FATEGARH MEDICAL SAHI	2232DT040	100	MIXED	AMI	Yes	67%	114	0.0358047	0.030044	0.0057607	16.09%
3902	TPCODL	BBSR2	NYD	KHANDAPADA	FATEGARH	14056	11 KV BHAPUR	14056202	BHAPUR SUNDHISAHI	2231DT203	250	MIXED	AMI	Yes	67%	126	0.06148112	0.052458	0.00902312	14.68%
3903	TPCODL	BBSR2	NYD	KHANDAPADA	FATEGARH	14056	11 KV BHAPUR	14056202	BHAPUR GOUDISAHI-2	2231DT207	100	MIXED	AMI	Yes	0%	121	0.0460344	0.039757	0.0062774	13.64%
3904	TPCODL	BBSR2	NYD	KHANDAPADA	FATEGARH	14056	11 KV BHAPUR	14056202	BHAPUR GOUDI SAHI-1	2231DT208	100	MIXED	AMI	Yes	0%	57	0.0272561	0.020509	0.0067471	24.75%
3905	TPCODL	BBSR2	NYD	KHANDAPADA	FATEGARH	14056	11 KV BHAPUR	14056202	BHAPUR COLLAGE ROAD	2231DT216	100	MIXED	AMI	Yes	0%	69	0.06211892	0.038626	0.02349292	37.82%
3906	TPCODL	BBSR2	NYD	KHANDAPADA	FATEGARH	14056	11 KV BHAPUR	14056202	JAGANNATH TEMPLE 250KVA	2231DT218	500	MIXED	AMI	Yes	0%	198	0.10737504	0.092788	0.01458704	13.59%
3907	TPCODL	BBSR2	NYD	KHANDAPADA	FATEGARH	14056	11 KV BHAPUR	14056202	MANDARBERANI VILLAGE 100KVA	2231DT233	100	MIXED	AMI	Yes	0%	14	0.01144576	0.002903	0.00854276	74.64%
3908	TPCODL	BBSR2	NYD	KHANDAPADA	FATEGARH	14056	11 KV BHAPUR	14056202	SALAPADA BUS STOP.-2	2231DT242	100	MIXED	AMI	Yes	0%	117	0.04228388	0.031252	0.01103188	26.09%
3909	TPCODL	BBSR2	NYD	KHANDAPADA	FATEGARH	14056	11 KV BHAPUR	14056202	BHAPUR PETROL PUMP OPOSITE VET	2231DT257	250	MIXED	AMI	Yes	67%	200	0.15535572	0.119389	0.03596672	23.15%
3910	TPCODL	BBSR2	NYD	KHANDAPADA	FATEGARH	14056	11 KV GOLAPOKHARI	14056203	MARICHIA 1	2231DT300	100	MIXED	AMI	Yes	0%	88	0.03032674	0.021605	0.00872174	28.76%
3911	TPCODL	BBSR2	NYD	KHANDAPADA	FATEGARH	14056	11 KV GOLAPOKHARI	14056203	BEGUNIA 1	2231DT315	100	MIXED	AMI	Yes	33%	127	0.0428794	0.03077	0.0121094	28.24%
3912	TPCODL	BBSR2	NYD	KHANDAPADA	FATEGARH	14056	11 KV GOLAPOKHARI	14056203	TARBALO 5	2231DT342	100	MIXED	AMI	Yes	33%	86	0.03522406	0.019053	0.01617106	45.91%
3913	TPCODL	BBSR2	NYD	KHANDAPADA	FATEGARH	14056	11 KV GOLAPOKHARI	14056203	SAGARGAUN 2	2231DT347	100	MIXED	AMI	Yes	0%	76	0.03728194	0.019271	0.01801094	48.31%
3914	TPCODL	BBSR2	NYD	KHANDAPADA	FATEGARH	14056	11 KV GOLAPOKHARI	14056203	HALADIPADA	2231DT366	100	MIXED	AMI	Yes	0%	165	0.05470162	0.038146	0.01655562	30.27%
3915	TPCODL	BBSR2	NYD	KHANDAPADA	FATEGARH	14056	11 KV GOLAPOKHARI	14056203	GODIALLI 6	2231DT370	100	MIXED	AMI	Yes	0%	227	0.07720714	0.050737	0.02647014	34.28%
3916	TPCODL	BBSR2	NYD	KHANDAPADA	FATEGARH	14056	11 KV GOLAPOKHARI	14056203	CHAKRADHAR PRASAD	2231DT400	100	MIXED	AMI	Yes	33%	127	0.05237734	0.032561	0.01981634	37.83%
3917	TPCODL	BBSR2	NYD	KHANDAPADA	FATEGARH	14056	11 KV GOLAPOKHARI	14056203	CHAKRADHAR PRASAD 4	2231DT404	100	MIXED	AMI	Yes	33%	92	0.02833136	0.017828	0.01050336	37.07%
3918	TPCODL	BBSR2	NYD	KHANDAPADA	FATEGARH	14056	11 KV GOLAPOKHARI	14056203	GOLAPAKHARI 1	2231DT408	100	MIXED	AMI	Yes	33%	67	0.02823064	0.016638	0.01159264	41.06%
3919	TPCODL	BBSR2	NYD	KHANDAPADA	FATEGARH	14056	11 KV GOLAPOKHARI	14056203	BALIAPATA	2231DT424	100	MIXED	AMI	Yes	0%	138	0.04038672	0.027978	0.01240872	30.72%
3920	TPCODL	BBSR2	NYD	KHANDAPADA	KANTILO	14055	11 KV KANTILO	14055201	DHOBA SAHI-2	2233DT017	250	MIXED	AMI	Yes	67%	85	0.10964096	0.025934	0.08370696	76.35%
3921	TPCODL	BBSR2	NYD	KHANDAPADA	KANTILO	14055	11 KV KANTILO	14055201	VETENARY-1	2233DT026	100	MIXED	AMI	Yes	0%	243	0.1071081	0.085773	0.0213351	19.92%
3922	TPCODL	BBSR2	NYD	KHANDAPADA	KANTILO	14055	11 KV KANTILO	14055201	VETENARY-2	2233DT027	250	MIXED	AMI	Yes	67%	129	0.13982144	0.048133	0.09168844	65.58%
3923	TPCODL	BBSR2	NYD	KHANDAPADA	KANTILO	14055	11 KV KANTILO	14055201	THODIA SAHI	2233DT030	250	MIXED	AMI	Yes	0%	274	0.1237694	0.093335	0.0304344	24.59%
3924	TPCODL	BBSR2	NYD	KHANDAPADA	KANTILO	14055	11 KV KANTILO	14055201	GODISAHI	2233DT044	100	MIXED	AMI	Yes	67%	90	0.02373428	0.018608	0.00512628	21.60%
3925	TPCODL	BBSR2	NYD	KHANDAPADA	KANTILO	14055	11 KV KANTILO	14055201	MADHUPUR 3	2233DT052	100	MIXED	AMI	Yes	0%	187	0.06545586	0.048013	0.01744286	26.65%
3926	TPCODL	BBSR2	NYD	KHANDAPADA	KANTILO	14055	11 KV KANTILO	14055201	MADHAPUR 6	2233DT057	100	MIXED	AMI	Yes	0%	192	0.0521821	0.040497	0.0116851	22.39%
3927	TPCODL	BBSR2	NYD	KHANDAPADA	KANTILO	14055	11 KV KANTILO	14055201	KAXMIPRASAD 2	2233DT066	100	MIXED	AMI	Yes	0%	85	0.01899042	0.014873	0.00411742	21.68%
3928	TPCODL	BBSR2	NYD	KHANDAPADA	KANTILO	14055	11 KV KANTILO	14055201	BHANCHANDAGADA 2	2233DT077	100	MIXED	AMI	Yes	0%	68	0.02133426	0.011222	0.01011226	47.40%
3929	TPCODL	BBSR2	NYD	KHANDAPADA	KANTILO	14055	11 KV BENAGADIA	14055203	GOPINATHPUR -3	2233DT173	100	MIXED	AMI	Yes	33%	87	0.01877636	0.015419	0.00335736	17.88%
3930	TPCODL	BBSR2	NYD	KHANDAPADA	KANTILO	14055	11 KV BENAGADIA	14055203	MANGARAJPUR -2	2233DT202	100	MIXED	AMI	Yes	0%	71	0.029831	0.011841	0.01799	60.31%
3931	TPCODL	BBSR2	NYD	KHANDAPADA	KANTILO	14055	11 KV BENAGADIA	14055203	PATTHAR DWAR -4	2233DT224	100	MIXED	AMI	Yes	33%	111	0.02590444	0.016353	0.00955144	36.87%
3932	TPCODL	BBSR2	NYD	KHANDAPADA	KANTILO	14055	11 KV BENAGADIA	14055203	TENTULIA PALLI - 1	2233DT225	100	MIXED	AMI	Yes	33%	235	0.04881192	0.041111	0.00770092	15.78%
3933	TPCODL	BBSR2	NYD	KHANDAPADA	KANTILO	14055	11 KV BENAGADIA	14055203	TENTULIA PALLI - 2	2233DT227	100	MIXED	AMI	Yes	33%	123	0.03029466	0.01667	0.01362466	44.97%
3934	TPCODL	BBSR2	NYD	KHANDAPADA	KANTILO	14055	11 KV BENAGADIA	14055203	BENAGADIA - 3	2233DT229	100	MIXED	AMI	Yes	0%	100	0.03823412	0.021335	0.01689912	44.20%
3935	TPCODL	BBSR2	NYD	KHANDAPADA	KANTILO	14055	11 KV BENAGADIA	14055203	KODUA - 1	2233DT232	100	MIXED	AMI	Yes	33%	83	0.02699046	0.017025	0.00996546	36.92%
3936	TPCODL	BBSR2	NYD	KHANDAPADA	KHANDAPADA	14054	11 KV KHANDAPADA	14054201	NUASAHASPUR1	2234DT004	100	MIXED	AMI	Yes	0%	76	0.0317064	0.01983	0.0118764	37.46%
3937	TPCODL	BBSR2	NYD	KHANDAPADA	KHANDAPADA	14054	11 KV KHANDAPADA	14054201	NEAR SUBSTETION	2234DT009	100	MIXED	AMI	Yes	0%	53	0.04503546	0.020103	0.02493246	55.36%
3938	TPCODL	BBSR2	NYD	KHANDAPADA	KHANDAPADA	14054	11 KV KHANDAPADA	14054201	KHANDAPADA1	2234DT010	100	MIXED	AMI	Yes	0%	79	0.04622892	0.033751	0.01247792	26.99%
3939	TPCODL	BBSR2	NYD	KHANDAPADA	KHANDAPADA	14054	11 KV KHANDAPADA	14054201	KHANDAPADA TINA CHAKA NEAR PLA	2234DT015	100	MIXED	AMI	Yes	0%	73	0.04351518	0.027207	0.01630818	37.48%
3940	TPCODL	BBSR2	NYD	KHANDAPADA	KHANDAPADA	14054	11 KV KHANDAPADA	14054201	ROAD SIDE NEAR Odisha Adarsha Vid	2234DT025	63	MIXED	AMI	Yes	100%	22	0.011848	0.00937	0.002478	20.91%
3941	TPCODL	BBSR2	NYD	KHANDAPADA	KHANDAPADA	14054	11 KV KHANDAPADA	14054201	FRONT OF KHANDAPADA CORT1	2234DT027	100	MIXED	AMI	Yes	100%	59	0.05336174	0.039159	0.01420274	26.62%

Sl. No.	Zone Name	Circle name	Division name	Name of the Sub-division	Name of the Sub-station	Substation Code	Name of the 11 kV Feeder	Feeder Code	Name of the Location where DT situated	DT code	DT Capacity (kVA)	Predominant consumer type of DT (Domestic/Industrial/Agriculture/Mixed)	Type of metering AMR/AMI/ Communicable/Conventional metered/Unmetered	Status of Meter- whether Functional (Yes/No)	% of data received automatically (if AMR/AMI)	No. of Connected Consumers	Input Energy (MU) (A)	Billed Energy (MU) (B)	Loss (MU) (A-B)	% DT Loss (A-B)/A
3942	TPCODL	BBSR2	NYD	KHANDAPADA	KHANDAPADA	14054	11 KV KHANDAPADA	14054201	FRONT OF KHANDAPADA CORT 2	2234DT028	100	MIXED	AMI	Yes	100%	40	0.03002886	0.02417	0.00585886	19.51%
3943	TPCODL	BBSR2	NYD	KHANDAPADA	KHANDAPADA	14054	11 KV KHANDAPADA	14054201	OF KHANDAPADA PHD	2234DT029	100	MIXED	AMI	Yes	0%	59	0.07442938	0.058956	0.01547338	20.79%
3944	TPCODL	BBSR2	NYD	KHANDAPADA	KHANDAPADA	14054	11 KV KHANDAPADA	14054201	TULASIBANI IPDS	2234DT030	100	MIXED	AMI	Yes	0%	100	0.0827673	0.061938	0.0208293	25.17%
3945	TPCODL	BBSR2	NYD	KHANDAPADA	KHANDAPADA	14054	11 KV KHANDAPADA	14054201	KARADABANI VILLAGE	2234DT035	100	MIXED	AMI	Yes	0%	46	0.01049404	0.009221	0.00127304	12.13%
3946	TPCODL	BBSR2	NYD	KHANDAPADA	KHANDAPADA	14054	11 KV KHANDAPADA	14054201	TALA SAHI1	2234DT041	100	MIXED	AMI	Yes	0%	64	0.04676702	0.028337	0.01843002	39.41%
3947	TPCODL	BBSR2	NYD	KHANDAPADA	KHANDAPADA	14054	11 KV KHANDAPADA	14054201	TALA SAHI2	2234DT042	100	MIXED	AMI	Yes	0%	82	0.0377381	0.036588	0.0011501	3.05%
3948	TPCODL	BBSR2	NYD	KHANDAPADA	KHANDAPADA	14054	11 KV KHANDAPADA	14054201	POST OFFICE	2234DT043	100	MIXED	AMI	Yes	0%	50	0.03330924	0.029281	0.00402824	12.09%
3949	TPCODL	BBSR2	NYD	KHANDAPADA	KHANDAPADA	14054	11 KV KHANDAPADA	14054201	KADUA SAHI-2	2234DT044	100	MIXED	AMI	Yes	0%	11	0.01785888	0.008715	0.00914388	51.20%
3950	TPCODL	BBSR2	NYD	KHANDAPADA	KHANDAPADA	14054	11 KV KHANDAPADA	14054201	KADUA SAHI-1	2234DT045	250	MIXED	AMI	Yes	0%	150	0.07839316	0.059928	0.01846516	23.55%
3951	TPCODL	BBSR2	NYD	KHANDAPADA	KHANDAPADA	14054	11 KV KHANDAPADA	14054201	RATHAGADA 2	2234DT053	100	MIXED	AMI	Yes	0%	164	0.07412248	0.064308	0.00981448	13.24%
3952	TPCODL	BBSR2	NYD	KHANDAPADA	KHANDAPADA	14054	11 KV KHANDAPADA	14054201	HARIZAN SAHI	2234DT059	100	MIXED	AMI	Yes	0%	75	0.04265848	0.032176	0.01048248	24.57%
3953	TPCODL	BBSR2	NYD	KHANDAPADA	KHANDAPADA	14054	11 KV KHANDAPADA	14054201	JAIL KHANA 1	2234DT060	100	MIXED	AMI	Yes	0%	7	0.01954856	0.006804	0.01274456	65.19%
3954	TPCODL	BBSR2	NYD	KHANDAPADA	KHANDAPADA	14054	11 KV KHANDAPADA	14054201	KUNDRA SAHI 1	2234DT061	100	MIXED	AMI	Yes	0%	21	0.0125506	0.010457	0.0020936	16.68%
3955	TPCODL	BBSR2	NYD	KHANDAPADA	KHANDAPADA	14054	11 KV KHANDAPADA	14054201	DASANDISAHI1	2234DT064	100	MIXED	AMI	Yes	0%	114	0.09333362	0.050713	0.04262062	45.66%
3956	TPCODL	BBSR2	NYD	KHANDAPADA	KHANDAPADA	14054	11 KV BAIGUNIA	14054202	TARENI CHHAKA-2	2234DT082	250	MIXED	AMI	Yes	0%	181	0.13597448	0.083784	0.05219048	38.38%
3957	TPCODL	BBSR2	NYD	KHANDAPADA	KHANDAPADA	14054	11 KV BAIGUNIA	14054202	HADAGODIA SAHI BAIGUNIA	2234DT086	100	MIXED	AMI	Yes	0%	265	0.09183632	0.067365	0.02447132	26.65%
3958	TPCODL	BBSR2	NYD	KHANDAPADA	KHANDAPADA	14054	11 KV BAIGUNIA	14054202	BAIGUNIA PATANA SAHI	2234DT091	100	MIXED	AMI	Yes	0%	96	0.0415043	0.03495	0.0065543	15.79%
3959	TPCODL	BBSR2	NYD	KHANDAPADA	KHANDAPADA	14054	11 KV BAIGUNIA	14054202	BAHADA MANDIRA SAHI	2234DT092	100	MIXED	AMI	Yes	33%	146	0.03426218	0.032348	0.00191418	5.59%
3960	TPCODL	BBSR2	NYD	KHANDAPADA	KHANDAPADA	14054	11 KV BAIGUNIA	14054202	BANAMALIPUR BADA SAHI	2234DT098	100	MIXED	AMI	Yes	0%	213	0.06436514	0.048017	0.01634814	25.40%
3961	TPCODL	BBSR2	NYD	KHANDAPADA	KHANDAPADA	14054	11 KV BAIGUNIA	14054202	BANAMALIPUR HIGH SCHOOL_02	2234DT100	100	MIXED	AMI	Yes	33%	118	0.04646644	0.04174	0.00472644	10.17%
3962	TPCODL	BBSR2	NYD	KHANDAPADA	KHANDAPADA	14054	11 KV BAIGUNIA	14054202	BAIGINIA DERA SAHI	2234DT115	100	MIXED	AMI	Yes	0%	96	0.05164294	0.031791	0.01985194	38.44%
3963	TPCODL	BBSR2	NYD	KHANDAPADA	KHANDAPADA	14054	11 KV BAIGUNIA	14054202	BHAGABANPUR	2234DT159	100	MIXED	AMI	Yes	0%	205	0.0479899	0.038025	0.0099649	20.76%
3964	TPCODL	BBSR2	NYD	KHANDAPADA	KHANDAPADA	14054	11 KV BAIGUNIA	14054202	LUNIAUTI SCHOOL_01	2234DT165	100	MIXED	AMI	Yes	33%	46	0.01747736	0.007932	0.00954536	54.62%
3965	TPCODL	BBSR2	NYD	KHANDAPADA	KHANDAPADA	14054	11 KV BAIGUNIA	14054202	KESHAR SINGH	2234DT168	100	MIXED	AMI	Yes	33%	82	0.01750934	0.014313	0.00319634	18.26%
3966	TPCODL	BBSR2	NYD	KHANDAPADA	KHANDAPADA	14054	11 KV PANIPOILL	14054203	BARAPALLI VILLAGE_01	2234DT280	100	MIXED	AMI	Yes	67%	140	0.04269804	0.032375	0.01032304	24.18%
3967	TPCODL	BBSR2	NYD	KHANDAPADA	KHANDAPADA	14054	11 KV PANIPOILL	14054203	SHIKARPUR VILLAGE	2234DT284	100	MIXED	AMI	Yes	67%	31	0.01700566	0.014733	0.00227266	13.36%
3968	TPCODL	BBSR2	NYD	KHANDAPADA	KHANDAPADA	14054	11 KV PANIPOILL	14054203	BIRIDIHI VILLAGE_01	2234DT316	100	MIXED	AMI	Yes	33%	42	0.01873592	0.015073	0.00366292	19.55%
3969	TPCODL	BBSR2	NYD	KHANDAPADA	KHANDAPADA	14054	11 KV PANIPOILL	14054203	NAYAPALLI_03	2234DT343	100	MIXED	AMI	Yes	33%	112	0.02598144	0.016294	0.00968744	37.29%
3970	TPCODL	BBSR2	NYD	KHANDAPADA	KHANDAPADA	14054	11 KV PANIPOILL	14054203	LAXMIPRASADA VILLAGE	2234DT353	100	MIXED	AMI	Yes	33%	54	0.02116578	0.017121	0.00404478	19.11%
3971	TPCODL	BBSR2	NYD	KHANDAPADA	KHANDAPADA	14054	11 KV PANIPOILL	14054203	JOGIAPALLI ROAD SIDE 100 KVA_01	2234DT369	100	MIXED	AMI	Yes	0%	119	0.04978982	0.038515	0.01127482	22.64%
3972	TPCODL	BBSR2	NYD	KHANDAPADA	KHANDAPADA	14054	11 KV PANIPOILL	14054203	JOGIYAPALLI TOLOSAHI 100KVA	2234DT371	100	MIXED	AMI	Yes	67%	55	0.01768838	0.013273	0.00441538	24.96%
3973	TPCODL	BBSR2	NYD	KHANDAPADA	MACHHIPADA ODSS	14279	11 KV KALYANPUR	14279202	KALYANPUR BUDHI MAA TEMPLE-1	2245DT224	100	MIXED	AMI	Yes	67%	99	0.03090589	0.021641	0.00926489	29.98%
3974	TPCODL	BBSR2	NYD	NAYAGARH	NAYAGARH	14058	11 kV OLD TOWN	14058202	GOPINATH TEMPLE - II	2241DT169	250	MIXED	AMI	Yes	67%	61	0.09757744	0.037027	0.06055044	62.05%
3975	TPCODL	BBSR2	NYD	NAYAGARH	MACHHIPADA ODSS	14279	11 kV LEKUDIPADA	14279204	PRINUPLE PTS_01	2241DT361	250	MIXED	AMI	Yes	67%	73	0.10087036	0.04317	0.05770036	57.20%
3976	TPCODL	BBSR2	NYD	NAYAGARH	ODOGAON	14063	33 kV KURAL & HARIPUR	14063401	33/11 KV HARIPUR SS ST	2242DT950	100	MIXED	AMI	Yes	67%	1	0.00803652	0.007883	0.00015352	1.91%
3977	TPCODL	BBSR2	NYD	NAYAGARH	ODOGAON	14063	33 kV KURAL & HARIPUR	14063401	33/11 kV KURAL SS ST	2243DT952	100	MIXED	AMI	Yes	100%	1	0.00679544	0.006792	3.44E-06	0.05%
3978	TPCODL	BBSR2	NYD	NAYAGARH	NAYAGARH	17011	33 kV KHANDAPADA	17011403	33/11 kV BALUGAON (PANIPOILA) SS	2244DT950	100	MIXED	AMI	Yes	100%	1	0.00876203	0.008762	3E-08	0.00%
3979	TPCODL	BBSR2	NYD	NAYAGARH	MACHHIPADA ODSS	14279	11 kV LEKUDIPADA	14279204	KAITHAGADIA_02	2245DT034	100	MIXED	AMI	Yes	0%	106	0.05522892	0.045002	0.01022692	18.52%
3980	TPCODL	BBSR2	NYD	NAYAGARH	NAYAGARH	17011	33 kV LATHIPADA	17011407	33/11 KV LATHIPADA SS ST	2245DT950	100	MIXED	AMI	Yes	100%	1	0.01447399	0.014473	9.9E-07	0.01%
3981	TPCODL	BBSR2	NYD	NAYAGARH	NAYAGARH	17011	33 kV MACHHIPADA	17011409	33/11 kV MACHHIPADA SS ST	2245DT951	100	MIXED	AMI	Yes	100%	1	0.01272354	0.012724	-4.6E-07	0.00%
3982	TPCODL	BBSR2	NYD	NAYAGARH	NAYAGARH	17011	33 kV GODIPADA	17011408	33/11 kV GODIPADA SS ST	2246DT950	100	MIXED	AMI	Yes	67%	1	0.00547324	0.005377	0.00009624	1.76%
3983	TPCODL	BBSR2	NYD	NAYAGARH	BALUGAON (PANIP	14278	11 KV PANIPOILA	14278201	JAY MANGAL PRASAD_4	2244DT109	100	MIXED	AMI	Yes	33%	15	0.02446874	0.005636	0.01883274	76.97%
3984	TPCODL	BBSR2	NYD	NAYAGARH	BALUGAON (PANIP	14278	11 KV PANIPOILA	14278201	JAY MANGAL PRASAD_3	2244DT110	100	MIXED	AMI	Yes	0%	32	0.0170888	0.013286	0.0038028	22.25%
3985	TPCODL	BBSR2	NYD	NAYAGARH	BALUGAON (PANIP	14278	11 KV PANIPOILA	14278201	KANTABANIA_2	2244DT119	250	MIXED	AMI	Yes	67%	110	0.05278856	0.038366	0.01442256	27.32%
3986	TPCODL	BBSR2	NYD	NAYAGARH	BALUGAON (PANIP	14278	11 KV MALISAHI	14278202	BALUGAN CHANDI HUDA	2244DT049	500	MIXED	AMI	Yes	67%	411	0.21366592	0.15223	0.06143592	28.75%
3987	TPCODL	BBSR2	NYD	NAYAGARH	BALUGAON (PANIP	14278	11 KV MALISAHI	14278202	JEMADEIPUR_1	2244DT056	100	MIXED	AMI	Yes	67%	103	0.04597974	0.0335	0.01247974	27.14%
3988	TPCODL	BBSR2	NYD	NAYAGARH	BALUGAON (PANIP	14278	11 KV MALISAHI	14278202	KANCHAN BELLI	2244DT077	100	MIXED	AMI	Yes	0%	83	0.04349666	0.020471	0.02302566	52.94%
3989	TPCODL	BBSR2	NYD	NAYAGARH	BALUGAON (PANIP	14278	11 KV MALISAHI	14278202	KHANDUGAON	2244DT180	250	MIXED	AMI	Yes	67%	209	0.07814124	0.048169	0.02997224	38.36%
3990	TPCODL	BBSR2	NYD	NAYAGARH	BIJIPUR ODSSP	14280	11 KV KARA BARA	14280202	PADMABATI-9 TALA SAHI	2232DT197	250	MIXED	AMI	Yes	0%	236	0.08799644	0.063617	0.02437944	27.71%
3991	TPCODL	BBSR2	NYD	NAYAGARH	FATEGARH	14056	11 KV GOLAPOKHARI	14056203	JAGODISHPRASAD	2231DT417	100	MIXED	AMI	Yes	33%	87	0.02860336	0.022462	0.00614136	21.47%
3992	TPCODL	BBSR2	NYD	NAYAGARH	GANIA	14057	11 KV BALARAM	14057203	KISHORE PRASAD-1	2212DT814	250	MIXED	AMI	Yes	0%	334	0.33392316	0.072747	0.26117616	78.21%
3993	TPCODL	BBSR2	NYD	NAYAGARH	GODIPADA ODSSP	14274	11 KV GODIPADA	14274201	GODIPADA TANGSAHI-2	2246DT484	100	MIXED	AMI	Yes	67%	130	0.0536913	0.043359	0.0103323	19.24%
3994	TPCODL	BBSR2	NYD	NAYAGARH	GODIPADA ODSSP	14274	11 KV GODIPADA	14274201	JAGRIKHAIRAPATI	2246DT485	100	MIXED	AMI	Yes	33%	164	0.07034332	0.053706	0.01663732	23.65%
3995	TPCODL	BBSR2	NYD	NAYAGARH	GODIPADA ODSSP	14274	11 KV GODIPADA	14274201	GODIPADA RI OFFICE	2246DT486	100	MIXED	AMI	Yes	67%	294	0.10548918	0.072912	0.03257718	30.88%
3996	TPCODL	BBSR2	NYD	NAYAGARH	GODIPADA ODSSP	14274	11 KV GODIPADA	14274201	GODIPADA MAGARANA SAHI	2246DT490	100	MIXED	AMI	Yes	67%	110	0.03481554	0.024874	0.00994154	28.55%
3997	TPCODL	BBSR2	NYD	NAYAGARH	GODIPADA ODSSP	14274	11 KV GODIPADA	14274201	GODIPADA BAZAR	2246DT491	100	MIXED	AMI	Yes	67%	155	0.06967536	0.054178	0.01549736	22.24%
3998	TPCODL	BBSR2	NYD	NAYAGARH	GODIPADA ODSSP	14274	11 KV DAMASAHI	14274202	BADABHUIN VILLAGE-1	2246DT290	100	MIXED	AMI	Yes	67%	198	0.04606198	0.042921	0.00314098	6.82%
3999	TPCODL	BBSR2	NYD	NAYAGARH	GODIPADA ODSSP	14274	11 KV DAMASAHI	14274202	MALISAHI BAZAR	2246DT303	100	MIXED	AMI	Yes	67%	46	0.02289342	0.015787	0.00710642	31.04%
4000	TPCODL	BBSR2	NYD	NAYAGARH	GODIPADA ODSSP	14274	11 KV DAMASAHI	14274202	DAMASAHI (TANGISAHI)-1	2246DT305	100	MIXED	AMI	Yes	67%	77	0.0359559	0.022905	0.0130509	36.30%
4001	TPCODL	BBSR2	NYD	NAYAGARH	GODIPADA ODSSP	14274	11 KV DAMASAHI	14274202	MALISAHI VILLAGE	2246DT314	100	MIXED	AMI	Yes	67%	151	0.0422419	0.033217	0.0090249	21.36%
4002	TPCODL	BBSR2	NYD	NAYAGARH	GODIPADA ODSSP	14274	11 KV DAMASAHI	14274202	NADI UPARA SAHI-1	2246DT325	100	MIXED	AMI	Yes	67%	43	0.01381056	0.009569	0.00424156	30.71%
4003	TPCODL	BBSR2	NYD	NAYAGARH	GODIPADA ODSSP	14274	11 KV NAGAMUNDULI	14274203	PATULISAHI	2246DT359	100	MIXED	AMI	Yes	67%	123	0.05243427	0.038162	0.01427227	27.22%
4004	TPCODL	BBSR2	NYD	NAYAGARH	GODIPADA ODSSP	14274	11 KV NAGAMUNDULI	14274203	KESARPUR-2	2246DT367	100	MIXED	AMI	Yes	0%	176	0.04872004	0.043203	0.00551704	11.32%
4005	TPCODL	BBSR2	NYD	NAYAGARH	GODIPADA ODSSP	14274	11 KV NAGAMUNDULI	14274203	NAGAMUNDALI NEW	2246DT370	100	MIXED	AMI	Yes	33%	67	0.07056088	0.015308	0.05525288	78.31%
4006	TPCODL	BBSR2	NYD	NAYAGARH	GODIPADA ODSSP	14274	11 KV NAGAMUNDULI	14274203	DIMISAR CHHAK	2246DT381	100	MIXED	AMI	Yes	67%	94	0.04492378	0.024022	0.02090178	46.53%
4007	TPCODL	BBSR2	NYD	NAYAGARH	GODIPADA ODSSP	14274	11 KV NAGAMUNDULI	14274203	DIMISAR BADASAHI	2246DT386	100	MIXED	AMI	Yes	67%	92	0.04368082	0.018452	0.02522882	57.76%
4008	TPCODL	BBSR2	NYD	NAYAGARH	GODIPADA ODSSP	14274	11 KV NAGAMUNDULI	14274203	DIMISAR MAA MANGALA SAHI-1	2246DT393	63	MIXED	AMI	Yes	0%	129	0.06257366	0.029628	0.03294566	52.65%
4009	TPCODL	BBSR2	NYD	NAYAGARH	GODIPADA ODSSP	14274	11 KV KESHPANIA	14274204	BHALIADIHI-3	2246DT262	100	MIXED	AMI	Yes	67%	119	0.04112069	0.025542	0.01557869	37.89%
4010	TPCODL	BBSR2	NYD	NAYAGARH	GODIPADA ODSSP	14274	11 KV KESHPANIA	14274204	KAINFULLIA	2246DT404	100	MIXED	AMI	Yes	0%	46	0.02066582	0.006281	0.01438482	69.61%
4011	TPCODL	BBSR2	NYD	NAYAGARH	GODIPADA ODSSP	14274	11 KV KESHPANIA	14274204	TOTAPADA	2246DT405	100	MIXED	AMI	Yes	67%	87	0.02885388	0.018757	0.01009688	34.99%
4012	TPCODL	BBSR2	NYD	NAYAGARH	GODIPADA ODSSP	14274	11 KV KESHPANIA	14274204	MAJHIAKHANDA-2	2246DT425	100	MIXED	AMI	Yes	67%	151	0.04022246	0.02907	0.01115246	27.73%
4013	TPCODL	BBSR2	NYD	NAYAGARH	GODIPADA ODSSP	14274	11 KV KESHPANIA	14274204	KESHAPANIA-2	2246DT440	100	MIXED	AMI	Yes	0%	150	0.0458402	0.030972	0.0148682	32.43%
4014	TPCODL	BBSR2	NYD	NAYAGARH	HARIPUR (BAHADAJ	14285	11 KV BAHADAJHOLA (HA	14285201	R.M.C. BAHADAJHOLA	2243DT628	500	MIXED	AMI	Yes	33%	415	0.18150496	0.147053	0.03445196	18.98%

Sl. No.	Zone Name	Circle name	Division name	Name of the Sub-division	Name of the Sub-station	Substation Code	Name of the 11 kV Feeder	Feeder Code	Name of the Location where DT situated	DT code	DT Capacity (kVA)	Predominant consumer type of DT (Domestic/Industrial/Agriculture/Mixed)	Type of metering AMR/AMI/ Communicable/Conventional metered/Unmetered	Status of Meter-whether Functional (Yes/No)	% of data received automatically (if AMR/AMI)	No. of Connected Consumers	Input Energy (MU) (A)	Billed Energy (MU) (B)	Loss (MU) (A-B)	% DT Loss (A-B)/A
4015	TPCODL	BBSR2	NYD	NAYAGARH	HARIPUR (BAHADAJ	14285	11 KV BAHADAJHOLA (HA	14285201	CHAMU SAHI	2243DT683	100	MIXED	AMI	Yes	33%	58	0.02159912	0.017215	0.00438412	20.30%
4016	TPCODL	BBSR2	NYD	NAYAGARH	HARIPUR (BAHADAJ	14285	11 KV BAHADAJHOLA (HA	14285201	SUTAKATA 1	2243DT685	100	MIXED	AMI	Yes	33%	189	0.1497142	0.040093	0.1096212	73.22%
4017	TPCODL	BBSR2	NYD	NAYAGARH	HARIPUR (BAHADAJ	14285	11 KV BAHADAJHOLA (HA	14285201	SUTAKATA 2	2243DT686	100	MIXED	AMI	Yes	67%	162	0.05320915	0.036721	0.01648815	30.99%
4018	TPCODL	BBSR2	NYD	NAYAGARH	HARIPUR (BAHADAJ	14285	11 KV BERUNHABADI	14285202	BERUANBARI 2	2243DT511	100	MIXED	AMI	Yes	0%	157	0.02686032	0.022751	0.00410932	15.30%
4019	TPCODL	BBSR2	NYD	NAYAGARH	HARIPUR (BAHADAJ	14285	11 KV BERUNHABADI	14285202	BERUABARI KUMVAR SAHI 2	2243DT514	100	MIXED	AMI	Yes	0%	81	0.02356726	0.014502	0.00906526	38.47%
4020	TPCODL	BBSR2	NYD	NAYAGARH	ITAMATI	14053	11 KV ITAMATI	14053201	SANATANGI PATANA	2222DT007	250	MIXED	AMI	Yes	0%	207	0.20149752	0.138553	0.06294452	31.24%
4021	TPCODL	BBSR2	NYD	NAYAGARH	JANLA	14034	11 KV MENDHASAL	14034201	CUSTOM COLONY	2142DT002	100	MIXED	AMI	Yes	0%	73	0.070734	0.046394	0.02434	34.41%
4022	TPCODL	BBSR2	NYD	NAYAGARH	KANTILO	14055	11 KV KANTILO	14055201	PATHARA CHAKADA	2233DT040	100	MIXED	AMI	Yes	67%	100	0.04863532	0.029681	0.01895432	38.97%
4023	TPCODL	BBSR2	NYD	NAYAGARH	KIRIALANJI (SIMILIS/	14284	11 KV SIMILISAHI	14284201	M.I COLONY	2241DT201	100	MIXED	AMI	Yes	0%	100	0.06315384	0.038575	0.02457884	38.92%
4024	TPCODL	BBSR2	NYD	NAYAGARH	KIRIALANJI (SIMILIS/	14284	11 KV SIMILISAHI	14284201	JHUMPURI 2	2241DT210	500	MIXED	AMI	Yes	33%	123	0.19741344	0.069461	0.12795244	64.81%
4025	TPCODL	BBSR2	NYD	NAYAGARH	KIRIALANJI (SIMILIS/	14284	11 KV SIMILISAHI	14284201	KALAHANDI-2	2241DT212	100	MIXED	AMI	Yes	67%	58	0.04130986	0.020166	0.02114386	51.18%
4026	TPCODL	BBSR2	NYD	NAYAGARH	KIRIALANJI (SIMILIS/	14284	11 KV SIMILISAHI	14284201	LADUKESHAR PUR 1	2241DT220	100	MIXED	AMI	Yes	67%	78	0.03743422	0.020178	0.01725622	46.10%
4027	TPCODL	BBSR2	NYD	NAYAGARH	KIRIALANJI (SIMILIS/	14284	11 KV SIMILISAHI	14284201	BHATASAHI VILLAGE	2241DT222	100	MIXED	AMI	Yes	67%	222	0.09316648	0.054782	0.03838448	41.20%
4028	TPCODL	BBSR2	NYD	NAYAGARH	KIRIALANJI (SIMILIS/	14284	11 KV SIMILISAHI	14284201	MUKTAPUR VILLAGE 2	2241DT235	100	MIXED	AMI	Yes	67%	104	0.06735251	0.049344	0.01800851	26.74%
4029	TPCODL	BBSR2	NYD	NAYAGARH	KIRIALANJI (SIMILIS/	14284	11 KV SIMILISAHI	14284201	MUTHAGADIA	2241DT238	100	MIXED	AMI	Yes	67%	70	0.02917253	0.023919	0.00525353	18.01%
4030	TPCODL	BBSR2	NYD	NAYAGARH	KIRIALANJI (SIMILIS/	14284	11 KV SIMILISAHI	14284201	DIANPADA 2	2241DT248	100	MIXED	AMI	Yes	67%	93	0.03861611	0.031904	0.00671211	17.38%
4031	TPCODL	BBSR2	NYD	NAYAGARH	KIRIALANJI (SIMILIS/	14284	11 KV SIMILISAHI	14284201	SIALIKHAL VILLAGE	2241DT257	100	MIXED	AMI	Yes	67%	26	0.00396512	0.002472	0.00149312	37.66%
4032	TPCODL	BBSR2	NYD	NAYAGARH	KIRIALANJI (SIMILIS/	14284	11 KV SIMILISAHI	14284201	BARAPALLA	2241DT260	100	MIXED	AMI	Yes	67%	33	0.00707848	0.006079	0.00099948	14.12%
4033	TPCODL	BBSR2	NYD	NAYAGARH	KIRIALANJI (SIMILIS/	14284	11 KV SIMILISAHI	14284201	NABAGHANPUR HIGH SCHOOL	2241DT267	100	MIXED	AMI	Yes	67%	57	0.03939696	0.028495	0.01090196	27.67%
4034	TPCODL	BBSR2	NYD	NAYAGARH	KIRIALANJI (SIMILIS/	14284	11 KV SIMILISAHI	14284201	HARIHARPUR VILLAGE 2	2241DT270	100	MIXED	AMI	Yes	67%	178	0.07201831	0.061169	0.01084931	15.06%
4035	TPCODL	BBSR2	NYD	NAYAGARH	KIRIALANJI (SIMILIS/	14284	11 KV SIMILISAHI	14284201	JAYPUR VILLAGE 2	2241DT274	100	MIXED	AMI	Yes	67%	145	0.05636776	0.044676	0.01169176	20.74%
4036	TPCODL	BBSR2	NYD	NAYAGARH	KIRIALANJI (SIMILIS/	14284	11 KV SIMILISAHI	14284201	TULSI PUR VILLAGE 2	2241DT277	100	MIXED	AMI	Yes	67%	175	0.08818976	0.059485	0.02870476	32.55%
4037	TPCODL	BBSR2	NYD	NAYAGARH	KIRIALANJI (SIMILIS/	14284	11 KV SIMILISAHI	14284201	KHETRIBARPUR VILLAGE 2	2241DT282	25	MIXED	AMI	Yes	67%	45	0.01378594	0.012447	0.00133894	9.71%
4038	TPCODL	BBSR2	NYD	NAYAGARH	KIRIALANJI (SIMILIS/	14284	11 KV SIMILISAHI	14284201	MAHANKPALLI VILLAGE 2	2241DT285	100	MIXED	AMI	Yes	67%	78	0.046016	0.032843	0.013173	28.63%
4039	TPCODL	BBSR2	NYD	NAYAGARH	KIRIALANJI (SIMILIS/	14284	11 KV SIMILISAHI	14284201	KHAMARI SAHI	2241DT294	100	MIXED	AMI	Yes	67%	127	0.07001654	0.060529	0.00948754	13.55%
4040	TPCODL	BBSR2	NYD	NAYAGARH	KIRIALANJI (SIMILIS/	14284	11 KV SIMILISAHI	14284201	HATADWAR VILLAGE	2241DT300	100	MIXED	AMI	Yes	67%	79	0.04695761	0.022005	0.02495261	53.14%
4041	TPCODL	BBSR2	NYD	NAYAGARH	KIRIALANJI (SIMILIS/	14284	11 KV SIMILISAHI	14284201	SIMILISAHI VILLAGE	2241DT322	100	MIXED	AMI	Yes	0%	117	0.03364646	0.021228	0.01241846	36.91%
4042	TPCODL	BBSR2	NYD	NAYAGARH	KIRIALANJI (SIMILIS/	14284	11 KV SIMILISAHI	14284201	BARADWAR VILLAGE	2241DT329	100	MIXED	AMI	Yes	67%	80	0.01888106	0.01671	0.00217106	11.50%
4043	TPCODL	BBSR2	NYD	NAYAGARH	KIRIALANJI (SIMILIS/	14284	11 KV KIRIALANJI	14284203	KIRIANANJI VILLAGE -2	2244DT361	250	MIXED	AMI	Yes	0%	55	0.01722248	0.011296	0.00592648	34.41%
4044	TPCODL	BBSR2	NYD	NAYAGARH	KURALA ODSSP	14275	11 KV KURALA	14275201	SUBUDHISAHI (KOMANDA ROAD)	2242DT200	100	MIXED	AMI	Yes	0%	189	0.04943228	0.040909	0.00852328	17.24%
4045	TPCODL	BBSR2	NYD	NAYAGARH	KURALA ODSSP	14275	11 KV KURALA	14275201	CHADICHHAK KURAL-2	2242DT212	500	MIXED	AMI	Yes	33%	526	0.1565336	0.126408	0.0301256	19.25%
4046	TPCODL	BBSR2	NYD	NAYAGARH	KURALA ODSSP	14275	11 KV KURALA	14275201	TANGISAHI-6 NIDHIA SAHI	2242DT222	100	MIXED	AMI	Yes	67%	109	0.03388328	0.033241	0.00064228	1.90%
4047	TPCODL	BBSR2	NYD	NAYAGARH	KURALA ODSSP	14275	11 KV KURALA	14275201	HANUMAN TIA-2	2242DT230	100	MIXED	AMI	Yes	67%	64	0.02041896	0.015509	0.00490996	24.05%
4048	TPCODL	BBSR2	NYD	NAYAGARH	KURALA ODSSP	14275	11 KV KURALA	14275201	NAURIAGADA-1	2242DT233	100	MIXED	AMI	Yes	67%	67	0.01461256	0.013534	0.00107856	7.38%
4049	TPCODL	BBSR2	NYD	NAYAGARH	KURALA ODSSP	14275	11 KV SUNAMUNHI	14275202	GIRIDIPALLI-1 (NILAKANTHESWAR)	2242DT244	100	MIXED	AMI	Yes	0%	261	0.06422708	0.047616	0.01661108	25.86%
4050	TPCODL	BBSR2	NYD	NAYAGARH	KURALA ODSSP	14275	11 KV SUNAMUNHI	14275202	SUNAMUHIN -1	2242DT263	100	MIXED	AMI	Yes	33%	183	0.06742012	0.050462	0.01695812	25.15%
4051	TPCODL	BBSR2	NYD	NAYAGARH	KURALA ODSSP	14275	11 KV SUNAMUNHI	14275202	LANDABADU -2(POND)	2242DT266	100	MIXED	AMI	Yes	0%	151	0.02525322	0.018418	0.00683522	27.07%
4052	TPCODL	BBSR2	NYD	NAYAGARH	KURALA ODSSP	14275	11 KV SUNAMUNHI	14275202	LUNI-1	2242DT279	100	MIXED	AMI	Yes	33%	50	0.01346326	0.008946	0.00451726	33.55%
4053	TPCODL	BBSR2	NYD	NAYAGARH	KURALA ODSSP	14275	11 KV SUNAMUNHI	14275202	SUNAMUHIN -2	2242DT284	100	MIXED	AMI	Yes	33%	119	0.04559468	0.0271	0.01849468	40.56%
4054	TPCODL	BBSR2	NYD	NAYAGARH	KURALA ODSSP	14275	11 KV SUNAMUNHI	14275202	BALISISA -2	2242DT301	100	MIXED	AMI	Yes	0%	26	0.01704408	0.005443	0.01160108	68.07%
4055	TPCODL	BBSR2	NYD	NAYAGARH	KURALA ODSSP	14275	11 KV KOMANDA	14275203	UDAYAPUR NUASAHI	2242DT114	100	MIXED	AMI	Yes	0%	130	0.02893648	0.01748	0.01145648	39.59%
4056	TPCODL	BBSR2	NYD	NAYAGARH	KURALA ODSSP	14275	11 KV KOMANDA	14275203	KOMANDA VILLAGE-1	2242DT119	250	MIXED	AMI	Yes	0%	322	0.08976688	0.062001	0.02776588	30.93%
4057	TPCODL	BBSR2	NYD	NAYAGARH	KURALA ODSSP	14275	11 KV KOMANDA	14275203	BAGHUA CHHAKA	2242DT168	100	MIXED	AMI	Yes	0%	194	0.08171587	0.064121	0.01759487	21.53%
4058	TPCODL	BBSR2	NYD	NAYAGARH	KURALA ODSSP	14275	11 KV KOMANDA	14275203	ROHI BANKA	2242DT170	100	MIXED	AMI	Yes	0%	206	0.05311618	0.035011	0.01810518	34.09%
4059	TPCODL	BBSR2	NYD	NAYAGARH	KURALA ODSSP	14275	11 KV KOMANDA	14275203	MAKARPADA	2242DT173	100	MIXED	AMI	Yes	0%	116	0.06766076	0.035968	0.03169276	46.84%
4060	TPCODL	BBSR2	NYD	NAYAGARH	LATHIPADA ODSSP	14283	11 KV NOTAR	14283202	FASHIPADA VILLAGE 5	2222DT388	100	MIXED	AMI	Yes	67%	95	0.03755957	0.017032	0.02052757	54.65%
4061	TPCODL	BBSR2	NYD	NAYAGARH	MACHHIPADA ODSS	14279	11 KV MACHHIPADA BAZ	14279201	NEAR LIBRARY	2245DT104	100	MIXED	AMI	Yes	100%	94	0.07491052	0.042435	0.03247552	43.35%
4062	TPCODL	BBSR2	NYD	NAYAGARH	MACHHIPADA ODSS	14279	11 KV MACHHIPADA BAZ	14279201	MACHIPADIA CHAAK, BACKSIDE OF T	2245DT107	100	MIXED	AMI	Yes	0%	145	0.16331576	0.07034	0.09297576	56.93%
4063	TPCODL	BBSR2	NYD	NAYAGARH	MACHHIPADA ODSS	14279	11 KV MACHHIPADA BAZ	14279201	KUSHAVHANDARI	2245DT128	100	MIXED	AMI	Yes	67%	84	0.02270748	0.016876	0.00583148	25.68%
4064	TPCODL	BBSR2	NYD	NAYAGARH	MACHHIPADA ODSS	14279	11 KV KALYANPUR	14279202	SOLAPATA MAIN ROAD SIDE	2245DT079	100	MIXED	AMI	Yes	33%	36	0.01936428	0.014922	0.00444228	22.94%
4065	TPCODL	BBSR2	NYD	NAYAGARH	MACHHIPADA ODSS	14279	11 KV KALYANPUR	14279202	GOTISAHI (TANTI SAHI)	2245DT081	100	MIXED	AMI	Yes	67%	88	0.03401798	0.024315	0.00970298	28.52%
4066	TPCODL	BBSR2	NYD	NAYAGARH	MACHHIPADA ODSS	14279	11 KV KALYANPUR	14279202	GOTISAHI	2245DT084	250	MIXED	AMI	Yes	0%	167	0.10097756	0.056523	0.04445456	44.02%
4067	TPCODL	BBSR2	NYD	NAYAGARH	MACHHIPADA ODSS	14279	11 KV KALYANPUR	14279202	GAMBHARIDIHI	2245DT086	250	MIXED	AMI	Yes	0%	162	0.030145	0.029241	0.000904	3.00%
4068	TPCODL	BBSR2	NYD	NAYAGARH	MACHHIPADA ODSS	14279	11 KV KALYANPUR	14279202	KANTABANIA	2245DT091	100	MIXED	AMI	Yes	67%	76	0.0370613	0.019969	0.0170923	46.12%
4069	TPCODL	BBSR2	NYD	NAYAGARH	MACHHIPADA ODSS	14279	11 KV KALYANPUR	14279202	GAMEI PRIMARY SCHOOL FRONT	2245DT100	100	MIXED	AMI	Yes	100%	49	0.01927515	0.007723	0.01155215	59.93%
4070	TPCODL	BBSR2	NYD	NAYAGARH	MACHHIPADA ODSS	14279	11 KV KALYANPUR	14279202	PUANIA-2	2245DT214	100	MIXED	AMI	Yes	67%	159	0.04156796	0.028372	0.01319596	31.75%
4071	TPCODL	BBSR2	NYD	NAYAGARH	MACHHIPADA ODSS	14279	11 KV PALLISASAN	14279203	PALLISASHAN-1	2245DT152	100	MIXED	AMI	Yes	100%	87	0.04007992	0.031329	0.00875092	21.83%
4072	TPCODL	BBSR2	NYD	NAYAGARH	MACHHIPADA ODSS	14279	11 KV PALLISASAN	14279203	PADMADEIPUR-1	2245DT159	100	MIXED	AMI	Yes	100%	124	0.03703828	0.02873	0.00830828	22.43%
4073	TPCODL	BBSR2	NYD	NAYAGARH	MACHHIPADA ODSS	14279	11 KV PALLISASAN	14279203	GABANAL-1	2245DT168	100	MIXED	AMI	Yes	0%	64	0.0316971	0.012206	0.0194911	61.49%
4074	TPCODL	BBSR2	NYD	NAYAGARH	MACHHIPADA ODSS	14279	11 KV PALLISASAN	14279203	NADIALI-1	2245DT172	100	MIXED	AMI	Yes	100%	135	0.05826668	0.03638	0.02188668	37.56%
4075	TPCODL	BBSR2	NYD	NAYAGARH	MACHHIPADA ODSS	14279	11 KV PALLISASAN	14279203	PATANASAHI	2245DT175	100	MIXED	AMI	Yes	100%	78	0.03548511	0.02327	0.01221511	34.42%
4076	TPCODL	BBSR2	NYD	NAYAGARH	MACHHIPADA ODSS	14279	11 KV PALLISASAN	14279203	HINJALGADIA KAMARASAHI	2245DT178	100	MIXED	AMI	Yes	67%	36	0.01072622	0.008194	0.00253222	23.61%
4077	TPCODL	BBSR2	NYD	NAYAGARH	MACHHIPADA ODSS	14279	11 KV PALLISASAN	14279203	KHUNTUBANDHA TALASAH	2245DT187	100	MIXED	AMI	Yes	0%	69	0.02428018	0.022127	0.00215318	8.87%
4078	TPCODL	BBSR2	NYD	NAYAGARH	MACHHIPADA ODSS	14279	11 KV PALLISASAN	14279203	KHUNTUBANDHA NAUSAH-1	2245DT188	100	MIXED	AMI	Yes	67%	109	0.03312724	0.032079	0.00104824	3.16%
4079	TPCODL	BBSR2	NYD	NAYAGARH	MACHHIPADA ODSS	14279	11 KV LEKUDIPADA	14279204	AUROBINDANAGAR	2241DT351	500	MIXED	AMI	Yes	100%	218	0.32750776	0.182103	0.14540476	44.40%
4080	TPCODL	BBSR2	NYD	NAYAGARH	MACHHIPADA ODSS	14279	11 KV LEKUDIPADA	14279204	SREEBIHAR	2241DT353	100	MIXED	AMI	Yes	0%	158	0.13233836	0.123709	0.00862936	6.52%
4081	TPCODL	BBSR2	NYD	NAYAGARH	MACHHIPADA ODSS	14279	11 KV LEKUDIPADA	14279204	BARAMASHI DANDA 2	2241DT357	100	MIXED	AMI	Yes	0%	108	0.0944471	0.08544	0.0090071	9.54%
4082	TPCODL	BBSR2	NYD	NAYAGARH	MACHHIPADA ODSS	14279	11 KV LEKUDIPADA	14279204	PTS	2241DT358	500	MIXED	AMI	Yes	100%	169	0.26238152	0.225455	0.03692652	14.07%
4083	TPCODL	BBSR2	NYD	NAYAGARH	MACHHIPADA ODSS	14279	11 KV LEKUDIPADA	14279204	DEBOTTOR COLLONY 5TH LANE	2241DT371	100	MIXED	AMI	Yes	100%	65	0.0679302	0.060901	0.0070292	10.35%
4084	TPCODL	BBSR2	NYD	NAYAGARH	MACHHIPADA ODSS	14279	11 KV LEKUDIPADA	14279204	VODAFONE TOWER	2241DT373	100	MIXED	AMI	Yes	0%	80	0.10102996	0.077149	0.02388096	23.64%
4085	TPCODL	BBSR2	NYD	NAYAGARH	MACHHIPADA ODSS	14279	11 KV LEKUDIPADA	14279204	DEBOTTOR COLLONY 4TH LANE	2241DT377	500	MIXED	AMI	Yes	0%	185	0.30407512	0.161915	0.14216012	46.75%
4086	TPCODL	BBSR2	NYD	NAYAGARH	MACHHIPADA ODSS	14279	11 KV LEKUDIPADA	14279204	DEBOTTOR COLLONY	2241DT378	100	MIXED	AMI	Yes	0%	61	0.06313634	0.044608	0.01852834	29.35%
4087	TPCODL	BBSR2	NYD	NAYAGARH	MACHHIPADA ODSS	14279	11 KV LEKUDIPADA	14279204	IRRIGATION OFFICE 1	2241DT383	100	MIXED	AMI	Yes	0%	33	0.04050774	0.032309	0.00819874	20.24%

Sl. No.	Zone Name	Circle name	Division name	Name of the Sub-division	Name of the Sub-station	Substation Code	Name of the 11 kV Feeder	Feeder Code	Name of the Location where DT situated	DT code	DT Capacity (kVA)	Predominant consumer type of DT (Domestic/Industrial/Agriculture/Mixed)	Type of metering AMR/AMI/ Communicable/Conventional metered/Unmetered	Status of Meter-whether Functional (Yes/No)	% of data received automatically (if AMR/AMI)	No. of Connected Consumers	Input Energy (MU) (A)	Billed Energy (MU) (B)	Loss (MU) (A-B)	% DT Loss (A-B)/A
4088	TPCODL	BBSR2	NYD	NAYAGARH	MACHHIPADA ODSS	14279	11 KV LEKUDIPADA	14279204	LENKUDIPADA (RAM MANDIR)	2245DT019	100	MIXED	AMI	Yes	100%	73	0.0722168	0.024867	0.0473498	65.57%
4089	TPCODL	BBSR2	NYD	NAYAGARH	MACHHIPADA ODSS	14279	11 KV LEKUDIPADA	14279204	KAITHAGADIA_03	2245DT035	500	MIXED	AMI	Yes	33%	182	0.11082976	0.069642	0.04118776	37.16%
4090	TPCODL	BBSR2	NYD	NAYAGARH	MACHHIPADA ODSS	14279	11 KV LEKUDIPADA	14279204	KAITHAGADIA_01	2245DT037	100	MIXED	AMI	Yes	67%	148	0.0705386	0.058128	0.0124106	17.59%
4091	TPCODL	BBSR2	NYD	NAYAGARH	MACHHIPADA ODSS	14279	11 KV LEKUDIPADA	14279204	LENKUDI PADA BAZAR	2245DT050	500	MIXED	AMI	Yes	0%	136	0.22416728	0.097922	0.12624528	56.32%
4092	TPCODL	BBSR2	NYD	NAYAGARH	MACHHIPADA ODSS	14279	11 KV LEKUDIPADA	14279204	BELABANI	2245DT059	100	MIXED	AMI	Yes	0%	104	0.03880394	0.03543	0.00337394	8.69%
4093	TPCODL	BBSR2	NYD	NAYAGARH	MAHIPUR	14061	11 KV MAHIPUR	14061201	VIRUDA BRIDGE 2	2244DT812	100	MIXED	AMI	Yes	0%	43	0.03594378	0.024034	0.01190978	33.13%
4094	TPCODL	BBSR2	NYD	NAYAGARH	MAHIPUR	14061	11 KV MAHIPUR	14061201	BRAJASUNDARPUR 1	2244DT816	100	MIXED	AMI	Yes	0%	33	0.02233588	0.01202	0.01031588	46.19%
4095	TPCODL	BBSR2	NYD	NAYAGARH	MAHIPUR	14061	11 KV MAHIPUR	14061201	NILADRIPUR 4	2244DT830	100	MIXED	AMI	Yes	67%	110	0.05429857	0.051032	0.00326657	6.02%
4096	TPCODL	BBSR2	NYD	NAYAGARH	MAHIPUR	14061	11 KV MAHIPUR	14061201	DIMIRIJHARI 1	2244DT849	100	MIXED	AMI	Yes	0%	140	0.06224568	0.032507	0.02973868	47.78%
4097	TPCODL	BBSR2	NYD	NAYAGARH	MAHIPUR	14061	11 KV MAHIPUR	14061201	EKATAL 2	2244DT859	100	MIXED	AMI	Yes	0%	99	0.0258025	0.017764	0.0080385	31.15%
4098	TPCODL	BBSR2	NYD	NAYAGARH	MAHIPUR	14061	11 KV MAHIPUR	14061201	DURDURA 1	2244DT864	500	MIXED	AMI	Yes	0%	245	0.09332224	0.06669	0.02663224	28.54%
4099	TPCODL	BBSR2	NYD	NAYAGARH	MAHIPUR	14061	11 KV MAHIPUR	14061201	DURDURA 2	2244DT865	100	MIXED	AMI	Yes	100%	89	0.03912162	0.02285	0.01627162	41.59%
4100	TPCODL	BBSR2	NYD	NAYAGARH	MAHIPUR	14061	11 KV MAHIPUR	14061201	MAHIPUR 1	2244DT873	500	MIXED	AMI	Yes	0%	350	0.12875472	0.08374078	0.04501394	34.96%
4101	TPCODL	BBSR2	NYD	NAYAGARH	MAHIPUR	14061	11 KV MAHIPUR	14061201	MAHIPUR 3	2244DT875	500	MIXED	AMI	Yes	0%	260	0.1158054	0.091797	0.0240084	20.73%
4102	TPCODL	BBSR2	NYD	NAYAGARH	MAHIPUR	14061	11 KV VIRUDA	14061202	BIRUDA VILLAGE 5	2244DT209	100	MIXED	AMI	Yes	0%	111	0.04747082	0.036407	0.01106382	23.31%
4103	TPCODL	BBSR2	NYD	NAYAGARH	MAHIPUR	14061	11 KV VIRUDA	14061202	JOGI CAHALI	2244DT227	100	MIXED	AMI	Yes	67%	67	0.01623536	0.013425	0.00281036	17.31%
4104	TPCODL	BBSR2	NYD	NAYAGARH	MAHIPUR	14061	11 KV VIRUDA	14061202	UDAYPUR 1	2244DT241	100	MIXED	AMI	Yes	33%	68	0.01622972	0.014272	0.00195772	12.06%
4105	TPCODL	BBSR2	NYD	NAYAGARH	MAHIPUR	14061	11 KV VIRUDA	14061202	NUA RAIPUR	2244DT243	100	MIXED	AMI	Yes	0%	78	0.03578792	0.01826	0.01752792	48.98%
4106	TPCODL	BBSR2	NYD	NAYAGARH	MAHIPUR	14061	11 KV VIRUDA	14061202	DAILIAMADA VILLAGE	2244DT246	100	MIXED	AMI	Yes	33%	120	0.03149808	0.020222	0.01127608	35.80%
4107	TPCODL	BBSR2	NYD	NAYAGARH	MAHIPUR	14061	11 KV VIRUDA	14061202	PETA PALLI	2244DT262	100	MIXED	AMI	Yes	0%	50	0.01047002	0.006981	0.00348902	33.32%
4108	TPCODL	BBSR2	NYD	NAYAGARH	MAHIPUR	14061	11 KV VIRUDA	14061202	HIRADEIPUR VILLAGE 1	2244DT293	500	MIXED	AMI	Yes	0%	126	0.04611008	0.030337	0.01577308	34.21%
4109	TPCODL	BBSR2	NYD	NAYAGARH	MAHIPUR	14061	11 KV VIRUDA	14061202	BALABHADRAPUR 2	2244DT300	250	MIXED	AMI	Yes	0%	169	0.06083472	0.038478	0.02235672	36.75%
4110	TPCODL	BBSR2	NYD	NAYAGARH	MAHIPUR	14061	11 KV SINGARPALLY-1	14061203	THUABARI VILLAGE 3	2244DT411	100	MIXED	AMI	Yes	67%	58	0.029363	0.012583	0.01678	57.15%
4111	TPCODL	BBSR2	NYD	NAYAGARH	MAHIPUR	14061	11 KV SINGARPALLY-1	14061203	POKHARA 2	2244DT448	100	MIXED	AMI	Yes	0%	40	0.0186177	0.011702	0.0069157	37.15%
4112	TPCODL	BBSR2	NYD	NAYAGARH	MAHIPUR	14061	11 KV SINGARPALLY-1	14061203	ADIPADA SCHOOL	2244DT459	100	MIXED	AMI	Yes	0%	96	0.0311121	0.018711	0.0124011	39.86%
4113	TPCODL	BBSR2	NYD	NAYAGARH	MAHIPUR	14061	11 KV SINGARPALLY-1	14061203	GATRI VILLAGE	2244DT470	100	MIXED	AMI	Yes	0%	76	0.02229422	0.021897	0.00039722	1.78%
4114	TPCODL	BBSR2	NYD	NAYAGARH	MAHIPUR	14061	11 KV SINGARPALLY-1	14061203	SINGARPALLI VILLAGE 250 KVA DTR	2244DT494	250	MIXED	AMI	Yes	0%	187	0.07207592	0.039461	0.03261492	45.25%
4115	TPCODL	BBSR2	NYD	NAYAGARH	MAHIPUR	14061	11 KV SINGARPALLY-1	14061203	SINGARPALLI VILLAGE KARAN SAHI	2244DT502	100	MIXED	AMI	Yes	0%	45	0.00793862	0.005153	0.00278562	35.09%
4116	TPCODL	BBSR2	NYD	NAYAGARH	MAHIPUR	14061	11 KV SINGARPALLY-1	14061203	JORA SAHI VILLAGE 1	2244DT508	100	MIXED	AMI	Yes	0%	64	0.01985788	0.006682	0.01317588	66.35%
4117	TPCODL	BBSR2	NYD	NAYAGARH	MAHIPUR	14061	11 KV SINGARPALLY-2	14061204	SENTERI BADASAHI-1	2244DT608	100	MIXED	AMI	Yes	0%	83	0.02180324	0.009412	0.01239124	56.83%
4118	TPCODL	BBSR2	NYD	NAYAGARH	MAHIPUR	14061	11 KV SINGARPALLY-2	14061204	GUMI(SUDHA SAHI)	2244DT650	100	MIXED	AMI	Yes	0%	113	0.02128878	0.014864	0.00642478	30.18%
4119	TPCODL	BBSR2	NYD	NAYAGARH	MAHIPUR	14061	11 KV SINGARPALLY-2	14061204	DIMRIPALI	2244DT676	100	MIXED	AMI	Yes	0%	34	0.01585928	0.007368	0.00849128	53.54%
4120	TPCODL	BBSR2	NYD	NAYAGARH	MAHIPUR	14061	11 KV SINGARPALLY-2	14061204	DIMIRIPALI(KANDHA SAHI)	2244DT677	25	MIXED	AMI	Yes	0%	41	0.00974602	0.00274	0.00700602	71.89%
4121	TPCODL	BBSR2	NYD	NAYAGARH	MAHIPUR	14061	11 KV SINGARPALLY-2	14061204	DIMIRIPALI HARIJON SAHI AND DANT	2244DT678	63	MIXED	AMI	Yes	0%	54	0.02003546	0.005587	0.01444846	72.11%
4122	TPCODL	BBSR2	NYD	NAYAGARH	NAYAGARH	14058	11 KV NAYAGARH	14058201	NAYAGARH SUB STATION -2	2241DT102	500	MIXED	AMI	Yes	100%	252	0.21832136	0.131846	0.08647536	39.61%
4123	TPCODL	BBSR2	NYD	NAYAGARH	NAYAGARH	14058	11 KV NAYAGARH	14058201	KHANDAPADA TRAFFIC CHHAK	2241DT103	500	MIXED	AMI	Yes	100%	136	0.22011864	0.124201	0.09591764	43.58%
4124	TPCODL	BBSR2	NYD	NAYAGARH	NAYAGARH	14058	11 KV NAYAGARH	14058201	RAJIV MARKET-I	2241DT105	100	MIXED	AMI	Yes	0%	58	0.01789826	0.014212	0.00368626	20.60%
4125	TPCODL	BBSR2	NYD	NAYAGARH	NAYAGARH	14058	11 KV NAYAGARH	14058201	MILLAN SUBSTATION -I	2241DT108	250	MIXED	AMI	Yes	0%	68	0.09405952	0.047795	0.04626452	49.19%
4126	TPCODL	BBSR2	NYD	NAYAGARH	NAYAGARH	14058	11 KV NAYAGARH	14058201	SIBAJI NAGAR	2241DT112	500	MIXED	AMI	Yes	100%	179	0.20936208	0.146294	0.06306808	30.12%
4127	TPCODL	BBSR2	NYD	NAYAGARH	NAYAGARH	14058	11 KV NAYAGARH	14058201	SASTRI NAGAR	2241DT114	500	MIXED	AMI	Yes	100%	139	0.1763032	0.113941	0.0623622	35.37%
4128	TPCODL	BBSR2	NYD	NAYAGARH	NAYAGARH	14058	11 KV NAYAGARH	14058201	KAITHA GADIA ROAD	2241DT116	500	MIXED	AMI	Yes	100%	238	0.2243308	0.178975	0.0453558	20.22%
4129	TPCODL	BBSR2	NYD	NAYAGARH	NAYAGARH	14058	11 KV NAYAGARH	14058201	TRINATH CHHAK	2241DT117	500	MIXED	AMI	Yes	100%	360	0.38574288	0.353566	0.03217688	8.34%
4130	TPCODL	BBSR2	NYD	NAYAGARH	NAYAGARH	14058	11 KV NAYAGARH	14058201	RD SUBSTATION	2241DT119	100	MIXED	AMI	Yes	0%	72	0.11123816	0.088658	0.02258016	20.30%
4131	TPCODL	BBSR2	NYD	NAYAGARH	NAYAGARH	14058	11 KV NAYAGARH	14058201	DIVISION OFFICE - II	2241DT124	250	MIXED	AMI	Yes	0%	179	0.1544822	0.113215	0.0412672	26.71%
4132	TPCODL	BBSR2	NYD	NAYAGARH	NAYAGARH	14058	11 KV NAYAGARH	14058201	KASTURI COMPLEX	2241DT174	100	MIXED	AMI	Yes	100%	59	0.08308138	0.070499	0.01258238	15.14%
4133	TPCODL	BBSR2	NYD	NAYAGARH	NAYAGARH	14058	11 KV NAYAGARH	14058201	HANUMAN NAGAR	2241DT192	500	MIXED	AMI	Yes	100%	89	0.16420028	0.062803	0.10139728	61.75%
4134	TPCODL	BBSR2	NYD	NAYAGARH	NAYAGARH	14058	11 KV OLD TOWN	14058202	PANI TANKI SAHI (OLD TOWN)	2241DT128	100	MIXED	AMI	Yes	0%	30	0.02212176	0.008047	0.01407476	63.62%
4135	TPCODL	BBSR2	NYD	NAYAGARH	NAYAGARH	14058	11 KV OLD TOWN	14058202	JAGANNATH TEMPLE	2241DT130	500	MIXED	AMI	Yes	100%	121	0.1433112	0.082632	0.0606792	42.34%
4136	TPCODL	BBSR2	NYD	NAYAGARH	NAYAGARH	14058	11 KV OLD TOWN	14058202	SP OFFICE - I	2241DT151	100	MIXED	AMI	Yes	0%	6	0.02948668	0.014366	0.01512068	51.28%
4137	TPCODL	BBSR2	NYD	NAYAGARH	NAYAGARH	14058	11 KV OLD TOWN	14058202	SP OFFICE - II	2241DT155	250	MIXED	AMI	Yes	0%	42	0.0877544	0.049552	0.0382024	43.53%
4138	TPCODL	BBSR2	NYD	NAYAGARH	NAYAGARH	14058	11 KV OLD TOWN	14058202	HOUSING BOARD - I	2241DT162	250	MIXED	AMI	Yes	100%	36	0.03542484	0.022491	0.01293384	36.51%
4139	TPCODL	BBSR2	NYD	NAYAGARH	NAYAGARH	14058	11 KV OLD TOWN	14058202	HOUSING BOARD - II	2241DT163	250	MIXED	AMI	Yes	100%	65	0.054466	0.04459	0.009876	18.13%
4140	TPCODL	BBSR2	NYD	NAYAGARH	NAYAGARH	14058	11 KV OLD TOWN	14058202	M.I. COLONY SAGUDIA SAHI	2241DT167	100	MIXED	AMI	Yes	0%	149	0.13414762	0.090422	0.04372562	32.60%
4141	TPCODL	BBSR2	NYD	NAYAGARH	NAYAGARH	14058	11 KV OLD TOWN	14058202	GOPINATH TEMPLE - I	2241DT168	250	MIXED	AMI	Yes	0%	117	0.1307054	0.066033	0.0646724	49.48%
4142	TPCODL	BBSR2	NYD	NAYAGARH	NAYAGARH	14058	11 KV OLD TOWN	14058202	NABAGHANPUR 3	2241DT240	100	MIXED	AMI	Yes	67%	206	0.08277162	0.060128	0.02264362	27.36%
4143	TPCODL	BBSR2	NYD	NAYAGARH	NAYAGARH	14058	11 KV SINDURIA	14058203	DURGA PRASAD-1	2241DT012	500	MIXED	AMI	Yes	0%	159	0.10394824	0.061953	0.04199524	40.40%
4144	TPCODL	BBSR2	NYD	NAYAGARH	NAYAGARH	14058	11 KV SINDURIA	14058203	BJD PARTY OFFICE	2241DT014	100	MIXED	AMI	Yes	67%	40	0.07869584	0.027917	0.05077884	64.53%
4145	TPCODL	BBSR2	NYD	NAYAGARH	NAYAGARH	14058	11 KV SINDURIA	14058203	DURGA PRASAD PETROL PUMP	2241DT016	250	MIXED	AMI	Yes	0%	176	0.2122158	0.145742	0.0664738	31.32%
4146	TPCODL	BBSR2	NYD	NAYAGARH	NAYAGARH	14058	11 KV SINDURIA	14058203	HARIZAN SAHI-V	2241DT038	100	MIXED	AMI	Yes	0%	84	0.10924614	0.037475	0.07177114	65.70%
4147	TPCODL	BBSR2	NYD	NAYAGARH	NAYAGARH	14058	11 KV SINDURIA	14058203	BEBARTA PALLI	2241DT043	100	MIXED	AMI	Yes	0%	55	0.0291126	0.024275	0.0048376	16.62%
4148	TPCODL	BBSR2	NYD	NAYAGARH	NAYAGARH	14058	11 KV SINDURIA	14058203	SINDURIA-I	2241DT051	500	MIXED	AMI	Yes	0%	111	0.21875152	0.058827	0.15992452	73.11%
4149	TPCODL	BBSR2	NYD	NAYAGARH	NAYAGARH	14058	11 KV SINDURIA	14058203	WOMEN COLLEGE	2241DT060	100	MIXED	AMI	Yes	67%	25	0.06512488	0.020074	0.04505088	69.18%
4150	TPCODL	BBSR2	NYD	NAYAGARH	NAYAGARH	14058	11 KV SINDURIA	14058203	GIRLS HIGH SCHOOL	2241DT061	500	MIXED	AMI	Yes	0%	140	0.17024928	0.154585	0.01566428	9.20%
4151	TPCODL	BBSR2	NYD	NAYAGARH	NAYAGARH	14058	11 KV SINDURIA	14058203	D.F.O OTR-I	2241DT069	250	MIXED	AMI	Yes	100%	36	0.149944	0.066227	0.083717	55.83%
4152	TPCODL	BBSR2	NYD	NAYAGARH	NAYAGARH	14058	11 KV SINDURIA	14058203	CHHAYA PATHA-II	2241DT074	500	MIXED	AMI	Yes	0%	105	0.18559752	0.098209	0.08738852	47.08%
4153	TPCODL	BBSR2	NYD	NAYAGARH	NAYAGARH	14058	11 KV SINDURIA	14058203	OLD HOSTEL LANE-1	2241DT075	100	MIXED	AMI	Yes	0%	7	0.01159812	0.010473	0.00112512	9.70%
4154	TPCODL	BBSR2	NYD	NAYAGARH	NAYAGARH	14058	11 KV SINDURIA	14058203	OLD HOSTEL LANE-2	2241DT076	250	MIXED	AMI	Yes	67%	115	0.14509284	0.098924	0.04616884	31.82%
4155	TPCODL	BBSR2	NYD	NAYAGARH	NAYAGARH	14058	11 KV SINDURIA	14058203	MADHUSUDAN BIHAR	2241DT078	250	MIXED	AMI	Yes	100%	251	0.23495364	0.189228	0.04572564	19.46%
4156	TPCODL	BBSR2	NYD	NAYAGARH	NAYAGARH	14058	11 KV SINDURIA	14058203	POSTAL	2241DT080	250	MIXED	AMI	Yes	0%	92	0.15055875	0.091355	0.05920375	39.32%
4157	TPCODL	BBSR2	NYD	NAYAGARH	NAYAGARH	14058	11 KV SINDURIA	14058203	BLOCK OFFICE	2241DT086	100	MIXED	AMI	Yes	0%	42	0.07719198	0.072909	0.00428298	5.55%
4158	TPCODL	BBSR2	NYD	NAYAGARH	NAYAGARH	14058	11 KV SINDURIA	14058203	MEDICAL BACK SIDE-I	2241DT090	500	MIXED	AMI	Yes	67%	249	0.21838792	0.207027	0.01136092	5.20%
4159	TPCODL	BBSR2	NYD	NAYAGARH	NAYAGARH	14058	11 KV SINDURIA	14058203	SDPO QTR	2241DT092	100	MIXED	AMI	Yes	67%	27	0.01878364	0.014421	0.00436264	23.23%
4160	TPCODL	BBSR2	NYD	NAYAGARH	NAYAGARH	14058	11 KV SINDURIA	14058203	MEDICAL BACK SIDE-IV	2241DT095	500	MIXED	AMI	Yes	67%	115	0.1215316	0.088389	0.0331426	27.27%

Sl. No.	Zone Name	Circle name	Division name	Name of the Sub-division	Name of the Sub-station	Substation Code	Name of the 11 kV Feeder	Feeder Code	Name of the Location where DT situated	DT code	DT Capacity (kVA)	Predominant consumer type of DT (Domestic/Industrial/Agriculture/Mixed)	Type of metering AMR/AMI/ Communicable/Conventional metered/Unmetered	Status of Meter-whether Functional (Yes/No)	% of data received automatically (if AMR/AMI)	No. of Connected Consumers	Input Energy (MU) (A)	Billed Energy (MU) (B)	Loss (MU) (A-B)	% DT Loss (A-B)/A
4161	TPCODL	BBSR2	NYD	NAYAGARH	NAYAGARH	14058	11 KV SINDURIA	14058203	RAJA BAGICHA -I	2241DT096	100	MIXED	AMI	Yes	0%	80	0.09992052	0.073143	0.02677752	26.80%
4162	TPCODL	BBSR2	NYD	NAYAGARH	NAYAGARH	14058	11 KV SINDURIA	14058203	RAJA BAGICHA -II	2241DT097	100	MIXED	AMI	Yes	0%	87	0.1513951	0.07968	0.0717151	47.37%
4163	TPCODL	BBSR2	NYD	NAYAGARH	NAYAGARH	14058	11 KV SINDURIA	14058203	RAJA BAGICHA -III	2241DT099	100	MIXED	AMI	Yes	67%	52	0.04263316	0.038658	0.00397516	9.32%
4164	TPCODL	BBSR2	NYD	NAYAGARH	NAYAGARH	14058	11 KV SINDURIA	14058203	RAJA BAGICHA -IV	2241DT100	100	MIXED	AMI	Yes	0%	79	0.09046504	0.04519	0.04527504	50.05%
4165	TPCODL	BBSR2	NYD	NAYAGARH	NAYAGARH	14058	11 KV BARABATI	14058204	AMBIKA VILLA	2241DT004	100	MIXED	AMI	Yes	0%	38	0.07014732	0.041942	0.02820532	40.21%
4166	TPCODL	BBSR2	NYD	NAYAGARH	NAYAGARH	14058	11 KV BARABATI	14058204	GODI SAHI_2	2244DT002	100	MIXED	AMI	Yes	67%	153	0.0949997	0.062278	0.0327217	34.44%
4167	TPCODL	BBSR2	NYD	NAYAGARH	NAYAGARH	14058	11 KV BARABATI	14058204	BARAPALLI CHHAKA	2244DT003	100	MIXED	AMI	Yes	67%	22	0.0147404	0.010653	0.0040874	27.73%
4168	TPCODL	BBSR2	NYD	NAYAGARH	NAYAGARH	14058	11 KV BARABATI	14058204	BARAPALLI_3	2244DT004	100	MIXED	AMI	Yes	67%	106	0.05998138	0.049037	0.01094438	18.25%
4169	TPCODL	BBSR2	NYD	NAYAGARH	NAYAGARH	14058	11 KV BARABATI	14058204	BARABATI (1)	2244DT028	100	MIXED	AMI	Yes	67%	93	0.03827054	0.035587	0.00268354	7.01%
4170	TPCODL	BBSR2	NYD	NAYAGARH	NAYAGARH	14058	11 KV BARABATI	14058204	JADUPUR_1	2244DT045	100	MIXED	AMI	Yes	67%	177	0.07844814	0.045581	0.03286714	41.90%
4171	TPCODL	BBSR2	NYD	NAYAGARH	ODOGAON	14063	11 KV BAHADAJHOLA (O	14063201	KOTHA SAHI RANGANI PATANA 1	2242DT320	100	MIXED	AMI	Yes	0%	161	0.04078074	0.033044	0.00773674	18.97%
4172	TPCODL	BBSR2	NYD	NAYAGARH	ODOGAON	14063	11 KV BAHADAJHOLA (O	14063201	PANTI KHARI SASAN 1	2242DT327	100	MIXED	AMI	Yes	0%	115	0.05159476	0.032176	0.01941876	37.64%
4173	TPCODL	BBSR2	NYD	NAYAGARH	ODOGAON	14063	11 KV BAHADAJHOLA (O	14063201	MASHA BARI 2	2243DT020	200	MIXED	AMI	Yes	67%	167	0.0755775	0.04797926	0.02759824	36.52%
4174	TPCODL	BBSR2	NYD	NAYAGARH	ODOGAON	14063	11 KV BAHADAJHOLA (O	14063201	ANANDAPUR BEDHA	2243DT033	100	MIXED	AMI	Yes	33%	73	0.0294371	0.022964	0.0064731	21.99%
4175	TPCODL	BBSR2	NYD	NAYAGARH	ODOGAON	14063	11 KV BAHADAJHOLA (O	14063201	PAIKABAN KATARA 1	2243DT085	100	MIXED	AMI	Yes	67%	114	0.03594353	0.015655	0.02028853	56.45%
4176	TPCODL	BBSR2	NYD	NAYAGARH	ODOGAON	14063	11 KV BAHADAJHOLA (O	14063201	KORAPITHA 3	2243DT101	100	MIXED	AMI	Yes	67%	116	0.03953086	0.030242	0.00928886	23.50%
4177	TPCODL	BBSR2	NYD	NAYAGARH	ODOGAON	14063	11 KV KOMANDA	14063202	RANGANIPATANA MAIN ROAD -2	2242DT060	100	MIXED	AMI	Yes	0%	45	0.0490021	0.026855	0.0221471	45.20%
4178	TPCODL	BBSR2	NYD	NAYAGARH	ODOGAON	14063	11 KV KOMANDA	14063202	RANGANIPATANA MAIN ROAD -1	2242DT062	250	MIXED	AMI	Yes	33%	224	0.0850688	0.06323	0.0218388	25.67%
4179	TPCODL	BBSR2	NYD	NAYAGARH	ODOGAON	14063	11 KV KOMANDA	14063202	RANGANIPATANA ITASAHI	2242DT072	100	MIXED	AMI	Yes	0%	78	0.03445432	0.028333	0.00612132	17.77%
4180	TPCODL	BBSR2	NYD	NAYAGARH	ODOGAON	14063	11 KV KOMANDA	14063202	RANGANIPATANA BADASAHI	2242DT077	100	MIXED	AMI	Yes	0%	96	0.03793	0.029073	0.008857	23.35%
4181	TPCODL	BBSR2	NYD	NAYAGARH	ODOGAON	14063	11 KV KOMANDA	14063202	GODIPALLI MAIN ROAD	2242DT089	100	MIXED	AMI	Yes	0%	114	0.03546074	0.03357	0.00189074	5.33%
4182	TPCODL	BBSR2	NYD	NAYAGARH	ODOGAON	14063	11 KV KOMANDA	14063202	NABARATNAPUR-1	2242DT183	100	MIXED	AMI	Yes	0%	72	0.02516606	0.017745	0.00742106	29.49%
4183	TPCODL	BBSR2	NYD	NAYAGARH	ODOGAON	14063	11 KV ODOGAON-1	14063203	STRUCTURE CAMPUS	2242DT001	500	MIXED	AMI	Yes	0%	326	0.22700608	0.154932	0.07207408	31.75%
4184	TPCODL	BBSR2	NYD	NAYAGARH	ODOGAON	14063	11 KV ODOGAON-1	14063203	CHHAMUSAHI-1(CHAMUSAHI)	2242DT006	250	MIXED	AMI	Yes	67%	171	0.09229173	0.06677	0.02552173	27.65%
4185	TPCODL	BBSR2	NYD	NAYAGARH	ODOGAON	14063	11 KV ODOGAON-1	14063203	ODIA SAHI (RAGHUNATH MANDIRA-3	2242DT008	100	MIXED	AMI	Yes	0%	118	0.05939414	0.038984	0.02041014	34.36%
4186	TPCODL	BBSR2	NYD	NAYAGARH	ODOGAON	14063	11 KV ODOGAON-2	14063204	MANSANIPADA-2	2242DT012	500	MIXED	AMI	Yes	67%	222	0.33434264	0.105022	0.22932064	68.59%
4187	TPCODL	BBSR2	NYD	NAYAGARH	ODOGAON	14063	11 KV ODOGAON-2	14063204	ODAGAON CLUB-2	2242DT029	500	MIXED	AMI	Yes	33%	227	0.1680244	0.128613	0.0394114	23.46%
4188	TPCODL	BBSR2	NYD	NAYAGARH	ODOGAON	14063	11 KV ODOGAON-2	14063204	TOTA SAHI	2242DT030	100	MIXED	AMI	Yes	33%	146	0.07811406	0.068899	0.00921506	11.80%
4189	TPCODL	BBSR2	NYD	NAYAGARH	ODOGAON	14063	11 KV ODOGAON-2	14063204	BIYAYAMANDAP SAHI-1	2242DT033	500	MIXED	AMI	Yes	33%	213	0.21369936	0.079101	0.13459836	62.98%
4190	TPCODL	BBSR2	NYD	NAYAGARH	ODOGAON	14063	11 KV ODOGAON-2	14063204	NITYANANDASAHI	2242DT034	500	MIXED	AMI	Yes	0%	168	0.17285104	0.081637	0.09121404	52.77%
4191	TPCODL	BBSR2	NYD	NAYAGARH	ODOGAON	14063	11 KV ODOGAON-2	14063204	DALAK MAIN ROADS-2	2242DT036	100	MIXED	AMI	Yes	0%	89	0.09077702	0.047509	0.04326802	47.66%
4192	TPCODL	BBSR2	NYD	NAYAGARH	ODOGAON	14063	11 KV ODOGAON-2	14063204	DALAKA GOUDIA SAHI-1	2242DT037	500	MIXED	AMI	Yes	0%	429	0.2397848	0.18977	0.0500148	20.86%
4193	TPCODL	BBSR2	NYD	NAYAGARH	ODOGAON	14063	11 KV ODOGAON-2	14063204	JARINGI	2242DT042	100	MIXED	AMI	Yes	0%	176	0.08109952	0.056723	0.02437652	30.06%
4194	TPCODL	BBSR2	NYD	NAYAGARH	ODOGAON	14063	11 KV AMBARPUR	14063205	BAUNSSA GADI 1	2243DT441	100	MIXED	AMI	Yes	67%	98	0.03794764	0.030146	0.00780164	20.56%
4195	TPCODL	BBSR2	NYD	NAYAGARH	ODOGAON	14063	11 KV AMBARPUR	14063205	BAUNSSA GADI 3	2243DT444	250	MIXED	AMI	Yes	67%	74	0.03098068	0.027627	0.00335368	10.83%
4196	TPCODL	BBSR2	NYD	NAYAGARH	ODOGAON	14063	11 KV AMBARPUR	14063205	BHADILA 5	2243DT466	63	MIXED	AMI	Yes	0%	75	0.02604446	0.014581	0.01146346	44.01%
4197	TPCODL	BBSR2	NYD	NAYAGARH	ODOGAON	14063	11 KV NANDIGHOR	14063206	GOVT POLY TECHNIC ODAGAON 2	2243DT220	100	MIXED	AMI	Yes	0%	11	0.00749776	0.004364	0.00313376	41.80%
4198	TPCODL	BBSR2	NYD	NAYAGARH	ODOGAON	14063	11 KV NANDIGHOR	14063206	KENAL SHHAK00KVA S/S	2243DT227	100	MIXED	AMI	Yes	0%	75	0.0377944	0.02253	0.0152644	40.39%
4199	TPCODL	BBSR2	NYD	NAYAGARH	ODOGAON	14063	11 KV NANDIGHOR	14063206	GOTHABAN -2	2243DT230	100	MIXED	AMI	Yes	0%	59	0.02664036	0.017843	0.00879736	33.02%
4200	TPCODL	BBSR2	NYD	NAYAGARH	ODOGAON	14063	11 KV NANDIGHOR	14063206	GOUDAPUT HIGH SCHOOL 2	2243DT241	100	MIXED	AMI	Yes	67%	104	0.0255918	0.025155	0.0004368	1.71%
4201	TPCODL	BBSR2	NYD	NAYAGARH	ODOGAON	14063	11 KV NANDIGHOR	14063206	NANDIGHORA BUS STAND 1	2243DT342	100	MIXED	AMI	Yes	0%	174	0.07374348	0.053138	0.02060548	27.94%
4202	TPCODL	BBSR2	NYD	NAYAGARH	SARANKUL	14062	11 KV SARANKUL	14062201	SARANKUL BAZAR	2245DT232	250	MIXED	AMI	Yes	67%	106	0.06395096	0.034038	0.02991296	46.77%
4203	TPCODL	BBSR2	NYD	NAYAGARH	SARANKUL	14062	11 KV SARANKUL	14062201	SARASWATI SHISHU VIDHYA MANDIR	2245DT233	250	MIXED	AMI	Yes	67%	197	0.13491304	0.09878	0.03613304	26.78%
4204	TPCODL	BBSR2	NYD	NAYAGARH	SARANKUL	14062	11 KV SARANKUL	14062201	BATA MANGALA	2245DT235	100	MIXED	AMI	Yes	67%	89	0.03408622	0.027489	0.00659722	19.35%
4205	TPCODL	BBSR2	NYD	NAYAGARH	SARANKUL	14062	11 KV SARANKUL	14062201	BAZAR -1	2245DT243	100	MIXED	AMI	Yes	67%	159	0.07341195	0.055642	0.01776995	24.21%
4206	TPCODL	BBSR2	NYD	NAYAGARH	SARANKUL	14062	11 KV SARANKUL	14062201	LAXMI BAZAR	2245DT247	100	MIXED	AMI	Yes	67%	113	0.05855952	0.044134	0.01442552	24.63%
4207	TPCODL	BBSR2	NYD	NAYAGARH	SARANKUL	14062	11 KV SARANKUL	14062201	HARIHARPUR -2	2245DT254	100	MIXED	AMI	Yes	0%	102	0.05192856	0.029434	0.02249456	43.32%
4208	TPCODL	BBSR2	NYD	NAYAGARH	SARANKUL	14062	11 KV SARANKUL	14062201	BRIDGE	2245DT256	100	MIXED	AMI	Yes	0%	118	0.05351237	0.03213	0.02138237	39.96%
4209	TPCODL	BBSR2	NYD	NAYAGARH	SARANKUL	14062	11 KV GODIPADA	14062202	GUNJABARANA	2246DT151	100	MIXED	AMI	Yes	0%	55	0.02253148	0.013355	0.00917648	40.73%
4210	TPCODL	BBSR2	NYD	NAYAGARH	SARANKUL	14062	11 KV GODIPADA	14062202	GOLAGAON	2246DT186	200	MIXED	AMI	Yes	0%	307	0.14472472	0.062802	0.08192272	56.61%
4211	TPCODL	BBSR2	NYD	NAYAGARH	SARANKUL	14062	11 KV GODIPADA	14062202	GANDHABARANA-2	2246DT202	100	MIXED	AMI	Yes	67%	69	0.02469377	0.017224	0.00746977	30.25%
4212	TPCODL	BBSR2	NYD	NAYAGARH	SARANKUL	14062	11 KV GODIPADA	14062202	BADAKUTUNI-2	2246DT210	100	MIXED	AMI	Yes	67%	247	0.05597178	0.039664	0.01630778	29.14%
4213	TPCODL	BBSR2	NYD	NAYAGARH	SARANKUL	14062	11 KV GODIPADA	14062202	SANAGORADA GOPINATH PRASAD	2246DT247	100	MIXED	AMI	Yes	0%	44	0.01806858	0.008646	0.00942258	52.15%
4214	TPCODL	BBSR2	NYD	NAYAGARH	SARANKUL	14062	11 KV MACHHIPADA	14062203	CHUDAMILL SAHI	2245DT264	500	MIXED	AMI	Yes	67%	240	0.15124284	0.084554	0.06668884	44.09%
4215	TPCODL	BBSR2	NYD	NAYAGARH	SARANKUL	14062	11 KV MACHHIPADA	14062203	MALI SAHI	2245DT266	250	MIXED	AMI	Yes	67%	187	0.07026616	0.054813	0.01545316	21.99%
4216	TPCODL	BBSR2	NYD	NAYAGARH	SARANKUL	14062	11 KV DARAPADA	14062204	JAGANNATH PUR	2245DT306	250	MIXED	AMI	Yes	33%	168	0.0775192	0.063477	0.0140422	18.11%
4217	TPCODL	BBSR2	NYD	NAYAGARH	SARANKUL	14062	11 KV DARAPADA	14062204	KATARAJHARI - 1	2245DT308	100	MIXED	AMI	Yes	67%	152	0.04454642	0.030814	0.01373242	30.83%
4218	TPCODL	BBSR2	NYD	NAYAGARH	SARANKUL	14062	11 KV DARAPADA	14062204	DARAPADA VILLEAGE	2245DT322	100	MIXED	AMI	Yes	67%	197	0.05726688	0.048524	0.00874288	15.27%
4219	TPCODL	BBSR2	NYD	NAYAGARH	SARANKUL	14062	11 KV DARAPADA	14062204	MAGARABANDHA (MEDICAL)	2245DT332	100	MIXED	AMI	Yes	67%	31	0.03350532	0.013426	0.02007932	59.93%
4220	TPCODL	BBSR2	NYD	NAYAGARH	SARANKUL	14062	11 KV DARAPADA	14062204	MAGARABANDHA (GODISAHI)	2245DT338	100	MIXED	AMI	Yes	67%	176	0.04485732	0.041989	0.00286832	6.39%
4221	TPCODL	BBSR2	NYD	NAYAGARH	SARANKUL	14062	11 KV DARAPADA	14062204	NUAGAON - 1	2245DT342	100	MIXED	AMI	Yes	67%	92	0.02320294	0.01786	0.00534294	23.03%
4222	TPCODL	BBSR2	NYD	NAYAGARH	SARANKUL	14062	11 KV DARAPADA	14062204	BALISAHI (VILLEAGE)	2245DT348	100	MIXED	AMI	Yes	67%	64	0.02333352	0.010515	0.01281852	54.94%
4223	TPCODL	BBSR2	NYD	NAYAGARH	SARANKUL	14062	11 KV DARAPADA	14062204	GHODA GADIA - 2	2245DT361	100	MIXED	AMI	Yes	67%	82	0.02290706	0.01752	0.00538706	23.52%
4224	TPCODL	BBSR2	NYD	NAYAGARH	SARANKUL	14062	11 KV PANCHIDA	14062205	ASURIDHIPA-1	2246DT002	250	MIXED	AMI	Yes	67%	154	0.042712	0.037397	0.005315	12.44%
4225	TPCODL	BBSR2	NYD	NAYAGARH	SARANKUL	14062	11 KV PANCHIDA	14062205	AVIMANPUR-1	2246DT046	250	MIXED	AMI	Yes	67%	227	0.05155932	0.043133	0.00842632	16.34%
4226	TPCODL	BBSR2	NYD	NAYAGARH	SARANKUL	14062	11 KV PANCHIDA	14062205	GODIPALI NEAR POND	2246DT050	100	MIXED	AMI	Yes	33%	183	0.07363232	0.051404	0.02222832	30.19%
4227	TPCODL	BBSR2	NYD	NAYAGARH	SARANKUL	14062	11 KV PANCHIDA	14062205	KARADA NEAR POND	2246DT055	100	MIXED	AMI	Yes	100%	138	0.04174136	0.034401	0.00734036	17.59%
4228	TPCODL	BBSR2	NYD	NAYAGARH	SARANKUL	14062	11 KV PANCHIDA	14062205	KARADA NUA SAHI-2	2246DT058	100	MIXED	AMI	Yes	67%	106	0.04374081	0.030267	0.01347381	30.80%
4229	TPCODL	BBSR2	NYD	NAYAGARH	SARANKUL	14062	11 KV PANCHIDA	14062205	P. PAIKABADA (BEDSAHI)	2246DT079	100	MIXED	AMI	Yes	67%	187	0.04696221	0.033976	0.01298621	27.65%
4230	TPCODL	BBSR2	NYD	NAYAGARH	SARANKUL	14062	11 KV PANCHIDA	14062205	PANCHIRIDA	2246DT100	100	MIXED	AMI	Yes	67%	158	0.04650689	0.033002	0.01350489	29.04%
4231	TPCODL	BBSR2	NYD	NAYAGARH	SARANKUL	14062	11 KV PANCHIDA	14062205	ARADA MAIN SAHI-2	2246DT107	100	MIXED	AMI	Yes	67%	137	0.04820322	0.029347	0.01885622	39.12%
4232	TPCODL	BBSR2	NYD	NAYAGARH	SARANKUL	14062	11 KV PANCHIDA	14062205	PETA PALLI	2246DT135	100	MIXED	AMI	Yes	67%	87	0.02262304	0.016443	0.00618004	27.32%
4233	TPCODL	BBSR2	NYD	NAYAGARH	SARANKUL	14062	11 KV SIKHARPUR	14062206	JENASAHI -2	2245DT385	100	MIXED	AMI	Yes	67%	114	0.07492617	0.021385	0.05354117	71.46%

Sl. No.	Zone Name	Circle name	Division name	Name of the Sub-division	Name of the Sub-station	Substation Code	Name of the 11 kV Feeder	Feeder Code	Name of the Location where DT situated	DT code	DT Capacity (kVA)	Predominant consumer type of DT (Domestic/Industrial/Agriculture/Mixed)	Type of metering AMR/AMI/ Communicable/Conventional metered/Unmetered	Status of Meter-whether Functional (Yes/No)	% of data received automatically (if AMR/AMI)	No. of Connected Consumers	Input Energy (MU) (A)	Billed Energy (MU) (B)	Loss (MU) (A-B)	% DT Loss (A-B)/A
4234	TPCODL	BBSR2	NYD	NAYAGARH	SARANKUL	14062	11 KV SIKHARPUR	14062206	JANGYESWARI SAHI	2245DT392	100	MIXED	AMI	Yes	67%	126	0.03687658	0.034047	0.00282958	7.67%
4235	TPCODL	BBSR2	NYD	NAYAGARH	SARANKUL	14062	11 KV SIKHARPUR	14062206	MATHA SAHI	2245DT400	250	MIXED	AMI	Yes	67%	70	0.06077044	0.018703	0.04206744	69.22%
4236	TPCODL	BBSR2	NYD	NAYAGARH	SARANKUL	14062	11 KV SIKHARPUR	14062206	BAUNSIA-2	2245DT405	100	MIXED	AMI	Yes	67%	110	0.05025865	0.035206	0.01505265	29.95%
4237	TPCODL	BBSR2	PED	PURI-I	ATHARNALA	14207	11 KV Narendra Pokhari	14207203	PURI ITI COLLEGE 01	2413DT002	500	MIXED	AMI	Yes	100%	433	0.39381748	0.283265	0.11055248	28.07%
4238	TPCODL	BBSR2	PED	PURI-I	ATHARNALA	14207	11 KV Narendra Pokhari	14207203	SRI JAGANNATH BHAKTA NIWAS	2413DT010	250	MIXED	AMI	Yes	100%	37	0.03277872	0.008593	0.02418572	73.78%
4239	TPCODL	BBSR2	PED	PURI-I	ATHARNALA	14207	11 KV Narendra Pokhari	14207203	JADESWARI COLONY	2413DT012	100	MIXED	AMI	Yes	0%	114	0.11431732	0.064566	0.04975132	43.52%
4240	TPCODL	BBSR2	PED	PURI-I	BALIAPANDA	14066	11 KV 11kV Lokanath	14066201	KRIYA YOGA ASHRAM	2411DT001	100	MIXED	AMI	Yes	67%	155	0.15212771	0.110011	0.04211671	27.69%
4241	TPCODL	BBSR2	PED	PURI-I	BALIAPANDA	14066	11 KV 11kV Lokanath	14066201	DIVINE MANSION APARTMENT	2411DT007	250	MIXED	AMI	Yes	100%	42	0.01226848	0.005367	0.00690148	56.25%
4242	TPCODL	BBSR2	PED	PURI-I	BALIAPANDA	14066	11 KV 11kV Lokanath	14066201	JAMUKHUTIYA	2411DT008	250	MIXED	AMI	Yes	100%	88	0.18687312	0.059874	0.12699912	67.96%
4243	TPCODL	BBSR2	PED	PURI-I	BALIAPANDA	14066	11 KV 11kV Lokanath	14066201	SANDHA CHHAKA	2411DT010	500	MIXED	AMI	Yes	33%	444	0.52155056	0.344974	0.17657656	33.86%
4244	TPCODL	BBSR2	PED	PURI-I	BALIAPANDA	14066	11 KV 11kV Lokanath	14066201	CREATIVE APARTMENT	2411DT011	500	MIXED	AMI	Yes	100%	67	0.0205656	0.014749	0.0058166	28.28%
4245	TPCODL	BBSR2	PED	PURI-I	BALIAPANDA	14066	11 KV 11kV Lokanath	14066201	CHAPAN CHAKKA	2411DT012	500	MIXED	AMI	Yes	100%	638	0.4329948	0.423733	0.0092618	2.14%
4246	TPCODL	BBSR2	PED	PURI-I	BALIAPANDA	14066	11 KV 11kV Lokanath	14066201	NAWAGARH RESIDENCY	2411DT017	250	MIXED	AMI	Yes	100%	27	0.00634868	0.003544	0.00280468	44.18%
4247	TPCODL	BBSR2	PED	PURI-I	BALIAPANDA	14066	11 KV 11kV Lokanath	14066201	DHARMA APARTMENT	2411DT018	500	MIXED	AMI	Yes	100%	112	0.01415528	0.010735	0.00342028	24.16%
4248	TPCODL	BBSR2	PED	PURI-I	BALIAPANDA	14066	11 KV 11kV Lokanath	14066201	NABAKALEBAR HOUSE	2411DT023	100	MIXED	AMI	Yes	100%	13	0.01128728	0.00531	0.00597728	52.96%
4249	TPCODL	BBSR2	PED	PURI-I	BALIAPANDA	14066	11 KV 11kV Lokanath	14066201	PAIKHA SAHI	2411DT026	250	MIXED	AMI	Yes	100%	314	0.2390504	0.189413	0.0496374	20.76%
4250	TPCODL	BBSR2	PED	PURI-I	BALIAPANDA	14066	11 KV 11kV Lokanath	14066201	MANI MAHASASUR	2411DT028	100	MIXED	AMI	Yes	100%	118	0.0717152	0.065767	0.0059482	8.29%
4251	TPCODL	BBSR2	PED	PURI-I	BALIAPANDA	14066	11 KV 11kV Lokanath	14066201	MANI MAHASASUR	2411DT029	250	MIXED	AMI	Yes	100%	293	0.20814412	0.151857	0.05628712	27.04%
4252	TPCODL	BBSR2	PED	PURI-I	BALIAPANDA	14066	11 KV 11kV Lokanath	14066201	SHANKARPUR	2411DT039	63	MIXED	AMI	Yes	100%	55	0.07002552	0.042374	0.02765152	39.49%
4253	TPCODL	BBSR2	PED	PURI-I	BALIAPANDA	14066	11 KV 11kV Lokanath	14066201	SAPATGIRI ICON	2411DT041	100	MIXED	AMI	Yes	100%	76	0.01623612	0.014076	0.00216012	13.30%
4254	TPCODL	BBSR2	PED	PURI-I	BALIAPANDA	14066	11 KV 11kV Lokanath	14066201	OLD BASELI SAHI P S	2411DT042	250	MIXED	AMI	Yes	0%	191	0.25019474	0.131414	0.11878074	47.48%
4255	TPCODL	BBSR2	PED	PURI-I	BALIAPANDA	14066	11 KV BALIAPANDA KACH	14066202	NANDGHOSH APARTMENT	2411DT044	500	MIXED	AMI	Yes	100%	117	0.03851	0.029871	0.008639	22.43%
4256	TPCODL	BBSR2	PED	PURI-I	BALIAPANDA	14066	11 KV BALIAPANDA KACH	14066202	TOTA GOPINATH	2414DT032	250	MIXED	AMI	Yes	100%	119	0.14078464	0.100636	0.04014864	28.52%
4257	TPCODL	BBSR2	PED	PURI-I	BALIAPANDA	14066	11 KV BALIAPANDA KACH	14066202	JAMBESHWAR 2	2414DT033	500	MIXED	AMI	Yes	100%	179	0.2961976	0.131688	0.1645096	55.54%
4258	TPCODL	BBSR2	PED	PURI-I	BALIAPANDA	14066	11 KV BALIAPANDA KACH	14066202	KHUTIYA 1 KAMAKSHYA	2414DT035	250	MIXED	AMI	Yes	100%	84	0.21349632	0.083002	0.13049432	61.12%
4259	TPCODL	BBSR2	PED	PURI-I	BALIAPANDA	14066	11 KV BALIAPANDA KACH	14066202	TIGLI SAHI TIODISAHI	2414DT036	500	MIXED	AMI	Yes	0%	197	0.30968176	0.160627	0.14905476	48.13%
4260	TPCODL	BBSR2	PED	PURI-I	BALIAPANDA	14066	11 KV BALIAPANDA KACH	14066202	THAKUR SHREE SHREE RAMDASH ACI	2414DT046	500	MIXED	AMI	Yes	0%	167	0.62439384	0.346508	0.27788584	44.50%
4261	TPCODL	BBSR2	PED	PURI-I	BALIAPANDA	14066	11 KV 11kV Prachi OH	14066204	MANGLA SAMITI	2411DT069	250	MIXED	AMI	Yes	0%	287	0.28871156	0.133084	0.15562756	53.90%
4262	TPCODL	BBSR2	PED	PURI-I	BALIAPANDA	14066	11 KV 11kV Prachi OH	14066204	NARAYANI APARMENT	2411DT083	100	MIXED	AMI	Yes	67%	17	0.00307453	0.002113	0.00096153	31.27%
4263	TPCODL	BBSR2	PED	PURI-I	BALIAPANDA	14066	11 KV 11kV Prachi OH	14066204	RULDRASHKA BALSINGH	2411DT089	100	MIXED	AMI	Yes	100%	34	0.00572232	0.004638	0.00108432	18.95%
4264	TPCODL	BBSR2	PED	PURI-I	BALIAPANDA	14066	11 KV 11kV Prachi OH	14066204	MANDAKINI APARTMENT	2411DT106	100	MIXED	AMI	Yes	100%	21	0.00196514	0.001819	0.00014614	7.44%
4265	TPCODL	BBSR2	PED	PURI-I	BALIAPANDA	14066	11 KV 11kV Prachi OH	14066204	KALINGA BIHAR	2411DT112	250	MIXED	AMI	Yes	33%	60	0.07379868	0.046056	0.02774268	37.59%
4266	TPCODL	BBSR2	PED	PURI-I	BALIAPANDA	14066	11 KV 11kV Prachi OH	14066204	CREATIVE SEA SITE	2411DT115	100	MIXED	AMI	Yes	100%	21	0.01634168	0.015385	0.00095668	5.85%
4267	TPCODL	BBSR2	PED	PURI-I	BALIAPANDA	14066	11 KV 11kV Prachi OH	14066204	PRAGYAN	2411DT119	500	MIXED	AMI	Yes	100%	198	0.52005112	0.416952	0.10309912	19.82%
4268	TPCODL	BBSR2	PED	PURI-I	BALIAPANDA	14066	11 KV 11kV Prachi OH	14066204	ASHIANA LAGOON	2411DT128	100	MIXED	AMI	Yes	0%	30	0.02210528	0.013227	0.00887828	40.16%
4269	TPCODL	BBSR2	PED	PURI-I	BALIAPANDA	14066	11 KV 11kV Prachi OH	14066204	RANI CHOWRAHA	2411DT147	100	MIXED	AMI	Yes	100%	64	0.06875488	0.03348	0.03527488	51.31%
4270	TPCODL	BBSR2	PED	PURI-I	BALIAPANDA	14066	11 KV Baliapanda - Sri M	14066205	KAPALA MACHHOU CSS	2413DT051	750	MIXED	AMI	Yes	100%	308	0.67678189	0.220499	0.45628289	67.42%
4271	TPCODL	BBSR2	PED	PURI-I	BALIAPANDA	14066	11 KV Baliapanda - Sri M	14066205	BASELI SAHI	2413DT053	500	MIXED	AMI	Yes	100%	170	0.35889304	0.177314	0.18157904	50.59%
4272	TPCODL	BBSR2	PED	PURI-I	BALIAPANDA	14066	11 KV Baliapanda - Sri M	14066205	MISRA SAHI	2413DT059	500	MIXED	AMI	Yes	0%	313	0.39785432	0.22365	0.17420432	43.79%
4273	TPCODL	BBSR2	PED	PURI-I	BALIAPANDA	14066	11 KV Baliapanda - Sri M	14066205	CHUDAMILL	2413DT061	250	MIXED	AMI	Yes	67%	174	0.1862248	0.095443	0.0907818	48.75%
4274	TPCODL	BBSR2	PED	PURI-I	BALIAPANDA	14066	11 KV Baliapanda - Sri M	14066205	RADHAGOBINDA LANE	2413DT062	500	MIXED	AMI	Yes	100%	390	0.50603064	0.287112	0.21891864	43.26%
4275	TPCODL	BBSR2	PED	PURI-I	BALIAPANDA	14066	11 KV Baliapanda - Sri M	14066205	GOSALA	2413DT063	500	MIXED	AMI	Yes	100%	150	0.14120376	0.087511	0.05369276	38.03%
4276	TPCODL	BBSR2	PED	PURI-I	BALIAPANDA	14066	11 KV Baliapanda - Sri M	14066205	TRIDEV NAGAR	2413DT067	250	MIXED	AMI	Yes	0%	236	0.22260118	0.181098	0.04150318	18.64%
4277	TPCODL	BBSR2	PED	PURI-I	BALIAPANDA	14066	11 KV Baliapanda - Sri M	14066205	BALI SCHOOL 2 NRUSINGHA TEMPLE	2413DT071	250	MIXED	AMI	Yes	67%	119	0.1224224	0.089311	0.0331114	27.05%
4278	TPCODL	BBSR2	PED	PURI-I	BALIAPANDA	14066	11 KV Baliapanda - Sri M	14066205	SHREE APARTMENT	2413DT074	250	MIXED	AMI	Yes	100%	226	0.09158916	0.079647	0.01194216	13.04%
4279	TPCODL	BBSR2	PED	PURI-I	BALIAPANDA	14066	11 KV Baliapanda - Sri M	14066205	MUDULI JAGA	2413DT075	250	MIXED	AMI	Yes	100%	213	0.28097524	0.200206	0.08076924	28.75%
4280	TPCODL	BBSR2	PED	PURI-I	BALIAPANDA	14066	11 KV 11kV Prachi UG	14066206	RAJ PUJAPANDA	2411DT167	500	MIXED	AMI	Yes	0%	423	0.6349584	0.564151	0.0708074	11.15%
4281	TPCODL	BBSR2	PED	PURI-I	BALIAPANDA	14066	11 KV 11kV Prachi UG	14066206	MASANI	2411DT182	500	MIXED	AMI	Yes	100%	28	0.4188416	0.156715	0.2621266	62.58%
4282	TPCODL	BBSR2	PED	PURI-I	CHARINALA	14067	11 KV VIJAY MARINE	14067204	ANNPURNA NAGAR	2431DT023	250	MIXED	AMI	Yes	33%	208	0.2563932	0.169206	0.0871872	34.01%
4283	TPCODL	BBSR2	PED	PURI-I	KACHERI	14065	11 KV 11kV Swargadwar	14065201	HARIHAR CHHAK	2412DT001	250	MIXED	AMI	Yes	0%	83	0.22818944	0.175283	0.05290644	23.19%
4284	TPCODL	BBSR2	PED	PURI-I	KACHERI	14065	11 KV 11kV Swargadwar	14065201	BHOLAGIRI	2412DT010	250	MIXED	AMI	Yes	0%	385	0.33362184	0.220975	0.11264684	33.76%
4285	TPCODL	BBSR2	PED	PURI-I	KACHERI	14065	11 KV 11kV Swargadwar	14065201	SAHOO LODGE	2412DT011	250	MIXED	AMI	Yes	100%	391	0.31921732	0.238316	0.08090132	25.34%
4286	TPCODL	BBSR2	PED	PURI-I	KACHERI	14065	11 KV 11kV Swargadwar	14065201	MAHABAHU INTERNATIONAL	2412DT022	100	MIXED	AMI	Yes	100%	12	0.03719512	0.02894	0.00825512	22.19%
4287	TPCODL	BBSR2	PED	PURI-I	KACHERI	14065	11 KV Swargadwar-2	14065202	NEAR SURYA LODEGE	2412DT030	250	MIXED	AMI	Yes	100%	100	0.32185208	0.26762	0.05423208	16.85%
4288	TPCODL	BBSR2	PED	PURI-I	KACHERI	14065	11 KV Swargadwar-2	14065202	KHUTIA SHAI	2412DT034	500	MIXED	AMI	Yes	100%	266	0.50938888	0.303193	0.20619588	40.48%
4289	TPCODL	BBSR2	PED	PURI-I	KACHERI	14065	11 KV Swargadwar-2	14065202	MAHODADHI ENCLAVE 1	2412DT035	250	MIXED	AMI	Yes	100%	52	0.03107426	0.015467	0.01560726	50.23%
4290	TPCODL	BBSR2	PED	PURI-I	KACHERI	14065	11 KV Swargadwar-2	14065202	MAHODADHI ENCLAVE 2	2412DT036	250	MIXED	AMI	Yes	100%	50	0.01869838	0.014688	0.00401038	21.45%
4291	TPCODL	BBSR2	PED	PURI-I	KACHERI	14065	11 KV Swargadwar-2	14065202	NIRUPAMA ENCLAVE	2412DT037	100	MIXED	AMI	Yes	100%	30	0.01291556	0.00915	0.00376556	29.16%
4292	TPCODL	BBSR2	PED	PURI-I	KACHERI	14065	11 KV Swargadwar-2	14065202	NIHAR NIWAS	2412DT038	250	MIXED	AMI	Yes	0%	38	0.01475276	0.008121	0.00663176	44.95%
4293	TPCODL	BBSR2	PED	PURI-I	KACHERI	14065	11 KV Swargadwar-2	14065202	DAWARI BABU 01	2412DT039	100	MIXED	AMI	Yes	100%	85	0.11913828	0.091775	0.02736328	22.97%
4294	TPCODL	BBSR2	PED	PURI-I	KACHERI	14065	11 KV Swargadwar-2	14065202	DAWARI BABU 02	2412DT040	250	MIXED	AMI	Yes	100%	247	0.31352112	0.241173	0.07234812	23.08%
4295	TPCODL	BBSR2	PED	PURI-I	KACHERI	14065	11 KV Swargadwar-2	14065202	HARI JANA BASTI	2414DT001	250	MIXED	AMI	Yes	100%	209	0.25372188	0.165849	0.08787288	34.63%
4296	TPCODL	BBSR2	PED	PURI-I	KACHERI	14065	11 KV Swargadwar-2	14065202	MANGAL ALATI	2414DT016	200	MIXED	AMI	Yes	33%	48	0.01293472	0.007401	0.00553372	42.78%
4297	TPCODL	BBSR2	PED	PURI-I	KACHERI	14065	11 KV Swargadwar-2	14065202	BATA KALI	2414DT017	500	MIXED	AMI	Yes	100%	206	0.36203784	0.21831	0.14372784	39.70%
4298	TPCODL	BBSR2	PED	PURI-I	KACHERI	14065	11 KV Swargadwar-2	14065202	RAJA RANI COTTAGE	2414DT019	160	MIXED	AMI	Yes	100%	32	0.00395892	0.003127	0.00083192	21.01%
4299	TPCODL	BBSR2	PED	PURI-I	KACHERI	14065	11 KV Swargadwar-2	14065202	GIRI SWAMI	2414DT020	250	MIXED	AMI	Yes	100%	180	0.37429156	0.175834	0.19845756	53.02%
4300	TPCODL	BBSR2	PED	PURI-I	KACHERI	14065	11 KV Swargadwar-2	14065202	MACHHA HATA	2414DT023	500	MIXED	AMI	Yes	0%	191	0.4626152	0.110411	0.3522042	76.13%
4301	TPCODL	BBSR2	PED	PURI-I	KACHERI	14065	11 KV Swargadwar-2	14065202	SWETAGANGA	2414DT024	500	MIXED	AMI	Yes	0%	246	0.48279672	0.228242	0.25455472	52.73%
4302	TPCODL	BBSR2	PED	PURI-I	KACHERI	14065	11 KV DOLAMANDAP	14065203	GHANSHAYAM VILLA APARTMENT	2412DT042	100	MIXED	AMI	Yes	100%	29	0.00880256	0.00738	0.00142256	16.16%
4303	TPCODL	BBSR2	PED	PURI-I	KACHERI	14065	11 KV DOLAMANDAP	14065203	PURI GREENS APARTMENT	2412DT043	100	MIXED	AMI	Yes	100%	21	0.02599116	0.023585	0.00240616	9.26%
4304	TPCODL	BBSR2	PED	PURI-I	KACHERI	14065	11 KV DOLAMANDAP	14065203	GADI KHANG	2412DT044	250	MIXED	AMI	Yes	100%	77	0.22479352	0.113737	0.11105652	49.40%
4305	TPCODL	BBSR2	PED	PURI-I	KACHERI	14065	11 KV DOLAMANDAP	14065203	MACHHA HATA	2412DT046	250	MIXED	AMI	Yes	100%	161	0.25549072	0.212643	0.04284772	16.77%
4306	TPCODL	BBSR2	PED	PURI-I	KACHERI	14065	11 KV DOLAMANDAP	14065203	VIATACHHA APARTMENT DOLAMANI	2412DT049	500	MIXED	AMI	Yes	100%	49	0.02390368	0.012552	0.01135168	47.49%

Sl. No.	Zone Name	Circle name	Division name	Name of the Sub-division	Name of the Sub-station	Substation Code	Name of the 11 kV Feeder	Feeder Code	Name of the Location where DT situated	DT code	DT Capacity (kVA)	Predominant consumer type of DT (Domestic/Industrial/Agriculture/Mixed)	Type of metering AMR/AMI/ Communicable/Conventional metered/Unmetered	Status of Meter-whether Functional (Yes/No)	% of data received automatically (if AMR/AMI)	No. of Connected Consumers	Input Energy (MU) (A)	Billed Energy (MU) (B)	Loss (MU) (A-B)	% DT Loss (A-B)/A
4307	TPCODL	BBSR2	PED	PURI-I	KACHERI	14065	11 KV DOLAMANDAP	14065203	NUA SAHI	2412DT050	250	MIXED	AMI	Yes	0%	81	0.1524828	0.073921	0.0785618	51.52%
4308	TPCODL	BBSR2	PED	PURI-I	KACHERI	14065	11 KV DOLAMANDAP	14065203	HABILLI GALLI	2412DT051	500	MIXED	AMI	Yes	0%	191	0.34215904	0.18795	0.15420904	45.07%
4309	TPCODL	BBSR2	PED	PURI-I	KACHERI	14065	11 KV DOLAMANDAP	14065203	JANHI MUMDIA 1 CHAAK	2412DT052	500	MIXED	AMI	Yes	100%	179	0.6579132	0.213914	0.4439992	67.49%
4310	TPCODL	BBSR2	PED	PURI-I	KACHERI	14065	11 KV DOLAMANDAP	14065203	BHOG JAGA	2412DT055	500	MIXED	AMI	Yes	33%	130	0.28178496	0.173916	0.10786896	38.28%
4311	TPCODL	BBSR2	PED	PURI-I	KACHERI	14065	11 KV 11kV Duttatota	14065204	CHANDAN APARTMENT	2412DT060	100	MIXED	AMI	Yes	100%	17	0.00952659	0.005213	0.00431359	45.28%
4312	TPCODL	BBSR2	PED	PURI-I	KACHERI	14065	11 KV 11kV Duttatota	14065204	DHYANAMANDIR	2412DT061	500	MIXED	AMI	Yes	100%	64	0.11006888	0.095177	0.01489188	13.53%
4313	TPCODL	BBSR2	PED	PURI-I	KACHERI	14065	11 KV 11kV Duttatota	14065204	LIC COLONY	2412DT062	250	MIXED	AMI	Yes	67%	96	0.09899972	0.086447	0.01255272	12.68%
4314	TPCODL	BBSR2	PED	PURI-I	KACHERI	14065	11 KV 11kV Duttatota	14065204	CHURCH 1	2412DT064	500	MIXED	AMI	Yes	100%	190	0.19766984	0.164189	0.03348084	16.94%
4315	TPCODL	BBSR2	PED	PURI-I	KACHERI	14065	11 KV 11kV Duttatota	14065204	CHURCH 2	2412DT065	250	MIXED	AMI	Yes	100%	156	0.19855652	0.130302	0.06825452	34.38%
4316	TPCODL	BBSR2	PED	PURI-I	KACHERI	14065	11 KV 11kV Duttatota	14065204	LABANIKHIA 2	2412DT069	250	MIXED	AMI	Yes	100%	104	0.1745077	0.123597	0.0509107	29.17%
4317	TPCODL	BBSR2	PED	PURI-I	KACHERI	14065	11 KV 11kV Duttatota	14065204	LABANIKHIA	2412DT071	500	MIXED	AMI	Yes	100%	288	0.35774984	0.290295	0.06745484	18.86%
4318	TPCODL	BBSR2	PED	PURI-I	KACHERI	14065	11 KV 11kV Duttatota	14065204	TULSI APARTMENT	2412DT072	100	MIXED	AMI	Yes	100%	18	0.01150864	0.006995	0.00451364	39.22%
4319	TPCODL	BBSR2	PED	PURI-I	KACHERI	14065	11 KV 11kV Duttatota	14065204	AMALA CLUB 2	2412DT073	250	MIXED	AMI	Yes	0%	127	0.17190844	0.118058	0.05385044	31.33%
4320	TPCODL	BBSR2	PED	PURI-I	KACHERI	14065	11 KV 11kV Duttatota	14065204	BRAHMAN SAMITI	2412DT084	250	MIXED	AMI	Yes	100%	185	0.24109184	0.197441	0.04365084	18.11%
4321	TPCODL	BBSR2	PED	PURI-I	KACHERI	14065	11 KV 11kV Duttatota	14065204	BOARDING CHHAK	2412DT086	500	MIXED	AMI	Yes	100%	319	0.46065664	0.285586	0.17507064	38.00%
4322	TPCODL	BBSR2	PED	PURI-I	KACHERI	14065	11 KV 11kV Duttatota	14065204	BAREN PATTNAIK	2412DT087	250	MIXED	AMI	Yes	100%	171	0.24882552	0.208023	0.04080252	16.40%
4323	TPCODL	BBSR2	PED	PURI-I	KACHERI	14065	11 KV 11kV Duttatota	14065204	CLOCK ROAD (SATYA SAI SEVA SAMIT	2412DT088	500	MIXED	AMI	Yes	100%	152	0.28783256	0.204315	0.08351756	29.02%
4324	TPCODL	BBSR2	PED	PURI-I	KACHERI	14065	11 KV 11kV Duttatota	14065204	OPP COOL KIDZ	2412DT096	16	MIXED	AMI	Yes	100%	69	0.14103548	0.110981	0.03005448	21.31%
4325	TPCODL	BBSR2	PED	PURI-I	KACHERI	14065	11 KV 11kV Duttatota	14065204	SRIGURU APARTMENT	2412DT103	100	MIXED	AMI	Yes	100%	19	0.02518256	0.016796	0.00838656	33.30%
4326	TPCODL	BBSR2	PED	PURI-I	KACHERI	14065	11 KV 11kV Duttatota	14065204	VIP PLAZA	2412DT105	250	MIXED	AMI	Yes	100%	12	0.02990992	0.015228	0.01468192	49.09%
4327	TPCODL	BBSR2	PED	PURI-I	KACHERI	14065	11 KV 11kV Duttatota	14065204	NIRMAYA APARTMENT	2412DT109	250	MIXED	AMI	Yes	100%	27	0.01653312	0.014241	0.00229212	13.86%
4328	TPCODL	BBSR2	PED	PURI-I	KACHERI	14065	11 KV 11kV Duttatota	14065204	NILADEE APARTMENT	2412DT115	250	MIXED	AMI	Yes	100%	17	0.06764684	0.064642	0.00300484	4.44%
4329	TPCODL	BBSR2	PED	PURI-I	KACHERI	14065	11 KV 11kV Duttatota	14065204	HOSTEL NO 1	2412DT116	500	MIXED	AMI	Yes	100%	308	0.41442776	0.357007	0.05742076	13.86%
4330	TPCODL	BBSR2	PED	PURI-I	KACHERI	14065	11 KV 11kV Kacheri- Sri M	14065205	MARKET BACK SIDE	2413DT017	250	MIXED	AMI	Yes	100%	166	0.2759978	0.21253	0.0634678	23.00%
4331	TPCODL	BBSR2	PED	PURI-I	KACHERI	14065	11 KV 11kV Kacheri- Sri M	14065205	NILACHAL COMPLEX CSS	2413DT020	500	MIXED	AMI	Yes	100%	103	0.24889089	0.164852	0.08403889	33.77%
4332	TPCODL	BBSR2	PED	PURI-I	KACHERI	14065	11 KV 11kV Kacheri- Sri M	14065205	MARACHIKOTE LANE	2413DT022	250	MIXED	AMI	Yes	100%	161	0.29709704	0.145793	0.15130404	50.93%
4333	TPCODL	BBSR2	PED	PURI-I	KACHERI	14065	11 KV 11kV Kacheri- Sri M	14065205	SURYA COMPLEX CSS	2413DT023	500	MIXED	AMI	Yes	0%	206	0.33989788	0.320647	0.01925088	5.66%
4334	TPCODL	BBSR2	PED	PURI-I	KACHERI	14065	11 KV 11kV Sea Beach- U	14065206	BEACH POLICE STATION	2412DT117	500	MIXED	AMI	Yes	100%	31	0.18900912	0.095862	0.09314712	49.28%
4335	TPCODL	BBSR2	PED	PURI-I	KACHERI	14065	11 KV 11kV Sea Beach- U	14065206	CHADRA BINDU SWAPANAPURI	2414DT026	750	MIXED	AMI	Yes	0%	151	0.14822232	0.109419	0.03880332	26.18%
4336	TPCODL	BBSR2	PED	PURI-I	TALABANIA	14064	11 KV Talabania- Sri Mar	14064208	MUSICAL WATER FOUNTAIN	2413DT030	500	MIXED	AMI	Yes	100%	160	0.37246248	0.123345	0.24911748	66.88%
4337	TPCODL	BBSR2	PED	PURI-I	TALABANIA	14064	11 KV Talabania- Sri Mar	14064208	NILADRI COMPLEX BACKSIDE	2413DT039	250	MIXED	AMI	Yes	0%	205	0.33920248	0.16094	0.17826248	52.55%
4338	TPCODL	BBSR2	PED	PURI-I	TALABANIA	14064	11 KV Talabania- Sri Mar	14064208	BADU MAHAPATRA 01	2413DT045	100	MIXED	AMI	Yes	67%	98	0.09742568	0.059144	0.03828168	39.29%
4339	TPCODL	BBSR2	PED	PURI-I	TALABANIA	14064	11 KV Talabania- Sri Mar	14064208	BADU MAHAPATRA 02	2413DT046	250	MIXED	AMI	Yes	0%	316	0.45496776	0.245632	0.20933576	46.01%
4340	TPCODL	BBSR2	PED	PURI-I	TALABANIA	14064	11 KV Talabania- Sri Mar	14064208	DOLABEDIKONA CSS	2413DT077	750	MIXED	AMI	Yes	0%	116	0.18241288	0.107204	0.07520888	41.23%
4341	TPCODL	BBSR2	PED	PURI-II	42 MAUZA	14092	11 KV KALAPADA	14092204	UPPER BASANTA KUNDALA	3221DT201	100	MIXED	AMI	Yes	100%	32	0.01678176	0.0117	0.00508176	30.28%
4342	TPCODL	BBSR2	PED	PURI-II	BASUDEIPUR	14364	11 KV BASUDEIPUR	14364201	BASUDEIPUR	2424DT002	100	MIXED	AMI	Yes	100%	76	0.04185882	0.029603	0.01225582	29.28%
4343	TPCODL	BBSR2	PED	PURI-II	BASUDEIPUR	14364	11 KV BASUDEIPUR	14364201	KAMASASAN	2424DT006	100	MIXED	AMI	Yes	100%	120	0.04988594	0.036229	0.01365694	27.38%
4344	TPCODL	BBSR2	PED	PURI-II	BASUDEIPUR	14364	11 KV BASUDEIPUR	14364201	BALIPATNA	2424DT011	63	MIXED	AMI	Yes	100%	75	0.04302668	0.0222862	0.02074048	48.20%
4345	TPCODL	BBSR2	PED	PURI-II	BASUDEIPUR	14364	11 KV BASUDEIPUR	14364201	UTTARANA	2424DT017	100	MIXED	AMI	Yes	100%	117	0.04657836	0.033337	0.01324136	28.43%
4346	TPCODL	BBSR2	PED	PURI-II	BASUDEIPUR	14364	11 KV BASUDEIPUR	14364201	MATHA SAHI	2424DT020	100	MIXED	AMI	Yes	67%	66	0.03240564	0.019493	0.01291264	39.85%
4347	TPCODL	BBSR2	PED	PURI-II	BASUDEIPUR	14364	11 KV BASUDEIPUR	14364201	PODAKERA	2424DT027	100	MIXED	AMI	Yes	100%	94	0.0451545	0.020371	0.0247835	54.89%
4348	TPCODL	BBSR2	PED	PURI-II	BASUDEIPUR	14364	11 KV BASUDEIPUR	14364201	SWANTERA	2424DT035	100	MIXED	AMI	Yes	0%	73	0.03445762	0.017969	0.01648862	47.85%
4349	TPCODL	BBSR2	PED	PURI-II	BASUDEIPUR	14364	11 KV BASUDEIPUR	14364201	TANDI KERA	2424DT038	100	MIXED	AMI	Yes	100%	67	0.01906462	0.017801	0.00126362	6.63%
4350	TPCODL	BBSR2	PED	PURI-II	BASUDEIPUR	14364	11 KV BASUDEIPUR	14364201	JAGANNATH BIDYADHARPUR	2424DT046	100	MIXED	AMI	Yes	100%	184	0.08583618	0.055129	0.03070718	35.77%
4351	TPCODL	BBSR2	PED	PURI-II	BASUDEIPUR	14364	11 KV HANTUKA	14364202	HANTUKA DAKHINA SAHI	2424DT057	100	MIXED	AMI	Yes	67%	80	0.0927685	0.022499	0.0702695	75.75%
4352	TPCODL	BBSR2	PED	PURI-II	BASUDEIPUR	14364	11 KV HANTUKA	14364202	HANTUKA MAJHI SAHI	2424DT061	100	MIXED	AMI	Yes	67%	128	0.05479466	0.032098	0.02269666	41.42%
4353	TPCODL	BBSR2	PED	PURI-II	BASUDEIPUR	14364	11 KV HANTUKA	14364202	DHANIKERA	2424DT064	100	MIXED	AMI	Yes	67%	71	0.04432914	0.015026	0.02930314	66.10%
4354	TPCODL	BBSR2	PED	PURI-II	BASUDEIPUR	14364	11 KV KAPILESWARAPUR	14364203	KESKERA	2421DT278	100	MIXED	AMI	Yes	0%	103	0.03286018	0.031118	0.00174218	5.30%
4355	TPCODL	BBSR2	PED	PURI-II	BASUDEIPUR	14364	11 KV KAPILESWARAPUR	14364203	MAHARNA SAHI	2421DT281	100	MIXED	AMI	Yes	67%	92	0.10323044	0.025771	0.07745944	75.04%
4356	TPCODL	BBSR2	PED	PURI-II	BASUDEIPUR	14364	11 KV KAPILESWARAPUR	14364203	KAPILESHWERPUR - PART 4	2421DT285	100	MIXED	AMI	Yes	67%	152	0.1227588	0.04268	0.0800788	65.23%
4357	TPCODL	BBSR2	PED	PURI-II	BASUDEIPUR	14364	11 KV KAPILESWARAPUR	14364203	KAPILESHWERPUR PART 2	2421DT301	100	MIXED	AMI	Yes	67%	46	0.04415582	0.013116	0.03103982	70.30%
4358	TPCODL	BBSR2	PED	PURI-II	BASUDEIPUR	14364	11 KV KAPILESWARAPUR	14364203	KAPILESHWERPUR PART 1	2421DT303	100	MIXED	AMI	Yes	0%	78	0.05639768	0.014303	0.04209468	74.64%
4359	TPCODL	BBSR2	PED	PURI-II	BRAHMAGIRI	14068	11 KV BRAHMAGIRI-2	14068201	MANA PADA 1	2421DT038	100	MIXED	AMI	Yes	0%	59	0.05038018	0.014213	0.03616718	71.79%
4360	TPCODL	BBSR2	PED	PURI-II	BRAHMAGIRI	14068	11 KV ALARNATH	14068202	KATHUAREADY CHHAKA	2421DT070	250	MIXED	AMI	Yes	33%	160	0.19096152	0.06012246	0.13083906	68.52%
4361	TPCODL	BBSR2	PED	PURI-II	BRAHMAGIRI	14068	11 KV ALARNATH	14068202	COLLEGE CHHAKA	2421DT078	250	MIXED	AMI	Yes	33%	284	0.30561836	0.178218	0.12740036	41.69%
4362	TPCODL	BBSR2	PED	PURI-II	BRAHMAGIRI	14068	11 KV ALARNATH	14068202	BENTAPUR (1)	2421DT080	100	MIXED	AMI	Yes	100%	130	0.09262719	0.043372	0.04925519	53.18%
4363	TPCODL	BBSR2	PED	PURI-II	BRAHMAGIRI	14068	11 KV ALARNATH	14068202	BENTAPUR (2)	2421DT081	100	MIXED	AMI	Yes	67%	197	0.05970186	0.059104	0.00059786	1.00%
4364	TPCODL	BBSR2	PED	PURI-II	BRAHMAGIRI	14068	11 KV ALARNATH	14068202	CUTTAKPADA	2421DT082	100	MIXED	AMI	Yes	100%	155	0.09431152	0.052604	0.04170752	44.22%
4365	TPCODL	BBSR2	PED	PURI-II	BRAHMAGIRI	14068	11 KV ALARNATH	14068202	MARKET	2421DT090	250	MIXED	AMI	Yes	67%	299	0.28769376	0.163765	0.12392876	43.08%
4366	TPCODL	BBSR2	PED	PURI-II	BRAHMAGIRI	14068	11 KV ALARNATH	14068202	GOPA-1	2421DT094	500	MIXED	AMI	Yes	67%	289	0.2876798	0.109109	0.1785708	62.07%
4367	TPCODL	BBSR2	PED	PURI-II	BRAHMAGIRI	14068	11 KV ALARNATH	14068202	Gopa-2	2421DT095	200	MIXED	AMI	Yes	67%	140	0.14303104	0.051136	0.09189504	64.25%
4368	TPCODL	BBSR2	PED	PURI-II	BRAHMAGIRI	14068	11 KV ALARNATH	14068202	ALARPUR	2421DT097	250	MIXED	AMI	Yes	67%	184	0.19798204	0.078409	0.11957304	60.40%
4369	TPCODL	BBSR2	PED	PURI-II	BRAHMAGIRI	14068	11 KV ALARNATH	14068202	NEMA PADA BANK	2421DT100	100	MIXED	AMI	Yes	67%	123	0.128007	0.048962	0.079045	61.75%
4370	TPCODL	BBSR2	PED	PURI-II	BRAHMAGIRI	14068	11 KV ALARNATH	14068202	BAISI BATAI	2421DT102	100	MIXED	AMI	Yes	67%	86	0.05610491	0.027212	0.02889291	51.50%
4371	TPCODL	BBSR2	PED	PURI-II	BRAHMAGIRI	14068	11 KV ALARNATH	14068202	BRAHMAGIRI	2421DT109	250	MIXED	AMI	Yes	67%	215	0.23521224	0.077368	0.15784424	67.11%
4372	TPCODL	BBSR2	PED	PURI-II	BRAHMAGIRI	14068	11 KV PALANKA	14068203	CHANDI PUT VILLAGE -1	2421DT116	100	MIXED	AMI	Yes	67%	73	0.05787004	0.018	0.03987004	68.90%
4373	TPCODL	BBSR2	PED	PURI-II	BRAHMAGIRI	14068	11 KV PALANKA	14068203	BALABHADRA PATANA VILLAGE -1	2421DT129	100	MIXED	AMI	Yes	67%	121	0.02730352	0.01891	0.00839352	30.74%
4374	TPCODL	BBSR2	PED	PURI-II	BRAHMAGIRI	14068	11 KV PALANKA	14068203	NEAR NIYAZPUR VILLAGE	2421DT157	100	MIXED	AMI	Yes	0%	66	0.04539924	0.013742	0.03165724	69.73%
4375	TPCODL	BBSR2	PED	PURI-II	BRAHMAGIRI	14068	11 KV PALANKA	14068203	CHAPA MANIK VILLAGE PANCHAYAT	2421DT163	100	MIXED	AMI	Yes	67%	75	0.06344549	0.028728	0.03471749	54.72%
4376	TPCODL	BBSR2	PED	PURI-II	BRAHMAGIRI	14068	11 KV PALANKA	14068203	PALANK VILLAGE - 2	2421DT173	100	MIXED	AMI	Yes	67%	171	0.08881446	0.055085	0.03372946	37.98%
4377	TPCODL	BBSR2	PED	PURI-II	BRAHMAGIRI	14068	11 KV BASUDEIPUR	14068204	GAUDIAGHAI-1	2421DT222	100	MIXED	AMI	Yes	67%	53	0.06199612	0.015685	0.04631112	74.70%
4378	TPCODL	BBSR2	PED	PURI-II	BRAHMAGIRI	14068	11 KV BASUDEIPUR	14068204	DENG	2421DT232	100	MIXED	AMI	Yes	0%	24	0.05218622	0.01593	0.03625622	69.47%
4379	TPCODL	BBSR2	PED	PURI-II	BRAHMAGIRI	14068	11 KV BASUDEIPUR	14068204	AMBAPADA-1	2421DT237	100	MIXED	AMI	Yes	67%	85	0.04250634	0.037282	0.00522434	12.29%

Sl. No.	Zone Name	Circle name	Division name	Name of the Sub-division	Name of the Sub-station	Substation Code	Name of the 11 kV Feeder	Feeder Code	Name of the Location where DT situated	DT code	DT Capacity (kVA)	Predominant consumer type of DT (Domestic/Industrial/Agriculture/Mixed)	Type of metering AMR/AMI/ Communicable/Conventional metered/Unmetered	Status of Meter- whether Functional (Yes/No)	% of data received automatically (if AMR/AMI)	No. of Connected Consumers	Input Energy (MU) (A)	Billed Energy (MU) (B)	Loss (MU) (A-B)	% DT Loss (A-B)/A
4380	TPCODL	BBSR2	PED	PURI-II	BRAHMAGIRI	14068	11 KV REBANA	14068205	REBNA BALIPAKHORI	2421DT182	100	MIXED	AMI	Yes	67%	124	0.03521112	0.030298	0.00491312	13.95%
4381	TPCODL	BBSR2	PED	PURI-II	BRAHMAGIRI	14068	11 KV REBANA	14068205	NUAGAON-3	2421DT190	100	MIXED	AMI	Yes	67%	92	0.07127648	0.02505155	0.04622493	64.85%
4382	TPCODL	BBSR2	PED	PURI-II	CHANDANPUR	14071	11 KV BALABHADRAPUR	14071203	TULASI CHAURA-2	2441DT204	100	MIXED	AMI	Yes	100%	25	0.07636368	0.043503	0.03286068	43.03%
4383	TPCODL	BBSR2	PED	PURI-II	CHARINALA	14067	11 KV HAREKRUSHNAPU	14067203	TALAJANG	2424DT115	100	MIXED	AMI	Yes	67%	70	0.04578642	0.023272	0.02251442	49.17%
4384	TPCODL	BBSR2	PED	PURI-II	CHARINALA	14067	11 KV HAREKRUSHNAPU	14067203	JAGANNATH CHOWK	2424DT137	100	MIXED	AMI	Yes	67%	87	0.06111028	0.04309	0.01802028	29.49%
4385	TPCODL	BBSR2	PED	PURI-II	CHARINALA	14067	11 KV HAREKRUSHNAPU	14067203	HAREKRISHNAPUR BAZAR	2431DT035	250	MIXED	AMI	Yes	0%	130	0.10376956	0.074629	0.02914056	28.08%
4386	TPCODL	BBSR2	PED	PURI-II	DELANGA	14073	11 KV DELANGA	14073201	RAMACHANDRAPUR 2	2422DT069	100	MIXED	AMI	Yes	0%	100	0.09956394	0.071848	0.02771594	27.84%
4387	TPCODL	BBSR2	PED	PURI-II	DELANGA	14073	11 KV DELANGA	14073201	ROUT SAHI	2422DT075	100	MIXED	AMI	Yes	67%	28	0.02634398	0.012263	0.01408098	53.45%
4388	TPCODL	BBSR2	PED	PURI-II	DELANGA	14073	11 KV DELANGA	14073201	RENCHA KATA NO.2	2422DT089	100	MIXED	AMI	Yes	67%	50	0.04435352	0.024368	0.01998552	45.06%
4389	TPCODL	BBSR2	PED	PURI-II	DELANGA	14073	11 KV DELANGA	14073201	REANCHA	2422DT094	100	MIXED	AMI	Yes	0%	146	0.05716824	0.04561224	0.011556	20.21%
4390	TPCODL	BBSR2	PED	PURI-II	DELANGA	14073	11 KV DELANGA	14073201	PALI	2422DT106	100	MIXED	AMI	Yes	0%	69	0.03329356	0.01911	0.01418356	42.60%
4391	TPCODL	BBSR2	PED	PURI-II	DELANGA	14073	11 KV DELANGA	14073201	BRAMAHANTARO BOI	2422DT108	100	MIXED	AMI	Yes	67%	98	0.05106832	0.031682	0.01938632	37.96%
4392	TPCODL	BBSR2	PED	PURI-II	DELANGA	14073	11 KV DELANGA	14073201	ARISAL	2422DT131	100	MIXED	AMI	Yes	0%	67	0.06873074	0.020357	0.04837374	70.38%
4393	TPCODL	BBSR2	PED	PURI-II	DELANGA	14073	11 KV DELANGA	14073201	DELANGA POLICE STATION	2422DT141	100	MIXED	AMI	Yes	0%	6	0.01582998	0.009565	0.00626498	39.58%
4394	TPCODL	BBSR2	PED	PURI-II	DELANGA	14073	11 KV DELANGA	14073201	BEROBOI ANDHRA BANK	2422DT158	100	MIXED	AMI	Yes	0%	70	0.0873929	0.034496	0.0528969	60.53%
4395	TPCODL	BBSR2	PED	PURI-II	DELANGA	14073	11 KV DELANGA	14073201	BERO BOI	2422DT159	100	MIXED	AMI	Yes	0%	57	0.08404386	0.025352	0.05869186	69.83%
4396	TPCODL	BBSR2	PED	PURI-II	DELANGA	14073	11 KV DELANGA	14073201	BEROBOI	2422DT161	100	MIXED	AMI	Yes	67%	81	0.12313079	0.02729	0.09584079	77.84%
4397	TPCODL	BBSR2	PED	PURI-II	DELANGA	14073	11 KV DELANGA	14073201	SEBAKASAHI PATANA	2422DT177	100	MIXED	AMI	Yes	67%	75	0.03543298	0.02489	0.01054298	29.75%
4398	TPCODL	BBSR2	PED	PURI-II	DELANGA	14073	11 KV DELANGA	14073201	BIDRURAPUR NEAR SCHOOL	2422DT181	100	MIXED	AMI	Yes	67%	93	0.0566513	0.021761	0.0348903	61.59%
4399	TPCODL	BBSR2	PED	PURI-II	DELANGA	14073	11 KV DELANGA	14073201	CHITALPUR, DHIAPUR	2422DT192	100	MIXED	AMI	Yes	67%	70	0.02642822	0.01719	0.00923822	34.96%
4400	TPCODL	BBSR2	PED	PURI-II	DELANGA	14073	11 KV DELANGA	14073201	GUALIPADA (BADA)	2422DT227	100	MIXED	AMI	Yes	0%	79	0.06029232	0.020183	0.04010932	66.52%
4401	TPCODL	BBSR2	PED	PURI-II	DELANGA	14073	11 KV DELANGA	14073201	GUDUPAILI	2422DT234	100	MIXED	AMI	Yes	67%	132	0.04891832	0.023556	0.02536232	51.85%
4402	TPCODL	BBSR2	PED	PURI-II	DELANGA	14073	11 KV DELANGA	14073201	THANTANA	2422DT243	100	MIXED	AMI	Yes	0%	88	0.03727912	0.018765	0.01851412	49.66%
4403	TPCODL	BBSR2	PED	PURI-II	DELANGA	14073	11 KV DELANGA	14073201	MACHHAPADA	2422DT245	100	MIXED	AMI	Yes	67%	118	0.04441512	0.023491	0.02092412	47.11%
4404	TPCODL	BBSR2	PED	PURI-II	DELANGA	14073	11 KV DELANGA	14073201	SRI PURASTAMPUR BRAMAHANPADA	2422DT251	100	MIXED	AMI	Yes	67%	94	0.04970768	0.024809	0.02489868	50.09%
4405	TPCODL	BBSR2	PED	PURI-II	DELANGA	14073	11 KV DELANGA	14073201	KUNJARA	2422DT257	100	MIXED	AMI	Yes	67%	97	0.03348948	0.023747	0.00974248	29.09%
4406	TPCODL	BBSR2	PED	PURI-II	DELANGA	14073	11 KV DELANGA	14073201	DASABIDYADHARPUR SASANA -1	2422DT261	100	MIXED	AMI	Yes	67%	133	0.0687679	0.03744016	0.03132774	45.56%
4407	TPCODL	BBSR2	PED	PURI-II	DELANGA	14073	11 KV GHORADIA	14073202	JAGADALPUR	2422DT283	250	MIXED	AMI	Yes	0%	133	0.11072188	0.033094	0.07762788	70.11%
4408	TPCODL	BBSR2	PED	PURI-II	DELANGA	14073	11 KV GHORADIA	14073202	BAYA BAZAR	2422DT314	100	MIXED	AMI	Yes	0%	84	0.0558439	0.046559	0.0092849	16.63%
4409	TPCODL	BBSR2	PED	PURI-II	DELANGA	14073	11 KV GHORADIA	14073202	PURANA DELANG 1	2422DT317	100	MIXED	AMI	Yes	0%	67	0.0342315	0.020771	0.0134605	39.32%
4410	TPCODL	BBSR2	PED	PURI-II	DELANGA	14073	11 KV GHORADIA	14073202	DAKAPADA 1	2422DT322	100	MIXED	AMI	Yes	67%	68	0.05511234	0.032489	0.02262334	41.05%
4411	TPCODL	BBSR2	PED	PURI-II	DELANGA	14073	11 KV GHORADIA	14073202	BOLAKANA 1	2422DT332	100	MIXED	AMI	Yes	0%	119	0.07243102	0.019257	0.05317402	73.41%
4412	TPCODL	BBSR2	PED	PURI-II	DELANGA	14073	11 KV GHORADIA	14073202	MANJIPUR 1	2422DT334	100	MIXED	AMI	Yes	0%	93	0.07020388	0.024089	0.04611488	65.69%
4413	TPCODL	BBSR2	PED	PURI-II	DELANGA	14073	11 KV GHORADIA	14073202	BENUPADA 1	2422DT337	100	MIXED	AMI	Yes	0%	81	0.07463604	0.02331	0.05132604	68.77%
4414	TPCODL	BBSR2	PED	PURI-II	DELANGA	14073	11 KV GHORADIA	14073202	BELAPADA	2422DT348	100	MIXED	AMI	Yes	0%	92	0.02627002	0.01782006	0.00844996	32.17%
4415	TPCODL	BBSR2	PED	PURI-II	DELANGA	14073	11 KV GHORADIA	14073202	BELAPADA	2422DT350	100	MIXED	AMI	Yes	67%	29	0.0097744	0.00509542	0.00467898	47.87%
4416	TPCODL	BBSR2	PED	PURI-II	DELANGA	14073	11 KV GHORADIA	14073202	BADA AANKULA	2422DT354	100	MIXED	AMI	Yes	0%	102	0.06479492	0.02575144	0.03904348	60.26%
4417	TPCODL	BBSR2	PED	PURI-II	DELANGA	14073	11 KV GHORADIA	14073202	BATOLA UPAREA SAHI	2422DT368	100	MIXED	AMI	Yes	67%	78	0.03721732	0.01917	0.01804732	48.49%
4418	TPCODL	BBSR2	PED	PURI-II	DELANGA	14073	11 KV GHORADIA	14073202	KANLAPADA	2422DT375	100	MIXED	AMI	Yes	67%	72	0.03783936	0.021116	0.01672336	44.20%
4419	TPCODL	BBSR2	PED	PURI-II	DELANGA	14073	11 KV GHORADIA	14073202	OU PADA	2422DT377	100	MIXED	AMI	Yes	67%	112	0.03511774	0.025365	0.00975274	27.77%
4420	TPCODL	BBSR2	PED	PURI-II	DELANGA	14073	11 KV GHORADIA	14073202	GORADIA NEAR PRIMARY SCHOOL	2422DT382	100	MIXED	AMI	Yes	67%	193	0.07848368	0.042644	0.03583968	45.67%
4421	TPCODL	BBSR2	PED	PURI-II	DELANGA	14073	11 KV GHORADIA	14073202	KUMUDHALA	2422DT387	100	MIXED	AMI	Yes	0%	79	0.0377003	0.022406	0.0152943	40.57%
4422	TPCODL	BBSR2	PED	PURI-II	DELANGA	14073	11 KV GHORADIA	14073202	BATOLA UPARA SAHI	2422DT390	100	MIXED	AMI	Yes	33%	49	0.02754066	0.015288	0.01225266	44.49%
4423	TPCODL	BBSR2	PED	PURI-II	DELANGA	14073	11 KV GHORADIA	14073202	BAT JENA SAHI	2422DT399	100	MIXED	AMI	Yes	67%	101	0.04817084	0.026191	0.02197984	45.63%
4424	TPCODL	BBSR2	PED	PURI-II	DELANGA	14073	11 KV GHORADIA	14073202	PMU BRAMANO SAHI	2422DT400	100	MIXED	AMI	Yes	67%	171	0.07830808	0.042605	0.03570308	45.59%
4425	TPCODL	BBSR2	PED	PURI-II	DELANGA	14073	11 KV GHORADIA	14073202	GHANIPUR DESI	2422DT401	100	MIXED	AMI	Yes	0%	74	0.04095574	0.017144	0.02381174	58.14%
4426	TPCODL	BBSR2	PED	PURI-II	DELANGA	14073	11 KV GHORADIA	14073202	POCHAR PADA	2422DT408	100	MIXED	AMI	Yes	67%	115	0.09186358	0.029951	0.06191258	67.40%
4427	TPCODL	BBSR2	PED	PURI-II	DELANGA	14073	11 KV MAA GELA BAI	14073203	NEAR TPCODL OFFICE (DELANGA)	2422DT419	100	MIXED	AMI	Yes	100%	41	0.04202073	0.013874	0.02814673	66.98%
4428	TPCODL	BBSR2	PED	PURI-II	DELANGA	14073	11 KV MAA GELA BAI	14073203	RAMCHANDRAPUR 1	2422DT451	100	MIXED	AMI	Yes	0%	70	0.0527748	0.029352	0.0234228	44.38%
4429	TPCODL	BBSR2	PED	PURI-II	DELANGA	14073	11 KV MAA GELA BAI	14073203	BANKILO	2422DT458	100	MIXED	AMI	Yes	100%	77	0.03401318	0.018891	0.01512218	44.46%
4430	TPCODL	BBSR2	PED	PURI-II	HEMSURPADA	14187	11 KV HEMSURPADA	14187201	BHANDUBAR COLONY	4211DT010	250	MIXED	AMI	Yes	0%	294	0.33465192	0.331602	0.00304992	0.91%
4431	TPCODL	BBSR2	PED	PURI-II	JAIL ROAD (SAMAN(	14291	11 KV Koilada	14291201	NUA PATANA	2421DT365	100	MIXED	AMI	Yes	100%	62	0.08023696	0.0307	0.04953696	61.74%
4432	TPCODL	BBSR2	PED	PURI-II	JAIL ROAD (SAMAN(	14291	11 KV Koilada	14291201	GOLA SAHI	2424DT074	100	MIXED	AMI	Yes	100%	332	0.10832542	0.084512	0.02381342	21.98%
4433	TPCODL	BBSR2	PED	PURI-II	JAIL ROAD (SAMAN(	14291	11 KV Koilada	14291201	KORUA	2424DT080	100	MIXED	AMI	Yes	33%	95	0.05116592	0.03254	0.01862592	36.40%
4434	TPCODL	BBSR2	PED	PURI-II	JAIL ROAD (SAMAN(	14291	11 KV Koilada	14291201	OXY GREEN APARTMENT PRIVATE	2424DT086	315	MIXED	AMI	Yes	100%	43	0.00566008	0.002566	0.00309408	54.66%
4435	TPCODL	BBSR2	PED	PURI-II	JAIL ROAD (SAMAN(	14291	11 KV Koilada	14291201	REWATI RAMAN MAHAGIRI NEAR 1	2424DT088	100	MIXED	AMI	Yes	100%	60	0.04303636	0.026977	0.01605936	37.32%
4436	TPCODL	BBSR2	PED	PURI-II	JAIL ROAD (SAMAN(	14291	11 KV Koilada	14291201	KANTHAPUR VILLAGE	2424DT091	250	MIXED	AMI	Yes	100%	353	0.25785108	0.166377	0.09147408	35.48%
4437	TPCODL	BBSR2	PED	PURI-II	JAIL ROAD (SAMAN(	14291	11 KV Koilada	14291201	KHARI PADA VILLAGE	2424DT094	100	MIXED	AMI	Yes	100%	94	0.07729774	0.05563	0.02166774	28.03%
4438	TPCODL	BBSR2	PED	PURI-II	JAIL ROAD (SAMAN(	14291	11 KV Koilada	14291201	REWATI RAMAN	2424DT096	100	MIXED	AMI	Yes	100%	58	0.03721116	0.02619966	0.0110115	29.59%
4439	TPCODL	BBSR2	PED	PURI-II	JAIL ROAD (SAMAN(	14291	11 KV Koilada	14291201	BADA PAIKA SAHI	2424DT108	100	MIXED	AMI	Yes	100%	79	0.05903604	0.027753	0.03128304	52.99%
4440	TPCODL	BBSR2	PED	PURI-II	JAIL ROAD (SAMAN(	14291	11 KV Koilada	14291201	NARA HARIPUR	2424DT110	100	MIXED	AMI	Yes	100%	130	0.09697772	0.053629	0.04334872	44.70%
4441	TPCODL	BBSR2	PED	PURI-II	KALAYANPUR ODSS	14294	11 KV KALYANPUR	14294202	KALYANAPUR BAZAR 2	2422DT027	100	MIXED	AMI	Yes	67%	69	0.0411713	0.029027	0.0121443	29.50%
4442	TPCODL	BBSR2	PED	PURI-II	KALAYANPUR ODSS	14294	11 KV KALYANPUR	14294202	KALAYANPUR MELANPADIA	2422DT028	100	MIXED	AMI	Yes	67%	121	0.04714972	0.031455	0.01569472	33.29%
4443	TPCODL	BBSR2	PED	PURI-II	KALAYANPUR ODSS	14294	11 KV KALYANPUR	14294202	KALAYANPUR POKHARI SAHI	2422DT029	100	MIXED	AMI	Yes	67%	88	0.04191256	0.028441	0.01347156	32.14%
4444	TPCODL	BBSR2	PED	PURI-II	KALAYANPUR ODSS	14294	11 KV KALYANPUR	14294202	NUAHATA 2	2422DT033	100	MIXED	AMI	Yes	0%	27	0.02956268	0.007264	0.02229868	75.43%
4445	TPCODL	BBSR2	PED	PURI-II	KALAYANPUR ODSS	14294	11 KV KALYANPUR	14294202	BAISHUNKA	2422DT035	100	MIXED	AMI	Yes	0%	159	0.07194096	0.041955	0.02998596	41.68%
4446	TPCODL	BBSR2	PED	PURI-II	KALAYANPUR ODSS	14294	11 KV KALYANPUR	14294202	SISUAPADA	2422DT036	100	MIXED	AMI	Yes	67%	87	0.03672244	0.023009	0.01371344	37.34%
4447	TPCODL	BBSR2	PED	PURI-II	KALAYANPUR ODSS	14294	11 KV KALYANPUR	14294202	BADAPUR BARODA	2422DT043	100	MIXED	AMI	Yes	67%	23	0.01567866	0.004727	0.01095166	69.85%
4448	TPCODL	BBSR2	PED	PURI-II	KALAYANPUR ODSS	14294	11 KV KALYANPUR	14294202	RADHUA	2422DT048	100	MIXED	AMI	Yes	67%	92	0.040172	0.021981	0.018191	45.28%
4449	TPCODL	BBSR2	PED	PURI-II	KALAYANPUR ODSS	14294	11 KV KALYANPUR	14294202	KANTAPADA	2422DT050	100	MIXED	AMI	Yes	0%	168	0.0522539	0.036406	0.0158479	30.33%
4450	TPCODL	BBSR2	PED	PURI-II	KALAYANPUR ODSS	14294	11 KV KALYANPUR	14294202	BIRAKISHORPUR	2422DT063	100	MIXED	AMI	Yes	0%	27	0.01255988	0.006557	0.00600288	47.79%
4451	TPCODL	BBSR2	PED	PURI-II	KANASA	14074	11 KV KANASA	14074201	BALIGAI CHAKKA 2	2423DT004	100	MIXED	AMI	Yes	67%	142	0.09770536	0.030725	0.06698036	68.55%
4452	TPCODL	BBSR2	PED	PURI-II	KANASA	14074	11 KV KANASA	14074201	BALIGAI CHAKKA 1	2423DT005	250	MIXED	AMI	Yes	67%	114	0.12039776	0.026338	0.09405976	78.12%

Sl. No.	Zone Name	Circle name	Division name	Name of the Sub-division	Name of the Sub-station	Substation Code	Name of the 11 kV Feeder	Feeder Code	Name of the Location where DT situated	DT code	DT Capacity (kVA)	Predominant consumer type of DT (Domestic/Industrial/Agriculture/Mixed)	Type of metering AMR/AMI/ Communicable/Conventional metered/Unmetered	Status of Meter-whether Functional (Yes/No)	% of data received automatically (if AMR/AMI)	No. of Connected Consumers	Input Energy (MU) (A)	Billed Energy (MU) (B)	Loss (MU) (A-B)	% DT Loss (A-B)/A
4453	TPCODL	BBSR2	PED	PURI-II	KANASA	14074	11 KV KANASA	14074201	KUNNJARISWARI 1	2423DT006	250	MIXED	AMI	Yes	67%	89	0.15562204	0.045596	0.11002604	70.70%
4454	TPCODL	BBSR2	PED	PURI-II	KANASA	14074	11 KV KANASA	14074201	DOKANDA 1	2423DT011	100	MIXED	AMI	Yes	0%	102	0.03560138	0.027087	0.00851438	23.92%
4455	TPCODL	BBSR2	PED	PURI-II	KANASA	14074	11 KV KANASA	14074201	BADAS 2	2423DT019	100	MIXED	AMI	Yes	67%	79	0.0473694	0.02251	0.0248594	52.48%
4456	TPCODL	BBSR2	PED	PURI-II	KANASA	14074	11 KV KANASA	14074201	BALIPATNA	2423DT030	100	MIXED	AMI	Yes	67%	124	0.04050866	0.021	0.01950866	48.16%
4457	TPCODL	BBSR2	PED	PURI-II	KANASA	14074	11 KV KANASA	14074201	BHATAPADA	2423DT040	100	MIXED	AMI	Yes	67%	107	0.06699976	0.038384	0.02861576	42.71%
4458	TPCODL	BBSR2	PED	PURI-II	KANASA	14074	11 KV KANASA	14074201	PADIAKARA	2423DT043	100	MIXED	AMI	Yes	67%	87	0.0347656	0.023817	0.0109486	31.49%
4459	TPCODL	BBSR2	PED	PURI-II	KANASA	14074	11 KV KANASA	14074201	NANAKARA 1	2423DT059	100	MIXED	AMI	Yes	67%	126	0.05014274	0.028357921	0.021784819	43.45%
4460	TPCODL	BBSR2	PED	PURI-II	KANASA	14074	11 KV KANASA	14074201	RANIPADA	2423DT078	100	MIXED	AMI	Yes	67%	100	0.05501808	0.031813	0.02320508	42.18%
4461	TPCODL	BBSR2	PED	PURI-II	KANASA	14074	11 KV KANASA	14074201	RANIPADA 2	2423DT088	63	MIXED	AMI	Yes	67%	90	0.05741564	0.024891	0.03252464	56.65%
4462	TPCODL	BBSR2	PED	PURI-II	KANASA	14074	11 KV KANASA	14074201	SHARI 1	2423DT089	100	MIXED	AMI	Yes	67%	132	0.07960564	0.036814	0.04279164	53.75%
4463	TPCODL	BBSR2	PED	PURI-II	KANASA	14074	11 KV KANASA	14074201	SHARI 3	2423DT093	100	MIXED	AMI	Yes	67%	111	0.0741661	0.02909	0.0450761	60.78%
4464	TPCODL	BBSR2	PED	PURI-II	KANASA	14074	11 KV KANASA	14074201	NUASAHI	2423DT096	100	MIXED	AMI	Yes	67%	89	0.02970188	0.023975	0.00572688	19.28%
4465	TPCODL	BBSR2	PED	PURI-II	KANASA	14074	11 KV KANASA	14074201	SAHANA 1	2423DT099	100	MIXED	AMI	Yes	0%	97	0.08181136	0.043915	0.03789636	46.32%
4466	TPCODL	BBSR2	PED	PURI-II	KANASA	14074	11 KV KARAMALA	14074202	GADAPODA SCHOOL	2423DT103	100	MIXED	AMI	Yes	67%	82	0.03969776	0.021335	0.01836276	46.26%
4467	TPCODL	BBSR2	PED	PURI-II	KANASA	14074	11 KV KARAMALA	14074202	NUADOKANDA	2423DT104	100	MIXED	AMI	Yes	67%	131	0.04122056	0.030485	0.01073556	26.04%
4468	TPCODL	BBSR2	PED	PURI-II	KANASA	14074	11 KV KARAMALA	14074202	BENAGAN	2423DT113	100	MIXED	AMI	Yes	33%	109	0.03732281	0.030374	0.00694881	18.62%
4469	TPCODL	BBSR2	PED	PURI-II	KANASA	14074	11 KV KARAMALA	14074202	JAKIA GADASAHI	2423DT124	100	MIXED	AMI	Yes	67%	65	0.06523906	0.035721	0.02951806	45.25%
4470	TPCODL	BBSR2	PED	PURI-II	KANASA	14074	11 KV KARAMALA	14074202	JAKIA GADASAHU	2423DT127	100	MIXED	AMI	Yes	67%	123	0.05551724	0.029745	0.02577224	46.42%
4471	TPCODL	BBSR2	PED	PURI-II	KANASA	14074	11 KV KARAMALA	14074202	NABADA	2423DT174	100	MIXED	AMI	Yes	67%	78	0.02422836	0.015567	0.00866136	35.75%
4472	TPCODL	BBSR2	PED	PURI-II	KANASA	14074	11 KV KARAMALA	14074202	KAHNDAGADA	2423DT177	100	MIXED	AMI	Yes	67%	96	0.03745534	0.01758	0.01987534	53.06%
4473	TPCODL	BBSR2	PED	PURI-II	KANASA	14074	11 KV KARAMALA	14074202	BASANTAPUR	2423DT208	100	MIXED	AMI	Yes	67%	81	0.0302236	0.01521573	0.01500787	49.66%
4474	TPCODL	BBSR2	PED	PURI-II	KANASA	14074	11 KV KARAMALA	14074202	GADISAGADA	2423DT243	100	MIXED	AMI	Yes	0%	120	0.0467105	0.028846	0.0178645	38.25%
4475	TPCODL	BBSR2	PED	PURI-II	KANASA	14074	11 KV KARAMALA	14074202	KALAPADARA 2	2423DT253	100	MIXED	AMI	Yes	67%	59	0.04431732	0.01499	0.02932732	66.18%
4476	TPCODL	BBSR2	PED	PURI-II	KANASA	14074	11 KV KARAMALA	14074202	PAIKAMARA	2423DT262	100	MIXED	AMI	Yes	67%	85	0.04632296	0.014657	0.03166596	68.36%
4477	TPCODL	BBSR2	PED	PURI-II	KANASA	14074	11 KV KARAMALA	14074202	SAHASAPUR	2423DT280	100	MIXED	AMI	Yes	67%	115	0.07619608	0.023941	0.05225508	68.58%
4478	TPCODL	BBSR2	PED	PURI-II	KANASA	14074	11 KV KARAMALA	14074202	NUAGAN	2423DT289	100	MIXED	AMI	Yes	67%	102	0.05124516	0.020468	0.03077716	60.06%
4479	TPCODL	BBSR2	PED	PURI-II	KANASA	14074	11 KV KARAMALA	14074202	CHUPURING 1	2423DT323	100	MIXED	AMI	Yes	67%	50	0.0418697	0.017641	0.0242287	57.87%
4480	TPCODL	BBSR2	PED	PURI-II	KANASA	14074	11 KV KARAMALA	14074202	PAHILUNDI 2	2423DT330	100	MIXED	AMI	Yes	67%	98	0.03040172	0.01862	0.01178172	38.75%
4481	TPCODL	BBSR2	PED	PURI-II	KANASA	14074	11 KV KARAMALA	14074202	BALABHADRAPUR SCHOOL	2423DT346	100	MIXED	AMI	Yes	67%	67	0.05649478	0.015729	0.04076578	72.16%
4482	TPCODL	BBSR2	PED	PURI-II	KANASA	14074	11 KV JAGANNATHPUR	14074203	POSIAPADA 2	2423DT359	100	MIXED	AMI	Yes	67%	107	0.04691336	0.028585	0.01832836	39.07%
4483	TPCODL	BBSR2	PED	PURI-II	KANASA	14074	11 KV JAGANNATHPUR	14074203	JANGHAR 2	2423DT363	100	MIXED	AMI	Yes	67%	69	0.03381946	0.014786	0.01903346	56.28%
4484	TPCODL	BBSR2	PED	PURI-II	KANASA	14074	11 KV JAGANNATHPUR	14074203	NALIBASHANTA OLIC	2423DT387	100	MIXED	AMI	Yes	0%	6	0.00729562	0.001801	0.00549462	75.31%
4485	TPCODL	BBSR2	PED	PURI-II	KANASA	14074	11 KV JAGANNATHPUR	14074203	EKARUKHA	2423DT397	100	MIXED	AMI	Yes	67%	103	0.04161944	0.0271	0.01451944	34.89%
4486	TPCODL	BBSR2	PED	PURI-II	KANASA	14074	11 KV JAGANNATHPUR	14074203	DETHIAPADA	2423DT398	100	MIXED	AMI	Yes	67%	70	0.02823048	0.014709	0.01352148	47.90%
4487	TPCODL	BBSR2	PED	PURI-II	KANASA	14074	11 KV JAGANNATHPUR	14074203	NUAGANHA	2423DT401	100	MIXED	AMI	Yes	67%	81	0.03139633	0.016429	0.01496733	47.67%
4488	TPCODL	BBSR2	PED	PURI-II	KANASA	14074	11 KV JAGANNATHPUR	14074203	NANDIGADA 2	2423DT451	100	MIXED	AMI	Yes	67%	66	0.03777316	0.014097	0.02367616	62.68%
4489	TPCODL	BBSR2	PED	PURI-II	KANASA	14074	11 KV JAGANNATHPUR	14074203	JAGANNATHPUR	2423DT453	100	MIXED	AMI	Yes	67%	75	0.03511682	0.01634	0.01877682	53.47%
4490	TPCODL	BBSR2	PED	PURI-II	KANASA	14074	11 KV JAGANNATHPUR	14074203	JHAREDA	2423DT459	100	MIXED	AMI	Yes	0%	69	0.02311102	0.015308	0.00780302	33.76%
4491	TPCODL	BBSR2	PED	PURI-II	KANASA	14074	11 KV JAGANNATHPUR	14074203	ANDALANSINGH 2	2423DT526	100	MIXED	AMI	Yes	67%	81	0.03841022	0.022923	0.01548722	40.32%
4492	TPCODL	BBSR2	PED	PURI-II	KANASA	14074	11 KV JAGANNATHPUR	14074203	PASIAPADA 2	2423DT552	100	MIXED	AMI	Yes	67%	66	0.02509974	0.017498	0.00760174	30.29%
4493	TPCODL	BBSR2	PED	PURI-II	KHAJURIA	14225	11 KV KHAJURIA	14225201	KHAJURIA TOWER	2421DT383	25	MIXED	AMI	Yes	67%	88	0.04406384	0.018517	0.02554684	57.98%
4494	TPCODL	BBSR2	PED	PURI-II	KHAJURIA	14225	11 KV KHAJURIA	14225201	SUJANPUR1	2421DT399	100	MIXED	AMI	Yes	0%	50	0.01905764	0.005641	0.01341664	70.40%
4495	TPCODL	BBSR2	PED	PURI-II	KHAJURIA	14225	11 KV TALAMALA	14225202	CHHOTAPUR	2421DT564	100	MIXED	AMI	Yes	67%	108	0.06093828	0.017197	0.04374128	71.78%
4496	TPCODL	BBSR2	PED	PURI-II	KHAJURIA	14225	11 KV TALAMALA	14225202	RANAPADA	2421DT567	100	MIXED	AMI	Yes	67%	94	0.04730306	0.014826	0.03247706	68.66%
4497	TPCODL	BBSR2	PED	PURI-II	NAUGAON	14194	11 KV NAUGAON HQ	14194204	NEAR NAUGAON MARKET	5313DT021	500	MIXED	AMI	Yes	100%	371	0.2744308	0.21958	0.0548508	19.99%
4498	TPCODL	BBSR2	PED	PURI-II	PANASPADA ODSSP	14290	11 KV PANASPADA	14290201	GABA KUNDA	2425DT025	100	MIXED	AMI	Yes	67%	116	0.05985262	0.036432	0.02342062	39.13%
4499	TPCODL	BBSR2	PED	PURI-II	PANASPADA ODSSP	14290	11 KV PANASPADA	14290201	KAZIBHOI SAHI	2425DT042	100	MIXED	AMI	Yes	67%	82	0.02816436	0.016963	0.01120136	39.77%
4500	TPCODL	BBSR2	PED	PURI-II	PANASPADA ODSSP	14290	11 KV SATAPADA(Panasp	14290202	ALUPATANA 1	2425DT390	250	MIXED	AMI	Yes	67%	253	0.1643246	0.060245	0.1040796	63.34%
4501	TPCODL	BBSR2	PED	PURI-II	PANASPADA ODSSP	14290	11 KV SATAPADA(Panasp	14290202	BALABHADRAPUR	2425DT402	100	MIXED	AMI	Yes	0%	108	0.05186422	0.030121	0.02174322	41.92%
4502	TPCODL	BBSR2	PED	PURI-II	PANASPADA ODSSP	14290	11 KV SATAPADA(Panasp	14290202	SATAPADA BAZAR	2425DT405	100	MIXED	AMI	Yes	0%	23	0.02922312	0.007688	0.02153512	73.69%
4503	TPCODL	BBSR2	PED	PURI-II	PANASPADA ODSSP	14290	11 KV SATAPADA(Panasp	14290202	MERJAPUR 1	2425DT417	100	MIXED	AMI	Yes	0%	49	0.06843706	0.02002	0.04841706	70.75%
4504	TPCODL	BBSR2	PED	PURI-II	PANASPADA ODSSP	14290	11 KV SATAPADA(Panasp	14290202	MERJAPUR 2	2425DT418	100	MIXED	AMI	Yes	0%	140	0.04594068	0.03833778	0.0076029	16.55%
4505	TPCODL	BBSR2	PED	PURI-II	RAHAMA	14177	11 KV RAHAMA	14177201	TRITOL 3	5413DT096	100	MIXED	AMI	Yes	100%	180	0.09039452	0.080374	0.01002052	11.09%
4506	TPCODL	BBSR2	PED	PURI-II	SRI RAM NAGAR	14070	11 KV 11kV PKRIT	14070201	THE SWAN REGALE	2424DT162	250	MIXED	AMI	Yes	100%	34	0.00889928	0.005731	0.00316828	35.60%
4507	TPCODL	BBSR2	PED	PURI-II	SRI RAM NAGAR	14070	11 KV 11kV PKRIT	14070201	THE SWAN REGALE	2424DT163	500	MIXED	AMI	Yes	100%	33	0.01351568	0.006988	0.00652768	48.30%
4508	TPCODL	BBSR2	PED	PURI-II	SRI RAM NAGAR	14070	11 KV 11kV PKRIT	14070201	ALEKHYA PRADAN SAI	2424DT167	100	MIXED	AMI	Yes	100%	146	0.08292602	0.056021	0.02690502	32.44%
4509	TPCODL	BBSR2	PED	PURI-II	SRI RAM NAGAR	14070	11 KV 11kV PKRIT	14070201	HARIKRISHNAPUR	2424DT171	500	MIXED	AMI	Yes	100%	134	0.17904112	0.066399	0.11264212	62.91%
4510	TPCODL	BBSR2	PED	PURI-II	SRI RAM NAGAR	14070	11 KV 11kV Baliguali	14070202	GOPALPUR VILLAGE 1	2424DT177	100	MIXED	AMI	Yes	67%	273	0.1426863	0.101266	0.0414203	29.03%
4511	TPCODL	BBSR2	PED	PURI-II	SRI RAM NAGAR	14070	11 KV 11kV Baliguali	14070202	GOPALPUR VILLAGE 2	2424DT178	100	MIXED	AMI	Yes	33%	155	0.14911578	0.086627	0.06248878	41.91%
4512	TPCODL	BBSR2	PED	PURI-II	SRI RAM NAGAR	14070	11 KV 11kV Baliguali	14070202	SAMANGARA MALION PATIA	2424DT194	100	MIXED	AMI	Yes	67%	184	0.08435032	0.053001	0.03134932	37.17%
4513	TPCODL	BBSR2	PED	PURI-II	SRI RAM NAGAR	14070	11 KV 11kV Baliguali	14070202	RENDEO	2424DT201	100	MIXED	AMI	Yes	67%	115	0.05694588	0.038588	0.01835788	32.24%
4514	TPCODL	BBSR2	PED	PURI-II	SRI RAM NAGAR	14070	11 KV 11kV Baliguali	14070202	PADA	2424DT205	100	MIXED	AMI	Yes	33%	217	0.0832574	0.062314	0.0209434	25.16%
4515	TPCODL	BBSR2	PED	PURI-II	SRI RAM NAGAR	14070	11 KV 11kV Baliguali	14070202	PACHEMOUHA	2424DT208	100	MIXED	AMI	Yes	67%	106	0.0766236	0.045127	0.0314966	41.11%
4516	TPCODL	BBSR2	PED	PURI-II	SRI RAM NAGAR	14070	11 KV 11kV Baliguali	14070202	BALIGUALI	2424DT212	63	MIXED	AMI	Yes	100%	163	0.07411165	0.058835	0.01527665	20.61%
4517	TPCODL	BBSR2	PED	PURI-II	SRI RAM NAGAR	14070	11 KV 11kV Baliguali	14070202	NAGAPATAMA	2424DT216	100	MIXED	AMI	Yes	0%	113	0.07708248	0.045565	0.03151748	40.89%
4518	TPCODL	BBSR2	PED	PURI-II	SRI RAM NAGAR	14070	11 KV 11kV Toshali	14070204	TOTA BEHRA SAHI 2	2424DT232	100	MIXED	AMI	Yes	100%	163	0.15279694	0.108146	0.04465094	29.22%
4519	TPCODL	BBSR2	PED	PURI-II	SRI RAM NAGAR	14070	11 KV 11kV Toshali	14070204	SENAPATI SWEETS	2424DT235	63	MIXED	AMI	Yes	100%	29	0.04908683	0.039946	0.00914083	18.62%
4520	TPCODL	BBSR2	PED	PURI-II	SRI RAM NAGAR	14070	11 KV 11kV Toshali	14070204	SAI TEMPLE	2424DT236	250	MIXED	AMI	Yes	100%	215	0.16988648	0.13285	0.03703648	21.80%
4521	TPCODL	BBSR2	PED	PURI-II	SUNAMUHIN	14069	11 KV BRAHMAGIRI	14069201	HANDIALI VILLAGE	2425DT204	100	MIXED	AMI	Yes	0%	105	0.05034848	0.015413	0.03493548	69.39%
4522	TPCODL	BBSR2	PED	PURI-II	SUNAMUHIN	14069	11 KV BRAHMAGIRI	14069201	SHAHAR SAHI	2425DT210	100	MIXED	AMI	Yes	0%	88	0.09229424	0.020449	0.07184524	77.84%
4523	TPCODL	BBSR2	PED	PURI-II	SUNAMUHIN	14069	11 KV BRAHMAGIRI	14069201	GOMUNDI VILLAGE	2425DT228	100	MIXED	AMI	Yes	67%	83	0.05917038	0.017932	0.04123838	69.69%
4524	TPCODL	BBSR2	PED	PURI-II	SUNAMUHIN	14069	11 KV MODIRATH	14069202	BADABENAKUDI VILLAGE	2425DT130	100	MIXED	AMI	Yes	0%	131	0.07975334	0.029705	0.05004834	62.75%
4525	TPCODL	BBSR2	PED	PURI-II	SUNAMUHIN	14069	11 KV MODIRATH	14069202	KUAPADA 1	2425DT136	100	MIXED	AMI	Yes	0%	69	0.07775722	0.016661	0.06109622	78.57%

Sl. No.	Zone Name	Circle name	Division name	Name of the Sub-division	Name of the Sub-station	Substation Code	Name of the 11 kV Feeder	Feeder Code	Name of the Location where DT situated	DT code	DT Capacity (kVA)	Predominant consumer type of DT (Domestic/Industrial/Agriculture/Mixed)	Type of metering AMR/AMI/ Communicable/Conventional metered/Unmetered	Status of Meter-whether Functional (Yes/No)	% of data received automatically (if AMR/AMI)	No. of Connected Consumers	Input Energy (MU) (A)	Billed Energy (MU) (B)	Loss (MU) (A-B)	% DT Loss (A-B)/A
4526	TPCODL	BBSR2	PED	PURI-II	SUNAMUHIN	14069	11 KV SATAPADA	14069203	SUNAMUHIN	2425DT054	100	MIXED	AMI	Yes	0%	55	0.0658736	0.018687	0.0471866	71.63%
4527	TPCODL	BBSR2	PED	PURI-II	SUNAMUHIN	14069	11 KV SATAPADA	14069203	HASINPUR	2425DT065	100	MIXED	AMI	Yes	0%	111	0.08331698	0.022039	0.06127798	73.55%
4528	TPCODL	BBSR2	PED	PURI-II	SUNAMUHIN	14069	11 KV SATAPADA	14069203	HARCHADI SAHI	2425DT090	100	MIXED	AMI	Yes	67%	91	0.06251684	0.020834	0.04168284	66.67%
4529	TPCODL	BBSR2	PED	PURI-II	SUNAMUHIN	14069	11 KV SATAPADA	14069203	ARKODA	2425DT094	250	MIXED	AMI	Yes	67%	227	0.18053596	0.048017	0.13251896	73.40%
4530	TPCODL	BBSR2	PED	PURI-II	SUNAMUHIN	14069	11 KV SATAPADA	14069203	RAIPUR	2425DT106	100	MIXED	AMI	Yes	0%	44	0.02417276	0.007277	0.01689576	69.90%
4531	TPCODL	BBSR2	PED	PURI-II	TIRIMAL	14050	11 KV RENGALA	14050205	HARIPUR	2422DT483	100	MIXED	AMI	Yes	100%	101	0.06190944	0.044631	0.01727844	27.91%
4532	TPCODL	BBSR2	PED	PURI-II	TIRIMAL	14050	11 KV RENGALA	14050205	GODA SHAI	2422DT487	100	MIXED	AMI	Yes	33%	112	0.0952032	0.041176	0.0540272	56.75%
4533	TPCODL	BBSR2	PED	PURI-II	TIRIMAL	14050	11 KV RENGALA	14050205	BASANATPUR	2422DT519	100	MIXED	AMI	Yes	67%	50	0.03373042	0.011913	0.02181742	64.68%
4534	TPCODL	BBSR2	PED	PURI-III	ATHARNALA	14207	11 KV MADHUBANA	14207201	AKHANDA MANI	2433DT001	500	MIXED	AMI	Yes	0%	604	0.53230984	0.52681	0.00549984	1.03%
4535	TPCODL	BBSR2	PED	PURI-III	ATHARNALA	14207	11 KV MADHUBANA	14207201	TIKARPADA-1	2433DT004	250	MIXED	AMI	Yes	0%	214	0.27748368	0.197301	0.08018268	28.90%
4536	TPCODL	BBSR2	PED	PURI-III	ATHARNALA	14207	11 KV MADHUBANA	14207201	TIKARPADA-2	2433DT005	250	MIXED	AMI	Yes	100%	204	0.2101818	0.15337	0.0568118	27.03%
4537	TPCODL	BBSR2	PED	PURI-III	ATHARNALA	14207	11 KV MADHUBANA	14207201	TIKARPADA-3	2433DT007	500	MIXED	AMI	Yes	0%	463	0.50254248	0.335729	0.16681348	33.19%
4538	TPCODL	BBSR2	PED	PURI-III	ATHARNALA	14207	11 KV MADHUBANA	14207201	CHOTA LAXMANA	2433DT008	250	MIXED	AMI	Yes	100%	316	0.3435586	0.264931	0.0786276	22.89%
4539	TPCODL	BBSR2	PED	PURI-III	ATHARNALA	14207	11 KV MADHUBANA	14207201	CHAU PATNAYAK LANE	2433DT015	250	MIXED	AMI	Yes	0%	223	0.37271952	0.225708	0.14701152	39.44%
4540	TPCODL	BBSR2	PED	PURI-III	ATHARNALA	14207	11 KV MAKUBANA	14207202	MAKUBAN 1ST LINE	2433DT018	100	MIXED	AMI	Yes	100%	75	0.07225214	0.057306	0.01494614	20.69%
4541	TPCODL	BBSR2	PED	PURI-III	ATHARNALA	14207	11 KV MAKUBANA	14207202	MAKUBAN 2ND LINE	2433DT019	100	MIXED	AMI	Yes	0%	65	0.07845016	0.055488	0.02296216	29.27%
4542	TPCODL	BBSR2	PED	PURI-III	ATHARNALA	14207	11 KV MAKUBANA	14207202	MAKUBAN 5TH LINE	2433DT020	100	MIXED	AMI	Yes	100%	74	0.06623464	0.055266	0.01096864	16.56%
4543	TPCODL	BBSR2	PED	PURI-III	ATHARNALA	14207	11 KV Narendra Pokhari	14207203	KHADIABANDHA	2431DT064	250	MIXED	AMI	Yes	67%	440	0.44252904	0.232304	0.21022504	47.51%
4544	TPCODL	BBSR2	PED	PURI-III	ATHARNALA	14207	11 KV Narendra Pokhari	14207203	FISHERY ROAD	2431DT065	100	MIXED	AMI	Yes	100%	103	0.08075314	0.049928	0.03082514	38.17%
4545	TPCODL	BBSR2	PED	PURI-III	ATHARNALA	14207	11 KV Narendra Pokhari	14207203	FISHERY	2431DT066	250	MIXED	AMI	Yes	67%	303	0.28789612	0.230591	0.05730512	19.90%
4546	TPCODL	BBSR2	PED	PURI-III	ATHARNALA	14207	11 KV Narendra Pokhari	14207203	GARUDA	2433DT022	100	MIXED	AMI	Yes	100%	68	0.12686128	0.060385	0.06647628	52.40%
4547	TPCODL	BBSR2	PED	PURI-III	BALIAPANDA	14066	11 KV Baliapanda - Sri M	14066205	BHATAJAGA	2413DT068	250	MIXED	AMI	Yes	100%	306	0.221227	0.149416	0.071811	32.46%
4548	TPCODL	BBSR2	PED	PURI-III	CHARINALA	14067	11 KV M M NAGAR	14067201	MM NAGAR 01	2431DT001	250	MIXED	AMI	Yes	100%	236	0.30130754	0.188784	0.11252354	37.35%
4549	TPCODL	BBSR2	PED	PURI-III	CHARINALA	14067	11 KV M M NAGAR	14067201	DAGARABANDHA	2431DT003	500	MIXED	AMI	Yes	100%	204	0.19765532	0.154266	0.04338932	21.95%
4550	TPCODL	BBSR2	PED	PURI-III	CHARINALA	14067	11 KV M M NAGAR	14067201	BISWANATH BIHAR	2431DT004	250	MIXED	AMI	Yes	100%	112	0.17453336	0.099643	0.07489036	42.91%
4551	TPCODL	BBSR2	PED	PURI-III	CHARINALA	14067	11 KV M M NAGAR	14067201	KADARIBADI	2431DT006	100	MIXED	AMI	Yes	100%	125	0.16647172	0.087241	0.07923072	47.59%
4552	TPCODL	BBSR2	PED	PURI-III	CHARINALA	14067	11 KV M M NAGAR	14067201	SHREEHARI CONSTRUCTION	2431DT007	100	MIXED	AMI	Yes	100%	38	0.04529996	0.043531	0.00176896	3.90%
4553	TPCODL	BBSR2	PED	PURI-III	CHARINALA	14067	11 KV M M NAGAR	14067201	SHREEHARI TOWER	2431DT008	500	MIXED	AMI	Yes	100%	71	0.0370028	0.034185	0.0028178	7.62%
4554	TPCODL	BBSR2	PED	PURI-III	CHARINALA	14067	11 KV M M NAGAR	14067201	SHREEHARI HEIGHTS	2431DT009	500	MIXED	AMI	Yes	100%	70	0.04317912	0.03097	0.01220912	28.28%
4555	TPCODL	BBSR2	PED	PURI-III	CHARINALA	14067	11 KV KHNDIA BANDHA	14067202	GOPINATHPUR 2	2431DT019	100	MIXED	AMI	Yes	100%	84	0.09893091	0.082666	0.01626491	16.44%
4556	TPCODL	BBSR2	PED	PURI-III	CHARINALA	14067	11 KV KHNDIA BANDHA	14067202	CREATIVE HEIGHTS DK CONSTRUCTIO	2431DT020	250	MIXED	AMI	Yes	100%	22	0.01352988	0.008257	0.00527288	38.97%
4557	TPCODL	BBSR2	PED	PURI-III	CHARINALA	14067	11 KV KHNDIA BANDHA	14067202	NILACHAKRA NAGAR	2431DT021	500	MIXED	AMI	Yes	100%	615	0.65811008	0.446571	0.21153908	32.14%
4558	TPCODL	BBSR2	PED	PURI-III	CHARINALA	14067	11 KV HAREKRUSHNAPU	14067203	MANGARAJPUR BYPASS	2431DT039	100	MIXED	AMI	Yes	0%	40	0.09158736	0.024287	0.06730036	73.48%
4559	TPCODL	BBSR2	PED	PURI-III	JAIL ROAD (SAMAN(	14291	11 KV Koilada	14291201	MANGLA PATNA KANTHOPUR	2424DT103	100	MIXED	AMI	Yes	0%	113	0.05785582	0.044192	0.01366382	23.62%
4560	TPCODL	BBSR2	PED	PURI-III	JAPAKUDA ODSSP	14312	11 KV MALAMOUDA	14312204	MALA MUDA	3534DT179	100	MIXED	AMI	Yes	100%	67	0.07559876	0.017525	0.05807376	76.82%
4561	TPCODL	BBSR2	PED	PURI-III	KACHERI	14065	11 KV 11kV Kacheri- Sri M	14065205	NIMAKADA CSS	2433DT058	750	MIXED	AMI	Yes	0%	265	0.49031664	0.420119	0.07019764	14.32%
4562	TPCODL	BBSR2	PED	PURI-III	KACHERI	14065	11 KV 11kV Kacheri- Sri M	14065205	NAYAK PLAZA	2433DT061	250	MIXED	AMI	Yes	100%	60	0.11857348	0.103213	0.01536048	12.95%
4563	TPCODL	BBSR2	PED	PURI-III	SRI RAM NAGAR	14070	11 KV 11kV PKRIT	14070201	CENTRAL SCHOOL NEW	2434DT001	250	MIXED	AMI	Yes	100%	61	0.05367668	0.052606	0.00107068	1.99%
4564	TPCODL	BBSR2	PED	PURI-III	SRI RAM NAGAR	14070	11 KV 11kV PKRIT	14070201	SUBA MANDIRA PKRIT 2	2434DT005	100	MIXED	AMI	Yes	100%	96	0.05074916	0.050031	0.00071816	1.42%
4565	TPCODL	BBSR2	PED	PURI-III	SRI RAM NAGAR	14070	11 KV 11kV PKRIT	14070201	SIDHA MAHAVIR 2	2434DT011	250	MIXED	AMI	Yes	0%	213	0.36461408	0.147242	0.21737208	59.62%
4566	TPCODL	BBSR2	PED	PURI-III	SRI RAM NAGAR	14070	11 KV 11kV PKRIT	14070201	BHARATIPUR 1	2434DT020	250	MIXED	AMI	Yes	67%	271	0.18230564	0.176202	0.00610364	3.35%
4567	TPCODL	BBSR2	PED	PURI-III	SRI RAM NAGAR	14070	11 KV 11kV PKRIT	14070201	BHIMA SEN RESIDENCY	2434DT025	100	MIXED	AMI	Yes	100%	8	0.00571188	0.003835	0.00187688	32.86%
4568	TPCODL	BBSR2	PED	PURI-III	SRI RAM NAGAR	14070	11 KV 11kV PKRIT	14070201	SENAPATI BAGICHA	2434DT026	250	MIXED	AMI	Yes	100%	189	0.25980648	0.139593	0.12021348	46.27%
4569	TPCODL	BBSR2	PED	PURI-III	SRI RAM NAGAR	14070	11 KV 11kV PKRIT	14070201	BHARATIPUR 2	2434DT027	250	MIXED	AMI	Yes	33%	133	0.17467832	0.097303	0.07737532	44.30%
4570	TPCODL	BBSR2	PED	PURI-III	SRI RAM NAGAR	14070	11 KV 11kV PKRIT	14070201	SAILA SHREE VIHAR	2434DT028	100	MIXED	AMI	Yes	100%	151	0.1253109	0.089966	0.0353449	28.21%
4571	TPCODL	BBSR2	PED	PURI-III	SRI RAM NAGAR	14070	11 KV 11kV PKRIT	14070201	BATA MAHAVIR	2434DT029	100	MIXED	AMI	Yes	33%	52	0.08629024	0.020844	0.06544624	75.84%
4572	TPCODL	BBSR2	PED	PURI-III	SRI RAM NAGAR	14070	11 KV 11kV Baliguali	14070202	ASHRAM	2434DT030	250	MIXED	AMI	Yes	100%	191	0.23419244	0.167357	0.06683544	28.54%
4573	TPCODL	BBSR2	PED	PURI-III	SRI RAM NAGAR	14070	11 KV 11kV Baliguali	14070202	HARIHAR NAGAR	2434DT032	100	MIXED	AMI	Yes	100%	95	0.10123402	0.075441	0.02579302	25.48%
4574	TPCODL	BBSR2	PED	PURI-III	SRI RAM NAGAR	14070	11 KV 11kV Baliguali	14070202	MARUTI NAGAR 1	2434DT033	250	MIXED	AMI	Yes	100%	207	0.21976596	0.1518	0.06796596	30.93%
4575	TPCODL	BBSR2	PED	PURI-III	SRI RAM NAGAR	14070	11 KV 11kV Baliguali	14070202	MARUTI NAGAR MAHAVEER ENCLAV	2434DT034	250	MIXED	AMI	Yes	100%	28	0.01161492	0.009887	0.00172792	14.88%
4576	TPCODL	BBSR2	PED	PURI-III	SRI RAM NAGAR	14070	11 KV 11kV Baliguali	14070202	MADHUSUDAN NAGAR	2434DT036	250	MIXED	AMI	Yes	100%	151	0.20953434	0.124752	0.08478234	40.46%
4577	TPCODL	BBSR2	PED	PURI-III	SRI RAM NAGAR	14070	11 KV 11kV Baliguali	14070202	BHUDAN 2	2434DT038	100	MIXED	AMI	Yes	100%	119	0.10200134	0.058585	0.04341634	42.56%
4578	TPCODL	BBSR2	PED	PURI-III	SRI RAM NAGAR	14070	11 KV 11kV Water Works	14070203	PHD NO 7	2432DT091	100	MIXED	AMI	Yes	100%	1	0.023021	0.022997	2.4E-05	0.10%
4579	TPCODL	BBSR2	PED	PURI-III	SRI RAM NAGAR	14070	11 KV 11kV Water Works	14070203	PUMP CHAMPER 8	2432DT094	100	MIXED	AMI	Yes	100%	3	0.03332317	0.032844	0.00047917	1.44%
4580	TPCODL	BBSR2	PED	PURI-III	SRI RAM NAGAR	14070	11 KV 11kV Water Works	14070203	ITI COLONY PUMP CHAMBER	2432DT097	100	MIXED	AMI	Yes	0%	18	0.02476408	0.019596	0.00516808	20.87%
4581	TPCODL	BBSR2	PED	PURI-III	SRI RAM NAGAR	14070	11 KV 11kV Water Works	14070203	BHUDAN NAGAR CHURCH CAPEX	2432DT104	100	MIXED	AMI	Yes	100%	155	0.11751666	0.0834	0.03411666	29.03%
4582	TPCODL	BBSR2	PED	PURI-III	SRI RAM NAGAR	14070	11 KV 11kV Water Works	14070203	NEER G M.LAW .COLLEG	2432DT105	100	MIXED	AMI	Yes	100%	8	0.03989303	0.037976	0.00191703	4.81%
4583	TPCODL	BBSR2	PED	PURI-III	SRI RAM NAGAR	14070	11 KV 11kV Water Works	14070203	LAW COLLEGE UTHANI	2432DT106	250	MIXED	AMI	Yes	100%	527	0.16887688	0.135378	0.03349888	19.84%
4584	TPCODL	BBSR2	PED	PURI-III	SRI RAM NAGAR	14070	11 KV 11kV Water Works	14070203	BALIAPAR	2432DT108	100	MIXED	AMI	Yes	100%	411	0.23815054	0.144921	0.09322954	39.15%
4585	TPCODL	BBSR2	PED	PURI-III	SRI RAM NAGAR	14070	11 KV 11kV Water Works	14070203	LADIES HOSTEL	2432DT111	250	MIXED	AMI	Yes	100%	24	0.0374098	0.031809	0.0056008	14.97%
4586	TPCODL	BBSR2	PED	PURI-III	SRI RAM NAGAR	14070	11 KV 11kV Water Works	14070203	JAGANNATH SANSKRIT UNIVERSITY O	2432DT112	100	MIXED	AMI	Yes	100%	18	0.03618316	0.035674	0.00050916	1.41%
4587	TPCODL	BBSR2	PED	PURI-III	SRI RAM NAGAR	14070	11 KV 11kV Water Works	14070203	PENTHA KATA CSS	2432DT114	750	MIXED	AMI	Yes	0%	85	0.30909568	0.07741	0.23168568	74.96%
4588	TPCODL	BBSR2	PED	PURI-III	SRI RAM NAGAR	14070	11 KV 11kV Water Works	14070203	PRASAD BABA CAPEX	2432DT119	100	MIXED	AMI	Yes	100%	159	0.08670546	0.052941	0.03376446	38.94%
4589	TPCODL	BBSR2	PED	PURI-III	SRI RAM NAGAR	14070	11 KV 11kV Water Works	14070203	SINDHU HOLIDAY HOME	2432DT123	100	MIXED	AMI	Yes	100%	39	0.01080216	0.008672	0.00213016	19.72%
4590	TPCODL	BBSR2	PED	PURI-III	SRI RAM NAGAR	14070	11 KV 11kV Water Works	14070203	ASIYAN APARTMENT	2432DT125	100	MIXED	AMI	Yes	100%	24	0.01512214	0.006886	0.00823614	54.46%
4591	TPCODL	BBSR2	PED	PURI-III	SRI RAM NAGAR	14070	11 KV 11kV Water Works	14070203	BEACH HUT	2432DT129	250	MIXED	AMI	Yes	0%	38	0.1476934	0.078793	0.0689004	46.65%
4592	TPCODL	BBSR2	PED	PURI-III	SRI RAM NAGAR	14070	11 KV 11kV Water Works	14070203	LAXMI SAGAR APT	2432DT142	100	MIXED	AMI	Yes	100%	19	0.01090862	0.008701	0.00220762	20.24%
4593	TPCODL	BBSR2	PED	PURI-III	SRI RAM NAGAR	14070	11 KV 11kV Water Works	14070203	ANUSUYA VILLA	2432DT143	63	MIXED	AMI	Yes	100%	16	0.01429428	0.008911	0.00538328	37.66%
4594	TPCODL	BBSR2	PED	PURI-III	SRI RAM NAGAR	14070	11 KV 11kV Water Works	14070203	HIGH MAST CSS	2432DT148	750	MIXED	AMI	Yes	100%	53	0.3210422	0.217235	0.1038072	32.33%
4595	TPCODL	BBSR2	PED	PURI-III	SRI RAM NAGAR	14070	11 KV 11kV Water Works	14070203	POSTEL COLONY CSS	2432DT157	750	MIXED	AMI	Yes	100%	120	0.1655992	0.136523	0.0290762	17.56%
4596	TPCODL	BBSR2	PED	PURI-III	TALABANIA	14064	11 KV 11kV Sri Mandira (	14064201	BALI BASTI	2433DT026	100	MIXED	AMI	Yes	100%	199	0.15914086	0.127651	0.03148986	19.79%
4597	TPCODL	BBSR2	PED	PURI-III	TALABANIA	14064	11 KV 11kV Sri Mandira (	14064201	PANCHAMUKHI HANUMAN 2	2433DT028	100	MIXED	AMI	Yes	0%	171	0.10307224	0.067688	0.03538424	34.33%
4598	TPCODL	BBSR2	PED	PURI-III	TALABANIA	14064	11 KV 11kV Sri Mandira (	14064201	POLICE HIGH SCHOOL	2433DT031	500	MIXED	AMI	Yes	100%	551	0.32076112	0.275563	0.04519812	14.09%

Sl. No.	Zone Name	Circle name	Division name	Name of the Sub-division	Name of the Sub-station	Substation Code	Name of the 11 kV Feeder	Feeder Code	Name of the Location where DT situated	DT code	DT Capacity (kVA)	Predominant consumer type of DT (Domestic/Industrial/Agriculture/Mixed)	Type of metering AMR/AMI/ Communicable/Conventional metered/Unmetered	Status of Meter-whether Functional (Yes/No)	% of data received automatically (if AMR/AMI)	No. of Connected Consumers	Input Energy (MU) (A)	Billed Energy (MU) (B)	Loss (MU) (A-B)	% DT Loss (A-B)/A
4599	TPCODL	BBSR2	PED	PURI-III	TALABANIA	14064	11 KV 11kV Sri Gundicha	14064202	BAHADUR BEHRA	2433DT036	250	MIXED	AMI	Yes	100%	281	0.3649458	0.242899	0.1220468	33.44%
4600	TPCODL	BBSR2	PED	PURI-III	TALABANIA	14064	11 KV 11kV Sri Gundicha	14064202	SANDHYA RAANI APARTMENT	2433DT037	250	MIXED	AMI	Yes	100%	27	0.01125708	0.010349	0.00090808	8.07%
4601	TPCODL	BBSR2	PED	PURI-III	TALABANIA	14064	11 KV 11kV Sri Gundicha	14064202	HARIHAR COMPLEX	2433DT039	250	MIXED	AMI	Yes	100%	20	0.020664	0.011902	0.008762	42.40%
4602	TPCODL	BBSR2	PED	PURI-III	TALABANIA	14064	11 KV 11kV Sri Gundicha	14064202	NRUSINGHA MANDIR	2433DT040	500	MIXED	AMI	Yes	100%	373	0.49617272	0.409389	0.08678372	17.49%
4603	TPCODL	BBSR2	PED	PURI-III	TALABANIA	14064	11 KV 11kV Sri Gundicha	14064202	BUS STAND OUTGATE	2433DT042	250	MIXED	AMI	Yes	100%	206	0.26558412	0.161778	0.10380612	39.09%
4604	TPCODL	BBSR2	PED	PURI-III	TALABANIA	14064	11 KV 11kV Raj Bhawan (	14064204	BHOBA SAHI	2432DT001	250	MIXED	AMI	Yes	100%	195	0.18466556	0.139204	0.04546156	24.62%
4605	TPCODL	BBSR2	PED	PURI-III	TALABANIA	14064	11 KV 11kV Raj Bhawan (	14064204	KRISHANA PALACE	2432DT006	250	MIXED	AMI	Yes	100%	25	0.01957036	0.018721	0.00084936	4.34%
4606	TPCODL	BBSR2	PED	PURI-III	TALABANIA	14064	11 KV 11kV Raj Bhawan (	14064204	YOUTH HOSTEL CSS	2432DT008	500	MIXED	AMI	Yes	100%	141	0.18622544	0.123834	0.06239144	33.50%
4607	TPCODL	BBSR2	PED	PURI-III	TALABANIA	14064	11 KV 11kV Raj Bhawan (	14064204	HOTEL SAMUDRA CSS	2432DT018	500	MIXED	AMI	Yes	0%	90	0.31230944	0.131528	0.18078144	57.89%
4608	TPCODL	BBSR2	PED	PURI-III	TALABANIA	14064	11 KV 11kV Kacheri	14064205	KOILA ADDA	2432DT032	250	MIXED	AMI	Yes	0%	87	0.13588476	0.075251	0.06063376	44.62%
4609	TPCODL	BBSR2	PED	PURI-III	TALABANIA	14064	11 KV 11kV Kacheri	14064205	BLOCK	2432DT039	250	MIXED	AMI	Yes	100%	255	0.28739504	0.231079	0.05631604	19.60%
4610	TPCODL	BBSR2	PED	PURI-III	TALABANIA	14064	11 KV 11kV Kacheri	14064205	PUMP CHAMBER 06	2432DT044	100	MIXED	AMI	Yes	100%	11	0.03795232	0.034563	0.00338932	8.93%
4611	TPCODL	BBSR2	PED	PURI-III	TALABANIA	14064	11 KV 11kV Kacheri	14064205	MANJULA RESIDENCY	2432DT048	250	MIXED	AMI	Yes	100%	20	0.01677712	0.009144	0.00763312	45.50%
4612	TPCODL	BBSR2	PED	PURI-III	TALABANIA	14064	11 KV 11kV Kacheri	14064205	GORAKABAR	2432DT049	100	MIXED	AMI	Yes	100%	281	0.19504479	0.158362	0.03668279	18.81%
4613	TPCODL	BBSR2	PED	PURI-III	TALABANIA	14064	11 KV 11kV Kacheri	14064205	AYURVEDIC HOSPITAL	2432DT051	500	MIXED	AMI	Yes	0%	19	0.11360312	0.083438	0.03016512	26.55%
4614	TPCODL	BBSR2	PED	PURI-III	TALABANIA	14064	11 KV 11kV Kacheri	14064205	POLICE COLONY	2432DT052	250	MIXED	AMI	Yes	100%	104	0.08709749	0.070489	0.01660849	19.07%
4615	TPCODL	BBSR2	PED	PURI-III	TALABANIA	14064	11 KV 11kV Kacheri	14064205	RELIANCE DIGITAL AJAYA JENA	2432DT055	250	MIXED	AMI	Yes	33%	7	0.10595603	0.053248	0.05270803	49.75%
4616	TPCODL	BBSR2	PED	PURI-III	TALABANIA	14064	11 KV MAUSIMA U/G	14064206	BUS STAND CSS	2433DT047	750	MIXED	AMI	Yes	100%	138	0.42456832	0.130275	0.29429332	69.32%
4617	TPCODL	BBSR2	PED	PURI-III	TALABANIA	14064	11 KV MAUSIMA U/G	14064206	INDRAPURI CSS	2433DT048	750	MIXED	AMI	Yes	100%	90	0.21216624	0.091856	0.12031024	56.71%
4618	TPCODL	BBSR2	PED	PURI-III	TALABANIA	14064	11 KV MAUSIMA U/G	14064206	GAJPATI NAGAR	2433DT049	100	MIXED	AMI	Yes	100%	81	0.11213704	0.070506	0.04163104	37.13%
4619	TPCODL	BBSR2	PED	PURI-III	TALABANIA	14064	11 KV MAUSIMA U/G	14064206	OLD LIC CSS	2433DT050	750	MIXED	AMI	Yes	100%	464	0.7768192	0.373017	0.4038022	51.98%
4620	TPCODL	BBSR2	PED	PURI-III	TALABANIA	14064	11 KV MAUSIMA U/G	14064206	HANUMAN CSS	2433DT052	750	MIXED	AMI	Yes	100%	223	0.50718128	0.25926	0.24792128	48.88%
4621	TPCODL	BBSR2	PED	PURI-III	TALABANIA	14064	11 KV MAUSIMA U/G	14064206	KAWADI BADA	2433DT056	500	MIXED	AMI	Yes	67%	265	0.4194452	0.259601	0.1598442	38.11%
4622	TPCODL	BBSR2	PED	PURI-III	TALABANIA	14064	11 KV Talabania- Sri Mar	14064208	HATHI STHAL CSS	2433DT062	750	MIXED	AMI	Yes	0%	205	0.29821301	0.213908	0.08430501	28.27%
4623	TPCODL	BBSR2	PED	PURI-III	TALABANIA	14064	11 KV Talabania- Sri Mar	14064208	BANIA	2433DT067	100	MIXED	AMI	Yes	0%	76	0.14677728	0.060945	0.08583228	58.48%
4624	TPCODL	BBSR2	PED	PURI-III	TALABANIA	14064	11 KV Talabania- Sri Mar	14064208	GOPI BANDHU	2433DT068	100	MIXED	AMI	Yes	100%	80	0.10831248	0.088368	0.01994448	18.41%
4625	TPCODL	BBSR2	PED	PURI-III	TALABANIA	14064	11 KV Talabania- Sri Mar	14064208	BHOLANATH CSS	2433DT071	750	MIXED	AMI	Yes	100%	164	0.23635513	0.153433	0.08292213	35.08%
4626	TPCODL	BBSR2	PED	PURI-III	TALABANIA	14064	11 KV Talabania- Sri Mar	14064208	SANGRAM CLUB	2433DT072	250	MIXED	AMI	Yes	100%	199	0.25706424	0.180617	0.07644724	29.74%
4627	TPCODL	BBSR2	PED	PURI-III	TALABANIA	14064	11 KV Talabania- Sri Mar	14064208	BAGHA AKHADA MATHA CSS	2433DT073	750	MIXED	AMI	Yes	100%	182	0.495964	0.164432	0.331532	66.85%
4628	TPCODL	BBSR2	PED	PURI-III	TALABANIA	14064	11 KV Talabania- Sri Mar	14064208	RENUKA APPARTMENT	2433DT075	100	MIXED	AMI	Yes	100%	19	0.01873534	0.011518	0.00721734	38.52%
4629	TPCODL	BBSR2	PED	PURI-III	TALABANIA	14064	11 KV Talabania- Sri Mar	14064208	GRAND ASIANA APPARTMENT	2433DT079	500	MIXED	AMI	Yes	0%	88	0.05961984	0.046779	0.01284084	21.54%
4630	TPCODL	BBSR2	PED	PURI-III	TALABANIA	14064	11 KV Talabania- Sri Mar	14064208	GIRIA	2433DT082	100	MIXED	AMI	Yes	100%	44	0.0676973	0.030843	0.0368543	54.44%
4631	TPCODL	BBSR2	PED	PURI-III	TALABANIA	14064	11 KV Talabania- Sri Mar	14064208	RAJENDRA ENCLAVE	2433DT084	250	MIXED	AMI	Yes	100%	91	0.06739704	0.047355	0.02004204	29.74%
4632	TPCODL	BBSR2	PED	PURI-III	TALABANIA	14064	11 KV Talabania- Sri Mar	14064208	JAGANNATH MEDICAL CSS	2433DT086	750	MIXED	AMI	Yes	100%	96	0.26084928	0.214289	0.04656028	17.85%
4633	TPCODL	BBSR2	PED	PURI-III	TALABANIA	14064	11 KV Talabania- Sri Mar	14064208	BALAGANDI CSS	2433DT088	750	MIXED	AMI	Yes	100%	261	0.46317232	0.357248	0.10592432	22.87%
4634	TPCODL	BBSR2	PED	PURI-III	TALABANIA	14064	11 KV Talabania- Sri Mar	14064208	AKSHAYA PATRA CSS	2433DT089	750	MIXED	AMI	Yes	100%	108	0.47592064	0.266656	0.20926464	43.97%
4635	TPCODL	BBSR2	PED	PURI-III	TALABANIA	14064	11 KV 11kV Raj Bhavan U	14064209	ACRUX SRIKHETRA ENCLAVE	2432DT064	63	MIXED	AMI	Yes	67%	24	0.01199838	0.008347	0.00365138	30.43%
4636	TPCODL	BBSR2	PED	PURI-III	TALABANIA	14064	11 KV 11kV Raj Bhavan U	14064209	HARE KRISHANA RESTAURANT	2432DT066	100	MIXED	AMI	Yes	100%	38	0.02335364	0.013732	0.00962164	41.20%
4637	TPCODL	BBSR2	PED	PURI-III	TALABANIA	14064	11 KV 11kV Raj Bhavan U	14064209	SWASTIK APPARTMENT	2432DT068	200	MIXED	AMI	Yes	0%	60	0.04049376	0.028254	0.01223976	30.23%
4638	TPCODL	BBSR2	PED	PURI-III	TALABANIA	14064	11 KV 11kV Raj Bhavan U	14064209	MEERA RESIDENCY (ANAPURNA PRIS	2432DT078	100	MIXED	AMI	Yes	100%	17	0.0245153	0.016747	0.0077683	31.69%
4639	TPCODL	BBSR2	PED	PURI-III	TALABANIA	14064	11 KV 11kV Raj Bhavan U	14064209	SRI PALACE	2432DT079	250	MIXED	AMI	Yes	100%	28	0.01507104	0.010901	0.00417004	27.67%
4640	TPCODL	BBSR2	PED	PURI-III	TALABANIA	14064	11 KV 11kV Raj Bhavan U	14064209	GREE KUNJ TRADING LINK PVT LTD 02	2432DT085	500	MIXED	AMI	Yes	100%	45	0.09070112	0.039232	0.05146912	56.75%
4641	TPCODL	BBSR2	PED	SAKHIGOPAL	PURI	17012	33 kV SAKHIGOPAL	17012401	33/11 kV ALGUM (SOMESWARPUR) (	2443DT901	100	MIXED	AMI	Yes	0%	1	0.012129	0.012128	1E-06	0.01%
4642	TPCODL	BBSR2	PED	SAKHIGOPAL	GABAKUNDA (SUAN	14289	11 KV GUALIGORADA	14289202	GABAKUND BAZAR	2442DT014	100	MIXED	AMI	Yes	100%	86	0.02403096	0.017072	0.00695896	28.96%
4643	TPCODL	BBSR2	PED	SAKHIGOPAL	GABAKUNDA (SUAN	14289	11 KV GUALIGORADA	14289202	SUANLO	2442DT017	100	MIXED	AMI	Yes	100%	131	0.05639032	0.039485	0.01690532	29.98%
4644	TPCODL	BBSR2	PED	SAKHIGOPAL	GABAKUNDA (SUAN	14289	11 KV GUALIGORADA	14289202	DHOLA PRADHAN SAHI	2442DT025	100	MIXED	AMI	Yes	0%	96	0.04137346	0.023411	0.01796246	43.42%
4645	TPCODL	BBSR2	PED	SAKHIGOPAL	BALIAPANDA	14066	11 KV 11kV Prachi OH	14066204	AMRITAM APT	2411DT094	25	MIXED	AMI	Yes	100%	7	0.01388422	0.009268	0.00461622	33.25%
4646	TPCODL	BBSR2	PED	SAKHIGOPAL	CHALISIBATIA ODSS	14288	11 KV CHALISBATIA	14288201	URAD	2441DT077	100	MIXED	AMI	Yes	67%	143	0.05998108	0.028805	0.03117608	51.98%
4647	TPCODL	BBSR2	PED	SAKHIGOPAL	CHALISIBATIA ODSS	14288	11 KV CHALISBATIA	14288201	CHALISBATIA NO 2	2441DT081	100	MIXED	AMI	Yes	67%	42	0.0153223	0.009518	0.0058043	37.88%
4648	TPCODL	BBSR2	PED	SAKHIGOPAL	CHALISIBATIA ODSS	14288	11 KV CHALISBATIA	14288201	GOBINDAPUR	2441DT084	100	MIXED	AMI	Yes	67%	37	0.01668572	0.011407	0.00527872	31.64%
4649	TPCODL	BBSR2	PED	SAKHIGOPAL	CHALISIBATIA ODSS	14288	11 KV CHALISBATIA	14288201	DANDA	2441DT110	100	MIXED	AMI	Yes	67%	66	0.03313064	0.016709	0.01642164	49.57%
4650	TPCODL	BBSR2	PED	SAKHIGOPAL	CHALISIBATIA ODSS	14288	11 KV BALIPUT	14288202	TADASARAMAHAN SAPRUR	2441DT004	100	MIXED	AMI	Yes	67%	49	0.0491569	0.013502	0.0356549	72.53%
4651	TPCODL	BBSR2	PED	SAKHIGOPAL	CHALISIBATIA ODSS	14288	11 KV BALIPUT	14288202	JAGRANATHPUR	2441DT005	100	MIXED	AMI	Yes	67%	120	0.05718902	0.034077	0.02311202	40.41%
4652	TPCODL	BBSR2	PED	SAKHIGOPAL	CHALISIBATIA ODSS	14288	11 KV BALIPUT	14288202	JAMARSUAN	2441DT023	100	MIXED	AMI	Yes	67%	110	0.05922526	0.029982	0.02924326	49.38%
4653	TPCODL	BBSR2	PED	SAKHIGOPAL	CHALISIBATIA ODSS	14288	11 KV BALIPUT	14288202	MARKHANDAPUR MAJHI SAHI OLD	2441DT046	100	MIXED	AMI	Yes	67%	78	0.05291382	0.019912	0.03300182	62.37%
4654	TPCODL	BBSR2	PED	SAKHIGOPAL	CHALISIBATIA ODSS	14288	11 KV BALIPUT	14288202	BALISAHI	2441DT061	100	MIXED	AMI	Yes	0%	75	0.04495172	0.024363	0.02058872	45.80%
4655	TPCODL	BBSR2	PED	SAKHIGOPAL	CHANDANPUR	14071	11 KV CHANDANPUR	14071201	DOLA GOBINDPUR NADI BANDH-1	2441DT124	100	MIXED	AMI	Yes	67%	167	0.09552218	0.071645	0.02387718	25.00%
4656	TPCODL	BBSR2	PED	SAKHIGOPAL	CHANDANPUR	14071	11 KV CHANDANPUR	14071201	KETAKIPATNA (407 STAND)	2441DT134	100	MIXED	AMI	Yes	67%	73	0.08078798	0.043073	0.03771498	46.68%
4657	TPCODL	BBSR2	PED	SAKHIGOPAL	CHANDANPUR	14071	11 KV CHANDANPUR	14071201	APILA	2441DT149	100	MIXED	AMI	Yes	67%	79	0.06144008	0.018453	0.04298708	69.97%
4658	TPCODL	BBSR2	PED	SAKHIGOPAL	CHANDANPUR	14071	11 KV CHANDANPUR	14071201	GANGA NARAYANPUR NEW	2441DT151	100	MIXED	AMI	Yes	67%	90	0.04575266	0.029075	0.01667766	36.45%
4659	TPCODL	BBSR2	PED	SAKHIGOPAL	CHANDANPUR	14071	11 KV CHANDANPUR	14071201	BARBODIA JANA SAHI	2441DT155	100	MIXED	AMI	Yes	67%	49	0.01679014	0.014126	0.00266414	15.87%
4660	TPCODL	BBSR2	PED	SAKHIGOPAL	CHANDANPUR	14071	11 KV CHANDANPUR	14071201	NAYAK PATNA OLD	2441DT165	100	MIXED	AMI	Yes	67%	148	0.07623668	0.060714	0.01552268	20.36%
4661	TPCODL	BBSR2	PED	SAKHIGOPAL	CHANDANPUR	14071	11 KV BIRANARSINGHPU	14071202	BHAHMANI ALANDI	2441DT236	100	MIXED	AMI	Yes	67%	137	0.06739106	0.051882	0.01550906	23.01%
4662	TPCODL	BBSR2	PED	SAKHIGOPAL	CHANDANPUR	14071	11 KV BIRANARSINGHPU	14071202	PRATAPPURUSOTTAMPUR 2	2441DT248	100	MIXED	AMI	Yes	0%	68	0.02179186	0.018362	0.00342986	15.74%
4663	TPCODL	BBSR2	PED	SAKHIGOPAL	CHANDANPUR	14071	11 KV BIRANARSINGHPU	14071202	PRATAPPURUSOTTAMPUR 1	2441DT249	100	MIXED	AMI	Yes	67%	160	0.07458974	0.053339	0.02125074	28.49%
4664	TPCODL	BBSR2	PED	SAKHIGOPAL	CHANDANPUR	14071	11 KV BIRANARSINGHPU	14071202	JAMUNA KUDA	2441DT254	100	MIXED	AMI	Yes	67%	47	0.02072898	0.008666	0.01206298	58.19%
4665	TPCODL	BBSR2	PED	SAKHIGOPAL	CHANDANPUR	14071	11 KV BIRANARSINGHPU	14071202	BIRENARASINGHHAPUPS 1	2441DT259	100	MIXED	AMI	Yes	67%	169	0.14048908	0.083663	0.05682608	40.45%
4666	TPCODL	BBSR2	PED	SAKHIGOPAL	CHANDANPUR	14071	11 KV BIRANARSINGHPU	14071202	THENTADUD 2	2441DT266	100	MIXED	AMI	Yes	67%	57	0.05672392	0.028902	0.02782192	49.05%
4667	TPCODL	BBSR2	PED	SAKHIGOPAL	CHANDANPUR	14071	11 KV BIRANARSINGHPU	14071202	BIRA PRATAPUR BYEPASS CHHAKA	2441DT270	100	MIXED	AMI	Yes	67%	68	0.0700279	0.065562	0.0044659	6.38%
4668	TPCODL	BBSR2	PED	SAKHIGOPAL	CHANDANPUR	14071	11 KV BIRANARSINGHPU	14071202	BALISAHI	2441DT299	100	MIXED	AMI	Yes	67%	48	0.01692	0.011034	0.005886	34.79%
4669	TPCODL	BBSR2	PED	SAKHIGOPAL	CHANDANPUR	14071	11 KV BIRANARSINGHPU	14071202	MASANI 3/5	2441DT302	100	MIXED	AMI	Yes	67%	10	0.01882164	0.010427	0.00839464	44.60%
4670	TPCODL	BBSR2	PED	SAKHIGOPAL	CHANDANPUR	14071	11 KV BIRANARSINGHPU	14071202	BIJAYARAMACHANDRA PAN 2	2441DT327	100	MIXED	AMI	Yes	67%	44	0.02279062	0.012621	0.01016962	44.62%
4671	TPCODL	BBSR2	PED	SAKHIGOPAL	CHANDANPUR	14071	11 KV BIRANARSINGHPU	14071202	KURUNTI 2	2441DT343	100	MIXED	AMI	Yes	67%	54	0.03781866	0.009657	0.02816166	74.46%

Sl. No.	Zone Name	Circle name	Division name	Name of the Sub-division	Name of the Sub-station	Substation Code	Name of the 11 kV Feeder	Feeder Code	Name of the Location where DT situated	DT code	DT Capacity (kVA)	Predominant consumer type of DT (Domestic/Industrial/Agriculture/Mixed)	Type of metering AMR/AMI/ Communicable/Conventional metered/Unmetered	Status of Meter-whether Functional (Yes/No)	% of data received automatically (if AMR/AMI)	No. of Connected Consumers	Input Energy (MU) (A)	Billed Energy (MU) (B)	Loss (MU) (A-B)	% DT Loss (A-B)/A
4672	TPCODL	BBSR2	PED	SAKHIGOPAL	CHANDANPUR	14071	11 KV BIRANARSINGHPU	14071202	ATHANABHAGA VILLAGE	2441DT381	100	MIXED	AMI	Yes	67%	110	0.05190258	0.024592	0.02731058	52.62%
4673	TPCODL	BBSR2	PED	SAKHIGOPAL	CHANDANPUR	14071	11 KV BIRANARSINGHPU	14071202	KANHEEBIDYADHANPUR 1	2441DT383	100	MIXED	AMI	Yes	67%	155	0.05363216	0.030554	0.02307816	43.03%
4674	TPCODL	BBSR2	PED	SAKHIGOPAL	CHANDANPUR	14071	11 KV BIRANARSINGHPU	14071202	JAGESHWAPUR	2441DT396	100	MIXED	AMI	Yes	67%	55	0.0238772	0.0106	0.0132772	55.61%
4675	TPCODL	BBSR2	PED	SAKHIGOPAL	CHANDANPUR	14071	11 KV BIRANARSINGHPU	14071202	RVA VILLAGE	2441DT405	100	MIXED	AMI	Yes	67%	97	0.04311022	0.024943	0.01816722	42.14%
4676	TPCODL	BBSR2	PED	SAKHIGOPAL	CHANDANPUR	14071	11 KV BIRANARSINGHPU	14071202	BHAILPUR BAZAR	2441DT418	100	MIXED	AMI	Yes	67%	46	0.0418286	0.01211	0.0297186	71.05%
4677	TPCODL	BBSR2	PED	SAKHIGOPAL	CHANDANPUR	14071	11 KV BALABHADRAPUR	14071203	SINGAMAPUR	2441DT178	100	MIXED	AMI	Yes	100%	35	0.05076116	0.013801	0.03696016	72.81%
4678	TPCODL	BBSR2	PED	SAKHIGOPAL	CHANDANPUR	14071	11 KV BALABHADRAPUR	14071203	BIRA KISHOREPUR	2441DT180	100	MIXED	AMI	Yes	100%	190	0.11376388	0.079349	0.03441488	30.25%
4679	TPCODL	BBSR2	PED	SAKHIGOPAL	CHANDANPUR	14071	11 KV BALABHADRAPUR	14071203	BUDHA LINGA SAHI	2441DT186	100	MIXED	AMI	Yes	100%	143	0.11938348	0.067117	0.05226648	43.78%
4680	TPCODL	BBSR2	PED	SAKHIGOPAL	CHANDANPUR	14071	11 KV BALABHADRAPUR	14071203	CHANDANPUR BADA BAZAR	2441DT188	100	MIXED	AMI	Yes	100%	126	0.13251048	0.090774	0.04173648	31.50%
4681	TPCODL	BBSR2	PED	SAKHIGOPAL	CHANDANPUR	14071	11 KV BALABHADRAPUR	14071203	GADI SAHI	2441DT191	250	MIXED	AMI	Yes	0%	144	0.14904684	0.056079	0.09296784	62.37%
4682	TPCODL	BBSR2	PED	SAKHIGOPAL	CHANDANPUR	14071	11 KV BALABHADRAPUR	14071203	PARAMANANDA PUR	2441DT194	100	MIXED	AMI	Yes	100%	94	0.07429822	0.0502	0.02409822	32.43%
4683	TPCODL	BBSR2	PED	SAKHIGOPAL	CHANDANPUR	14071	11 KV BALABHADRAPUR	14071203	BIRABALABHADRAPUR	2441DT195	250	MIXED	AMI	Yes	100%	184	0.09689164	0.067261	0.02963064	30.58%
4684	TPCODL	BBSR2	PED	SAKHIGOPAL	CHANDANPUR	14071	11 KV BALABHADRAPUR	14071203	SULAVADEIPUR	2441DT198	100	MIXED	AMI	Yes	100%	79	0.05089522	0.033508	0.01738722	34.16%
4685	TPCODL	BBSR2	PED	SAKHIGOPAL	CHANDANPUR	14071	11 KV BALABHADRAPUR	14071203	TULASI CHAURA-1	2441DT205	250	MIXED	AMI	Yes	100%	214	0.12200924	0.089489	0.03252024	26.65%
4686	TPCODL	BBSR2	PED	SAKHIGOPAL	GABAKUNDA (SUAN	14289	11 KV KETAKIPATNA	14289201	BILIPADA	2442DT005	100	MIXED	AMI	Yes	100%	82	0.02806808	0.018939	0.00912908	32.52%
4687	TPCODL	BBSR2	PED	SAKHIGOPAL	GABAKUNDA (SUAN	14289	11 KV KETAKIPATNA	14289201	BADABASANT	2442DT011	100	MIXED	AMI	Yes	67%	116	0.04641868	0.032342	0.01407668	30.33%
4688	TPCODL	BBSR2	PED	SAKHIGOPAL	GABAKUNDA (SUAN	14289	11 KV KETAKIPATNA	14289201	BIDHYADHARPUR	2442DT066	100	MIXED	AMI	Yes	100%	174	0.0706098	0.045462	0.0251478	35.62%
4689	TPCODL	BBSR2	PED	SAKHIGOPAL	GABAKUNDA (SUAN	14289	11 KV KETAKIPATNA	14289201	GUALIGORADA	2442DT071	100	MIXED	AMI	Yes	100%	40	0.02222204	0.01513	0.00709204	31.91%
4690	TPCODL	BBSR2	PED	SAKHIGOPAL	GABAKUNDA (SUAN	14289	11 KV KETAKIPATNA	14289201	KAHALPADA	2442DT074	100	MIXED	AMI	Yes	100%	115	0.04379518	0.033825	0.00997018	22.77%
4691	TPCODL	BBSR2	PED	SAKHIGOPAL	GABAKUNDA (SUAN	14289	11 KV KETAKIPATNA	14289201	MALA SAHI 2	2442DT107	100	MIXED	AMI	Yes	0%	101	0.0395252	0.024051	0.0154742	39.15%
4692	TPCODL	BBSR2	PED	SAKHIGOPAL	GABAKUNDA (SUAN	14289	11 KV KETAKIPATNA	14289201	BUDHAKERA BAZAR	2442DT110	100	MIXED	AMI	Yes	67%	30	0.01438562	0.00841	0.00597562	41.54%
4693	TPCODL	BBSR2	PED	SAKHIGOPAL	GABAKUNDA (SUAN	14289	11 KV KETAKIPATNA	14289201	RUDUPUR	2442DT118	100	MIXED	AMI	Yes	67%	21	0.01568228	0.005547	0.01013528	64.63%
4694	TPCODL	BBSR2	PED	SAKHIGOPAL	GABAKUNDA (SUAN	14289	11 KV KETAKIPATNA	14289201	BADATOTA 2	2442DT124	25	MIXED	AMI	Yes	67%	18	0.0213555	0.004879	0.0164765	77.15%
4695	TPCODL	BBSR2	PED	SAKHIGOPAL	GABAKUNDA (SUAN	14289	11 KV KETAKIPATNA	14289201	DHOJA	2442DT127	100	MIXED	AMI	Yes	67%	49	0.0300185	0.012267	0.0177515	59.14%
4696	TPCODL	BBSR2	PED	SAKHIGOPAL	GABAKUNDA (SUAN	14289	11 KV KETAKIPATNA	14289201	MIRZAPUR	2442DT133	100	MIXED	AMI	Yes	67%	73	0.02936978	0.016965	0.01240478	42.24%
4697	TPCODL	BBSR2	PED	SAKHIGOPAL	GABAKUNDA (SUAN	14289	11 KV KETAKIPATNA	14289201	DUBEPUR BARIK SAHI	2442DT167	100	MIXED	AMI	Yes	67%	31	0.02392966	0.007794	0.01613566	67.43%
4698	TPCODL	BBSR2	PED	SAKHIGOPAL	KUMARESWAR	14208	11 KV BALANGA	14208201	PARIPOTALI	2444DT167	100	MIXED	AMI	Yes	100%	124	0.0535915	0.032175	0.0214165	39.96%
4699	TPCODL	BBSR2	PED	SAKHIGOPAL	KUMARESWAR	14208	11 KV BALANGA	14208201	BADAJOPAN	2444DT192	100	MIXED	AMI	Yes	100%	40	0.01823618	0.012667	0.00556918	30.54%
4700	TPCODL	BBSR2	PED	SAKHIGOPAL	KUMARESWAR	14208	11 KV BALANGA	14208201	NUAHAT	2444DT194	100	MIXED	AMI	Yes	100%	176	0.07798552	0.054411	0.02357452	30.23%
4701	TPCODL	BBSR2	PED	SAKHIGOPAL	KUMARESWAR	14208	11 KV BALANGA	14208201	RATH PURUSOTTAMPURE	2444DT198	100	MIXED	AMI	Yes	100%	158	0.08042148	0.060558	0.01986348	24.70%
4702	TPCODL	BBSR2	PED	SAKHIGOPAL	KUMARESWAR	14208	11 KV BALANGA	14208201	GANDASAHI	2444DT210	100	MIXED	AMI	Yes	100%	62	0.03225584	0.021363	0.01089284	33.77%
4703	TPCODL	BBSR2	PED	SAKHIGOPAL	KUMARESWAR	14208	11 KV BALANGA	14208201	RUPEDEIPUR NO-3	2444DT215	100	MIXED	AMI	Yes	100%	92	0.05407826	0.037178	0.01690026	31.25%
4704	TPCODL	BBSR2	PED	SAKHIGOPAL	KUMARESWAR	14208	11 KV BALANGA	14208201	GHANDREADEIPUR GOPINATH	2444DT226	100	MIXED	AMI	Yes	67%	133	0.06891354	0.049042	0.01987154	28.84%
4705	TPCODL	BBSR2	PED	SAKHIGOPAL	KUMARESWAR	14208	11 KV BALANGA	14208201	CHANDRADEIPUR PRADHANSAHI	2444DT227	100	MIXED	AMI	Yes	67%	57	0.03043616	0.017282	0.01315416	43.22%
4706	TPCODL	BBSR2	PED	SAKHIGOPAL	KUMARESWAR	14208	11 KV BALANGA	14208201	MAUZHEG BADAPATNA	2444DT240	100	MIXED	AMI	Yes	0%	183	0.09507368	0.082525	0.01254868	13.20%
4707	TPCODL	BBSR2	PED	SAKHIGOPAL	KUMARESWAR	14208	11 KV BALANGA	14208201	MAUZHEG BADAPATNA	2444DT241	100	MIXED	AMI	Yes	67%	130	0.064884	0.052661	0.012223	18.84%
4708	TPCODL	BBSR2	PED	SAKHIGOPAL	KUMARESWAR	14208	11 KV BALANGA	14208201	PARVATIPUR	2444DT265	100	MIXED	AMI	Yes	67%	121	0.05117734	0.033014	0.01816334	35.49%
4709	TPCODL	BBSR2	PED	SAKHIGOPAL	KUMARESWAR	14208	11 KV BALANGA	14208201	NUA GOPALPUR-2	2444DT273	100	MIXED	AMI	Yes	67%	87	0.05471196	0.035996	0.01871596	34.21%
4710	TPCODL	BBSR2	PED	SAKHIGOPAL	KUMARESWAR	14208	11 KV BALANGA	14208201	TERAHALA-1	2444DT274	100	MIXED	AMI	Yes	67%	76	0.03702006	0.028399	0.00862106	23.29%
4711	TPCODL	BBSR2	PED	SAKHIGOPAL	KUMARESWAR	14208	11 KV BALANGA	14208201	TERAHALA-2	2444DT277	100	MIXED	AMI	Yes	67%	54	0.02957702	0.022989	0.00658802	22.27%
4712	TPCODL	BBSR2	PED	SAKHIGOPAL	KUMARESWAR	14208	11 KV BALANGA	14208201	GOPINATHPUR,HARIJAN SAHI	2444DT280	100	MIXED	AMI	Yes	67%	61	0.02176301	0.016073	0.00569001	26.15%
4713	TPCODL	BBSR2	PED	SAKHIGOPAL	KUMARESWAR	14208	11 KV SATASANKHA BAZ	14208203	SATSANKHA BAZAR	2444DT073	100	MIXED	AMI	Yes	100%	131	0.1127475	0.073117	0.0396305	35.15%
4714	TPCODL	BBSR2	PED	SAKHIGOPAL	KUMARESWAR	14208	11 KV SATASANKHA BAZ	14208203	SULTAN NAGAR	2444DT088	100	MIXED	AMI	Yes	67%	80	0.05577784	0.040457	0.01532084	27.47%
4715	TPCODL	BBSR2	PED	SAKHIGOPAL	KUMARESWAR	14208	11 KV SATASANKHA BAZ	14208203	PRAHARAJPUR VILLAGE	2444DT103	100	MIXED	AMI	Yes	67%	109	0.06851106	0.04582	0.02269106	33.12%
4716	TPCODL	BBSR2	PED	SAKHIGOPAL	SAKHIGOPAL	14072	11 KV EXPRESS	14072201	PODANG SAHI	2443DT031	100	MIXED	AMI	Yes	33%	89	0.11192558	0.086717	0.02520858	22.52%
4717	TPCODL	BBSR2	PED	SAKHIGOPAL	SAKHIGOPAL	14072	11 KV EXPRESS	14072201	SRI RAM CHANDRAPUR	2443DT039	100	MIXED	AMI	Yes	67%	55	0.08340386	0.017107	0.06629686	79.49%
4718	TPCODL	BBSR2	PED	SAKHIGOPAL	SAKHIGOPAL	14072	11 KV EXPRESS	14072201	SRI RAM CHANDRAPUR-1	2443DT041	100	MIXED	AMI	Yes	67%	91	0.07394642	0.032875	0.04107142	55.54%
4719	TPCODL	BBSR2	PED	SAKHIGOPAL	SAKHIGOPAL	14072	11 KV EXPRESS	14072201	MULAALASA	2443DT046	100	MIXED	AMI	Yes	100%	108	0.05328416	0.043808	0.00947616	17.78%
4720	TPCODL	BBSR2	PED	SAKHIGOPAL	SAKHIGOPAL	14072	11 KV EXPRESS	14072201	ALASARAN	2443DT050	100	MIXED	AMI	Yes	67%	138	0.07231252	0.042389	0.02992352	41.38%
4721	TPCODL	BBSR2	PED	SAKHIGOPAL	SAKHIGOPAL	14072	11 KV EXPRESS	14072201	TIKKI BIL SAHI	2443DT056	100	MIXED	AMI	Yes	67%	54	0.02718976	0.013021	0.01416876	52.11%
4722	TPCODL	BBSR2	PED	SAKHIGOPAL	SAKHIGOPAL	14072	11 KV EXPRESS	14072201	BAGULA PARI	2443DT070	100	MIXED	AMI	Yes	67%	78	0.0394429	0.017645	0.0217979	55.26%
4723	TPCODL	BBSR2	PED	SAKHIGOPAL	SAKHIGOPAL	14072	11 KV EXPRESS	14072201	TENTUDIYA	2443DT071	100	MIXED	AMI	Yes	67%	116	0.05255892	0.030094	0.02246492	42.74%
4724	TPCODL	BBSR2	PED	SAKHIGOPAL	SAKHIGOPAL	14072	11 KV EXPRESS	14072201	GHASI BHAWANIPUR	2443DT091	100	MIXED	AMI	Yes	67%	95	0.04555254	0.015911	0.02964154	65.07%
4725	TPCODL	BBSR2	PED	SAKHIGOPAL	SAKHIGOPAL	14072	11 KV EXPRESS	14072201	PURANA SOMESHWARPUR BILLAGE	2443DT159	100	MIXED	AMI	Yes	67%	127	0.0529537	0.033394	0.0195597	36.94%
4726	TPCODL	BBSR2	PED	SAKHIGOPAL	SAKHIGOPAL	14072	11 KV EXPRESS	14072201	NARENDRAPUR	2443DT178	100	MIXED	AMI	Yes	67%	167	0.06945714	0.043882	0.02557514	36.82%
4727	TPCODL	BBSR2	PED	SAKHIGOPAL	SAKHIGOPAL	14072	11 KV EXPRESS	14072201	BATULI PADA	2443DT186	100	MIXED	AMI	Yes	67%	133	0.06772436	0.0305381	0.03718626	54.91%
4728	TPCODL	BBSR2	PED	SAKHIGOPAL	SAKHIGOPAL	14072	11 KV EXPRESS	14072201	KHANDAYAT SAHI	2443DT202	100	MIXED	AMI	Yes	67%	73	0.03928688	0.018694	0.02059288	52.42%
4729	TPCODL	BBSR2	PED	SAKHIGOPAL	SAKHIGOPAL	14072	11 KV EXPRESS	14072201	ALGUM	2443DT203	200	MIXED	AMI	Yes	0%	188	0.06730114	0.057456	0.00984514	14.63%
4730	TPCODL	BBSR2	PED	SAKHIGOPAL	SAKHIGOPAL	14072	11 KV EXPRESS	14072201	SINGAR KODA	2443DT234	100	MIXED	AMI	Yes	67%	90	0.0350006	0.020309	0.0146916	41.98%
4731	TPCODL	BBSR2	PED	SAKHIGOPAL	SAKHIGOPAL	14072	11 KV EXPRESS	14072201	INDIPUR V HARI KHAND	2443DT249	100	MIXED	AMI	Yes	67%	102	0.0538971	0.038284	0.0156131	28.97%
4732	TPCODL	BBSR2	PED	SAKHIGOPAL	SAKHIGOPAL	14072	11 KV EXPRESS	14072201	INDIPUR BAZAR-1	2443DT254	100	MIXED	AMI	Yes	67%	57	0.05232618	0.021667	0.03065918	58.59%
4733	TPCODL	BBSR2	PED	SAKHIGOPAL	SAKHIGOPAL	14072	11 KV EXPRESS	14072201	INDIPUR BADA SAHI	2443DT277	100	MIXED	AMI	Yes	0%	83	0.05782746	0.02215592	0.03567154	61.69%
4734	TPCODL	BBSR2	PED	SAKHIGOPAL	SAKHIGOPAL	14072	11 KV EXPRESS	14072201	KUMBHAR PADA ROAD	2443DT298	100	MIXED	AMI	Yes	67%	73	0.04430778	0.011934	0.03237378	73.07%
4735	TPCODL	BBSR2	PED	SAKHIGOPAL	SAKHIGOPAL	14072	11 KV EXPRESS	14072201	BANPUR	2443DT309	100	MIXED	AMI	Yes	67%	63	0.02928008	0.017325	0.01195508	40.83%
4736	TPCODL	BBSR2	PED	SAKHIGOPAL	SAKHIGOPAL	14072	11 KV EXPRESS	14072201	SUKAL AISHAN PADA	2443DT315	100	MIXED	AMI	Yes	67%	117	0.04001486	0.021737	0.01827786	45.68%
4737	TPCODL	BBSR2	PED	SAKHIGOPAL	SAKHIGOPAL	14072	11 KV EXPRESS	14072201	SUKAL BADA PADA	2443DT322	100	MIXED	AMI	Yes	67%	144	0.05445592	0.031764	0.02269192	41.67%
4738	TPCODL	BBSR2	PED	SAKHIGOPAL	SAKHIGOPAL	14072	11 KV EXPRESS	14072201	BAMBARDA TALAS	2443DT339	100	MIXED	AMI	Yes	67%	147	0.05823696	0.033286	0.02495096	42.84%
4739	TPCODL	BBSR2	PED	SAKHIGOPAL	SAKHIGOPAL	14072	11 KV EXPRESS	14072201	ALIS	2443DT348	100	MIXED	AMI	Yes	67%	167	0.06675756	0.038909	0.02784856	41.72%
4740	TPCODL	BBSR2	PED	SAKHIGOPAL	SAKHIGOPAL	14072	11 KV EXPRESS	14072201	ABHAYAMUKHI	2443DT352	63	MIXED	AMI	Yes	67%	6	0.00193564	0.001881	5.464E-05	2.82%
4741	TPCODL	BBSR2	PED	SAKHIGOPAL	SAKHIGOPAL	14072	11 KV EXPRESS	14072201	DAHAN	2443DT356	63	MIXED	AMI	Yes	0%	4	0.00017876	0.000168	0.00001076	6.02%
4742	TPCODL	BBSR2	PED	SAKHIGOPAL	SAKHIGOPAL	14072	11 KV EXPRESS	14072201	DAHAN	2443DT357	63	MIXED	AMI	Yes	0%	6	0.00265322	0.001351	0.00130222	49.08%
4743	TPCODL	BBSR2	PED	SAKHIGOPAL	SAKHIGOPAL	14072	11 KV SATASANKHA	14072202	BADAKANJIYA-2	2444DT001	100	MIXED	AMI	Yes	67%	90	0.05728564	0.048103	0.00918264	16.03%
4744	TPCODL	BBSR2	PED	SAKHIGOPAL	SAKHIGOPAL	14072	11 KV SATASANKHA	14072202	BADAKANJIYA-1	2444DT002	100	MIXED	AMI	Yes	0%	82	0.05890208	0.037632	0.02127008	36.11%

Sl. No.	Zone Name	Circle name	Division name	Name of the Sub-division	Name of the Sub-station	Substation Code	Name of the 11 kV Feeder	Feeder Code	Name of the Location where DT situated	DT code	DT Capacity (kVA)	Predominant consumer type of DT (Domestic/Industrial/Agriculture/Mixed)	Type of metering AMR/AMI/ Communicable/Conventional metered/Unmetered	Status of Meter-whether Functional (Yes/No)	% of data received automatically (if AMR/AMI)	No. of Connected Consumers	Input Energy (MU) (A)	Billed Energy (MU) (B)	Loss (MU) (A-B)	% DT Loss (A-B)/A
4745	TPCODL	BBSR2	PED	SAKHIGOPAL	SAKHIGOPAL	14072	11 KV SATASANKHA	14072202	BIRAMCHANDRAPUR-1	2444DT013	100	MIXED	AMI	Yes	67%	60	0.03866128	0.024449	0.01421228	36.76%
4746	TPCODL	BBSR2	PED	SAKHIGOPAL	SAKHIGOPAL	14072	11 KV SATASANKHA	14072202	KABIRAJPURBALI SAHI	2444DT018	100	MIXED	AMI	Yes	67%	168	0.08270488	0.059182	0.02352288	28.44%
4747	TPCODL	BBSR2	PED	SAKHIGOPAL	SAKHIGOPAL	14072	11 KV SATASANKHA	14072202	CHANDRAKOT	2444DT019	100	MIXED	AMI	Yes	67%	140	0.06665372	0.046743	0.01991072	29.87%
4748	TPCODL	BBSR2	PED	SAKHIGOPAL	SAKHIGOPAL	14072	11 KV SATASANKHA	14072202	KADWA VILLAGE	2444DT025	100	MIXED	AMI	Yes	67%	87	0.05824066	0.041708	0.01653266	28.39%
4749	TPCODL	BBSR2	PED	SAKHIGOPAL	SAKHIGOPAL	14072	11 KV SATASANKHA	14072202	CHAUD BATIYA	2444DT032	100	MIXED	AMI	Yes	67%	38	0.02579752	0.019026	0.00677152	26.25%
4750	TPCODL	BBSR2	PED	SAKHIGOPAL	SAKHIGOPAL	14072	11 KV SARANGAJODI	14072203	BAIPANDA	2442DT187	100	MIXED	AMI	Yes	67%	79	0.0272816	0.017916	0.0093656	34.33%
4751	TPCODL	BBSR2	PED	SAKHIGOPAL	SAKHIGOPAL	14072	11 KV SARANGAJODI	14072203	BADAPUR	2442DT196	100	MIXED	AMI	Yes	67%	117	0.04595652	0.032792	0.01316452	28.65%
4752	TPCODL	BBSR2	PED	SAKHIGOPAL	SAKHIGOPAL	14072	11 KV SARANGAJODI	14072203	KOTOSAHI SHASHAN	2442DT210	100	MIXED	AMI	Yes	67%	38	0.02593602	0.018645	0.00729102	28.11%
4753	TPCODL	BBSR2	PED	SAKHIGOPAL	SAKHIGOPAL	14072	11 KV SARANGAJODI	14072203	BALIPOKHARI-1	2442DT216	100	MIXED	AMI	Yes	67%	99	0.04508058	0.027022	0.01805858	40.06%
4754	TPCODL	BBSR2	PED	SAKHIGOPAL	SAKHIGOPAL	14072	11 KV SARANGAJODI	14072203	DAKHNIYA SAHI	2442DT221	100	MIXED	AMI	Yes	33%	78	0.08005484	0.025571	0.05448384	68.06%
4755	TPCODL	BBSR2	PED	SAKHIGOPAL	SAKHIGOPAL	14072	11 KV SARANGAJODI	14072203	RAICHAKRA DHARPUR SASAN	2442DT248	100	MIXED	AMI	Yes	67%	75	0.04342104	0.033865	0.00955604	22.01%
4756	TPCODL	BBSR2	PED	SAKHIGOPAL	SAKHIGOPAL	14072	11 KV SARANGAJODI	14072203	PATNA SAI	2442DT249	100	MIXED	AMI	Yes	67%	113	0.03901718	0.028978	0.01003918	25.73%
4757	TPCODL	BBSR2	PED	SAKHIGOPAL	SAKHIGOPAL	14072	11 KV SARANGAJODI	14072203	HATSAHI	2442DT250	100	MIXED	AMI	Yes	67%	114	0.0594697	0.039513	0.0199567	33.56%
4758	TPCODL	BBSR2	PED	SAKHIGOPAL	SAKHIGOPAL	14072	11 KV SARANGAJODI	14072203	KALIPADA	2442DT253	100	MIXED	AMI	Yes	67%	22	0.01657769	0.010548	0.00602969	36.37%
4759	TPCODL	BBSR2	PED	SAKHIGOPAL	SAKHIGOPAL	14072	11 KV SARANGAJODI	14072203	BALIPADA-2	2442DT258	63	MIXED	AMI	Yes	67%	87	0.03679306	0.024331	0.01246206	33.87%
4760	TPCODL	BBSR2	PED	SAKHIGOPAL	SAKHIGOPAL	14072	11 KV SARANGAJODI	14072203	BALIPADA-3	2442DT259	100	MIXED	AMI	Yes	0%	95	0.04798158	0.03454	0.01344158	28.01%
4761	TPCODL	BBSR2	PED	SAKHIGOPAL	SAKHIGOPAL	14072	11 KV SARANGAJODI	14072203	LAMDU PADA	2442DT268	100	MIXED	AMI	Yes	100%	72	0.0271078	0.019804	0.0073038	26.94%
4762	TPCODL	BBSR2	PED	SAKHIGOPAL	SAKHIGOPAL	14072	11 KV SARANGAJODI	14072203	DUGAL-1	2442DT271	100	MIXED	AMI	Yes	67%	96	0.0330404	0.024774	0.0082664	25.02%
4763	TPCODL	BBSR2	PED	SAKHIGOPAL	SAKHIGOPAL	14072	11 KV SARANGAJODI	14072203	VISHWNATHPUR	2442DT280	250	MIXED	AMI	Yes	67%	171	0.11202128	0.069118	0.04290328	38.30%
4764	TPCODL	BBSR2	PED	SAKHIGOPAL	SAKHIGOPAL	14072	11 KV SAKHIGOPALA	14072204	JAIPUR VESARIYA SAHI-2	2442DT292	100	MIXED	AMI	Yes	67%	82	0.04382454	0.025002	0.01882254	42.95%
4765	TPCODL	BBSR2	PED	SAKHIGOPAL	SAKHIGOPAL	14072	11 KV SAKHIGOPALA	14072204	MAHAVIR COLONY	2442DT303	100	MIXED	AMI	Yes	100%	42	0.04359696	0.02937	0.01422696	32.63%
4766	TPCODL	BBSR2	PED	SAKHIGOPAL	SAKHIGOPAL	14072	11 KV SAKHIGOPALA	14072204	SATYAWADI,BLOCK	2442DT304	100	MIXED	AMI	Yes	100%	103	0.07585326	0.051423	0.02443026	32.21%
4767	TPCODL	BBSR2	PED	SAKHIGOPAL	SAKHIGOPAL	14072	11 KV SAKHIGOPALA	14072204	ATYASI BOI SAHI	2442DT307	100	MIXED	AMI	Yes	100%	42	0.01669024	0.010979	0.00571124	34.22%
4768	TPCODL	BBSR2	PED	SAKHIGOPAL	SAKHIGOPAL	14072	11 KV SAKHIGOPALA	14072204	BADA HALT	2442DT318	100	MIXED	AMI	Yes	67%	165	0.09403264	0.058385	0.03564764	37.91%
4769	TPCODL	BBSR2	PED	SAKHIGOPAL	SAKHIGOPAL	14072	11 KV SAKHIGOPALA	14072204	CHANDUKA	2442DT331	250	MIXED	AMI	Yes	100%	13	0.0072054	0.003668	0.0035374	49.09%
4770	TPCODL	BBSR2	PED	SAKHIGOPAL	SAKHIGOPAL	14072	11 KV SAKHIGOPALA	14072204	MARKET-2	2442DT345	250	MIXED	AMI	Yes	67%	286	0.18943616	0.145467	0.04396916	23.21%
4771	TPCODL	BBSR2	PED	SAKHIGOPAL	SAKHIGOPAL	14072	11 KV SAKHIGOPALA	14072204	KANJIYA-1	2442DT354	500	MIXED	AMI	Yes	0%	299	0.40654152	0.145868	0.26067352	64.12%
4772	TPCODL	BBSR2	PED	SAKHIGOPAL	SAKHIGOPAL	14072	11 KV SAKHIGOPALA	14072204	PANAS PATNA	2443DT005	63	MIXED	AMI	Yes	100%	110	0.05522166	0.046431	0.00879066	15.92%
4773	TPCODL	BBSR2	PED	SAKHIGOPAL	SAKHIGOPAL	14072	11 KV SAKHIGOPALA	14072204	BADA BAZAR	2443DT006	100	MIXED	AMI	Yes	100%	106	0.0776656	0.059795	0.0178706	23.01%
4774	TPCODL	BBSR2	PED	SAKHIGOPAL	SAKHIGOPAL	14072	11 KV SAKHIGOPALA	14072204	KALINGA VIHAR	2443DT007	100	MIXED	AMI	Yes	100%	98	0.05050734	0.04183	0.00867734	17.18%
4775	TPCODL	BBSR2	PED	SAKHIGOPAL	SAKHIGOPAL	14072	11 KV SAKHIGOPALA	14072204	GOPALPUR PATNA	2443DT012	250	MIXED	AMI	Yes	0%	141	0.09627808	0.07412	0.02215808	23.01%
4776	TPCODL	BBSR2	PED	SAKHIGOPAL	SAKHIGOPAL	14072	11 KV SAKHIGOPALA	14072204	GOPALPUR PATNA	2443DT013	100	MIXED	AMI	Yes	100%	66	0.05667966	0.032263	0.02441666	43.08%
4777	TPCODL	BBSR2	PED	SAKHIGOPAL	SAKHIGOPAL	14072	11 KV SAKHIGOPALA	14072204	RAGNI SAHI	2443DT014	100	MIXED	AMI	Yes	100%	54	0.0550838	0.032263	0.0228208	41.43%
4778	TPCODL	BBSR2	PED	SAKHIGOPAL	SAKHIGOPAL	14072	11 KV SAKHIGOPALA	14072204	CHANDN POKHARI	2443DT015	500	MIXED	AMI	Yes	100%	291	0.20690944	0.145346	0.06156344	29.75%
4779	TPCODL	BBSR2	PED	SAKHIGOPAL	SAKHIGOPAL	14072	11 KV SAKHIGOPALA	14072204	SAKHIGOPAL TEMPLE-1	2443DT018	100	MIXED	AMI	Yes	100%	23	0.03421048	0.009407	0.02480348	72.50%
4780	TPCODL	BBSR2	PED	SAKHIGOPAL	SAKHIGOPAL	14072	11 KV SAKHIGOPALA	14072204	SAKHIGOPAL TEMPLE-2	2443DT019	200	MIXED	AMI	Yes	0%	177	0.0879055	0.078456	0.0094495	10.75%
4781	TPCODL	BBSR2	PED	SAKHIGOPAL	SAKHIGOPAL	14072	11 KV SAKHIGOPALA	14072204	SAKHIGOPAL TEMPLE BACKSIDE	2443DT020	100	MIXED	AMI	Yes	100%	23	0.03699274	0.015065	0.02192774	59.28%
4782	TPCODL	BBSR2	PED	SAKHIGOPAL	SAKHIGOPAL	14072	11 KV SAKHIGOPALA	14072204	SUBRADM COLONY	2443DT027	100	MIXED	AMI	Yes	67%	119	0.08044582	0.065179	0.01526682	18.98%
4783	TPCODL	CUTTACK	AED	ATHAGADA	SARANDA ODSSP	14306	11 kV KANTAPANHARA	14306201	KANTAPANHA TANGI NEW-5	3422DT599	100	MIXED	AMI	Yes	67%	44	0.0551782	0.011214	0.0439642	79.68%
4784	TPCODL	CUTTACK	AED	ATHAGADA	NUAPATANA	17023	33 kV NUAPATNA	17023403	33/11 kV NUAPATANA SS ST	3424DT235	100	MIXED	AMI	Yes	0%	1	0.00464286	0.004643	-1.4E-07	0.00%
4785	TPCODL	CUTTACK	AED	ATHAGADA	TIGIRIA	14115	11 KV TIGIRIA	14115203	33/11 kV TIGIRIA SS ST	3425DT346	100	MIXED	AMI	Yes	0%	1	0.0027892	0.002789	2E-07	0.01%
4786	TPCODL	CUTTACK	AED	ATHAGADA	ATHAGARH	14116	11 KV ATHAGARH TOWN	14116201	RASARASIKAPUR1	3421DT001	250	MIXED	AMI	Yes	100%	186	0.25154592	0.101553	0.14999292	59.63%
4787	TPCODL	CUTTACK	AED	ATHAGADA	ATHAGARH	14116	11 KV ATHAGARH TOWN	14116201	HANUMAN TEMPLE	3421DT002	250	MIXED	AMI	Yes	100%	195	0.22085868	0.148642	0.07221668	32.70%
4788	TPCODL	CUTTACK	AED	ATHAGADA	ATHAGARH	14116	11 KV ATHAGARH TOWN	14116201	COLLEGE FRONT (RAJABATI NAGAR 2	3421DT005	250	MIXED	AMI	Yes	33%	140	0.22054088	0.118512	0.10202888	46.26%
4789	TPCODL	CUTTACK	AED	ATHAGADA	ATHAGARH	14116	11 KV ATHAGARH TOWN	14116201	GOPABANDHU CHHACK	3421DT019	500	MIXED	AMI	Yes	100%	223	0.3030536	0.094969	0.2080846	68.66%
4790	TPCODL	CUTTACK	AED	ATHAGADA	ATHAGARH	14116	11 KV ATHAGARH TOWN	14116201	GIRLS HIGH SCHOOL	3421DT022	250	MIXED	AMI	Yes	100%	163	0.25005828	0.082242	0.16781628	67.11%
4791	TPCODL	CUTTACK	AED	ATHAGADA	ATHAGARH	14116	11 KV ATHAGARH TOWN	14116201	GADA SAHI	3421DT023	250	MIXED	AMI	Yes	100%	142	0.2033498	0.048877	0.1544728	75.96%
4792	TPCODL	CUTTACK	AED	ATHAGADA	ATHAGARH	14116	11 KV ATHAGARH TOWN	14116201	MICRO	3421DT030	100	MIXED	AMI	Yes	0%	91	0.14814844	0.051565	0.09658344	65.19%
4793	TPCODL	CUTTACK	AED	ATHAGADA	ATHAGARH	14116	11 KV ATHAGARH TOWN	14116201	PWD OFFICE	3421DT033	100	MIXED	AMI	Yes	100%	90	0.10570384	0.062237	0.04346684	41.12%
4794	TPCODL	CUTTACK	AED	ATHAGADA	ATHAGARH	14116	11 KV ATHAGARH TOWN	14116201	NAC OFFICE	3421DT035	500	MIXED	AMI	Yes	33%	263	0.48650648	0.237782	0.24872448	51.12%
4795	TPCODL	CUTTACK	AED	ATHAGADA	ATHAGARH	14116	11 KV ATHAGARH TOWN	14116201	BIRAKISHOREPUR 1	3421DT037	250	MIXED	AMI	Yes	67%	165	0.2423522	0.164884	0.0774682	31.97%
4796	TPCODL	CUTTACK	AED	ATHAGADA	ATHAGARH	14116	11 KV ATHAGARH TOWN	14116201	BIRAKISHOREPUR 2	3421DT038	250	MIXED	AMI	Yes	0%	156	0.20829728	0.099886	0.10841128	52.05%
4797	TPCODL	CUTTACK	AED	ATHAGADA	ATHAGARH	14116	11 KV ATHAGARH TOWN	14116201	RADHAPATIPUR	3421DT039	250	MIXED	AMI	Yes	100%	199	0.2489696	0.127919	0.1210506	48.62%
4798	TPCODL	CUTTACK	AED	ATHAGADA	ATHAGARH	14116	11 KV ATHAGARH TOWN	14116201	RCMS	3421DT041	100	MIXED	AMI	Yes	100%	63	0.06552604	0.048102	0.01742404	26.59%
4799	TPCODL	CUTTACK	AED	ATHAGADA	ATHAGARH	14116	11 KV ATHAGARH TOWN	14116201	KANGADASAHI	3421DT046	100	MIXED	AMI	Yes	100%	126	0.12536822	0.083725	0.04164322	33.22%
4800	TPCODL	CUTTACK	AED	ATHAGADA	ATHAGARH	14116	11 KV ATHAGARH TOWN	14116201	BANIKANTHA NGR4	3421DT053	100	MIXED	AMI	Yes	100%	71	0.086253	0.058726	0.027527	31.91%
4801	TPCODL	CUTTACK	AED	ATHAGADA	ATHAGARH	14116	11 KV ATHAGARH TOWN	14116201	UTTARACHANDI	3421DT076	100	MIXED	AMI	Yes	0%	85	0.16520464	0.05052	0.11468464	69.42%
4802	TPCODL	CUTTACK	AED	ATHAGADA	ATHAGARH	14116	11 KV ATHAGARH TOWN	14116201	RASARASIKPUR SHANI TEMPLE	3421DT110	250	MIXED	AMI	Yes	100%	82	0.08550864	0.063472	0.02203664	25.77%
4803	TPCODL	CUTTACK	AED	ATHAGADA	ATHAGARH	14116	11 KV ATHAGARH TOWN	14116201	HOUSING BORD COLONY	3421DT112	500	MIXED	AMI	Yes	100%	323	0.27559752	0.160842	0.11475552	41.64%
4804	TPCODL	CUTTACK	AED	ATHAGADA	ATHAGARH	14116	11 KV ATHAGARH TOWN	14116201	SAMSARPUR-1	3422DT337	100	MIXED	AMI	Yes	67%	193	0.12173004	0.037881	0.08384904	68.88%
4805	TPCODL	CUTTACK	AED	ATHAGADA	ATHAGARH	14116	11 KV ATHAGARH TOWN	14116201	SAMSARPUR-2	3422DT341	100	MIXED	AMI	Yes	33%	190	0.10541074	0.021384	0.08402674	79.71%
4806	TPCODL	CUTTACK	AED	ATHAGADA	ATHAGARH	14116	11 KV ATHAGARH TOWN	14116201	SANKR PUR	3422DT348	100	MIXED	AMI	Yes	67%	104	0.09067258	0.026423	0.06424958	70.86%
4807	TPCODL	CUTTACK	AED	ATHAGADA	ATHAGARH	14116	11 KV ATHAGARH TOWN	14116201	SANKR PUR	3422DT352	100	MIXED	AMI	Yes	67%	113	0.10819234	0.029174	0.07901834	73.04%
4808	TPCODL	CUTTACK	AED	ATHAGADA	ATHAGARH	14116	11 KV ATHAGARH TOWN	14116201	SANKAR PUR BAZAR	3422DT357	250	MIXED	AMI	Yes	0%	118	0.13487932	0.055684	0.07919532	58.72%
4809	TPCODL	CUTTACK	AED	ATHAGADA	ATHAGARH	14116	11 KV ATHAGARH TOWN	14116201	PAMALA	3422DT381	100	MIXED	AMI	Yes	33%	162	0.1238176	0.04072	0.0830976	67.11%
4810	TPCODL	CUTTACK	AED	ATHAGADA	ATHAGARH	14116	11 KV KARIKOLA	14116202	PAIKERAPUR BHADRALOKA	3422DT218	100	MIXED	AMI	Yes	67%	106	0.06836004	0.023998	0.04436204	64.89%
4811	TPCODL	CUTTACK	AED	ATHAGADA	ATHAGARH	14116	11 KV KARIKOLA	14116202	GOPINATHPUR MOHANTY SAHI	3422DT223	250	MIXED	AMI	Yes	67%	69	0.07867912	0.021873	0.05680612	72.20%
4812	TPCODL	CUTTACK	AED	ATHAGADA	ATHAGARH	14116	11 KV KARIKOLA	14116202	PATALINGA	3422DT234	100	MIXED	AMI	Yes	67%	100	0.0654783	0.028158	0.0373203	57.00%
4813	TPCODL	CUTTACK	AED	ATHAGADA	ATHAGARH	14116	11 KV KARIKOLA	14116202	KARIKOL1	3422DT268	100	MIXED	AMI	Yes	67%	87	0.11407485	0.03203	0.08204485	71.92%
4814	TPCODL	CUTTACK	AED	ATHAGADA	ATHAGARH	14116	11 KV KARIKOLA	14116202	KARIKOL-2	3422DT271	100	MIXED	AMI	Yes	67%	123	0.12030307	0.036162	0.08414107	69.94%
4815	TPCODL	CUTTACK	AED	ATHAGADA	ATHAGARH	14116	11 KV KARIKOLA	14116202	HARDAGAHIRI	3422DT272	100	MIXED	AMI	Yes	100%	91	0.0690071	0.027535	0.0414721	60.10%
4816	TPCODL	CUTTACK	AED	ATHAGADA	ATHAGARH	14116	11 KV KARIKOLA	14116202	PARASURAM PUR	3422DT273	100	MIXED	AMI	Yes	67%	68	0.06674236	0.016772	0.04997036	74.87%
4817	TPCODL	CUTTACK	AED	ATHAGADA	ATHAGARH	14116	11 KV KARIKOLA	14116202	MANJARIPADA	3422DT277	100	MIXED	AMI	Yes	67%	41	0.0510444	0.014156	0.0368884	72.27%

Sl. No.	Zone Name	Circle name	Division name	Name of the Sub-division	Name of the Sub-station	Substation Code	Name of the 11 kV Feeder	Feeder Code	Name of the Location where DT situated	DT code	DT Capacity (kVA)	Predominant consumer type of DT (Domestic/Industrial/Agriculture/Mixed)	Type of metering AMR/AMI/ Communicable/Conventional metered/Unmetered	Status of Meter-whether Functional (Yes/No)	% of data received automatically (if AMR/AMI)	No. of Connected Consumers	Input Energy (MU) (A)	Billed Energy (MU) (B)	Loss (MU) (A-B)	% DT Loss (A-B)/A
4818	TPCODL	CUTTACK	AED	ATHAGADA	ATHAGARH	14116	11 KV KARIKOLA	14116202	MANJARIPADA BPL	3422DT278	63	MIXED	AMI	Yes	0%	60	0.01960338	0.012689	0.00691438	35.27%
4819	TPCODL	CUTTACK	AED	ATHAGADA	ATHAGARH	14116	11 KV KARIKOLA	14116202	DAHISARA-1	3422DT284	100	MIXED	AMI	Yes	0%	158	0.06048226	0.024531	0.03595126	59.44%
4820	TPCODL	CUTTACK	AED	ATHAGADA	ATHAGARH	14116	11 KV KARIKOLA	14116202	CHAMPAPIR-2	3422DT293	100	MIXED	AMI	Yes	67%	89	0.0781913	0.0288	0.0493913	63.17%
4821	TPCODL	CUTTACK	AED	ATHAGADA	ATHAGARH	14116	11 KV KARIKOLA	14116202	MAHAKALABASTA	3422DT305	100	MIXED	AMI	Yes	67%	111	0.07627522	0.022128	0.05414722	70.99%
4822	TPCODL	CUTTACK	AED	ATHAGADA	ATHAGARH	14116	11 KV KARIKOLA	14116202	TARDING MAJHI SAI	3422DT438	63	MIXED	AMI	Yes	67%	24	0.03202636	0.00858305	0.02344331	73.20%
4823	TPCODL	CUTTACK	AED	ATHAGADA	ATHAGARH	14116	11 KV KARIKOLA	14116202	METRO BETAKHOLI	3422DT490	250	MIXED	AMI	Yes	67%	55	0.011224	0.009494	0.00173	15.41%
4824	TPCODL	CUTTACK	AED	ATHAGADA	ATHAGARH	14116	11 KV KARIKOLA	14116202	HANA SABHANUI	3422DT497	100	MIXED	AMI	Yes	67%	73	0.03882304	0.016226	0.02259704	58.21%
4825	TPCODL	CUTTACK	AED	ATHAGADA	ATHAGARH	14116	11 KV KARIKOLA	14116202	BANTAPADA	3422DT502	250	MIXED	AMI	Yes	0%	174	0.13529332	0.052751	0.08254232	61.01%
4826	TPCODL	CUTTACK	AED	ATHAGADA	ATHAGARH	14116	11 KV KARIKOLA	14116202	BANTAPADA	3422DT503	100	MIXED	AMI	Yes	67%	81	0.1005918	0.031067	0.0695248	69.12%
4827	TPCODL	CUTTACK	AED	ATHAGADA	ATHAGARH	14116	11 KV KARIKOLA	14116202	DORADA-2	3422DT513	100	MIXED	AMI	Yes	67%	87	0.091696	0.047471	0.044225	48.23%
4828	TPCODL	CUTTACK	AED	ATHAGADA	ATHAGARH	14116	11 KV KARIKOLA	14116202	TARSHIN	3422DT693	100	MIXED	AMI	Yes	67%	58	0.02964656	0.014641	0.01500556	50.61%
4829	TPCODL	CUTTACK	AED	ATHAGADA	ATHAGARH	14116	11 KV ANKULO	14116203	NEW ANKULA	3422DT002	100	MIXED	AMI	Yes	67%	124	0.05064512	0.045809	0.00483612	9.55%
4830	TPCODL	CUTTACK	AED	ATHAGADA	ATHAGARH	14116	11 KV ANKULO	14116203	KANKADAGADHIA-2	3422DT006	100	MIXED	AMI	Yes	67%	49	0.06437442	0.019938	0.04443642	69.03%
4831	TPCODL	CUTTACK	AED	ATHAGADA	ATHAGARH	14116	11 KV ANKULO	14116203	OLD ANKULA-1	3422DT012	100	MIXED	AMI	Yes	67%	80	0.06700894	0.02792	0.03908894	58.33%
4832	TPCODL	CUTTACK	AED	ATHAGADA	ATHAGARH	14116	11 KV ANKULO	14116203	OLD ANKULA-2	3422DT019	100	MIXED	AMI	Yes	0%	40	0.04253406	0.014459	0.02807506	66.01%
4833	TPCODL	CUTTACK	AED	ATHAGADA	ATHAGARH	14116	11 KV ANKULO	14116203	NADUAPADA	3422DT020	100	MIXED	AMI	Yes	33%	85	0.03472619	0.029308	0.00541819	15.60%
4834	TPCODL	CUTTACK	AED	ATHAGADA	ATHAGARH	14116	11 KV ATHAGARH KANTO	14116204	KANTOL HANUMAN	3421DT062	250	MIXED	AMI	Yes	100%	306	0.32748132	0.109654	0.21782732	66.52%
4835	TPCODL	CUTTACK	AED	ATHAGADA	ATHAGARH	14116	11 KV ATHAGARH KANTO	14116204	RASARASIKAPUR	3421DT090	100	MIXED	AMI	Yes	100%	134	0.11808946	0.051769	0.06632046	56.16%
4836	TPCODL	CUTTACK	AED	ATHAGADA	ATHAGARH	14116	11 KV DORODA	14116205	DORADA-1	3422DT512	250	MIXED	AMI	Yes	67%	197	0.17022172	0.062388	0.10783372	63.35%
4837	TPCODL	CUTTACK	AED	ATHAGADA	ATHAGARH	14116	11 KV DORODA	14116205	DEOPADA-2	3422DT539	100	MIXED	AMI	Yes	0%	117	0.1153278	0.075564	0.0397638	34.48%
4838	TPCODL	CUTTACK	AED	ATHAGADA	ATHAGARH	14116	11 KV DORODA	14116205	MANIPUR-2	3422DT545	100	MIXED	AMI	Yes	67%	180	0.09579218	0.058778	0.03701418	38.64%
4839	TPCODL	CUTTACK	AED	ATHAGADA	ATHAGARH	14116	11 KV DHAIPUR	14116206	NANDEILO	3422DT263	100	MIXED	AMI	Yes	67%	65	0.0303075	0.019102	0.0112055	36.97%
4840	TPCODL	CUTTACK	AED	ATHAGADA	ATHAGARH	14116	11 KV DHAIPUR	14116206	KANDHARPUR	3422DT392	100	MIXED	AMI	Yes	67%	176	0.0926695	0.051474	0.0411955	44.45%
4841	TPCODL	CUTTACK	AED	ATHAGADA	ATHAGARH	14116	11 KV DHAIPUR	14116206	KANDHARPUR TANGI SHAHI	3422DT395	100	MIXED	AMI	Yes	67%	83	0.06028872	0.022884	0.03740472	62.04%
4842	TPCODL	CUTTACK	AED	ATHAGADA	ATHAGARH	14116	11 KV DHAIPUR	14116206	PHUL BARI	3422DT402	100	MIXED	AMI	Yes	67%	104	0.05067238	0.029312	0.02136038	42.15%
4843	TPCODL	CUTTACK	AED	ATHAGADA	ATHAGARH	14116	11 KV DHAIPUR	14116206	LASHHMI NARAYAN PUR	3422DT427	100	MIXED	AMI	Yes	67%	58	0.0508058	0.019328	0.0314778	61.96%
4844	TPCODL	CUTTACK	AED	ATHAGADA	BANDALO (BAUNSA	14307	11 KV GADADHARAPUR	14307201	RAGHURAMPUR	3425DT225	100	MIXED	AMI	Yes	0%	105	0.09511656	0.028562	0.06655456	69.97%
4845	TPCODL	CUTTACK	AED	ATHAGADA	BANDALO (BAUNSA	14307	11 KV GADADHARAPUR	14307201	GADADHARPUR	3425DT239	250	MIXED	AMI	Yes	67%	145	0.14046	0.045177	0.095283	67.84%
4846	TPCODL	CUTTACK	AED	ATHAGADA	BANDALO (BAUNSA	14307	11 KV MANAPUR	14307202	MANAPUR	3425DT254	250	MIXED	AMI	Yes	0%	149	0.18067012	0.036665	0.14400512	79.71%
4847	TPCODL	CUTTACK	AED	ATHAGADA	BANDALO (BAUNSA	14307	11 KV MANAPUR	14307202	HARITHA	3425DT270	100	MIXED	AMI	Yes	67%	48	0.0371227	0.010757	0.0263657	71.02%
4848	TPCODL	CUTTACK	AED	ATHAGADA	BANDALO (BAUNSA	14307	11 KV MANAPUR	14307202	MANAPUR 3	3425DT281	100	MIXED	AMI	Yes	100%	87	0.05705656	0.027826	0.02923056	51.23%
4849	TPCODL	CUTTACK	AED	ATHAGADA	BANDALO (BAUNSA	14307	11 KV BANDALO	14307203	KHAJURIPADA MADHUPUR	3425DT304	100	MIXED	AMI	Yes	100%	87	0.04606494	0.023359	0.02270594	49.29%
4850	TPCODL	CUTTACK	AED	ATHAGADA	BANDALO (BAUNSA	14307	11 KV BANDALO	14307203	CHARIMADHIA	3425DT305	100	MIXED	AMI	Yes	33%	89	0.02444294	0.019738	0.00470494	19.25%
4851	TPCODL	CUTTACK	AED	ATHAGADA	BANDALO (BAUNSA	14307	11 KV BANDALO	14307203	SUNTHIPAL	3425DT306	100	MIXED	AMI	Yes	100%	214	0.0873804	0.060449	0.0269314	30.82%
4852	TPCODL	CUTTACK	AED	ATHAGADA	BANDALO (BAUNSA	14307	11 KV BANDALO	14307203	TENTULIA	3425DT311	100	MIXED	AMI	Yes	100%	141	0.05860626	0.041963	0.01664326	28.40%
4853	TPCODL	CUTTACK	AED	ATHAGADA	BANDALO (BAUNSA	14307	11 KV BANDALO	14307203	BADANAUPUT UPPARSAHI 2	3425DT313	100	MIXED	AMI	Yes	100%	133	0.05757804	0.047887	0.00969104	16.83%
4854	TPCODL	CUTTACK	AED	ATHAGADA	BANDALO (BAUNSA	14307	11 KV BANDALO	14307203	BARAPATNA	3425DT321	100	MIXED	AMI	Yes	100%	111	0.0395232	0.034224	0.0052992	13.41%
4855	TPCODL	CUTTACK	AED	ATHAGADA	GURUDIJHATIA	14213	11 KV GURUDIJHATIA	14213201	BALI	3423DT003	250	MIXED	AMI	Yes	100%	118	0.10907616	0.035707	0.07336916	67.26%
4856	TPCODL	CUTTACK	AED	ATHAGADA	GURUDIJHATIA	14213	11 KV GURUDIJHATIA	14213201	KHAMARANUAGAON 1 DSS	3423DT269	100	MIXED	AMI	Yes	100%	224	0.10620456	0.068789	0.03741556	35.23%
4857	TPCODL	CUTTACK	AED	ATHAGADA	GURUDIJHATIA	14213	11 KV GURUDIJHATIA	14213201	GURUDIJATIA MED CK DSS	3423DT276	100	MIXED	AMI	Yes	0%	67	0.09730612	0.047889	0.04941712	50.79%
4858	TPCODL	CUTTACK	AED	ATHAGADA	GURUDIJHATIA	14213	11 KV GURUDIJHATIA	14213201	KOTAR 1 DSS	3423DT283	100	MIXED	AMI	Yes	100%	83	0.07466584	0.042683	0.03198284	42.83%
4859	TPCODL	CUTTACK	AED	ATHAGADA	GURUDIJHATIA	14213	11 KV GURUDIJHATIA	14213201	GURUDIJHATIA 3 DSS	3423DT288	63	MIXED	AMI	Yes	0%	125	0.12323742	0.046746	0.07649142	62.07%
4860	TPCODL	CUTTACK	AED	ATHAGADA	GURUDIJHATIA	14213	11 KV GURUDIJHATIA	14213201	ORNDA 1 DSS	3423DT300	63	MIXED	AMI	Yes	100%	69	0.07582274	0.030426	0.04539674	59.87%
4861	TPCODL	CUTTACK	AED	ATHAGADA	GURUDIJHATIA	14213	11 KV GURUDIJHATIA	14213201	ORNDA 2 DSS	3423DT302	250	MIXED	AMI	Yes	100%	98	0.1027624	0.054822	0.0479404	46.65%
4862	TPCODL	CUTTACK	AED	ATHAGADA	GURUDIJHATIA	14213	11 KV GURUDIJHATIA	14213201	BALI 2 DSS	3423DT318	250	MIXED	AMI	Yes	0%	48	0.06586152	0.021405	0.04445652	67.50%
4863	TPCODL	CUTTACK	AED	ATHAGADA	GURUDIJHATIA	14213	11 KV KUMARPUR	14213202	CHHAGAON 3 DSS	3423DT328	250	MIXED	AMI	Yes	100%	127	0.11486792	0.046934	0.06793392	59.14%
4864	TPCODL	CUTTACK	AED	ATHAGADA	GURUDIJHATIA	14213	11 KV KUMARPUR	14213202	KUMARPUR 1 DSS	3423DT346	100	MIXED	AMI	Yes	100%	62	0.09600198	0.024117	0.07188498	74.88%
4865	TPCODL	CUTTACK	AED	ATHAGADA	GURUDIJHATIA	14213	11 KV KUMARPUR	14213202	KUMARPUR HIGH SCHOOL	3423DT348	100	MIXED	AMI	Yes	0%	109	0.1211019	0.041864	0.0792379	65.43%
4866	TPCODL	CUTTACK	AED	ATHAGADA	GURUDIJHATIA	14213	11 KV KUMARPUR	14213202	SASANGA 1 DSS	3423DT350	100	MIXED	AMI	Yes	67%	60	0.06600868	0.017499	0.04850968	73.49%
4867	TPCODL	CUTTACK	AED	ATHAGADA	GURUDIJHATIA	14213	11 KV KUMARPUR	14213202	SASANGA 2 DSS	3423DT351	100	MIXED	AMI	Yes	100%	128	0.08544178	0.039092	0.04634978	54.25%
4868	TPCODL	CUTTACK	AED	ATHAGADA	GURUDIJHATIA	14213	11 KV KUMARPUR	14213202	KUMARPUR SASAN 2 DSS	3423DT359	100	MIXED	AMI	Yes	100%	51	0.02239774	0.011436	0.01096174	48.94%
4869	TPCODL	CUTTACK	AED	ATHAGADA	GURUDIJHATIA	14213	11 KV KUMARPUR	14213202	KUMARPUR SASAN 1 DSS	3423DT360	100	MIXED	AMI	Yes	100%	15	0.02750542	0.008154	0.01935142	70.35%
4870	TPCODL	CUTTACK	AED	ATHAGADA	GURUDIJHATIA	14213	11 KV KUMARPUR	14213202	OSTAPUR 2 DSS	3423DT364	63	MIXED	AMI	Yes	0%	120	0.0653486	0.029316	0.0360326	55.14%
4871	TPCODL	CUTTACK	AED	ATHAGADA	KHUNTAKATA	14214	11 KV KHUNTAKATA	14214201	RADHADARSANPUR	3422DT030	100	MIXED	AMI	Yes	0%	105	0.11568708	0.036834	0.07885308	68.16%
4872	TPCODL	CUTTACK	AED	ATHAGADA	KHUNTAKATA	14214	11 KV KHUNTAKATA	14214201	KHUNTAKATA	3422DT031	500	MIXED	AMI	Yes	33%	221	0.164411	0.134257	0.030154	18.34%
4873	TPCODL	CUTTACK	AED	ATHAGADA	KHUNTAKATA	14214	11 KV KHUNTAKATA	14214201	RAMACHANDARPUR-1	3422DT040	100	MIXED	AMI	Yes	100%	88	0.0745717	0.02832	0.0462517	62.02%
4874	TPCODL	CUTTACK	AED	ATHAGADA	KHUNTAKATA	14214	11 KV KHUNTAKATA	14214201	MALABIHARPUR -2	3422DT044	100	MIXED	AMI	Yes	100%	95	0.07505134	0.017094	0.05795734	77.22%
4875	TPCODL	CUTTACK	AED	ATHAGADA	KHUNTAKATA	14214	11 KV KHUNTAKATA	14214201	MALABIHARPUR -4	3422DT048	100	MIXED	AMI	Yes	100%	90	0.06680872	0.01491	0.05189872	77.68%
4876	TPCODL	CUTTACK	AED	ATHAGADA	KHUNTAKATA	14214	11 KV KHUNTAKATA	14214201	KADALIBADI -1	3422DT068	100	MIXED	AMI	Yes	100%	160	0.06283512	0.024156	0.03867912	61.56%
4877	TPCODL	CUTTACK	AED	ATHAGADA	KHUNTAKATA	14214	11 KV GODIJHARIA	14214202	NUABANDHA -3	3422DT087	100	MIXED	AMI	Yes	33%	85	0.03053628	0.028735	0.00180128	5.90%
4878	TPCODL	CUTTACK	AED	ATHAGADA	KHUNTAKATA	14214	11 KV GODIJHARIA	14214202	RENGALI RWSS	3422DT104	100	MIXED	AMI	Yes	67%	7	0.0167791	0.004382	0.0123971	73.88%
4879	TPCODL	CUTTACK	AED	ATHAGADA	KHUNTAKATA	14214	11 KV GODIJHARIA	14214202	JENAPADA DAL	3422DT113	100	MIXED	AMI	Yes	67%	38	0.04837668	0.010944	0.03743268	77.38%
4880	TPCODL	CUTTACK	AED	ATHAGADA	KHUNTAKATA	14214	11 KV GODIJHARIA	14214202	MUKDADEIPUR	3422DT124	100	MIXED	AMI	Yes	33%	67	0.02671044	0.01371	0.01300044	48.67%
4881	TPCODL	CUTTACK	AED	ATHAGADA	KHUNTAKATA	14214	11 KV GODIJHARIA	14214202	ARAKHAPATANA	3422DT125	100	MIXED	AMI	Yes	0%	136	0.05571956	0.031631	0.02408856	43.23%
4882	TPCODL	CUTTACK	AED	ATHAGADA	KHUNTAKATA	14214	11 KV GODIJHARIA	14214202	MATIKOTE	3422DT128	100	MIXED	AMI	Yes	67%	95	0.03762882	0.031786	0.00584282	15.53%
4883	TPCODL	CUTTACK	AED	ATHAGADA	KHUNTAKATA	14214	11 KV GODIJHARIA	14214202	ICHHAPUR	3422DT138	100	MIXED	AMI	Yes	0%	158	0.12014928	0.052817	0.06733228	56.04%
4884	TPCODL	CUTTACK	AED	ATHAGADA	KHUNTAKATA	14214	11 KV GODIJHARIA	14214202	PATANDA	3422DT141	100	MIXED	AMI	Yes	33%	106	0.12628494	0.028848	0.09743694	77.16%
4885	TPCODL	CUTTACK	AED	ATHAGADA	KHUNTAKATA	14214	11 KV GODIJHARIA	14214202	MANIMAKPATNA	3422DT163	100	MIXED	AMI	Yes	0%	38	0.04141692	0.016542	0.02487492	60.06%
4886	TPCODL	CUTTACK	AED	ATHAGADA	KHUNTAKATA	14214	11 KV GODIJHARIA	14214202	VIRUDA PANASPATNA	3422DT178	100	MIXED	AMI	Yes	100%	72	0.05657214	0.019656	0.03691614	65.25%
4887	TPCODL	CUTTACK	AED	ATHAGADA	KHUNTAKATA	14214	11 KV GODIJHARIA	14214202	GODIJHARIA	3422DT181	250	MIXED	AMI	Yes	0%	143	0.11344408	0.066447	0.04699708	41.43%
4888	TPCODL	CUTTACK	AED	ATHAGADA	KHUNTAKATA	14214	11 KV GODIJHARIA	14214202	HARIDAPASI -2	3422DT187	100	MIXED	AMI	Yes	67%	73	0.03895768	0.01353	0.02542768	65.27%
4889	TPCODL	CUTTACK	AED	ATHAGADA	KHUNTAKATA	14214	11 KV GODIJHARIA	14214202	HARIDAPASI -1	3422DT188	100	MIXED	AMI	Yes	0%	114	0.0708044	0.023448	0.0473564	66.88%
4890	TPCODL	CUTTACK	AED	ATHAGADA	KHUNTAKATA	14214	11 KV GODIJHARIA	14214202	ACHALKOTE	3422DT199	250	MIXED	AMI	Yes	0%	134	0.06117508	0.030682	0.03049308	49.85%

Sl. No.	Zone Name	Circle name	Division name	Name of the Sub-division	Name of the Sub-station	Substation Code	Name of the 11 kV Feeder	Feeder Code	Name of the Location where DT situated	DT code	DT Capacity (kVA)	Predominant consumer type of DT (Domestic/Industrial/Agriculture/Mixed)	Type of metering AMR/AMI/ Communicable/Conventional metered/Unmetered	Status of Meter-whether Functional (Yes/No)	% of data received automatically (if AMR/AMI)	No. of Connected Consumers	Input Energy (MU) (A)	Billed Energy (MU) (B)	Loss (MU) (A-B)	% DT Loss (A-B)/A
4891	TPCODL	CUTTACK	AED	ATHAGADA	KHUNTAKATA	14214	11 KV GODIJHARIA	14214202	ACHALKOTE BADAPATNA	3422DT204	100	MIXED	AMI	Yes	0%	86	0.04686792	0.028221	0.01864692	39.79%
4892	TPCODL	CUTTACK	AED	ATHAGADA	KHUNTUNI	14117	11 KV GURUDIJHATIA OL	14117201	RADHASHYAMPUR	3423DT080	100	MIXED	AMI	Yes	100%	24	0.00729446	0.004882	0.00241246	33.07%
4893	TPCODL	CUTTACK	AED	ATHAGADA	KHUNTUNI	14117	11 KV GURUDIJHATIA OL	14117201	RADHADAMODARPUR	3423DT101	100	MIXED	AMI	Yes	100%	77	0.10170344	0.033639	0.06806444	66.92%
4894	TPCODL	CUTTACK	AED	ATHAGADA	KHUNTUNI	14117	11 KV GURUDIJHATIA OL	14117201	RADHAKISHORE PUR	3423DT108	100	MIXED	AMI	Yes	100%	93	0.07536544	0.032899	0.04246644	56.35%
4895	TPCODL	CUTTACK	AED	ATHAGADA	KHUNTUNI	14117	11 KV KULEILO	14117202	KHUNTUNI	3423DT061	500	MIXED	AMI	Yes	100%	327	0.41444208	0.150347	0.26409508	63.72%
4896	TPCODL	CUTTACK	AED	ATHAGADA	KHUNTUNI	14117	11 KV KULEILO	14117202	DALABHAGA	3423DT158	100	MIXED	AMI	Yes	100%	108	0.07995628	0.028611	0.05134528	64.22%
4897	TPCODL	CUTTACK	AED	ATHAGADA	KHUNTUNI	14117	11 KV KULEILO	14117202	TALAGADA	3423DT164	63	MIXED	AMI	Yes	100%	57	0.0669515	0.018375	0.0485765	72.55%
4898	TPCODL	CUTTACK	AED	ATHAGADA	KHUNTUNI	14117	11 KV KULEILO	14117202	KULAILO	3423DT168	100	MIXED	AMI	Yes	0%	62	0.10490806	0.026798	0.07811006	74.46%
4899	TPCODL	CUTTACK	AED	ATHAGADA	KHUNTUNI	14117	11 KV KULEILO	14117202	TOTAPADA	3423DT175	250	MIXED	AMI	Yes	100%	232	0.13963676	0.077127	0.06250976	44.77%
4900	TPCODL	CUTTACK	AED	ATHAGADA	KHUNTUNI	14117	11 KV KULEILO	14117202	MATHURAPUR	3423DT178	100	MIXED	AMI	Yes	100%	78	0.05104352	0.027319	0.02372452	46.48%
4901	TPCODL	CUTTACK	AED	ATHAGADA	KHUNTUNI	14117	11 KV KULEILO	14117202	BHOGARA	3423DT197	250	MIXED	AMI	Yes	100%	172	0.12060188	0.076894	0.04370788	36.24%
4902	TPCODL	CUTTACK	AED	ATHAGADA	KHUNTUNI	14117	11 KV MAHALAXMIPUR	14117203	KANDAREI HANUMAN MANDIR SID	3423DT011	100	MIXED	AMI	Yes	0%	49	0.03493902	0.016256	0.01868302	53.47%
4903	TPCODL	CUTTACK	AED	ATHAGADA	KHUNTUNI	14117	11 KV MAHALAXMIPUR	14117203	KHUNTUNI JHATIASAHI	3423DT065	100	MIXED	AMI	Yes	100%	39	0.04940482	0.013474	0.03593082	72.73%
4904	TPCODL	CUTTACK	AED	ATHAGADA	KHUNTUNI	14117	11 KV MAHALAXMIPUR	14117203	TALASASAHI	3423DT070	100	MIXED	AMI	Yes	33%	128	0.12908244	0.048954	0.08012844	62.08%
4905	TPCODL	CUTTACK	AED	ATHAGADA	KHUNTUNI	14117	11 KV MAHALAXMIPUR	14117203	SARYANARAYANPUR	3423DT201	100	MIXED	AMI	Yes	0%	46	0.0188023	0.015432	0.0033703	17.92%
4906	TPCODL	CUTTACK	AED	ATHAGADA	NARANGABASTA	14113	11 KV NARANGABASTA M	14113201	MAHALAPADA RAM MANDIR	3423DT450	100	MIXED	AMI	Yes	100%	129	0.13454736	0.034452	0.10009536	74.39%
4907	TPCODL	CUTTACK	AED	ATHAGADA	NARANGABASTA	14113	11 KV NARANGABASTA M	14113201	CSC BARHAMPUR	3423DT452	100	MIXED	AMI	Yes	100%	20	0.05624704	0.027841	0.02840604	50.50%
4908	TPCODL	CUTTACK	AED	ATHAGADA	NARANGABASTA	14113	11 KV NARANGABASTA M	14113201	BARHAMPUR -3	3423DT456	250	MIXED	AMI	Yes	100%	81	0.11588956	0.03091	0.08497956	73.33%
4909	TPCODL	CUTTACK	AED	ATHAGADA	NARANGABASTA	14113	11 KV NARANGABASTA M	14113201	DHURUSIA HIGH SCHOOL -5	3423DT482	100	MIXED	AMI	Yes	100%	149	0.10510558	0.046356	0.05874958	55.90%
4910	TPCODL	CUTTACK	AED	ATHAGADA	NUAPATANA	14114	11 KV NUAPATNA	14114201	SURENDRAPATNA	3424DT004	100	MIXED	AMI	Yes	100%	121	0.05236422	0.051167	0.00119722	2.29%
4911	TPCODL	CUTTACK	AED	ATHAGADA	NUAPATANA	14114	11 KV NUAPATNA	14114201	SURENDRAPATNA	3424DT006	250	MIXED	AMI	Yes	100%	208	0.11750824	0.107119	0.01038924	8.84%
4912	TPCODL	CUTTACK	AED	ATHAGADA	NUAPATANA	14114	11 KV NUAPATNA	14114201	HATA BAZAR	3424DT007	250	MIXED	AMI	Yes	100%	201	0.14082468	0.126616	0.01420868	10.09%
4913	TPCODL	CUTTACK	AED	ATHAGADA	NUAPATANA	14114	11 KV NUAPATNA	14114201	DURGABAZAR	3424DT010	500	MIXED	AMI	Yes	100%	479	0.37796752	0.295974	0.08199352	21.69%
4914	TPCODL	CUTTACK	AED	ATHAGADA	NUAPATANA	14114	11 KV NUAPATNA	14114201	BUDHAJAYANPIPUR	3424DT022	500	MIXED	AMI	Yes	0%	290	0.15886888	0.141083	0.01778588	11.20%
4915	TPCODL	CUTTACK	AED	ATHAGADA	NUAPATANA	14114	11 KV NUAPATNA	14114201	JEMADEIPUR JAGANNATHSAHI	3424DT023	100	MIXED	AMI	Yes	100%	204	0.09981832	0.060412	0.03940632	39.48%
4916	TPCODL	CUTTACK	AED	ATHAGADA	NUAPATANA	14114	11 KV NUAPATNA	14114201	JEMADEIPUR GODISAHI	3424DT025	100	MIXED	AMI	Yes	100%	70	0.11358834	0.028416	0.08517234	74.98%
4917	TPCODL	CUTTACK	AED	ATHAGADA	NUAPATANA	14114	11 KV NUAPATNA	14114201	BIDYANAGAR NO-1	3424DT034	250	MIXED	AMI	Yes	100%	217	0.1731736	0.10389013	0.06928347	40.01%
4918	TPCODL	CUTTACK	AED	ATHAGADA	NUAPATANA	14114	11 KV NUAPATNA	14114201	BHOGADA NO-1	3424DT052	100	MIXED	AMI	Yes	0%	67	0.0327489	0.027955	0.0047939	14.64%
4919	TPCODL	CUTTACK	AED	ATHAGADA	NUAPATANA	14114	11 KV NUAPATNA	14114201	JEMADEIPUR NO-2	3424DT065	100	MIXED	AMI	Yes	100%	53	0.0405425	0.019041	0.0215015	53.03%
4920	TPCODL	CUTTACK	AED	ATHAGADA	NUAPATANA	14114	11 KV NUAPATNA	14114201	BASUDEVPUR NO-1	3424DT066	100	MIXED	AMI	Yes	100%	106	0.04199774	0.031965	0.01003274	23.89%
4921	TPCODL	CUTTACK	AED	ATHAGADA	NUAPATANA	14114	11 KV NUAPATNA	14114201	BANAMALIPUR NO-1	3424DT090	100	MIXED	AMI	Yes	100%	89	0.08497864	0.023556	0.06142264	72.28%
4922	TPCODL	CUTTACK	AED	ATHAGADA	NUAPATANA	14114	11 KV NUAPATNA	14114201	KANKADAJODI NO-2	3424DT107	500	MIXED	AMI	Yes	100%	400	0.1942092	0.15949	0.0347192	17.88%
4923	TPCODL	CUTTACK	AED	ATHAGADA	NUAPATANA	14114	11 KV NUAPATNA	14114201	KANKADAJODI JAGANNATHSAHI	3424DT113	100	MIXED	AMI	Yes	67%	92	0.03222566	0.031271	0.00095466	2.96%
4924	TPCODL	CUTTACK	AED	ATHAGADA	NUAPATANA	14114	11 KV NUAPATNA	14114201	TALAMUNDALI NO-1	3424DT115	250	MIXED	AMI	Yes	100%	161	0.07073672	0.048938	0.02179872	30.82%
4925	TPCODL	CUTTACK	AED	ATHAGADA	NUAPATANA	14114	11 KV NUAPATNA	14114201	TALAMUNDALI NO-2	3424DT118	100	MIXED	AMI	Yes	100%	82	0.02576218	0.019977	0.00578518	22.46%
4926	TPCODL	CUTTACK	AED	ATHAGADA	NUAPATANA	14114	11 KV MANIABANDHA	14114202	BIDHARPUR NO-1	3424DT094	250	MIXED	AMI	Yes	100%	141	0.12649624	0.078821	0.04767524	37.69%
4927	TPCODL	CUTTACK	AED	ATHAGADA	NUAPATANA	14114	11 KV MANIABANDHA	14114202	BIDHARPUR NO-2	3424DT095	100	MIXED	AMI	Yes	100%	70	0.05884388	0.020763	0.03808088	64.72%
4928	TPCODL	CUTTACK	AED	ATHAGADA	NUAPATANA	14114	11 KV MANIABANDHA	14114202	KUANRPAL NO-1	3424DT136	100	MIXED	AMI	Yes	0%	74	0.03453668	0.021159	0.01337768	38.73%
4929	TPCODL	CUTTACK	AED	ATHAGADA	NUAPATANA	14114	11 KV MANIABANDHA	14114202	AVIMANAPUR NO-1	3424DT153	250	MIXED	AMI	Yes	100%	89	0.09163476	0.034768	0.05686676	62.06%
4930	TPCODL	CUTTACK	AED	ATHAGADA	NUAPATANA	14114	11 KV MANIABANDHA	14114202	AVIMANAPUR NO-2	3424DT154	100	MIXED	AMI	Yes	100%	102	0.10172064	0.044179	0.05754164	56.57%
4931	TPCODL	CUTTACK	AED	ATHAGADA	NUAPATANA	14114	11 KV MANIABANDHA	14114202	AVIMANAPUR NO-3	3424DT156	500	MIXED	AMI	Yes	100%	227	0.13820904	0.092696	0.04551304	32.93%
4932	TPCODL	CUTTACK	AED	ATHAGADA	NUAPATANA	14114	11 KV MANIABANDHA	14114202	BIRABARAPUR NO-1	3424DT162	250	MIXED	AMI	Yes	100%	183	0.09575452	0.065499	0.03025552	31.60%
4933	TPCODL	CUTTACK	AED	ATHAGADA	NUAPATANA	14114	11 KV MANIABANDHA	14114202	MATIAPADA NO-1	3424DT168	100	MIXED	AMI	Yes	67%	68	0.03762456	0.026725	0.01089956	28.97%
4934	TPCODL	CUTTACK	AED	ATHAGADA	NUAPATANA	14114	11 KV MANIABANDHA	14114202	LAXMIDHARPUR	3424DT169	100	MIXED	AMI	Yes	67%	65	0.05375946	0.018378	0.03538146	65.81%
4935	TPCODL	CUTTACK	AED	ATHAGADA	NUAPATANA	14114	11 KV MANIABANDHA	14114202	KIRIKICHA NO-1	3424DT179	100	MIXED	AMI	Yes	33%	103	0.02470302	0.022548	0.00215502	8.72%
4936	TPCODL	CUTTACK	AED	ATHAGADA	NUAPATANA	14114	11 KV MANIABANDHA	14114202	MAHULIA NO-1	3424DT184	100	MIXED	AMI	Yes	100%	33	0.06557868	0.013973	0.05160568	78.69%
4937	TPCODL	CUTTACK	AED	ATHAGADA	NUAPATANA	14114	11 KV MANIABANDHA	14114202	MANIABANDHA NO-2	3424DT196	250	MIXED	AMI	Yes	0%	412	0.1824658	0.136829	0.0456368	25.01%
4938	TPCODL	CUTTACK	AED	ATHAGADA	NUAPATANA	14114	11 KV MANIABANDHA	14114202	MANIABANDHA NO-1	3424DT197	250	MIXED	AMI	Yes	67%	329	0.1805925	0.122673	0.0579195	32.07%
4939	TPCODL	CUTTACK	AED	ATHAGADA	NUAPATANA	14114	11 KV MANIABANDHA	14114202	HARIHARAPATNA NO-2	3424DT207	100	MIXED	AMI	Yes	100%	129	0.06414798	0.044509	0.01963898	30.62%
4940	TPCODL	CUTTACK	AED	ATHAGADA	NUAPATANA	14114	11 KV MANIABANDHA	14114202	DHANAPALLI NO-1	3424DT214	100	MIXED	AMI	Yes	100%	109	0.10273666	0.032815	0.06992166	68.06%
4941	TPCODL	CUTTACK	AED	ATHAGADA	NUAPATANA	14114	11 KV MANIABANDHA	14114202	KASIKIARI NO-1	3424DT217	100	MIXED	AMI	Yes	67%	114	0.04940554	0.031085	0.01832054	37.08%
4942	TPCODL	CUTTACK	AED	ATHAGADA	NUAPATANA	14114	11 KV MANIABANDHA	14114202	BARIMUL NO-1	3424DT222	100	MIXED	AMI	Yes	0%	127	0.05721156	0.030469	0.02674256	46.74%
4943	TPCODL	CUTTACK	AED	ATHAGADA	SARANDA ODSSP	14306	11 KV KANTAPANHARA	14306201	KRUSHANAPUR	3422DT633	250	MIXED	AMI	Yes	67%	44	0.02849564	0.009659	0.01883664	66.10%
4944	TPCODL	CUTTACK	AED	ATHAGADA	SARANDA ODSSP	14306	11 KV KANTAPANHARA	14306201	GOLOPUR-5 CAPAC	3422DT652	100	MIXED	AMI	Yes	67%	79	0.03352208	0.015563	0.01795908	53.57%
4945	TPCODL	CUTTACK	AED	ATHAGADA	SARANDA ODSSP	14306	11 KV KANTAPANHARA	14306201	CHANDIPUR PATNA -1	3422DT654	100	MIXED	AMI	Yes	33%	123	0.04995106	0.036318	0.01363306	27.29%
4946	TPCODL	CUTTACK	AED	ATHAGADA	SARANDA ODSSP	14306	11 KV KANTAPANHARA	14306201	JAGIAPADA-1	3422DT656	100	MIXED	AMI	Yes	67%	121	0.05662724	0.03168	0.02494724	44.06%
4947	TPCODL	CUTTACK	AED	ATHAGADA	SARANDA ODSSP	14306	11 KV KANTAPANHARA	14306201	RAGHUNATHPUR PATAN	3422DT659	100	MIXED	AMI	Yes	67%	93	0.07064904	0.025756	0.04489304	63.54%
4948	TPCODL	CUTTACK	AED	ATHAGADA	SARANDA ODSSP	14306	11 KV KANTAPANHARA	14306201	SOMA PARA BARICK SAHI -4	3422DT663	100	MIXED	AMI	Yes	0%	65	0.06849896	0.019415	0.04908396	71.66%
4949	TPCODL	CUTTACK	AED	ATHAGADA	SARANDA ODSSP	14306	11 KV KANTAPANHARA	14306201	SAM PADA-1	3422DT668	250	MIXED	AMI	Yes	67%	136	0.06727788	0.033264	0.03401388	50.56%
4950	TPCODL	CUTTACK	AED	ATHAGADA	SARANDA ODSSP	14306	11 KV KANTAPANHARA	14306201	BARAVINDARA -2	3422DT681	100	MIXED	AMI	Yes	0%	124	0.05923506	0.024251	0.03498406	59.06%
4951	TPCODL	CUTTACK	AED	ATHAGADA	SARANDA ODSSP	14306	11 KV KANTAPANHARA	14306201	BADABHIUINIDSS-1	3422DT687	100	MIXED	AMI	Yes	67%	70	0.05725404	0.012388	0.04486604	78.36%
4952	TPCODL	CUTTACK	AED	ATHAGADA	SARANDA ODSSP	14306	11 KV SUBARNAPUR	14306202	NUASTIA	3422DT575	100	MIXED	AMI	Yes	100%	131	0.06462278	0.039907	0.02471578	38.25%
4953	TPCODL	CUTTACK	AED	ATHAGADA	SARANDA ODSSP	14306	11 KV SUBARNAPUR	14306202	SUBRNOPUR-4	3422DT623	100	MIXED	AMI	Yes	100%	143	0.059129	0.042224	0.016905	28.59%
4954	TPCODL	CUTTACK	AED	ATHAGADA	SARANDA ODSSP	14306	11 KV GHODABARA	14306204	GHODABAR	3422DT239	100	MIXED	AMI	Yes	0%	83	0.06613218	0.013824	0.05230818	79.10%
4955	TPCODL	CUTTACK	AED	ATHAGADA	SARANDA ODSSP	14306	11 KV GHODABARA	14306204	RATAGARH 1	3422DT244	100	MIXED	AMI	Yes	67%	29	0.01769674	0.005671	0.01202574	67.95%
4956	TPCODL	CUTTACK	AED	ATHAGADA	SARANDA ODSSP	14306	11 KV GHODABARA	14306204	GOBINDPUR 4	3422DT247	100	MIXED	AMI	Yes	67%	191	0.06686584	0.04189	0.02497584	37.35%
4957	TPCODL	CUTTACK	AED	ATHAGADA	SARANDA ODSSP	14306	11 KV GHODABARA	14306204	GOBINDPUR 2	3422DT249	100	MIXED	AMI	Yes	67%	139	0.0741872	0.024837	0.0493502	66.52%
4958	TPCODL	CUTTACK	AED	ATHAGADA	SARANDA ODSSP	14306	11 KV GHODABARA	14306204	OLD KFW	3422DT250	100	MIXED	AMI	Yes	0%	40	0.03613194	0.009492	0.02663994	73.73%
4959	TPCODL	CUTTACK	AED	ATHAGADA	SARANDA ODSSP	14306	11 KV GHODABARA	14306204	SAHANGAGOPALPUR 3	3422DT254	100	MIXED	AMI	Yes	67%	52	0.01937376	0.008983	0.01039076	53.63%
4960	TPCODL	CUTTACK	AED	ATHAGADA	SARPESWAR	14365	11 KV SARPESWAR MEGI	14365201	ANANTAPUR	3423DT465	100	MIXED	AMI	Yes	100%	147	0.10803962	0.056731	0.05130862	47.49%
4961	TPCODL	CUTTACK	AED	ATHAGADA	SARPESWAR	14365	11 KV SARPESWAR MEGI	14365201	BALISAHI -1	3423DT531	63	MIXED	AMI	Yes	0%	73	0.05006828	0.018382	0.03168628	63.29%
4962	TPCODL	CUTTACK	AED	ATHAGADA	SARPESWAR	14365	11 KV SARPESWAR MEGI	14365201	BAULAPADA -1	3423DT533	63	MIXED	AMI	Yes	0%	68	0.06056474	0.01833	0.04223474	69.73%
4963	TPCODL	CUTTACK	AED	ATHAGADA	SARPESWAR	14365	11 KV SARPESWAR MEGI	14365201	DHURUKUDIA -2	3423DT552	100	MIXED	AMI	Yes	0%	57	0.07409808	0.021674	0.05242408	70.75%

Sl. No.	Zone Name	Circle name	Division name	Name of the Sub-division	Name of the Sub-station	Substation Code	Name of the 11 kV Feeder	Feeder Code	Name of the Location where DT situated	DT code	DT Capacity (kVA)	Predominant consumer type of DT (Domestic/Industrial/Agriculture/Mixed)	Type of metering AMR/AMI/ Communicable/Conventional metered/Unmetered	Status of Meter-whether Functional (Yes/No)	% of data received automatically (if AMR/AMI)	No. of Connected Consumers	Input Energy (MU) (A)	Billed Energy (MU) (B)	Loss (MU) (A-B)	% DT Loss (A-B)/A
4964	TPCODL	CUTTACK	AED	ATHAGADA	SARPESWAR	14365	11 KV SARPESWAR MEGI	14365201	KAIPUDIA -3	3423DT556	100	MIXED	AMI	Yes	0%	95	0.04681378	0.030186	0.01662778	35.52%
4965	TPCODL	CUTTACK	AED	ATHAGADA	SARPESWAR	14365	11 KV SARPESWAR MEGI	14365201	KADAMPATANA-1	3423DT559	100	MIXED	AMI	Yes	67%	56	0.06498942	0.014557	0.05043242	77.60%
4966	TPCODL	CUTTACK	AED	ATHAGADA	SARPESWAR	14365	11 KV SARPESWAR MEGI	14365201	DWARABATIPUR	3423DT587	100	MIXED	AMI	Yes	100%	110	0.0569208	0.030875	0.0260458	45.76%
4967	TPCODL	CUTTACK	AED	ATHAGADA	SARPESWAR	14365	11 KV SARPESWAR MEGI	14365201	ANANTAPUR	3423DT592	63	MIXED	AMI	Yes	0%	58	0.05817306	0.014009	0.04416406	75.92%
4968	TPCODL	CUTTACK	AED	ATHAGADA	TIGIRIA	14115	11 KV BINDHANIMA	14115201	TIGIRIA TOWN	3425DT024	250	MIXED	AMI	Yes	0%	153	0.29557588	0.09123	0.20434588	69.13%
4969	TPCODL	CUTTACK	AED	ATHAGADA	TIGIRIA	14115	11 KV BINDHANIMA	14115201	GOPINATHPUR SASAN-1	3425DT046	100	MIXED	AMI	Yes	100%	67	0.04845893	0.041181	0.00727793	15.02%
4970	TPCODL	CUTTACK	AED	ATHAGADA	TIGIRIA	14115	11 KV BINDHANIMA	14115201	GOPINATHPUR SASAN-3	3425DT048	100	MIXED	AMI	Yes	100%	127	0.0806434	0.050335	0.0303084	37.58%
4971	TPCODL	CUTTACK	AED	ATHAGADA	TIGIRIA	14115	11 KV BINDHANIMA	14115201	BALIPUT	3425DT174	100	MIXED	AMI	Yes	100%	107	0.0347869	0.028283	0.0065039	18.70%
4972	TPCODL	CUTTACK	AED	ATHAGADA	TIGIRIA	14115	11 KV BINDHANIMA	14115201	KALIBIRI-1 NUASAHI	3425DT204	100	MIXED	AMI	Yes	100%	54	0.04293798	0.015999	0.02693898	62.74%
4973	TPCODL	CUTTACK	AED	ATHAGADA	TIGIRIA	14115	11 KV BINDHANIMA	14115201	KALIBIRI-2 KEUTA SAHI	3425DT207	250	MIXED	AMI	Yes	100%	109	0.0853696	0.028239	0.0571306	66.92%
4974	TPCODL	CUTTACK	AED	ATHAGADA	TIGIRIA	14115	11 KV PANCHAGAON	14115202	PACHAGAON	3425DT101	500	MIXED	AMI	Yes	100%	316	0.31791648	0.105134	0.21278248	66.93%
4975	TPCODL	CUTTACK	AED	ATHAGADA	TIGIRIA	14115	11 KV PANCHAGAON	14115202	KUMBHIPUT	3425DT104	100	MIXED	AMI	Yes	100%	128	0.05407244	0.039975	0.01409744	26.07%
4976	TPCODL	CUTTACK	AED	ATHAGADA	TIGIRIA	14115	11 KV PANCHAGAON	14115202	HIGH SCHOOL	3425DT111	100	MIXED	AMI	Yes	100%	80	0.07273026	0.019932	0.05279826	72.59%
4977	TPCODL	CUTTACK	AED	ATHAGADA	TIGIRIA	14115	11 KV PANCHAGAON	14115202	MAHULDHIPA	3425DT115	100	MIXED	AMI	Yes	100%	214	0.0678314	0.05367	0.0141614	20.88%
4978	TPCODL	CUTTACK	AED	ATHAGADA	TIGIRIA	14115	11 KV PANCHAGAON	14115202	NUA SADAK CHHAK	3425DT135	100	MIXED	AMI	Yes	100%	52	0.0360372	0.022666	0.0133712	37.10%
4979	TPCODL	CUTTACK	AED	ATHAGADA	TIGIRIA	14115	11 KV TIGIRIA	14115203	TIGIRIA GIRLS HIGH SCHOOL	3425DT035	500	MIXED	AMI	Yes	100%	227	0.23130944	0.152059	0.07925044	34.26%
4980	TPCODL	CUTTACK	AED	ATHAGADA	TIGIRIA	14115	11 KV PURUNA TIGIRIA	14115204	KEUTAPATANA	3425DT008	63	MIXED	AMI	Yes	100%	41	0.03666844	0.009714	0.02695444	73.51%
4981	TPCODL	CUTTACK	AED	ATHAGADA	TIGIRIA	14115	11 KV PURUNA TIGIRIA	14115204	KHANDAHATA	3425DT020	250	MIXED	AMI	Yes	100%	144	0.0705196	0.044723	0.0257966	36.58%
4982	TPCODL	CUTTACK	AED	ATHAGADA	TIGIRIA	14115	11 KV PURUNA TIGIRIA	14115204	PURUNATIGIRIA- 2	3425DT065	100	MIXED	AMI	Yes	100%	161	0.06360052	0.050112	0.01348852	21.21%
4983	TPCODL	CUTTACK	AED	ATHAGADA	TIGIRIA	14115	11 KV PURUNA TIGIRIA	14115204	AMUNIASHAI	3425DT068	100	MIXED	AMI	Yes	0%	75	0.04045742	0.033288	0.00716942	17.72%
4984	TPCODL	CUTTACK	AED	ATHAGADA	TIGIRIA	14115	11 KV PURUNA TIGIRIA	14115204	PURNATIGIRIA 1	3425DT073	100	MIXED	AMI	Yes	100%	78	0.05463082	0.033176	0.02145482	39.27%
4985	TPCODL	CUTTACK	AED	ATHAGADA	TIGIRIA	14115	11 KV PURUNA TIGIRIA	14115204	PAIKINARA -2	3425DT088	100	MIXED	AMI	Yes	0%	82	0.0557763	0.018231	0.0375453	67.31%
4986	TPCODL	CUTTACK	AED	ATHAGADA	TIGIRIA	14115	11 KV PURUNA TIGIRIA	14115204	SALIJANGA	3425DT097	63	MIXED	AMI	Yes	100%	35	0.04605498	0.009412	0.03664298	79.56%
4987	TPCODL	CUTTACK	AED	NARASINGPUR	BADAMBA	14110	100 KVA STATION TRANS	14110STN01	33/11kV BADAMBA PSS STATION TRA	3411DT726	100	MIXED	AMI	Yes	100%	1	0.00336009	0.00336	9E-08	0.00%
4988	TPCODL	CUTTACK	AED	NARASINGPUR	BADAMBA	14110	11 KV GOPAMATHURA	14110201	KANTAPADA	3411DT148	100	MIXED	AMI	Yes	100%	116	0.06049842	0.041564	0.01893442	31.30%
4989	TPCODL	CUTTACK	AED	NARASINGPUR	BADAMBA	14110	11 KV GOPAMATHURA	14110201	KANTAPADA NUASAHI	3411DT159	250	MIXED	AMI	Yes	100%	105	0.04754232	0.036356	0.01118632	23.53%
4990	TPCODL	CUTTACK	AED	NARASINGPUR	BADAMBA	14110	11 KV GOPAMATHURA	14110201	KANTAPADA BEHERA SAHI	3411DT161	100	MIXED	AMI	Yes	67%	73	0.05870004	0.02403	0.03467004	59.06%
4991	TPCODL	CUTTACK	AED	NARASINGPUR	BADAMBA	14110	11 KV GOPAMATHURA	14110201	KANTAPADA PRADHAN SAHI	3411DT164	100	MIXED	AMI	Yes	100%	66	0.03483992	0.020862	0.01397792	40.12%
4992	TPCODL	CUTTACK	AED	NARASINGPUR	BADAMBA	14110	11 KV GOPAMATHURA	14110201	SANKHAMERI BADA SAHI 1	3411DT165	250	MIXED	AMI	Yes	100%	91	0.06033552	0.026601	0.03373452	55.91%
4993	TPCODL	CUTTACK	AED	NARASINGPUR	BADAMBA	14110	11 KV GOPAMATHURA	14110201	SANKHAMERI BADA SAHI	3411DT166	250	MIXED	AMI	Yes	0%	97	0.0677618	0.032796	0.0349658	51.60%
4994	TPCODL	CUTTACK	AED	NARASINGPUR	BADAMBA	14110	11 KV GOPAMATHURA	14110201	SANKHAMERI JANIGADIASAHI	3411DT167	100	MIXED	AMI	Yes	0%	86	0.0689484	0.02488	0.0440684	63.92%
4995	TPCODL	CUTTACK	AED	NARASINGPUR	BADAMBA	14110	11 KV GOPAMATHURA	14110201	SANKHAMERI GOUDA SAHI	3411DT170	63	MIXED	AMI	Yes	100%	63	0.02415452	0.01482	0.00933452	38.65%
4996	TPCODL	CUTTACK	AED	NARASINGPUR	BADAMBA	14110	11 KV GOPAMATHURA	14110201	GOPAMATHURA PANCHAYAT -IV A(K	3411DT179	100	MIXED	AMI	Yes	100%	107	0.1038351	0.027185	0.0766501	73.82%
4997	TPCODL	CUTTACK	AED	NARASINGPUR	BADAMBA	14110	11 KV GOPAMATHURA	14110201	BRUNDABANPUR	3411DT191	100	MIXED	AMI	Yes	0%	50	0.03929788	0.011011	0.02828688	71.98%
4998	TPCODL	CUTTACK	AED	NARASINGPUR	BADAMBA	14110	11 KV GOPAMATHURA	14110201	BRUNDABANPUR-I	3411DT192	100	MIXED	AMI	Yes	100%	79	0.06739714	0.01645	0.05094714	75.59%
4999	TPCODL	CUTTACK	AED	NARASINGPUR	BADAMBA	14110	11 KV GOPAMATHURA	14110201	MULIABANKA	3411DT193	100	MIXED	AMI	Yes	100%	84	0.06252084	0.032665	0.02985584	47.75%
5000	TPCODL	CUTTACK	AED	NARASINGPUR	BADAMBA	14110	11 KV BADAMBA TOWN	14110202	BARAMBA KACHARI-II TAHASIL	3411DT075	100	MIXED	AMI	Yes	100%	53	0.04920102	0.034899	0.01430202	29.07%
5001	TPCODL	CUTTACK	AED	NARASINGPUR	BADAMBA	14110	11 KV BADAMBA TOWN	14110202	BADAMBHA KACHARI-III GHS	3411DT077	63	MIXED	AMI	Yes	0%	23	0.06819892	0.015337	0.05286192	77.51%
5002	TPCODL	CUTTACK	AED	NARASINGPUR	BADAMBA	14110	11 KV BADAMBA TOWN	14110202	BADAMBA BELESWARPADA	3411DT079	100	MIXED	AMI	Yes	100%	60	0.05311584	0.01862	0.03449584	64.94%
5003	TPCODL	CUTTACK	AED	NARASINGPUR	BADAMBA	14110	11 KV BADAMBA TOWN	14110202	BADAMBA KACHARI FIELD	3411DT085	100	MIXED	AMI	Yes	0%	58	0.06423474	0.027557	0.03667774	57.10%
5004	TPCODL	CUTTACK	AED	NARASINGPUR	BADAMBA	14110	11 KV BADAMBA TOWN	14110202	BADAMBA GANDHI CHHAK	3411DT091	250	MIXED	AMI	Yes	100%	107	0.14413276	0.070882	0.07325076	50.82%
5005	TPCODL	CUTTACK	AED	NARASINGPUR	BADAMBA	14110	11 KV BADAMBA TOWN	14110202	BADAMBA GUNDICHIBADI	3411DT097	500	MIXED	AMI	Yes	0%	63	0.0586152	0.01805	0.0405652	69.21%
5006	TPCODL	CUTTACK	AED	NARASINGPUR	BADAMBA	14110	11 KV BADAMBA TOWN	14110202	BADAMBA SUBSTATION	3411DT114	250	MIXED	AMI	Yes	100%	71	0.14231736	0.062089	0.08022836	56.37%
5007	TPCODL	CUTTACK	AED	NARASINGPUR	BADAMBA	14110	11 KV BADAMBA TOWN	14110202	BADAMBA HATA-I (HEROSORUM)	3411DT125	100	MIXED	AMI	Yes	67%	52	0.0801302	0.024968	0.0551622	68.84%
5008	TPCODL	CUTTACK	AED	NARASINGPUR	BADAMBA	14110	11 KV BADAMBA TOWN	14110202	BISWAMBAR PUR	3411DT145	100	MIXED	AMI	Yes	0%	102	0.05735734	0.029118	0.02823934	49.23%
5009	TPCODL	CUTTACK	AED	NARASINGPUR	BADAMBA	14110	11 KV RATAPATA	14110203	SUNAPAL BRAHMANSAHI	3411DT208	100	MIXED	AMI	Yes	100%	35	0.03161024	0.015124	0.01648624	52.15%
5010	TPCODL	CUTTACK	AED	NARASINGPUR	BADAMBA	14110	11 KV RATAPATA	14110203	ICHHAPUR	3411DT240	100	MIXED	AMI	Yes	100%	86	0.04263544	0.023444	0.01919144	45.01%
5011	TPCODL	CUTTACK	AED	NARASINGPUR	BADAMBA	14110	11 KV RATAPATA	14110203	PARAJAPADA	3411DT247	100	MIXED	AMI	Yes	0%	78	0.03624556	0.020646	0.01559956	43.04%
5012	TPCODL	CUTTACK	AED	NARASINGPUR	BADAMBA	14110	11 KV RATAPATA	14110203	PARAJAPADA (HADI SAHI)-I	3411DT250	100	MIXED	AMI	Yes	100%	57	0.02701328	0.015067	0.01194628	44.22%
5013	TPCODL	CUTTACK	AED	NARASINGPUR	BADAMBA	14110	11 KV RATAPATA	14110203	MANGARAJPUR1	3411DT289	100	MIXED	AMI	Yes	0%	141	0.06182862	0.028807	0.03302162	53.41%
5014	TPCODL	CUTTACK	AED	NARASINGPUR	BADAMBA	14110	11 KV RATAPATA	14110203	BADAMBA BANGALATALA	3411DT295	100	MIXED	AMI	Yes	100%	73	0.0725554	0.047713	0.0248424	34.24%
5015	TPCODL	CUTTACK	AED	NARASINGPUR	BADAMBA	14110	11 KV RATAPATA	14110203	ICHHAPUR SASAN	3411DT714	100	MIXED	AMI	Yes	100%	57	0.02983974	0.015818	0.01402174	46.99%
5016	TPCODL	CUTTACK	AED	NARASINGPUR	BADAMBA	14110	11 KV RAGADIPADA	14110204	CHAMPEIDWAR II	3411DT035	100	MIXED	AMI	Yes	67%	66	0.03521834	0.015405	0.01981334	56.26%
5017	TPCODL	CUTTACK	AED	NARASINGPUR	BADAMBA	14110	11 KV RAGADIPADA	14110204	RAGDIPADA NUATALA ROAD	3411DT041	100	MIXED	AMI	Yes	67%	39	0.03356142	0.020491	0.01307042	38.94%
5018	TPCODL	CUTTACK	AED	NARASINGPUR	BADAMBA	14110	11 KV RAGADIPADA	14110204	RAGADIPADA JATRA PADIA -I	3411DT048	100	MIXED	AMI	Yes	67%	122	0.0484768	0.031447	0.0170298	35.13%
5019	TPCODL	CUTTACK	AED	NARASINGPUR	BADAMBA	14110	11 KV RAGADIPADA	14110204	RAGADIPADA NAHAK SAHI -I	3411DT054	100	MIXED	AMI	Yes	67%	77	0.04203864	0.034339	0.00769964	18.32%
5020	TPCODL	CUTTACK	AED	NARASINGPUR	BADAMBA	14110	11 KV GOPINATHAPUR	14110205	GOPONATHPUR(TALA SAHI)	3411DT020	100	MIXED	AMI	Yes	0%	97	0.06368248	0.029913	0.03376948	53.03%
5021	TPCODL	CUTTACK	AED	NARASINGPUR	BADAMBA	14110	11 KV GOPINATHAPUR	14110205	GOPONATHPUR(UPARA SAHI)	3411DT024	100	MIXED	AMI	Yes	0%	50	0.06636316	0.014312	0.05205116	78.43%
5022	TPCODL	CUTTACK	AED	NARASINGPUR	BADAMBA	14110	11 KV GOPINATHAPUR	14110205	GOPONATHPUR(PUJARI SAHI)	3411DT025	100	MIXED	AMI	Yes	0%	100	0.0445482	0.030909	0.0136392	30.62%
5023	TPCODL	CUTTACK	AED	NARASINGPUR	BADAMBA	14110	11 KV GOPINATHAPUR	14110205	GOPINATHPUR HATA- I	3411DT306	100	MIXED	AMI	Yes	67%	122	0.05785956	0.045126	0.01273356	22.01%
5024	TPCODL	CUTTACK	AED	NARASINGPUR	BADAMBA	14110	11 KV GOPINATHAPUR	14110205	GOPINATHPUR HATA	3411DT307	100	MIXED	AMI	Yes	67%	46	0.05667408	0.012925	0.04374908	77.19%
5025	TPCODL	CUTTACK	AED	NARASINGPUR	BADAMBA	14110	11 KV GOPINATHAPUR	14110205	KEUTASAHI NEAR (BARODRA BANK)	3411DT310	100	MIXED	AMI	Yes	67%	80	0.04700254	0.020426	0.02657654	56.54%
5026	TPCODL	CUTTACK	AED	NARASINGPUR	BADAMBA	14110	11 KV GOPINATHAPUR	14110205	CHANDIMANGAL	3411DT316	100	MIXED	AMI	Yes	0%	86	0.05649046	0.023443	0.03304746	58.50%
5027	TPCODL	CUTTACK	AED	NARASINGPUR	BADAMBA	14110	11 KV GOPINATHAPUR	14110205	MUGAGAHRI II	3411DT335	100	MIXED	AMI	Yes	0%	44	0.0615336	0.013311	0.0482226	78.37%
5028	TPCODL	CUTTACK	AED	NARASINGPUR	BADAMBA	14110	11 KV GOPINATHAPUR	14110205	TUNAPUR NUA SAHI	3411DT353	100	MIXED	AMI	Yes	67%	157	0.06064246	0.037877	0.02276546	37.54%
5029	TPCODL	CUTTACK	AED	NARASINGPUR	BADAMBA	14110	11 KV GOPINATHAPUR	14110205	TELENIA MATHA SAHI	3411DT360	100	MIXED	AMI	Yes	100%	112	0.04908286	0.022847	0.02623586	53.45%
5030	TPCODL	CUTTACK	AED	NARASINGPUR	CDA	14080	11 KV SECTOR 9	14080203	PHD PUMP HOUSE SEC 8	3142DT152	250	MIXED	AMI	Yes	100%	98	0.13426884	0.075103	0.05916584	44.07%
5031	TPCODL	CUTTACK	AED	NARASINGPUR	CDA	14080	11 KV SECTOR 9	14080203	TONPE-2	3142DT153	250	MIXED	AMI	Yes	100%	41	0.14086936	0.040521	0.10034836	71.24%
5032	TPCODL	CUTTACK	AED	NARASINGPUR	DHOBANINALA ODS	14308	11 KV BANGERISINGHA	14308201	BADABARSINGH -I & II	3411DT586	100	MIXED	AMI	Yes	100%	91	0.05918554	0.023828	0.03535754	59.74%
5033	TPCODL	CUTTACK	AED	NARASINGPUR	DHOBANINALA ODS	14308	11 KV BANGERISINGHA	14308201	BADABARSINGH -I & II. (I)	3411DT587	100	MIXED	AMI	Yes	0%	22	0.01896294	0.007665	0.01129794	59.58%
5034	TPCODL	CUTTACK	AED	NARASINGPUR	DHOBANINALA ODS	14308	11 KV BANGERISINGHA	14308201	SMABARSINGH	3411DT615	250	MIXED	AMI	Yes	100%	160	0.14323636	0.033521	0.10971536	76.60%
5035	TPCODL	CUTTACK	AED	NARASINGPUR	DHOBANINALA ODS	14308	11 KV BADABARSINGHA	14308203	Diniary Dianipatna	3411DT061	100	MIXED	AMI	Yes	0%	34	0.0214861	0.007762	0.0137241	63.87%
5036	TPCODL	CUTTACK	AED	NARASINGPUR	DHOBANINALA ODS	14308	11 KV BADABARSINGHA	14308203	NARANPUR UPPER SAHI-11	3411DT667	100	MIXED	AMI	Yes	0%	74	0.03477228	0.014106	0.02066628	59.43%

Sl. No.	Zone Name	Circle name	Division name	Name of the Sub-division	Name of the Sub-station	Substation Code	Name of the 11 kV Feeder	Feeder Code	Name of the Location where DT situated	DT code	DT Capacity (kVA)	Predominant consumer type of DT (Domestic/Industrial/Agriculture/Mixed)	Type of metering AMR/AMI/ Communicable/Conventional metered/Unmetered	Status of Meter-whether Functional (Yes/No)	% of data received automatically (if AMR/AMI)	No. of Connected Consumers	Input Energy (MU) (A)	Billed Energy (MU) (B)	Loss (MU) (A-B)	% DT Loss (A-B)/A
5037	TPCODL	CUTTACK	AED	NARASINGPUR	DHOBANINALA ODS	14308	11 KV BADABARSINGHA	14308203	BANGERISINGHA -3	3411DT674	250	MIXED	AMI	Yes	0%	103	0.03258828	0.019025	0.01356328	41.62%
5038	TPCODL	CUTTACK	AED	NARASINGPUR	DHOBANINALA ODS	14308	11 KV BADABARSINGHA	14308203	NUABENGERISINGHA SABAR SAHI	3411DT678	100	MIXED	AMI	Yes	100%	105	0.03459344	0.018707	0.01588644	45.92%
5039	TPCODL	CUTTACK	AED	NARASINGPUR	DHOBANINALA ODS	14308	11 KV BADABARSINGHA	14308203	BANGERISINGHA -13	3411DT680	500	MIXED	AMI	Yes	100%	136	0.09850504	0.033507	0.06499804	65.98%
5040	TPCODL	CUTTACK	AED	NARASINGPUR	DHOBANINALA ODS	14308	11 KV BADABARSINGHA	14308203	TELUNIA OLIC-1	3411DT707	100	MIXED	AMI	Yes	0%	64	0.04918124	0.017777	0.03140424	63.85%
5041	TPCODL	CUTTACK	AED	NARASINGPUR	DHOBANINALA ODS	14308	11 KV KHUNTAKATA	14308204	KHUNTAKATA (HADI SAHI)	3411DT006	100	MIXED	AMI	Yes	0%	125	0.0774333	0.025764	0.0516693	66.73%
5042	TPCODL	CUTTACK	AED	NARASINGPUR	DHOBANINALA ODS	14308	11 KV KHUNTAKATA	14308204	KHUNTAKATA (KATA SAHI)	3411DT011	100	MIXED	AMI	Yes	0%	82	0.04669316	0.018938	0.02775516	59.44%
5043	TPCODL	CUTTACK	AED	NARASINGPUR	GOPAPUR ODSSP	14305	11 KV RATTAPATA	14305201	KHAIRAPANGA	3411DT404	100	MIXED	AMI	Yes	100%	88	0.06007392	0.025027	0.03504692	58.34%
5044	TPCODL	CUTTACK	AED	NARASINGPUR	GOPAPUR ODSSP	14305	11 KV RATTAPATA	14305201	KC PUR VILLAGE	3411DT497	100	MIXED	AMI	Yes	0%	82	0.03852088	0.019105	0.01941588	50.40%
5045	TPCODL	CUTTACK	AED	NARASINGPUR	GOPAPUR ODSSP	14305	11 KV RATTAPATA	14305201	KHALIDIPA UPER SAHI	3411DT506	250	MIXED	AMI	Yes	100%	123	0.06936996	0.02485	0.04451996	64.18%
5046	TPCODL	CUTTACK	AED	NARASINGPUR	GOPAPUR ODSSP	14305	11 KV RATTAPATA	14305201	JANISAHI TALA SAHI	3411DT516	100	MIXED	AMI	Yes	0%	63	0.03020066	0.011348	0.01885266	62.42%
5047	TPCODL	CUTTACK	AED	NARASINGPUR	GOPAPUR ODSSP	14305	11 KV RATTAPATA	14305201	AMANTIA SAHI	3411DT534	100	MIXED	AMI	Yes	100%	34	0.02485088	0.01259	0.01226088	49.34%
5048	TPCODL	CUTTACK	AED	NARASINGPUR	GOPAPUR ODSSP	14305	11 KV RATTAPATA	14305201	AMANITA UPPER SAHI	3411DT535	100	MIXED	AMI	Yes	100%	43	0.021546	0.013184	0.008362	38.81%
5049	TPCODL	CUTTACK	AED	NARASINGPUR	GOPAPUR ODSSP	14305	11 KV RATTAPATA	14305201	GOPALPUR VILLAGE	3411DT583	100	MIXED	AMI	Yes	67%	51	0.04860764	0.010379	0.03822864	78.65%
5050	TPCODL	CUTTACK	AED	NARASINGPUR	GOPAPUR ODSSP	14305	11 KV RATTAPATA	14305201	DAMANGIDIA 2	3411DT584	100	MIXED	AMI	Yes	0%	41	0.0263171	0.010721	0.0155961	59.26%
5051	TPCODL	CUTTACK	AED	NARASINGPUR	GOPAPUR ODSSP	14305	11 KV GOPAPUR LOCAL	14305202	NARAYANPRASAD NO 1	3411DT371	100	MIXED	AMI	Yes	0%	80	0.04239222	0.023922	0.01847022	43.57%
5052	TPCODL	CUTTACK	AED	NARASINGPUR	GOPAPUR ODSSP	14305	11 KV GOPAPUR LOCAL	14305202	PADAMALAVPUR SADAKSAHI	3411DT385	100	MIXED	AMI	Yes	100%	145	0.0937289	0.048363	0.0453659	48.40%
5053	TPCODL	CUTTACK	AED	NARASINGPUR	GOPAPUR ODSSP	14305	11 KV GOPAPUR LOCAL	14305202	PADMANAVAPUR VILLAGE	3411DT397	100	MIXED	AMI	Yes	100%	80	0.08456288	0.022967	0.06159588	72.84%
5054	TPCODL	CUTTACK	AED	NARASINGPUR	GOPAPUR ODSSP	14305	11 KV GOPAPUR LOCAL	14305202	GOPAPUR VILLAGE	3411DT400	100	MIXED	AMI	Yes	100%	65	0.08194258	0.026101	0.05584158	68.15%
5055	TPCODL	CUTTACK	AED	NARASINGPUR	GOPAPUR ODSSP	14305	11 KV BHATTARIKA	14305203	JHAJIA	3411DT421	250	MIXED	AMI	Yes	100%	118	0.08068248	0.024195	0.05648748	70.01%
5056	TPCODL	CUTTACK	AED	NARASINGPUR	GOPAPUR ODSSP	14305	11 KV BHATTARIKA	14305203	BAMALIPUR TALA SAHI	3411DT439	100	MIXED	AMI	Yes	0%	85	0.03257394	0.016655	0.01591894	48.87%
5057	TPCODL	CUTTACK	AED	NARASINGPUR	GOPAPUR ODSSP	14305	11 KV BHATTARIKA	14305203	KESHABERENI	3411DT442	100	MIXED	AMI	Yes	100%	87	0.0577632	0.024917	0.0328462	56.86%
5058	TPCODL	CUTTACK	AED	NARASINGPUR	GOPAPUR ODSSP	14305	11 KV BHATTARIKA	14305203	KARADIBANDHA	3411DT455	100	MIXED	AMI	Yes	100%	83	0.05636154	0.018899	0.03746254	66.47%
5059	TPCODL	CUTTACK	AED	NARASINGPUR	GOPAPUR ODSSP	14305	11 KV BHATTARIKA	14305203	KARADIBANDHA-II	3411DT459	100	MIXED	AMI	Yes	67%	85	0.06516546	0.019889	0.04527646	69.48%
5060	TPCODL	CUTTACK	AED	NARASINGPUR	GOPAPUR ODSSP	14305	11 KV BHATTARIKA	14305203	SASANGA MALISAHI	3411DT476	250	MIXED	AMI	Yes	100%	148	0.06304868	0.037215	0.02583368	40.97%
5061	TPCODL	CUTTACK	AED	NARASINGPUR	GOPAPUR ODSSP	14305	11 KV BHATTARIKA	14305203	OGALPUR	3411DT479	100	MIXED	AMI	Yes	33%	106	0.08371026	0.024105	0.05960526	71.20%
5062	TPCODL	CUTTACK	AED	NARASINGPUR	GOPAPUR ODSSP	14305	11 KV BHATTARIKA	14305203	SASANGA BHATTRIKA PITHA2	3411DT490	100	MIXED	AMI	Yes	33%	197	0.06107799	0.052993	0.00808499	13.24%
5063	TPCODL	CUTTACK	AED	NARASINGPUR	KANPUR / KANDHAI	14111	11 KV BAGDHARIA / KAR	14111201	BAUNSAPADA	3412DT033	100	MIXED	AMI	Yes	67%	42	0.0127239	0.00946	0.0032639	25.65%
5064	TPCODL	CUTTACK	AED	NARASINGPUR	KANPUR / KANDHAI	14111	11 KV BAGDHARIA / KAR	14111201	BAGADHARIA 5	3412DT405	100	MIXED	AMI	Yes	67%	105	0.06597636	0.050673	0.01530336	23.20%
5065	TPCODL	CUTTACK	AED	NARASINGPUR	KANPUR / KANDHAI	14111	11 KV BAGDHARIA / KAR	14111201	PAIKABARABATI	3412DT413	100	MIXED	AMI	Yes	67%	91	0.04326516	0.025085	0.01818016	42.02%
5066	TPCODL	CUTTACK	AED	NARASINGPUR	KANPUR / KANDHAI	14111	11 KV KANPUR	14111202	KANPUR BAZAR	3412DT046	100	MIXED	AMI	Yes	0%	88	0.04743826	0.033477	0.01396126	29.43%
5067	TPCODL	CUTTACK	AED	NARASINGPUR	KANPUR / KANDHAI	14111	11 KV KANPUR	14111202	JHARAGADIA VILLAGE	3412DT048	100	MIXED	AMI	Yes	100%	72	0.03647876	0.025799	0.01067976	29.28%
5068	TPCODL	CUTTACK	AED	NARASINGPUR	KANPUR / KANDHAI	14111	11 KV KANPUR	14111202	KANPUR MATHA	3412DT066	500	MIXED	AMI	Yes	100%	185	0.08419304	0.051024	0.03316904	39.40%
5069	TPCODL	CUTTACK	AED	NARASINGPUR	KANPUR / KANDHAI	14111	11 KV KANPUR	14111202	NUA KANJIAPADA BADASANKHA	3412DT072	100	MIXED	AMI	Yes	100%	9	0.00773488	0.004782	0.00295288	38.18%
5070	TPCODL	CUTTACK	AED	NARASINGPUR	KANPUR / KANDHAI	14111	11 KV KANPUR	14111202	NUA KANJIAPADA VILLAGE	3412DT073	250	MIXED	AMI	Yes	100%	215	0.07807772	0.053277	0.02480072	31.76%
5071	TPCODL	CUTTACK	AED	NARASINGPUR	KANPUR / KANDHAI	14111	11 KV KANPUR	14111202	NUA KANJIAPADA MULIASAHI	3412DT074	100	MIXED	AMI	Yes	100%	179	0.0528087	0.039077	0.0137317	26.00%
5072	TPCODL	CUTTACK	AED	NARASINGPUR	KANPUR / KANDHAI	14111	11 KV KANPUR	14111202	NANDAPUR RATANPUR	3412DT077	100	MIXED	AMI	Yes	100%	82	0.03110602	0.021899	0.00920702	29.60%
5073	TPCODL	CUTTACK	AED	NARASINGPUR	KANPUR / KANDHAI	14111	11 KV KANPUR	14111202	PURUNA KANJIAPADA	3412DT089	100	MIXED	AMI	Yes	100%	61	0.0186354	0.015782	0.0028534	15.31%
5074	TPCODL	CUTTACK	AED	NARASINGPUR	KANPUR / KANDHAI	14111	11 KV KANPUR	14111202	PADAMAL VILLAGE	3412DT097	100	MIXED	AMI	Yes	100%	157	0.06546234	0.032768	0.03269434	49.94%
5075	TPCODL	CUTTACK	AED	NARASINGPUR	KANPUR / KANDHAI	14111	11 KV KANPUR	14111202	EKADAL KFW	3412DT108	100	MIXED	AMI	Yes	100%	106	0.03499058	0.018633	0.01635758	46.75%
5076	TPCODL	CUTTACK	AED	NARASINGPUR	KANPUR / KANDHAI	14111	11 KV KANPUR	14111202	EKADAL VILLAGE	3412DT111	250	MIXED	AMI	Yes	100%	281	0.12877904	0.073657	0.05512204	42.80%
5077	TPCODL	CUTTACK	AED	NARASINGPUR	KANPUR / KANDHAI	14111	11 KV KANPUR	14111202	EKADAL MURARIPUR	3412DT117	250	MIXED	AMI	Yes	0%	137	0.03646464	0.025801	0.01066364	29.24%
5078	TPCODL	CUTTACK	AED	NARASINGPUR	KANPUR / KANDHAI	14111	11 KV BALIJHARIA	14111203	BALIJHARI PATHARABANI SAHI	3412DT153	63	MIXED	AMI	Yes	100%	131	0.08968616	0.020812	0.06887416	76.79%
5079	TPCODL	CUTTACK	AED	NARASINGPUR	KANPUR / KANDHAI	14111	11 KV BALIJHARIA	14111203	KALAMATIA	3412DT180	63	MIXED	AMI	Yes	0%	58	0.0257252	0.017256	0.0084692	32.92%
5080	TPCODL	CUTTACK	AED	NARASINGPUR	KANPUR / KANDHAI	14111	11 KV BALIJHARIA	14111203	KALAMATIA MUNDIASAHI	3412DT183	63	MIXED	AMI	Yes	67%	34	0.0285454	0.012254	0.0162914	57.07%
5081	TPCODL	CUTTACK	AED	NARASINGPUR	KANPUR / KANDHAI	14111	11 KV BALIJHARIA	14111203	ATTANDA VILLAGE	3412DT187	100	MIXED	AMI	Yes	0%	115	0.06761408	0.033129	0.03448508	51.00%
5082	TPCODL	CUTTACK	AED	NARASINGPUR	KANPUR / KANDHAI	14111	11 KV BALIJHARIA	14111203	BASELIHATA BAZAR	3412DT191	100	MIXED	AMI	Yes	100%	23	0.04033104	0.010241	0.03009004	74.61%
5083	TPCODL	CUTTACK	AED	NARASINGPUR	KANPUR / KANDHAI	14111	11 KV BALIJHARIA	14111203	KURANJA ROAD	3412DT194	100	MIXED	AMI	Yes	100%	126	0.06055004	0.033319	0.02723104	44.97%
5084	TPCODL	CUTTACK	AED	NARASINGPUR	KANPUR / KANDHAI	14111	11 KV BALIJHARIA	14111203	BALIJHARI PAIKASAHI	3412DT197	500	MIXED	AMI	Yes	100%	89	0.11978552	0.027628	0.09215752	76.94%
5085	TPCODL	CUTTACK	AED	NARASINGPUR	KANPUR / KANDHAI	14111	11 KV BALIJHARIA	14111203	BALIJHARI BAZAR	3412DT204	500	MIXED	AMI	Yes	100%	280	0.21898336	0.062197	0.15678636	71.60%
5086	TPCODL	CUTTACK	AED	NARASINGPUR	KANPUR / KANDHAI	14111	11 KV BALIJHARIA	14111203	BALIJHARI VILLAGE	3412DT205	250	MIXED	AMI	Yes	100%	178	0.11017556	0.051656	0.05851956	53.11%
5087	TPCODL	CUTTACK	AED	NARASINGPUR	KANPUR / KANDHAI	14111	11 KV BALIJHARIA	14111203	KURANJA VILLAGE	3412DT206	100	MIXED	AMI	Yes	100%	99	0.053036	0.01883	0.034206	64.50%
5088	TPCODL	CUTTACK	AED	NARASINGPUR	KANPUR / KANDHAI	14111	11 KV BALIJHARIA	14111203	RATAPAT PATNASAHI	3412DT216	100	MIXED	AMI	Yes	100%	144	0.08711816	0.021217	0.06590116	75.65%
5089	TPCODL	CUTTACK	AED	NARASINGPUR	KANPUR / KANDHAI	14111	11 KV BALIJHARIA	14111203	SHYAMASUNDRAPUR	3412DT220	100	MIXED	AMI	Yes	100%	195	0.08938332	0.03849	0.05089332	56.94%
5090	TPCODL	CUTTACK	AED	NARASINGPUR	KANPUR / KANDHAI	14111	11 KV GODIBANDHA	14111204	JENAPALA	3412DT021	100	MIXED	AMI	Yes	0%	51	0.0281633	0.009795	0.0183683	65.22%
5091	TPCODL	CUTTACK	AED	NARASINGPUR	KANPUR / KANDHAI	14111	11 KV GODIBANDHA	14111204	BICHANABATI VILLAGE	3412DT248	100	MIXED	AMI	Yes	67%	93	0.0266708	0.018205	0.0084658	31.74%
5092	TPCODL	CUTTACK	AED	NARASINGPUR	KANPUR / KANDHAI	14111	11 KV GODIBANDHA	14111204	JANIPADAR VILLAGE	3412DT291	100	MIXED	AMI	Yes	67%	95	0.04173854	0.026409	0.01532954	36.73%
5093	TPCODL	CUTTACK	AED	NARASINGPUR	KANPUR / KANDHAI	14111	11 KV GODIBANDHA	14111204	KHAROD VILLAGE	3412DT299	100	MIXED	AMI	Yes	67%	85	0.0224414	0.012925	0.0095164	42.41%
5094	TPCODL	CUTTACK	AED	NARASINGPUR	KANPUR / KANDHAI	14111	11 KV BASALIHATA	14111205	BISWANATHPUR	3412DT122	100	MIXED	AMI	Yes	100%	53	0.05397754	0.016105	0.03787254	70.16%
5095	TPCODL	CUTTACK	AED	NARASINGPUR	KANPUR / KANDHAI	14111	11 KV BASALIHATA	14111205	SIARIA BADASAHI	3412DT123	100	MIXED	AMI	Yes	100%	87	0.05599864	0.029415	0.02658364	47.47%
5096	TPCODL	CUTTACK	AED	NARASINGPUR	KANPUR / KANDHAI	14111	11 KV BASALIHATA	14111205	SIARIA BUS STAND	3412DT126	100	MIXED	AMI	Yes	0%	90	0.03540788	0.023968	0.01143988	32.31%
5097	TPCODL	CUTTACK	AED	NARASINGPUR	KANPUR / KANDHAI	14111	11 KV BASALIHATA	14111205	HARIPUR KALAPADIA	3412DT136	100	MIXED	AMI	Yes	0%	75	0.07111582	0.021308	0.04980782	70.04%
5098	TPCODL	CUTTACK	AED	NARASINGPUR	KANPUR / KANDHAI	14111	11 KV BASALIHATA	14111205	HARIPUR OLD SAHI	3412DT140	100	MIXED	AMI	Yes	67%	49	0.03860708	0.014767	0.02384008	61.75%
5099	TPCODL	CUTTACK	AED	NARASINGPUR	KANPUR / KANDHAI	14111	11 KV BASALIHATA	14111205	RUSHIPADA PATNA SAHI	3412DT141	100	MIXED	AMI	Yes	100%	117	0.04784884	0.026648	0.02120084	44.31%
5100	TPCODL	CUTTACK	AED	NARASINGPUR	KANPUR / KANDHAI	14111	11 KV BASALIHATA	14111205	RUSHIPADA JALESWAR TEMPLE	3412DT142	100	MIXED	AMI	Yes	0%	133	0.04312924	0.03234	0.01078924	25.02%
5101	TPCODL	CUTTACK	AED	NARASINGPUR	KANPUR / KANDHAI	14111	11 KV BASALIHATA	14111205	KAANARAPIR TOTASAHI	3412DT148	100	MIXED	AMI	Yes	0%	23	0.01052062	0.007572	0.00294862	28.03%
5102	TPCODL	CUTTACK	AED	NARASINGPUR	KANPUR / KANDHAI	14111	11 KV BASALIHATA	14111205	BASELIHATA GP OFFICE	3412DT150	100	MIXED	AMI	Yes	67%	65	0.05921002	0.015111	0.04409902	74.48%
5103	TPCODL	CUTTACK	AED	NARASINGPUR	KANPUR / KANDHAI	14111	11 KV BASALIHATA	14111205	KANDHABERENI	3412DT161	100	MIXED	AMI	Yes	67%	70	0.0236997	0.017344	0.0063557	26.82%
5104	TPCODL	CUTTACK	AED	NARASINGPUR	KANPUR / KANDHAI	14111	11 KV BASALIHATA	14111205	NUA SOLABANDHA	3412DT164	63	MIXED	AMI	Yes	100%	56	0.03798081	0.018796	0.01918481	50.51%
5105	TPCODL	CUTTACK	AED	NARASINGPUR	KANPUR / KANDHAI	14111	11 KV KARILO & BAGADH	14111206	TRILOCHANPUR	3412DT009	100	MIXED	AMI	Yes	67%	47	0.0239324	0.015783	0.0081494	34.05%
5106	TPCODL	CUTTACK	AED	NARASINGPUR	KANPUR / KANDHAI	14111	11 KV KARILO & BAGADH	14111206	KARILO VILLAGE	3412DT317	250	MIXED	AMI	Yes	100%	122	0.06132056	0.044802	0.01651856	26.94%
5107	TPCODL	CUTTACK	AED	NARASINGPUR	KANPUR / KANDHAI	14111	11 KV KARILO & BAGADH	14111206	ADHEIGUNDI NO-1	3412DT318	100	MIXED	AMI	Yes	67%	47	0.03761192	0.023144	0.01446792	38.47%
5108	TPCODL	CUTTACK	AED	NARASINGPUR	KANPUR / KANDHAI	14111	11 KV KARILO & BAGADH	14111206	ADHEIGUNDI NO-2	3412DT319	100	MIXED	AMI	Yes	67%	118	0.07050894	0.036991	0.03351794	47.54%
5109	TPCODL	CUTTACK	AED	NARASINGPUR	KANPUR / KANDHAI	14111	11 KV KARILO & BAGADH	14111206	SAGAR NUASAHI	3412DT331	100	MIXED	AMI	Yes	67%	93	0.06405756	0.028563	0.03549456	55.41%

Sl. No.	Zone Name	Circle name	Division name	Name of the Sub-division	Name of the Sub-station	Substation Code	Name of the 11 kV Feeder	Feeder Code	Name of the Location where DT situated	DT code	DT Capacity (kVA)	Predominant consumer type of DT (Domestic/Industrial/Agriculture/Mixed)	Type of metering AMR/AMI/ Communicable/Conventional metered/Unmetered	Status of Meter-whether Functional (Yes/No)	% of data received automatically (if AMR/AMI)	No. of Connected Consumers	Input Energy (MU) (A)	Billed Energy (MU) (B)	Loss (MU) (A-B)	% DT Loss (A-B)/A
5110	TPCODL	CUTTACK	AED	NARASINGPUR	KANPUR / KANDHAI	14111	11 KV KARILO & BAGADH	14111206	SAGAR PURUNASAHI	3412DT335	250	MIXED	AMI	Yes	67%	124	0.06489676	0.029829	0.03506776	54.04%
5111	TPCODL	CUTTACK	AED	NARASINGPUR	KANPUR / KANDHAI	14111	11 KV KARILO & BAGADH	14111206	GAMILO	3412DT345	100	MIXED	AMI	Yes	67%	85	0.04631624	0.028915	0.01740124	37.57%
5112	TPCODL	CUTTACK	AED	NARASINGPUR	KANPUR / KANDHAI	14111	11 KV KARILO & BAGADH	14111206	BAHALI VILLAGE	3412DT353	100	MIXED	AMI	Yes	100%	36	0.0166497	0.010956	0.0056937	34.20%
5113	TPCODL	CUTTACK	AED	NARASINGPUR	KANPUR / KANDHAI	14111	11 KV KARILO & BAGADH	14111206	GOPALPUR RGGVY-2	3412DT385	63	MIXED	AMI	Yes	100%	45	0.02398562	0.017718	0.00626762	26.13%
5114	TPCODL	CUTTACK	AED	NARASINGPUR	KANPUR / KANDHAI	14111	11 KV KARILO & BAGADH	14111206	GOPALPUR	3412DT386	100	MIXED	AMI	Yes	67%	74	0.05446718	0.039252	0.01521518	27.93%
5115	TPCODL	CUTTACK	AED	NARASINGPUR	KANPUR / KANDHAI	14111	11 KV KARILO & BAGADH	14111206	CHAMPESWAR SINGHDWAR	3412DT387	63	MIXED	AMI	Yes	100%	78	0.03125606	0.031237	1.906E-05	0.06%
5116	TPCODL	CUTTACK	AED	NARASINGPUR	KANPUR / KANDHAI	14111	11 KV KARILO & BAGADH	14111206	CHASABARABATI MATHA	3412DT395	100	MIXED	AMI	Yes	0%	102	0.03321348	0.022179	0.01103448	33.22%
5117	TPCODL	CUTTACK	AED	NARASINGPUR	KANPUR / KANDHAI	14111	11 KV KARILO & BAGADH	14111206	CHAMPESWAR MUNDIASAHI	3412DT400	250	MIXED	AMI	Yes	100%	169	0.0886192	0.068224	0.0203952	23.01%
5118	TPCODL	CUTTACK	AED	NARASINGPUR	KANPUR / KANDHAI	14111	11 KV KARILO & BAGADH	14111206	CHAMPESWAR MALISAHI	3412DT402	100	MIXED	AMI	Yes	67%	69	0.03027776	0.020804	0.00947376	31.29%
5119	TPCODL	CUTTACK	AED	NARASINGPUR	KANPUR / KANDHAI	14111	11 KV KARILO & BAGADH	14111206	PAIKABARABATI GHADEISAHI	3412DT411	100	MIXED	AMI	Yes	67%	148	0.04934204	0.038248	0.01109404	22.48%
5120	TPCODL	CUTTACK	AED	NARASINGPUR	MARDAMEKHA ODS	14304	11 KV KAMALADIHA	14304201	KAMALADIHA GANDHI CHAKA	3413DT345	250	MIXED	AMI	Yes	100%	173	0.09350772	0.06964	0.02386772	25.52%
5121	TPCODL	CUTTACK	AED	NARASINGPUR	MARDAMEKHA ODS	14304	11 KV KAMALADIHA	14304201	REGEDA -I	3413DT367	100	MIXED	AMI	Yes	0%	132	0.05019168	0.035128	0.01506368	30.01%
5122	TPCODL	CUTTACK	AED	NARASINGPUR	MARDAMEKHA ODS	14304	11 KV KAMALADIHA	14304201	KUNJABANAPUR	3413DT390	100	MIXED	AMI	Yes	33%	67	0.01756576	0.015186	0.00237976	13.55%
5123	TPCODL	CUTTACK	AED	NARASINGPUR	MARDAMEKHA ODS	14304	11 KV KAMALADIHA	14304201	JODUM HADISAHI	3413DT395	100	MIXED	AMI	Yes	100%	130	0.04462816	0.041413	0.00321516	7.20%
5124	TPCODL	CUTTACK	AED	NARASINGPUR	MARDAMEKHA ODS	14304	11 KV KAMALADIHA	14304201	ZILLINDA	3413DT405	500	MIXED	AMI	Yes	100%	179	0.16584392	0.092256	0.07358792	44.37%
5125	TPCODL	CUTTACK	AED	NARASINGPUR	NARANGABASTA	14113	11 KV NARANGABASTA M	14113201	KAKHADI MANGALA SAHI	3423DT429	500	MIXED	AMI	Yes	100%	161	0.20934128	0.054169	0.15517228	74.12%
5126	TPCODL	CUTTACK	AED	NARASINGPUR	NARSINGHPUR	14112	11 KV NUKHAPADA	14112201	KENDUPALI	3413DT002	100	MIXED	AMI	Yes	100%	123	0.06848804	0.0508	0.01768804	25.83%
5127	TPCODL	CUTTACK	AED	NARASINGPUR	NARSINGHPUR	14112	11 KV NUKHAPADA	14112201	NUKHAPADA	3413DT003	100	MIXED	AMI	Yes	100%	130	0.04004902	0.03561165	0.00443737	11.08%
5128	TPCODL	CUTTACK	AED	NARASINGPUR	NARSINGHPUR	14112	11 KV NUKHAPADA	14112201	NILAKANTHAPUR	3413DT006	63	MIXED	AMI	Yes	100%	75	0.02435079	0.018317	0.00603379	24.78%
5129	TPCODL	CUTTACK	AED	NARASINGPUR	NARSINGHPUR	14112	11 KV NUKHAPADA	14112201	KAMALADEIPUR	3413DT007	63	MIXED	AMI	Yes	33%	65	0.09047015	0.021976	0.06849415	75.71%
5130	TPCODL	CUTTACK	AED	NARASINGPUR	NARSINGHPUR	14112	11 KV NUKHAPADA	14112201	NUKHAPADA CHOWK	3413DT031	250	MIXED	AMI	Yes	100%	72	0.03498328	0.025745	0.00923828	26.41%
5131	TPCODL	CUTTACK	AED	NARASINGPUR	NARSINGHPUR	14112	11 KV NUKHAPADA	14112201	PATANDA-3	3413DT036	63	MIXED	AMI	Yes	100%	63	0.0295817	0.012872	0.0167097	56.49%
5132	TPCODL	CUTTACK	AED	NARASINGPUR	NARSINGHPUR	14112	11 KV NUKHAPADA	14112201	KAMALADEIPUR KALIMANDIR TEMPL	3413DT044	63	MIXED	AMI	Yes	100%	49	0.02106052	0.01424	0.00682052	32.39%
5133	TPCODL	CUTTACK	AED	NARASINGPUR	NARSINGHPUR	14112	11 KV NUKHAPADA	14112201	BANDHAHUDA -1	3413DT049	100	MIXED	AMI	Yes	100%	139	0.05958502	0.035767	0.02381802	39.97%
5134	TPCODL	CUTTACK	AED	NARASINGPUR	NARSINGHPUR	14112	11 KV NUKHAPADA	14112201	BANDHUHUDA BHAIGA BANDHA SAH	3413DT154	100	MIXED	AMI	Yes	0%	150	0.07402686	0.057828	0.01619886	21.88%
5135	TPCODL	CUTTACK	AED	NARASINGPUR	NARSINGHPUR	14112	11 KV NUKHAPADA	14112201	ALARA HADI SAHI 1	3413DT180	100	MIXED	AMI	Yes	0%	114	0.07303808	0.030644	0.04239408	58.04%
5136	TPCODL	CUTTACK	AED	NARASINGPUR	NARSINGHPUR	14112	11 KV NUKHAPADA	14112201	LEHENGA 1	3413DT187	100	MIXED	AMI	Yes	100%	86	0.05298524	0.017319	0.03566624	67.31%
5137	TPCODL	CUTTACK	AED	NARASINGPUR	NARSINGHPUR	14112	11 KV NUKHAPADA	14112201	ROUT BHUIN 2	3413DT197	63	MIXED	AMI	Yes	100%	96	0.04031116	0.032557	0.00775416	19.24%
5138	TPCODL	CUTTACK	AED	NARASINGPUR	NARSINGHPUR	14112	11 KV NUKHAPADA	14112201	ALARA	3413DT207	100	MIXED	AMI	Yes	100%	76	0.04033306	0.015859	0.02447406	60.68%
5139	TPCODL	CUTTACK	AED	NARASINGPUR	NARSINGHPUR	14112	11 KV KAKUDIA (NARASI	14112202	OLD PHULAPADA	3413DT113	100	MIXED	AMI	Yes	100%	136	0.05216764	0.034444	0.01772364	33.97%
5140	TPCODL	CUTTACK	AED	NARASINGPUR	NARSINGHPUR	14112	11 KV KAKUDIA (NARASI	14112202	JAYAMANGAL-I	3413DT122	100	MIXED	AMI	Yes	100%	95	0.05363784	0.028566	0.02507184	46.74%
5141	TPCODL	CUTTACK	AED	NARASINGPUR	NARSINGHPUR	14112	11 KV KAKUDIA (NARASI	14112202	KAKUDIA-I	3413DT511	100	MIXED	AMI	Yes	100%	100	0.03770538	0.033483	0.00422238	11.20%
5142	TPCODL	CUTTACK	AED	NARASINGPUR	NARSINGHPUR	14112	11 KV KAKUDIA (NARASI	14112202	KAKUDIA-II	3413DT512	100	MIXED	AMI	Yes	100%	87	0.06592434	0.029394	0.03653034	55.41%
5143	TPCODL	CUTTACK	AED	NARASINGPUR	NARSINGHPUR	14112	11 KV KAKUDIA (NARASI	14112202	NUAPATNA-I	3413DT543	100	MIXED	AMI	Yes	100%	167	0.06145674	0.048678	0.01277874	20.79%
5144	TPCODL	CUTTACK	AED	NARASINGPUR	NARSINGHPUR	14112	11 KV NARSINGHPUR TO	14112203	NARSINGHPUR PITHAKHAI	3413DT020	100	MIXED	AMI	Yes	100%	83	0.08875442	0.087315	0.00143942	1.62%
5145	TPCODL	CUTTACK	AED	NARASINGPUR	NARSINGHPUR	14112	11 KV NARSINGHPUR TO	14112203	NARSINGHPUR HANUMANTIA	3413DT023	250	MIXED	AMI	Yes	100%	124	0.17537472	0.108713	0.06666172	38.01%
5146	TPCODL	CUTTACK	AED	NARASINGPUR	NARSINGHPUR	14112	11 KV NARSINGHPUR TO	14112203	NARSINGHPUR CLUB CHHAK	3413DT024	500	MIXED	AMI	Yes	0%	344	0.38339432	0.163893	0.21950132	57.25%
5147	TPCODL	CUTTACK	AED	NARASINGPUR	NARSINGHPUR	14112	11 KV NARSINGHPUR TO	14112203	NUA SAHI NARSINGHPUR HANUMAN	3413DT026	100	MIXED	AMI	Yes	100%	96	0.0709303	0.043238	0.0276923	39.04%
5148	TPCODL	CUTTACK	AED	NARASINGPUR	NARSINGHPUR	14112	11 KV NARSINGHPUR TO	14112203	NARSINGHPUR THANA CHHAK	3413DT027	250	MIXED	AMI	Yes	100%	76	0.09057804	0.050167	0.04041104	44.61%
5149	TPCODL	CUTTACK	AED	NARASINGPUR	NARSINGHPUR	14112	11 KV NARSINGHPUR TO	14112203	BLOCK OFFICE N P.PUR	3413DT056	100	MIXED	AMI	Yes	100%	39	0.07275634	0.056376	0.01638034	22.51%
5150	TPCODL	CUTTACK	AED	NARASINGPUR	NARSINGHPUR	14112	11 KV NARSINGHPUR TO	14112203	OSTANARAYANPUR -II	3413DT059	100	MIXED	AMI	Yes	100%	52	0.06840712	0.026129	0.04227812	61.80%
5151	TPCODL	CUTTACK	AED	NARASINGPUR	NARSINGHPUR	14112	11 KV NARSINGHPUR TO	14112203	Ostanarayanpur-I	3413DT060	250	MIXED	AMI	Yes	100%	114	0.13498608	0.043418	0.09156808	67.84%
5152	TPCODL	CUTTACK	AED	NARASINGPUR	NARSINGHPUR	14112	11 KV NARSINGHPUR TO	14112203	NIMASAHI	3413DT067	100	MIXED	AMI	Yes	100%	24	0.07527756	0.020678	0.05459956	72.53%
5153	TPCODL	CUTTACK	AED	NARASINGPUR	NARSINGHPUR	14112	11 KV NARSINGHPUR TO	14112203	DAMASAHI-II	3413DT068	100	MIXED	AMI	Yes	100%	51	0.05886932	0.015828	0.04304132	73.11%
5154	TPCODL	CUTTACK	AED	NARASINGPUR	NARSINGHPUR	14112	11 KV NARSINGHPUR TO	14112203	DAMAKATA-I	3413DT075	250	MIXED	AMI	Yes	100%	86	0.05684016	0.0353634	0.02147676	37.78%
5155	TPCODL	CUTTACK	AED	NARASINGPUR	NARSINGHPUR	14112	11 KV NARSINGHPUR TO	14112203	PANDASAHI-I	3413DT090	100	MIXED	AMI	Yes	0%	46	0.0660266	0.028077	0.0379496	57.48%
5156	TPCODL	CUTTACK	AED	NARASINGPUR	NARSINGHPUR	14112	11 KV NARSINGHPUR TO	14112203	N.P.PUR STRUCTURE -I	3413DT092	100	MIXED	AMI	Yes	0%	121	0.09856448	0.078681	0.01988348	20.17%
5157	TPCODL	CUTTACK	AED	NARASINGPUR	NARSINGHPUR	14112	11 KV NARSINGHPUR TO	14112203	NIZIGARH BALISAHI-I	3413DT094	100	MIXED	AMI	Yes	0%	90	0.05133592	0.034425	0.01691092	32.94%
5158	TPCODL	CUTTACK	AED	NARASINGPUR	NARSINGHPUR	14112	11 KV NARSINGHPUR TO	14112203	JAMADEIPUR	3413DT097	100	MIXED	AMI	Yes	100%	95	0.03835546	0.03277	0.00558546	14.56%
5159	TPCODL	CUTTACK	AED	NARASINGPUR	NARSINGHPUR	14112	11 KV NARSINGHPUR TO	14112203	PARBHATIPUR-III	3413DT105	100	MIXED	AMI	Yes	0%	23	0.0165124	0.011012	0.0055004	33.31%
5160	TPCODL	CUTTACK	AED	NARASINGPUR	NARSINGHPUR	14112	11 KV NARSINGHPUR TO	14112203	N.P.PUR STRUCTURE -II	3413DT112	100	MIXED	AMI	Yes	0%	195	0.09656646	0.063143	0.03342346	34.61%
5161	TPCODL	CUTTACK	AED	NARASINGPUR	NARSINGHPUR	14112	11 KV NARSINGHPUR TO	14112203	MULIAPADA	3413DT139	100	MIXED	AMI	Yes	100%	67	0.0172194	0.013604	0.0036154	21.00%
5162	TPCODL	CUTTACK	AED	NARASINGPUR	NARSINGHPUR	14112	11 KV KAMALADIHA OLD	14112204	JAGANNATH PUR	3413DT227	100	MIXED	AMI	Yes	0%	133	0.05290014	0.033399	0.01950114	36.86%
5163	TPCODL	CUTTACK	AED	NARASINGPUR	NARSINGHPUR	14112	11 KV KAMALADIHA OLD	14112204	BADABHUIN	3413DT476	100	MIXED	AMI	Yes	100%	53	0.04954246	0.017633	0.03190946	64.41%
5164	TPCODL	CUTTACK	AED	NARASINGPUR	NARSINGHPUR	14112	11 KV KAMALADIHA OLD	14112204	GHANTAPADA-I	3413DT485	100	MIXED	AMI	Yes	100%	22	0.01856672	0.005276	0.01329072	71.58%
5165	TPCODL	CUTTACK	AED	NARASINGPUR	NARSINGHPUR	14112	11 KV KAMALADIHA OLD	14112204	SARGUNAPALI	3413DT496	100	MIXED	AMI	Yes	100%	33	0.00559662	0.004557	0.00103962	18.58%
5166	TPCODL	CUTTACK	AED	NARASINGPUR	NARSINGHPUR	14112	11 KV KAMALADIHA OLD	14112204	KOKOLABA-I	3413DT609	100	MIXED	AMI	Yes	100%	69	0.03481486	0.025966	0.00884886	25.42%
5167	TPCODL	CUTTACK	AED	NARASINGPUR	NARSINGHPUR	14112	11 KV KAMALADIHA OLD	14112204	NEW KATHAKHUNTA	3413DT616	100	MIXED	AMI	Yes	100%	114	0.06175766	0.028752	0.03300566	53.44%
5168	TPCODL	CUTTACK	AED	NARASINGPUR	NARSINGHPUR	14112	11 KV KAMALADIHA OLD	14112204	KHATAKHUNTA	3413DT617	100	MIXED	AMI	Yes	100%	72	0.04234778	0.013984	0.02836378	66.98%
5169	TPCODL	CUTTACK	AED	NARASINGPUR	NARSINGHPUR	14112	11 KV KAMALADIHA OLD	14112204	NUAGAON-I	3413DT643	100	MIXED	AMI	Yes	0%	53	0.04531712	0.016153	0.02916412	64.36%
5170	TPCODL	CUTTACK	AED	NARASINGPUR	NARSINGHPUR	14112	11 KV KAMALADIHA OLD	14112204	NAKHAPADA -I	3413DT649	100	MIXED	AMI	Yes	100%	88	0.02516184	0.015019	0.01014284	40.31%
5171	TPCODL	CUTTACK	AED	NARASINGPUR	NARSINGHPUR	14112	11 KV KAMALADIHA OLD	14112204	KRUSHNAPRASAD	3413DT680	100	MIXED	AMI	Yes	100%	48	0.00844594	0.005601	0.00284494	33.68%
5172	TPCODL	CUTTACK	AED	NARASINGPUR	NARSINGHPUR	14112	11 KV JAIPUR	14112205	CHATARAPADA	3413DT018	100	MIXED	AMI	Yes	100%	20	0.00542672	0.005109	0.00031772	5.85%
5173	TPCODL	CUTTACK	AED	NARASINGPUR	NARSINGHPUR	14112	11 KV JAIPUR	14112205	ANANTAPRASAD-1	3413DT281	100	MIXED	AMI	Yes	67%	36	0.00894078	0.003912	0.00502878	56.25%
5174	TPCODL	CUTTACK	CDD-1	SUB DIVISION 01	MATAMATHA	14209	11 kV CB9	14209202	JAGANNATH HOME (P) LTD	3111DT055	250	MIXED	AMI	Yes	0%	33	0.08000428	0.075471	0.00453328	5.67%
5175	TPCODL	CUTTACK	CDD-1	SUB DIVISION 01	MATAMATHA	14209	11 kV CB9	14209202	MS. KIRON PROJECT 1	3111DT058	250	MIXED	AMI	Yes	0%	33	0.06916776	0.068108	0.00105976	1.53%
5176	TPCODL	CUTTACK	CDD-1	SUB DIVISION 01	MATAMATHA	14209	11 kV CB9	14209202	PRACHI COMPLEX	3111DT064	100	MIXED	AMI	Yes	0%	21	0.01758612	0.015116	0.00247012	14.05%
5177	TPCODL	CUTTACK	CDD-1	SUB DIVISION 01	MATAMATHA	14209	11 kV CB9	14209202	CM ROAD(GIRNER HOTEL)(CAPEX)	3111DT065	250	MIXED	AMI	Yes	100%	77	0.11823752	0.058036	0.06020152	50.92%
5178	TPCODL	CUTTACK	CDD-1	SUB DIVISION 01	MATAMATHA	14209	11 kV CB9	14209202	HONDA SHOWROOM BACK 1	3111DT118	500	MIXED	AMI	Yes	0%	56	0.08419032	0.071887	0.01230332	14.61%
5179	TPCODL	CUTTACK	CDD-1	SUB DIVISION 01	MATAMATHA	14209	11 kV CB9	14209202	HONDA SHOWROOM BACK 2	3111DT119	250	MIXED	AMI	Yes	0%	36	0.04313284	0.043128	4.84E-06	0.01%
5180	TPCODL	CUTTACK	CDD-1	SUB DIVISION 01	JOBRA	14082	11 kV RAILWAY	14082202	PLATINUM APARTMENT	3112DT032	160	MIXED	AMI	Yes	0%	25	0.0329242	0.021925	0.0109992	33.41%
5181	TPCODL	CUTTACK	CDD-1	SUB DIVISION 01	MEDICAL	14083	11 kV RANIHAT	14083202	ANIL KU AGARWAL	3113DT006	250	MIXED	AMI	Yes	100%	9	0.0426492	0.014876	0.0277732	65.12%
5182	TPCODL	CUTTACK	CDD-1	SUB DIVISION 01	MEDICAL	14083	11 kV TELEPHONE BHAW	14083201	HEALING TOUCH NURSING HOME	3113DT056	250	MIXED	AMI	Yes	0%	69	0.15395068	0.085717	0.06823368	44.32%

Sl. No.	Zone Name	Circle name	Division name	Name of the Sub-division	Name of the Sub-station	Substation Code	Name of the 11 kV Feeder	Feeder Code	Name of the Location where DT situated	DT code	DT Capacity (kVA)	Predominant consumer type of DT (Domestic/Industrial/Agriculture/Mixed)	Type of metering AMR/AMI/ Communicable/Conventional metered/Unmetered	Status of Meter-whether Functional (Yes/No)	% of data received automatically (if AMR/AMI)	No. of Connected Consumers	Input Energy (MU) (A)	Billed Energy (MU) (B)	Loss (MU) (A-B)	% DT Loss (A-B)/A
5183	TPCODL	CUTTACK	CDD-1	SUB DIVISION 01	DRDA	14210	11 KV KAZIBAZAR	14210202	CTC CENTRAL CO-OPERATIVE BANK2	3123DT002	500	MIXED	AMI	Yes	0%	167	0.4511184	0.213063	0.2380554	52.77%
5184	TPCODL	CUTTACK	CDD-1	SUB DIVISION 01	JOBRA	14082	11 KV RAILWAY	14082202	MAP-III	3112DT008	250	MIXED	AMI	Yes	100%	122	0.24658764	0.107146	0.13944164	56.55%
5185	TPCODL	CUTTACK	CDD-1	SUB DIVISION 01	JOBRA	14082	11 KV RAILWAY	14082202	LIC COLONY SS(SI)	3112DT014	250	MIXED	AMI	Yes	100%	50	0.25190684	0.053842	0.19806484	78.63%
5186	TPCODL	CUTTACK	CDD-1	SUB DIVISION 01	JOBRA	14082	11 KV RAILWAY	14082202	BOMBAY HOTEL 1	3112DT026	500	MIXED	AMI	Yes	100%	93	0.197912	0.104413	0.093499	47.24%
5187	TPCODL	CUTTACK	CDD-1	SUB DIVISION 01	JOBRA	14082	11 KV RAILWAY	14082202	NEAR BOMBAY HOTEL	3112DT027	250	MIXED	AMI	Yes	100%	92	0.1887552	0.130653	0.0581022	30.78%
5188	TPCODL	CUTTACK	CDD-1	SUB DIVISION 01	JOBRA	14082	11 KV RAVENSHAW	14082203	CDA MARKET 1	3112DT065	250	MIXED	AMI	Yes	100%	51	0.10171892	0.043467	0.05825192	57.27%
5189	TPCODL	CUTTACK	CDD-1	SUB DIVISION 01	JOBRA	14082	11 KV RAVENSHAW	14082203	LAW COLLEGE	3112DT071	250	MIXED	AMI	Yes	100%	22	0.17596584	0.037306	0.13865984	78.80%
5190	TPCODL	CUTTACK	CDD-1	SUB DIVISION 01	JOBRA	14082	11 KV RAVENSHAW	14082203	CDA MARKET	3112DT126	630	MIXED	AMI	Yes	0%	54	0.0640045	0.040695	0.0233095	36.42%
5191	TPCODL	CUTTACK	CDD-1	SUB DIVISION 01	JOBRA	14082	11 KV JOBRA BARRAGE	14082204	JOBRA FIELD SS	3112DT095	250	MIXED	AMI	Yes	100%	209	0.21615772	0.196897	0.01926072	8.91%
5192	TPCODL	CUTTACK	CDD-1	SUB DIVISION 01	JOBRA	14082	11 KV JOBRA BARRAGE	14082204	BAIBABA MATHA 2	3112DT102	100	MIXED	AMI	Yes	100%	81	0.1042732	0.095024	0.0092492	8.87%
5193	TPCODL	CUTTACK	CDD-1	SUB DIVISION 01	JOBRA	14082	11 KV JOBRA BARRAGE	14082204	TRENCHING GROUND 2	3112DT104	250	MIXED	AMI	Yes	100%	132	0.20868156	0.096197	0.11248456	53.90%
5194	TPCODL	CUTTACK	CDD-1	SUB DIVISION 01	JOBRA	14082	11 KV JOBRA BARRAGE	14082204	MUNICIPALITY COLONY SS	3112DT106	250	MIXED	AMI	Yes	100%	198	0.20581388	0.194486	0.01132788	5.50%
5195	TPCODL	CUTTACK	CDD-1	SUB DIVISION 01	JOBRA	14082	11 KV MATAMATHA	14082205	HERO HONDA2	3114DT114	250	MIXED	AMI	Yes	100%	55	0.16755716	0.111449	0.05610816	33.49%
5196	TPCODL	CUTTACK	CDD-1	SUB DIVISION 01	JOBRA	14082	11 KV COLLEGE SQ. UG	14082206	PILIGRIM ROAD	3112DT047	250	MIXED	AMI	Yes	100%	65	0.08449724	0.075202	0.00929524	11.00%
5197	TPCODL	CUTTACK	CDD-1	SUB DIVISION 01	KALINGA	14084	11 KV JNI Stadium	14084205	CHIEF JUSTICE	3131DT051	100	MIXED	AMI	Yes	100%	8	0.0229411	0.010956	0.0119851	52.24%
5198	TPCODL	CUTTACK	CDD-1	SUB DIVISION 01	KALYANI NAGAR	14089	11 KV RING-1	14089203	BALABHADRAPUR 1	3212DT021	500	MIXED	AMI	Yes	100%	85	0.44405272	0.129854	0.31419872	70.76%
5199	TPCODL	CUTTACK	CDD-1	SUB DIVISION 01	KHAN NAGAR (BADA	14296	11 KV Mahatab	14296201	DOLAMUNDAI 5	3212DT140	250	MIXED	AMI	Yes	100%	246	0.29556656	0.21929	0.07627656	25.81%
5200	TPCODL	CUTTACK	CDD-1	SUB DIVISION 01	KHAN NAGAR (BADA	14296	11 KV Mahatab	14296201	DOLAMUNDAI JE OFFICE	3212DT202	630	MIXED	AMI	Yes	0%	146	0.53803175	0.305829	0.23220275	43.16%
5201	TPCODL	CUTTACK	CDD-1	SUB DIVISION 01	MATAMATHA	14209	11 KV CB9	14209202	SARTHAK TOWER	3111DT039	500	MIXED	AMI	Yes	67%	30	0.1734424	0.06263	0.1108124	63.89%
5202	TPCODL	CUTTACK	CDD-1	SUB DIVISION 01	MATAMATHA	14209	11 KV CB9	14209202	MATAMATHA	3111DT043	500	MIXED	AMI	Yes	0%	168	0.46566472	0.157945	0.30771972	66.08%
5203	TPCODL	CUTTACK	CDD-1	SUB DIVISION 01	MATAMATHA	14209	11 KV CB9	14209202	JE OFFICE 1	3111DT047	500	MIXED	AMI	Yes	33%	29	0.11119357	0.025831	0.08536257	76.77%
5204	TPCODL	CUTTACK	CDD-1	SUB DIVISION 01	MATAMATHA	14209	11 KV CB9	14209202	TELEPHONE QTR	3111DT084	250	MIXED	AMI	Yes	0%	18	0.16676744	0.039047	0.12772044	76.59%
5205	TPCODL	CUTTACK	CDD-1	SUB DIVISION 01	MATAMATHA	14209	11 KV MUSEUM	14209203	METRO MANORAMA COMPLEX	3111DT089	500	MIXED	AMI	Yes	100%	45	0.10615344	0.048928	0.05722544	53.91%
5206	TPCODL	CUTTACK	CDD-1	SUB DIVISION 01	MATAMATHA	14209	11 KV BUXI BAZAR	14209204	BEPARI SAHI	3111DT025	500	MIXED	AMI	Yes	0%	154	0.36788832	0.155859	0.21202932	57.63%
5207	TPCODL	CUTTACK	CDD-1	SUB DIVISION 01	MATAMATHA	14209	11 KV BUXI BAZAR	14209204	MOHANTY LANE-1	3111DT030	500	MIXED	AMI	Yes	100%	92	0.44077872	0.122657	0.31812172	72.17%
5208	TPCODL	CUTTACK	CDD-1	SUB DIVISION 01	MATAMATHA	14209	11 KV BUXI BAZAR	14209204	BANIA SAHI-1	3111DT035	250	MIXED	AMI	Yes	100%	162	0.19847132	0.160382	0.03808932	19.19%
5209	TPCODL	CUTTACK	CDD-1	SUB DIVISION 01	MATAMATHA	14209	11 KV BUXI BAZAR	14209204	BANIA SAHI-2	3111DT036	250	MIXED	AMI	Yes	0%	224	0.4063644	0.243309	0.1630554	40.13%
5210	TPCODL	CUTTACK	CDD-1	SUB DIVISION 01	MATAMATHA	14209	11 KV BUXI BAZAR	14209204	FIRE OFFICE(RAPDRP)	3111DT037	250	MIXED	AMI	Yes	100%	77	0.14620836	0.085073	0.06113536	41.81%
5211	TPCODL	CUTTACK	CDD-1	SUB DIVISION 01	MATAMATHA	14209	11 KV BUXI BAZAR	14209204	AKADA GALI 2	3111DT114	250	MIXED	AMI	Yes	0%	122	0.18777356	0.088125	0.09964856	53.07%
5212	TPCODL	CUTTACK	CDD-1	SUB DIVISION 01	MEDICAL	14083	11 KV TELEPHONE BHAW	14083201	DAS HOSPITAL	3113DT048	250	MIXED	AMI	Yes	0%	139	0.2558338	0.197936	0.0578978	22.63%
5213	TPCODL	CUTTACK	CDD-1	SUB DIVISION 01	MEDICAL	14083	11 KV TELEPHONE BHAW	14083201	KALYANI APARTMENT-CESU	3113DT049	250	MIXED	AMI	Yes	100%	48	0.12090172	0.060823	0.06007872	49.69%
5214	TPCODL	CUTTACK	CDD-1	SUB DIVISION 01	MEDICAL	14083	11 KV TELEPHONE BHAW	14083201	BATAGALI	3113DT051	200	MIXED	AMI	Yes	100%	67	0.10314644	0.093127	0.01001944	9.71%
5215	TPCODL	CUTTACK	CDD-1	SUB DIVISION 01	MEDICAL	14083	11 KV TELEPHONE BHAW	14083201	CHOURASI MANDAL	3113DT053	500	MIXED	AMI	Yes	100%	136	0.4322588	0.160125	0.2721338	62.96%
5216	TPCODL	CUTTACK	CDD-1	SUB DIVISION 01	MEDICAL	14083	11 KV TELEPHONE BHAW	14083201	GAMANDIA (JICA)	3113DT060	250	MIXED	AMI	Yes	100%	143	0.21255324	0.197983	0.01457024	6.85%
5217	TPCODL	CUTTACK	CDD-1	SUB DIVISION 01	MEDICAL	14083	11 KV TELEPHONE BHAW	14083201	FRIENDS COLLONY	3113DT070	250	MIXED	AMI	Yes	0%	39	0.1113264	0.043765	0.0675614	60.69%
5218	TPCODL	CUTTACK	CDD-1	SUB DIVISION 01	MEDICAL	14083	11 KV TELEPHONE BHAW	14083201	SANTASAHI,JAICA-II	3133DT040	500	MIXED	AMI	Yes	100%	131	0.3058896	0.179718	0.1261716	41.25%
5219	TPCODL	CUTTACK	CDD-1	SUB DIVISION 01	MEDICAL	14083	11 KV RANIHAT	14083202	HIND CINEMA SS	3113DT003	500	MIXED	AMI	Yes	0%	143	0.23405648	0.148556	0.08550048	36.53%
5220	TPCODL	CUTTACK	CDD-1	SUB DIVISION 01	MEDICAL	14083	11 KV RANIHAT	14083202	SARPESWAR TEMPLE	3113DT004	500	MIXED	AMI	Yes	0%	206	0.26859176	0.198431	0.07016076	26.12%
5221	TPCODL	CUTTACK	CDD-1	SUB DIVISION 01	MEDICAL	14083	11 KV RANIHAT	14083202	RANIHAT OLD PHD	3113DT005	500	MIXED	AMI	Yes	0%	238	0.39730592	0.233892	0.16341392	41.13%
5222	TPCODL	CUTTACK	CDD-1	SUB DIVISION 01	MEDICAL	14083	11 KV MANGALABAG	14083203	RANIHAT ELECTRICITY OFF 1 (GOPAL	3114DT017	500	MIXED	AMI	Yes	100%	270	0.28310449	0.208905	0.07419949	26.21%
5223	TPCODL	CUTTACK	CDD-1	SUB DIVISION 01	MEDICAL	14083	11 KV MANGALABAG	14083203	P.G. HOSTEL-I SS	3114DT025	250	MIXED	AMI	Yes	0%	53	0.14443216	0.12702	0.01741216	12.06%
5224	TPCODL	CUTTACK	CDD-1	SUB DIVISION 01	MEDICAL	14083	11 KV MANGALABAG	14083203	VETNARY SS 1	3114DT028	500	MIXED	AMI	Yes	0%	41	0.29728336	0.071679	0.22560436	75.89%
5225	TPCODL	CUTTACK	CDD-1	SUB DIVISION 01	MEDICAL	14083	11 KV MANGALABAG	14083203	SUNAKAR SS	3114DT033	500	MIXED	AMI	Yes	0%	234	0.4121236	0.224599	0.1875246	45.50%
5226	TPCODL	CUTTACK	CDD-1	SUB DIVISION 01	MEDICAL	14083	11 KV MANGALABAG	14083203	OUTDOOR SS	3114DT034	500	MIXED	AMI	Yes	100%	28	0.1832216	0.037336	0.1458856	79.62%
5227	TPCODL	CUTTACK	CDD-1	SUB DIVISION 01	RANIHAT	14378	11 KV OGFED-3	14378203	RAMACHANDRA APARTMENT	3113DT025	100	MIXED	AMI	Yes	100%	6	0.02841152	0.019048	0.00936352	32.96%
5228	TPCODL	CUTTACK	CDD-1	SUB DIVISION 01	RANIHAT	14378	11 KV OGFED-3	14378203	CESU OFFICE BR CSS-7	3114DT171	630	MIXED	AMI	Yes	100%	50	0.25932776	0.056354	0.20297376	78.27%
5229	TPCODL	CUTTACK	CDD-1	SUB DIVISION 01	RANIHAT	14378	11 KV OGFED-4	14378204	NEAR BY BSNL 2	3113DT084	630	MIXED	AMI	Yes	100%	73	0.22633338	0.113461	0.11287238	49.87%
5230	TPCODL	CUTTACK	CDD-1	SUB DIVISION 01	BIDANASI	17019	33 kV SISHUBHABAN-1	17019405	33/11 kV JAIL SS ST	3121DT001	250	MIXED	AMI	Yes	67%	11	0.00835691	0.003338	0.00501891	60.06%
5231	TPCODL	CUTTACK	CDD-1	SUB DIVISION 01	SISHUBHABAN	14081	11 kV TOWNHALL	14081202	METRO RIVER VIEW	3122DT025	250	MIXED	AMI	Yes	0%	34	0.04183052	0.036099	0.00573152	13.70%
5232	TPCODL	CUTTACK	CDD-1	SUB DIVISION 01	BIDANASI	14085	11 KV TULASIPUR	14085204	HATI GADA	3143DT092	250	MIXED	AMI	Yes	100%	25	0.0187938	0.014895	0.0038988	20.75%
5233	TPCODL	CUTTACK	CDD-1	SUB DIVISION 01	DRDA	14210	11 KV GANESHGHAT	14210201	GANESHGHAT SECTION BACK SIDE	3121DT061	500	MIXED	AMI	Yes	0%	169	0.23609368	0.187092	0.04900168	20.76%
5234	TPCODL	CUTTACK	CDD-1	SUB DIVISION 01	DRDA	14210	11 KV GANESHGHAT	14210201	GANESHGHAT	3122DT023	250	MIXED	AMI	Yes	100%	176	0.26071712	0.201268	0.05944912	22.80%
5235	TPCODL	CUTTACK	CDD-1	SUB DIVISION 01	DRDA	14210	11 KV GANESHGHAT	14210201	ARADHANA APARTMENT	3122DT043	250	MIXED	AMI	Yes	100%	10	0.03984124	0.009902	0.02993924	75.15%
5236	TPCODL	CUTTACK	CDD-1	SUB DIVISION 01	DRDA	14210	11 KV GANESHGHAT	14210201	MANIK GHOS BAZAR	3122DT046	500	MIXED	AMI	Yes	0%	168	0.4817828	0.17074	0.3110428	64.56%
5237	TPCODL	CUTTACK	CDD-1	SUB DIVISION 01	DRDA	14210	11 KV GANESHGHAT	14210201	BAKHARA BAG	3122DT050	500	MIXED	AMI	Yes	100%	109	0.34720024	0.10592	0.24128024	69.49%
5238	TPCODL	CUTTACK	CDD-1	SUB DIVISION 01	DRDA	14210	11 KV KAZIBAZAR	14210202	NAVODAY ENCLAVE	3123DT008	100	MIXED	AMI	Yes	100%	17	0.01642022	0.014515	0.00190522	11.60%
5239	TPCODL	CUTTACK	CDD-1	SUB DIVISION 01	DRDA	14210	11 KV KAZIBAZAR	14210202	NETAJI MUSIOM1	3123DT015	500	MIXED	AMI	Yes	0%	84	0.26168	0.08139	0.18029	68.90%
5240	TPCODL	CUTTACK	CDD-1	SUB DIVISION 01	DRDA	14210	11 KV JUDGE COURT	14210203	LOCAL JUDGE COURT	3122DT008	500	MIXED	AMI	Yes	0%	177	0.19944304	0.190367	0.00907604	4.55%
5241	TPCODL	CUTTACK	CDD-1	SUB DIVISION 01	DRDA	14210	11 KV JUDGE COURT	14210203	KALI GALI	3122DT011	500	MIXED	AMI	Yes	0%	222	0.28566608	0.248114	0.03755208	13.15%
5242	TPCODL	CUTTACK	CDD-1	SUB DIVISION 01	JAGATPUR	14088	11 KV OLD INDUSTRIAL	14088204	LAXMI BIHAR	3223DT119	500	MIXED	AMI	Yes	100%	329	0.34726592	0.347275	-9.08E-06	0.00%
5243	TPCODL	CUTTACK	CDD-1	SUB DIVISION 01	JAIL	14086	11 KV HATIPOKHARI	14086201	KADAM RASUL	3121DT031	250	MIXED	AMI	Yes	100%	58	0.11543572	0.04717	0.06826572	59.14%
5244	TPCODL	CUTTACK	CDD-1	SUB DIVISION 01	JAIL	14086	11 KV HATIPOKHARI	14086201	HATI POKHARI 3	3121DT035	250	MIXED	AMI	Yes	100%	214	0.31511528	0.195624	0.11949128	37.92%
5245	TPCODL	CUTTACK	CDD-1	SUB DIVISION 01	JAIL	14086	11 KV HATIPOKHARI	14086201	KOCHILA KHAI-2	3121DT037	250	MIXED	AMI	Yes	0%	42	0.08130756	0.052537	0.02877056	35.38%
5246	TPCODL	CUTTACK	CDD-1	SUB DIVISION 01	JAIL	14086	11 KV HATIPOKHARI	14086201	KOCHILA KHAI-1	3121DT039	500	MIXED	AMI	Yes	100%	173	0.334698	0.157019	0.177679	53.09%
5247	TPCODL	CUTTACK	CDD-1	SUB DIVISION 01	JAIL	14086	11 KV HATIPOKHARI	14086201	KUMBHAR SAHI 2	3121DT041	500	MIXED	AMI	Yes	100%	351	0.40711472	0.286393	0.12072172	29.65%
5248	TPCODL	CUTTACK	CDD-1	SUB DIVISION 01	JAIL	14086	11 KV HATIPOKHARI	14086201	KUMBHAR SAHI 1	3121DT042	250	MIXED	AMI	Yes	0%	46	0.17461108	0.036738	0.13787308	78.96%
5249	TPCODL	CUTTACK	CDD-1	SUB DIVISION 01	JAIL	14086	11 KV HATIPOKHARI	14086201	NANDI SAHI-1	3124DT031	500	MIXED	AMI	Yes	0%	145	0.37262808	0.174708	0.19792008	53.11%
5250	TPCODL	CUTTACK	CDD-1	SUB DIVISION 01	JAIL	14086	11 KV HATIPOKHARI	14086201	KATHAGADA SAHI-1	3124DT032	250	MIXED	AMI	Yes	0%	162	0.29764212	0.24397	0.05367212	18.03%
5251	TPCODL	CUTTACK	CDD-1	SUB DIVISION 01	JAIL	14086	11 KV CITY	14086203	NAYASADAK	3121DT017	500	MIXED	AMI	Yes	100%	124	0.3109776	0.173513	0.1374646	44.20%
5252	TPCODL	CUTTACK	CDD-1	SUB DIVISION 01	JAIL	14086	11 KV CITY	14086203	GANGA MANDIR(BRUNDABAN APPAI	3121DT019	200	MIXED	AMI	Yes	100%	13	0.03833464	0.017096	0.02123864	55.40%
5253	TPCODL	CUTTACK	CDD-1	SUB DIVISION 01	JAIL	14086	11 KV CITY	14086203	KEUTA SAHI-1	3121DT025	250	MIXED	AMI	Yes	100%	37	0.12140876	0.042028	0.07938076	65.38%
5254	TPCODL	CUTTACK	CDD-1	SUB DIVISION 01	JAIL	14086	11 KV CITY	14086203	KEUTA SAHI-2	3121DT026	250	MIXED	AMI	Yes	0%	72	0.12805344	0.095605	0.03244844	25.34%
5255	TPCODL	CUTTACK	CDD-1	SUB DIVISION 01	JAIL	14086	11 KV CITY	14086203	CHUNABHATI GALI 3	3123DT039	250	MIXED	AMI	Yes	100%	32	0.04328674	0.029633	0.01365374	31.54%

Sl. No.	Zone Name	Circle name	Division name	Name of the Sub-division	Name of the Sub-station	Substation Code	Name of the 11 kV Feeder	Feeder Code	Name of the Location where DT situated	DT code	DT Capacity (kVA)	Predominant consumer type of DT (Domestic/Industrial/Agriculture/Mixed)	Type of metering AMR/AMI/ Communicable/Conventional metered/Unmetered	Status of Meter-whether Functional (Yes/No)	% of data received automatically (if AMR/AMI)	No. of Connected Consumers	Input Energy (MU) (A)	Billed Energy (MU) (B)	Loss (MU) (A-B)	% DT Loss (A-B)/A
5256	TPCODL	CUTTACK	CDD-1	SUB DIVISION 03	JOBRA	14082	11 KV JOBRA BARRAGE	14082204	BAIBABA MATHA 1	3112DT099	250	MIXED	AMI	Yes	0%	187	0.20786944	0.169378	0.03849144	18.52%
5257	TPCODL	CUTTACK	CDD-1	SUB DIVISION 03	KALINGA	14084	11 KV CHOUDHURY BAZA	14084202	NEW COLONY	3133DT036	250	MIXED	AMI	Yes	0%	190	0.17962476	0.147059	0.03256576	18.13%
5258	TPCODL	CUTTACK	CDD-1	SUB DIVISION 03	KHAN NAGAR (BADA	14296	11 KV Mahatab	14296201	DOLAMUNDAI 8	3212DT144	500	MIXED	AMI	Yes	100%	343	0.6250436	0.431139	0.1939046	31.02%
5259	TPCODL	CUTTACK	CDD-1	SUB DIVISION 03	RANIHAT	14378	11 KV OGFED-2	14378202	RANIHAT PHD 2 SS	3114DT155	250	MIXED	AMI	Yes	67%	13	0.08223144	0.016972	0.06525944	79.36%
5260	TPCODL	CUTTACK	CDD-1	SUB DIVISION 03	SATICHAURA ODSSP	14238	11 KV EYE HOSPITAL	14238202	SARASWATI SISUMANDIRA	3142DT050	250	MIXED	AMI	Yes	100%	150	0.23636016	0.155736	0.08062416	34.11%
5261	TPCODL	CUTTACK	CDD-1	SUB DIVISION 03	SISHUBHABAN	14081	11 KV TOWNHALL	14081202	SUNSHINEFIELD	3122DT027	250	MIXED	AMI	Yes	67%	131	0.18114472	0.161188	0.01995672	11.02%
5262	TPCODL	CUTTACK	CDD-1	SUB DIVISION 03	SISHUBHABAN	14081	11 KV TOWNHALL	14081202	FIRINGI BAZAR DURGAGHAR	3122DT032	250	MIXED	AMI	Yes	100%	230	0.29603496	0.267769	0.02826596	9.55%
5263	TPCODL	CUTTACK	CDD-1	SUB DIVISION 03	SISHUBHABAN	14081	11 KV TOWNHALL	14081202	PHD PUMP HOUSE CAPEX	3124DT002	200	MIXED	AMI	Yes	0%	23	0.08821616	0.040347	0.04786916	54.26%
5264	TPCODL	CUTTACK	CDD-1	SUB DIVISION 03	SISHUBHABAN	14081	11 KV TOWNHALL	14081202	MANDENSEN	3124DT005	500	MIXED	AMI	Yes	100%	48	0.22847	0.059459	0.169011	73.98%
5265	TPCODL	CUTTACK	CDD-1	SUB DIVISION 03	SISHUBHABAN	14081	11 KV TOWNHALL	14081202	JAUNLIA PATTY 2	3124DT016	250	MIXED	AMI	Yes	100%	194	0.32024792	0.198714	0.12153392	37.95%
5266	TPCODL	CUTTACK	CDD-1	SUB DIVISION 03	SISHUBHABAN	14081	11 KV TOWNHALL	14081202	RAGHUNNATH JEW	3124DT023	250	MIXED	AMI	Yes	100%	51	0.17139136	0.051322	0.12006936	70.06%
5267	TPCODL	CUTTACK	CDD-1	SUB DIVISION 03	SISHUBHABAN	14081	11 KV PURI GHAT	14081205	N N GADA	3124DT048	500	MIXED	AMI	Yes	0%	278	0.46861088	0.272338	0.19627288	41.88%
5268	TPCODL	CUTTACK	CDD-1	SUB DIVISION 03	SISHUBHABAN	14081	11 KV PURI GHAT	14081205	RK COTTAGE	3124DT051	500	MIXED	AMI	Yes	0%	297	0.30355568	0.259974	0.04358168	14.36%
5269	TPCODL	CUTTACK	CDD-1	SUB DIVISION 04	KALINGA	14084	11 kV GORAKABAR	14084204	EXCLUSIVE APARTMENT	3131DT028	100	MIXED	AMI	Yes	0%	18	0.013434	0.009893	0.003541	26.36%
5270	TPCODL	CUTTACK	CDD-1	SUB DIVISION 04	KALINGA	14084	11 kV GORAKABAR	14084204	METRO VILLA 2	3131DT032	250	MIXED	AMI	Yes	0%	39	0.04868472	0.033817	0.01486772	30.54%
5271	TPCODL	CUTTACK	CDD-1	SUB DIVISION 04	KALINGA	14084	11 kV GORAKABAR	14084204	NARSHINGPUR PLAZA	3131DT046	250	MIXED	AMI	Yes	0%	49	0.05424472	0.034902	0.01934272	35.66%
5272	TPCODL	CUTTACK	CDD-1	SUB DIVISION 04	KALINGA	14084	11 kV CANTONMENT 2	14084203	GOURAB SAROGI BUILDER	3131DT100	250	MIXED	AMI	Yes	0%	20	0.06600308	0.030071	0.03593208	54.44%
5273	TPCODL	CUTTACK	CDD-1	SUB DIVISION 04	SISHUBHABAN	14081	11 kV Chandini Chowk	14081203	NARMADA VIHAR	3132DT006	250	MIXED	AMI	Yes	0%	20	0.0288164	0.02151	0.0073064	25.36%
5274	TPCODL	CUTTACK	CDD-1	SUB DIVISION 04	SISHUBHABAN	14081	11 kV Chandini Chowk	14081203	MM SIGNURE APPARTMENT	3132DT043	250	MIXED	AMI	Yes	0%	19	0.03997504	0.021593	0.01838204	45.98%
5275	TPCODL	CUTTACK	CDD-1	SUB DIVISION 04	DRDA	14210	11 KV KAZIBAZAR	14210202	CHAMAR SAHI	3123DT018	250	MIXED	AMI	Yes	100%	277	0.24373464	0.225464	0.01827064	7.50%
5276	TPCODL	CUTTACK	CDD-1	SUB DIVISION 04	DRDA	14210	11 KV KAZIBAZAR	14210202	TANTISAHI	3123DT025	250	MIXED	AMI	Yes	0%	276	0.29378316	0.217559	0.07622416	25.95%
5277	TPCODL	CUTTACK	CDD-1	SUB DIVISION 04	KALINGA	14084	11 KV CHOUDHURY BAZA	14084201	RAOSA PATNA	3111DT103	500	MIXED	AMI	Yes	0%	253	0.43945976	0.310201	0.12925876	29.41%
5278	TPCODL	CUTTACK	CDD-1	SUB DIVISION 04	KALINGA	14084	11 KV CHOUDHURY BAZA	14084201	RP LANE	3131DT138	250	MIXED	AMI	Yes	100%	51	0.10021256	0.053986	0.04622656	46.13%
5279	TPCODL	CUTTACK	CDD-1	SUB DIVISION 04	KALINGA	14084	11 KV CHOUDHURY BAZA	14084201	BAXIBAZAR MARKET	3133DT042	500	MIXED	AMI	Yes	0%	195	0.38288328	0.239477	0.14340628	37.45%
5280	TPCODL	CUTTACK	CDD-1	SUB DIVISION 04	KALINGA	14084	11 KV CHOUDHURY BAZA	14084201	SYED SEMINARY SCHOOL	3133DT051	500	MIXED	AMI	Yes	100%	347	0.452444	0.331971	0.120473	26.63%
5281	TPCODL	CUTTACK	CDD-1	SUB DIVISION 04	KALINGA	14084	11 KV CHOUDHURY BAZA	14084201	BARA PATHRA	3133DT056	250	MIXED	AMI	Yes	67%	96	0.13728376	0.081345	0.05593876	40.75%
5282	TPCODL	CUTTACK	CDD-1	SUB DIVISION 04	KALINGA	14084	11 KV CHOUDHURY BAZA	14084202	ODIYA BAZAR 1	3123DT032	250	MIXED	AMI	Yes	100%	56	0.14075276	0.049073	0.09167976	65.14%
5283	TPCODL	CUTTACK	CDD-1	SUB DIVISION 04	KALINGA	14084	11 KV CHOUDHURY BAZA	14084202	BOOK LAND	3133DT010	250	MIXED	AMI	Yes	100%	81	0.24319232	0.08567	0.15752232	64.77%
5284	TPCODL	CUTTACK	CDD-1	SUB DIVISION 04	KALINGA	14084	11 KV CHOUDHURY BAZA	14084202	TKB PARK 1	3133DT012	500	MIXED	AMI	Yes	0%	159	0.30365712	0.126884	0.17677312	58.21%
5285	TPCODL	CUTTACK	CDD-1	SUB DIVISION 04	KALINGA	14084	11 KV CHOUDHURY BAZA	14084202	PARAS PLAZA 1	3133DT019	500	MIXED	AMI	Yes	100%	227	0.41549832	0.209217	0.20628132	49.65%
5286	TPCODL	CUTTACK	CDD-1	SUB DIVISION 04	KALINGA	14084	11 KV CHOUDHURY BAZA	14084202	MAKRABAG SAHI	3133DT021	250	MIXED	AMI	Yes	100%	92	0.25992216	0.110607	0.14931516	57.45%
5287	TPCODL	CUTTACK	CDD-1	SUB DIVISION 04	KALINGA	14084	11 KV CHOUDHURY BAZA	14084202	TKB OFC2	3133DT027	500	MIXED	AMI	Yes	100%	119	0.21412464	0.153005	0.06111964	28.54%
5288	TPCODL	CUTTACK	CDD-1	SUB DIVISION 04	KALINGA	14084	11 KV CHOUDHURY BAZA	14084202	SRI VENKATESWAR BUILDER	3133DT034	500	MIXED	AMI	Yes	0%	16	0.13101072	0.061426	0.06958472	53.11%
5289	TPCODL	CUTTACK	CDD-1	SUB DIVISION 04	KALINGA	14084	11 KV CHOUDHURY BAZA	14084202	DARGHA BAZAR	3133DT082	250	MIXED	AMI	Yes	0%	147	0.2708956	0.137896	0.1329996	49.10%
5290	TPCODL	CUTTACK	CDD-1	SUB DIVISION 04	KALINGA	14084	11 KV CHOUDHURY BAZA	14084202	P.M.ACCADEAMY	3133DT083	100	MIXED	AMI	Yes	100%	23	0.07957042	0.018331	0.06123942	76.96%
5291	TPCODL	CUTTACK	CDD-1	SUB DIVISION 04	KALINGA	14084	11 KV GORAKABAR	14084204	GORKABAR 2	3131DT036	250	MIXED	AMI	Yes	100%	217	0.18181532	0.17852	0.00329532	1.81%
5292	TPCODL	CUTTACK	CDD-1	SUB DIVISION 04	KALINGA	14084	11 KV GORAKABAR	14084204	GARIBA DAS MATHA	3131DT042	500	MIXED	AMI	Yes	0%	157	0.3364316	0.153365	0.1830666	54.41%
5293	TPCODL	CUTTACK	CDD-1	SUB DIVISION 04	KALINGA	14084	11 KV GORAKABAR	14084204	OJHA LANE SARALA BHAWAN	3131DT047	250	MIXED	AMI	Yes	100%	18	0.04089004	0.027495	0.01339504	32.76%
5294	TPCODL	CUTTACK	CDD-1	SUB DIVISION 04	KALINGA	14084	11 KV CANTONMENT 1	14084206	AIR COLONY	3131DT099	250	MIXED	AMI	Yes	100%	87	0.10708188	0.095139	0.01194288	11.15%
5295	TPCODL	CUTTACK	CDD-1	SUB DIVISION 04	KALINGA	14084	11 KV CANTONMENT 1	14084206	SUTAHATA CHRISTAN SAHI (DISCONT	3131DT110	250	MIXED	AMI	Yes	0%	70	0.1490798	0.106397	0.0426828	28.63%
5296	TPCODL	CUTTACK	CDD-1	SUB DIVISION 04	KALINGA	14084	11 KV CANTONMENT 1	14084206	POLICE OUTPOST 1	3131DT111	250	MIXED	AMI	Yes	100%	24	0.13229896	0.029347	0.10295196	77.82%
5297	TPCODL	CUTTACK	CDD-1	SUB DIVISION 04	KALINGA	14084	11 KV CANTONMENT 1	14084206	GADHI KHANA	3131DT116	500	MIXED	AMI	Yes	0%	331	0.492634	0.347076	0.145558	29.55%
5298	TPCODL	CUTTACK	CDD-1	SUB DIVISION 04	KALINGA	14084	11 KV CANTONMENT 1	14084206	DURGA BHAWAN 2	3132DT050	250	MIXED	AMI	Yes	0%	59	0.25556504	0.072147	0.18341804	71.77%
5299	TPCODL	CUTTACK	CDD-1	SUB DIVISION 04	KALINGA	14084	11 KV HIGH COURT	14084208	ISO COLONY	3131DT076	250	MIXED	AMI	Yes	0%	126	0.2132734	0.183352	0.0299214	14.03%
5300	TPCODL	CUTTACK	CDD-1	SUB DIVISION 04	KALINGA	14084	11 KV HIGH COURT	14084208	KANIKA SQUARE DTC 1	3131DT077	500	MIXED	AMI	Yes	100%	499	0.48998952	0.458576	0.03141352	6.41%
5301	TPCODL	CUTTACK	CDD-1	SUB DIVISION 04	KALINGA	14084	11 KV HIGH COURT	14084208	KANIKA SQUARE DTC 2	3131DT078	250	MIXED	AMI	Yes	0%	64	0.18588232	0.106622	0.07926032	42.64%
5302	TPCODL	CUTTACK	CDD-1	SUB DIVISION 04	KALINGA	14084	11 KV HIGH COURT	14084208	CHRIST COLLEGE 1	3131DT084	500	MIXED	AMI	Yes	0%	227	0.3304468	0.319777	0.0106698	3.23%
5303	TPCODL	CUTTACK	CDD-1	SUB DIVISION 04	KALINGA	14084	11 KV HIGH COURT	14084208	SRIBIHAR SHIV MANDIR-1	3131DT090	500	MIXED	AMI	Yes	0%	209	0.28702736	0.239793	0.04723436	16.46%
5304	TPCODL	CUTTACK	CDD-1	SUB DIVISION 04	KALINGA	14084	11 KV HIGH COURT	14084208	STEWARD PATNA 2	3132DT028	500	MIXED	AMI	Yes	0%	262	0.344598	0.267823	0.076775	22.28%
5305	TPCODL	CUTTACK	CDD-1	SUB DIVISION 04	KALINGA	14084	11 KV HIGH COURT	14084208	ANNAPURNA RESIDENCY COMPLEX	3143DT025	250	MIXED	AMI	Yes	100%	89	0.12022576	0.088334	0.03189176	26.53%
5306	TPCODL	CUTTACK	CDD-1	SUB DIVISION 04	KALINGA	14084	11 KV DD OH	14084209	HINDOL KHUNTIA	3131DT024	500	MIXED	AMI	Yes	100%	452	0.49562904	0.47808	0.01754904	3.54%
5307	TPCODL	CUTTACK	CDD-1	SUB DIVISION 04	KALINGA	14084	11 KV SRI VIHAR	14084210	KALINGA 1	3131DT001	500	MIXED	AMI	Yes	100%	206	0.38669416	0.266985	0.11970916	30.96%
5308	TPCODL	CUTTACK	CDD-1	SUB DIVISION 04	KALINGA	14084	11 KV SRI VIHAR	14084210	KALINGA 2	3131DT002	500	MIXED	AMI	Yes	0%	246	0.33606824	0.250888	0.08518024	25.35%
5309	TPCODL	CUTTACK	CDD-1	SUB DIVISION 04	KALINGA	14084	11 KV UPPER GROUND	14084212	CONTONMENT 2	3131DT169	250	MIXED	AMI	Yes	100%	135	0.32736838	0.321156	0.00621238	1.90%
5310	TPCODL	CUTTACK	CDD-1	SUB DIVISION 04	KALINGA	14084	11 KV CHANDI MANDIR	14084213	KHATBIN SAHI 2	3131DT156	250	MIXED	AMI	Yes	100%	99	0.1250256	0.086159	0.0388666	31.09%
5311	TPCODL	CUTTACK	CDD-1	SUB DIVISION 04	MEDICAL	14083	11 KV TELEPHONE BHAW	14083201	PHD2 GAMHADIYA	3113DT059	200	MIXED	AMI	Yes	100%	34	0.13546071	0.027269	0.10819171	79.87%
5312	TPCODL	CUTTACK	CDD-1	SUB DIVISION 04	RANIHAT	14378	11 KV OGFED-2	14378202	RANIHAT PHD 1 SS	3114DT020	500	MIXED	AMI	Yes	100%	136	0.16988376	0.135827	0.03405676	20.05%
5313	TPCODL	CUTTACK	CDD-1	SUB DIVISION 04	SISHUBHABAN	14081	11 KV Chandini Chowk	14081203	CHANDANI CHOUK	3132DT003	500	MIXED	AMI	Yes	100%	427	0.43999288	0.386112	0.05388088	12.25%
5314	TPCODL	CUTTACK	CDD-1	SUB DIVISION 04	SISHUBHABAN	14081	11 KV Chandini Chowk	14081203	MEHENDIPUR	3132DT007	500	MIXED	AMI	Yes	0%	228	0.3057292	0.194247	0.1114822	36.46%
5315	TPCODL	CUTTACK	CDD-1	SUB DIVISION 04	SISHUBHABAN	14081	11 KV Chandini Chowk	14081203	MAHANTIPADA	3132DT038	500	MIXED	AMI	Yes	0%	416	0.44009904	0.403059	0.03704004	8.42%
5316	TPCODL	CUTTACK	CDD-1	SUB DIVISION 04	SISHUBHABAN	14081	11 KV Chandini Chowk	14081203	KAFLA 4	3132DT040	100	MIXED	AMI	Yes	0%	57	0.0532372	0.042858	0.0103792	19.50%
5317	TPCODL	CUTTACK	CDD-1	SUB DIVISION 04	SISHUBHABAN	14081	11 KV Chandini Chowk	14081203	ALISHA BAZAR 2	3132DT048	500	MIXED	AMI	Yes	0%	283	0.45331816	0.231295	0.22202316	48.98%
5318	TPCODL	CUTTACK	CDD-1	SUB DIVISION 06	BIDANASI	14085	11 kV BIDANASI-2	14085205	JAIN HERITAGE	3141DT299	500	MIXED	AMI	Yes	0%	23	0.025226	0.022671	0.002555	10.13%
5319	TPCODL	CUTTACK	CDD-1	SUB DIVISION 06	BIDANASI	14085	11 KV TULASIPUR	14085204	ODISHI ENCLAVE	3143DT091	100	MIXED	AMI	Yes	0%	21	0.02728342	0.018512	0.00877142	32.15%
5320	TPCODL	CUTTACK	CDD-1	SUB DIVISION 06	BIDANASI	14085	11 KV BIDANASI-1	14085202	SUBHADRA NAGAR	3141DT111	500	MIXED	AMI	Yes	0%	81	0.250426	0.068962	0.181464	72.46%
5321	TPCODL	CUTTACK	CDD-1	SUB DIVISION 06	BIDANASI	14085	11 KV BIDANASI-1	14085202	SUBHADRA NAGAR	3141DT112	250	MIXED	AMI	Yes	0%	230	0.21002748	0.171188	0.03883948	18.49%
5322	TPCODL	CUTTACK	CDD-1	SUB DIVISION 06	BIDANASI	14085	11 KV BIDANASI-1	14085202	NUA SAHI KOILA DIPA	3141DT146	250	MIXED	AMI	Yes	100%	281	0.21859528	0.182341	0.03625428	16.59%
5323	TPCODL	CUTTACK	CDD-1	SUB DIVISION 06	BIDANASI	14085	11 KV BIDANASI-1	14085202	PUMP HOUSE	3142DT167	100	MIXED	AMI	Yes	67%	42	0.05416048	0.042301	0.01185948	21.90%
5324	TPCODL	CUTTACK	CDD-1	SUB DIVISION 06	BIDANASI	14085	11 KV TULASIPUR	14085204	GASTI SAUCHALAYA	3141DT039	100	MIXED	AMI	Yes	0%	19	0.09376536	0.028457	0.06530836	69.65%
5325	TPCODL	CUTTACK	CDD-1	SUB DIVISION 06	BIDANASI	14085	11 KV TULASIPUR	14085204	SRI SUSIL KUMAR AGARWALA	3141DT071	250	MIXED	AMI	Yes	100%	16	0.02149264	0.018159	0.00333364	15.51%
5326	TPCODL	CUTTACK	CDD-1	SUB DIVISION 06	BIDANASI	14085	11 KV TULASIPUR	14085204	PIPE STORE 2	3143DT052	250	MIXED	AMI	Yes	100%	105	0.13411328	0.09407	0.04004328	29.86%
5327	TPCODL	CUTTACK	CDD-1	SUB DIVISION 06	BIDANASI	14085	11 KV TULASIPUR	14085204	LOWER POLICE COLONI 1	3143DT055	250	MIXED	AMI	Yes	100%	44	0.11652516	0.043578	0.07294716	62.60%
5328	TPCODL	CUTTACK	CDD-1	SUB DIVISION 06	BIDANASI	14085	11 KV TULASIPUR	14085204	CHAHATA NAGAR LANE 5	3143DT058	250	MIXED	AMI	Yes	0%	104	0.11965476	0.101135	0.01851976	15.48%

Sl. No.	Zone Name	Circle name	Division name	Name of the Sub-division	Name of the Sub-station	Substation Code	Name of the 11 kV Feeder	Feeder Code	Name of the Location where DT situated	DT code	DT Capacity (kVA)	Predominant consumer type of DT (Domestic/Industrial/Agriculture/Mixed)	Type of metering AMR/AMI/ Communicable/Conventional metered/Unmetered	Status of Meter-whether Functional (Yes/No)	% of data received automatically (if AMR/AMI)	No. of Connected Consumers	Input Energy (MU) (A)	Billed Energy (MU) (B)	Loss (MU) (A-B)	% DT Loss (A-B)/A
5329	TPCODL	CUTTACK	CDD-1	SUB DIVISION 0(	BIDANASI	14085	11 KV TULASIPUR	14085204	TULSIPUR CESU OFFICE 1	3143DT066	250	MIXED	AMI	Yes	100%	218	0.27110232	0.185933	0.08516932	31.42%
5330	TPCODL	CUTTACK	CDD-1	SUB DIVISION 0(	BIDANASI	14085	11 KV TULASIPUR	14085204	TULSIPUR CESU OFFICE 3	3143DT068	250	MIXED	AMI	Yes	0%	53	0.15416716	0.084053	0.07011416	45.48%
5331	TPCODL	CUTTACK	CDD-1	SUB DIVISION 0(	BIDANASI	14085	11 KV TULASIPUR	14085204	LOWER POLICE COLONI 5	3143DT073	200	MIXED	AMI	Yes	100%	64	0.04437588	0.043722	0.00065388	1.47%
5332	TPCODL	CUTTACK	CDD-1	SUB DIVISION 0(	BIDANASI	14085	11 KV TULASIPUR	14085204	SIRIDI NAGAR	3143DT089	63	MIXED	AMI	Yes	100%	24	0.03259376	0.021214	0.01137976	34.91%
5333	TPCODL	CUTTACK	CDD-1	SUB DIVISION 0(	BIDANASI	14085	11 KV TULASIPUR	14085204	HATUA SAHI 1	3143DT100	250	MIXED	AMI	Yes	100%	130	0.17818032	0.148414	0.02976632	16.71%
5334	TPCODL	CUTTACK	CDD-1	SUB DIVISION 0(	BIDANASI	14085	11 KV TULASIPUR	14085204	TULASHI BATIKA	3143DT106	250	MIXED	AMI	Yes	100%	8	0.03202544	0.012436	0.01958944	61.17%
5335	TPCODL	CUTTACK	CDD-1	SUB DIVISION 0(	BIDANASI	14085	11 KV TULASIPUR	14085204	UPENDRA NATH SUTAR	3143DT174	250	MIXED	AMI	Yes	0%	21	0.02305648	0.016906	0.00615048	26.68%
5336	TPCODL	CUTTACK	CDD-1	SUB DIVISION 0(	BIDANASI	14085	11 KV BIDANASI -2	14085205	JYOTI VIHAR	3141DT165	500	MIXED	AMI	Yes	100%	214	0.38847472	0.133725	0.25474972	65.58%
5337	TPCODL	CUTTACK	CDD-1	SUB DIVISION 0(	CDA	14080	11 KV SATICHOURA	14080201	MARKET COMPLEX SECTOR 6 CDA	3142DT024	500	MIXED	AMI	Yes	100%	248	0.31828328	0.318006	0.00027728	0.09%
5338	TPCODL	CUTTACK	CDD-1	SUB DIVISION 0(	CDA	14080	11 KV SATICHOURA	14080201	TARENI MANDIRA	3142DT025	250	MIXED	AMI	Yes	100%	61	0.18779048	0.062852	0.12493848	66.53%
5339	TPCODL	CUTTACK	CDD-1	SUB DIVISION 0(	CDA	14080	11 KV SECTOR 6,7	14080202	ADVOCATE GENERAL STAFF COLONY	3142DT056	250	MIXED	AMI	Yes	0%	31	0.03503612	0.014946	0.02009012	57.34%
5340	TPCODL	CUTTACK	CDD-1	SUB DIVISION 0(	CDA	14080	11 KV SECTOR 6,7	14080202	MARKAT POLICE STATION	3142DT073	250	MIXED	AMI	Yes	100%	102	0.16858298	0.115908	0.05267498	31.25%
5341	TPCODL	CUTTACK	CDD-1	SUB DIVISION 0(	CDA	14080	11 KV SECTOR 6,7	14080202	BISWAL BABU(RAPDRP)	3142DT074	250	MIXED	AMI	Yes	100%	137	0.2923144	0.117228	0.1750864	59.90%
5342	TPCODL	CUTTACK	CDD-1	SUB DIVISION 0(	CDA	14080	11 KV SECTOR 6,7	14080202	BARAGACHHA2	3142DT076	250	MIXED	AMI	Yes	67%	127	0.2111076	0.111236	0.0998716	47.31%
5343	TPCODL	CUTTACK	CDD-1	SUB DIVISION 0(	CDA	14080	11 KV SECTOR 6,7	14080202	POSTAL2	3142DT089	250	MIXED	AMI	Yes	0%	206	0.3337288	0.182509	0.1512198	45.31%
5344	TPCODL	CUTTACK	CDD-1	SUB DIVISION 0(	CDA	14080	11 KV SECTOR 6,7	14080202	OU GACHHA2	3142DT100	250	MIXED	AMI	Yes	100%	43	0.16568316	0.044106	0.12157716	73.38%
5345	TPCODL	CUTTACK	CDD-1	SUB DIVISION 0(	CDA	14080	11 KV SECTOR 9	14080203	7D BLOCK .SECTOR 9	3142DT131	250	MIXED	AMI	Yes	100%	151	0.15656124	0.155626	0.00093524	0.60%
5346	TPCODL	CUTTACK	CDD-1	SUB DIVISION 0(	CDA	14080	11 KV SECTOR 9	14080203	PRACHI	3142DT133	100	MIXED	AMI	Yes	100%	47	0.05494594	0.042907	0.01203894	21.91%
5347	TPCODL	CUTTACK	CDD-1	SUB DIVISION 0(	CDA	14080	11 KV SECTOR 9	14080203	KZK 2	3142DT135	500	MIXED	AMI	Yes	100%	114	0.19101584	0.137847	0.05316884	27.83%
5348	TPCODL	CUTTACK	CDD-1	SUB DIVISION 0(	CDA	14080	11 KV SECTOR 9	14080203	SHIV TAMPLE NEAR PLOT NO 395.SEC	3142DT139	500	MIXED	AMI	Yes	100%	509	0.48825792	0.468823	0.01943492	3.98%
5349	TPCODL	CUTTACK	CDD-1	SUB DIVISION 0(	CDA	14080	11 KV SECTOR 9	14080203	TARINI BIHAR 1	3142DT143	250	MIXED	AMI	Yes	100%	267	0.265943	0.250903	0.01504	5.66%
5350	TPCODL	CUTTACK	CDD-1	SUB DIVISION 0(	CDA	14080	11 KV SECTOR 9	14080203	GANESH PALACE(SWARAJ)	3142DT149	250	MIXED	AMI	Yes	0%	308	0.43857248	0.266416	0.17215648	39.25%
5351	TPCODL	CUTTACK	CDD-1	SUB DIVISION 0(	KALINGA	14084	11 KV HIGH COURT	14084208	NEAR SUN HOSPITAL KANIKA ROAD	3131DT071	250	MIXED	AMI	Yes	0%	121	0.22972544	0.146036	0.08368944	36.43%
5352	TPCODL	CUTTACK	CDD-1	SUB DIVISION 0(	KALINGA	14084	11 KV HIGH COURT	14084208	SIBAJI NAGAR	3143DT032	500	MIXED	AMI	Yes	100%	313	0.36073568	0.273457	0.08727868	24.19%
5353	TPCODL	CUTTACK	CDD-1	SUB DIVISION 0(	MATAMATHA	14209	11 KV BUXI BAZAR	14209204	CHHELIKATA-1	3111DT026	500	MIXED	AMI	Yes	100%	226	0.40234328	0.208651	0.19369228	48.14%
5354	TPCODL	CUTTACK	CDD-1	SUB DIVISION 0(	SATICHAURA ODSSP	14238	11 KV TULASIPUR	14238201	SATIGUMPHA	3143DT124	250	MIXED	AMI	Yes	0%	82	0.06607528	0.039536	0.02653928	40.17%
5355	TPCODL	CUTTACK	CDD-1	SUB DIVISION 0(	SATICHAURA ODSSP	14238	11 KV TULASIPUR	14238201	U P COLONY 2	3143DT142	250	MIXED	AMI	Yes	100%	15	0.05455872	0.014123	0.04043572	74.11%
5356	TPCODL	CUTTACK	CDD-1	SUB DIVISION 0(	SATICHAURA ODSSP	14238	11 KV TULASIPUR	14238201	U.P COLONY 8	3143DT144	100	MIXED	AMI	Yes	100%	14	0.02035774	0.009936	0.01042174	51.19%
5357	TPCODL	CUTTACK	CDD-1	SUB DIVISION 0(	SATICHAURA ODSSP	14238	11 KV TULASIPUR	14238201	U.P COLONY POLE NO 255	3143DT151	100	MIXED	AMI	Yes	67%	16	0.01664456	0.012429	0.00421556	25.33%
5358	TPCODL	CUTTACK	CDD-1	SUB DIVISION 0(	SATICHAURA ODSSP	14238	11 KV TULASIPUR	14238201	U.P COLONY POLE NO 256	3143DT152	100	MIXED	AMI	Yes	100%	12	0.01518086	0.009728	0.00545286	35.92%
5359	TPCODL	CUTTACK	CDD-1	SUB DIVISION 0(	SATICHAURA ODSSP	14238	11 KV EYE HOSPITAL	14238202	BIMA BIHAR LIC COLONY	3142DT034	500	MIXED	AMI	Yes	100%	176	0.1866732	0.154169	0.0325042	17.41%
5360	TPCODL	CUTTACK	CDD-1	SUB DIVISION 0(	SATICHAURA ODSSP	14238	11 KV EYE HOSPITAL	14238202	5 NO SUBSTATION	3142DT041	500	MIXED	AMI	Yes	100%	374	0.46998344	0.431841	0.03814244	8.12%
5361	TPCODL	CUTTACK	CDD-1	SUB DIVISION 0(	SATICHAURA ODSSP	14238	11 KV EYE HOSPITAL	14238202	J P PARK	3142DT049	250	MIXED	AMI	Yes	0%	21	0.2000268	0.046348	0.1536788	76.83%
5362	TPCODL	CUTTACK	CDD-1	SUB DIVISION 0(	SATICHAURA ODSSP	14238	11 KV EYE HOSPITAL	14238202	ANADI SAHOO 1	3142DT053	500	MIXED	AMI	Yes	100%	268	0.46608736	0.261625	0.20446236	43.87%
5363	TPCODL	CUTTACK	CDD-1	SUB DIVISION 0(	SATICHAURA ODSSP	14238	11 KV EYE HOSPITAL	14238202	ANADI SAHOO	3142DT054	250	MIXED	AMI	Yes	100%	44	0.12127826	0.050043	0.07123526	58.74%
5364	TPCODL	CUTTACK	CDD-1	SUB DIVISION 0(	SECTOR-10 & 11 OD	14239	11 KV CDA-10	14239201	JAGANNATH TEMPLE-2	3141DT173	250	MIXED	AMI	Yes	100%	75	0.21739912	0.048102	0.16929712	77.87%
5365	TPCODL	CUTTACK	CDD-1	SUB DIVISION 0(	SECTOR-10 & 11 OD	14239	11 KV CDA-10	14239201	MUKTESWAR TEMPLE SEC 10-1	3141DT199	500	MIXED	AMI	Yes	0%	133	0.41185888	0.151217	0.26064188	63.28%
5366	TPCODL	CUTTACK	CDD-1	SUB DIVISION 0(	SECTOR-10 & 11 OD	14239	11 KV CDA-11	14239202	AIR TEL SEC 10	3141DT182	200	MIXED	AMI	Yes	100%	60	0.22607612	0.070653	0.15542312	68.75%
5367	TPCODL	CUTTACK	CDD-1	SUB DIVISION 0(	SECTOR-10 & 11 OD	14239	11 KV CDA-11	14239202	AIRTEL 2	3141DT184	250	MIXED	AMI	Yes	67%	146	0.153061	0.129043	0.024018	15.69%
5368	TPCODL	CUTTACK	CDD-1	SUB DIVISION 0(	SECTOR-10 & 11 OD	14239	11 KV CDA-11	14239202	NEAR BM PARK SEC 11 1	3142DT188	250	MIXED	AMI	Yes	67%	49	0.18690076	0.132574	0.05432676	29.07%
5369	TPCODL	CUTTACK	CDD-1	SUB DIVISION 0(	SECTOR-10 & 11 OD	14239	11 KV CDA-11	14239202	BIRENMITRA PARK 3	3142DT202	250	MIXED	AMI	Yes	0%	106	0.11539008	0.105307	0.01008308	8.74%
5370	TPCODL	CUTTACK	CDD-1	SUB DIVISION 0(	SECTOR-10 & 11 OD	14239	11 KV NARAJ	14239203	DHABALESWAR GADA-2	3141DT004	250	MIXED	AMI	Yes	0%	177	0.08052948	0.050222	0.03030748	37.64%
5371	TPCODL	CUTTACK	CDD-1	SUB DIVISION 0(	SECTOR-13 ODSSP	14240	11 KV SECTOR-13	14240203	SECTOR 13 CALONY 1	3141DT238	100	MIXED	AMI	Yes	100%	15	0.01118238	0.003135	0.00804738	71.96%
5372	TPCODL	CUTTACK	CDD-1	SUB DIVISION 0(	SECTOR-13 ODSSP	14240	11 KV SECTOR-13	14240203	SECTOR 13 CALONY 2	3141DT239	250	MIXED	AMI	Yes	100%	75	0.04999	0.027962	0.022028	44.06%
5373	TPCODL	CUTTACK	CDD-1	SUB DIVISION 0(	SECTOR-13 ODSSP	14240	11 KV SECTOR-13	14240203	JUDICIAL ASSOCIATION OFFICE	3141DT302	250	MIXED	AMI	Yes	100%	169	0.1451288	0.107414	0.0377148	25.99%
5374	TPCODL	CUTTACK	CDD-1	SUB DIVISION 0(	SECTOR-13 ODSSP	14240	11 KV SECTOR-13	14240203	SECTOR 13 CALONY 6	3142DT205	250	MIXED	AMI	Yes	0%	110	0.27481912	0.106426	0.16839312	61.27%
5375	TPCODL	CUTTACK	CDD-1	SUB DIVISION 0(	SECTOR-13 ODSSP	14240	11 KV SECTOR-13	14240203	SECTOR 13 CALONY 8	3142DT207	500	MIXED	AMI	Yes	100%	183	0.23433552	0.182234	0.05210152	22.23%
5376	TPCODL	CUTTACK	CDD-1	SUB DIVISION 0(	SECTOR-13 ODSSP	14240	11 KV SECTOR-13	14240203	ODISHA	3142DT208	500	MIXED	AMI	Yes	100%	176	0.24999056	0.202784	0.04720656	18.88%
5377	TPCODL	CUTTACK	CDD-1	SUB DIVISION 0(	SECTOR-13 ODSSP	14240	11 KV SECTOR-13	14240203	SECTOR 13 CALONY 11	3142DT213	500	MIXED	AMI	Yes	0%	83	0.25722168	0.094681	0.16254068	63.19%
5378	TPCODL	CUTTACK	CDD-2	BADAMBADI	KALYANI NAGAR	14089	11 kV RING-1	14089203	JADU KULA	3212DT030	250	MIXED	AMI	Yes	0%	32	0.06347328	0.030319	0.03315428	52.23%
5379	TPCODL	CUTTACK	CDD-2	BADAMBADI	KALYANI NAGAR	14089	11 kV RING-1	14089203	M M ENGG	3212DT033	250	MIXED	AMI	Yes	0%	22	0.02553896	0.023808	0.00173096	6.78%
5380	TPCODL	CUTTACK	CDD-2	BADAMBADI	KHAN NAGAR (BAD/	14296	11 kV HARIPUR	14296202	KRISHNA	3212DT156	500	MIXED	AMI	Yes	0%	114	0.1395608	0.0996	0.0399608	28.63%
5381	TPCODL	CUTTACK	CDD-2	BADAMBADI	CUTTACK	17020	BADAMBADI UG	17020410	33/11 kV BADAMBADI SS DT	3211DT001	100	MIXED	AMI	Yes	100%	1	0.00624512	0.006245	1.2E-07	0.00%
5382	TPCODL	CUTTACK	CDD-2	BADAMBADI	42 MAUZA	14092	11 KV BENTKAR	14092202	KALIMA TODA(TOTA)	3221DT026	63	MIXED	AMI	Yes	0%	118	0.10516503	0.083936	0.02122903	20.19%
5383	TPCODL	CUTTACK	CDD-2	BADAMBADI	BADAMBADI	14087	11 KV Badambadi OGP U	14087202	SBI 1	3211DT069	250	MIXED	AMI	Yes	100%	45	0.0514574	0.03256	0.0188974	36.72%
5384	TPCODL	CUTTACK	CDD-2	BADAMBADI	BADAMBADI	14087	11 KV Badambadi OGP U	14087202	INDIAN OIL PETROL PUMP	3211DT086	630	MIXED	AMI	Yes	0%	129	0.30927725	0.216418	0.09285925	30.02%
5385	TPCODL	CUTTACK	CDD-2	BADAMBADI	BADAMBADI	14087	11 KV BADAMBADI-2	14087204	NEW LIC COLONY 2	3211DT004	500	MIXED	AMI	Yes	0%	109	0.15497912	0.074646	0.08033312	51.83%
5386	TPCODL	CUTTACK	CDD-2	BADAMBADI	BADAMBADI	14087	11 KV BADAMBADI-2	14087204	ARCHANA PRESS	3211DT034	500	MIXED	AMI	Yes	100%	134	0.29143216	0.173179	0.11825316	40.58%
5387	TPCODL	CUTTACK	CDD-2	BADAMBADI	BADAMBADI	14087	11 KV BADAMBADI-2	14087204	LUNIA SAHI	3211DT038	250	MIXED	AMI	Yes	67%	105	0.1716596	0.101805	0.0698546	40.69%
5388	TPCODL	CUTTACK	CDD-2	BADAMBADI	BADAMBADI	14087	11 KV BADAMBADI-2	14087204	LUNIA SAHI	3211DT039	500	MIXED	AMI	Yes	100%	244	0.34473136	0.279854	0.06487736	18.82%
5389	TPCODL	CUTTACK	CDD-2	BADAMBADI	BADAMBADI	14087	11 KV BADAMBADI-2	14087204	RAJABAGICHA NAYAK SAHI	3211DT040	100	MIXED	AMI	Yes	100%	111	0.11740944	0.058478	0.05893144	50.19%
5390	TPCODL	CUTTACK	CDD-2	BADAMBADI	BADAMBADI	14087	11 KV BADAMBADI-2	14087204	CITY COLLEGE 2	3211DT050	250	MIXED	AMI	Yes	100%	50	0.19546848	0.058515	0.13695348	70.06%
5391	TPCODL	CUTTACK	CDD-2	BADAMBADI	BADAMBADI	14087	11 KV BADAMBADI-2	14087204	BASANTA BISWAL_01	3211DT130	250	MIXED	AMI	Yes	33%	37	0.15740212	0.049456	0.10794612	68.58%
5392	TPCODL	CUTTACK	CDD-2	BADAMBADI	BADAMBADI	14087	11 KV Badambadi-Kalyar	14087205	INSIDE PURI BUS STAND CSS	3212DT180	630	MIXED	AMI	Yes	0%	151	0.35607038	0.176666	0.17940438	50.38%
5393	TPCODL	CUTTACK	CDD-2	BADAMBADI	BADAMBADI	14087	11 KV Badambadi-Kalyar	14087205	MAHAVIR CSS 6	3212DT183	630	MIXED	AMI	Yes	100%	297	0.61361651	0.327304	0.28631251	46.66%
5394	TPCODL	CUTTACK	CDD-2	BADAMBADI	BADAMBADI	14087	11 KV Badambadi-Kalyar	14087205	SBI CSS	3212DT185	630	MIXED	AMI	Yes	0%	97	0.43677288	0.152142	0.28463088	65.17%
5395	TPCODL	CUTTACK	CDD-2	BADAMBADI	BADAMBADI	14087	11 KV Badambadi-Kalyar	14087205	ORRISA STEVDECORS LTD CSS	3212DT190	630	MIXED	AMI	Yes	0%	135	0.29593625	0.189355	0.10658125	36.01%
5396	TPCODL	CUTTACK	CDD-2	BADAMBADI	BADAMBADI	14087	11 KV Badambadi-Kalyar	14087205	POSTAL COLONY CSS 9	3212DT193	500	MIXED	AMI	Yes	100%	31	0.13090938	0.046858	0.08405138	64.21%
5397	TPCODL	CUTTACK	CDD-2	BADAMBADI	BADAMBADI	14087	11 KV Badambadi-Kalyar	14087205	SHAKTI NAGAR LANE	3212DT196	500	MIXED	AMI	Yes	33%	178	0.34143269	0.240853	0.10057969	29.46%
5398	TPCODL	CUTTACK	CDD-2	BADAMBADI	BADAMBADI	14087	11 KV Badambadi-Kalyar	14087205	SHAKTI NAGAR2	3212DT197	250	MIXED	AMI	Yes	100%	114	0.1366392	0.104665	0.0319742	23.40%
5399	TPCODL	CUTTACK	CDD-2	BADAMBADI	KALYANI NAGAR	14089	11 KV KALYANI NAGAR	14089201	CAPEX, KALYANI NAGAR	3213DT001	250	MIXED	AMI	Yes	0%	145	0.17900892	0.16807	0.01093892	6.11%
5400	TPCODL	CUTTACK	CDD-2	BADAMBADI	KALYANI NAGAR	14089	11 KV KALYANI NAGAR	14089201	UTKAL APARTMERNT	3213DT002	500	MIXED	AMI	Yes	0%	204	0.36393648	0.220063	0.14387348	39.53%
5401	TPCODL	CUTTACK	CDD-2	BADAMBADI	KALYANI NAGAR	14089	11 KV KALYANI NAGAR	14089201	UTKAL APARTMENT	3213DT003	250	MIXED	AMI	Yes	0%	122	0.18656128	0.086618	0.09994328	53.57%

Sl. No.	Zone Name	Circle name	Division name	Name of the Sub-division	Name of the Sub-station	Substation Code	Name of the 11 kV Feeder	Feeder Code	Name of the Location where DT situated	DT code	DT Capacity (kVA)	Predominant consumer type of DT (Domestic/Industrial/Agriculture/Mixed)	Type of metering AMR/AMI/ Communicable/Conventional metered/Unmetered	Status of Meter-whether Functional (Yes/No)	% of data received automatically (if AMR/AMI)	No. of Connected Consumers	Input Energy (MU) (A)	Billed Energy (MU) (B)	Loss (MU) (A-B)	% DT Loss (A-B)/A
5402	TPCODL	CUTTACK	CDD-2	BADAMBADI	KALYANI NAGAR	14089	11 KV KALYANI NAGAR	14089201	KUSUMDEVI COLLAGE	3213DT006	500	MIXED	AMI	Yes	0%	247	0.54898488	0.293036	0.25594888	46.62%
5403	TPCODL	CUTTACK	CDD-2	BADAMBADI	KALYANI NAGAR	14089	11 KV KALYANI NAGAR	14089201	RED CROSS PADIA	3213DT009	100	MIXED	AMI	Yes	0%	33	0.04848524	0.025073	0.02341224	48.29%
5404	TPCODL	CUTTACK	CDD-2	BADAMBADI	KALYANI NAGAR	14089	11 KV KALYANI NAGAR	14089201	PRASANNA DAS	3213DT012	500	MIXED	AMI	Yes	0%	258	0.78771984	0.309954	0.47776584	60.65%
5405	TPCODL	CUTTACK	CDD-2	BADAMBADI	KALYANI NAGAR	14089	11 KV KALYANI NAGAR	14089201	GANESH GALI	3213DT013	250	MIXED	AMI	Yes	0%	146	0.24416692	0.220822	0.02334492	9.56%
5406	TPCODL	CUTTACK	CDD-2	BADAMBADI	KALYANI NAGAR	14089	11 KV KALYANI NAGAR	14089201	VIJAY LAXMI MANDAP	3213DT014	500	MIXED	AMI	Yes	0%	196	0.39717864	0.258982	0.13819664	34.79%
5407	TPCODL	CUTTACK	CDD-2	BADAMBADI	KALYANI NAGAR	14089	11 KV KALYANI NAGAR	14089201	PATANJALI	3213DT017	250	MIXED	AMI	Yes	0%	67	0.16588708	0.09101	0.07487708	45.14%
5408	TPCODL	CUTTACK	CDD-2	BADAMBADI	KALYANI NAGAR	14089	11 KV KALYANI NAGAR	14089201	SURA BEHRA	3213DT020	250	MIXED	AMI	Yes	0%	186	0.2456498	0.209726	0.0359238	14.62%
5409	TPCODL	CUTTACK	CDD-2	BADAMBADI	KALYANI NAGAR	14089	11 KV RING-1	14089203	EE PHD 1	3212DT019	250	MIXED	AMI	Yes	100%	95	0.18369896	0.104197	0.07950196	43.28%
5410	TPCODL	CUTTACK	CDD-2	BADAMBADI	KALYANI NAGAR	14089	11 KV RING-1	14089203	MANGALA MANDIR	3212DT028	250	MIXED	AMI	Yes	0%	180	0.2537814	0.228903	0.0248784	9.80%
5411	TPCODL	CUTTACK	CDD-2	BADAMBADI	KALYANI NAGAR	14089	11 KV RING-1	14089203	HARISH MOHANTY2	3212DT037	250	MIXED	AMI	Yes	100%	36	0.226265	0.090873	0.135392	59.84%
5412	TPCODL	CUTTACK	CDD-2	BADAMBADI	KALYANI NAGAR	14089	11 KV RING-1	14089203	KAMALA TOWER	3212DT210	500	MIXED	AMI	Yes	100%	8	0.028878	0.0075	0.021378	74.03%
5413	TPCODL	CUTTACK	CDD-2	BADAMBADI	KALYANI NAGAR	14089	11 KV CHAULIAGANJ-2	14089206	ANDARPUR NEW COLONY	3213DT093	250	MIXED	AMI	Yes	0%	142	0.21246904	0.153763	0.05870604	27.63%
5414	TPCODL	CUTTACK	CDD-2	BADAMBADI	KHAN NAGAR (BAD/	14296	11 KV Mahatab	14296201	DOLAMUNDAI 3	3212DT135	500	MIXED	AMI	Yes	33%	241	0.31097524	0.211309	0.09966624	32.05%
5415	TPCODL	CUTTACK	CDD-2	BADAMBADI	KHAN NAGAR (BAD/	14296	11 KV Mahatab	14296201	DOLAMUNDAI 7	3212DT145	500	MIXED	AMI	Yes	100%	388	0.53702936	0.455495	0.08153436	15.18%
5416	TPCODL	CUTTACK	CDD-2	BADAMBADI	KHAN NAGAR (BAD/	14296	11 KV Mahatab	14296201	DOLAMUNDAI 14	3212DT149	500	MIXED	AMI	Yes	100%	130	0.6110156	0.146969	0.4640466	75.95%
5417	TPCODL	CUTTACK	CDD-2	BADAMBADI	KHAN NAGAR (BAD/	14296	11 KV Mahatab	14296201	JK APARTMENT	3212DT151	100	MIXED	AMI	Yes	33%	9	0.00920516	0.006789	0.00241616	26.25%
5418	TPCODL	CUTTACK	CDD-2	BADAMBADI	KHAN NAGAR (BAD/	14296	11 KV Mahatab	14296201	SRIRAM NAGAR 2	3212DT159	250	MIXED	AMI	Yes	100%	209	0.27807632	0.264965	0.01311132	4.72%
5419	TPCODL	CUTTACK	CDD-2	BADAMBADI	KHAN NAGAR (BAD/	14296	11 KV Mahatab	14296201	IN SIDE OLD LIC COLONY 2	3212DT160	630	MIXED	AMI	Yes	0%	74	0.05754276	0.045436	0.01210676	21.04%
5420	TPCODL	CUTTACK	CDD-2	BADAMBADI	KHAN NAGAR (BAD/	14296	11 KV Mahatab	14296201	IN SIDE OLD LIC COLONY 1	3212DT161	630	MIXED	AMI	Yes	0%	157	0.12478651	0.117003	0.00778351	6.24%
5421	TPCODL	CUTTACK	CDD-2	BADAMBADI	MATTAGAJAPUR	14211	11 KV POPARADA	14211201	POPARADA-II	3213DT102	250	MIXED	AMI	Yes	100%	172	0.1855956	0.091475	0.0941206	50.71%
5422	TPCODL	CUTTACK	CDD-2	BADAMBADI	MATTAGAJAPUR	14211	11 KV MATAGAJPUR	14211202	MATGAJPUR 1	3213DT128	250	MIXED	AMI	Yes	100%	134	0.14663688	0.056807	0.08982988	61.26%
5423	TPCODL	CUTTACK	CDD-2	BADAMBADI	MATTAGAJAPUR	14211	11 KV MATAGAJPUR	14211202	MATGAJPUR 3	3213DT132	100	MIXED	AMI	Yes	100%	22	0.0433511	0.010809	0.0325421	75.07%
5424	TPCODL	CUTTACK	CDD-2	BADAMBADI	MATTAGAJAPUR	14211	11 KV MATAGAJPUR	14211202	BALIKANTIA	3213DT134	100	MIXED	AMI	Yes	0%	25	0.04918334	0.011698	0.03748534	76.22%
5425	TPCODL	CUTTACK	CDD-2	BADAMBADI	MEDICAL	14083	11 KV TELEPHONE BHAW	14083201	KHUNTIA LANE	3113DT047	250	MIXED	AMI	Yes	0%	157	0.2751914	0.204646	0.0705454	25.64%
5426	TPCODL	CUTTACK	CDD-2	BADAMBADI	MEDICAL	14083	11 KV TELEPHONE BHAW	14083201	SAUCHALAYA	3133DT039	250	MIXED	AMI	Yes	100%	157	0.1698352	0.16844	0.0013952	0.82%
5427	TPCODL	CUTTACK	CDD-2	BADAMBADI	NISCHINTAKOILI	14099	11 KV UMARA	14099201	PRAHARAJ PUR BUDHEJWAR TEMPLE	3522DT188	100	MIXED	AMI	Yes	100%	64	0.04898268	0.017283	0.03169968	64.72%
5428	TPCODL	CUTTACK	CDD-2	BADAMBADI	OGP	14090	11 KV INDUSTRIAL-1	14090201	THERMACOL FACTORY(KALINGA SS)	3213DT156	500	MIXED	AMI	Yes	0%	69	0.33237132	0.148574	0.18379732	55.30%
5429	TPCODL	CUTTACK	CDD-2	BADAMBADI	OGP	14090	11 KV INDUSTRIAL-1	14090201	SRIRAM NAGAR	3213DT166	500	MIXED	AMI	Yes	100%	60	0.1571354	0.074568	0.0825674	52.55%
5430	TPCODL	CUTTACK	CDD-2	BADAMBADI	OGP	14090	11 KV INDUSTRIAL-1	14090201	LABOUR COLONY	3213DT177	500	MIXED	AMI	Yes	100%	373	0.39427648	0.316715	0.07756148	19.67%
5431	TPCODL	CUTTACK	CDD-2	BADAMBADI	OGP	14090	11 KV INDUSTRIAL-1	14090201	JICA	3213DT225	63	MIXED	AMI	Yes	0%	2	0.00950172	0.009461	4.072E-05	0.43%
5432	TPCODL	CUTTACK	CDD-2	BADAMBADI	OGP	14090	11 KV INDUSTRIAL-2	14090202	OFFICERS COLONY	3213DT029	250	MIXED	AMI	Yes	100%	262	0.15308804	0.11987	0.03321804	21.70%
5433	TPCODL	CUTTACK	CDD-2	BADAMBADI	OGP	14090	11 KV INDUSTRIAL-2	14090202	SANTOSHI NAGAR, NURSARY	3213DT047	250	MIXED	AMI	Yes	0%	88	0.15723728	0.045604	0.11163328	71.00%
5434	TPCODL	CUTTACK	CDD-2	BADAMBADI	OGP	14090	11 KV INDUSTRIAL-2	14090202	SUBAS BEHERA	3213DT049	250	MIXED	AMI	Yes	100%	130	0.1729446	0.10833	0.0646146	37.36%
5435	TPCODL	CUTTACK	CDD-2	BADAMBADI	OGP	14090	11 KV INDUSTRIAL-2	14090202	RUCHI GALI	3213DT056	500	MIXED	AMI	Yes	33%	259	0.30812056	0.26296	0.04516056	14.66%
5436	TPCODL	CUTTACK	CDD-2	BADAMBADI	OGP	14090	11 KV KATHAJODI	14090204	DARGHA PATNA	3213DT181	100	MIXED	AMI	Yes	100%	65	0.1081364	0.069552	0.0385844	35.68%
5437	TPCODL	CUTTACK	CDD-2	BADAMBADI	OGP	14090	11 KV KATHAJODI	14090204	BINAYAK VIHAR 1	3213DT182	250	MIXED	AMI	Yes	100%	25	0.05708436	0.026278	0.03080636	53.97%
5438	TPCODL	CUTTACK	CDD-2	BADAMBADI	OGP	14090	11 KV KATHAJODI	14090204	ANANDI JENA	3213DT187	100	MIXED	AMI	Yes	100%	34	0.0453073	0.036941	0.0083663	18.47%
5439	TPCODL	CUTTACK	CDD-2	BADAMBADI	OGP	14090	11 KV KATHAJODI	14090204	NUA PADA 1	3213DT193	250	MIXED	AMI	Yes	67%	275	0.23226204	0.232048	0.00021404	0.09%
5440	TPCODL	CUTTACK	CDD-2	BADAMBADI	OGP	14090	GOSALA	14090205	GOPESWAR VIHAR	3213DT180	250	MIXED	AMI	Yes	100%	153	0.20216532	0.140101	0.06206432	30.70%
5441	TPCODL	CUTTACK	CDD-2	BADAMBADI	OGP	14090	GOSALA	14090205	PRESS COLONY	3213DT196	200	MIXED	AMI	Yes	100%	47	0.13646996	0.029191	0.10727896	78.61%
5442	TPCODL	CUTTACK	CDD-2	BADAMBADI	OGP	14090	GOSALA	14090205	KUNJA BIHARI 1	3213DT202	500	MIXED	AMI	Yes	100%	63	0.10682728	0.075176	0.03165128	29.63%
5443	TPCODL	CUTTACK	CDD-2	BADAMBADI	OGP	14090	OGP BADAMBADI UG	14090206	SJPL	3213DT061	100	MIXED	AMI	Yes	0%	1	0.040533	0.040526	7E-06	0.02%
5444	TPCODL	CUTTACK	CDD-2	BADAMBADI	OGP	14090	11 KV OGP-KALYANI NAG	14090207	SAMRAT CINEMA CSS	3213DT142	630	MIXED	AMI	Yes	100%	65	0.32122963	0.077174	0.24405563	75.98%
5445	TPCODL	CUTTACK	CDD-2	BADAMBADI	OGP	14090	11 KV OGP-KALYANI NAG	14090207	Akash institute css-26	3213DT229	630	MIXED	AMI	Yes	100%	68	0.45122338	0.092838	0.35838538	79.43%
5446	TPCODL	CUTTACK	CDD-2	BADAMBADI	PRATAP NAGARI (DA	14298	11KV PRATAP NAGARI	14298202	OMFED COLONY 1	3332DT293	100	MIXED	AMI	Yes	100%	31	0.07731532	0.01991	0.05740532	74.25%
5447	TPCODL	CUTTACK	CDD-2	BADAMBADI	SOMAPUR ODSSP	14297	11 KV RAMKUMARPUR	14297203	RAMKUMARPUR CHAKKA	3225DT165	63	MIXED	AMI	Yes	100%	63	0.03660588	0.025082	0.01152388	31.48%
5448	TPCODL	CUTTACK	CDD-2	JOBRA	42 MAUZA	14092	11 kV BENTKAR	14092202	PUJA TOTA	3221DT013	100	MIXED	AMI	Yes	67%	110	0.06715566	0.050723	0.01643266	24.47%
5449	TPCODL	CUTTACK	CDD-2	JOBRA	KANDARPUR	14093	11 kV KANDARPUR	14093202	KANDARPUR PUR 2	3225DT189	100	MIXED	AMI	Yes	67%	120	0.0458098	0.036895	0.0089148	19.46%
5450	TPCODL	CUTTACK	CDD-2	JOBRA	CHOUDWAR	17018	JAGATPUR	17018405	33/11 kV JAGATPUR (IPICOL) ODSSP S	3222DT002	100	MIXED	AMI	Yes	100%	1	0.00891927	0.008919	2.7E-07	0.00%
5451	TPCODL	CUTTACK	CDD-2	JOBRA	42 MAUZA	14092	11 KV CHANDULI	14092201	BENTKAR2	3221DT078	100	MIXED	AMI	Yes	0%	70	0.0830092	0.03851	0.0444992	53.61%
5452	TPCODL	CUTTACK	CDD-2	JOBRA	42 MAUZA	14092	11 KV CHANDULI	14092201	BENTKAR JENASAHI	3221DT079	63	MIXED	AMI	Yes	100%	112	0.0608198	0.05073	0.0100898	16.59%
5453	TPCODL	CUTTACK	CDD-2	JOBRA	42 MAUZA	14092	11 KV CHANDULI	14092201	SISUA RAGIP	3221DT080	63	MIXED	AMI	Yes	0%	69	0.03876048	0.028697	0.01006348	25.96%
5454	TPCODL	CUTTACK	CDD-2	JOBRA	42 MAUZA	14092	11 KV CHANDULI	14092201	GOBINDPUR3	3221DT084	100	MIXED	AMI	Yes	100%	104	0.06422506	0.052123	0.01210206	18.84%
5455	TPCODL	CUTTACK	CDD-2	JOBRA	42 MAUZA	14092	11 KV CHANDULI	14092201	GOBINDPUR4	3221DT085	63	MIXED	AMI	Yes	67%	27	0.02499602	0.011733	0.01326302	53.06%
5456	TPCODL	CUTTACK	CDD-2	JOBRA	42 MAUZA	14092	11 KV CHANDULI	14092201	PODA SAHI	3221DT089	100	MIXED	AMI	Yes	100%	41	0.03056488	0.018718	0.01184688	38.76%
5457	TPCODL	CUTTACK	CDD-2	JOBRA	42 MAUZA	14092	11 KV CHANDULI	14092201	JENA SAHI(ROUTRAPUR)	3221DT093	100	MIXED	AMI	Yes	100%	90	0.0653232	0.038404	0.0269192	41.21%
5458	TPCODL	CUTTACK	CDD-2	JOBRA	42 MAUZA	14092	11 KV CHANDULI	14092201	PARIDA SAHI KULA KALAPADA	3221DT098	100	MIXED	AMI	Yes	100%	61	0.05414498	0.031494	0.02265098	41.83%
5459	TPCODL	CUTTACK	CDD-2	JOBRA	42 MAUZA	14092	11 KV CHANDULI	14092201	KULASARICHUAN HIGH SCHOOL	3221DT110	100	MIXED	AMI	Yes	0%	52	0.01797826	0.016743	0.00123526	6.87%
5460	TPCODL	CUTTACK	CDD-2	JOBRA	42 MAUZA	14092	11 KV CHANDULI	14092201	SAHABAZAR	3221DT111	100	MIXED	AMI	Yes	0%	148	0.0854105	0.056918	0.0284925	33.36%
5461	TPCODL	CUTTACK	CDD-2	JOBRA	42 MAUZA	14092	11 KV CHANDULI	14092201	KALASRUCHUAN6 BEHERA SAHI	3221DT113	100	MIXED	AMI	Yes	100%	148	0.10353316	0.070901	0.03263216	31.52%
5462	TPCODL	CUTTACK	CDD-2	JOBRA	42 MAUZA	14092	11 KV CHANDULI	14092201	NEELKANTH NATH TEMPLE	3221DT123	100	MIXED	AMI	Yes	0%	208	0.09511968	0.070151	0.02496868	26.25%
5463	TPCODL	CUTTACK	CDD-2	JOBRA	42 MAUZA	14092	11 KV CHANDULI	14092201	RWSS CHANDULI	3221DT127	100	MIXED	AMI	Yes	0%	66	0.06326408	0.036547	0.02671708	42.23%
5464	TPCODL	CUTTACK	CDD-2	JOBRA	42 MAUZA	14092	11 KV CHANDULI	14092201	MIRZAPUR	3221DT129	100	MIXED	AMI	Yes	100%	138	0.05955218	0.043266	0.01628618	27.35%
5465	TPCODL	CUTTACK	CDD-2	JOBRA	42 MAUZA	14092	11 KV CHANDULI	14092201	BARAL6	3221DT143	100	MIXED	AMI	Yes	100%	100	0.04260024	0.031591	0.01100924	25.84%
5466	TPCODL	CUTTACK	CDD-2	JOBRA	42 MAUZA	14092	11 KV BENTKAR	14092202	SHRI RAM NEW COLONY	3221DT003	63	MIXED	AMI	Yes	100%	54	0.0579296	0.044563	0.0133666	23.07%
5467	TPCODL	CUTTACK	CDD-2	JOBRA	42 MAUZA	14092	11 KV BENTKAR	14092202	SAMAL SAHI SHRIRAM	3221DT004	63	MIXED	AMI	Yes	100%	99	0.06476192	0.04866	0.01610192	24.86%
5468	TPCODL	CUTTACK	CDD-2	JOBRA	42 MAUZA	14092	11 KV BENTKAR	14092202	BALRAM VIHAR	3221DT006	250	MIXED	AMI	Yes	100%	46	0.05685676	0.033364	0.02349276	41.32%
5469	TPCODL	CUTTACK	CDD-2	JOBRA	42 MAUZA	14092	11 KV BENTKAR	14092202	DIHA BHOI SAHI	3221DT008	63	MIXED	AMI	Yes	100%	73	0.02392736	0.019596	0.00433136	18.10%
5470	TPCODL	CUTTACK	CDD-2	JOBRA	42 MAUZA	14092	11 KV BENTKAR	14092202	CHAKRADHAR DIXIT SHRIRAM	3221DT011	250	MIXED	AMI	Yes	100%	135	0.14811952	0.097684	0.05043552	34.05%
5471	TPCODL	CUTTACK	CDD-2	JOBRA	42 MAUZA	14092	11 KV BENTKAR	14092202	DURGA FARM SHRIRAM	3221DT012	100	MIXED	AMI	Yes	100%	235	0.16767232	0.144817	0.02285532	13.63%
5472	TPCODL	CUTTACK	CDD-2	JOBRA	42 MAUZA	14092	11 KV BENTKAR	14092202	BASULI BRAHMPUR	3221DT016	100	MIXED	AMI	Yes	0%	90	0.04867176	0.040101	0.00857076	17.61%
5473	TPCODL	CUTTACK	CDD-2	JOBRA	42 MAUZA	14092	11 KV BENTKAR	14092202	SNGEETA JENA	3221DT018	63	MIXED	AMI	Yes	100%	76	0.089188	0.048024	0.041164	46.15%
5474	TPCODL	CUTTACK	CDD-2	JOBRA	42 MAUZA	14092	11 KV BENTKAR	14092202	SECTOR 7	3221DT019	100	MIXED	AMI	Yes	100%	116	0.11010218	0.083137	0.02696518	24.49%

Sl. No.	Zone Name	Circle name	Division name	Name of the Sub-division	Name of the Sub-station	Substation Code	Name of the 11 kV Feeder	Feeder Code	Name of the Location where DT situated	DT code	DT Capacity (kVA)	Predominant consumer type of DT (Domestic/Industrial/Agriculture/Mixed)	Type of metering AMR/AMI/ Communicable/Conventional metered/Unmetered	Status of Meter-whether Functional (Yes/No)	% of data received automatically (if AMR/AMI)	No. of Connected Consumers	Input Energy (MU) (A)	Billed Energy (MU) (B)	Loss (MU) (A-B)	% DT Loss (A-B)/A
5475	TPCODL	CUTTACK	CDD-2	JOBRA	42 MAUZA	14092	11 KV BENTKAR	14092202	S.K.VIHAR 2	3221DT029	500	MIXED	AMI	Yes	0%	109	0.34502512	0.070105	0.27492012	79.68%
5476	TPCODL	CUTTACK	CDD-2	JOBRA	42 MAUZA	14092	11 KV BENTKAR	14092202	S.K.VIHAR TEMPLE	3221DT030	250	MIXED	AMI	Yes	0%	173	0.20000988	0.116694	0.08331588	41.66%
5477	TPCODL	CUTTACK	CDD-2	JOBRA	42 MAUZA	14092	11 KV BENTKAR	14092202	KANTA BANIYA 1	3221DT034	63	MIXED	AMI	Yes	0%	41	0.0097982	0.00844	0.0013582	13.86%
5478	TPCODL	CUTTACK	CDD-2	JOBRA	42 MAUZA	14092	11 KV BENTKAR	14092202	RANASANDH TEMPLE	3221DT035	100	MIXED	AMI	Yes	100%	45	0.0628615	0.037787	0.0250745	39.89%
5479	TPCODL	CUTTACK	CDD-2	JOBRA	42 MAUZA	14092	11 KV BENTKAR	14092202	CITI FEED	3221DT037	250	MIXED	AMI	Yes	100%	2	0.0259064	0.025819	8.74E-05	0.34%
5480	TPCODL	CUTTACK	CDD-2	JOBRA	42 MAUZA	14092	11 KV BENTKAR	14092202	AMULYA SAHOO	3221DT040	500	MIXED	AMI	Yes	0%	135	0.22510512	0.082871	0.14223412	63.19%
5481	TPCODL	CUTTACK	CDD-2	JOBRA	42 MAUZA	14092	11 KV BENTKAR	14092202	BGJY MANIBAD	3221DT053	63	MIXED	AMI	Yes	67%	40	0.01723482	0.01266	0.00457482	26.54%
5482	TPCODL	CUTTACK	CDD-2	JOBRA	42 MAUZA	14092	11 KV BENTKAR	14092202	NAHARPADA	3221DT057	63	MIXED	AMI	Yes	67%	98	0.06194764	0.047773	0.01417464	22.88%
5483	TPCODL	CUTTACK	CDD-2	JOBRA	42 MAUZA	14092	11 KV BENTKAR	14092202	JHARAKATA 1	3221DT058	100	MIXED	AMI	Yes	67%	139	0.13357062	0.085929	0.04764162	35.67%
5484	TPCODL	CUTTACK	CDD-2	JOBRA	42 MAUZA	14092	11 KV BENTKAR	14092202	GOBINDPUR1	3221DT071	100	MIXED	AMI	Yes	0%	158	0.0730837	0.071202	0.0018817	2.57%
5485	TPCODL	CUTTACK	CDD-2	JOBRA	42 MAUZA	14092	11 KV JHINKIRIA	14092203	DOBHANI	3221DT148	63	MIXED	AMI	Yes	0%	117	0.1459655	0.05837	0.0875955	60.01%
5486	TPCODL	CUTTACK	CDD-2	JOBRA	42 MAUZA	14092	11 KV JHINKIRIA	14092203	BAHALA PADA	3221DT149	63	MIXED	AMI	Yes	100%	29	0.07857537	0.017289	0.06128637	78.00%
5487	TPCODL	CUTTACK	CDD-2	JOBRA	42 MAUZA	14092	11 KV JHINKIRIA	14092203	KHAIRIPADIA	3221DT157	100	MIXED	AMI	Yes	100%	155	0.093338	0.083629	0.009709	10.40%
5488	TPCODL	CUTTACK	CDD-2	JOBRA	42 MAUZA	14092	11 KV JHINKIRIA	14092203	AITALANGA	3221DT161	100	MIXED	AMI	Yes	100%	35	0.05003394	0.013908	0.03612594	72.20%
5489	TPCODL	CUTTACK	CDD-2	JOBRA	42 MAUZA	14092	11 KV JHINKIRIA	14092203	BATUNIA	3221DT174	100	MIXED	AMI	Yes	100%	133	0.09634734	0.090315	0.00603234	6.26%
5490	TPCODL	CUTTACK	CDD-2	JOBRA	42 MAUZA	14092	11 KV KALAPADA	14092204	BANTUNIYA-2	3221DT176	100	MIXED	AMI	Yes	100%	69	0.04235024	0.027803	0.01454724	34.35%
5491	TPCODL	CUTTACK	CDD-2	JOBRA	42 MAUZA	14092	11 KV KALAPADA	14092204	TAILIPADA	3221DT177	63	MIXED	AMI	Yes	0%	68	0.0627183	0.040687	0.0220313	35.13%
5492	TPCODL	CUTTACK	CDD-2	JOBRA	42 MAUZA	14092	11 KV KALAPADA	14092204	SABALPUR-2	3221DT179	100	MIXED	AMI	Yes	67%	32	0.03260488	0.013725	0.01887988	57.91%
5493	TPCODL	CUTTACK	CDD-2	JOBRA	42 MAUZA	14092	11 KV KALAPADA	14092204	DAHIGAON	3221DT181	63	MIXED	AMI	Yes	100%	55	0.03975167	0.037458	0.00229367	5.77%
5494	TPCODL	CUTTACK	CDD-2	JOBRA	42 MAUZA	14092	11 KV KALAPADA	14092204	DEUU RWSS	3221DT188	63	MIXED	AMI	Yes	100%	166	0.07545504	0.072522	0.00293304	3.89%
5495	TPCODL	CUTTACK	CDD-2	JOBRA	42 MAUZA	14092	11 KV KALAPADA	14092204	DEULI-2	3221DT191	100	MIXED	AMI	Yes	100%	73	0.0709989	0.028829	0.0421699	59.40%
5496	TPCODL	CUTTACK	CDD-2	JOBRA	42 MAUZA	14092	11 KV KALAPADA	14092204	TANKIA RGGVY	3221DT192	100	MIXED	AMI	Yes	100%	29	0.0678273	0.017995	0.0498323	73.47%
5497	TPCODL	CUTTACK	CDD-2	JOBRA	42 MAUZA	14092	11 KV KALAPADA	14092204	KALUPADA-3	3221DT198	100	MIXED	AMI	Yes	100%	64	0.05544436	0.03205	0.02339436	42.19%
5498	TPCODL	CUTTACK	CDD-2	JOBRA	42 MAUZA	14092	11 KV KALAPADA	14092204	KALUPADA-4	3221DT199	100	MIXED	AMI	Yes	100%	148	0.09806966	0.087596	0.01047366	10.68%
5499	TPCODL	CUTTACK	CDD-2	JOBRA	42 MAUZA	14092	11 KV KALAPADA	14092204	BASANTA KUNDAL-1	3221DT200	63	MIXED	AMI	Yes	100%	64	0.03304665	0.023732	0.00931465	28.19%
5500	TPCODL	CUTTACK	CDD-2	JOBRA	42 MAUZA	14092	11 KV KALAPADA	14092204	UPPER BHARAGOLA	3221DT203	63	MIXED	AMI	Yes	100%	72	0.03649704	0.031606	0.00489104	13.40%
5501	TPCODL	CUTTACK	CDD-2	JOBRA	42 MAUZA	14092	11 KV KALAPADA	14092204	KUDA TAINKANA	3221DT206	63	MIXED	AMI	Yes	100%	97	0.03211458	0.026769	0.00534558	16.65%
5502	TPCODL	CUTTACK	CDD-2	JOBRA	42 MAUZA	14092	11 KV KALAPADA	14092204	KUDA TAINKANA	3221DT207	100	MIXED	AMI	Yes	0%	72	0.04212628	0.028269	0.01385728	32.89%
5503	TPCODL	CUTTACK	CDD-2	JOBRA	42 MAUZA	14092	11 KV KALAPADA	14092204	KALUPADA BARIKA SAHI	3221DT209	63	MIXED	AMI	Yes	100%	41	0.02632843	0.01371	0.01261843	47.93%
5504	TPCODL	CUTTACK	CDD-2	JOBRA	42 MAUZA	14092	11 KV KALAPADA	14092204	BHARAGALA	3221DT210	100	MIXED	AMI	Yes	100%	52	0.03686866	0.024577	0.01229166	33.34%
5505	TPCODL	CUTTACK	CDD-2	JOBRA	CRRI	14091	11 KV MAHANADI VIHAR	14091202	AG COLONY	3231DT184	250	MIXED	AMI	Yes	0%	114	0.14911096	0.112315	0.03679596	24.68%
5506	TPCODL	CUTTACK	CDD-2	JOBRA	JAGATPUR	14088	11 KV IDCO	14088201	APEX	3223DT137	500	MIXED	AMI	Yes	0%	9	0.40143968	0.192699	0.20874068	52.00%
5507	TPCODL	CUTTACK	CDD-2	JOBRA	JAGATPUR	14088	11 KV IDCO	14088201	ROYAL PLASTIC	3223DT141	500	MIXED	AMI	Yes	0%	48	0.28022648	0.238961	0.04126548	14.73%
5508	TPCODL	CUTTACK	CDD-2	JOBRA	JAGATPUR	14088	11 KV BARRAGE	14088202	BARRAGE COLONY	3223DT156	250	MIXED	AMI	Yes	100%	150	0.10148104	0.088724	0.01275704	12.57%
5509	TPCODL	CUTTACK	CDD-2	JOBRA	JAGATPUR	14088	11 KV BARRAGE	14088202	TARALO	3223DT168	100	MIXED	AMI	Yes	100%	42	0.12165224	0.039094	0.08255824	67.86%
5510	TPCODL	CUTTACK	CDD-2	JOBRA	JAGATPUR	14088	11 KV BARRAGE	14088202	TAROL BEHERA SAHI	3223DT170	250	MIXED	AMI	Yes	67%	51	0.07439448	0.040469	0.03392548	45.60%
5511	TPCODL	CUTTACK	CDD-2	JOBRA	JAGATPUR	14088	11 KV OLD INDUSTRIAL	14088204	COLD STORAGE 1	3223DT057	250	MIXED	AMI	Yes	67%	144	0.19153884	0.174383	0.01715584	8.96%
5512	TPCODL	CUTTACK	CDD-2	JOBRA	JAGATPUR	14088	11 KV OLD INDUSTRIAL	14088204	BHUBANPUR 3	3223DT084	250	MIXED	AMI	Yes	100%	81	0.16858996	0.069764	0.09882596	58.62%
5513	TPCODL	CUTTACK	CDD-2	JOBRA	JAGATPUR	14088	11 KV OLD INDUSTRIAL	14088204	BAIKUNTHA VIHAR	3223DT088	250	MIXED	AMI	Yes	0%	180	0.16289372	0.133423	0.02947072	18.09%
5514	TPCODL	CUTTACK	CDD-2	JOBRA	JAGATPUR	14088	11 KV OLD INDUSTRIAL	14088204	SHANTI NAGAR	3223DT089	250	MIXED	AMI	Yes	0%	75	0.11841288	0.036286	0.08212688	69.36%
5515	TPCODL	CUTTACK	CDD-2	JOBRA	JAGATPUR	14088	11 KV OLD INDUSTRIAL	14088204	DELTA 1	3223DT090	100	MIXED	AMI	Yes	100%	101	0.06562394	0.062177	0.00344694	5.25%
5516	TPCODL	CUTTACK	CDD-2	JOBRA	JAGATPUR	14088	11 KV OLD INDUSTRIAL	14088204	LAXMANPUR 1	3223DT093	250	MIXED	AMI	Yes	100%	218	0.1220754	0.121939	0.0001364	0.11%
5517	TPCODL	CUTTACK	CDD-2	JOBRA	JAGATPUR	14088	11 KV OLD INDUSTRIAL	14088204	LAXMANPUR2	3223DT094	63	MIXED	AMI	Yes	100%	39	0.02620815	0.021383	0.00482515	18.41%
5518	TPCODL	CUTTACK	CDD-2	JOBRA	JAGATPUR	14088	11 KV OLD INDUSTRIAL	14088204	JAGATPUR MALLIK SAHI	3223DT101	100	MIXED	AMI	Yes	0%	153	0.12014994	0.087298	0.03285194	27.34%
5519	TPCODL	CUTTACK	CDD-2	JOBRA	JAGATPUR	14088	11 KV OLD INDUSTRIAL	14088204	OLD INDUSTRY 2	3223DT104	500	MIXED	AMI	Yes	100%	18	0.15686944	0.105984	0.05088544	32.44%
5520	TPCODL	CUTTACK	CDD-2	JOBRA	JAGATPUR	14088	11 KV OLD INDUSTRIAL	14088204	NEW KALONI(RHC SAI VIHAR)	3223DT110	250	MIXED	AMI	Yes	100%	107	0.05635488	0.026812	0.02954288	52.42%
5521	TPCODL	CUTTACK	CDD-2	JOBRA	JAGATPUR	14088	11 KV OLD INDUSTRIAL	14088204	FAKIRPUR	3223DT120	250	MIXED	AMI	Yes	0%	138	0.21608648	0.122015	0.09407148	43.53%
5522	TPCODL	CUTTACK	CDD-2	JOBRA	JAGATPUR	14088	11 KV OLD INDUSTRIAL	14088204	RIVER 2 RHC TRIVENI GADA	3223DT121	500	MIXED	AMI	Yes	100%	282	0.2138486	0.088302	0.1255466	58.71%
5523	TPCODL	CUTTACK	CDD-2	JOBRA	JAGATPUR	14088	11 KV OLD INDUSTRIAL	14088204	RIVER 4	3223DT127	250	MIXED	AMI	Yes	100%	107	0.18061496	0.057813	0.12280196	67.99%
5524	TPCODL	CUTTACK	CDD-2	JOBRA	JAGATPUR (IPICOL)	14241	11 KV MAHANADI	14241201	SARALA	3222DT240	500	MIXED	AMI	Yes	100%	44	0.25183365	0.199618	0.05221565	20.73%
5525	TPCODL	CUTTACK	CDD-2	JOBRA	JAGATPUR (IPICOL)	14241	11 KV MAHANADI	14241201	PANACEA	3223DT019	250	MIXED	AMI	Yes	100%	50	0.09644144	0.060918	0.03552344	36.83%
5526	TPCODL	CUTTACK	CDD-2	JOBRA	JAGATPUR (IPICOL)	14241	11 KV MAHANADI	14241201	OMIN	3223DT025	250	MIXED	AMI	Yes	100%	21	0.19221888	0.124213	0.06800588	35.38%
5527	TPCODL	CUTTACK	CDD-2	JOBRA	JAGATPUR (IPICOL)	14241	11 KV NEW INDUSTRIAL	14241202	NEAR SS 1	3222DT107	250	MIXED	AMI	Yes	100%	121	0.1459378	0.131365	0.0145728	9.99%
5528	TPCODL	CUTTACK	CDD-2	JOBRA	JAGATPUR (IPICOL)	14241	11 KV NEW INDUSTRIAL	14241202	KANCHAN PLASTIC 1	3222DT150	250	MIXED	AMI	Yes	100%	117	0.15165808	0.14977	0.00188808	1.24%
5529	TPCODL	CUTTACK	CDD-2	JOBRA	JAGATPUR (IPICOL)	14241	11 KV NEW INDUSTRIAL	14241202	COMPANY 11	3222DT155	250	MIXED	AMI	Yes	100%	46	0.08629312	0.071753	0.01454012	16.85%
5530	TPCODL	CUTTACK	CDD-2	JOBRA	JAGATPUR (IPICOL)	14241	11 KV KHAIRA	14241203	GOPABANDHU NAGAR	3222DT162	200	MIXED	AMI	Yes	0%	169	0.26812856	0.239082	0.02904656	10.83%
5531	TPCODL	CUTTACK	CDD-2	JOBRA	JAGATPUR (IPICOL)	14241	11 KV KHAIRA	14241203	VENOS ESTCON PVT LTD	3222DT178	500	MIXED	AMI	Yes	0%	179	0.36274744	0.154502	0.20824544	57.41%
5532	TPCODL	CUTTACK	CDD-2	JOBRA	JAGATPUR (IPICOL)	14241	11 KV KHAIRA	14241203	GUNJARPUR	3222DT225	250	MIXED	AMI	Yes	100%	160	0.1140163	0.086506	0.0275103	24.13%
5533	TPCODL	CUTTACK	CDD-2	JOBRA	JAGATPUR (IPICOL)	14241	11 KV KHAIRA	14241203	MADHUBANA CHAKA	3222DT303	250	MIXED	AMI	Yes	100%	45	0.09547892	0.033298	0.06218092	65.13%
5534	TPCODL	CUTTACK	CDD-2	JOBRA	KALYANI NAGAR	14089	11 KV RING-1	14089203	NAKEI PADIA 2	3212DT010	250	MIXED	AMI	Yes	100%	144	0.18819931	0.150221	0.03797831	20.18%
5535	TPCODL	CUTTACK	CDD-2	JOBRA	KANDARPUR	14093	11 KV ALL INDIA RADIO	14093201	MUSLIMSAHI	3224DT015	100	MIXED	AMI	Yes	0%	18	0.0335311	0.014251	0.0192801	57.50%
5536	TPCODL	CUTTACK	CDD-2	JOBRA	KANDARPUR	14093	11 KV ALL INDIA RADIO	14093201	FAKIR PADA 2,BARUNEI-2	3224DT018	100	MIXED	AMI	Yes	100%	111	0.09869762	0.06227	0.03642762	36.91%
5537	TPCODL	CUTTACK	CDD-2	JOBRA	KANDARPUR	14093	11 KV ALL INDIA RADIO	14093201	AMBICA BRICKS BARUNEI-1	3224DT019	100	MIXED	AMI	Yes	0%	116	0.06138296	0.05224	0.00914296	14.89%
5538	TPCODL	CUTTACK	CDD-2	JOBRA	KANDARPUR	14093	11 KV ALL INDIA RADIO	14093201	SASAN	3224DT020	63	MIXED	AMI	Yes	100%	29	0.02220052	0.009155	0.01304552	58.76%
5539	TPCODL	CUTTACK	CDD-2	JOBRA	KANDARPUR	14093	11 KV ALL INDIA RADIO	14093201	NAWBHANGA	3224DT030	100	MIXED	AMI	Yes	0%	57	0.04495948	0.024128	0.02083148	46.33%
5540	TPCODL	CUTTACK	CDD-2	JOBRA	KANDARPUR	14093	11 KV ALL INDIA RADIO	14093201	BIRIBATI BAZAR	3224DT040	250	MIXED	AMI	Yes	100%	69	0.13875016	0.053388	0.08536216	61.52%
5541	TPCODL	CUTTACK	CDD-2	JOBRA	KANDARPUR	14093	11 KV ALL INDIA RADIO	14093201	BHUAI SAI 1	3224DT043	63	MIXED	AMI	Yes	100%	100	0.05195934	0.02655	0.02540934	48.90%
5542	TPCODL	CUTTACK	CDD-2	JOBRA	KANDARPUR	14093	11 KV ALL INDIA RADIO	14093201	TANA RAPA VILLAGE-1	3224DT060	100	MIXED	AMI	Yes	0%	206	0.10662388	0.09641	0.01021388	9.58%
5543	TPCODL	CUTTACK	CDD-2	JOBRA	KANDARPUR	14093	11 KV ALL INDIA RADIO	14093201	TANA RAPA VILLAGE-2	3224DT061	63	MIXED	AMI	Yes	0%	82	0.07593824	0.047756	0.02818224	37.11%
5544	TPCODL	CUTTACK	CDD-2	JOBRA	KANDARPUR	14093	11 KV KANDARPUR	14093202	KARAPADA	3224DT119	100	MIXED	AMI	Yes	0%	96	0.09132908	0.071388	0.01994108	21.83%
5545	TPCODL	CUTTACK	CDD-2	JOBRA	KANDARPUR	14093	11 KV KANDARPUR	14093202	KANDARPUR VILLAGE	3224DT140	63	MIXED	AMI	Yes	0%	76	0.04791263	0.038179	0.00973363	20.32%
5546	TPCODL	CUTTACK	CDD-2	JOBRA	KANDARPUR	14093	11 KV KANDARPUR	14093202	SIDHESWAR	3224DT146	100	MIXED	AMI	Yes	100%	193	0.12018152	0.092586	0.02759552	22.96%
5547	TPCODL	CUTTACK	CDD-2	JOBRA	KANDARPUR	14093	11 KV KANDARPUR	14093202	DARDA SASANA	3224DT149	63	MIXED	AMI	Yes	100%	61	0.02573857	0.018404	0.00733457	28.50%

Sl. No.	Zone Name	Circle name	Division name	Name of the Sub-division	Name of the Sub-station	Substation Code	Name of the 11 kV Feeder	Feeder Code	Name of the Location where DT situated	DT code	DT Capacity (kVA)	Predominant consumer type of DT (Domestic/Industrial/Agriculture/Mixed)	Type of metering AMR/AMI/ Communicable/Conventional metered/Unmetered	Status of Meter-whether Functional (Yes/No)	% of data received automatically (if AMR/AMI)	No. of Connected Consumers	Input Energy (MU) (A)	Billed Energy (MU) (B)	Loss (MU) (A-B)	% DT Loss (A-B)/A
5548	TPCODL	CUTTACK	CDD-2	JOBRA	KANDARPUR	14093	11 KV KANDARPUR	14093202	SIDHESWAR PUR	3224DT157	100	MIXED	AMI	Yes	100%	161	0.09866618	0.06573	0.03293618	33.38%
5549	TPCODL	CUTTACK	CDD-2	JOBRA	KANDARPUR	14093	11 KV KANDARPUR	14093202	RATNABATA	3224DT161	100	MIXED	AMI	Yes	100%	101	0.07861846	0.039775	0.03884346	49.41%
5550	TPCODL	CUTTACK	CDD-2	JOBRA	KANDARPUR	14093	11 KV KANDARPUR	14093202	RAUT SAHI	3224DT165	63	MIXED	AMI	Yes	100%	19	0.0234448	0.010795	0.0126498	53.96%
5551	TPCODL	CUTTACK	CDD-2	JOBRA	KANDARPUR	14093	11 KV KANDARPUR	14093202	SALIJANG 1	3224DT174	100	MIXED	AMI	Yes	67%	105	0.0970579	0.035528	0.0615299	63.40%
5552	TPCODL	CUTTACK	CDD-2	JOBRA	KANDARPUR	14093	11 KV KANDARPUR	14093202	SALIJANG 2(SARASUDHA MALI SAHI)	3224DT175	63	MIXED	AMI	Yes	0%	40	0.02664608	0.006952	0.01969408	73.91%
5553	TPCODL	CUTTACK	CDD-2	JOBRA	KANDARPUR	14093	11 KV KANDARPUR	14093202	SARASODA 1	3224DT177	63	MIXED	AMI	Yes	67%	87	0.03894072	0.031779	0.00716172	18.39%
5554	TPCODL	CUTTACK	CDD-2	JOBRA	KANDARPUR	14093	11 KV KANDARPUR	14093202	SARASODA 2	3224DT178	100	MIXED	AMI	Yes	67%	71	0.0599367	0.023858	0.0360787	60.19%
5555	TPCODL	CUTTACK	CDD-2	JOBRA	KANDARPUR	14093	11 KV KANDARPUR	14093202	KANDARPUR PUR 1	3224DT288	250	MIXED	AMI	Yes	100%	47	0.09630928	0.023775	0.07253428	75.31%
5556	TPCODL	CUTTACK	CDD-2	JOBRA	KANDARPUR	14093	11 KV KANDARPUR	14093202	JASPADA 6/KAMARPADA-1	3225DT060	100	MIXED	AMI	Yes	100%	72	0.09838766	0.035452	0.06293566	63.97%
5557	TPCODL	CUTTACK	CDD-2	JOBRA	KANDARPUR	14093	11 KV KANDARPUR	14093202	DHARINA 1	3225DT061	63	MIXED	AMI	Yes	67%	139	0.0838921	0.064335	0.0195571	23.31%
5558	TPCODL	CUTTACK	CDD-2	JOBRA	KANDARPUR	14093	11 KV KANDARPUR	14093202	PAIKASAHI	3225DT066	63	MIXED	AMI	Yes	67%	144	0.07061308	0.050786	0.01982708	28.08%
5559	TPCODL	CUTTACK	CDD-2	JOBRA	KANDARPUR	14093	11 KV KANDARPUR	14093202	JASA PADA 1	3225DT067	63	MIXED	AMI	Yes	67%	83	0.02536994	0.01807	0.00729994	28.77%
5560	TPCODL	CUTTACK	CDD-2	JOBRA	KANDARPUR	14093	11 KV KANDARPUR	14093202	JASA PADA 2	3225DT068	100	MIXED	AMI	Yes	0%	108	0.04360038	0.042248	0.00135238	3.10%
5561	TPCODL	CUTTACK	CDD-2	JOBRA	KANDARPUR	14093	11 KV KANDARPUR	14093202	JASA PADA 3	3225DT069	100	MIXED	AMI	Yes	33%	49	0.03542094	0.01704	0.01838094	51.89%
5562	TPCODL	CUTTACK	CDD-2	JOBRA	KANDARPUR	14093	11 KV KANDARPUR	14093202	SALI JASPADA	3225DT071	100	MIXED	AMI	Yes	67%	92	0.03595962	0.024772	0.01118762	31.11%
5563	TPCODL	CUTTACK	CDD-2	JOBRA	KANDARPUR	14093	11 KV KANDARPUR	14093202	KAMARA PADA	3225DT073	250	MIXED	AMI	Yes	0%	145	0.08540964	0.067836	0.01757364	20.58%
5564	TPCODL	CUTTACK	CDD-2	JOBRA	KANDARPUR	14093	11 KV PARAMAHANSA	14093203	KORPADA R	3224DT181	100	MIXED	AMI	Yes	0%	117	0.09083214	0.048542	0.04229014	46.56%
5565	TPCODL	CUTTACK	CDD-2	JOBRA	KANDARPUR	14093	11 KV PARAMAHANSA	14093203	BAMBURI 2	3224DT194	100	MIXED	AMI	Yes	67%	55	0.07326254	0.025553	0.04770954	65.12%
5566	TPCODL	CUTTACK	CDD-2	JOBRA	KANDARPUR	14093	11 KV PARAMAHANSA	14093203	KARA SAI-1	3224DT198	100	MIXED	AMI	Yes	0%	187	0.0937967	0.066744	0.0270527	28.84%
5567	TPCODL	CUTTACK	CDD-2	JOBRA	KANDARPUR	14093	11 KV PARAMAHANSA	14093203	SIDHASIR	3224DT204	100	MIXED	AMI	Yes	0%	61	0.02510856	0.013911	0.01119756	44.60%
5568	TPCODL	CUTTACK	CDD-2	JOBRA	KANDARPUR	14093	11 KV PARAMAHANSA	14093203	KAIJANGA	3224DT206	100	MIXED	AMI	Yes	0%	222	0.11766992	0.08781	0.02985992	25.38%
5569	TPCODL	CUTTACK	CDD-2	JOBRA	KANDARPUR	14093	11 KV PARAMAHANSA	14093203	DEVRAPARI	3224DT219	100	MIXED	AMI	Yes	67%	103	0.0563997	0.034096	0.0223037	39.55%
5570	TPCODL	CUTTACK	CDD-2	JOBRA	KANDARPUR	14093	11 KV PARAMAHANSA	14093203	MADHYASASAN-1	3224DT233	100	MIXED	AMI	Yes	100%	127	0.08155924	0.056881	0.02467824	30.26%
5571	TPCODL	CUTTACK	CDD-2	JOBRA	KANDARPUR	14093	11 KV PARAMAHANSA	14093203	BAREDA MADHYASASAN	3224DT234	63	MIXED	AMI	Yes	67%	44	0.01100198	0.007245	0.00375698	34.15%
5572	TPCODL	CUTTACK	CDD-2	JOBRA	KANDARPUR	14093	11 KV PARAMAHANSA	14093203	BAMBURI-3	3224DT236	63	MIXED	AMI	Yes	67%	124	0.05423776	0.046157	0.00808076	14.90%
5573	TPCODL	CUTTACK	CDD-2	JOBRA	KANDARPUR	14093	11 KV PARAMAHANSA	14093203	BAMBURI-2	3224DT237	100	MIXED	AMI	Yes	0%	86	0.0444762	0.037834	0.0066422	14.93%
5574	TPCODL	CUTTACK	CDD-2	JOBRA	KANDARPUR	14093	11 KV PARAMAHANSA	14093203	MAHAURA	3224DT241	250	MIXED	AMI	Yes	100%	170	0.09975344	0.071775	0.02797844	28.05%
5575	TPCODL	CUTTACK	CDD-2	JOBRA	KANDARPUR	14093	11 KV PARAMAHANSA	14093203	KUSINGA(SIKARI SAHI)	3224DT244	63	MIXED	AMI	Yes	100%	35	0.01408534	0.009642	0.00444334	31.55%
5576	TPCODL	CUTTACK	CDD-2	JOBRA	KANDARPUR	14093	11 KV PARAMAHANSA	14093203	DEOPUR	3224DT246	100	MIXED	AMI	Yes	0%	193	0.1058417	0.104933	0.0009087	0.86%
5577	TPCODL	CUTTACK	CDD-2	JOBRA	KANDARPUR	14093	11 KV PARAMAHANSA	14093203	RAGHUNATHPUR-1	3224DT253	100	MIXED	AMI	Yes	67%	118	0.09412932	0.056089	0.03804032	40.41%
5578	TPCODL	CUTTACK	CDD-2	JOBRA	KANDARPUR	14093	11 KV PARAMAHANSA	14093203	RAGHUNATHPUR-2	3224DT254	100	MIXED	AMI	Yes	0%	108	0.10274866	0.043516	0.05923266	57.65%
5579	TPCODL	CUTTACK	CDD-2	JOBRA	KANDARPUR	14093	11 KV PARAMAHANSA	14093203	BADHAI SAI PARAMHANS	3224DT259	63	MIXED	AMI	Yes	0%	33	0.01955748	0.004605	0.01495248	76.45%
5580	TPCODL	CUTTACK	CDD-2	JOBRA	KANDARPUR	14093	11 KV PARAMAHANSA	14093203	DEVIPUR-1	3224DT284	100	MIXED	AMI	Yes	100%	179	0.08662392	0.056509	0.03011492	34.77%
5581	TPCODL	CUTTACK	CDD-2	JOBRA	KANDARPUR	14093	11 KV AYATPUR	14093204	NIMIKIAPADA NEAR BY MAHANADE M	3224DT087	250	MIXED	AMI	Yes	100%	171	0.08444444	0.070726	0.01371844	16.25%
5582	TPCODL	CUTTACK	CDD-2	JOBRA	KANDARPUR	14093	11 KV AYATPUR	14093204	MADHAYM SAI	3224DT094	100	MIXED	AMI	Yes	0%	62	0.06368188	0.034003	0.02967888	46.60%
5583	TPCODL	CUTTACK	CDD-2	JOBRA	KANDARPUR	14093	11 KV AYATPUR	14093204	BRAMHWAN MVSLIMYAI	3224DT096	100	MIXED	AMI	Yes	33%	50	0.03133832	0.01952	0.01181832	37.71%
5584	TPCODL	CUTTACK	CDD-2	JOBRA	KANDARPUR	14093	11 KV AYATPUR	14093204	KOCHALI DEVLI SAI 2 KAHORE	3224DT099	63	MIXED	AMI	Yes	100%	72	0.03289654	0.020507	0.01238954	37.66%
5585	TPCODL	CUTTACK	CDD-2	JOBRA	KANDARPUR	14093	11 KV AYATPUR	14093204	NAGESHWAR NATHMANDIR	3224DT100	63	MIXED	AMI	Yes	0%	35	0.0265192	0.01273	0.0137892	52.00%
5586	TPCODL	CUTTACK	CDD-2	JOBRA	KANDARPUR	14093	11 KV AYATPUR	14093204	NUAINGAON ANGANBADI CENTER 2	3224DT105	63	MIXED	AMI	Yes	33%	23	0.01416668	0.010703	0.00346368	24.45%
5587	TPCODL	CUTTACK	CDD-2	JOBRA	KANDARPUR	14093	11 KV AYATPUR	14093204	BRAMANBAD	3224DT108	63	MIXED	AMI	Yes	100%	63	0.04311614	0.024759	0.01835714	42.58%
5588	TPCODL	CUTTACK	CDD-2	JOBRA	KANDARPUR	14093	11 KV AYATPUR	14093204	BEHRA SAI	3224DT114	100	MIXED	AMI	Yes	100%	82	0.02995498	0.018182	0.01177298	39.30%
5589	TPCODL	CUTTACK	CDD-2	JOBRA	KANDARPUR	14093	11 KV AYATPUR	14093204	DAMODER PUR 2	3224DT116	100	MIXED	AMI	Yes	0%	85	0.04470634	0.032333	0.01237334	27.68%
5590	TPCODL	CUTTACK	CDD-2	JOBRA	KANDARPUR	14093	11 KV AYATPUR	14093204	DANDUSIPADA 1	3224DT117	100	MIXED	AMI	Yes	0%	60	0.13760092	0.036714	0.10088692	73.32%
5591	TPCODL	CUTTACK	CDD-2	JOBRA	KANDARPUR	14093	11 KV AYATPUR	14093204	DANDUSIPADA 2	3224DT118	63	MIXED	AMI	Yes	100%	46	0.0330009	0.030348	0.0026529	8.04%
5592	TPCODL	CUTTACK	CDD-2	JOBRA	KANDARPUR	14093	11 KV AYATPUR	14093204	BARDA ROAD 1	3225DT003	500	MIXED	AMI	Yes	100%	145	0.08540152	0.062328	0.02307352	27.02%
5593	TPCODL	CUTTACK	CDD-2	JOBRA	KANDARPUR	14093	11 KV AYATPUR	14093204	NEAR BY TUDA TEE STOLA	3225DT004	63	MIXED	AMI	Yes	100%	28	0.01531184	0.010444	0.00486784	31.79%
5594	TPCODL	CUTTACK	CDD-2	JOBRA	KANDARPUR	14093	11 KV AYATPUR	14093204	BARDA ROAD 2	3225DT011	63	MIXED	AMI	Yes	100%	60	0.0324893	0.025088	0.0074013	22.78%
5595	TPCODL	CUTTACK	CDD-2	JOBRA	KANDARPUR	14093	11 KV AYATPUR	14093204	NEAR BY NARAYAN MANDIR	3225DT012	63	MIXED	AMI	Yes	100%	57	0.03846234	0.026861	0.01160134	30.16%
5596	TPCODL	CUTTACK	CDD-2	JOBRA	KANDARPUR	14093	11 KV AYATPUR	14093204	CANCHAPADA 2	3225DT015	63	MIXED	AMI	Yes	0%	45	0.04801508	0.011307	0.03670808	76.45%
5597	TPCODL	CUTTACK	CDD-2	JOBRA	KANDARPUR	14093	11 KV AYATPUR	14093204	NEAR BY PRAKASHA BETEL SOPE 1	3225DT019	25	MIXED	AMI	Yes	100%	52	0.02567924	0.015908	0.00977124	38.05%
5598	TPCODL	CUTTACK	CDD-2	JOBRA	KANDARPUR	14093	11 KV AYATPUR	14093204	CHANCHAPADA	3225DT021	63	MIXED	AMI	Yes	100%	24	0.02305243	0.015704	0.00734843	31.88%
5599	TPCODL	CUTTACK	CDD-2	JOBRA	KANDARPUR	14093	11 KV AYATPUR	14093204	BERYMANDI VILLAGE ROAD 1	3225DT022	100	MIXED	AMI	Yes	100%	65	0.04671478	0.027072	0.01964278	42.05%
5600	TPCODL	CUTTACK	CDD-2	JOBRA	KANDARPUR	14093	11 KV AYATPUR	14093204	SAGARIPUR 3	3225DT028	100	MIXED	AMI	Yes	100%	53	0.05413654	0.029243	0.02489354	45.98%
5601	TPCODL	CUTTACK	CDD-2	JOBRA	KISHAN NAGAR	14094	11 KV KISHANNAGAR	14094201	RI OFFICE	3225DT075	63	MIXED	AMI	Yes	100%	68	0.05958384	0.050001	0.00958284	16.08%
5602	TPCODL	CUTTACK	CDD-2	JOBRA	KISHAN NAGAR	14094	11 KV KISHANNAGAR	14094201	NADI KUDA	3225DT087	63	MIXED	AMI	Yes	100%	111	0.0651501	0.047853	0.0172971	26.55%
5603	TPCODL	CUTTACK	CDD-2	JOBRA	KISHAN NAGAR	14094	11 KV KISHANNAGAR	14094201	MANDAL TRANSFORMER	3225DT094	100	MIXED	AMI	Yes	100%	111	0.0559605	0.037181	0.0187795	33.56%
5604	TPCODL	CUTTACK	CDD-2	JOBRA	KISHAN NAGAR	14094	11 KV MALIPUR	14094202	BHAI PADA 1	3225DT098	100	MIXED	AMI	Yes	0%	46	0.02024524	0.010959	0.00928624	45.87%
5605	TPCODL	CUTTACK	CDD-2	JOBRA	KISHAN NAGAR	14094	11 KV MALIPUR	14094202	MALIPUR	3225DT102	63	MIXED	AMI	Yes	100%	63	0.02119186	0.019207	0.00198486	9.37%
5606	TPCODL	CUTTACK	CDD-2	JOBRA	KISHAN NAGAR	14094	11 KV MALIPUR	14094202	MALLIPUR BAGICHA	3225DT104	63	MIXED	AMI	Yes	0%	16	0.00921598	0.00327	0.00594598	64.52%
5607	TPCODL	CUTTACK	CDD-2	JOBRA	KISHAN NAGAR	14094	11 KV MALIPUR	14094202	MANGLADAIPUR PATNA 2	3225DT106	63	MIXED	AMI	Yes	100%	62	0.02158067	0.014012	0.00756867	35.07%
5608	TPCODL	CUTTACK	CDD-2	JOBRA	KISHAN NAGAR	14094	11 KV MALIPUR	14094202	MANGLADAIPUR PATNA 6	3225DT110	63	MIXED	AMI	Yes	100%	41	0.01712963	0.015493	0.00163663	9.55%
5609	TPCODL	CUTTACK	CDD-2	JOBRA	KISHAN NAGAR	14094	11 KV MALIPUR	14094202	MANGLADAIPUR PATNA 7	3225DT111	63	MIXED	AMI	Yes	100%	90	0.0401782	0.028262	0.0119162	29.66%
5610	TPCODL	CUTTACK	CDD-2	JOBRA	KISHAN NAGAR	14094	11 KV MALIPUR	14094202	KHENTALO 1	3225DT112	100	MIXED	AMI	Yes	67%	138	0.05751012	0.042415	0.01509512	26.25%
5611	TPCODL	CUTTACK	CDD-2	JOBRA	KISHAN NAGAR	14094	11 KV MALIPUR	14094202	BERHEMPUR	3225DT116	100	MIXED	AMI	Yes	67%	100	0.0462524	0.040662	0.0055904	12.09%
5612	TPCODL	CUTTACK	CDD-2	JOBRA	KISHAN NAGAR	14094	11 KV SOMAPUR - II	14094203	BADAPOKHARI BISOI SAHI	3225DT169	100	MIXED	AMI	Yes	100%	87	0.04442522	0.033748	0.01067722	24.03%
5613	TPCODL	CUTTACK	CDD-2	JOBRA	KISHAN NAGAR	14094	11 KV RAMCHANDRAPUR	14094204	SAMANTRA PUR	3225DT117	100	MIXED	AMI	Yes	0%	108	0.04944798	0.041766	0.00768198	15.54%
5614	TPCODL	CUTTACK	CDD-2	JOBRA	KISHAN NAGAR	14094	11 KV RAMCHANDRAPUR	14094204	GHARA SUNI	3225DT122	250	MIXED	AMI	Yes	0%	75	0.03794092	0.035676	0.00226492	5.97%
5615	TPCODL	CUTTACK	CDD-2	JOBRA	KISHAN NAGAR	14094	11 KV RAMCHANDRAPUR	14094204	ODAPADA 1	3225DT127	100	MIXED	AMI	Yes	100%	49	0.05240066	0.019116	0.03328466	63.52%
5616	TPCODL	CUTTACK	CDD-2	JOBRA	KISHAN NAGAR	14094	11 KV RAMCHANDRAPUR	14094204	MITRA KISHAN NAGAR	3225DT131	63	MIXED	AMI	Yes	100%	133	0.0541796	0.045013	0.0091666	16.92%
5617	TPCODL	CUTTACK	CDD-2	JOBRA	KISHAN NAGAR	14094	11 KV RAMCHANDRAPUR	14094204	CINEMA HALL	3225DT132	250	MIXED	AMI	Yes	100%	104	0.0693364	0.043297	0.0260394	37.56%
5618	TPCODL	CUTTACK	CDD-2	JOBRA	KISHAN NAGAR	14094	11 KV BISWALAPADA	14094205	BISWAL PADA 2	3225DT033	100	MIXED	AMI	Yes	0%	74	0.02664504	0.022603	0.00404204	15.17%
5619	TPCODL	CUTTACK	CDD-2	JOBRA	KISHAN NAGAR	14094	11 KV BISWALAPADA	14094205	BALISURI 1 TUKUNA NANA	3225DT041	63	MIXED	AMI	Yes	100%	80	0.03354246	0.024963	0.00857946	25.58%
5620	TPCODL	CUTTACK	CDD-2	JOBRA	KISHAN NAGAR	14094	11 KV BISWALAPADA	14094205	BADA BALSURI	3225DT042	63	MIXED	AMI	Yes	100%	90	0.0472544	0.037999	0.0092554	19.59%

Sl. No.	Zone Name	Circle name	Division name	Name of the Sub-division	Name of the Sub-station	Substation Code	Name of the 11 kV Feeder	Feeder Code	Name of the Location where DT situated	DT code	DT Capacity (kVA)	Predominant consumer type of DT (Domestic/Industrial/Agriculture/Mixed)	Type of metering AMR/AMI/ Communicable/Conventional metered/Unmetered	Status of Meter-whether Functional (Yes/No)	% of data received automatically (if AMR/AMI)	No. of Connected Consumers	Input Energy (MU) (A)	Billed Energy (MU) (B)	Loss (MU) (A-B)	% DT Loss (A-B)/A
5621	TPCODL	CUTTACK	CDD-2	JOBRA	KISHAN NAGAR	14094	11 KV BISWALAPADA	14094205	KESHPUR 2	3225DT050	63	MIXED	AMI	Yes	100%	69	0.04290696	0.033756	0.00915096	21.33%
5622	TPCODL	CUTTACK	CDD-2	JOBRA	SOMAPUR ODSSP	14297	11 KV SOMAPUR - I	14297201	SOMPUR BAZAR 3	3225DT174	100	MIXED	AMI	Yes	100%	84	0.0577068	0.041176	0.0165308	28.65%
5623	TPCODL	CUTTACK	CDD-2	JOBRA	SOMAPUR ODSSP	14297	11 KV SOMAPUR - I	14297201	SOMPUR-2	3225DT176	100	MIXED	AMI	Yes	100%	107	0.07441244	0.050709	0.02370344	31.85%
5624	TPCODL	CUTTACK	CDD-2	JOBRA	SOMAPUR ODSSP	14297	11 KV TELDIA	14297202	HANSDIA 1	3225DT182	100	MIXED	AMI	Yes	0%	113	0.04754124	0.037976	0.00956524	20.12%
5625	TPCODL	CUTTACK	CDD-2	JOBRA	SOMAPUR ODSSP	14297	11 KV TELDIA	14297202	SINGAL 2	3225DT185	63	MIXED	AMI	Yes	100%	97	0.03718908	0.029183	0.00800608	21.53%
5626	TPCODL	CUTTACK	CDD-2	JOBRA	SOMAPUR ODSSP	14297	11 KV TELDIA	14297202	JADUASAHI	3225DT188	63	MIXED	AMI	Yes	100%	43	0.02728768	0.022159	0.00512868	18.79%
5627	TPCODL	CUTTACK	CDD-2	JOBRA	SOMAPUR ODSSP	14297	11 KV RAMKUMARPUR	14297203	SOMPUR MUSALMAN SAHI MAHAJID	3225DT142	100	MIXED	AMI	Yes	100%	42	0.02112704	0.015576	0.00555104	26.27%
5628	TPCODL	CUTTACK	CDD-2	JOBRA	SOMAPUR ODSSP	14297	11 KV RAMKUMARPUR	14297203	SOMPUR	3225DT145	100	MIXED	AMI	Yes	100%	128	0.04654556	0.039382	0.00716356	15.39%
5629	TPCODL	CUTTACK	CDD-2	JOBRA	SOMAPUR ODSSP	14297	11 KV RAMKUMARPUR	14297203	MANDIR KE PICHHE SOMPUR ROAD	3225DT148	63	MIXED	AMI	Yes	67%	64	0.03480294	0.022765	0.01203794	34.59%
5630	TPCODL	CUTTACK	CDD-2	JOBRA	SOMAPUR ODSSP	14297	11 KV RAMKUMARPUR	14297203	MANDIR KE PASS SOMPUR ROAD	3225DT149	100	MIXED	AMI	Yes	100%	55	0.0462663	0.025245	0.0210213	45.44%
5631	TPCODL	CUTTACK	CDD-2	JOBRA	SOMAPUR ODSSP	14297	11 KV RAMKUMARPUR	14297203	BHUASUNI PADIA	3225DT152	100	MIXED	AMI	Yes	100%	116	0.06284076	0.038467	0.02437376	38.79%
5632	TPCODL	CUTTACK	CDD-2	JOBRA	SOMAPUR ODSSP	14297	11 KV RAMKUMARPUR	14297203	BASTA PADA PANDA SAHI	3225DT155	100	MIXED	AMI	Yes	67%	85	0.04609827	0.038843	0.00725527	15.74%
5633	TPCODL	CUTTACK	CDD-2	JOBRA	SOMAPUR ODSSP	14297	11 KV RAMKUMARPUR	14297203	KOTUAN	3225DT159	100	MIXED	AMI	Yes	100%	37	0.0475739	0.017234	0.0303399	63.77%
5634	TPCODL	CUTTACK	CDD-2	MAHANADIVIHA	CHOUDWAR	14184	11 KV CHARBATIA KALIN	14184207	ANGAR JADI 1	3321DT118	100	MIXED	AMI	Yes	0%	35	0.0285013	0.022875	0.0056263	19.74%
5635	TPCODL	CUTTACK	CDD-2	MAHANADIVIHA	CRRI	14091	11 KV MAHANADI VIHAR	14091202	MARKET	3231DT182	100	MIXED	AMI	Yes	100%	36	0.01856586	0.016121	0.00244486	13.17%
5636	TPCODL	CUTTACK	CDD-2	MAHANADIVIHA	CRRI	14091	11 KV MAHANADI VIHAR	14091202	AG COLONY 1	3231DT185	500	MIXED	AMI	Yes	0%	163	0.25602896	0.187336	0.06869296	26.83%
5637	TPCODL	CUTTACK	CDD-2	MAHANADIVIHA	CRRI	14091	11 KV MAHANADI VIHAR	14091202	BHADIMULA 2	3232DT208	250	MIXED	AMI	Yes	100%	224	0.16894908	0.139915	0.02903408	17.19%
5638	TPCODL	CUTTACK	CDD-2	MAHANADIVIHA	CRRI	14091	11 KV MAHANADI VIHAR	14091202	BHATIMUL	3232DT211	250	MIXED	AMI	Yes	100%	88	0.06665276	0.062129	0.00452376	6.79%
5639	TPCODL	CUTTACK	CDD-2	MAHANADIVIHA	CRRI	14091	11 KV MAHANADI VIHAR	14091202	KANHEIPUR2	3232DT213	100	MIXED	AMI	Yes	100%	16	0.01937779	0.00958	0.00979779	50.56%
5640	TPCODL	CUTTACK	CDD-2	MAHANADIVIHA	CRRI	14091	11 KV MAHANADI VIHAR	14091202	NEHERPALI	3232DT216	100	MIXED	AMI	Yes	100%	59	0.13656254	0.036703	0.09985954	73.12%
5641	TPCODL	CUTTACK	CDD-2	MAHANADIVIHA	CRRI	14091	11 KV MAHANADI VIHAR	14091202	RAGHUNATH VIHAR	3232DT217	500	MIXED	AMI	Yes	0%	290	0.29245344	0.202979	0.08947444	30.59%
5642	TPCODL	CUTTACK	CDD-2	MAHANADIVIHA	CRRI	14091	11 KV MAHANADI VIHAR	14091202	XAVIER SCHOOL	3232DT231	250	MIXED	AMI	Yes	67%	72	0.088454	0.076526	0.011928	13.48%
5643	TPCODL	CUTTACK	CDD-2	MAHANADIVIHA	CRRI	14091	11 KV MAHANADI VIHAR	14091202	NEHRUPALLI - 3	3232DT236	63	MIXED	AMI	Yes	100%	40	0.0630042	0.039717	0.0232872	36.96%
5644	TPCODL	CUTTACK	CDD-2	MAHANADIVIHA	CRRI	14091	11 KV MAHANADI VIHAR	14091202	GANDHIPALI 1	3232DT240	100	MIXED	AMI	Yes	100%	157	0.12404638	0.09115	0.03289638	26.52%
5645	TPCODL	CUTTACK	CDD-2	MAHANADIVIHA	CRRI	14091	11 KV CRRI	14091203	CRRI 2	3232DT004	250	MIXED	AMI	Yes	100%	26	0.06543448	0.026798	0.03863648	59.05%
5646	TPCODL	CUTTACK	CDD-2	MAHANADIVIHA	CRRI	14091	11 KV CRRI	14091203	CRRI 3 POWER HOUSE	3232DT005	250	MIXED	AMI	Yes	100%	44	0.0804802	0.027152	0.0533282	66.26%
5647	TPCODL	CUTTACK	CDD-2	MAHANADIVIHA	CRRI	14091	11 KV NAYABAZAR	14091204	KESHPUR	3231DT144	500	MIXED	AMI	Yes	100%	314	0.3634824	0.332009	0.0314734	8.66%
5648	TPCODL	CUTTACK	CDD-2	MAHANADIVIHA	CRRI	14091	11 KV NAYABAZAR	14091204	KESH PUR	3231DT146	250	MIXED	AMI	Yes	100%	139	0.2678022	0.111624	0.1561782	58.32%
5649	TPCODL	CUTTACK	CDD-2	MAHANADIVIHA	CRRI	14091	11 KV NAYABAZAR	14091204	BARIKSAHI	3231DT148	250	MIXED	AMI	Yes	67%	143	0.17535864	0.11465	0.06070864	34.62%
5650	TPCODL	CUTTACK	CDD-2	MAHANADIVIHA	CRRI	14091	11 KV NAYABAZAR	14091204	SHANI MANDIR2	3231DT157	250	MIXED	AMI	Yes	67%	111	0.32339432	0.094211	0.22918332	70.87%
5651	TPCODL	CUTTACK	CDD-2	MAHANADIVIHA	CRRI	14091	11 KV NAYABAZAR	14091204	CUTTACK COLLEGE	3231DT158	250	MIXED	AMI	Yes	0%	58	0.13272516	0.086794	0.04593116	34.61%
5652	TPCODL	CUTTACK	CDD-2	MAHANADIVIHA	CRRI	14091	11 KV NAYABAZAR	14091204	BHAGAWATI SAHI	3231DT160	250	MIXED	AMI	Yes	100%	136	0.19724328	0.119727	0.07751628	39.30%
5653	TPCODL	CUTTACK	CDD-2	MAHANADIVIHA	KALYANI NAGAR	14089	11 KV MAHANADI	14089202	MALGODOWN	3112DT138	250	MIXED	AMI	Yes	67%	56	0.10126156	0.063102	0.03815956	37.68%
5654	TPCODL	CUTTACK	CDD-2	MAHANADIVIHA	KALYANI NAGAR	14089	11 KV MAHANADI	14089202	AMUL FACTORY	3231DT207	500	MIXED	AMI	Yes	100%	138	0.11240352	0.086604	0.02579952	22.95%
5655	TPCODL	CUTTACK	CDD-2	MAHANADIVIHA	KALYANI NAGAR	14089	11 KV CHAULIAGANJ-2	14089206	NILADRI VIHAR	3231DT127	100	MIXED	AMI	Yes	100%	7	0.12146592	0.062563	0.05890292	48.49%
5656	TPCODL	CUTTACK	CDD-2	MAHANADIVIHA	KANDARPUR	14093	11 KV ALL INDIA RADIO	14093201	RAJHANH VILLAGE	3224DT042	100	MIXED	AMI	Yes	100%	132	0.09975168	0.073403	0.02634868	26.41%
5657	TPCODL	CUTTACK	CDD-2	MAHANADIVIHA	MAHANADI VIHAR (	14242	11 KV MAHANADI BIHAR	14242201	ADITYA RESIDENCY	3232DT052	250	MIXED	AMI	Yes	100%	21	0.03004968	0.026574	0.00347568	11.57%
5658	TPCODL	CUTTACK	CDD-2	MAHANADIVIHA	MAHANADI VIHAR (	14242	11 KV MAHANADI BIHAR	14242201	PAL BABU	3232DT055	500	MIXED	AMI	Yes	0%	252	0.28990632	0.286439	0.00346732	1.20%
5659	TPCODL	CUTTACK	CDD-2	MAHANADIVIHA	MAHANADI VIHAR (	14242	11 KV MAHANADI BIHAR	14242202	N K DAS(CESU)	3232DT084	250	MIXED	AMI	Yes	0%	101	0.18769572	0.139378	0.04831772	25.74%
5660	TPCODL	CUTTACK	CDD-2	MAHANADIVIHA	MAHANADI VIHAR (	14242	11 KV MAHANADI BIHAR	14242202	CDA MARKET 1	3232DT247	500	MIXED	AMI	Yes	0%	173	0.23710112	0.218722	0.01837912	7.75%
5661	TPCODL	CUTTACK	CDD-2	MAHANADIVIHA	MAHANADI VIHAR (	14242	11 KV MAHANADI BIHAR	14242202	INDIAN BANK	3232DT250	250	MIXED	AMI	Yes	0%	187	0.28271132	0.243988	0.03872332	13.70%
5662	TPCODL	CUTTACK	CDD-2	MAHANADIVIHA	MAHANADI VIHAR (	14242	11 KV SIKHARPUR	14242203	DURGA GHARA	3232DT185	200	MIXED	AMI	Yes	0%	70	0.14103588	0.069594	0.07144188	50.66%
5663	TPCODL	CUTTACK	CDD-2	MAHANADIVIHA	MAHANADI VIHAR (	14242	11 KV GANDARPUR	14242204	RISHI MANDAP	3232DT171	100	MIXED	AMI	Yes	100%	13	0.01147262	0.007155	0.00431762	37.63%
5664	TPCODL	CUTTACK	CDD-2	MAHANADIVIHA	MAHANADI VIHAR (	14242	11 KV GANDARPUR	14242204	GANDARPUR 2	3232DT178	100	MIXED	AMI	Yes	100%	14	0.05658716	0.025109	0.03147816	55.63%
5665	TPCODL	CUTTACK	CDD-2	MAHANADIVIHA	MAHANADI VIHAR (	14242	11 KV GANDARPUR	14242204	SIKHARPUR 6(GADA)	3232DT256	500	MIXED	AMI	Yes	0%	60	0.36311864	0.085061	0.27805764	76.57%
5666	TPCODL	CUTTACK	CDD-2	MAHANADIVIHA	MAHANGA	14097	11 KV CHAINPAL	14097203	pasulanda-2	3513DT002	100	MIXED	AMI	Yes	33%	68	0.02475638	0.01546	0.00929638	37.55%
5667	TPCODL	CUTTACK	CDD-2	MAHANADIVIHA	MATTAGAJAPUR	14211	11 KV POPARADA	14211201	SARTOLA RLY CROSSING	3213DT110	250	MIXED	AMI	Yes	100%	91	0.15419316	0.07407	0.08012316	51.96%
5668	TPCODL	CUTTACK	CDD-2	MAHANADIVIHA	MATTAGAJAPUR	14211	11 KV POPARADA	14211201	CAPEX	3213DT120	500	MIXED	AMI	Yes	0%	254	0.38562528	0.232475	0.15315028	39.71%
5669	TPCODL	CUTTACK	CDD-2	MAHANADIVIHA	MATTAGAJAPUR	14211	11 KV JAICA	14211203	KANTIA 1	3231DT176	100	MIXED	AMI	Yes	0%	81	0.12604438	0.077994	0.04805038	38.12%
5670	TPCODL	CUTTACK	CDD-2	MAHANADIVIHA	OSAP	14368	11 KV DIVINE NAGAR	14368201	DEVINE NAGAR 2	3231DT026	500	MIXED	AMI	Yes	0%	141	0.2656136	0.204213	0.0614006	23.12%
5671	TPCODL	CUTTACK	CDD-2	MAHANADIVIHA	OSAP	14368	11 KV DIVINE NAGAR	14368201	SIDHESWAR2	3231DT029	500	MIXED	AMI	Yes	100%	240	0.30325416	0.279607	0.02364716	7.80%
5672	TPCODL	CUTTACK	CDD-2	MAHANADIVIHA	OSAP	14368	11 KV DIVINE NAGAR	14368201	APARNA NAGAR	3231DT033	250	MIXED	AMI	Yes	0%	134	0.22421212	0.122191	0.10202112	45.50%
5673	TPCODL	CUTTACK	CDD-2	MAHANADIVIHA	OSAP	14368	11 KV DIVINE NAGAR	14368201	KALYAN MANDAP,NAYABAZAR 1	3231DT040	250	MIXED	AMI	Yes	100%	103	0.13905324	0.117316	0.02173724	15.63%
5674	TPCODL	CUTTACK	CDD-2	MAHANADIVIHA	OSAP	14368	11 KV DIVINE NAGAR	14368201	KALYAN MANDAP,NAYABAZAR 2	3231DT041	250	MIXED	AMI	Yes	100%	115	0.20300056	0.132703	0.07029756	34.63%
5675	TPCODL	CUTTACK	CDD-2	MAHANADIVIHA	OSAP	14368	11 KV OSAP	14368202	NEAR CARIER COMPAUND2	3231DT010	250	MIXED	AMI	Yes	100%	62	0.09852184	0.088258	0.01026384	10.42%
5676	TPCODL	CUTTACK	CDD-2	MAHANADIVIHA	OSAP	14368	11 KV OSAP	14368202	JAGANNATH TEMPLE	3231DT022	500	MIXED	AMI	Yes	100%	146	0.20087304	0.137758	0.06311504	31.42%
5677	TPCODL	CUTTACK	CDD-2	MAHANADIVIHA	OSAP	14368	11 KV OSAP	14368202	SAHARSAHI2	3231DT023	250	MIXED	AMI	Yes	100%	85	0.14028496	0.094416	0.04586896	32.70%
5678	TPCODL	CUTTACK	CDD-2	MAHANADIVIHA	OSAP	14368	11 KV OSAP	14368202	DEVINE NAGAR 3	3231DT024	250	MIXED	AMI	Yes	100%	51	0.30887476	0.07482	0.23405476	75.78%
5679	TPCODL	CUTTACK	CDD-2	MAHANADIVIHA	OSAP	14368	11 KV OSAP	14368202	GOVERNMENT COLONY 1	3231DT046	500	MIXED	AMI	Yes	100%	187	0.12032896	0.066645	0.05368396	44.61%
5680	TPCODL	CUTTACK	CDD-2	MAHANADIVIHA	OSAP	14368	11 KV OSAP	14368202	OSAP MAIN GATE	3231DT048	500	MIXED	AMI	Yes	100%	98	0.2480854	0.114649	0.1334364	53.79%
5681	TPCODL	CUTTACK	CDD-2	MAHANADIVIHA	OSAP	14368	11 KV OSAP	14368202	MALBORN	3231DT053	250	MIXED	AMI	Yes	0%	138	0.15217944	0.133475	0.01870444	12.29%
5682	TPCODL	CUTTACK	CDD-2	MAHANADIVIHA	OSAP	14368	11 KV OSAP	14368202	GOVERNMENT COLONY 2	3231DT054	63	MIXED	AMI	Yes	0%	86	0.15629644	0.130968	0.02532844	16.21%
5683	TPCODL	CUTTACK	CDD-2	MAHANADIVIHA	OSAP	14368	11 KV OSAP	14368202	KORAPOKHARI	3232DT121	500	MIXED	AMI	Yes	0%	277	0.35758104	0.308621	0.04896004	13.69%
5684	TPCODL	CUTTACK	CDD-2	MAHANADIVIHA	OSAP	14368	11 KV OSAP	14368202	KUNA VIHAR	3232DT122	250	MIXED	AMI	Yes	0%	300	0.3947408	0.338976	0.0557648	14.13%
5685	TPCODL	CUTTACK	CED	BADACHANA	BALICHANDRAPUR	14109	11 KV BALICHANDRAPUR	14109201	PATRAJPUR	3312DT022	100	MIXED	AMI	Yes	100%	200	0.15359038	0.081823	0.07176738	46.73%
5686	TPCODL	CUTTACK	CED	BADACHANA	BADACHANA	14105	11 KV BADCHANA - BALI	14105201	KALIA INDIAN FAST FOOD	3311DT071	250	MIXED	AMI	Yes	67%	210	0.12260556	0.059105	0.06350056	51.79%
5687	TPCODL	CUTTACK	CED	BADACHANA	BADACHANA	14105	11 KV BADCHANA - BALI	14105201	THAKUR PATANA 2	3311DT074	100	MIXED	AMI	Yes	67%	82	0.0409287	0.021138	0.0197907	48.35%
5688	TPCODL	CUTTACK	CED	BADACHANA	BADACHANA	14105	11 KV BADCHANA - BALI	14105201	SANTIPUR 1	3311DT085	100	MIXED	AMI	Yes	67%	87	0.04555894	0.021617	0.02394194	52.55%
5689	TPCODL	CUTTACK	CED	BADACHANA	BADACHANA	14105	11 KV BADCHANA - BALI	14105201	BAISIMOUJA	3311DT097	500	MIXED	AMI	Yes	67%	174	0.1239644	0.04122	0.0827444	66.75%
5690	TPCODL	CUTTACK	CED	BADACHANA	BADACHANA	14105	11 KV BADCHANA - BALI	14105201	SURKHADAIPUR 1	3311DT103	100	MIXED	AMI	Yes	33%	109	0.09878462	0.021556	0.07722862	78.18%
5691	TPCODL	CUTTACK	CED	BADACHANA	BADACHANA	14105	11 KV BADCHANA - BALI	14105201	KOUDKALA 5	3311DT129	63	MIXED	AMI	Yes	100%	89	0.074031	0.025831	0.0482	65.11%
5692	TPCODL	CUTTACK	CED	BADACHANA	BADACHANA	14105	11 KV BADCHANA - BALI	14105201	ADAKA 4	3311DT164	100	MIXED	AMI	Yes	67%	67	0.03663096	0.020701	0.01592996	43.49%
5693	TPCODL	CUTTACK	CED	BADACHANA	BADACHANA	14105	11 KV BADCHANA - BALI	14105201	BHANDHAPATRAPUR 7	3311DT526	250	MIXED	AMI	Yes	0%	139	0.07268244	0.030711	0.04197144	57.75%

Sl. No.	Zone Name	Circle name	Division name	Name of the Sub-division	Name of the Sub-station	Substation Code	Name of the 11 kV Feeder	Feeder Code	Name of the Location where DT situated	DT code	DT Capacity (kVA)	Predominant consumer type of DT (Domestic/Industrial/Agriculture/Mixed)	Type of metering AMR/AMI/ Communicable/Conventional metered/Unmetered	Status of Meter-whether Functional (Yes/No)	% of data received automatically (if AMR/AMI)	No. of Connected Consumers	Input Energy (MU) (A)	Billed Energy (MU) (B)	Loss (MU) (A-B)	% DT Loss (A-B)/A
5694	TPCODL	CUTTACK	CED	BADACHANA	BADACHANA	14105	11 KV OLD BADACHANA	14105202	KHAIRA 1	3311DT010	100	MIXED	AMI	Yes	67%	78	0.08749626	0.0224	0.06509626	74.40%
5695	TPCODL	CUTTACK	CED	BADACHANA	BADACHANA	14105	11 KV OLD BADACHANA	14105202	KHAIRA VILLAGE 6	3311DT016	100	MIXED	AMI	Yes	67%	132	0.11989496	0.036813	0.08308196	69.30%
5696	TPCODL	CUTTACK	CED	BADACHANA	BADACHANA	14105	11 KV OLD BADACHANA	14105202	NUASASSN	3311DT020	150	MIXED	AMI	Yes	67%	121	0.06176876	0.041677	0.02009176	32.53%
5697	TPCODL	CUTTACK	CED	BADACHANA	BADACHANA	14105	11 KV OLD BADACHANA	14105202	GUTHANI 1	3311DT024	250	MIXED	AMI	Yes	67%	193	0.15037624	0.067047	0.08332924	55.41%
5698	TPCODL	CUTTACK	CED	BADACHANA	BADACHANA	14105	11 KV OLD BADACHANA	14105202	GUTHANI 2	3311DT025	100	MIXED	AMI	Yes	67%	87	0.03875578	0.02424	0.01451578	37.45%
5699	TPCODL	CUTTACK	CED	BADACHANA	BADACHANA	14105	11 KV OLD BADACHANA	14105202	DAGARPADA 2	3311DT054	100	MIXED	AMI	Yes	67%	96	0.0925927	0.02723	0.0653627	70.59%
5700	TPCODL	CUTTACK	CED	BADACHANA	BADACHANA	14105	11 KV OLD BADACHANA	14105202	GOPALPUR	3311DT056	100	MIXED	AMI	Yes	67%	105	0.09875818	0.029174	0.06958418	70.46%
5701	TPCODL	CUTTACK	CED	BADACHANA	BADACHANA	14105	11 KV OLD BADACHANA	14105202	ULLUR-2	3311DT059	100	MIXED	AMI	Yes	67%	60	0.0577281	0.012112	0.0456161	79.02%
5702	TPCODL	CUTTACK	CED	BADACHANA	BADACHANA	14105	11 KV SAKUNTALAPUR	14105203	PAKHERAPUR 1	3311DT456	100	MIXED	AMI	Yes	67%	60	0.05879434	0.013282	0.04551234	77.41%
5703	TPCODL	CUTTACK	CED	BADACHANA	BADACHANA	14105	11 KV SAKUNTALAPUR	14105203	BHUWANPUR 2	3311DT457	100	MIXED	AMI	Yes	33%	66	0.05599059	0.013196	0.04279459	76.43%
5704	TPCODL	CUTTACK	CED	BADACHANA	BADACHANA	14105	11 KV SAKUNTALAPUR	14105203	BADAGHUMARI 2	3311DT463	100	MIXED	AMI	Yes	67%	80	0.07923356	0.021414	0.05781956	72.97%
5705	TPCODL	CUTTACK	CED	BADACHANA	BADACHANA	14105	11 KV SAKUNTALAPUR	14105203	NVWA GAWA 1	3311DT479	100	MIXED	AMI	Yes	67%	106	0.07205726	0.023771	0.04828626	67.01%
5706	TPCODL	CUTTACK	CED	BADACHANA	BADACHANA	14105	11 KV SAKUNTALAPUR	14105203	PURASTAM PUR	3311DT507	100	MIXED	AMI	Yes	67%	60	0.05073618	0.011368	0.03936818	77.59%
5707	TPCODL	CUTTACK	CED	BADACHANA	BADACHANA	14105	11 KV SAKUNTALAPUR	14105203	JAGANNATH PUR 4	3311DT510	100	MIXED	AMI	Yes	67%	118	0.04628163	0.029522	0.01675963	36.21%
5708	TPCODL	CUTTACK	CED	BADACHANA	BADACHANA	14105	11 KV SAKUNTALAPUR	14105203	VIDHIYADHARPUR 4	3311DT515	100	MIXED	AMI	Yes	67%	66	0.06775558	0.02317	0.04458558	65.80%
5709	TPCODL	CUTTACK	CED	BADACHANA	BADACHANA	14105	11 KV CHANDIKHOL	14105204	DHANAMANDAL 1	3311DT348	100	MIXED	AMI	Yes	67%	47	0.0851398	0.026202	0.0589378	69.22%
5710	TPCODL	CUTTACK	CED	BADACHANA	BADACHANA	14105	11 KV CHANDIKHOL	14105204	SHINGUDA VILLAGE 2	3311DT349	250	MIXED	AMI	Yes	33%	120	0.25747076	0.056739	0.20073176	77.96%
5711	TPCODL	CUTTACK	CED	BADACHANA	BADACHANA	14105	11 KV CHANDIKHOL	14105204	KUMAR SAI 1	3311DT353	100	MIXED	AMI	Yes	67%	41	0.06554242	0.019775	0.04576742	69.83%
5712	TPCODL	CUTTACK	CED	BADACHANA	BADACHANA	14105	11 KV CHANDIKHOL	14105204	SHANSAN SHIMBHA 2	3311DT358	250	MIXED	AMI	Yes	0%	147	0.203816	0.063122	0.140694	69.03%
5713	TPCODL	CUTTACK	CED	BADACHANA	BADACHANA	14105	11 KV CHANDIKHOL	14105204	BPL 3	3311DT361	63	MIXED	AMI	Yes	67%	81	0.0828889	0.051137	0.0317519	38.31%
5714	TPCODL	CUTTACK	CED	BADACHANA	BADACHANA	14105	11 KV CHANDIKHOL	14105204	DHANAMANDAL 6	3311DT368	500	MIXED	AMI	Yes	67%	175	0.17286536	0.099671	0.07319436	42.34%
5715	TPCODL	CUTTACK	CED	BADACHANA	BADACHANA	14105	11 KV CHANDIKHOL	14105204	SAI TEMPLE 1	3311DT375	100	MIXED	AMI	Yes	67%	67	0.08463458	0.037276	0.04735858	55.96%
5716	TPCODL	CUTTACK	CED	BADACHANA	BADACHANA	14105	11 KV CHANDIKHOL	14105204	BAUSHA PUTO	3311DT383	100	MIXED	AMI	Yes	67%	12	0.03944424	0.009056	0.03038824	77.04%
5717	TPCODL	CUTTACK	CED	BADACHANA	BADACHANA	14105	11 KV CHANDIKHOL	14105204	BAZAR	3311DT400	500	MIXED	AMI	Yes	67%	94	0.15819152	0.093129	0.06506252	41.13%
5718	TPCODL	CUTTACK	CED	BADACHANA	BADACHANA	14105	11 KV DEULAPUR (LOCAL	14105205	SINGH SAI	3311DT434	100	MIXED	AMI	Yes	67%	41	0.07656268	0.016641	0.05992168	78.26%
5719	TPCODL	CUTTACK	CED	BADACHANA	BADACHANA	14105	11 KV DEULAPUR (LOCAL	14105205	NEAR POLICE STATION 3	3311DT440	250	MIXED	AMI	Yes	67%	68	0.0907364	0.073116	0.0176204	19.42%
5720	TPCODL	CUTTACK	CED	BADACHANA	BADACHANA	14105	11 KV DEULAPUR (LOCAL	14105205	BADACHANA 1	3311DT441	100	MIXED	AMI	Yes	67%	134	0.082716	0.039693	0.043023	52.01%
5721	TPCODL	CUTTACK	CED	BADACHANA	BADACHANA	14105	11 KV DEULAPUR (LOCAL	14105205	BADACHANA 3	3311DT443	250	MIXED	AMI	Yes	67%	135	0.11093664	0.048756	0.06218064	56.05%
5722	TPCODL	CUTTACK	CED	BADACHANA	BADACHANA	14105	11 KV DEULAPUR (LOCAL	14105205	Deulkur	3311DT448	500	MIXED	AMI	Yes	67%	157	0.19646904	0.062842	0.13362704	68.01%
5723	TPCODL	CUTTACK	CED	BADACHANA	BADACHANA	14105	11 KV DEULAPUR (LOCAL	14105205	DEVLAPUR 2	3311DT450	250	MIXED	AMI	Yes	67%	122	0.07244768	0.058986	0.01346168	18.58%
5724	TPCODL	CUTTACK	CED	BADACHANA	BALICHANDRAPUR	14109	11 KV BALICHANDRAPUR	14109201	PATRAJPUR 12	3312DT023	100	MIXED	AMI	Yes	100%	130	0.0819625	0.058739	0.0232235	28.33%
5725	TPCODL	CUTTACK	CED	BADACHANA	BALICHANDRAPUR	14109	11 KV BALICHANDRAPUR	14109201	PATRAJPUR 1	3312DT025	100	MIXED	AMI	Yes	100%	85	0.08529382	0.049304	0.03598982	42.20%
5726	TPCODL	CUTTACK	CED	BADACHANA	BALICHANDRAPUR	14109	11 KV BALICHANDRAPUR	14109201	BALICHANDRAPUR 2	3312DT027	100	MIXED	AMI	Yes	100%	117	0.0839381	0.059335	0.0246031	29.31%
5727	TPCODL	CUTTACK	CED	BADACHANA	BALICHANDRAPUR	14109	11 KV BALICHANDRAPUR	14109201	BALICHANDRAPUR 4	3312DT029	500	MIXED	AMI	Yes	0%	63	0.11551184	0.034021	0.08149084	70.55%
5728	TPCODL	CUTTACK	CED	BADACHANA	BALICHANDRAPUR	14109	11 KV BALICHANDRAPUR	14109201	BALICHANDRAPUR 8	3312DT033	100	MIXED	AMI	Yes	100%	92	0.08767448	0.038824	0.04885048	55.72%
5729	TPCODL	CUTTACK	CED	BADACHANA	BALICHANDRAPUR	14109	11 KV BALICHANDRAPUR	14109201	BALICHANDRAPUR 9	3312DT034	100	MIXED	AMI	Yes	100%	93	0.05572416	0.041703	0.01402116	25.16%
5730	TPCODL	CUTTACK	CED	BADACHANA	BALICHANDRAPUR	14109	11 KV BALICHANDRAPUR	14109201	NADIA SAHASPUR 3	3312DT041	100	MIXED	AMI	Yes	33%	56	0.04915828	0.023399	0.02575928	52.40%
5731	TPCODL	CUTTACK	CED	BADACHANA	BALICHANDRAPUR	14109	11 KV BALICHANDRAPUR	14109201	SAHASPUR 3	3312DT046	100	MIXED	AMI	Yes	100%	45	0.033933	0.014044	0.019889	58.61%
5732	TPCODL	CUTTACK	CED	BADACHANA	BALICHANDRAPUR	14109	11 KV BALICHANDRAPUR	14109201	NANPUR 1	3312DT048	100	MIXED	AMI	Yes	100%	132	0.12909168	0.055586	0.07350568	56.94%
5733	TPCODL	CUTTACK	CED	BADACHANA	BALICHANDRAPUR	14109	11 KV BALICHANDRAPUR	14109201	KUSUPUR 1	3312DT053	100	MIXED	AMI	Yes	100%	79	0.0582707	0.026257	0.0320137	54.94%
5734	TPCODL	CUTTACK	CED	BADACHANA	BALICHANDRAPUR	14109	11 KV BALICHANDRAPUR	14109201	KUSHUPUR 1	3312DT056	100	MIXED	AMI	Yes	100%	59	0.06206834	0.020133	0.04193534	67.56%
5735	TPCODL	CUTTACK	CED	BADACHANA	BALICHANDRAPUR	14109	11 KV BALICHANDRAPUR	14109201	KUSHUPUR 5	3312DT060	100	MIXED	AMI	Yes	100%	57	0.03426912	0.016728	0.01754112	51.19%
5736	TPCODL	CUTTACK	CED	BADACHANA	BALICHANDRAPUR	14109	11 KV BALICHANDRAPUR	14109201	KUSHUPUR 7	3312DT062	100	MIXED	AMI	Yes	100%	96	0.05900724	0.034825	0.02418224	40.98%
5737	TPCODL	CUTTACK	CED	BADACHANA	BALICHANDRAPUR	14109	11 KV BALICHANDRAPUR	14109201	KUSHUPUR 9	3312DT064	250	MIXED	AMI	Yes	67%	82	0.06315764	0.030138	0.03301964	52.28%
5738	TPCODL	CUTTACK	CED	BADACHANA	BALICHANDRAPUR	14109	11 KV CHARINANGALA	14109202	AMBA GAURI 5	3312DT227	100	MIXED	AMI	Yes	100%	67	0.03838102	0.032883	0.00549802	14.32%
5739	TPCODL	CUTTACK	CED	BADACHANA	BALICHANDRAPUR	14109	11 KV CHARINANGALA	14109202	CHARILANGALA 1	3312DT234	100	MIXED	AMI	Yes	100%	51	0.05728232	0.033426	0.02385632	41.65%
5740	TPCODL	CUTTACK	CED	BADACHANA	BALICHANDRAPUR	14109	11 KV CHARINANGALA	14109202	CHARILANGALA 2	3312DT235	100	MIXED	AMI	Yes	100%	40	0.06581712	0.023262	0.04255512	64.66%
5741	TPCODL	CUTTACK	CED	BADACHANA	BALICHANDRAPUR	14109	11 KV CHARINANGALA	14109202	CHARILANGALA 3	3312DT236	100	MIXED	AMI	Yes	100%	44	0.06260708	0.022078	0.04052908	64.74%
5742	TPCODL	CUTTACK	CED	BADACHANA	BALICHANDRAPUR	14109	11 KV CHARINANGALA	14109202	CHARINANGAL TALABAZAR	3312DT243	100	MIXED	AMI	Yes	100%	135	0.13445273	0.076786	0.05766673	42.89%
5743	TPCODL	CUTTACK	CED	BADACHANA	BALICHANDRAPUR	14109	11 KV CHARINANGALA	14109202	CHARILANGALA 13	3312DT246	100	MIXED	AMI	Yes	100%	17	0.03907088	0.009471	0.02959988	75.76%
5744	TPCODL	CUTTACK	CED	BADACHANA	BALICHANDRAPUR	14109	11 KV CHARINANGALA	14109202	CHATABAR	3312DT261	100	MIXED	AMI	Yes	67%	181	0.0750455	0.071334	0.0037115	4.95%
5745	TPCODL	CUTTACK	CED	BADACHANA	BALICHANDRAPUR	14109	11 KV CHARINANGALA	14109202	KALASHREE 4	3312DT264	100	MIXED	AMI	Yes	100%	67	0.03818894	0.016897	0.02129194	55.75%
5746	TPCODL	CUTTACK	CED	BADACHANA	BALICHANDRAPUR	14109	11 KV CHARINANGALA	14109202	GAJENDRAPUR 2	3312DT270	100	MIXED	AMI	Yes	100%	13	0.01067652	0.002877	0.00779952	73.05%
5747	TPCODL	CUTTACK	CED	BADACHANA	BALICHANDRAPUR	14109	11 KV CHARINANGALA	14109202	GAJENDRAPUR	3312DT274	250	MIXED	AMI	Yes	100%	117	0.095244	0.044772	0.050472	52.99%
5748	TPCODL	CUTTACK	CED	BADACHANA	BALICHANDRAPUR	14109	11 KV CHARINANGALA	14109202	TIGIRIA 5	3312DT285	100	MIXED	AMI	Yes	100%	63	0.03628798	0.02788	0.00840798	23.17%
5749	TPCODL	CUTTACK	CED	BADACHANA	BALICHANDRAPUR	14109	11 KV CHARINANGALA	14109202	BALIPADIA	3312DT296	100	MIXED	AMI	Yes	100%	151	0.05496354	0.047133	0.00783054	14.25%
5750	TPCODL	CUTTACK	CED	BADACHANA	BALICHANDRAPUR	14109	11 KV CHARINANGALA	14109202	BALIPADA HP GAS 1	3312DT305	100	MIXED	AMI	Yes	100%	44	0.0521135	0.017529	0.0345845	66.36%
5751	TPCODL	CUTTACK	CED	BADACHANA	BALICHANDRAPUR	14109	11 KV CHARINANGALA	14109202	GOPALPUR 2	3312DT322	250	MIXED	AMI	Yes	100%	81	0.05885748	0.036763	0.02209448	37.54%
5752	TPCODL	CUTTACK	CED	BADACHANA	BALICHANDRAPUR	14109	11 KV CHARINANGALA	14109202	BANAHPUR 2	3312DT351	100	MIXED	AMI	Yes	100%	115	0.06452782	0.027746	0.03678182	57.00%
5753	TPCODL	CUTTACK	CED	BADACHANA	BALICHANDRAPUR	14109	11 KV CHARINANGALA	14109202	BANAHPUR 7	3312DT356	100	MIXED	AMI	Yes	100%	129	0.07513826	0.036845	0.03829326	50.96%
5754	TPCODL	CUTTACK	CED	BADACHANA	BALICHANDRAPUR	14109	11 KV CHARINANGALA	14109202	JHARKULA 3	3312DT376	100	MIXED	AMI	Yes	100%	116	0.04945708	0.047079	0.00237808	4.81%
5755	TPCODL	CUTTACK	CED	BADACHANA	BALICHANDRAPUR	14109	11 KV RUKUTIPATA	14109203	BALICHANDRAPUR MARKET 4	3312DT457	100	MIXED	AMI	Yes	0%	93	0.08928352	0.040828	0.04845552	54.27%
5756	TPCODL	CUTTACK	CED	BADACHANA	BALICHANDRAPUR	14109	11 KV RUKUTIPATA	14109203	RUKUTIPATA 1	3312DT460	100	MIXED	AMI	Yes	100%	98	0.10210052	0.051435	0.05066552	49.62%
5757	TPCODL	CUTTACK	CED	BADACHANA	BALICHANDRAPUR	14109	11 KV RUKUTIPATA	14109203	RUKUTIPATA 5	3312DT466	100	MIXED	AMI	Yes	100%	92	0.09509282	0.026774	0.06831882	71.84%
5758	TPCODL	CUTTACK	CED	BADACHANA	BALICHANDRAPUR	14109	11 KV RUKUTIPATA	14109203	NANPUR 9	3312DT473	100	MIXED	AMI	Yes	0%	81	0.06964304	0.035571	0.03407204	48.92%
5759	TPCODL	CUTTACK	CED	BADACHANA	BALICHANDRAPUR	14109	11 KV RUKUTIPATA	14109203	NANPUR 6	3312DT503	100	MIXED	AMI	Yes	100%	150	0.11708146	0.063693	0.05338846	45.60%
5760	TPCODL	CUTTACK	CED	BADACHANA	BALICHANDRAPUR	14109	11 KV RUKUTIPATA	14109203	PADMALAVPUR 2	3312DT534	100	MIXED	AMI	Yes	67%	154	0.09639157	0.064366	0.03202557	33.22%
5761	TPCODL	CUTTACK	CED	BADACHANA	BALICHANDRAPUR	14109	11 KV MANITRI	14109204	AKARPADA 7	3312DT395	100	MIXED	AMI	Yes	100%	82	0.05642284	0.041699	0.01472384	26.10%
5762	TPCODL	CUTTACK	CED	BADACHANA	BALICHANDRAPUR	14109	11 KV MANITRI	14109204	AKARPADA 11	3312DT399	100	MIXED	AMI	Yes	100%	124	0.07509067	0.050589	0.02450167	32.63%
5763	TPCODL	CUTTACK	CED	BADACHANA	BALICHANDRAPUR	14109	11 KV MANITRI	14109204	PURUSHOTTAM PUR	3312DT404	100	MIXED	AMI	Yes	0%	41	0.04850298	0.01566	0.03284298	67.71%
5764	TPCODL	CUTTACK	CED	BADACHANA	BALICHANDRAPUR	14109	11 KV MANITRI	14109204	LALITAGIRI 3	3312DT406	63	MIXED	AMI	Yes	100%	65	0.03625166	0.021951	0.01430066	39.45%
5765	TPCODL	CUTTACK	CED	BADACHANA	BALICHANDRAPUR	14109	11 KV MANITRI	14109204	SOLARA 4	3312DT416	100	MIXED	AMI	Yes	100%	60	0.03336644	0.032952	0.00041444	1.24%
5766	TPCODL	CUTTACK	CED	BADACHANA	BALICHANDRAPUR	14109	11 KV MANITRI	14109204	MANITRI 1	3312DT433	100	MIXED	AMI	Yes	100%	105	0.10593908	0.043806	0.06213308	58.65%

Sl. No.	Zone Name	Circle name	Division name	Name of the Sub-division	Name of the Sub-station	Substation Code	Name of the 11 kV Feeder	Feeder Code	Name of the Location where DT situated	DT code	DT Capacity (kVA)	Predominant consumer type of DT (Domestic/Industrial/Agriculture/Mixed)	Type of metering AMR/AMI/ Communicable/Conventional metered/Unmetered	Status of Meter-whether Functional (Yes/No)	% of data received automatically (if AMR/AMI)	No. of Connected Consumers	Input Energy (MU) (A)	Billed Energy (MU) (B)	Loss (MU) (A-B)	% DT Loss (A-B)/A
5767	TPCODL	CUTTACK	CED	BADACHANA	BALICHANDRAPUR	14109	11 KV BANDARESWARA	14109205	PATRAJPUR-4	3312DT075	100	MIXED	AMI	Yes	67%	104	0.08971572	0.049669	0.04004672	44.64%
5768	TPCODL	CUTTACK	CED	BADACHANA	BALICHANDRAPUR	14109	11 KV BANDARESWARA	14109205	NALIPUR 4	3312DT091	100	MIXED	AMI	Yes	0%	117	0.17786446	0.064737	0.11312746	63.60%
5769	TPCODL	CUTTACK	CED	BADACHANA	BALICHANDRAPUR	14109	11 KV BANDARESWARA	14109205	MATKATPUR-1	3312DT106	100	MIXED	AMI	Yes	67%	95	0.08374882	0.040589	0.04315982	51.53%
5770	TPCODL	CUTTACK	CED	BADACHANA	BALICHANDRAPUR	14109	11 KV BANDARESWARA	14109205	MAA OLASUNI STONE CARVING	3312DT108	100	MIXED	AMI	Yes	67%	110	0.05285361	0.03589971	0.0169539	32.08%
5771	TPCODL	CUTTACK	CED	BADACHANA	BALICHANDRAPUR	14109	11 KV BANDARESWARA	14109205	BAUJANAGA BEHERA SAHII	3312DT115	100	MIXED	AMI	Yes	67%	69	0.03580192	0.020057	0.01574492	43.98%
5772	TPCODL	CUTTACK	CED	BADACHANA	BALICHANDRAPUR	14109	11 KV BANDARESWARA	14109205	DALAI SAHII 6	3312DT122	100	MIXED	AMI	Yes	67%	92	0.07331106	0.031544	0.04176706	56.97%
5773	TPCODL	CUTTACK	CED	BADACHANA	BALICHANDRAPUR	14109	11 KV BANDARESWARA	14109205	MAHAKALA PADA 3	3312DT149	100	MIXED	AMI	Yes	67%	144	0.06708718	0.031081	0.03600618	53.67%
5774	TPCODL	CUTTACK	CED	BADACHANA	BALICHANDRAPUR	14109	11 KV BANDARESWARA	14109205	PANASUDHA BISWAL SAHII	3312DT159	100	MIXED	AMI	Yes	33%	217	0.1186754	0.063321	0.0553544	46.64%
5775	TPCODL	CUTTACK	CED	BADACHANA	BALICHANDRAPUR	14109	11 KV BANDARESWARA	14109205	PANASUDHA 2	3312DT160	100	MIXED	AMI	Yes	33%	55	0.06293076	0.017828	0.04510276	71.67%
5776	TPCODL	CUTTACK	CED	BADACHANA	BALICHANDRAPUR	14109	11 KV BANDARESWARA	14109205	PARIPALAI 7	3312DT196	100	MIXED	AMI	Yes	67%	67	0.07860526	0.023018	0.05558726	70.72%
5777	TPCODL	CUTTACK	CED	BADACHANA	BALIKUDA	14102	11 KV BARANGA	14102202	DHOBA SAHI	3332DT148	100	MIXED	AMI	Yes	100%	133	0.13223936	0.079422	0.05281736	39.94%
5778	TPCODL	CUTTACK	CED	BADACHANA	BHINGARPUR	14224	11 KV GANGESWAR	14224201	SAI VILA APARTMENT 5	3331DT373	100	MIXED	AMI	Yes	67%	87	0.04332964	0.041621	0.00170864	3.94%
5779	TPCODL	CUTTACK	CED	BADACHANA	CHHATIA	14108	11 KV CHHATIA	14108201	EKANLALIYA VILLAGES	3313DT216	100	MIXED	AMI	Yes	67%	89	0.08609596	0.040718	0.04537796	52.71%
5780	TPCODL	CUTTACK	CED	BADACHANA	CHHATIA	14108	11 KV CHHATIA	14108201	SAPANPU	3313DT218	100	MIXED	AMI	Yes	100%	146	0.06850264	0.043734	0.02476864	36.16%
5781	TPCODL	CUTTACK	CED	BADACHANA	CHHATIA	14108	11 KV CHHATIA	14108201	NANAL SAI	3313DT221	250	MIXED	AMI	Yes	67%	76	0.07309198	0.051963	0.02112898	28.91%
5782	TPCODL	CUTTACK	CED	BADACHANA	CHHATIA	14108	11 KV CHHATIA	14108201	HIGH SCHOOL	3313DT225	100	MIXED	AMI	Yes	67%	124	0.11429636	0.077164	0.03713236	32.49%
5783	TPCODL	CUTTACK	CED	BADACHANA	CHHATIA	14108	11 KV CHHATIA	14108201	PANCHYAT INDISTRIES	3313DT226	100	MIXED	AMI	Yes	67%	76	0.0966462	0.042587	0.0540592	55.94%
5784	TPCODL	CUTTACK	CED	BADACHANA	CHHATIA	14108	11 KV CHHATIA	14108201	PUNYAH ANSA 1	3313DT229	250	MIXED	AMI	Yes	0%	162	0.15901796	0.076174	0.08284396	52.10%
5785	TPCODL	CUTTACK	CED	BADACHANA	CHHATIA	14108	11 KV CHHATIA	14108201	GOPAPUR1	3313DT231	100	MIXED	AMI	Yes	67%	50	0.06459362	0.038001	0.02659262	41.17%
5786	TPCODL	CUTTACK	CED	BADACHANA	CHHATIA	14108	11 KV CHHATIA	14108201	P.P MADDUP	3313DT232	63	MIXED	AMI	Yes	67%	80	0.06241808	0.051683	0.01073508	17.20%
5787	TPCODL	CUTTACK	CED	BADACHANA	CHHATIA	14108	11 KV CHHATIA	14108201	GOPAPUR2	3313DT234	100	MIXED	AMI	Yes	33%	62	0.05513042	0.02106	0.03407042	61.80%
5788	TPCODL	CUTTACK	CED	BADACHANA	CHHATIA	14108	11 KV CHHATIA	14108201	SAHEB NAGAR1	3313DT241	100	MIXED	AMI	Yes	67%	33	0.02340142	0.013299	0.01010242	43.17%
5789	TPCODL	CUTTACK	CED	BADACHANA	CHHATIA	14108	11 KV CHHATIA	14108201	ADEMPUR2	3313DT267	100	MIXED	AMI	Yes	0%	72	0.03809294	0.02015999	0.01793295	47.08%
5790	TPCODL	CUTTACK	CED	BADACHANA	CHHATIA	14108	11 KV CHHATIA	14108201	SCHOOL KE PASS	3323DT001	150	MIXED	AMI	Yes	0%	93	0.14775312	0.03357	0.11418312	77.28%
5791	TPCODL	CUTTACK	CED	BADACHANA	CHHATIA	14108	11 KV BAIREE	14108202	TALASAHI	3313DT011	100	MIXED	AMI	Yes	67%	100	0.07068366	0.028624	0.04205966	59.50%
5792	TPCODL	CUTTACK	CED	BADACHANA	CHHATIA	14108	11 KV BAIREE	14108202	SWAIN SAHI	3313DT017	100	MIXED	AMI	Yes	67%	134	0.07692666	0.051324	0.02560266	33.28%
5793	TPCODL	CUTTACK	CED	BADACHANA	CHHATIA	14108	11 KV BAIREE	14108202	MATHA SAHI	3313DT022	100	MIXED	AMI	Yes	67%	35	0.02821616	0.019093	0.00912316	32.33%
5794	TPCODL	CUTTACK	CED	BADACHANA	CHHATIA	14108	11 KV BAIREE	14108202	TALASAHI TEMPLE	3313DT053	100	MIXED	AMI	Yes	67%	133	0.1086115	0.035256	0.0733555	67.54%
5795	TPCODL	CUTTACK	CED	BADACHANA	CHHATIA	14108	11 KV BAIREE	14108202	PADMALAUPUR SASAN	3313DT070	100	MIXED	AMI	Yes	67%	57	0.0700143	0.025571	0.0444433	63.48%
5796	TPCODL	CUTTACK	CED	BADACHANA	CHHATIA	14108	11 KV CHAMPAPUR	14108203	GUNI SHAHI	3313DT114	100	MIXED	AMI	Yes	0%	77	0.0407357	0.028155	0.0125807	30.88%
5797	TPCODL	CUTTACK	CED	BADACHANA	CHHATIA	14108	11 KV CHAMPAPUR	14108203	CHAMPAPUR	3313DT115	500	MIXED	AMI	Yes	0%	218	0.19232328	0.077076	0.11524728	59.92%
5798	TPCODL	CUTTACK	CED	BADACHANA	CHHATIA	14108	11 KV CHAMPAPUR	14108203	RAUTHA SHAHI	3313DT116	63	MIXED	AMI	Yes	67%	81	0.06325234	0.039825	0.02342734	37.04%
5799	TPCODL	CUTTACK	CED	BADACHANA	CHHATIA	14108	11 KV CHAMPAPUR	14108203	GOTHUMAHUNI-1	3313DT120	100	MIXED	AMI	Yes	67%	70	0.05169422	0.025198	0.02649622	51.26%
5800	TPCODL	CUTTACK	CED	BADACHANA	CHHATIA	14108	11 KV CHAMPAPUR	14108203	CHIDA 1	3313DT130	100	MIXED	AMI	Yes	0%	43	0.04082226	0.010491	0.03033126	74.30%
5801	TPCODL	CUTTACK	CED	BADACHANA	CHHATIA	14108	11 KV CHAMPAPUR	14108203	JASHARAJAPUR	3313DT691	100	MIXED	AMI	Yes	67%	75	0.08418284	0.027178	0.05700484	67.72%
5802	TPCODL	CUTTACK	CED	BADACHANA	CHHATIA	14108	11 KV KADHEI	14108204	CHHATIA	3313DT302	100	MIXED	AMI	Yes	67%	50	0.07350388	0.042409	0.03109488	42.30%
5803	TPCODL	CUTTACK	CED	BADACHANA	CHHATIA	14108	11 KV KADHEI	14108204	PAIKRAPUR4	3313DT306	100	MIXED	AMI	Yes	67%	93	0.1416591	0.059152	0.0825071	58.24%
5804	TPCODL	CUTTACK	CED	BADACHANA	CHHATIA	14108	11 KV KADHEI	14108204	SALAR	3313DT310	100	MIXED	AMI	Yes	67%	29	0.0433093	0.01258	0.0307293	70.95%
5805	TPCODL	CUTTACK	CED	BADACHANA	CHHATIA	14108	11 KV KADHEI	14108204	AMRAWATI PATNA4	3313DT313	100	MIXED	AMI	Yes	67%	55	0.0333128	0.027262	0.0060508	18.16%
5806	TPCODL	CUTTACK	CED	BADACHANA	CHHATIA	14108	11 KV KADHEI	14108204	BIDHYADHARPUR	3313DT316	100	MIXED	AMI	Yes	0%	113	0.15632448	0.053576	0.10274848	65.73%
5807	TPCODL	CUTTACK	CED	BADACHANA	CHHATIA	14108	11 KV KADHEI	14108204	MAA GOJABAYANI TEMPLE	3313DT319	100	MIXED	AMI	Yes	67%	117	0.11052537	0.055804	0.05472137	49.51%
5808	TPCODL	CUTTACK	CED	BADACHANA	CHHATIA	14108	11 KV KADHEI	14108204	KADAI VILLAGE	3313DT327	100	MIXED	AMI	Yes	67%	87	0.07720138	0.032104	0.04509738	58.42%
5809	TPCODL	CUTTACK	CED	BADACHANA	CHHATIA	14108	11 KV KADHEI	14108204	SOLAR2	3313DT343	250	MIXED	AMI	Yes	67%	182	0.15067616	0.04948	0.10119616	67.16%
5810	TPCODL	CUTTACK	CED	BADACHANA	CHHATIA	14108	11 KV KADHEI	14108204	NELIA2	3313DT347	100	MIXED	AMI	Yes	67%	43	0.0911949	0.036687	0.0545079	59.77%
5811	TPCODL	CUTTACK	CED	BADACHANA	CHHATIA	14108	11 KV KADHEI	14108204	NELIA1	3313DT350	100	MIXED	AMI	Yes	67%	83	0.05047066	0.024866	0.02560466	50.73%
5812	TPCODL	CUTTACK	CED	BADACHANA	CHHATIA	14108	11 KV BANDALO (CHHAT	14108205	BANDALO VILLAGE -2	3313DT084	250	MIXED	AMI	Yes	0%	122	0.063184	0.027525	0.035659	56.44%
5813	TPCODL	CUTTACK	CED	BADACHANA	CHHATIA	14108	11 KV BANDALO (CHHAT	14108205	OLAR VILLAGE	3313DT089	100	MIXED	AMI	Yes	0%	82	0.0594502	0.021602	0.0378482	63.66%
5814	TPCODL	CUTTACK	CED	BADACHANA	CHHATIA	14108	11 KV BANDALO (CHHAT	14108205	UPULA 4	3313DT100	250	MIXED	AMI	Yes	100%	96	0.06102336	0.024615	0.03640836	59.66%
5815	TPCODL	CUTTACK	CED	BADACHANA	CHHATIA	14108	11 KV BANDALO (CHHAT	14108205	GANESH-2	3313DT104	100	MIXED	AMI	Yes	67%	23	0.03270548	0.021008	0.01169748	35.77%
5816	TPCODL	CUTTACK	CED	BADACHANA	CHHATISIA	14103	11 KV BANIPADA	14103201	BANIPADA 3	3321DT007	250	MIXED	AMI	Yes	100%	93	0.13902668	0.029964	0.10906268	78.45%
5817	TPCODL	CUTTACK	CED	BADACHANA	DAMODARPUR	14101	11 KV SUNDERGRAM	14101202	BAINLO BAZAR	3333DT244	100	MIXED	AMI	Yes	67%	13	0.00815478	0.007752	0.00040278	4.94%
5818	TPCODL	CUTTACK	CED	BADACHANA	ERAKANA (GOKUNA	14310	11 KV LAXMINARAYANPU	14310201	LAXMINARAYANPUR 1	3511DT228	250	MIXED	AMI	Yes	100%	193	0.116794	0.050438	0.066356	56.81%
5819	TPCODL	CUTTACK	CED	BADACHANA	KAIMATIA ODSSP	14301	11 KV SALAPADA	14301201	HARINA TIKARI 1	3313DT450	100	MIXED	AMI	Yes	67%	85	0.03424425	0.026788	0.00745625	21.77%
5820	TPCODL	CUTTACK	CED	BADACHANA	KAIMATIA ODSSP	14301	11 KV SALAPADA	14301201	BAUNSA MULI 4	3313DT455	100	MIXED	AMI	Yes	0%	74	0.0643606	0.025101	0.0392596	61.00%
5821	TPCODL	CUTTACK	CED	BADACHANA	KAIMATIA ODSSP	14301	11 KV SALAPADA	14301201	SALAPADA VILLAGE 1	3313DT459	100	MIXED	AMI	Yes	0%	111	0.07097686	0.033936	0.03704086	52.19%
5822	TPCODL	CUTTACK	CED	BADACHANA	KAIMATIA ODSSP	14301	11 KV SALAPADA	14301201	SALAPADA 3	3313DT471	250	MIXED	AMI	Yes	67%	93	0.0884842	0.033582	0.0549022	62.05%
5823	TPCODL	CUTTACK	CED	BADACHANA	KAIMATIA ODSSP	14301	11 KV SALAPADA	14301201	SAMYIA 4	3313DT506	500	MIXED	AMI	Yes	67%	219	0.1056052	0.07217	0.0334352	31.66%
5824	TPCODL	CUTTACK	CED	BADACHANA	KAIMATIA ODSSP	14301	11 KV SALAPADA	14301201	TASIL MADIA 2	3313DT562	100	MIXED	AMI	Yes	0%	37	0.00918919	0.002413	0.00677619	73.74%
5825	TPCODL	CUTTACK	CED	BADACHANA	KAIMATIA ODSSP	14301	11 KV LOCAL	14301202	KAIMATIA 1	3313DT434	100	MIXED	AMI	Yes	100%	118	0.06128858	0.039729	0.02155958	35.18%
5826	TPCODL	CUTTACK	CED	BADACHANA	KAIMATIA ODSSP	14301	11 KV BARI THENGADA	14301203	THENGADA 1	3313DT372	250	MIXED	AMI	Yes	100%	102	0.06362996	0.030197	0.03343296	52.54%
5827	TPCODL	CUTTACK	CED	BADACHANA	KAIMATIA ODSSP	14301	11 KV BARI THENGADA	14301203	BATTO 1	3313DT390	100	MIXED	AMI	Yes	100%	105	0.10365314	0.046064	0.05758914	55.56%
5828	TPCODL	CUTTACK	CED	BADACHANA	KAIMATIA ODSSP	14301	11 KV BARI THENGADA	14301203	KAPAS TIKIRI 1	3313DT404	100	MIXED	AMI	Yes	100%	70	0.05076802	0.012311	0.03845702	75.75%
5829	TPCODL	CUTTACK	CED	BADACHANA	KAIMATIA ODSSP	14301	11 KV SIHA	14301204	KHARMANGI 2	3313DT624	100	MIXED	AMI	Yes	67%	250	0.09980704	0.061688	0.03811904	38.19%
5830	TPCODL	CUTTACK	CED	BADACHANA	KAIMATIA ODSSP	14301	11 KV SIHA	14301204	KAMPIRA 4	3313DT641	100	MIXED	AMI	Yes	67%	89	0.04440406	0.017825	0.02657906	59.86%
5831	TPCODL	CUTTACK	CED	BADACHANA	KUNDALA ODSSP	14303	11 KV KADAMPAL	14303203	HARIPUR 4	3311DT184	250	MIXED	AMI	Yes	67%	102	0.10021932	0.021423	0.07879632	78.62%
5832	TPCODL	CUTTACK	CED	BADACHANA	KUNDALA ODSSP	14303	11 KV KADAMPAL	14303203	UDAYNAGAR 2	3311DT216	100	MIXED	AMI	Yes	33%	15	0.01391388	0.005745	0.00816888	58.71%
5833	TPCODL	CUTTACK	CED	BADACHANA	KUNDALA ODSSP	14303	11 KV KADAMPAL	14303203	UDAYNAGAR 4	3311DT218	63	MIXED	AMI	Yes	67%	64	0.03795888	0.018458	0.01950088	51.37%
5834	TPCODL	CUTTACK	CED	BADACHANA	KUNDALA ODSSP	14303	11 KV KADAMPAL	14303203	UDAYNAGAR 5	3311DT277	100	MIXED	AMI	Yes	67%	51	0.06091846	0.025157	0.03576146	58.70%
5835	TPCODL	CUTTACK	CED	BADACHANA	KUNDALA ODSSP	14303	11 KV KADAMPAL	14303203	NOSTA 2	3311DT538	100	MIXED	AMI	Yes	33%	78	0.05477304	0.018423	0.03635004	66.36%
5836	TPCODL	CUTTACK	CED	BADACHANA	KUNDALA ODSSP	14303	11 KV KADAMPAL	14303203	NEAR POND 1	3311DT546	63	MIXED	AMI	Yes	33%	84	0.06451194	0.03049	0.03402194	52.74%
5837	TPCODL	CUTTACK	CED	BADACHANA	KUNDALA ODSSP	14303	11 KV KUNDAL	14303204	GARGALI 3	3311DT172	100	MIXED	AMI	Yes	100%	78	0.0742566	0.045852	0.0284046	38.25%
5838	TPCODL	CUTTACK	CED	BADACHANA	KUNDALA ODSSP	14303	11 KV KUNDAL	14303204	GARGALI 4	3311DT173	250	MIXED	AMI	Yes	100%	113	0.09186432	0.025329	0.06653532	72.43%
5839	TPCODL	CUTTACK	CED	BADACHANA	MAHANGA	14097	11 KV CHAINPAL	14097203	DHARAPUR2	3513DT034	63	MIXED	AMI	Yes	100%	59	0.02685965	0.016523	0.01033665	38.48%

Sl. No.	Zone Name	Circle name	Division name	Name of the Sub-division	Name of the Sub-station	Substation Code	Name of the 11 kV Feeder	Feeder Code	Name of the Location where DT situated	DT code	DT Capacity (kVA)	Predominant consumer type of DT (Domestic/Industrial/Agriculture/Mixed)	Type of metering AMR/AMI/ Communicable/Conventional metered/Unmetered	Status of Meter-whether Functional (Yes/No)	% of data received automatically (if AMR/AMI)	No. of Connected Consumers	Input Energy (MU) (A)	Billed Energy (MU) (B)	Loss (MU) (A-B)	% DT Loss (A-B)/A
5840	TPCODL	CUTTACK	CED	BADACHANA	TANGI	14107	11 kV BHATTIMUNDA	14107202	GOVINPUR 1	3323DT153	250	MIXED	AMI	Yes	0%	92	0.10210948	0.043332	0.05877748	57.56%
5841	TPCODL	CUTTACK	CED	BADACHANA	TANGI	14107	11 KV GOBINDPUR-2	14107204	BAINCHUA-1	3323DT647	100	MIXED	AMI	Yes	100%	36	0.0488625	0.019442	0.0294205	60.21%
5842	TPCODL	CUTTACK	CED	CHOUDWAR	CHOUDWAR	14184	11 kV CITY BARRAGE	14184201	KADAPADA	3322DT092	250	MIXED	AMI	Yes	100%	82	0.0857676	0.025162	0.0606056	70.66%
5843	TPCODL	CUTTACK	CED	CHOUDWAR	CHOUDWAR	17018	33 kV IDCO/CITY	17018406	SALAGAON 1	3323DT692	100	MIXED	AMI	Yes	0%	37	0.12560516	0.031877066	0.093728094	74.62%
5844	TPCODL	CUTTACK	CED	CHOUDWAR	CHOUDWAR	17018	33 kV TANGI	17018402	33/11 kV TANGI SS DT	3323DT731	100	MIXED	AMI	Yes	100%	1	0.00565992	0.00566	-8E-08	0.00%
5845	TPCODL	CUTTACK	CED	CHOUDWAR	TANGI	14107	33 KV MAIN INCOMER	14107401	BAINCHUA VILLAGE	3323DT721	250	MIXED	AMI	Yes	100%	35	0.07835266	0.017863	0.06048966	77.20%
5846	TPCODL	CUTTACK	CED	CHOUDWAR	ADASPUR	14104	11 KV ADASPUR	14104201	ADASPUR HOSPITAL-1	3331DT029	250	MIXED	AMI	Yes	0%	59	0.076328	0.05284	0.023488	30.77%
5847	TPCODL	CUTTACK	CED	CHOUDWAR	ASURESWAR ODSSP	14311	11 KV SUKARPADA	14311201	KENDILO 1	3521DT060	100	MIXED	AMI	Yes	100%	33	0.03709062	0.011937	0.02515362	67.82%
5848	TPCODL	CUTTACK	CED	CHOUDWAR	BALICHANDRAPUR	14109	11 KV BALICHANDRAPUR	14109201	NANPUR 7	3312DT067	100	MIXED	AMI	Yes	100%	95	0.07427952	0.035258	0.03902152	52.53%
5849	TPCODL	CUTTACK	CED	CHOUDWAR	BALICHANDRAPUR	14109	11 KV CHARINANGALA	14109202	KHADAGPUR 4	3312DT277	100	MIXED	AMI	Yes	100%	108	0.074114	0.038614	0.0355	47.90%
5850	TPCODL	CUTTACK	CED	CHOUDWAR	CHHATIA	14108	11 KV CHHATIA	14108201	NALIKUL	3313DT273	100	MIXED	AMI	Yes	0%	74	0.0462429	0.025406	0.0208369	45.06%
5851	TPCODL	CUTTACK	CED	CHOUDWAR	CHHATISIA	14103	11 KV BANIPADA	14103201	CHANGUNIA 2	3321DT004	63	MIXED	AMI	Yes	100%	28	0.04315627	0.011723	0.03143327	72.84%
5852	TPCODL	CUTTACK	CED	CHOUDWAR	CHHATISIA	14103	11 KV BANIPADA	14103201	BANIPADA 4	3321DT008	250	MIXED	AMI	Yes	100%	61	0.13011664	0.031775	0.09834164	75.58%
5853	TPCODL	CUTTACK	CED	CHOUDWAR	CHHATISIA	14103	11 KV BANIPADA	14103201	BANIPADABANDALA 1	3321DT010	100	MIXED	AMI	Yes	100%	56	0.06871736	0.017866	0.05085136	74.00%
5854	TPCODL	CUTTACK	CED	CHOUDWAR	CHHATISIA	14103	11 KV INDUSTRIAL	14103202	RYSONS	3322DT098	100	MIXED	AMI	Yes	100%	7	0.0504481	0.045709	0.0047391	9.39%
5855	TPCODL	CUTTACK	CED	CHOUDWAR	CHHATISIA	14103	11 KV INDUSTRIAL	14103202	PERSONAL	3322DT110	100	MIXED	AMI	Yes	100%	28	0.11663952	0.03362	0.08301952	71.18%
5856	TPCODL	CUTTACK	CED	CHOUDWAR	CHHATISIA	14103	11 KV INDUSTRIAL	14103202	PULSE CLINIC	3322DT120	100	MIXED	AMI	Yes	100%	37	0.0502279	0.027466	0.0227619	45.32%
5857	TPCODL	CUTTACK	CED	CHOUDWAR	CHHATISIA	14103	11 KV INDUSTRIAL	14103202	LAXMINARAYAN PUR	3322DT122	500	MIXED	AMI	Yes	100%	118	0.17246312	0.125824	0.04663912	27.04%
5858	TPCODL	CUTTACK	CED	CHOUDWAR	CHHATISIA	14103	11 KV INDUSTRIAL	14103202	GOPALPUR	3322DT131	500	MIXED	AMI	Yes	100%	85	0.1066964	0.085706	0.0209904	19.67%
5859	TPCODL	CUTTACK	CED	CHOUDWAR	CHHATISIA	14103	11 KV INDUSTRIAL	14103202	SAW MILL 1	3322DT152	250	MIXED	AMI	Yes	0%	10	0.05363264	0.034573	0.01905964	35.54%
5860	TPCODL	CUTTACK	CED	CHOUDWAR	CHHATISIA	14103	11 KV INDUSTRIAL	14103202	SAW MILL 2	3322DT153	250	MIXED	AMI	Yes	0%	11	0.07847256	0.047256	0.03121656	39.78%
5861	TPCODL	CUTTACK	CED	CHOUDWAR	CHHATISIA	14103	11 KV KUSPANGI	14103203	KAJALKANA TELENGABASTI	3322DT158	63	MIXED	AMI	Yes	100%	17	0.0218994	0.011355	0.0105444	48.15%
5862	TPCODL	CUTTACK	CED	CHOUDWAR	CHHATISIA	14103	11 KV KUSPANGI	14103203	AMIYA FARM HOUSE	3322DT165	250	MIXED	AMI	Yes	100%	10	0.04019588	0.029277	0.01091888	27.16%
5863	TPCODL	CUTTACK	CED	CHOUDWAR	CHHATISIA	14103	11 KV KUSPANGI	14103203	PUSPANGI	3322DT171	250	MIXED	AMI	Yes	67%	131	0.10037184	0.056938	0.04343384	43.27%
5864	TPCODL	CUTTACK	CED	CHOUDWAR	CHHATISIA	14103	11 KV KUSPANGI	14103203	BHAGABAN BISWAL	3322DT181	250	MIXED	AMI	Yes	67%	130	0.10871582	0.070885	0.03783082	34.80%
5865	TPCODL	CUTTACK	CED	CHOUDWAR	CHHATISIA	14103	11 KV KUSPANGI	14103203	NUA PATNA	3322DT193	63	MIXED	AMI	Yes	67%	42	0.06913704	0.059886	0.00925104	13.38%
5866	TPCODL	CUTTACK	CED	CHOUDWAR	CHHATISIA	14103	11 KV KUSPANGI	14103203	PRATIVA ROY	3322DT206	100	MIXED	AMI	Yes	67%	13	0.03277212	0.021716	0.01105612	33.74%
5867	TPCODL	CUTTACK	CED	CHOUDWAR	CHHATISIA	14103	11 KV KUSPANGI	14103203	BAKLA VILLAGE	3322DT207	100	MIXED	AMI	Yes	67%	42	0.033364	0.022264	0.0111	33.27%
5868	TPCODL	CUTTACK	CED	CHOUDWAR	CHOUDWAR	14184	11 KV CITY BARRAGE	14184201	MANDAPADA	3322DT030	250	MIXED	AMI	Yes	100%	72	0.12755284	0.058407	0.06914584	54.21%
5869	TPCODL	CUTTACK	CED	CHOUDWAR	CHOUDWAR	14184	11 KV CITY BARRAGE	14184201	PAIKEREPUR	3322DT036	250	MIXED	AMI	Yes	100%	189	0.15181676	0.09641	0.05540676	36.50%
5870	TPCODL	CUTTACK	CED	CHOUDWAR	CHOUDWAR	14184	11 KV CITY BARRAGE	14184201	PAIKEREPUR 2	3322DT038	100	MIXED	AMI	Yes	100%	46	0.10069306	0.02137931	0.07931375	78.77%
5871	TPCODL	CUTTACK	CED	CHOUDWAR	CHOUDWAR	14184	11 KV CITY BARRAGE	14184201	PAEKARPUR 3	3322DT039	100	MIXED	AMI	Yes	100%	99	0.09038632	0.030354	0.06003232	66.42%
5872	TPCODL	CUTTACK	CED	CHOUDWAR	CHOUDWAR	14184	11 KV CITY BARRAGE	14184201	CHARIGRIYA 2	3322DT042	100	MIXED	AMI	Yes	0%	83	0.10522188	0.071606	0.03361588	31.95%
5873	TPCODL	CUTTACK	CED	CHOUDWAR	CHOUDWAR	14184	11 KV CITY BARRAGE	14184201	DOULATABAD	3322DT044	500	MIXED	AMI	Yes	0%	96	0.09029816	0.0581	0.03219816	35.66%
5874	TPCODL	CUTTACK	CED	CHOUDWAR	CHOUDWAR	14184	11 KV CITY BARRAGE	14184201	CHITLESWER	3322DT054	250	MIXED	AMI	Yes	67%	238	0.17706484	0.119372	0.05769284	32.58%
5875	TPCODL	CUTTACK	CED	CHOUDWAR	CHOUDWAR	14184	11 KV CITY BARRAGE	14184201	ENDRA PATNA 1	3322DT060	100	MIXED	AMI	Yes	0%	125	0.08748352	0.055907	0.03157652	36.09%
5876	TPCODL	CUTTACK	CED	CHOUDWAR	CHOUDWAR	14184	11 KV CITY BARRAGE	14184201	CHASPADA	3322DT068	250	MIXED	AMI	Yes	0%	277	0.17744648	0.119783	0.05766348	32.50%
5877	TPCODL	CUTTACK	CED	CHOUDWAR	CHOUDWAR	14184	11 KV CITY BARRAGE	14184201	SIMIDIHAN 3	3322DT083	100	MIXED	AMI	Yes	100%	168	0.09436854	0.061849	0.03251954	34.46%
5878	TPCODL	CUTTACK	CED	CHOUDWAR	CHOUDWAR	14184	11 KV CITY BARRAGE	14184201	SIMIDIHAN 5	3322DT085	100	MIXED	AMI	Yes	100%	162	0.1162713	0.064414	0.0518573	44.60%
5879	TPCODL	CUTTACK	CED	CHOUDWAR	CHOUDWAR	14184	11 KV CITY BARRAGE	14184201	SIMIDIHAN 8	3322DT088	100	MIXED	AMI	Yes	100%	168	0.12008114	0.069527	0.05055414	42.10%
5880	TPCODL	CUTTACK	CED	CHOUDWAR	CHOUDWAR	14184	11 KV CITY BARRAGE	14184201	KAYALPADA	3322DT090	100	MIXED	AMI	Yes	100%	104	0.08984202	0.042944	0.04689802	52.20%
5881	TPCODL	CUTTACK	CED	CHOUDWAR	CHOUDWAR	14184	11 KV CHOUDWAR	14184202	YATRA PRDIA	3322DT022	500	MIXED	AMI	Yes	100%	137	0.14230528	0.094709	0.04759628	33.45%
5882	TPCODL	CUTTACK	CED	CHOUDWAR	CHOUDWAR	14184	11 KV CHOUDWAR	14184202	BEURA SHAHI	3322DT023	250	MIXED	AMI	Yes	100%	37	0.20650792	0.048254	0.15825392	76.63%
5883	TPCODL	CUTTACK	CED	CHOUDWAR	CHOUDWAR	14184	11 KV CHOUDWAR	14184202	MAHAZAN SHAHI	3322DT024	500	MIXED	AMI	Yes	100%	275	0.20258984	0.199662	0.00292784	1.45%
5884	TPCODL	CUTTACK	CED	CHOUDWAR	CHOUDWAR	14184	11 KV ARC	14184203	MV WORK SHOP 250KVA	3321DT255	250	MIXED	AMI	Yes	100%	23	0.04363588	0.010598	0.03303788	75.71%
5885	TPCODL	CUTTACK	CED	CHOUDWAR	CHOUDWAR	14184	11 KV ARC	14184203	4R2	3321DT257	250	MIXED	AMI	Yes	100%	111	0.07882348	0.062501	0.01632248	20.71%
5886	TPCODL	CUTTACK	CED	CHOUDWAR	CHOUDWAR	14184	11 KV ARC	14184203	SIBHANI MANDIR1	3322DT311	250	MIXED	AMI	Yes	0%	68	0.12951344	0.048279	0.08123444	62.72%
5887	TPCODL	CUTTACK	CED	CHOUDWAR	CHOUDWAR	14184	11 KV ARC	14184203	SIBHANI MANDIR2	3322DT312	250	MIXED	AMI	Yes	100%	107	0.20059956	0.070293	0.13030656	64.96%
5888	TPCODL	CUTTACK	CED	CHOUDWAR	CHOUDWAR	14184	11 KV OTM	14184204	SHISHUMANDIR	3322DT269	250	MIXED	AMI	Yes	100%	107	0.1621016	0.14189	0.0202116	12.47%
5889	TPCODL	CUTTACK	CED	CHOUDWAR	CHOUDWAR	14184	11 KV OTM	14184204	TOWER 1	3322DT272	100	MIXED	AMI	Yes	100%	57	0.07513086	0.039585	0.03554586	47.31%
5890	TPCODL	CUTTACK	CED	CHOUDWAR	CHOUDWAR	14184	11 KV OTM	14184204	ITI 1	3322DT277	250	MIXED	AMI	Yes	100%	332	0.25650408	0.157801	0.09870308	38.48%
5891	TPCODL	CUTTACK	CED	CHOUDWAR	CHOUDWAR	14184	11 KV OTM	14184204	TEMPLE 2	3322DT280	250	MIXED	AMI	Yes	100%	162	0.15145052	0.134288	0.01716252	11.33%
5892	TPCODL	CUTTACK	CED	CHOUDWAR	CHOUDWAR	14184	11 KV OTM	14184204	STAFF COLONY	3322DT298	100	MIXED	AMI	Yes	100%	6	0.0698354	0.014512	0.0553234	79.22%
5893	TPCODL	CUTTACK	CED	CHOUDWAR	CHOUDWAR	14184	11 KV OTM	14184204	TEMPLE 3	3322DT302	250	MIXED	AMI	Yes	100%	36	0.0574058	0.025505	0.0319008	55.57%
5894	TPCODL	CUTTACK	CED	CHOUDWAR	CHOUDWAR	14184	11 KV OTM	14184204	JAYANTA NAGAR	3322DT307	250	MIXED	AMI	Yes	0%	112	0.0757724	0.058576	0.0171964	22.69%
5895	TPCODL	CUTTACK	CED	CHOUDWAR	CHOUDWAR	14184	11 KV OTM	14184204	OTM COLONY	3322DT308	250	MIXED	AMI	Yes	0%	26	0.03177172	0.006592	0.02517972	79.25%
5896	TPCODL	CUTTACK	CED	CHOUDWAR	CHOUDWAR	14184	11 KV OTM	14184204	LIVERA 2	3323DT071	250	MIXED	AMI	Yes	67%	18	0.06918016	0.059437	0.00974316	14.08%
5897	TPCODL	CUTTACK	CED	CHOUDWAR	CHOUDWAR	14184	11 KV OTM	14184204	RASMI PETROL PUMP 2	3323DT533	500	MIXED	AMI	Yes	100%	48	0.20917008	0.084286	0.12488408	59.70%
5898	TPCODL	CUTTACK	CED	CHOUDWAR	CHOUDWAR	14184	11 KV OTM	14184204	MANGULI	3323DT536	500	MIXED	AMI	Yes	100%	242	0.20985608	0.200628	0.00922808	4.40%
5899	TPCODL	CUTTACK	CED	CHOUDWAR	CHOUDWAR	14184	11 KV LOCAL	14184205	KAPILESWAR-1	3322DT228	200	MIXED	AMI	Yes	33%	19	0.08571468	0.033483	0.05223168	60.94%
5900	TPCODL	CUTTACK	CED	CHOUDWAR	CHOUDWAR	14184	11 KV LOCAL	14184205	KAPILESWAR-3	3322DT229	250	MIXED	AMI	Yes	100%	89	0.17303676	0.076525	0.09651176	55.78%
5901	TPCODL	CUTTACK	CED	CHOUDWAR	CHOUDWAR	14184	11 KV LOCAL	14184205	KAPILESWAR-2	3322DT230	250	MIXED	AMI	Yes	100%	90	0.0849887	0.083115	0.0018737	2.20%
5902	TPCODL	CUTTACK	CED	CHOUDWAR	CHOUDWAR	14184	11 KV LOCAL	14184205	KALINGA NAGAR	3322DT244	250	MIXED	AMI	Yes	100%	88	0.09271732	0.075369	0.01734832	18.71%
5903	TPCODL	CUTTACK	CED	CHOUDWAR	CHOUDWAR	14184	11 KV LOCAL	14184205	NUASAHI	3322DT246	500	MIXED	AMI	Yes	0%	203	0.19754952	0.165721	0.03182852	16.11%
5904	TPCODL	CUTTACK	CED	CHOUDWAR	CHOUDWAR	14184	11 KV LOCAL	14184205	MANGLA TEMPLE 1	3322DT247	250	MIXED	AMI	Yes	100%	150	0.11811434	0.113837	0.00427734	3.62%
5905	TPCODL	CUTTACK	CED	CHOUDWAR	CHOUDWAR	14184	11 KV LOCAL	14184205	MANGLA TEMPLE 2	3322DT248	100	MIXED	AMI	Yes	0%	30	0.05402332	0.024246	0.02977732	55.12%
5906	TPCODL	CUTTACK	CED	CHOUDWAR	CHOUDWAR	14184	11 KV LOCAL	14184205	BANGLA SAHI	3322DT249	250	MIXED	AMI	Yes	100%	233	0.1843968	0.169615	0.0147818	8.02%
5907	TPCODL	CUTTACK	CED	CHOUDWAR	CHOUDWAR	14184	11 KV LOCAL	14184205	BRAMHAN SAHI 3	3322DT264	250	MIXED	AMI	Yes	100%	122	0.22495476	0.08065	0.14430476	64.15%
5908	TPCODL	CUTTACK	CED	CHOUDWAR	CHOUDWAR	14184	11 KV NUNTIKIRI	14184206	ALARPUR 1	3323DT027	100	MIXED	AMI	Yes	100%	72	0.07540164	0.036328	0.03907364	51.82%
5909	TPCODL	CUTTACK	CED	CHOUDWAR	CHOUDWAR	14184	11 KV NUNTIKIRI	14184206	GOUDASAN NICGANDI 2	3323DT033	100	MIXED	AMI	Yes	100%	76	0.061967	0.032259	0.029708	47.94%
5910	TPCODL	CUTTACK	CED	CHOUDWAR	CHOUDWAR	14184	11 KV NUNTIKIRI	14184206	TERUA RAILSTATION 1	3323DT045	63	MIXED	AMI	Yes	100%	91	0.05405336	0.048448	0.00560536	10.37%
5911	TPCODL	CUTTACK	CED	CHOUDWAR	CHOUDWAR	14184	11 KV NUNTIKIRI	14184206	TERUA RAILSTATION 2	3323DT046	100	MIXED	AMI	Yes	100%	40	0.0349613	0.023478	0.0114833	32.85%
5912	TPCODL	CUTTACK	CED	CHOUDWAR	CHOUDWAR	14184	11 KV NUNTIKIRI	14184206	DAGARASAHI	3323DT049	100	MIXED	AMI	Yes	100%	54	0.05794232	0.038933	0.01900932	32.81%

Sl. No.	Zone Name	Circle name	Division name	Name of the Sub-division	Name of the Sub-station	Substation Code	Name of the 11 kV Feeder	Feeder Code	Name of the Location where DT situated	DT code	DT Capacity (kVA)	Predominant consumer type of DT (Domestic/Industrial/Agriculture/Mixed)	Type of metering AMR/AMI/ Communicable/Conventional metered/Unmetered	Status of Meter-whether Functional (Yes/No)	% of data received automatically (if AMR/AMI)	No. of Connected Consumers	Input Energy (MU) (A)	Billed Energy (MU) (B)	Loss (MU) (A-B)	% DT Loss (A-B)/A
5913	TPCODL	CUTTACK	CED	CHOUDWAR	CHOUDWAR	14184	11 KV CHARBATIA KALIN	14184207	ESI COLONY	3321DT058	250	MIXED	AMI	Yes	100%	65	0.0240084	0.015839	0.0081694	34.03%
5914	TPCODL	CUTTACK	CED	CHOUDWAR	CHOUDWAR	14184	11 KV CHARBATIA KALIN	14184207	IN FRONT LABOR OFFICE 2	3321DT061	100	MIXED	AMI	Yes	0%	39	0.04201696	0.034843	0.00717396	17.07%
5915	TPCODL	CUTTACK	CED	CHOUDWAR	CHOUDWAR	14184	11 KV CHARBATIA KALIN	14184207	GAYATRI PITHA	3321DT065	250	MIXED	AMI	Yes	0%	107	0.11824888	0.068223	0.05002588	42.31%
5916	TPCODL	CUTTACK	CED	CHOUDWAR	CHOUDWAR	14184	11 KV CHARBATIA KALIN	14184207	NEAR NEW MANGAL TEMPLE	3321DT068	100	MIXED	AMI	Yes	100%	72	0.08248734	0.063485	0.01900234	23.04%
5917	TPCODL	CUTTACK	CED	CHOUDWAR	CHOUDWAR	14184	11 KV CHARBATIA KALIN	14184207	NEAR TEMPLE	3321DT069	100	MIXED	AMI	Yes	0%	91	0.093522	0.06912	0.024402	26.09%
5918	TPCODL	CUTTACK	CED	CHOUDWAR	CHOUDWAR	14184	11 KV CHARBATIA KALIN	14184207	BATA GUDI COLONY	3321DT071	100	MIXED	AMI	Yes	100%	46	0.05006726	0.03428	0.01578726	31.53%
5919	TPCODL	CUTTACK	CED	CHOUDWAR	CHOUDWAR	14184	11 KV CHARBATIA KALIN	14184207	BATAGUDI	3321DT073	100	MIXED	AMI	Yes	0%	97	0.0963869	0.082216	0.0141709	14.70%
5920	TPCODL	CUTTACK	CED	CHOUDWAR	CHOUDWAR	14184	11 KV CHARBATIA KALIN	14184207	JAJA BHAIRAB NUAGAN 2	3321DT078	100	MIXED	AMI	Yes	100%	48	0.06041072	0.025302	0.03510872	58.12%
5921	TPCODL	CUTTACK	CED	CHOUDWAR	CHOUDWAR	14184	11 KV CHARBATIA KALIN	14184207	BUDAHALINGA 1	3321DT082	100	MIXED	AMI	Yes	0%	55	0.0613144	0.036859	0.0244554	39.89%
5922	TPCODL	CUTTACK	CED	CHOUDWAR	CHOUDWAR	14184	11 KV CHARBATIA KALIN	14184207	BUDHALINGA 2	3321DT083	100	MIXED	AMI	Yes	100%	87	0.05458018	0.04445	0.01013018	18.56%
5923	TPCODL	CUTTACK	CED	CHOUDWAR	CHOUDWAR	14184	11 KV CHARBATIA KALIN	14184207	SHREE VIHAR	3321DT084	100	MIXED	AMI	Yes	100%	93	0.10968995	0.085006	0.02468395	22.50%
5924	TPCODL	CUTTACK	CED	CHOUDWAR	CHOUDWAR	14184	11 KV CHARBATIA KALIN	14184207	HAUSING BORD PHASE 2	3321DT086	250	MIXED	AMI	Yes	100%	105	0.12470712	0.079029	0.04567812	36.63%
5925	TPCODL	CUTTACK	CED	CHOUDWAR	CHOUDWAR	14184	11 KV CHARBATIA KALIN	14184207	HAUSING BOARD PHASE 2	3321DT087	500	MIXED	AMI	Yes	0%	103	0.1113828	0.0634	0.0479828	43.08%
5926	TPCODL	CUTTACK	CED	CHOUDWAR	CHOUDWAR	14184	11 KV CHARBATIA KALIN	14184207	NEAR MAHIMA PALACE	3321DT089	100	MIXED	AMI	Yes	0%	16	0.0413005	0.021272	0.0200285	48.49%
5927	TPCODL	CUTTACK	CED	CHOUDWAR	CHOUDWAR	14184	11 KV CHARBATIA KALIN	14184207	B. COLONY 1	3321DT094	250	MIXED	AMI	Yes	100%	154	0.14532816	0.117598	0.02773016	19.08%
5928	TPCODL	CUTTACK	CED	CHOUDWAR	CHOUDWAR	14184	11 KV CHARBATIA KALIN	14184207	FOREST	3321DT111	63	MIXED	AMI	Yes	33%	43	0.0473028	0.021269	0.0260338	55.04%
5929	TPCODL	CUTTACK	CED	CHOUDWAR	CHOUDWAR	14184	11 KV CHARBATIA KALIN	14184207	MANGAL PUR NEW COLONY	3321DT112	100	MIXED	AMI	Yes	100%	45	0.03989134	0.027418	0.01247334	31.27%
5930	TPCODL	CUTTACK	CED	CHOUDWAR	CHOUDWAR	14184	11 KV CHARBATIA KALIN	14184207	AGRAHAT TARINI TEMPLE	3321DT115	100	MIXED	AMI	Yes	100%	90	0.09213944	0.050688	0.04145144	44.99%
5931	TPCODL	CUTTACK	CED	CHOUDWAR	CHOUDWAR	14184	11 KV CHARBATIA KALIN	14184207	AGRA HAT PARIDA SAHI 1	3321DT123	250	MIXED	AMI	Yes	100%	136	0.12150968	0.074853	0.04665668	38.40%
5932	TPCODL	CUTTACK	CED	CHOUDWAR	CHOUDWAR	14184	11 KV CHARBATIA KALIN	14184207	AGRA HAT PARIDA SAHI 2	3321DT124	250	MIXED	AMI	Yes	100%	122	0.14430128	0.083307	0.06099428	42.27%
5933	TPCODL	CUTTACK	CED	CHOUDWAR	CHOUDWAR	14184	11 KV CHARBATIA KALIN	14184207	BIJU PATNAYAK PARK	3321DT126	250	MIXED	AMI	Yes	100%	111	0.12539212	0.052577	0.07281512	58.07%
5934	TPCODL	CUTTACK	CED	CHOUDWAR	CHOUDWAR	14184	11 KV CHARBATIA KALIN	14184207	INFRONT BIRAT CTC SCHOOL 2	3321DT128	250	MIXED	AMI	Yes	100%	33	0.05649236	0.017555	0.03893736	68.93%
5935	TPCODL	CUTTACK	CED	CHOUDWAR	CHOUDWAR	14184	11 KV CHARBATIA KALIN	14184207	UMSL GATE	3321DT134	100	MIXED	AMI	Yes	0%	102	0.1021209	0.076761	0.0253599	24.83%
5936	TPCODL	CUTTACK	CED	CHOUDWAR	JAGATPUR (IPICOL)	14241	11 KV NEW INDUSTRIAL	14241202	HIRA PLUS	3222DT102	250	MIXED	AMI	Yes	100%	13	0.1043886	0.05571	0.0486786	46.63%
5937	TPCODL	CUTTACK	CED	CHOUDWAR	KAJALPUR ODSSP	14299	11 KV NAHALPUR	14299201	BANKESWAR 3	3333DT197	100	MIXED	AMI	Yes	100%	73	0.04278568	0.0217	0.02108568	49.28%
5938	TPCODL	CUTTACK	CED	CHOUDWAR	KASARDA	14220	11 KV SITHALO	14220204	KUMARKULA 1	3343DT381	100	MIXED	AMI	Yes	0%	119	0.06756424	0.017397	0.05016724	74.25%
5939	TPCODL	CUTTACK	CED	CHOUDWAR	ORIKANTA	14212	11 KV BILAHATA	14212202	BHUYAN SAHI 2	3523DT028	100	MIXED	AMI	Yes	100%	41	0.04733354	0.016614	0.03071954	64.90%
5940	TPCODL	CUTTACK	CED	CHOUDWAR	PRATAP NAGARI (DA	14298	11KV PRATAP NAGARI	14298202	NIUAPATANA VILLAGE 1	3332DT274	100	MIXED	AMI	Yes	100%	72	0.14711266	0.032994	0.11411866	77.57%
5941	TPCODL	CUTTACK	CED	CHOUDWAR	SANKARPUR ODSSP	14233	11 KV SANKARPUR	14233201	BEGUNIA SAHI	3321DT200	100	MIXED	AMI	Yes	0%	109	0.10013082	0.079028	0.02110282	21.08%
5942	TPCODL	CUTTACK	CED	CHOUDWAR	SANKARPUR ODSSP	14233	11 KV SANKARPUR	14233201	JAGANNATH	3321DT215	250	MIXED	AMI	Yes	67%	178	0.17772764	0.070346	0.10738164	60.42%
5943	TPCODL	CUTTACK	CED	CHOUDWAR	SANKARPUR ODSSP	14233	11 KV SANKARPUR	14233201	MAJHI SAHI-2	3321DT218	250	MIXED	AMI	Yes	100%	71	0.14415432	0.029019	0.11513532	79.87%
5944	TPCODL	CUTTACK	CED	CHOUDWAR	SANKARPUR ODSSP	14233	11 KV SANKARPUR	14233201	BADA SAMANTAPUR NEW	3321DT226	500	MIXED	AMI	Yes	0%	43	0.04265536	0.015391	0.02726436	63.92%
5945	TPCODL	CUTTACK	CED	CHOUDWAR	SANKARPUR ODSSP	14233	11 KV SANKARPUR	14233201	Badasamantaraypur	3321DT231	500	MIXED	AMI	Yes	33%	129	0.11391088	0.041809	0.07210188	63.30%
5946	TPCODL	CUTTACK	CED	CHOUDWAR	SANKARPUR ODSSP	14233	11 KV SANKARPUR	14233201	PRADHAN SAHI	3321DT232	63	MIXED	AMI	Yes	0%	61	0.05804614	0.020893	0.03715314	64.01%
5947	TPCODL	CUTTACK	CED	CHOUDWAR	SANKARPUR ODSSP	14233	11 KV SANKARPUR	14233201	BADASAMTARPUR	3321DT236	250	MIXED	AMI	Yes	100%	77	0.11267288	0.023036	0.08963688	79.55%
5948	TPCODL	CUTTACK	CED	CHOUDWAR	SANKARPUR ODSSP	14233	11 KV SANKARPUR	14233201	BADAPADA	3321DT250	100	MIXED	AMI	Yes	100%	38	0.05492088	0.016359	0.03856188	70.21%
5949	TPCODL	CUTTACK	CED	CHOUDWAR	SANKARPUR ODSSP	14233	11 KV BERHAMPUR	14233202	BANTU	3321DT024	100	MIXED	AMI	Yes	100%	50	0.01118426	0.005908	0.00527626	47.18%
5950	TPCODL	CUTTACK	CED	CHOUDWAR	SANKARPUR ODSSP	14233	11 KV BERHAMPUR	14233202	MAHISALAND	3321DT025	100	MIXED	AMI	Yes	100%	57	0.05671634	0.022757	0.03395934	59.88%
5951	TPCODL	CUTTACK	CED	CHOUDWAR	SANKARPUR ODSSP	14233	11 KV BERHAMPUR	14233202	MAISA LANDA	3321DT029	100	MIXED	AMI	Yes	100%	72	0.04808604	0.023316	0.02477004	51.51%
5952	TPCODL	CUTTACK	CED	CHOUDWAR	SANKARPUR ODSSP	14233	11 KV BERHAMPUR	14233202	MAISA LANDA CRICKET GROUND	3321DT030	100	MIXED	AMI	Yes	100%	95	0.04905996	0.02122	0.02783996	56.75%
5953	TPCODL	CUTTACK	CED	CHOUDWAR	SANKARPUR ODSSP	14233	11 KV BERHAMPUR	14233202	KABARBADI	3321DT035	100	MIXED	AMI	Yes	100%	66	0.0299495	0.02655	0.0033995	11.35%
5954	TPCODL	CUTTACK	CED	CHOUDWAR	SANKARPUR ODSSP	14233	11 KV BERHAMPUR	14233202	BAHRAMPUR MARKET	3321DT036	500	MIXED	AMI	Yes	100%	132	0.12559432	0.064554	0.06104032	48.60%
5955	TPCODL	CUTTACK	CED	CHOUDWAR	SANKARPUR ODSSP	14233	11 KV BERHAMPUR	14233202	MATHA SAHI YATRA	3321DT047	250	MIXED	AMI	Yes	100%	147	0.08031592	0.059014	0.02130192	26.52%
5956	TPCODL	CUTTACK	CED	CHOUDWAR	SANKARPUR ODSSP	14233	11 KV BERHAMPUR	14233202	BELDA POND 1	3321DT052	100	MIXED	AMI	Yes	100%	42	0.0433946	0.020173	0.0232216	53.51%
5957	TPCODL	CUTTACK	CED	CHOUDWAR	SANKARPUR ODSSP	14233	11 KV MANGARAJPUR	14233203	MAGROJPUR 1	3321DT143	500	MIXED	AMI	Yes	100%	135	0.10169192	0.048276	0.05341592	52.53%
5958	TPCODL	CUTTACK	CED	CHOUDWAR	SANKARPUR ODSSP	14233	11 KV MANGARAJPUR	14233203	MAGROJPUR 4	3321DT147	100	MIXED	AMI	Yes	100%	52	0.0268985	0.016622	0.0102765	38.20%
5959	TPCODL	CUTTACK	CED	CHOUDWAR	SANKARPUR ODSSP	14233	11 KV MANGARAJPUR	14233203	RAMACHANDRA PUR	3321DT192	250	MIXED	AMI	Yes	100%	55	0.03184468	0.013169	0.01867568	58.65%
5960	TPCODL	CUTTACK	CED	CHOUDWAR	TANGI	14107	11 KV HARIPUR	14107201	BHAGATPUR MILL CHAK	3323DT179	250	MIXED	AMI	Yes	100%	186	0.18189676	0.137398	0.04449876	24.46%
5961	TPCODL	CUTTACK	CED	CHOUDWAR	TANGI	14107	11 KV HARIPUR	14107201	ANATHSAHI100 KV	3323DT184	100	MIXED	AMI	Yes	100%	82	0.07754524	0.04021	0.03733524	48.15%
5962	TPCODL	CUTTACK	CED	CHOUDWAR	TANGI	14107	11 KV HARIPUR	14107201	KANEIPUR 100KVA	3323DT185	100	MIXED	AMI	Yes	100%	79	0.06710368	0.044882	0.02222168	33.12%
5963	TPCODL	CUTTACK	CED	CHOUDWAR	TANGI	14107	11 KV HARIPUR	14107201	BHAGAT PUR HATA SAHI	3323DT240	100	MIXED	AMI	Yes	100%	71	0.06339566	0.031614	0.03178166	50.13%
5964	TPCODL	CUTTACK	CED	CHOUDWAR	TANGI	14107	11 KV HARIPUR	14107201	SAPANPAR 100 KVA	3323DT275	100	MIXED	AMI	Yes	100%	139	0.0768287	0.038213	0.0386157	50.26%
5965	TPCODL	CUTTACK	CED	CHOUDWAR	TANGI	14107	11 KV HARIPUR	14107201	SAFA 63KVA RWSS KE BACK SIDE	3323DT296	100	MIXED	AMI	Yes	67%	80	0.0491643	0.037235	0.0119293	24.26%
5966	TPCODL	CUTTACK	CED	CHOUDWAR	TANGI	14107	11 KV HARIPUR	14107201	SWARI 4	3323DT300	100	MIXED	AMI	Yes	100%	29	0.02603282	0.01048	0.01555282	59.74%
5967	TPCODL	CUTTACK	CED	CHOUDWAR	TANGI	14107	11 KV HARIPUR	14107201	KARANJI 2	3323DT338	100	MIXED	AMI	Yes	67%	88	0.03180408	0.021149	0.01065508	33.50%
5968	TPCODL	CUTTACK	CED	CHOUDWAR	TANGI	14107	11 KV HARIPUR	14107201	KUMBHAI 1	3323DT388	100	MIXED	AMI	Yes	100%	84	0.05419094	0.031849	0.02234194	41.23%
5969	TPCODL	CUTTACK	CED	CHOUDWAR	TANGI	14107	11 KV HARIPUR	14107201	VISHWAKANI MANDIR	3323DT406	63	MIXED	AMI	Yes	100%	72	0.04799686	0.033767	0.01422986	29.65%
5970	TPCODL	CUTTACK	CED	CHOUDWAR	TANGI	14107	11 KV HARIPUR	14107201	KANPUR HIGH SCHOOL	3323DT417	100	MIXED	AMI	Yes	67%	75	0.03619576	0.032224	0.00397176	10.97%
5971	TPCODL	CUTTACK	CED	CHOUDWAR	TANGI	14107	11 kV BHATTIMUNDA	14107202	KANDARKANA	3323DT085	250	MIXED	AMI	Yes	100%	86	0.15340752	0.032231	0.12117652	78.99%
5972	TPCODL	CUTTACK	CED	CHOUDWAR	TANGI	14107	11 kV BHATTIMUNDA	14107202	GANRABA 1	3323DT093	100	MIXED	AMI	Yes	100%	51	0.058818	0.048736	0.010082	17.14%
5973	TPCODL	CUTTACK	CED	CHOUDWAR	TANGI	14107	11 kV BHATTIMUNDA	14107202	BHATIMUNDA 1	3323DT097	500	MIXED	AMI	Yes	100%	398	0.28192872	0.20492607	0.07700265	27.31%
5974	TPCODL	CUTTACK	CED	CHOUDWAR	TANGI	14107	11 kV BHATTIMUNDA	14107202	SARANGA 1	3323DT104	250	MIXED	AMI	Yes	100%	194	0.19543996	0.097765	0.09767496	49.98%
5975	TPCODL	CUTTACK	CED	CHOUDWAR	TANGI	14107	11 kV BHATTIMUNDA	14107202	SARANGA NO 2	3323DT107	100	MIXED	AMI	Yes	100%	162	0.12105454	0.077366	0.04368854	36.09%
5976	TPCODL	CUTTACK	CED	CHOUDWAR	TANGI	14107	11 kV BHATTIMUNDA	14107202	BADASAHI 100KVA	3323DT110	100	MIXED	AMI	Yes	0%	116	0.17158928	0.069545	0.10204428	59.47%
5977	TPCODL	CUTTACK	CED	CHOUDWAR	TANGI	14107	11 kV BHATTIMUNDA	14107202	TIKARAPADA 4	3323DT118	100	MIXED	AMI	Yes	100%	169	0.11909912	0.089917	0.02918212	24.50%
5978	TPCODL	CUTTACK	CED	CHOUDWAR	TANGI	14107	11 kV BHATTIMUNDA	14107202	PAIGUAN 1	3323DT128	100	MIXED	AMI	Yes	100%	79	0.0599567	0.03641735	0.02353935	39.26%
5979	TPCODL	CUTTACK	CED	CHOUDWAR	TANGI	14107	11 kV BHATTIMUNDA	14107202	GUKULPUR 1	3323DT149	250	MIXED	AMI	Yes	67%	133	0.09080172	0.06286	0.02794172	30.77%
5980	TPCODL	CUTTACK	CED	CHOUDWAR	TANGI	14107	11 kV BHATTIMUNDA	14107202	GOVINDPUR NO2	3323DT154	100	MIXED	AMI	Yes	67%	130	0.07535998	0.057748	0.01761198	23.37%
5981	TPCODL	CUTTACK	CED	CHOUDWAR	TANGI	14107	11 kV BHATTIMUNDA	14107202	GOVINDPUR 3	3323DT155	100	MIXED	AMI	Yes	67%	69	0.04939792	0.025661	0.02373692	48.05%
5982	TPCODL	CUTTACK	CED	CHOUDWAR	TANGI	14107	11 kV BHATTIMUNDA	14107202	SAMNTRAPUR	3323DT165	100	MIXED	AMI	Yes	0%	77	0.05314102	0.036029	0.01711202	32.20%
5983	TPCODL	CUTTACK	CED	CHOUDWAR	TANGI	14107	11 kV BHATTIMUNDA	14107202	GOKULPUR 2	3323DT175	100	MIXED	AMI	Yes	67%	55	0.10839238	0.031942	0.07645038	70.53%
5984	TPCODL	CUTTACK	CED	CHOUDWAR	TANGI	14107	11 KV MANGULI	14107203	OREJANTA 2	3323DT462	100	MIXED	AMI	Yes	100%	38	0.06335574	0.02576	0.03759574	59.34%
5985	TPCODL	CUTTACK	CED	CHOUDWAR	TANGI	14107	11 KV MANGULI	14107203	BAJAT	3323DT497	250	MIXED	AMI	Yes	100%	40	0.07658028	0.033002	0.04357828	56.91%

Sl. No.	Zone Name	Circle name	Division name	Name of the Sub-division	Name of the Sub-station	Substation Code	Name of the 11 kV Feeder	Feeder Code	Name of the Location where DT situated	DT code	DT Capacity (kVA)	Predominant consumer type of DT (Domestic/Industrial/Agriculture/Mixed)	Type of metering AMR/AMI/ Communicable/Conventional metered/Unmetered	Status of Meter-whether Functional (Yes/No)	% of data received automatically (if AMR/AMI)	No. of Connected Consumers	Input Energy (MU) (A)	Billed Energy (MU) (B)	Loss (MU) (A-B)	% DT Loss (A-B)/A
5986	TPCODL	CUTTACK	CED	CHOUDWAR	TANGI	14107	11 KV MANGULI	14107203	PANDA DEEPO	3323DT507	100	MIXED	AMI	Yes	100%	33	0.084154	0.048079	0.036075	42.87%
5987	TPCODL	CUTTACK	CED	CHOUDWAR	TANGI	14107	11 KV MANGULI	14107203	PONDA DEEPO	3323DT508	100	MIXED	AMI	Yes	100%	21	0.04405438	0.024301	0.01975338	44.84%
5988	TPCODL	CUTTACK	CED	CHOUDWAR	TANGI	14107	11 KV MANGULI	14107203	KABADI MARKET	3323DT522	100	MIXED	AMI	Yes	100%	99	0.06867328	0.05296491	0.01570837	22.87%
5989	TPCODL	CUTTACK	CED	CHOUDWAR	TANGI	14107	11 KV MANGULI	14107203	MAGICAL LIGHT	3323DT543	100	MIXED	AMI	Yes	100%	69	0.0840168	0.04227	0.0417468	49.69%
5990	TPCODL	CUTTACK	CED	CHOUDWAR	TANGI	14107	11 KV MANGULI	14107203	NEEL KAMAL	3323DT553	100	MIXED	AMI	Yes	100%	35	0.04071348	0.036284	0.00442948	10.88%
5991	TPCODL	CUTTACK	CED	CHOUDWAR	TANGI	14107	11 KV MANGULI	14107203	KURKUR SAHI 2	3323DT572	100	MIXED	AMI	Yes	100%	50	0.02148004	0.014623	0.00685704	31.92%
5992	TPCODL	CUTTACK	CED	CHOUDWAR	TANGI	14107	11 KV MANGULI	14107203	NAPANGA	3323DT576	100	MIXED	AMI	Yes	100%	90	0.03940616	0.037275	0.00213116	5.41%
5993	TPCODL	CUTTACK	CED	CHOUDWAR	TANGI	14107	11 KV MANGULI	14107203	UDASHI	3323DT582	100	MIXED	AMI	Yes	100%	33	0.0237617	0.014429	0.0093327	39.28%
5994	TPCODL	CUTTACK	CED	CHOUDWAR	TANGI	14107	11 KV MANGULI	14107203	SANAKOSTI 3	3323DT593	100	MIXED	AMI	Yes	100%	72	0.0404198	0.020927	0.0194928	48.23%
5995	TPCODL	CUTTACK	CED	CHOUDWAR	TANGI	14107	11 KV MANGULI	14107203	BARANGA	3323DT595	100	MIXED	AMI	Yes	0%	38	0.02652472	0.013777	0.01274772	48.06%
5996	TPCODL	CUTTACK	CED	CHOUDWAR	TANGI	14107	11 KV MANGULI	14107203	HATA SISUA 2	3323DT605	100	MIXED	AMI	Yes	0%	26	0.04097032	0.010728	0.03024232	73.82%
5997	TPCODL	CUTTACK	CED	CHOUDWAR	TANGI	14107	11 KV MANGULI	14107203	PALASA 2	3323DT611	100	MIXED	AMI	Yes	100%	44	0.03946084	0.017701	0.02175984	55.14%
5998	TPCODL	CUTTACK	CED	CHOUDWAR	TANGI	14107	11 KV GOBINDPUR-2	14107204	RAMESWAR TEMPLE	3323DT623	100	MIXED	AMI	Yes	100%	35	0.0422098	0.039197	0.0030128	7.14%
5999	TPCODL	CUTTACK	CED	CHOUDWAR	TANGI	14107	11 KV GOBINDPUR-2	14107204	GHASI	3323DT780	100	MIXED	AMI	Yes	0%	52	0.06702168	0.017579	0.04944268	73.77%
6000	TPCODL	CUTTACK	CED	CHOUDWAR	TANGI	14107	11 KV TANGI LOCAL	14107205	BAHARHI BAJAR	3323DT657	100	MIXED	AMI	Yes	100%	56	0.13526862	0.050398	0.08487062	62.74%
6001	TPCODL	CUTTACK	CED	CHOUDWAR	TANGI	14107	11 KV TANGI LOCAL	14107205	KOTE SAHI	3323DT668	100	MIXED	AMI	Yes	100%	75	0.07130514	0.036954	0.03435114	48.17%
6002	TPCODL	CUTTACK	CED	CHOUDWAR	TANGI	14107	11 KV TANGI LOCAL	14107205	PAC	3323DT670	250	MIXED	AMI	Yes	100%	106	0.206672	0.069346	0.137326	66.45%
6003	TPCODL	CUTTACK	CED	CHOUDWAR	TANGI	14107	11 KV TANGI LOCAL	14107205	JAKENA	3323DT676	500	MIXED	AMI	Yes	0%	227	0.29194464	0.125009	0.16693564	57.18%
6004	TPCODL	CUTTACK	CED	CHOUDWAR	TANGI	14107	11 KV TANGI LOCAL	14107205	HADUA	3323DT681	100	MIXED	AMI	Yes	100%	59	0.083547	0.028782	0.054765	65.55%
6005	TPCODL	CUTTACK	CED	CHOUDWAR	TANGI	14107	11 KV TANGI LOCAL	14107205	BANDHAL 1	3323DT684	250	MIXED	AMI	Yes	100%	129	0.14842884	0.066168	0.08226084	55.42%
6006	TPCODL	CUTTACK	CED	GOPALPUR	BHINGARPUR	14224	11 kV GANGESWAR	14224201	BAJIPATANA	3331DT314	250	MIXED	AMI	Yes	67%	198	0.14163042	0.089829	0.05180142	36.58%
6007	TPCODL	CUTTACK	CED	GOPALPUR	DAMODARPUR	14101	STATION TRANSFORMER	14101STN01	33/11kV DAMODARPUR PSS STATION	3331DT378	100	MIXED	AMI	Yes	100%	1	0.0018465	0.001846	5E-07	0.03%
6008	TPCODL	CUTTACK	CED	GOPALPUR	ADASPUR	14104	11 KV ADASPUR	14104201	BEDHA SAHI NO-2	3331DT003	100	MIXED	AMI	Yes	67%	55	0.06982642	0.054332	0.01549442	22.19%
6009	TPCODL	CUTTACK	CED	GOPALPUR	ADASPUR	14104	11 KV ADASPUR	14104201	NEAR OMFED	3331DT006	100	MIXED	AMI	Yes	67%	40	0.09864724	0.046271	0.05237624	53.09%
6010	TPCODL	CUTTACK	CED	GOPALPUR	ADASPUR	14104	11 KV ADASPUR	14104201	SALIE 4	3331DT015	100	MIXED	AMI	Yes	67%	112	0.0961038	0.050638	0.0454658	47.31%
6011	TPCODL	CUTTACK	CED	GOPALPUR	ADASPUR	14104	11 KV ADASPUR	14104201	BEDHA SAHI	3331DT016	100	MIXED	AMI	Yes	100%	105	0.11384774	0.070108	0.04373974	38.42%
6012	TPCODL	CUTTACK	CED	GOPALPUR	ADASPUR	14104	11 KV ADASPUR	14104201	PETROL PUMP PVT	3331DT019	63	MIXED	AMI	Yes	67%	74	0.07695364	0.070706	0.00624764	8.12%
6013	TPCODL	CUTTACK	CED	GOPALPUR	ADASPUR	14104	11 KV ADASPUR	14104201	NILAKATHSAHI	3331DT020	250	MIXED	AMI	Yes	67%	170	0.16180172	0.106434	0.05536772	34.22%
6014	TPCODL	CUTTACK	CED	GOPALPUR	ADASPUR	14104	11 KV ADASPUR	14104201	MASANIKUDA	3331DT028	100	MIXED	AMI	Yes	33%	65	0.0642379	0.026731	0.0375069	58.39%
6015	TPCODL	CUTTACK	CED	GOPALPUR	ADASPUR	14104	11 KV ADASPUR	14104201	PMU BAZAR S/S	3331DT035	500	MIXED	AMI	Yes	67%	103	0.192822	0.092104	0.100718	52.23%
6016	TPCODL	CUTTACK	CED	GOPALPUR	ADASPUR	14104	11 KV ADASPUR	14104201	PLOTT T8	3331DT058	25	MIXED	AMI	Yes	67%	13	0.03130436	0.01163	0.01967436	62.85%
6017	TPCODL	CUTTACK	CED	GOPALPUR	ADASPUR	14104	11 KV ADASPUR	14104201	NEAR EACHCH PUR-2	3331DT066	200	MIXED	AMI	Yes	0%	178	0.29392724	0.084619	0.20930824	71.21%
6018	TPCODL	CUTTACK	CED	GOPALPUR	ADASPUR	14104	11 KV ADASPUR	14104201	BAHARIPUR	3343DT409	63	MIXED	AMI	Yes	100%	84	0.08826102	0.035009	0.05325202	60.33%
6019	TPCODL	CUTTACK	CED	GOPALPUR	ADASPUR	14104	11 KV UTTARAN	14104203	DIMIRI BAZAR 3	3331DT412	100	MIXED	AMI	Yes	0%	12	0.0063257	0.002756	0.0035697	56.43%
6020	TPCODL	CUTTACK	CED	GOPALPUR	BADAMBADI	14087	11 KV Badambadi OGP U	14087202	GOUDA SAHI 2	3211DT109	500	MIXED	AMI	Yes	100%	357	0.34462424	0.285741	0.05888324	17.09%
6021	TPCODL	CUTTACK	CED	GOPALPUR	BALIKUDA	14102	11 KV 42 MOUZA	14102201	BEHERA SAHI 2	3332DT002	250	MIXED	AMI	Yes	67%	148	0.13806128	0.08899425	0.04906703	35.54%
6022	TPCODL	CUTTACK	CED	GOPALPUR	BALIKUDA	14102	11 KV 42 MOUZA	14102201	GOPALA PUR UP SCHOOL 2	3332DT005	100	MIXED	AMI	Yes	100%	44	0.04895948	0.046094	0.00286548	5.85%
6023	TPCODL	CUTTACK	CED	GOPALPUR	BALIKUDA	14102	11 KV 42 MOUZA	14102201	SRIKURUMA 2	3332DT009	250	MIXED	AMI	Yes	100%	119	0.1375862	0.090657	0.0469292	34.11%
6024	TPCODL	CUTTACK	CED	GOPALPUR	BALIKUDA	14102	11 KV 42 MOUZA	14102201	GURUBARI SAHI	3332DT017	250	MIXED	AMI	Yes	33%	189	0.1939742	0.129163	0.0648112	33.41%
6025	TPCODL	CUTTACK	CED	GOPALPUR	BALIKUDA	14102	11 KV 42 MOUZA	14102201	NARSINGPUR	3332DT025	100	MIXED	AMI	Yes	33%	120	0.0629333	0.05775	0.0051833	8.24%
6026	TPCODL	CUTTACK	CED	GOPALPUR	BALIKUDA	14102	11 KV 42 MOUZA	14102201	JARIPADA 4	3332DT028	63	MIXED	AMI	Yes	67%	49	0.0684023	0.028596	0.0398063	58.19%
6027	TPCODL	CUTTACK	CED	GOPALPUR	BALIKUDA	14102	11 KV 42 MOUZA	14102201	JARIPADA 2	3332DT033	100	MIXED	AMI	Yes	67%	65	0.06525416	0.040837	0.02441716	37.42%
6028	TPCODL	CUTTACK	CED	GOPALPUR	BALIKUDA	14102	11 KV 42 MOUZA	14102201	JARIPADA 3	3332DT035	100	MIXED	AMI	Yes	67%	136	0.10487706	0.090698	0.01417906	13.52%
6029	TPCODL	CUTTACK	CED	GOPALPUR	BALIKUDA	14102	11 KV 42 MOUZA	14102201	NACHHIPUR BADHEI SAHI (SOBHAGY	3332DT042	100	MIXED	AMI	Yes	33%	51	0.06730382	0.034392	0.03291182	48.90%
6030	TPCODL	CUTTACK	CED	GOPALPUR	BALIKUDA	14102	11 KV 42 MOUZA	14102201	DHIHA NACHHIPUR	3332DT046	63	MIXED	AMI	Yes	67%	23	0.02267966	0.016939	0.00574066	25.31%
6031	TPCODL	CUTTACK	CED	GOPALPUR	BALIKUDA	14102	11 KV 42 MOUZA	14102201	NACHHIPUR (SOBHAGY) 2	3332DT052	63	MIXED	AMI	Yes	67%	57	0.06180092	0.029552	0.03224892	52.18%
6032	TPCODL	CUTTACK	CED	GOPALPUR	BALIKUDA	14102	11 KV 42 MOUZA	14102201	JHARIPADA JALESWARA MANDIRA	3332DT054	63	MIXED	AMI	Yes	67%	21	0.02707381	0.011949	0.01512481	55.87%
6033	TPCODL	CUTTACK	CED	GOPALPUR	BALIKUDA	14102	11 KV 42 MOUZA	14102201	BALISAHI 2	3332DT062	63	MIXED	AMI	Yes	67%	91	0.05337944	0.051932	0.00144744	2.71%
6034	TPCODL	CUTTACK	CED	GOPALPUR	BALIKUDA	14102	11 KV 42 MOUZA	14102201	BALISAHI 1	3332DT063	63	MIXED	AMI	Yes	0%	36	0.04936169	0.013353	0.03600869	72.95%
6035	TPCODL	CUTTACK	CED	GOPALPUR	BALIKUDA	14102	11 KV 42 MOUZA	14102201	NAGABALI	3332DT073	200	MIXED	AMI	Yes	0%	274	0.13823024	0.123776	0.01445424	10.46%
6036	TPCODL	CUTTACK	CED	GOPALPUR	BALIKUDA	14102	11 KV 42 MOUZA	14102201	DHANAGHARAPADA 1	3332DT077	100	MIXED	AMI	Yes	67%	92	0.07837712	0.034318	0.04405912	56.21%
6037	TPCODL	CUTTACK	CED	GOPALPUR	BALIKUDA	14102	11 KV 42 MOUZA	14102201	ARADA 1	3332DT085	100	MIXED	AMI	Yes	67%	91	0.08665368	0.037171	0.04948268	57.10%
6038	TPCODL	CUTTACK	CED	GOPALPUR	BALIKUDA	14102	11 KV 42 MOUZA	14102201	DHANAGHARAPADA MANGALA SAHI	3332DT089	100	MIXED	AMI	Yes	67%	86	0.07549284	0.035258	0.04023484	53.30%
6039	TPCODL	CUTTACK	CED	GOPALPUR	BALIKUDA	14102	11 KV 42 MOUZA	14102201	SUMANDI 2	3332DT093	63	MIXED	AMI	Yes	67%	144	0.05801636	0.053655	0.00436136	7.52%
6040	TPCODL	CUTTACK	CED	GOPALPUR	BALIKUDA	14102	11 KV 42 MOUZA	14102201	SANKHATARAS MELAKA SAHI (SOVAG	3332DT104	100	MIXED	AMI	Yes	67%	84	0.0506553	0.033464	0.0171913	33.94%
6041	TPCODL	CUTTACK	CED	GOPALPUR	BALIKUDA	14102	11 KV 42 MOUZA	14102201	SANKHATARAS 2	3332DT106	100	MIXED	AMI	Yes	67%	45	0.0203653	0.015683	0.0046823	22.99%
6042	TPCODL	CUTTACK	CED	GOPALPUR	BALIKUDA	14102	11 KV 42 MOUZA	14102201	MASTER COLONY PHD	3332DT370	100	MIXED	AMI	Yes	100%	33	0.03601288	0.017333	0.01867988	51.87%
6043	TPCODL	CUTTACK	CED	GOPALPUR	BALIKUDA	14102	11 KV BARANGA	14102202	AGIJALA PADIA 2	3332DT130	250	MIXED	AMI	Yes	100%	70	0.15358104	0.060944	0.09263704	60.32%
6044	TPCODL	CUTTACK	CED	GOPALPUR	BALIKUDA	14102	11 KV BARANGA	14102202	JAGANNATHA VEAR 1	3332DT142	100	MIXED	AMI	Yes	100%	60	0.07582754	0.047077	0.02875054	37.92%
6045	TPCODL	CUTTACK	CED	GOPALPUR	BALIKUDA	14102	11 KV UTTAMPUR	14102203	BADHAI SAHI	3332DT308	100	MIXED	AMI	Yes	100%	21	0.02146816	0.01393	0.00753816	35.11%
6046	TPCODL	CUTTACK	CED	GOPALPUR	BALIKUDA	14102	11 KV UTTAMPUR	14102203	BADHAI SAHI 2	3332DT309	250	MIXED	AMI	Yes	0%	37	0.08884564	0.035932	0.05291364	59.56%
6047	TPCODL	CUTTACK	CED	GOPALPUR	BALIKUDA	14102	11 KV UTTAMPUR	14102203	BALIKUDA NUA BAZAR 3	3332DT334	100	MIXED	AMI	Yes	100%	104	0.08787072	0.085287	0.00258372	2.94%
6048	TPCODL	CUTTACK	CED	GOPALPUR	BALIKUDA	14102	11 KV UTTAMPUR	14102203	BALIKUDA NUA BAZAR	3332DT336	100	MIXED	AMI	Yes	100%	51	0.07567242	0.04758	0.02809242	37.12%
6049	TPCODL	CUTTACK	CED	GOPALPUR	BALIKUDA	14102	11 KV UTTAMPUR	14102203	BALIKUDA NUA BAZAR 2	3332DT337	250	MIXED	AMI	Yes	67%	139	0.10167954	0.089143	0.01253654	12.33%
6050	TPCODL	CUTTACK	CED	GOPALPUR	BALIKUDA	14102	11 KV UTTAMPUR	14102203	KAJIPATANA 1	3332DT340	100	MIXED	AMI	Yes	100%	49	0.11588014	0.034045	0.08183514	70.62%
6051	TPCODL	CUTTACK	CED	GOPALPUR	BALIKUDA	14102	11 KV UTTAMPUR	14102203	UTAMPUR JATRA PADIA	3332DT344	100	MIXED	AMI	Yes	100%	127	0.10662886	0.099849	0.00677986	6.36%
6052	TPCODL	CUTTACK	CED	GOPALPUR	BALIKUDA	14102	11 KV UTTAMPUR	14102203	KAJIPATANA 3	3332DT353	250	MIXED	AMI	Yes	0%	109	0.1358372	0.0797	0.0561372	41.33%
6053	TPCODL	CUTTACK	CED	GOPALPUR	BALIKUDA	14102	11 KV UTTAMPUR	14102203	TENTULINALI 2	3332DT357	100	MIXED	AMI	Yes	100%	103	0.07197646	0.037213	0.03476346	48.30%
6054	TPCODL	CUTTACK	CED	GOPALPUR	BALIKUDA	14102	11 KV UTTAMPUR	14102203	MUKAMESWAR 2	3332DT363	100	MIXED	AMI	Yes	100%	36	0.0931097	0.022022	0.0710877	76.35%
6055	TPCODL	CUTTACK	CED	GOPALPUR	BHINGARPUR	14224	11 KV GANGESWAR	14224201	GENGESWAR 1	3331DT276	100	MIXED	AMI	Yes	67%	110	0.0981724	0.05085609	0.04731631	48.20%
6056	TPCODL	CUTTACK	CED	GOPALPUR	BHINGARPUR	14224	11 KV GANGESWAR	14224201	UTAMAPUR 3	3331DT286	100	MIXED	AMI	Yes	0%	16	0.01369684	0.00955	0.00414684	30.28%
6057	TPCODL	CUTTACK	CED	GOPALPUR	BHINGARPUR	14224	11 KV GANGESWAR	14224201	KURANGA BAZAR	3331DT299	500	MIXED	AMI	Yes	67%	226	0.16857016	0.148991	0.01957916	11.61%
6058	TPCODL	CUTTACK	CED	GOPALPUR	BHINGARPUR	14224	11 KV GANGESWAR	14224201	COLLEGE CHHAK RAIPUR 1	3331DT311	100	MIXED	AMI	Yes	67%	70	0.05645636	0.043865	0.01259136	22.30%

Sl. No.	Zone Name	Circle name	Division name	Name of the Sub-division	Name of the Sub-station	Substation Code	Name of the 11 kV Feeder	Feeder Code	Name of the Location where DT situated	DT code	DT Capacity (kVA)	Predominant consumer type of DT (Domestic/Industrial/Agriculture/Mixed)	Type of metering AMR/AMI/ Communicable/Conventional metered/Unmetered	Status of Meter-whether Functional (Yes/No)	% of data received automatically (if AMR/AMI)	No. of Connected Consumers	Input Energy (MU) (A)	Billed Energy (MU) (B)	Loss (MU) (A-B)	% DT Loss (A-B)/A
6059	TPCODL	CUTTACK	CED	GOPALPUR	BHINGARPUR	14224	11 KV GANGESWAR	14224201	BARAMAN JHILA BAZAR 1	3331DT315	500	MIXED	AMI	Yes	67%	169	0.31261496	0.121097	0.19151796	61.26%
6060	TPCODL	CUTTACK	CED	GOPALPUR	BHINGARPUR	14224	11 KV GANGESWAR	14224201	MATHA BAZAR	3331DT319	100	MIXED	AMI	Yes	67%	77	0.09175492	0.06519	0.02656492	28.95%
6061	TPCODL	CUTTACK	CED	GOPALPUR	BHINGARPUR	14224	11 KV GANGESWAR	14224201	RAIPUR	3331DT320	100	MIXED	AMI	Yes	67%	59	0.06089274	0.034817	0.02607574	42.82%
6062	TPCODL	CUTTACK	CED	GOPALPUR	BHINGARPUR	14224	11 KV GANGESWAR	14224201	KURANGA PRADHAN 1	3331DT325	250	MIXED	AMI	Yes	67%	87	0.09929412	0.043148	0.05614612	56.55%
6063	TPCODL	CUTTACK	CED	GOPALPUR	BHINGARPUR	14224	11 KV GANGESWAR	14224201	KOTHA PATANA 1	3331DT331	100	MIXED	AMI	Yes	67%	57	0.06110922	0.041449	0.01966022	32.17%
6064	TPCODL	CUTTACK	CED	GOPALPUR	BHINGARPUR	14224	11 KV GANGESWAR	14224201	SAI VILA APARTMENT 1	3331DT345	100	MIXED	AMI	Yes	67%	47	0.01471364	0.010629	0.00408464	27.76%
6065	TPCODL	CUTTACK	CED	GOPALPUR	BHINGARPUR	14224	11 KV GANGESWAR	14224201	SAI VILA APARTMENT 2	3331DT370	250	MIXED	AMI	Yes	67%	85	0.17139044	0.048962	0.12242844	71.43%
6066	TPCODL	CUTTACK	CED	GOPALPUR	DAMODARPUR	14101	11 KV GOBINDPUR	14101201	BADA PATASUNDARA PUR 4	3331DT088	63	MIXED	AMI	Yes	100%	114	0.05328682	0.030652	0.02263482	42.48%
6067	TPCODL	CUTTACK	CED	GOPALPUR	DAMODARPUR	14101	11 KV GOBINDPUR	14101201	SANA PATASUNDARA PUR 1	3333DT005	100	MIXED	AMI	Yes	100%	86	0.07165978	0.034845	0.03681478	51.37%
6068	TPCODL	CUTTACK	CED	GOPALPUR	DAMODARPUR	14101	11 KV GOBINDPUR	14101201	PATASUNDARA PUR 7	3333DT010	500	MIXED	AMI	Yes	100%	140	0.06252616	0.061443	0.00108316	1.73%
6069	TPCODL	CUTTACK	CED	GOPALPUR	DAMODARPUR	14101	11 KV GOBINDPUR	14101201	URUGANGA 2	3333DT023	500	MIXED	AMI	Yes	100%	165	0.10531816	0.073786	0.03153216	29.94%
6070	TPCODL	CUTTACK	CED	GOPALPUR	DAMODARPUR	14101	11 KV GOBINDPUR	14101201	CHOUPADA 3	3333DT029	100	MIXED	AMI	Yes	100%	74	0.05452942	0.03246	0.02206942	40.47%
6071	TPCODL	CUTTACK	CED	GOPALPUR	DAMODARPUR	14101	11 KV GOBINDPUR	14101201	NUASAHI	3333DT032	100	MIXED	AMI	Yes	100%	36	0.02760792	0.020499	0.00710892	25.75%
6072	TPCODL	CUTTACK	CED	GOPALPUR	DAMODARPUR	14101	11 KV GOBINDPUR	14101201	BADAKHARAMANGA 1	3333DT037	100	MIXED	AMI	Yes	100%	65	0.0415371	0.023947	0.0175901	42.35%
6073	TPCODL	CUTTACK	CED	GOPALPUR	DAMODARPUR	14101	11 KV GOBINDPUR	14101201	JHARAPADA 2	3333DT040	100	MIXED	AMI	Yes	100%	119	0.10961208	0.054249	0.05536308	50.51%
6074	TPCODL	CUTTACK	CED	GOPALPUR	DAMODARPUR	14101	11 KV GOBINDPUR	14101201	SAILO JHARAPADA 4	3333DT064	250	MIXED	AMI	Yes	100%	132	0.08028172	0.04467	0.03561172	44.36%
6075	TPCODL	CUTTACK	CED	GOPALPUR	DAMODARPUR	14101	11 KV GOBINDPUR	14101201	SAILO JHARAPADA 7	3333DT067	100	MIXED	AMI	Yes	100%	65	0.04107602	0.025568	0.01550802	37.75%
6076	TPCODL	CUTTACK	CED	GOPALPUR	DAMODARPUR	14101	11 KV GOBINDPUR	14101201	NETAKUNDI 5	3333DT072	100	MIXED	AMI	Yes	100%	96	0.04594272	0.03735	0.00859272	18.70%
6077	TPCODL	CUTTACK	CED	GOPALPUR	DAMODARPUR	14101	11 KV SUNDERGRAM	14101202	DAMADARPUR 1	3331DT097	250	MIXED	AMI	Yes	100%	188	0.14967336	0.103395	0.04627836	30.92%
6078	TPCODL	CUTTACK	CED	GOPALPUR	DAMODARPUR	14101	11 KV SUNDERGRAM	14101202	DAMADARPUR 5	3331DT102	100	MIXED	AMI	Yes	100%	81	0.0673565	0.040628	0.0267285	39.68%
6079	TPCODL	CUTTACK	CED	GOPALPUR	DAMODARPUR	14101	11 KV SUNDERGRAM	14101202	DEULI	3331DT106	100	MIXED	AMI	Yes	67%	140	0.08622784	0.067025	0.01920284	22.27%
6080	TPCODL	CUTTACK	CED	GOPALPUR	DAMODARPUR	14101	11 KV SUNDERGRAM	14101202	BAGALPUR OMM NIVAS	3331DT110	250	MIXED	AMI	Yes	0%	13	0.00302744	0.000977	0.00205044	67.73%
6081	TPCODL	CUTTACK	CED	GOPALPUR	DAMODARPUR	14101	11 KV SUNDERGRAM	14101202	PINGAPARA 1	3331DT112	100	MIXED	AMI	Yes	100%	164	0.08723778	0.074054	0.01318378	15.11%
6082	TPCODL	CUTTACK	CED	GOPALPUR	DAMODARPUR	14101	11 KV SUNDERGRAM	14101202	PINJAPADA 2	3331DT116	100	MIXED	AMI	Yes	100%	80	0.05331156	0.043058	0.01025356	19.23%
6083	TPCODL	CUTTACK	CED	GOPALPUR	DAMODARPUR	14101	11 KV SUNDERGRAM	14101202	SUNDARGRAM 7	3331DT141	100	MIXED	AMI	Yes	100%	122	0.08288452	0.064542	0.01834252	22.13%
6084	TPCODL	CUTTACK	CED	GOPALPUR	DAMODARPUR	14101	11 KV SUNDERGRAM	14101202	PINGAPARA 2	3331DT142	100	MIXED	AMI	Yes	100%	126	0.08829426	0.070459	0.01783526	20.20%
6085	TPCODL	CUTTACK	CED	GOPALPUR	DAMODARPUR	14101	11 KV SUNDERGRAM	14101202	SISIO	3331DT150	100	MIXED	AMI	Yes	100%	102	0.05614844	0.042492	0.01365644	24.32%
6086	TPCODL	CUTTACK	CED	GOPALPUR	DAMODARPUR	14101	11 KV SUNDERGRAM	14101202	KHANDAL 3	3331DT157	100	MIXED	AMI	Yes	67%	66	0.0318292	0.02906	0.0027692	8.70%
6087	TPCODL	CUTTACK	CED	GOPALPUR	DAMODARPUR	14101	11 KV SUNDERGRAM	14101202	ESVARPUR 1	3331DT163	250	MIXED	AMI	Yes	67%	129	0.10774926	0.072972	0.03477726	32.28%
6088	TPCODL	CUTTACK	CED	GOPALPUR	DAMODARPUR	14101	11 KV SUNDERGRAM	14101202	DALCHIRA SAHI	3331DT173	100	MIXED	AMI	Yes	67%	55	0.03427426	0.024395	0.00987926	28.82%
6089	TPCODL	CUTTACK	CED	GOPALPUR	DAMODARPUR	14101	11 KV SUNDERGRAM	14101202	KHALORA	3333DT236	100	MIXED	AMI	Yes	0%	98	0.05310634	0.041317	0.01178934	22.20%
6090	TPCODL	CUTTACK	CED	GOPALPUR	DAMODARPUR	14101	11 KV SUNDERGRAM	14101202	HARIYANTA 7	3333DT250	250	MIXED	AMI	Yes	67%	197	0.1590036	0.084104	0.0748996	47.11%
6091	TPCODL	CUTTACK	CED	GOPALPUR	DAMODARPUR	14101	11 KV SUNDERGRAM	14101202	GABABASTA 1	3333DT267	63	MIXED	AMI	Yes	67%	51	0.03062752	0.017835	0.01279252	41.77%
6092	TPCODL	CUTTACK	CED	GOPALPUR	DAMODARPUR	14101	11 KV SUNDERGRAM	14101202	NAKULESWAR NAGAR	3333DT270	100	MIXED	AMI	Yes	67%	111	0.06732344	0.054717	0.01260644	18.73%
6093	TPCODL	CUTTACK	CED	GOPALPUR	DAMODARPUR	14101	11 KV SUNDERGRAM	14101202	GABILO	3333DT275	100	MIXED	AMI	Yes	33%	45	0.03314502	0.020778	0.01236702	37.31%
6094	TPCODL	CUTTACK	CED	GOPALPUR	DAMODARPUR	14101	11 KV KANTAPADA	14101204	DAMADARPUR 1	3331DT176	100	MIXED	AMI	Yes	100%	56	0.0394674	0.025193	0.0142744	36.17%
6095	TPCODL	CUTTACK	CED	GOPALPUR	DAMODARPUR	14101	11 KV KANTAPADA	14101204	KOHARPUR	3331DT179	63	MIXED	AMI	Yes	100%	81	0.052025	0.041805	0.01022	19.64%
6096	TPCODL	CUTTACK	CED	GOPALPUR	DAMODARPUR	14101	11 KV KANTAPADA	14101204	ANTHARI 4	3331DT215	250	MIXED	AMI	Yes	100%	212	0.1214284	0.088668	0.0327604	26.98%
6097	TPCODL	CUTTACK	CED	GOPALPUR	DAMODARPUR	14101	11 KV KANTAPADA	14101204	ALAPUR 7	3331DT219	100	MIXED	AMI	Yes	100%	48	0.03274052	0.025598	0.00714252	21.82%
6098	TPCODL	CUTTACK	CED	GOPALPUR	DAMODARPUR	14101	11 KV KANTAPADA	14101204	KANTAPADA 15	3331DT225	500	MIXED	AMI	Yes	0%	255	0.20612264	0.154001	0.05212164	25.29%
6099	TPCODL	CUTTACK	CED	GOPALPUR	DAMODARPUR	14101	11 KV KANTAPADA	14101204	OLATPUR 1	3331DT239	500	MIXED	AMI	Yes	0%	178	0.17818384	0.137054	0.04112984	23.08%
6100	TPCODL	CUTTACK	CED	GOPALPUR	DAMODARPUR	14101	11 KV KANTAPADA	14101204	Shisva basti 1	3331DT241	500	MIXED	AMI	Yes	100%	117	0.09950276	0.072536	0.02696676	27.10%
6101	TPCODL	CUTTACK	CED	GOPALPUR	DAMODARPUR	14101	11 KV KANTAPADA	14101204	BAEROYI 1	3331DT242	100	MIXED	AMI	Yes	100%	80	0.05174373	0.031772	0.01997173	38.60%
6102	TPCODL	CUTTACK	CED	GOPALPUR	DAMODARPUR	14101	11 KV KANTAPADA	14101204	JOHAL	3331DT246	100	MIXED	AMI	Yes	100%	23	0.03109278	0.017451	0.01364178	43.87%
6103	TPCODL	CUTTACK	CED	GOPALPUR	DAMODARPUR	14101	11 KV KANTAPADA	14101204	KHALAGANW	3331DT248	100	MIXED	AMI	Yes	100%	163	0.0491409	0.04897	0.0001709	0.35%
6104	TPCODL	CUTTACK	CED	GOPALPUR	DAMODARPUR	14101	11 KV KANTAPADA	14101204	CHEDA 2	3331DT261	100	MIXED	AMI	Yes	0%	88	0.06037244	0.037248	0.02312444	38.30%
6105	TPCODL	CUTTACK	CED	GOPALPUR	DAMODARPUR	14101	11 KV KANTAPADA	14101204	KHERASA 1	3331DT271	100	MIXED	AMI	Yes	67%	80	0.03542134	0.029247	0.00617434	17.43%
6106	TPCODL	CUTTACK	CED	GOPALPUR	DAMODARPUR	14101	11 KV KANTAPADA	14101204	KHERASA 2	3331DT272	100	MIXED	AMI	Yes	67%	122	0.08119646	0.043231	0.03796546	46.76%
6107	TPCODL	CUTTACK	CED	GOPALPUR	ERAKANA (GOKUNA	14310	11 KV LAXMINARAYANPU	14310201	BARAHIPUR 4	3511DT176	100	MIXED	AMI	Yes	100%	66	0.04464872	0.016378	0.02827072	63.32%
6108	TPCODL	CUTTACK	CED	GOPALPUR	KAJALPUR ODSSP	14299	11 KV NAHALPUR	14299201	BCPADA 2	3333DT185	100	MIXED	AMI	Yes	100%	80	0.05096546	0.032537	0.01842846	36.16%
6109	TPCODL	CUTTACK	CED	GOPALPUR	KAJALPUR ODSSP	14299	11 KV NAHALPUR	14299201	SHABOLA	3333DT186	100	MIXED	AMI	Yes	0%	20	0.01858112	0.011606	0.00697512	37.54%
6110	TPCODL	CUTTACK	CED	GOPALPUR	KAJALPUR ODSSP	14299	11 KV NAHALPUR	14299201	DIHAPADA 1	3333DT191	100	MIXED	AMI	Yes	0%	7	0.00620538	0.003306	0.00289938	46.72%
6111	TPCODL	CUTTACK	CED	GOPALPUR	KAJALPUR ODSSP	14299	11 KV NAHALPUR	14299201	NAHALPUR 5	3333DT204	100	MIXED	AMI	Yes	100%	159	0.09183216	0.070209	0.02162316	23.55%
6112	TPCODL	CUTTACK	CED	GOPALPUR	KAJALPUR ODSSP	14299	11 KV NAHALPUR	14299201	NAHALPUR 6	3333DT205	100	MIXED	AMI	Yes	100%	96	0.06576028	0.039671	0.02608928	39.67%
6113	TPCODL	CUTTACK	CED	GOPALPUR	KAJALPUR ODSSP	14299	11 KV NAHALPUR	14299201	NUAGAON 4	3333DT207	100	MIXED	AMI	Yes	0%	94	0.08671894	0.034961	0.05175794	59.68%
6114	TPCODL	CUTTACK	CED	GOPALPUR	KAJALPUR ODSSP	14299	11 KV NAHALPUR	14299201	NUAGAON SASAN 1	3333DT212	100	MIXED	AMI	Yes	100%	80	0.05871464	0.02433	0.03438464	58.56%
6115	TPCODL	CUTTACK	CED	GOPALPUR	KAJALPUR ODSSP	14299	11 KV NAHALPUR	14299201	GOGALA	3333DT229	100	MIXED	AMI	Yes	100%	194	0.06612284	0.06242	0.00370284	5.60%
6116	TPCODL	CUTTACK	CED	GOPALPUR	KAJALPUR ODSSP	14299	11 KV NAHALPUR	14299201	JAINIO 1	3333DT232	100	MIXED	AMI	Yes	0%	35	0.01949024	0.01568	0.00381024	19.55%
6117	TPCODL	CUTTACK	CED	GOPALPUR	KAJALPUR ODSSP	14299	11 KV GOBINDPUR-II	14299202	GOPALPUR 4	3333DT078	63	MIXED	AMI	Yes	100%	30	0.01540548	0.007001	0.00840448	54.56%
6118	TPCODL	CUTTACK	CED	GOPALPUR	KAJALPUR ODSSP	14299	11 KV GOBINDPUR-II	14299202	TARALPADA	3333DT085	100	MIXED	AMI	Yes	100%	55	0.03375202	0.033061	0.00069102	2.05%
6119	TPCODL	CUTTACK	CED	GOPALPUR	KAJALPUR ODSSP	14299	11 KV GOBINDPUR-II	14299202	JAGANNATH PUR 1	3333DT087	63	MIXED	AMI	Yes	33%	12	0.0146979	0.003357	0.0113409	77.16%
6120	TPCODL	CUTTACK	CED	GOPALPUR	KAJALPUR ODSSP	14299	11 KV GOBINDPUR-II	14299202	RANIODA MISHRA SAHI	3333DT091	63	MIXED	AMI	Yes	100%	40	0.02698156	0.023664	0.00331756	12.30%
6121	TPCODL	CUTTACK	CED	GOPALPUR	KAJALPUR ODSSP	14299	11 KV GOBINDPUR-II	14299202	GOVINDPUR 3	3333DT102	100	MIXED	AMI	Yes	100%	76	0.04424298	0.033445	0.01079798	24.41%
6122	TPCODL	CUTTACK	CED	GOPALPUR	KAJALPUR ODSSP	14299	11 KV GOBINDPUR-II	14299202	GOVINDPUR 4	3333DT104	100	MIXED	AMI	Yes	100%	70	0.07605688	0.03369	0.04236688	55.70%
6123	TPCODL	CUTTACK	CED	GOPALPUR	KAJALPUR ODSSP	14299	11 KV GOBINDPUR-II	14299202	GOVINDPUR 6	3333DT106	100	MIXED	AMI	Yes	100%	103	0.04671132	0.036788	0.00992332	21.24%
6124	TPCODL	CUTTACK	CED	GOPALPUR	KAJALPUR ODSSP	14299	11 KV GOBINDPUR-II	14299202	MANKHA	3333DT107	100	MIXED	AMI	Yes	67%	102	0.04192728	0.040148	0.00177928	4.24%
6125	TPCODL	CUTTACK	CED	GOPALPUR	KAJALPUR ODSSP	14299	11 KV GOBINDPUR-II	14299202	SANKHUHA	3333DT121	63	MIXED	AMI	Yes	100%	70	0.03646634	0.030197	0.00626934	17.19%
6126	TPCODL	CUTTACK	CED	GOPALPUR	KAJALPUR ODSSP	14299	11 KV GOBINDPUR-II	14299202	BADABAURAI 3	3333DT131	100	MIXED	AMI	Yes	100%	93	0.05203002	0.038063	0.01396702	26.84%
6127	TPCODL	CUTTACK	CED	GOPALPUR	KAJALPUR ODSSP	14299	11 KV KHALARDA	14299203	KORKARA BAZAR 2	3333DT135	250	MIXED	AMI	Yes	67%	103	0.08925068	0.050171	0.03907968	43.79%
6128	TPCODL	CUTTACK	CED	GOPALPUR	KAJALPUR ODSSP	14299	11 KV KHALARDA	14299203	PURNA KORKARA	3333DT138	100	MIXED	AMI	Yes	100%	36	0.02690332	0.012021	0.01488232	55.32%
6129	TPCODL	CUTTACK	CED	GOPALPUR	KAJALPUR ODSSP	14299	11 KV KHALARDA	14299203	KHALARDA 2	3333DT141	63	MIXED	AMI	Yes	100%	84	0.0401147	0.030974	0.0091407	22.79%
6130	TPCODL	CUTTACK	CED	GOPALPUR	KAJALPUR ODSSP	14299	11 KV KHALARDA	14299203	UPAR KHALARDA BAZAR	3333DT147	63	MIXED	AMI	Yes	0%	47	0.03831506	0.019466	0.01884906	49.19%
6131	TPCODL	CUTTACK	CED	GOPALPUR	KAJALPUR ODSSP	14299	11 KV KHALARDA	14299203	KORKARA 3	3333DT148	100	MIXED	AMI	Yes	100%	25	0.02256208	0.011645	0.01091708	48.39%

Sl. No.	Zone Name	Circle name	Division name	Name of the Sub-division	Name of the Sub-station	Substation Code	Name of the 11 kV Feeder	Feeder Code	Name of the Location where DT situated	DT code	DT Capacity (kVA)	Predominant consumer type of DT (Domestic/Industrial/Agriculture/Mixed)	Type of metering AMR/AMI/ Communicable/Conventional metered/Unmetered	Status of Meter-whether Functional (Yes/No)	% of data received automatically (if AMR/AMI)	No. of Connected Consumers	Input Energy (MU) (A)	Billed Energy (MU) (B)	Loss (MU) (A-B)	% DT Loss (A-B)/A
6132	TPCODL	CUTTACK	CED	GOPALPUR	KAJALPUR ODSSP	14299	11 KV KHALARDA	14299203	KHALARDA 7	3333DT154	100	MIXED	AMI	Yes	100%	51	0.04261762	0.016279	0.02633862	61.80%
6133	TPCODL	CUTTACK	CED	GOPALPUR	KAJALPUR ODSSP	14299	11 KV KHALARDA	14299203	UPAR KHALARDA 3	3333DT159	100	MIXED	AMI	Yes	100%	31	0.05561744	0.017284	0.03833344	68.92%
6134	TPCODL	CUTTACK	CED	GOPALPUR	KAJALPUR ODSSP	14299	11 KV KHALARDA	14299203	UPAR KHALARDA 2	3333DT162	63	MIXED	AMI	Yes	100%	48	0.05576574	0.017428	0.03833774	68.75%
6135	TPCODL	CUTTACK	CED	GOPALPUR	NAKHARA	14023	11 KV GOBINDPUR RE	14023201	USHAMA PANCHAYAT 1	3333DT630	250	MIXED	AMI	Yes	0%	108	0.18351156	0.066354	0.11715756	63.84%
6136	TPCODL	CUTTACK	CED	GOPALPUR	NAKHARA	14023	11 KV GOBINDPUR RE	14023201	JIGINIPUR 2	3333DT637	63	MIXED	AMI	Yes	33%	29	0.01511204	0.010002	0.00511004	33.81%
6137	TPCODL	CUTTACK	CED	GOPALPUR	NAKHARA	14023	11 KV GOBINDPUR RE	14023201	SAINGO ROAD 3	3333DT641	250	MIXED	AMI	Yes	100%	146	0.19831036	0.08171	0.11660036	58.80%
6138	TPCODL	CUTTACK	CED	GOPALPUR	NAKHARA	14023	11 KV TRINATH BAZAR	14023202	BRAHMANAJHARILO VILLAGE DT01	3331DT379	250	MIXED	AMI	Yes	0%	29	0.0339233	0.01521	0.0187133	55.16%
6139	TPCODL	CUTTACK	CED	GOPALPUR	NISCHINTAKOILI	14099	11 KV UMARA	14099201	UMAR CANARA BANK 1	3522DT205	250	MIXED	AMI	Yes	100%	43	0.07818196	0.017008	0.06117396	78.25%
6140	TPCODL	CUTTACK	CED	GOPALPUR	PRATAP NAGARI (DA	14298	11KV PHULANAKHARA	14298201	KUMBHARAJ PUR	3332DT202	200	MIXED	AMI	Yes	67%	68	0.15249244	0.061077	0.09141544	59.95%
6141	TPCODL	CUTTACK	CED	GOPALPUR	PRATAP NAGARI (DA	14298	11KV PHULANAKHARA	14298201	AVAYA BHAT 1	3332DT379	100	MIXED	AMI	Yes	67%	62	0.0631093	0.039829	0.0232803	36.89%
6142	TPCODL	CUTTACK	CED	GOPALPUR	PRATAP NAGARI (DA	14298	11KV PRATAP NAGARI	14298202	PIRABAZAR-I	3332DT170	100	MIXED	AMI	Yes	100%	13	0.03493032	0.016401	0.01852932	53.05%
6143	TPCODL	CUTTACK	CED	GOPALPUR	PRATAP NAGARI (DA	14298	11KV PRATAP NAGARI	14298202	PATAPNAGARI SANTUKA	3332DT180	100	MIXED	AMI	Yes	100%	81	0.08759072	0.061373	0.02621772	29.93%
6144	TPCODL	CUTTACK	CED	GOPALPUR	PRATAP NAGARI (DA	14298	11KV PRATAP NAGARI	14298202	BHANAPUR JATRAPADIA 1	3332DT208	100	MIXED	AMI	Yes	100%	55	0.05020434	0.032976	0.01722834	34.32%
6145	TPCODL	CUTTACK	CED	GOPALPUR	PRATAP NAGARI (DA	14298	11KV PRATAP NAGARI	14298202	BHANAPUR JATRAPADIA 2	3332DT209	100	MIXED	AMI	Yes	100%	150	0.10814854	0.09351	0.01463854	13.54%
6146	TPCODL	CUTTACK	CED	GOPALPUR	PRATAP NAGARI (DA	14298	11KV PRATAP NAGARI	14298202	BHANAPUR	3332DT211	100	MIXED	AMI	Yes	100%	89	0.1242588	0.077542	0.0467168	37.60%
6147	TPCODL	CUTTACK	CED	GOPALPUR	PRATAP NAGARI (DA	14298	11KV PRATAP NAGARI	14298202	PRATAP NAGARIRAM MANDIRA 2	3332DT214	100	MIXED	AMI	Yes	100%	66	0.04880684	0.048349	0.00045784	0.94%
6148	TPCODL	CUTTACK	CED	GOPALPUR	PRATAP NAGARI (DA	14298	11KV PRATAP NAGARI	14298202	PRATAP NAGARI	3332DT227	250	MIXED	AMI	Yes	100%	24	0.0487972	0.022229	0.0265682	54.45%
6149	TPCODL	CUTTACK	CED	GOPALPUR	PRATAP NAGARI (DA	14298	11KV PRATAP NAGARI	14298202	PURUNA NUAGADA 3	3332DT244	250	MIXED	AMI	Yes	100%	63	0.12695602	0.044971	0.08198502	64.58%
6150	TPCODL	CUTTACK	CED	GOPALPUR	PRATAP NAGARI (DA	14298	11KV PRATAP NAGARI	14298202	GUDAKU FAKTRI	3332DT253	100	MIXED	AMI	Yes	100%	88	0.10082904	0.0498026	0.05102644	50.61%
6151	TPCODL	CUTTACK	CED	GOPALPUR	PRATAP NAGARI (DA	14298	11KV PRATAP NAGARI	14298202	KCEL	3332DT264	100	MIXED	AMI	Yes	0%	6	0.03937714	0.031493	0.00788414	20.02%
6152	TPCODL	CUTTACK	CED	GOPALPUR	PRATAP NAGARI (DA	14298	11KV PRATAP NAGARI	14298202	BAMPHAKUDA VILLAGE	3332DT283	100	MIXED	AMI	Yes	67%	50	0.12789451	0.091577	0.03631751	28.40%
6153	TPCODL	CUTTACK	CED	NIALI	NIALI	14106	11 kV TOLA	14106204	RUKUNIA SAHI	3341DT208	63	MIXED	AMI	Yes	67%	54	0.02131708	0.011045	0.01027208	48.19%
6154	TPCODL	CUTTACK	CED	NIALI	ADASPUR	14104	11 kV ADASPUR	14104201	BRAMHAMANBATI-1	3343DT034	63	MIXED	AMI	Yes	33%	41	0.00719238	0.006232	0.00096038	13.35%
6155	TPCODL	CUTTACK	CED	NIALI	ADASPUR	14104	33 kV KASARADA	14104401	33/11 kV KASARDA SS DT	3343DT404	100	MIXED	AMI	Yes	100%	1	0.00346306	0.003463	6E-08	0.00%
6156	TPCODL	CUTTACK	CED	NIALI	ADASPUR	14104	11 KV ADASPUR	14104201	SADTAFENI SAHI	3343DT005	100	MIXED	AMI	Yes	67%	81	0.06308576	0.020971	0.04211476	66.76%
6157	TPCODL	CUTTACK	CED	NIALI	ADASPUR	14104	11 KV ADASPUR	14104201	KALIA GAD-4	3343DT014	100	MIXED	AMI	Yes	67%	32	0.02352096	0.008579	0.01494196	63.53%
6158	TPCODL	CUTTACK	CED	NIALI	ADASPUR	14104	11 KV ADASPUR	14104201	BADAMULAI MOHANTY SAHI	3343DT032	250	MIXED	AMI	Yes	100%	23	0.02447664	0.010297	0.01417964	57.93%
6159	TPCODL	CUTTACK	CED	NIALI	ADASPUR	14104	11 KV ADASPUR	14104201	SANAMULAI JATRA PADIA	3343DT045	100	MIXED	AMI	Yes	0%	17	0.01420892	0.006096	0.00811292	57.10%
6160	TPCODL	CUTTACK	CED	NIALI	ADASPUR	14104	11 KV ADASPUR	14104201	BADA MULAI SCHOOL CHAKA	3343DT047	63	MIXED	AMI	Yes	67%	14	0.02482192	0.005116	0.01970592	79.39%
6161	TPCODL	CUTTACK	CED	NIALI	ADASPUR	14104	11 KV ADASPUR	14104201	MANIKUNDA 1	3343DT048	250	MIXED	AMI	Yes	67%	76	0.05853744	0.017225	0.04131244	70.57%
6162	TPCODL	CUTTACK	CED	NIALI	ADASPUR	14104	11 KV ADASPUR	14104201	DHANA. MANDAL	3343DT056	250	MIXED	AMI	Yes	0%	83	0.06903172	0.02419	0.04484172	64.96%
6163	TPCODL	CUTTACK	CED	NIALI	ADASPUR	14104	11 KV ADASPUR	14104201	Adaspur Medical	3343DT411	250	MIXED	AMI	Yes	0%	13	0.01493216	0.011906	0.00302616	20.27%
6164	TPCODL	CUTTACK	CED	NIALI	ADASPUR	14104	11 KV UTTARAN	14104203	DIMIRI CHHAKA	3331DT395	250	MIXED	AMI	Yes	67%	87	0.06711364	0.025322	0.04179164	62.27%
6165	TPCODL	CUTTACK	CED	NIALI	ADASPUR	14104	11 KV UTTARAN	14104203	DIMIRI JUITAR 1	3331DT419	250	MIXED	AMI	Yes	67%	87	0.10336456	0.03171114	0.07165342	69.32%
6166	TPCODL	CUTTACK	CED	NIALI	ADASPUR	14104	11 KV UTTARAN	14104203	DIMIRI JUITAR 3	3331DT421	63	MIXED	AMI	Yes	67%	19	0.01530576	0.003511	0.01179476	77.06%
6167	TPCODL	CUTTACK	CED	NIALI	ADASPUR	14104	11 KV UTTARAN	14104203	ADINGA 1	3331DT442	63	MIXED	AMI	Yes	67%	69	0.07685632	0.019519	0.05733732	74.60%
6168	TPCODL	CUTTACK	CED	NIALI	BALIKUDA	14102	11 KV UTTAMPUR	14102203	SYAMPUR	3332DT367	250	MIXED	AMI	Yes	100%	210	0.177203	0.138968	0.038235	21.58%
6169	TPCODL	CUTTACK	CED	NIALI	CHHATIA	14108	11 KV CHHATIA	14108201	PRANATHAPUR1	3313DT239	100	MIXED	AMI	Yes	67%	118	0.07806906	0.042971	0.03509806	44.96%
6170	TPCODL	CUTTACK	CED	NIALI	CHOUDWAR	14184	11 KV OTM	14184204	WORD 11	3322DT305	500	MIXED	AMI	Yes	67%	377	0.32529216	0.167579	0.15771316	48.48%
6171	TPCODL	CUTTACK	CED	NIALI	KAJALPUR ODSSP	14299	11 KV NAHALPUR	14299201	GUNADALA 3	3333DT221	250	MIXED	AMI	Yes	100%	132	0.09663084	0.059337	0.03729384	38.59%
6172	TPCODL	CUTTACK	CED	NIALI	KASARDA	14220	11 KV ERANCHA	14220201	KHARBILI 3	3343DT116	100	MIXED	AMI	Yes	67%	76	0.07635656	0.01571	0.06064656	79.43%
6173	TPCODL	CUTTACK	CED	NIALI	KASARDA	14220	11 KV ERANCHA	14220201	KHARBILI 9	3343DT122	100	MIXED	AMI	Yes	67%	40	0.0226363	0.011162	0.0114743	50.69%
6174	TPCODL	CUTTACK	CED	NIALI	KASARDA	14220	11 KV ERANCHA	14220201	ERANCH 1	3343DT123	100	MIXED	AMI	Yes	67%	112	0.07240798	0.035913	0.03649498	50.40%
6175	TPCODL	CUTTACK	CED	NIALI	KASARDA	14220	11 KV ERANCHA	14220201	ERANCH 12	3343DT139	100	MIXED	AMI	Yes	0%	34	0.07549438	0.0152	0.06029438	79.87%
6176	TPCODL	CUTTACK	CED	NIALI	KASARDA	14220	11 KV ERANCHA	14220201	PADASATHA 2	3343DT143	63	MIXED	AMI	Yes	67%	50	0.03692402	0.014627	0.02229702	60.39%
6177	TPCODL	CUTTACK	CED	NIALI	KASARDA	14220	11 KV ERANCHA	14220201	PADASATHA 4	3343DT145	500	MIXED	AMI	Yes	67%	138	0.067998	0.028562	0.039436	58.00%
6178	TPCODL	CUTTACK	CED	NIALI	KASARDA	14220	11 KV ERANCHA	14220201	DORMENPUR 2	3343DT149	500	MIXED	AMI	Yes	67%	192	0.09568284	0.049306	0.04637684	48.47%
6179	TPCODL	CUTTACK	CED	NIALI	KASARDA	14220	11 KV ERANCHA	14220201	DORMEPUR SAHI 3	3343DT150	100	MIXED	AMI	Yes	67%	95	0.05346305	0.034502	0.01896105	35.47%
6180	TPCODL	CUTTACK	CED	NIALI	KASARDA	14220	11 KV ERANCHA	14220201	ROHAMBA SAHI 1	3343DT172	100	MIXED	AMI	Yes	0%	33	0.02227744	0.005652	0.01662544	74.63%
6181	TPCODL	CUTTACK	CED	NIALI	KASARDA	14220	11 KV ERANCHA	14220201	KANDBIL 2	3343DT190	63	MIXED	AMI	Yes	67%	28	0.02147374	0.008472	0.01300174	60.55%
6182	TPCODL	CUTTACK	CED	NIALI	KASARDA	14220	11 KV ERANCHA	14220201	KANDBIL 3	3343DT191	63	MIXED	AMI	Yes	33%	50	0.04873926	0.013511	0.03522826	72.28%
6183	TPCODL	CUTTACK	CED	NIALI	KASARDA	14220	11 KV ERANCHA	14220201	PASTARA 1	3343DT193	100	MIXED	AMI	Yes	67%	31	0.01672352	0.005209	0.01151452	68.85%
6184	TPCODL	CUTTACK	CED	NIALI	KASARDA	14220	11 KV ERANCHA	14220201	SUDHUSAELO 1	3343DT200	100	MIXED	AMI	Yes	67%	26	0.0224175	0.006479	0.0159385	71.10%
6185	TPCODL	CUTTACK	CED	NIALI	KASARDA	14220	11 KV KASARDA	14220202	BABUZU SAHI	3343DT238	63	MIXED	AMI	Yes	0%	25	0.02620088	0.006453	0.01974788	75.37%
6186	TPCODL	CUTTACK	CED	NIALI	KASARDA	14220	11 KV KASARDA	14220202	KAVICHANDRAPUR 6	3343DT245	100	MIXED	AMI	Yes	33%	50	0.06730488	0.015794	0.05151088	76.53%
6187	TPCODL	CUTTACK	CED	NIALI	KASARDA	14220	11 KV KASARDA	14220202	NAYAK SAHI	3343DT269	100	MIXED	AMI	Yes	0%	84	0.08133354	0.029535	0.05179854	63.69%
6188	TPCODL	CUTTACK	CED	NIALI	KASARDA	14220	11 KV KULASHREE	14220203	KULASHREE 1	3343DT276	100	MIXED	AMI	Yes	67%	78	0.04242564	0.023316	0.01910964	45.04%
6189	TPCODL	CUTTACK	CED	NIALI	KASARDA	14220	11 KV KULASHREE	14220203	KULASHREE 5	3343DT281	100	MIXED	AMI	Yes	67%	84	0.05656056	0.022725	0.03383556	59.82%
6190	TPCODL	CUTTACK	CED	NIALI	KASARDA	14220	11 KV KULASHREE	14220203	ALATALANGA 3	3343DT294	100	MIXED	AMI	Yes	67%	133	0.06653006	0.049971	0.01655906	24.89%
6191	TPCODL	CUTTACK	CED	NIALI	KASARDA	14220	11 KV KULASHREE	14220203	KULASHREE 14	3343DT297	250	MIXED	AMI	Yes	67%	160	0.11892452	0.038129	0.08079552	67.94%
6192	TPCODL	CUTTACK	CED	NIALI	KASARDA	14220	11 KV SITHALO	14220204	BARISANA 7	3343DT316	100	MIXED	AMI	Yes	0%	73	0.04838528	0.0186391	0.02974618	61.48%
6193	TPCODL	CUTTACK	CED	NIALI	KASARDA	14220	11 KV SITHALO	14220204	KNTAGDIAMELAK	3343DT319	100	MIXED	AMI	Yes	0%	56	0.04406478	0.012039	0.03202578	72.68%
6194	TPCODL	CUTTACK	CED	NIALI	KASARDA	14220	11 KV SITHALO	14220204	KULA BARISANA	3343DT322	100	MIXED	AMI	Yes	0%	61	0.06710188	0.014088	0.05301388	79.01%
6195	TPCODL	CUTTACK	CED	NIALI	KASARDA	14220	11 KV SITHALO	14220204	SAGADAELO 1	3343DT342	100	MIXED	AMI	Yes	0%	79	0.04508398	0.01586	0.02922398	64.82%
6196	TPCODL	CUTTACK	CED	NIALI	KASARDA	14220	11 KV SITHALO	14220204	SITHALO 1	3343DT345	500	MIXED	AMI	Yes	0%	106	0.08329996	0.057831	0.02546896	30.57%
6197	TPCODL	CUTTACK	CED	NIALI	KASARDA	14220	11 KV SITHALO	14220204	SUMALO 1	3343DT379	100	MIXED	AMI	Yes	0%	73	0.01862766	0.01325	0.00537766	28.87%
6198	TPCODL	CUTTACK	CED	NIALI	KULA KAPASI ODSSP	14302	11 KV ARAKATA	14302201	NEAR POWE HOUSE KULAKAPSI	3342DT145	100	MIXED	AMI	Yes	0%	34	0.03242188	0.01782	0.01460188	45.04%
6199	TPCODL	CUTTACK	CED	NIALI	KULA KAPASI ODSSP	14302	11 KV ARAKATA	14302201	BADARO 2	3342DT172	100	MIXED	AMI	Yes	67%	59	0.047275	0.015011	0.032264	68.25%
6200	TPCODL	CUTTACK	CED	NIALI	KULA KAPASI ODSSP	14302	11 KV ARAKATA	14302201	BADARO 3	3342DT173	100	MIXED	AMI	Yes	67%	42	0.03492576	0.009527	0.02539876	72.72%
6201	TPCODL	CUTTACK	CED	NIALI	KULA KAPASI ODSSP	14302	11 KV ARAKATA	14302201	PATLI VILLAGE 5	3342DT182	100	MIXED	AMI	Yes	0%	70	0.03625492	0.015776	0.02047892	56.49%
6202	TPCODL	CUTTACK	CED	NIALI	KULA KAPASI ODSSP	14302	11 KV ARAKATA	14302201	PATLI VILLAGE 8	3342DT185	63	MIXED	AMI	Yes	67%	95	0.0524205	0.02268	0.0297405	56.73%
6203	TPCODL	CUTTACK	CED	NIALI	KULA KAPASI ODSSP	14302	11 KV ARAKATA	14302201	KATHISHALA 9	3342DT195	100	MIXED	AMI	Yes	67%	86	0.07201768	0.019327	0.05269068	73.16%
6204	TPCODL	CUTTACK	CED	NIALI	KULA KAPASI ODSSP	14302	11 KV ARAKATA	14302201	GONDAR 4	3342DT199	100	MIXED	AMI	Yes	67%	81	0.04332994	0.025568	0.01776194	40.99%

Sl. No.	Zone Name	Circle name	Division name	Name of the Sub-division	Name of the Sub-station	Substation Code	Name of the 11 kV Feeder	Feeder Code	Name of the Location where DT situated	DT code	DT Capacity (kVA)	Predominant consumer type of DT (Domestic/Industrial/Agriculture/Mixed)	Type of metering AMR/AMI/ Communicable/Conventional metered/Unmetered	Status of Meter-whether Functional (Yes/No)	% of data received automatically (if AMR/AMI)	No. of Connected Consumers	Input Energy (MU) (A)	Billed Energy (MU) (B)	Loss (MU) (A-B)	% DT Loss (A-B)/A
6205	TPCODL	CUTTACK	CED	NIALI	KULA KAPASI ODSSP	14302	11 KV PODANA	14302202	PODANA VILLAGE CHOWK 2	3342DT003	100	MIXED	AMI	Yes	67%	56	0.06821658	0.014865	0.05335158	78.21%
6206	TPCODL	CUTTACK	CED	NIALI	KULA KAPASI ODSSP	14302	11 KV PODANA	14302202	PODANA	3342DT020	100	MIXED	AMI	Yes	0%	40	0.02093866	0.006892	0.01404666	67.08%
6207	TPCODL	CUTTACK	CED	NIALI	KULA KAPASI ODSSP	14302	11 KV PODANA	14302202	COLESTER THUDI 1	3342DT069	100	MIXED	AMI	Yes	67%	8	0.00717252	0.001988	0.00518452	72.28%
6208	TPCODL	CUTTACK	CED	NIALI	KULA KAPASI ODSSP	14302	11 KV PODANA	14302202	COLESTER THUDI 2	3342DT076	100	MIXED	AMI	Yes	100%	16	0.00399734	0.003568	0.00042934	10.74%
6209	TPCODL	CUTTACK	CED	NIALI	KULA KAPASI ODSSP	14302	11 KV PODANA	14302202	ATHANTAR TO BAGMARA ROAD	3342DT083	100	MIXED	AMI	Yes	67%	98	0.0557568	0.029772	0.0259848	46.60%
6210	TPCODL	CUTTACK	CED	NIALI	KULA KAPASI ODSSP	14302	11 KV PODANA	14302202	ATHANTAR	3342DT088	100	MIXED	AMI	Yes	67%	44	0.0407887	0.014339	0.0264497	64.85%
6211	TPCODL	CUTTACK	CED	NIALI	KULA KAPASI ODSSP	14302	11 KV PODANA	14302202	DEULI VILLAGE 1	3342DT093	100	MIXED	AMI	Yes	0%	150	0.09391824	0.033853	0.06006524	63.95%
6212	TPCODL	CUTTACK	CED	NIALI	KULA KAPASI ODSSP	14302	11 KV PODANA	14302202	DEULI	3342DT094	100	MIXED	AMI	Yes	67%	47	0.04372068	0.011631	0.03208968	73.40%
6213	TPCODL	CUTTACK	CED	NIALI	KULA KAPASI ODSSP	14302	11 KV PODANA	14302202	PAHANGA VILLAGE 2	3342DT098	100	MIXED	AMI	Yes	0%	81	0.0666306	0.023356	0.0432746	64.95%
6214	TPCODL	CUTTACK	CED	NIALI	KULA KAPASI ODSSP	14302	11 KV PODANA	14302202	MATHIBUDA	3342DT102	100	MIXED	AMI	Yes	67%	89	0.08461717	0.024893	0.05972417	70.58%
6215	TPCODL	CUTTACK	CED	NIALI	KULA KAPASI ODSSP	14302	11 KV PODANA	14302202	MOTHO SAHI	3342DT103	100	MIXED	AMI	Yes	67%	89	0.1185996	0.032557	0.0860426	72.55%
6216	TPCODL	CUTTACK	CED	NIALI	KULA KAPASI ODSSP	14302	11 KV PODANA	14302202	SHUNDRA	3342DT108	100	MIXED	AMI	Yes	67%	41	0.05313394	0.011878	0.04125594	77.65%
6217	TPCODL	CUTTACK	CED	NIALI	KULA KAPASI ODSSP	14302	11 KV PANIMALA	14302203	KAPSI ROAD	3342DT211	100	MIXED	AMI	Yes	67%	69	0.09606708	0.026249	0.06981808	72.68%
6218	TPCODL	CUTTACK	CED	NIALI	KULA KAPASI ODSSP	14302	11 KV PANIMALA	14302203	MADHAK BUNISHIPUR MAIN ROAD	3342DT227	100	MIXED	AMI	Yes	67%	65	0.0980589	0.029634	0.0684249	69.78%
6219	TPCODL	CUTTACK	CED	NIALI	KULA KAPASI ODSSP	14302	11 KV PANIMALA	14302203	MADHAB VILLAGE 1	3342DT229	500	MIXED	AMI	Yes	67%	175	0.1584528	0.067974	0.0904788	57.10%
6220	TPCODL	CUTTACK	CED	NIALI	KULA KAPASI ODSSP	14302	11 KV PANIMALA	14302203	MADHAB VILLAGE 4	3342DT233	63	MIXED	AMI	Yes	67%	97	0.04810893	0.028987	0.01912193	39.75%
6221	TPCODL	CUTTACK	CED	NIALI	KULA KAPASI ODSSP	14302	11 KV PANIMALA	14302203	PARDHAN CHI VILLAGE TO NEXT VILL	3342DT237	100	MIXED	AMI	Yes	67%	100	0.0839295	0.031121	0.0528085	62.92%
6222	TPCODL	CUTTACK	CED	NIALI	KULA KAPASI ODSSP	14302	11 KV PANIMALA	14302203	ANGESWAR TEMPLE	3342DT239	100	MIXED	AMI	Yes	67%	86	0.05121112	0.027084	0.02412712	47.11%
6223	TPCODL	CUTTACK	CED	NIALI	KULA KAPASI ODSSP	14302	11 KV PANIMALA	14302203	KUSHANDPUR VILLAGE 2	3342DT244	250	MIXED	AMI	Yes	67%	143	0.08521404	0.051191	0.03402304	39.93%
6224	TPCODL	CUTTACK	CED	NIALI	KULA KAPASI ODSSP	14302	11 KV PANIMALA	14302203	SHORAKUR VILLAGE 2	3342DT247	100	MIXED	AMI	Yes	33%	55	0.01915672	0.016705	0.00245172	12.80%
6225	TPCODL	CUTTACK	CED	NIALI	KULA KAPASI ODSSP	14302	11 KV PANIMALA	14302203	KUSHAN PARSHAD VILLAGE NEXT 1	3342DT259	100	MIXED	AMI	Yes	0%	113	0.0765401	0.033262	0.0432781	56.54%
6226	TPCODL	CUTTACK	CED	NIALI	KULA KAPASI ODSSP	14302	11 KV PANIMALA	14302203	PADHANSAHI 1	3342DT272	100	MIXED	AMI	Yes	67%	152	0.05840576	0.036115	0.02229076	38.17%
6227	TPCODL	CUTTACK	CED	NIALI	KULA KAPASI ODSSP	14302	11 KV PANIMALA	14302203	PADHANSAHI 4	3342DT279	100	MIXED	AMI	Yes	67%	110	0.068424	0.046282	0.022142	32.36%
6228	TPCODL	CUTTACK	CED	NIALI	KULA KAPASI ODSSP	14302	11 KV PANIMALA	14302203	KK 2	3342DT280	63	MIXED	AMI	Yes	0%	89	0.04091031	0.029336	0.01157431	28.29%
6229	TPCODL	CUTTACK	CED	NIALI	KULA KAPASI ODSSP	14302	11 KV PANIMALA	14302203	NEAR BALAMPIPUR	3342DT283	250	MIXED	AMI	Yes	67%	97	0.060677	0.03312239	0.02755461	45.41%
6230	TPCODL	CUTTACK	CED	NIALI	KULA KAPASI ODSSP	14302	11 KV PANIMALA	14302203	BANMALIPUR VILLAGE	3342DT284	100	MIXED	AMI	Yes	67%	77	0.05096504	0.021893	0.02907204	57.04%
6231	TPCODL	CUTTACK	CED	NIALI	KULA KAPASI ODSSP	14302	11 KV PANIMALA	14302203	PONDSHI ROAD 4	3342DT294	100	MIXED	AMI	Yes	0%	94	0.06587318	0.03133	0.03454318	52.44%
6232	TPCODL	CUTTACK	CED	NIALI	KULA KAPASI ODSSP	14302	11 KV PANIMALA	14302203	PONDSHI ROAD 1	3342DT295	63	MIXED	AMI	Yes	67%	83	0.05858156	0.042284	0.01629756	27.82%
6233	TPCODL	CUTTACK	CED	NIALI	KULA KAPASI ODSSP	14302	11 KV PANIMALA	14302203	Jahangirpur	3342DT301	100	MIXED	AMI	Yes	67%	64	0.02978722	0.015316	0.01447122	48.58%
6234	TPCODL	CUTTACK	CED	NIALI	KUNDALA ODSSP	14303	11 KV KADAMPAL	14303203	NOSTA 8	3311DT553	100	MIXED	AMI	Yes	33%	203	0.08383174	0.046859	0.03697274	44.10%
6235	TPCODL	CUTTACK	CED	NIALI	NIALI	14106	11 KV KALIAGHAI	14106201	BALISAHI	3341DT016	100	MIXED	AMI	Yes	67%	52	0.07370662	0.020835	0.05287162	71.73%
6236	TPCODL	CUTTACK	CED	NIALI	NIALI	14106	11 KV KALIAGHAI	14106201	PADAMPADA	3341DT022	100	MIXED	AMI	Yes	67%	122	0.1086144	0.049203	0.0594114	54.70%
6237	TPCODL	CUTTACK	CED	NIALI	NIALI	14106	11 KV KALIAGHAI	14106201	SRIRAMPUR 5	3341DT024	100	MIXED	AMI	Yes	67%	107	0.05773266	0.031835	0.02589766	44.86%
6238	TPCODL	CUTTACK	CED	NIALI	NIALI	14106	11 KV KALIAGHAI	14106201	BANKUA OAIC	3341DT027	100	MIXED	AMI	Yes	67%	7	0.0062069	0.002286	0.0039209	63.17%
6239	TPCODL	CUTTACK	CED	NIALI	NIALI	14106	11 KV KALIAGHAI	14106201	NUAGAON COLLEGE CRB	3341DT034	63	MIXED	AMI	Yes	0%	69	0.11919661	0.042966	0.07623061	63.95%
6240	TPCODL	CUTTACK	CED	NIALI	NIALI	14106	11 KV KALIAGHAI	14106201	BADAKARKANA 2	3341DT037	63	MIXED	AMI	Yes	33%	122	0.06916081	0.049995	0.01916581	27.71%
6241	TPCODL	CUTTACK	CED	NIALI	NIALI	14106	11 KV KALIAGHAI	14106201	DEBENA	3341DT040	63	MIXED	AMI	Yes	0%	27	0.04216327	0.008836	0.03332727	79.04%
6242	TPCODL	CUTTACK	CED	NIALI	NIALI	14106	11 KV KALIAGHAI	14106201	KHANDESWER	3341DT042	63	MIXED	AMI	Yes	67%	66	0.0505805	0.017747	0.0328335	64.91%
6243	TPCODL	CUTTACK	CED	NIALI	NIALI	14106	11 KV KALIAGHAI	14106201	NUAPATANA 3	3341DT045	63	MIXED	AMI	Yes	67%	80	0.05380959	0.044893	0.00891659	16.57%
6244	TPCODL	CUTTACK	CED	NIALI	NIALI	14106	11 KV KALIAGHAI	14106201	KANKADABUDA	3341DT046	100	MIXED	AMI	Yes	67%	93	0.0836631	0.02693	0.0567331	67.81%
6245	TPCODL	CUTTACK	CED	NIALI	NIALI	14106	11 KV KALIAGHAI	14106201	AMANA KUDA NEW	3341DT055	63	MIXED	AMI	Yes	67%	31	0.02999195	0.023815	0.00617695	20.60%
6246	TPCODL	CUTTACK	CED	NIALI	NIALI	14106	11 KV KALIAGHAI	14106201	AMANA KUDA OLD	3341DT057	100	MIXED	AMI	Yes	0%	51	0.02647496	0.02266	0.00381496	14.41%
6247	TPCODL	CUTTACK	CED	NIALI	NIALI	14106	11 KV KALIAGHAI	14106201	PARIDA PATNA 1	3341DT062	100	MIXED	AMI	Yes	33%	93	0.06967854	0.022078	0.04760054	68.31%
6248	TPCODL	CUTTACK	CED	NIALI	NIALI	14106	11 KV KALIAGHAI	14106201	KUDAPATNA 5	3341DT074	100	MIXED	AMI	Yes	67%	136	0.09659326	0.04604021	0.05055305	52.34%
6249	TPCODL	CUTTACK	CED	NIALI	NIALI	14106	11 KV KALIAGHAI	14106201	JAMUDGADI	3341DT078	63	MIXED	AMI	Yes	33%	28	0.02729892	0.009051	0.01824792	66.84%
6250	TPCODL	CUTTACK	CED	NIALI	NIALI	14106	11 KV KALIAGHAI	14106201	BHAPUR	3341DT083	63	MIXED	AMI	Yes	33%	60	0.04254894	0.018321	0.02422794	56.94%
6251	TPCODL	CUTTACK	CED	NIALI	NIALI	14106	11 KV KALIAGHAI	14106201	BADADHIA PATNA 1	3341DT085	63	MIXED	AMI	Yes	33%	76	0.04566286	0.030183	0.01547986	33.90%
6252	TPCODL	CUTTACK	CED	NIALI	NIALI	14106	11 KV KALIAGHAI	14106201	BHAPUR BHOISAHI	3341DT087	63	MIXED	AMI	Yes	0%	33	0.0111204	0.010382	0.0007384	6.64%
6253	TPCODL	CUTTACK	CED	NIALI	NIALI	14106	11 KV KALIAGHAI	14106201	ARILO	3341DT091	63	MIXED	AMI	Yes	67%	110	0.05987615	0.021634	0.03824215	63.87%
6254	TPCODL	CUTTACK	CED	NIALI	NIALI	14106	11 KV KALIAGHAI	14106201	APUJA 1	3341DT092	100	MIXED	AMI	Yes	67%	77	0.04768482	0.0306	0.01708482	35.83%
6255	TPCODL	CUTTACK	CED	NIALI	NIALI	14106	11 KV KALIAGHAI	14106201	KAPILESWARPUR	3341DT102	63	MIXED	AMI	Yes	67%	67	0.03498397	0.014742	0.02024197	57.86%
6256	TPCODL	CUTTACK	CED	NIALI	NIALI	14106	11 KV KALIAGHAI	14106201	ANLO (SUNDAR SAHI)	3341DT110	100	MIXED	AMI	Yes	67%	91	0.09098895	0.020665	0.07032395	77.29%
6257	TPCODL	CUTTACK	CED	NIALI	NIALI	14106	11 KV KALIAGHAI	14106201	ANLO SCHOOL	3341DT111	100	MIXED	AMI	Yes	33%	142	0.0867593	0.043164	0.0435953	50.25%
6258	TPCODL	CUTTACK	CED	NIALI	NIALI	14106	11 KV KALIAGHAI	14106201	SALEI (BEHERA SAHI) 1	3341DT119	63	MIXED	AMI	Yes	33%	47	0.0357665	0.017036	0.0187305	52.37%
6259	TPCODL	CUTTACK	CED	NIALI	NIALI	14106	11 KV KALIAGHAI	14106201	GOBINDARAM PATNA	3341DT123	100	MIXED	AMI	Yes	33%	42	0.01956306	0.0104323	0.00913076	46.67%
6260	TPCODL	CUTTACK	CED	NIALI	NIALI	14106	11 KV KALIAGHAI	14106201	SALEI BAZAR	3341DT128	100	MIXED	AMI	Yes	33%	19	0.03758262	0.0079	0.02968262	78.98%
6261	TPCODL	CUTTACK	CED	NIALI	NIALI	14106	11 KV NIALI TOWN	14106202	HALL CHACK 1	3341DT143	250	MIXED	AMI	Yes	67%	228	0.27040196	0.126029	0.14437296	53.39%
6262	TPCODL	CUTTACK	CED	NIALI	NIALI	14106	11 KV NIALI TOWN	14106202	BLOCK	3341DT146	100	MIXED	AMI	Yes	100%	23	0.02203646	0.018062	0.00397446	18.04%
6263	TPCODL	CUTTACK	CED	NIALI	NIALI	14106	11 KV NIALI TOWN	14106202	BLOCK CHACK	3341DT147	500	MIXED	AMI	Yes	67%	235	0.28123152	0.203671	0.07756052	27.58%
6264	TPCODL	CUTTACK	CED	NIALI	NIALI	14106	11 KV NIALI TOWN	14106202	NIALI THANA	3341DT148	63	MIXED	AMI	Yes	0%	35	0.06007621	0.026327	0.03374921	56.18%
6265	TPCODL	CUTTACK	CED	NIALI	NIALI	14106	11 KV NIALI TOWN	14106202	GAYA SAHI	3341DT150	100	MIXED	AMI	Yes	0%	66	0.13651348	0.048671	0.08784248	64.35%
6266	TPCODL	CUTTACK	CED	NIALI	NIALI	14106	11 KV NIALI TOWN	14106202	ADHIRAJ PARIDA	3341DT151	63	MIXED	AMI	Yes	67%	85	0.08550666	0.062563	0.02294366	26.83%
6267	TPCODL	CUTTACK	CED	NIALI	NIALI	14106	11 KV NIALI TOWN	14106202	NIALI 1 MANDAP	3341DT153	63	MIXED	AMI	Yes	100%	36	0.05610626	0.028943	0.02716326	48.41%
6268	TPCODL	CUTTACK	CED	NIALI	NIALI	14106	11 KV NIALI TOWN	14106202	NALITA PARI 2	3341DT161	100	MIXED	AMI	Yes	67%	121	0.09896974	0.065282	0.03368774	34.04%
6269	TPCODL	CUTTACK	CED	NIALI	NIALI	14106	11 KV NIALI TOWN	14106202	MADRASA 1	3341DT164	100	MIXED	AMI	Yes	67%	55	0.1097812	0.035886	0.0738952	67.31%
6270	TPCODL	CUTTACK	CED	NIALI	NIALI	14106	11 KV NIALI TOWN	14106202	MADRASA 2	3341DT168	100	MIXED	AMI	Yes	67%	41	0.11247532	0.034114	0.07836132	69.67%
6271	TPCODL	CUTTACK	CED	NIALI	NIALI	14106	11 KV NIALI TOWN	14106202	MAJHI KHANDA 1	3341DT169	500	MIXED	AMI	Yes	67%	47	0.10266752	0.03516547	0.06750205	65.75%
6272	TPCODL	CUTTACK	CED	NIALI	NIALI	14106	11 KV NIALI TOWN	14106202	MAJHI KHANDA 2	3341DT170	100	MIXED	AMI	Yes	67%	60	0.03780284	0.029535	0.00826784	21.87%
6273	TPCODL	CUTTACK	CED	NIALI	NIALI	14106	11 KV NIALI TOWN	14106202	BANGALI SAHI	3341DT171	100	MIXED	AMI	Yes	67%	155	0.1314104	0.066189	0.0652214	49.63%
6274	TPCODL	CUTTACK	CED	NIALI	NIALI	14106	11 KV NIALI TOWN	14106202	PURBAKHANDA DHAN DHANA 1	3341DT172	100	MIXED	AMI	Yes	67%	95	0.09857426	0.047254	0.05132026	52.06%
6275	TPCODL	CUTTACK	CED	NIALI	NIALI	14106	11 KV NIALI TOWN	14106202	TOTASHAHI NIALI	3341DT285	63	MIXED	AMI	Yes	0%	69	0.04432725	0.032051	0.01227625	27.69%
6276	TPCODL	CUTTACK	CED	NIALI	NIALI	14106	11 KV NIALI TOWN	14106202	KAUMIRI SAHI	3341DT286	63	MIXED	AMI	Yes	67%	34	0.02938765	0.019425	0.00996265	33.90%
6277	TPCODL	CUTTACK	CED	NIALI	NIALI	14106	11 KV NIALI TOWN	14106202	HALADIBASANTA 1	3341DT287	63	MIXED	AMI	Yes	67%	98	0.05391101	0.035734	0.01817701	33.72%

Sl. No.	Zone Name	Circle name	Division name	Name of the Sub-division	Name of the Sub-station	Substation Code	Name of the 11 kV Feeder	Feeder Code	Name of the Location where DT situated	DT code	DT Capacity (kVA)	Predominant consumer type of DT (Domestic/Industrial/Agriculture/Mixed)	Type of metering AMR/AMI/ Communicable/Conventional metered/Unmetered	Status of Meter-whether Functional (Yes/No)	% of data received automatically (if AMR/AMI)	No. of Connected Consumers	Input Energy (MU) (A)	Billed Energy (MU) (B)	Loss (MU) (A-B)	% DT Loss (A-B)/A
6278	TPCODL	CUTTACK	CED	NIALI	NIALI	14106	11 KV NIALI TOWN	14106202	HAILADIBAS	3341DT288	63	MIXED	AMI	Yes	67%	31	0.05314334	0.019413	0.03373034	63.47%
6279	TPCODL	CUTTACK	CED	NIALI	NIALI	14106	11 KV NIALI TOWN	14106202	BARABODIA	3341DT292	63	MIXED	AMI	Yes	67%	80	0.08531449	0.037392	0.04792249	56.17%
6280	TPCODL	CUTTACK	CED	NIALI	NIALI	14106	11 KV NIALI TOWN	14106202	HARISHPUR	3341DT294	63	MIXED	AMI	Yes	33%	42	0.0263178	0.006978	0.0193398	73.49%
6281	TPCODL	CUTTACK	CED	NIALI	NIALI	14106	11 KV NIALI TOWN	14106202	BHAGATPADA	3341DT299	250	MIXED	AMI	Yes	67%	142	0.17460244	0.047751	0.12685144	72.65%
6282	TPCODL	CUTTACK	CED	NIALI	NIALI	14106	11 KV NIALI TOWN	14106202	CHANDIPADA 1	3341DT301	100	MIXED	AMI	Yes	33%	56	0.02556028	0.012897	0.01266328	49.54%
6283	TPCODL	CUTTACK	CED	NIALI	NIALI	14106	11 KV NIALI TOWN	14106202	NARISHO	3341DT306	100	MIXED	AMI	Yes	0%	109	0.11115714	0.042873	0.06828414	61.43%
6284	TPCODL	CUTTACK	CED	NIALI	NIALI	14106	11 KV NIALI TOWN	14106202	NARISO SASON	3341DT309	100	MIXED	AMI	Yes	67%	86	0.07124338	0.031071	0.04017238	56.39%
6285	TPCODL	CUTTACK	CED	NIALI	NIALI	14106	11 KV NIALI TOWN	14106202	BADA MATHA	3341DT312	63	MIXED	AMI	Yes	0%	55	0.03642455	0.009715	0.02670955	73.33%
6286	TPCODL	CUTTACK	CED	NIALI	NIALI	14106	11 KV KAPASI	14106203	KANTAPADA 2	3341DT323	100	MIXED	AMI	Yes	67%	102	0.06861484	0.028609	0.04000584	58.30%
6287	TPCODL	CUTTACK	CED	NIALI	NIALI	14106	11 KV KAPASI	14106203	SAHAJAN PUR	3342DT030	63	MIXED	AMI	Yes	0%	94	0.07029648	0.035187	0.03510948	49.94%
6288	TPCODL	CUTTACK	CED	NIALI	NIALI	14106	11 KV KAPASI	14106203	JALARPUR	3342DT032	100	MIXED	AMI	Yes	67%	215	0.1293022	0.088738	0.0405642	31.37%
6289	TPCODL	CUTTACK	CED	NIALI	NIALI	14106	11 KV KAPASI	14106203	TOLA GOPINATH PUR 1	3342DT040	250	MIXED	AMI	Yes	67%	145	0.11092624	0.058042	0.05288424	47.68%
6290	TPCODL	CUTTACK	CED	NIALI	NIALI	14106	11 KV KAPASI	14106203	TOLA GOPINATH PUR 2	3342DT041	63	MIXED	AMI	Yes	67%	90	0.04164035	0.029685	0.01195535	28.71%
6291	TPCODL	CUTTACK	CED	NIALI	NIALI	14106	11 KV KAPASI	14106203	KALAPACHANA 2	3342DT047	100	MIXED	AMI	Yes	67%	141	0.12870402	0.055739	0.07296502	56.69%
6292	TPCODL	CUTTACK	CED	NIALI	NIALI	14106	11 KV KAPASI	14106203	KALAPACHANA 6	3342DT053	63	MIXED	AMI	Yes	67%	81	0.04986869	0.022423	0.02744569	55.04%
6293	TPCODL	CUTTACK	CED	NIALI	NIALI	14106	11 KV KAPASI	14106203	MADHAB VILLAGE 4	3342DT065	100	MIXED	AMI	Yes	67%	124	0.04631982	0.040359	0.00596082	12.87%
6294	TPCODL	CUTTACK	CED	NIALI	NIALI	14106	11 KV TOLA	14106204	ALOK NAGAR 2	3341DT177	63	MIXED	AMI	Yes	67%	37	0.04922348	0.028781	0.02044248	41.53%
6295	TPCODL	CUTTACK	CED	NIALI	NIALI	14106	11 KV TOLA	14106204	OLANSA PLAY GROUND	3341DT181	100	MIXED	AMI	Yes	67%	88	0.0619719	0.017494	0.0444779	71.77%
6296	TPCODL	CUTTACK	CED	NIALI	NIALI	14106	11 KV TOLA	14106204	MAJHI KHANDA 3	3341DT185	63	MIXED	AMI	Yes	67%	30	0.02553966	0.013594	0.01194566	46.77%
6297	TPCODL	CUTTACK	CED	NIALI	NIALI	14106	11 KV TOLA	14106204	BAHARANA RATHA PADIA	3341DT192	100	MIXED	AMI	Yes	67%	101	0.04471588	0.030471	0.01424488	31.86%
6298	TPCODL	CUTTACK	CED	NIALI	NIALI	14106	11 KV TOLA	14106204	LEKHAN PUR	3341DT211	100	MIXED	AMI	Yes	67%	54	0.02887052	0.015976	0.01289452	44.66%
6299	TPCODL	CUTTACK	CED	NIALI	NIALI	14106	11 KV TOLA	14106204	BALIKUDA 2	3341DT220	100	MIXED	AMI	Yes	33%	81	0.08505202	0.023974	0.06107802	71.81%
6300	TPCODL	CUTTACK	CED	NIALI	NIALI	14106	11 KV TOLA	14106204	BALARA 1	3341DT221	250	MIXED	AMI	Yes	67%	117	0.06445836	0.031314	0.03314436	51.42%
6301	TPCODL	CUTTACK	CED	NIALI	NIALI	14106	11 KV TOLA	14106204	ADHANGA BUS STAND	3341DT224	100	MIXED	AMI	Yes	67%	74	0.07996894	0.019388	0.06058094	75.76%
6302	TPCODL	CUTTACK	CED	NIALI	NIALI	14106	11 KV TOLA	14106204	BANGIHATI BAZAR	3341DT229	63	MIXED	AMI	Yes	67%	94	0.03374242	0.025879	0.00786342	23.30%
6303	TPCODL	CUTTACK	CED	NIALI	NIALI	14106	11 KV TOLA	14106204	BANGIHATI	3341DT230	100	MIXED	AMI	Yes	67%	94	0.03648256	0.025458	0.01102456	30.22%
6304	TPCODL	CUTTACK	CED	NIALI	NIALI	14106	11 KV TOLA	14106204	RAJA SAHI	3341DT232	250	MIXED	AMI	Yes	67%	61	0.05930168	0.019598	0.03970368	66.95%
6305	TPCODL	CUTTACK	CED	NIALI	NIALI	14106	11 KV TOLA	14106204	ATHANGA (MAUNL BABY MATHA)	3341DT242	100	MIXED	AMI	Yes	67%	66	0.06707068	0.014463	0.05260768	78.44%
6306	TPCODL	CUTTACK	CED	NIALI	NIALI	14106	11 KV TOLA	14106204	MAHANGA (NEW)	3341DT250	63	MIXED	AMI	Yes	67%	93	0.05814686	0.028377	0.02976986	51.20%
6307	TPCODL	CUTTACK	CED	NIALI	NIALI	14106	11 KV TOLA	14106204	MAHANGA 2 (NEW)	3341DT251	63	MIXED	AMI	Yes	67%	77	0.0546829	0.030028	0.0246549	45.09%
6308	TPCODL	CUTTACK	CED	NIALI	NIALI	14106	11 KV TOLA	14106204	BAGAL SAHI	3341DT268	100	MIXED	AMI	Yes	67%	67	0.0314325	0.019546	0.0118865	37.82%
6309	TPCODL	CUTTACK	CED	NIALI	NIALI	14106	11 KV TOLA	14106204	POLASARA	3341DT269	100	MIXED	AMI	Yes	67%	67	0.05660242	0.013264	0.04333842	76.57%
6310	TPCODL	CUTTACK	CED	NIALI	NIALI	14106	11 KV TOLA	14106204	POLASARA HIGH SCHOOL 1	3341DT272	100	MIXED	AMI	Yes	67%	53	0.04595826	0.013292	0.03266626	71.08%
6311	TPCODL	CUTTACK	CED	NIALI	NIALI	14106	11 KV TOLA	14106204	POKHARIGAON	3341DT281	100	MIXED	AMI	Yes	67%	50	0.07676684	0.025643	0.05112384	66.60%
6312	TPCODL	CUTTACK	CED	NIALI	TANGI	14107	11 KV HARIPUR	14107201	MANIA01	3323DT206	100	MIXED	AMI	Yes	100%	116	0.0941644	0.027425	0.0667394	70.88%
6313	TPCODL	CUTTACK	SED	MAHANGA	TANGI	14107	11 kV MANGULI	14107203	KURKUR SAHE	3323DT571	100	MIXED	AMI	Yes	100%	57	0.0354915	0.024177	0.0113145	31.88%
6314	TPCODL	CUTTACK	SED	MAHANGA	ASURESWAR ODSSP	14311	11 KV SUKARPADA	14311201	SANKILO 1	3521DT146	63	MIXED	AMI	Yes	67%	87	0.07241058	0.020659	0.05175158	71.47%
6315	TPCODL	CUTTACK	SED	MAHANGA	BADACHANA	14105	11 KV SAKUNTALAPUR	14105203	ULLURI 5	3512DT054	100	MIXED	AMI	Yes	67%	51	0.03989092	0.012378	0.02751292	68.97%
6316	TPCODL	CUTTACK	SED	MAHANGA	CHHATA	14199	11 KV CHHATA	14199201	ENDNO HALDIC	5121DT086	63	MIXED	AMI	Yes	67%	58	0.03291487	0.011197	0.02171787	65.98%
6317	TPCODL	CUTTACK	SED	MAHANGA	CHHATA	14199	11 KV PANCHUPANDAVA	14199202	ALAKANPANCHU MADI 2	3511DT269	63	MIXED	AMI	Yes	33%	84	0.05576965	0.024324	0.03144565	56.38%
6318	TPCODL	CUTTACK	SED	MAHANGA	CHHATIA	14108	11 KV CHAMPAPUR	14108203	MADHUPUR NEAR OFFICE	3512DT039	100	MIXED	AMI	Yes	67%	133	0.05629282	0.036183	0.02010982	35.72%
6319	TPCODL	CUTTACK	SED	MAHANGA	ERAKANA (GOKUNA	14310	11 KV LAXMINARAYANPU	14310201	GORTANGA	3511DT162	250	MIXED	AMI	Yes	100%	68	0.11551144	0.027335	0.08817644	76.34%
6320	TPCODL	CUTTACK	SED	MAHANGA	ERAKANA (GOKUNA	14310	11 KV LAXMINARAYANPU	14310201	OSANGA MUSLIM SAHI	3511DT169	100	MIXED	AMI	Yes	100%	83	0.03656508	0.02877	0.00779508	21.32%
6321	TPCODL	CUTTACK	SED	MAHANGA	ERAKANA (GOKUNA	14310	11 KV LAXMINARAYANPU	14310201	OSANGA 1	3511DT171	100	MIXED	AMI	Yes	67%	139	0.04959514	0.033577	0.01601814	32.30%
6322	TPCODL	CUTTACK	SED	MAHANGA	ERAKANA (GOKUNA	14310	11 KV LAXMINARAYANPU	14310201	BARAHIPUR 3	3511DT178	100	MIXED	AMI	Yes	100%	147	0.06596778	0.045783	0.02018478	30.60%
6323	TPCODL	CUTTACK	SED	MAHANGA	ERAKANA (GOKUNA	14310	11 KV LAXMINARAYANPU	14310201	PAIKARAPUR 1	3511DT190	100	MIXED	AMI	Yes	100%	128	0.07474044	0.032511	0.04222944	56.50%
6324	TPCODL	CUTTACK	SED	MAHANGA	ERAKANA (GOKUNA	14310	11 KV LAXMINARAYANPU	14310201	OLANKA 3	3511DT242	100	MIXED	AMI	Yes	100%	158	0.05540564	0.049322	0.00608364	10.98%
6325	TPCODL	CUTTACK	SED	MAHANGA	ERAKANA (GOKUNA	14310	11 KV KURUJANGA	14310202	GOPAL PUR 3	3511DT091	63	MIXED	AMI	Yes	67%	100	0.05816428	0.034501	0.02366328	40.68%
6326	TPCODL	CUTTACK	SED	MAHANGA	ERAKANA (GOKUNA	14310	11 KV KURUJANGA	14310202	GOPAL PUR 8	3511DT096	250	MIXED	AMI	Yes	100%	105	0.12637924	0.042931	0.08344824	66.03%
6327	TPCODL	CUTTACK	SED	MAHANGA	ERAKANA (GOKUNA	14310	11 KV KURUJANGA	14310202	NRCSINGH PUR 12	3511DT117	63	MIXED	AMI	Yes	67%	45	0.01432842	0.011372	0.00295642	20.63%
6328	TPCODL	CUTTACK	SED	MAHANGA	ERAKANA (GOKUNA	14310	11 KV KURUJANGA	14310202	KURUJANGA 6	3511DT125	63	MIXED	AMI	Yes	33%	114	0.06186182	0.032059	0.02980282	48.18%
6329	TPCODL	CUTTACK	SED	MAHANGA	ERAKANA (GOKUNA	14310	11 KV KURUJANGA	14310202	KURUJANGA 10	3511DT129	63	MIXED	AMI	Yes	67%	38	0.01727512	0.012127	0.00514812	29.80%
6330	TPCODL	CUTTACK	SED	MAHANGA	ERAKANA (GOKUNA	14310	11 KV KURUJANGA	14310202	KURUJANGA 13	3511DT132	63	MIXED	AMI	Yes	100%	12	0.02372262	0.006618	0.01710462	72.10%
6331	TPCODL	CUTTACK	SED	MAHANGA	ERAKANA (GOKUNA	14310	11 KV KURUJANGA	14310202	NAIGUAN 1	3511DT144	100	MIXED	AMI	Yes	0%	88	0.03696186	0.030981	0.00598086	16.18%
6332	TPCODL	CUTTACK	SED	MAHANGA	ERAKANA (GOKUNA	14310	11 KV KURUJANGA	14310202	NAIGUAN 3	3511DT151	63	MIXED	AMI	Yes	100%	90	0.04842541	0.019477	0.02894841	59.78%
6333	TPCODL	CUTTACK	SED	MAHANGA	ERAKANA (GOKUNA	14310	11 KV GOUDAGOPA	14310203	KERAL 4	3511DT009	100	MIXED	AMI	Yes	100%	43	0.0547067	0.012781	0.0419257	76.64%
6334	TPCODL	CUTTACK	SED	MAHANGA	ERAKANA (GOKUNA	14310	11 KV GOUDAGOPA	14310203	GOUDGOP BUSUALI	3511DT021	100	MIXED	AMI	Yes	100%	116	0.05676402	0.03395	0.02281402	40.19%
6335	TPCODL	CUTTACK	SED	MAHANGA	ERAKANA (GOKUNA	14310	11 KV GOUDAGOPA	14310203	ACHYATPUR	3511DT026	100	MIXED	AMI	Yes	100%	124	0.05908618	0.042237	0.01684918	28.52%
6336	TPCODL	CUTTACK	SED	MAHANGA	ERAKANA (GOKUNA	14310	11 KV GOUDAGOPA	14310203	GOUDGOP BAZAR	3511DT028	100	MIXED	AMI	Yes	0%	166	0.10290946	0.055578	0.04733146	45.99%
6337	TPCODL	CUTTACK	SED	MAHANGA	ERAKANA (GOKUNA	14310	11 KV GOUDAGOPA	14310203	GOUDGOP SAWMILL	3511DT031	100	MIXED	AMI	Yes	100%	103	0.04544462	0.036381	0.00906362	19.94%
6338	TPCODL	CUTTACK	SED	MAHANGA	ERAKANA (GOKUNA	14310	11 KV GOUDAGOPA	14310203	JHADSWARPUR 3	3511DT040	100	MIXED	AMI	Yes	100%	85	0.02932338	0.022041	0.00728238	24.83%
6339	TPCODL	CUTTACK	SED	MAHANGA	ERAKANA (GOKUNA	14310	11 KV GOUDAGOPA	14310203	JHADSWARPUR 4	3511DT050	100	MIXED	AMI	Yes	100%	56	0.01743134	0.011919	0.00551234	31.62%
6340	TPCODL	CUTTACK	SED	MAHANGA	ERAKANA (GOKUNA	14310	11 KV GOUDAGOPA	14310203	HADADIA HATA	3511DT058	100	MIXED	AMI	Yes	100%	35	0.03507154	0.008556	0.02651554	75.60%
6341	TPCODL	CUTTACK	SED	MAHANGA	ERAKANA (GOKUNA	14310	11 KV GOUDAGOPA	14310203	NAHANGA PATANA	3522DT243	100	MIXED	AMI	Yes	100%	52	0.02641678	0.018602	0.00781478	29.58%
6342	TPCODL	CUTTACK	SED	MAHANGA	ERAKANA (GOKUNA	14310	11 KV GOUDAGOPA	14310203	BALIPADA 6	3522DT250	100	MIXED	AMI	Yes	100%	91	0.06769596	0.028293	0.03940296	58.21%
6343	TPCODL	CUTTACK	SED	MAHANGA	JAPAKUDA ODSSP	14312	11 KV MALAMOUDA	14312204	NEAR MAUDA VILLAGE	3532DT157	100	MIXED	AMI	Yes	100%	138	0.07764886	0.049519	0.02812986	36.23%
6344	TPCODL	CUTTACK	SED	MAHANGA	KOLAR(PARUNA)	14196	11 kV POSAL	14196203	DHANUA	5432DT299	63	MIXED	AMI	Yes	67%	60	0.02560488	0.021186	0.00441888	17.26%
6345	TPCODL	CUTTACK	SED	MAHANGA	KOTAPADA	14096	11 KV JAIPUR/KOTAPADA	14096201	DAULIA	3512DT066	100	MIXED	AMI	Yes	100%	76	0.0580794	0.017459	0.0406204	69.94%
6346	TPCODL	CUTTACK	SED	MAHANGA	KOTAPADA	14096	11 KV JAIPUR/KOTAPADA	14096201	ARILO dehuri SAHI	3512DT078	100	MIXED	AMI	Yes	100%	79	0.0213008	0.015639	0.0056618	26.58%
6347	TPCODL	CUTTACK	SED	MAHANGA	KOTAPADA	14096	11 KV JAIPUR/KOTAPADA	14096201	ARILO DOULATAPUR	3512DT086	100	MIXED	AMI	Yes	100%	61	0.0387023	0.028911	0.0097913	25.30%
6348	TPCODL	CUTTACK	SED	MAHANGA	KOTAPADA	14096	11 KV JAIPUR/KOTAPADA	14096201	MOHANTY SAHI	3512DT089	100	MIXED	AMI	Yes	100%	63	0.03152082	0.027148	0.00437282	13.87%
6349	TPCODL	CUTTACK	SED	MAHANGA	KOTAPADA	14096	11 KV JAIPUR/KOTAPADA	14096201	BENUPUR 6	3512DT096	100	MIXED	AMI	Yes	67%	90	0.10124822	0.022995	0.07825322	77.29%
6350	TPCODL	CUTTACK	SED	MAHANGA	KOTAPADA	14096	11 KV JAIPUR/KOTAPADA	14096201	KUMUDA 2	3512DT102	100	MIXED	AMI	Yes	33%	280	0.1155882	0.083259	0.0323292	27.97%

Sl. No.	Zone Name	Circle name	Division name	Name of the Sub-division	Name of the Sub-station	Substation Code	Name of the 11 kV Feeder	Feeder Code	Name of the Location where DT situated	DT code	DT Capacity (kVA)	Predominant consumer type of DT (Domestic/Industrial/Agriculture/Mixed)	Type of metering AMR/AMI/ Communicable/Conventional metered/Unmetered	Status of Meter-whether Functional (Yes/No)	% of data received automatically (if AMR/AMI)	No. of Connected Consumers	Input Energy (MU) (A)	Billed Energy (MU) (B)	Loss (MU) (A-B)	% DT Loss (A-B)/A
6351	TPCODL	CUTTACK	SED	MAHANGA	KOTAPADA	14096	11 KV JAIPUR/KOTAPADA	14096201	JAYPUR	3512DT107	250	MIXED	AMI	Yes	67%	233	0.2331462	0.082406	0.1507402	64.65%
6352	TPCODL	CUTTACK	SED	MAHANGA	KOTAPADA	14096	11 KV JAIPUR/KOTAPADA	14096201	MALIKPUR	3512DT111	100	MIXED	AMI	Yes	67%	86	0.0310936	0.023943	0.0071506	23.00%
6353	TPCODL	CUTTACK	SED	MAHANGA	KOTAPADA	14096	11 KV JAIPUR/KOTAPADA	14096201	DOULATAPUR	3512DT116	100	MIXED	AMI	Yes	67%	38	0.03931096	0.018083	0.02122796	54.00%
6354	TPCODL	CUTTACK	SED	MAHANGA	KOTAPADA	14096	11 KV JAIPUR/KOTAPADA	14096201	ISHANISWARA TEMPLE	3512DT269	100	MIXED	AMI	Yes	67%	63	0.02890796	0.016529	0.01237896	42.82%
6355	TPCODL	CUTTACK	SED	MAHANGA	KOTAPADA	14096	11 KV BASUDEVPUR	14096202	DHARMDASPUR	3512DT179	100	MIXED	AMI	Yes	67%	182	0.0987684	0.054499	0.0442694	44.82%
6356	TPCODL	CUTTACK	SED	MAHANGA	KOTAPADA	14096	11 KV BASUDEVPUR	14096202	BASUDEVPUR 1	3512DT201	500	MIXED	AMI	Yes	0%	173	0.20979744	0.075449	0.13434844	64.04%
6357	TPCODL	CUTTACK	SED	MAHANGA	KOTAPADA	14096	11 KV BASUDEVPUR	14096202	GHIJWAN-01	3512DT211	100	MIXED	AMI	Yes	67%	47	0.02717828	0.021972	0.00520628	19.16%
6358	TPCODL	CUTTACK	SED	MAHANGA	KOTAPADA	14096	11 KV BASUDEVPUR	14096202	GHIJWAN-02	3512DT216	100	MIXED	AMI	Yes	67%	74	0.06725652	0.028215	0.03904152	58.05%
6359	TPCODL	CUTTACK	SED	MAHANGA	KOTAPADA	14096	11 KV BASUDEVPUR	14096202	KOLIATHA 1	3512DT240	250	MIXED	AMI	Yes	67%	201	0.12910924	0.059299	0.06981024	54.07%
6360	TPCODL	CUTTACK	SED	MAHANGA	KOTAPADA	14096	11 KV BASUDEVPUR	14096202	MOHANPUR 2	3512DT247	100	MIXED	AMI	Yes	67%	27	0.05053296	0.010634	0.03989896	78.96%
6361	TPCODL	CUTTACK	SED	MAHANGA	KOTAPADA	14096	11 KV BASUDEVPUR	14096202	BARATHA 2	3512DT251	250	MIXED	AMI	Yes	67%	195	0.12500904	0.075336	0.04967304	39.74%
6362	TPCODL	CUTTACK	SED	MAHANGA	KOTAPADA	14096	11 KV MULABASANTA	14096203	KUMUDAHATA-1	3512DT147	250	MIXED	AMI	Yes	67%	165	0.0909064	0.051443	0.0394634	43.41%
6363	TPCODL	CUTTACK	SED	MAHANGA	KOTAPADA	14096	11 KV MULABASANTA	14096203	MULABASANT-2	3512DT152	250	MIXED	AMI	Yes	67%	182	0.09414672	0.056528	0.03761872	39.96%
6364	TPCODL	CUTTACK	SED	MAHANGA	KOTAPADA	14096	11 KV MULABASANTA	14096203	SIPURA HARIJAN SAHI	3512DT169	100	MIXED	AMI	Yes	67%	145	0.06106472	0.038301	0.02276372	37.28%
6365	TPCODL	CUTTACK	SED	MAHANGA	KOTAPADA	14096	11 KV MULABASANTA	14096203	GUNUPUR	3512DT175	100	MIXED	AMI	Yes	67%	131	0.11375938	0.041341	0.07241838	63.66%
6366	TPCODL	CUTTACK	SED	MAHANGA	KOTAPADA	14096	11 KV MULABASANTA	14096203	SUIPURA ROUT SAHI	3512DT182	100	MIXED	AMI	Yes	0%	113	0.10889328	0.039546	0.06934728	63.68%
6367	TPCODL	CUTTACK	SED	MAHANGA	MAHANGA	14097	11 KV MAHANGA	14097201	ALIJODA 1	3513DT157	100	MIXED	AMI	Yes	33%	36	0.01789132	0.010497	0.00739432	41.33%
6368	TPCODL	CUTTACK	SED	MAHANGA	MAHANGA	14097	11 KV MAHANGA	14097201	MALIPUR 2	3513DT170	100	MIXED	AMI	Yes	67%	65	0.03743294	0.020788	0.01664494	44.47%
6369	TPCODL	CUTTACK	SED	MAHANGA	MAHANGA	14097	11 KV MAHANGA	14097201	CHATTRATOTA	3513DT174	250	MIXED	AMI	Yes	67%	101	0.09162732	0.038161	0.05346632	58.35%
6370	TPCODL	CUTTACK	SED	MAHANGA	MAHANGA	14097	11 KV MAHANGA	14097201	ITA PADIA	3513DT179	63	MIXED	AMI	Yes	100%	25	0.03742302	0.019072	0.01835102	49.04%
6371	TPCODL	CUTTACK	SED	MAHANGA	MAHANGA	14097	11 KV MAHANGA	14097201	BINOD BIHARI	3513DT187	100	MIXED	AMI	Yes	67%	58	0.04787656	0.023246	0.02463056	51.45%
6372	TPCODL	CUTTACK	SED	MAHANGA	MAHANGA	14097	11 KV MAHANGA	14097201	ODA 3	3513DT211	63	MIXED	AMI	Yes	67%	58	0.03255514	0.016851	0.01570414	48.24%
6373	TPCODL	CUTTACK	SED	MAHANGA	MAHANGA	14097	11 KV MAHANGA	14097201	GUDAPADA LIC	3513DT212	100	MIXED	AMI	Yes	67%	82	0.04582944	0.02416	0.02166944	47.28%
6374	TPCODL	CUTTACK	SED	MAHANGA	MAHANGA	14097	11 KV MAHANGA	14097201	SIPURA	3513DT216	100	MIXED	AMI	Yes	67%	108	0.04966772	0.033293	0.01637472	32.97%
6375	TPCODL	CUTTACK	SED	MAHANGA	MAHANGA	14097	11 KV MAHANGA	14097201	HATA PADA 3	3513DT220	100	MIXED	AMI	Yes	67%	61	0.04530032	0.013147	0.03215332	70.98%
6376	TPCODL	CUTTACK	SED	MAHANGA	MAHANGA	14097	11 KV MAHANGA	14097201	HATA CHOWK	3513DT232	63	MIXED	AMI	Yes	67%	68	0.04857784	0.02852	0.02005784	41.29%
6377	TPCODL	CUTTACK	SED	MAHANGA	MAHANGA	14097	11 KV MAHANGA	14097201	MAHANGI BADI	3513DT238	63	MIXED	AMI	Yes	67%	46	0.03673783	0.019871	0.01686683	45.91%
6378	TPCODL	CUTTACK	SED	MAHANGA	MAHANGA	14097	11 KV MAHANGA	14097201	TULASIPUR-1	3513DT242	100	MIXED	AMI	Yes	67%	56	0.04315684	0.020474	0.02268284	52.56%
6379	TPCODL	CUTTACK	SED	MAHANGA	MAHANGA	14097	11 KV MAHANGA	14097201	GOPALPUR-3	3513DT251	100	MIXED	AMI	Yes	67%	81	0.04972554	0.024415	0.02531054	50.90%
6380	TPCODL	CUTTACK	SED	MAHANGA	MAHANGA	14097	11 KV MAHANGA	14097201	PALLI SAHI-2	3513DT260	100	MIXED	AMI	Yes	67%	129	0.05301158	0.052582	0.00042958	0.81%
6381	TPCODL	CUTTACK	SED	MAHANGA	MAHANGA	14097	11 KV MAHANGA	14097201	DSSPUR-3	3513DT264	100	MIXED	AMI	Yes	67%	102	0.0547112	0.035336	0.0193752	35.41%
6382	TPCODL	CUTTACK	SED	MAHANGA	MAHANGA	14097	11 KV MAHANGA	14097201	KHONDALA-2	3513DT269	63	MIXED	AMI	Yes	67%	122	0.05454816	0.040913	0.01363516	25.00%
6383	TPCODL	CUTTACK	SED	MAHANGA	MAHANGA	14097	11 KV MAHANGA	14097201	RANKAPUR-1	3513DT270	100	MIXED	AMI	Yes	67%	41	0.07160888	0.018896	0.05271288	73.61%
6384	TPCODL	CUTTACK	SED	MAHANGA	MAHANGA	14097	11 KV KUANPALA	14097202	GANGAPUR	3513DT062	100	MIXED	AMI	Yes	33%	190	0.06790142	0.060047	0.00785442	11.57%
6385	TPCODL	CUTTACK	SED	MAHANGA	MAHANGA	14097	11 KV KUANPALA	14097202	KUANPAL MARKET	3513DT067	100	MIXED	AMI	Yes	67%	129	0.06109788	0.060975	0.00012288	0.20%
6386	TPCODL	CUTTACK	SED	MAHANGA	MAHANGA	14097	11 KV KUANPALA	14097202	JALESWARPUR MADHUBAN	3513DT082	100	MIXED	AMI	Yes	67%	92	0.04473174	0.029564	0.01516774	33.91%
6387	TPCODL	CUTTACK	SED	MAHANGA	MAHANGA	14097	11 KV KUANPALA	14097202	NURTANGA 2	3513DT088	100	MIXED	AMI	Yes	67%	201	0.08154204	0.04939599	0.03214605	39.42%
6388	TPCODL	CUTTACK	SED	MAHANGA	MAHANGA	14097	11 KV KUANPALA	14097202	NURTUNGA 4	3513DT092	250	MIXED	AMI	Yes	0%	162	0.09749528	0.03727	0.06022528	61.77%
6389	TPCODL	CUTTACK	SED	MAHANGA	MAHANGA	14097	11 KV KUANPALA	14097202	NURTANGA 7	3513DT094	63	MIXED	AMI	Yes	67%	62	0.04069926	0.018725	0.02197426	53.99%
6390	TPCODL	CUTTACK	SED	MAHANGA	MAHANGA	14097	11 KV KUANPALA	14097202	ANANDA PUR 7	3513DT112	250	MIXED	AMI	Yes	67%	150	0.12473192	0.047294	0.07743792	62.08%
6391	TPCODL	CUTTACK	SED	MAHANGA	MAHANGA	14097	11 KV KUANPALA	14097202	ANDAPUR SETHI SAHI	3513DT140	63	MIXED	AMI	Yes	67%	143	0.04247486	0.035515	0.00695986	16.39%
6392	TPCODL	CUTTACK	SED	MAHANGA	MAHANGA	14097	11 KV KUANPALA	14097202	ANADAPUR 1	3513DT146	100	MIXED	AMI	Yes	67%	95	0.0648915	0.037998	0.0268935	41.44%
6393	TPCODL	CUTTACK	SED	MAHANGA	MAHANGA	14097	11 KV KUANPALA	14097202	RIVER	3513DT302	63	MIXED	AMI	Yes	67%	30	0.02778476	0.006872	0.02091276	75.27%
6394	TPCODL	CUTTACK	SED	MAHANGA	MAHANGA	14097	11 KV CHAINPAL	14097203	MALIHATA-2	3513DT009	100	MIXED	AMI	Yes	100%	42	0.032853	0.01419	0.018663	56.81%
6395	TPCODL	CUTTACK	SED	MAHANGA	MAHANGA	14097	11 KV CHAINPAL	14097203	ADAMA 1	3513DT013	100	MIXED	AMI	Yes	0%	72	0.04898958	0.016592	0.03239758	66.13%
6396	TPCODL	CUTTACK	SED	MAHANGA	MAHANGA	14097	11 KV CHAINPAL	14097203	RAMCHANDRAPUR	3513DT017	100	MIXED	AMI	Yes	100%	90	0.0529392	0.024908	0.0280312	52.95%
6397	TPCODL	CUTTACK	SED	MAHANGA	MAHANGA	14097	11 KV CHAINPAL	14097203	USAMA PATANA 2	3513DT029	100	MIXED	AMI	Yes	100%	78	0.03783048	0.02576717	0.01206331	31.89%
6398	TPCODL	CUTTACK	SED	MAHANGA	MAHANGA	14097	11 KV CHAINPAL	14097203	USAMA-2	3513DT030	63	MIXED	AMI	Yes	0%	58	0.03020941	0.011705	0.01850441	61.25%
6399	TPCODL	CUTTACK	SED	MAHANGA	MAHANGA	14097	11 KV CHAINPAL	14097203	KAIRPUR	3513DT033	63	MIXED	AMI	Yes	100%	47	0.02154314	0.013776	0.00776714	36.05%
6400	TPCODL	CUTTACK	SED	MAHANGA	MAHANGA	14097	11 KV CHAINPAL	14097203	DHARAPUR MOHANTY SAHI	3513DT035	63	MIXED	AMI	Yes	100%	75	0.02328953	0.022926	0.00036353	1.56%
6401	TPCODL	CUTTACK	SED	MAHANGA	MAHANGA	14097	11 KV CHAINPAL	14097203	GOKULPUR	3513DT041	100	MIXED	AMI	Yes	33%	109	0.03276404	0.032053	0.00071104	2.17%
6402	TPCODL	CUTTACK	SED	MAHANGA	MAHANGA	14097	11 KV CHAINPAL	14097203	MOGLAL PATNA1	3513DT044	100	MIXED	AMI	Yes	100%	64	0.0331704	0.018023	0.0151474	45.67%
6403	TPCODL	CUTTACK	SED	MAHANGA	MAHANGA	14097	11 KV CHAINPAL	14097203	MIRZA PATNA 1	3513DT048	100	MIXED	AMI	Yes	67%	46	0.0425248	0.014329	0.0281958	66.30%
6404	TPCODL	CUTTACK	SED	MAHANGA	NISCHINTAKOILI	14099	11 KV RAMAKRUSNAPUR	14099203	DAHA PADA NO.1 100 KVA	3513DT276	100	MIXED	AMI	Yes	100%	101	0.1073708	0.043191	0.0641798	59.77%
6405	TPCODL	CUTTACK	SED	MAHANGA	NISCHINTAKOILI	14099	11 KV RAMAKRUSNAPUR	14099203	BHORIA	3513DT280	100	MIXED	AMI	Yes	100%	89	0.04824942	0.03083	0.01741942	36.10%
6406	TPCODL	CUTTACK	SED	MAHANGA	NISCHINTAKOILI	14099	11 KV RAMAKRUSNAPUR	14099203	NAHANGA MUSLIMSAHI	3513DT281	250	MIXED	AMI	Yes	100%	111	0.06041498	0.030298	0.03011698	49.85%
6407	TPCODL	CUTTACK	SED	MAHANGA	NISCHINTAKOILI	14099	11 KV RAMAKRUSNAPUR	14099203	LHONG 2	3513DT282	100	MIXED	AMI	Yes	33%	56	0.02278008	0.019615	0.00316508	13.89%
6408	TPCODL	CUTTACK	SED	MAHANGA	ORIKANTA	14212	11 KV GOPINATHPUR	14212201	BAING PADA1	3523DT186	100	MIXED	AMI	Yes	67%	81	0.03460944	0.01922	0.01538944	44.47%
6409	TPCODL	CUTTACK	SED	MAHANGA	RAISUNGUDA (MOI	14309	11 KV DHARMAGATAPUR	14309202	KANPUR 1	3532DT097	250	MIXED	AMI	Yes	0%	74	0.16534412	0.034083	0.13126112	79.39%
6410	TPCODL	CUTTACK	SED	MAHANGA	RAISUNGUDA (MOI	14309	11 KV DHARMAGATAPUR	14309202	JAIRAMPUR 1	3532DT144	100	MIXED	AMI	Yes	100%	107	0.14134432	0.058001	0.08334332	58.96%
6411	TPCODL	CUTTACK	SED	N KOILI	NISCHINTAKOILI	14099	11 KV UMARA	14099201	BADIKHIRI-3	3522DT230	250	MIXED	AMI	Yes	100%	235	0.16803616	0.109001	0.05903516	35.13%
6412	TPCODL	CUTTACK	SED	N KOILI	ASURESWAR ODSSP	14311	11 KV SUKARPADA	14311201	JHULIKIPADA 1	3521DT064	100	MIXED	AMI	Yes	100%	180	0.0837511	0.060621	0.0231301	27.62%
6413	TPCODL	CUTTACK	SED	N KOILI	ASURESWAR ODSSP	14311	11 KV SUKARPADA	14311201	DHOLA SAHI	3521DT075	100	MIXED	AMI	Yes	100%	62	0.11836134	0.027659	0.09070234	76.63%
6414	TPCODL	CUTTACK	SED	N KOILI	ASURESWAR ODSSP	14311	11 KV SUKARPADA	14311201	SUKARA PADA SWAIN SAHI	3521DT076	100	MIXED	AMI	Yes	100%	69	0.05299978	0.034518	0.01848178	34.87%
6415	TPCODL	CUTTACK	SED	N KOILI	ASURESWAR ODSSP	14311	11 KV SUKARPADA	14311201	SUKARPADA 11	3521DT079	250	MIXED	AMI	Yes	100%	117	0.15591908	0.054637	0.10128208	64.96%
6416	TPCODL	CUTTACK	SED	N KOILI	ASURESWAR ODSSP	14311	11 KV SUKARPADA	14311201	SUNALUNDA	3521DT092	100	MIXED	AMI	Yes	0%	96	0.03323682	0.031143	0.00209382	6.30%
6417	TPCODL	CUTTACK	SED	N KOILI	ASURESWAR ODSSP	14311	11 KV SUKARPADA	14311201	RAMACHANDRA PUR	3521DT102	100	MIXED	AMI	Yes	100%	63	0.05921336	0.030847	0.02836636	47.91%
6418	TPCODL	CUTTACK	SED	N KOILI	ASURESWAR ODSSP	14311	11 KV SUKARPADA	14311201	KENTALO PARIDA SAHI	3521DT103	100	MIXED	AMI	Yes	100%	37	0.01756236	0.011183	0.00637936	36.32%
6419	TPCODL	CUTTACK	SED	N KOILI	ASURESWAR ODSSP	14311	11 KV SUKARPADA	14311201	KATARPADA	3521DT111	100	MIXED	AMI	Yes	33%	41	0.0227963	0.013604	0.0091923	40.32%
6420	TPCODL	CUTTACK	SED	N KOILI	ASURESWAR ODSSP	14311	11 KV SUKARPADA	14311201	MURDABAD 1	3521DT115	100	MIXED	AMI	Yes	100%	44	0.02803168	0.016597	0.01143468	40.79%
6421	TPCODL	CUTTACK	SED	N KOILI	ASURESWAR ODSSP	14311	11 KV SUKARPADA	14311201	PITHAPADA 5	3521DT122	100	MIXED	AMI	Yes	100%	37	0.017578	0.010347	0.007231	41.14%
6422	TPCODL	CUTTACK	SED	N KOILI	ASURESWAR ODSSP	14311	11 KV SUKARPADA	14311201	KULASARAPADA 2	3521DT136	100	MIXED	AMI	Yes	100%	33	0.03336012	0.015186	0.01817412	54.48%
6423	TPCODL	CUTTACK	SED	N KOILI	ASURESWAR ODSSP	14311	11 KV SUKARPADA	14311201	KULA BADA KHIRA	3521DT147	100	MIXED	AMI	Yes	100%	141	0.04899248	0.046297	0.00269548	5.50%

Sl. No.	Zone Name	Circle name	Division name	Name of the Sub-division	Name of the Sub-station	Substation Code	Name of the 11 kV Feeder	Feeder Code	Name of the Location where DT situated	DT code	DT Capacity (kVA)	Predominant consumer type of DT (Domestic/Industrial/Agriculture/Mixed)	Type of metering AMR/AMI/ Communicable/Conventional metered/Unmetered	Status of Meter-whether Functional (Yes/No)	% of data received automatically (if AMR/AMI)	No. of Connected Consumers	Input Energy (MU) (A)	Billed Energy (MU) (B)	Loss (MU) (A-B)	% DT Loss (A-B)/A
6424	TPCODL	CUTTACK	SED	N KOILI	ASURESWAR ODSSP	14311	11 KV ASURESWAR	14311202	MIRASAHI 1	3521DT003	100	MIXED	AMI	Yes	100%	65	0.03462926	0.022151	0.01247826	36.03%
6425	TPCODL	CUTTACK	SED	N KOILI	ASURESWAR ODSSP	14311	11 KV ASURESWAR	14311202	PAIKARAPUR 1	3521DT009	100	MIXED	AMI	Yes	100%	98	0.12368332	0.040182	0.08350132	67.51%
6426	TPCODL	CUTTACK	SED	N KOILI	ASURESWAR ODSSP	14311	11 KV ASURESWAR	14311202	DIKHITPADA 2	3521DT021	100	MIXED	AMI	Yes	100%	125	0.05906084	0.047063	0.01199784	20.31%
6427	TPCODL	CUTTACK	SED	N KOILI	ASURESWAR ODSSP	14311	11 KV ASURESWAR	14311202	NUAGAN 1	3521DT024	100	MIXED	AMI	Yes	100%	70	0.02680158	0.022269	0.00453258	16.91%
6428	TPCODL	CUTTACK	SED	N KOILI	ASURESWAR ODSSP	14311	11 KV ASURESWAR	14311202	NUAGAN 2	3521DT025	100	MIXED	AMI	Yes	100%	73	0.02967064	0.022174	0.00749664	25.27%
6429	TPCODL	CUTTACK	SED	N KOILI	ASURESWAR ODSSP	14311	11 KV ASURESWAR	14311202	KATIKATA BAZAR 2	3521DT035	100	MIXED	AMI	Yes	67%	67	0.11246066	0.033385	0.07907566	70.31%
6430	TPCODL	CUTTACK	SED	N KOILI	ASURESWAR ODSSP	14311	11 KV ASURESWAR	14311202	KATIKATA BAZAR 1	3521DT036	100	MIXED	AMI	Yes	100%	183	0.09536374	0.085274	0.01008974	10.58%
6431	TPCODL	CUTTACK	SED	N KOILI	ASURESWAR ODSSP	14311	11 KV ASURESWAR	14311202	PATSAILO 1	3521DT041	100	MIXED	AMI	Yes	100%	79	0.05744266	0.049322	0.00812066	14.14%
6432	TPCODL	CUTTACK	SED	N KOILI	ASURESWAR ODSSP	14311	11 KV ASURESWAR	14311202	BHARTAPADA PATRA SAHI	3521DT046	100	MIXED	AMI	Yes	100%	11	0.03266412	0.00797	0.02469412	75.60%
6433	TPCODL	CUTTACK	SED	N KOILI	ASURESWAR ODSSP	14311	11 KV ASURESWAR	14311202	KUSUNPUR 1	3521DT052	100	MIXED	AMI	Yes	100%	49	0.03568908	0.02564	0.01004908	28.16%
6434	TPCODL	CUTTACK	SED	N KOILI	ASURESWAR ODSSP	14311	11 KV ASURESWAR	14311202	GANESHPUR 1	3521DT055	63	MIXED	AMI	Yes	100%	69	0.02761096	0.026114	0.00149696	5.42%
6435	TPCODL	CUTTACK	SED	N KOILI	ASURESWAR ODSSP	14311	11 KV LUNA	14311203	LOKANATH PUR DAS SAHI	3521DT130	100	MIXED	AMI	Yes	100%	38	0.0296856	0.012907	0.0167786	56.52%
6436	TPCODL	CUTTACK	SED	N KOILI	ASURESWAR ODSSP	14311	11 KV LUNA	14311203	TARAT 3	3521DT202	250	MIXED	AMI	Yes	67%	194	0.16437044	0.088695	0.07567544	46.04%
6437	TPCODL	CUTTACK	SED	N KOILI	ASURESWAR ODSSP	14311	11 KV LUNA	14311203	PADHANA PATI BIRA	3521DT206	100	MIXED	AMI	Yes	67%	62	0.03322322	0.01419	0.01903322	57.29%
6438	TPCODL	CUTTACK	SED	N KOILI	ASURESWAR ODSSP	14311	11 KV LUNA	14311203	KULAPATIKIRA	3521DT213	100	MIXED	AMI	Yes	67%	64	0.01915767	0.017313	0.00184467	9.63%
6439	TPCODL	CUTTACK	SED	N KOILI	ASURESWAR ODSSP	14311	11 KV LUNA	14311203	JAMARA 3	3521DT228	100	MIXED	AMI	Yes	100%	85	0.03149356	0.018986	0.01250756	39.71%
6440	TPCODL	CUTTACK	SED	N KOILI	ASURESWAR ODSSP	14311	11 KV LUNA	14311203	KUTILO 1	3521DT229	63	MIXED	AMI	Yes	67%	47	0.02898928	0.016606	0.01238328	42.72%
6441	TPCODL	CUTTACK	SED	N KOILI	ASURESWAR ODSSP	14311	11 KV LUNA	14311203	ORTI 1	3521DT231	100	MIXED	AMI	Yes	67%	95	0.0393723	0.020812	0.0185603	47.14%
6442	TPCODL	CUTTACK	SED	N KOILI	ASURESWAR ODSSP	14311	11 KV LUNA	14311203	KUTILO 2	3521DT234	100	MIXED	AMI	Yes	67%	52	0.02873674	0.014918	0.01381874	48.09%
6443	TPCODL	CUTTACK	SED	N KOILI	ASURESWAR ODSSP	14311	11 KV LUNA	14311203	BARKOLIA BAZAR	3521DT237	63	MIXED	AMI	Yes	0%	114	0.06699056	0.039767	0.02722356	40.64%
6444	TPCODL	CUTTACK	SED	N KOILI	ASURESWAR ODSSP	14311	11 KV LUNA	14311203	JAMARA 2	3521DT241	100	MIXED	AMI	Yes	100%	37	0.01330344	0.00981	0.00349344	26.26%
6445	TPCODL	CUTTACK	SED	N KOILI	ASURESWAR ODSSP	14311	11 KV LUNA	14311203	KAMALPUR 1	3521DT261	100	MIXED	AMI	Yes	67%	60	0.03961072	0.018988	0.02062272	52.06%
6446	TPCODL	CUTTACK	SED	N KOILI	BADAMBADI	14087	11 KV Badambadi OGP U	14087202	AROUNDA NAGAR	3211DT107	100	MIXED	AMI	Yes	0%	191	0.20488052	0.178903	0.02597752	12.68%
6447	TPCODL	CUTTACK	SED	N KOILI	BAHUGRAM-2	14098	11 KV BAHUGRAM PADN	14098202	MAHAJAN PUR 2	3531DT008	500	MIXED	AMI	Yes	100%	126	0.16590528	0.066215	0.09969028	60.09%
6448	TPCODL	CUTTACK	SED	N KOILI	BAHUGRAM-2	14098	11 KV BAHUGRAM PADN	14098202	GANAPUR	3531DT025	63	MIXED	AMI	Yes	100%	36	0.06350246	0.014946	0.04855646	76.46%
6449	TPCODL	CUTTACK	SED	N KOILI	BAHUGRAM-2	14098	11 KV BAHUGRAM PADN	14098202	GANAPUR PRIMERY SCHOOL	3531DT026	100	MIXED	AMI	Yes	100%	129	0.07025374	0.05195159	0.01830215	26.05%
6450	TPCODL	CUTTACK	SED	N KOILI	BAHUGRAM-2	14098	11 KV PATAPUR	14098204	SIGMAPUR PRIMARY SCHOOL	3531DT240	250	MIXED	AMI	Yes	100%	134	0.10698968	0.051836	0.05515368	51.55%
6451	TPCODL	CUTTACK	SED	N KOILI	ERAKANA (GOKUNA	14310	11 KV KURUJANGA	14310202	KURUJANGA 11	3511DT130	100	MIXED	AMI	Yes	67%	117	0.04825824	0.02912	0.01913824	39.66%
6452	TPCODL	CUTTACK	SED	N KOILI	ERAKANA (GOKUNA	14310	11 KV KURUJANGA	14310202	KURUJANGA 16	3511DT135	100	MIXED	AMI	Yes	33%	95	0.03467606	0.028618	0.00605806	17.47%
6453	TPCODL	CUTTACK	SED	N KOILI	KORUA	14163	11 KV NARENDRAPUR	14163202	NARENDRAPUR 1	3521DT156	100	MIXED	AMI	Yes	100%	126	0.05882554	0.037995	0.02083054	35.41%
6454	TPCODL	CUTTACK	SED	N KOILI	KORUA	14163	11 KV NARENDRAPUR	14163202	NARENDRAPUR 2	3521DT157	250	MIXED	AMI	Yes	67%	147	0.10773852	0.078714	0.02902452	26.94%
6455	TPCODL	CUTTACK	SED	N KOILI	KORUA	14163	11 KV NARENDRAPUR	14163202	KAKUDIAPADA 1	3521DT163	100	MIXED	AMI	Yes	100%	115	0.05422166	0.052064	0.00215766	3.98%
6456	TPCODL	CUTTACK	SED	N KOILI	KORUA	14163	11 KV NARENDRAPUR	14163202	NAHALPUR 2	3521DT164	100	MIXED	AMI	Yes	100%	104	0.05843328	0.034452	0.02398128	41.04%
6457	TPCODL	CUTTACK	SED	N KOILI	KORUA	14163	11 KV NARENDRAPUR	14163202	BODHAGA 1	3521DT173	100	MIXED	AMI	Yes	100%	84	0.03775736	0.014904	0.02285336	60.53%
6458	TPCODL	CUTTACK	SED	N KOILI	KORUA	14163	11 KV NARENDRAPUR	14163202	NAHALPUR1	3521DT289	63	MIXED	AMI	Yes	100%	44	0.03552922	0.026523	0.00900622	25.35%
6459	TPCODL	CUTTACK	SED	N KOILI	KORUA	14163	11 KV NARENDRAPUR	14163202	NAHALAPUR 1	3521DT293	100	MIXED	AMI	Yes	100%	57	0.04301255	0.020587	0.02242555	52.14%
6460	TPCODL	CUTTACK	SED	N KOILI	KORUA	14163	11 KV NARENDRAPUR	14163202	KAKUDIAPADA ALARI	3521DT294	100	MIXED	AMI	Yes	100%	59	0.07567276	0.022386	0.05328676	70.42%
6461	TPCODL	CUTTACK	SED	N KOILI	KORUA	14163	11 KV NARENDRAPUR	14163202	NARUA 1	3523DT448	100	MIXED	AMI	Yes	67%	86	0.05547108	0.025627	0.02984408	53.80%
6462	TPCODL	CUTTACK	SED	N KOILI	KORUA	14163	11 KV NARENDRAPUR	14163202	GOPINATH PUR 6	3523DT456	100	MIXED	AMI	Yes	67%	94	0.04281778	0.029816	0.01300178	30.37%
6463	TPCODL	CUTTACK	SED	N KOILI	KORUA	14163	11 KV NARENDRAPUR	14163202	BADANAIGUAN 5	3523DT461	100	MIXED	AMI	Yes	67%	41	0.02856864	0.011965	0.01660364	58.12%
6464	TPCODL	CUTTACK	SED	N KOILI	KORUA	14163	11 KV NARENDRAPUR	14163202	DHARSARPUR 1	3523DT463	500	MIXED	AMI	Yes	67%	185	0.10186096	0.057537	0.04432396	43.51%
6465	TPCODL	CUTTACK	SED	N KOILI	KORUA	14163	11 KV NARENDRAPUR	14163202	MANGALAPUR 8	3523DT472	63	MIXED	AMI	Yes	67%	56	0.0335088	0.014329	0.0191798	57.24%
6466	TPCODL	CUTTACK	SED	N KOILI	KORUA	14163	11 KV NARENDRAPUR	14163202	MANGALAPUR 10	3523DT474	63	MIXED	AMI	Yes	67%	86	0.04828822	0.020235	0.02805322	58.10%
6467	TPCODL	CUTTACK	SED	N KOILI	KORUA	14163	11 KV NARENDRAPUR	14163202	BALIGADA	3523DT478	63	MIXED	AMI	Yes	67%	62	0.03789168	0.018544	0.01934768	51.06%
6468	TPCODL	CUTTACK	SED	N KOILI	KORUA	14163	11 KV NARENDRAPUR	14163202	CHARIRAKABA 1	3523DT479	100	MIXED	AMI	Yes	67%	48	0.02753696	0.018123	0.00941396	34.19%
6469	TPCODL	CUTTACK	SED	N KOILI	KORUA	14163	11 KV NARENDRAPUR	14163202	NAGASPUR 4	3523DT496	63	MIXED	AMI	Yes	67%	55	0.07221608	0.02175	0.05046608	69.88%
6470	TPCODL	CUTTACK	SED	N KOILI	KORUA	14163	11 KV NARENDRAPUR	14163202	DHARSARPUR 2	3523DT508	63	MIXED	AMI	Yes	67%	38	0.05280772	0.026962	0.02584572	48.94%
6471	TPCODL	CUTTACK	SED	N KOILI	KORUA	14163	11 KV NARENDRAPUR	14163202	GOPINATH PUR 2	3523DT510	100	MIXED	AMI	Yes	67%	46	0.0398302	0.025883	0.0139472	35.02%
6472	TPCODL	CUTTACK	SED	N KOILI	KORUA	14163	11 KV NARENDRAPUR	14163202	NEMALO 2	3523DT511	100	MIXED	AMI	Yes	67%	92	0.04845934	0.023684	0.02477534	51.13%
6473	TPCODL	CUTTACK	SED	N KOILI	NISCHINTAKOILI	14099	11 KV UMARA	14099201	NATKAL	3522DT152	100	MIXED	AMI	Yes	100%	63	0.04206502	0.021443	0.02062202	49.02%
6474	TPCODL	CUTTACK	SED	N KOILI	NISCHINTAKOILI	14099	11 KV UMARA	14099201	USTAPUR-4	3522DT162	63	MIXED	AMI	Yes	100%	42	0.0469344	0.016505	0.0304294	64.83%
6475	TPCODL	CUTTACK	SED	N KOILI	NISCHINTAKOILI	14099	11 KV UMARA	14099201	PATRASHAI	3522DT164	100	MIXED	AMI	Yes	100%	75	0.0649542	0.017347	0.0476072	73.29%
6476	TPCODL	CUTTACK	SED	N KOILI	NISCHINTAKOILI	14099	11 KV UMARA	14099201	JENA SAHI	3522DT170	100	MIXED	AMI	Yes	100%	78	0.04445676	0.018405	0.02605176	58.60%
6477	TPCODL	CUTTACK	SED	N KOILI	NISCHINTAKOILI	14099	11 KV UMARA	14099201	GOTARA 2	3522DT173	100	MIXED	AMI	Yes	100%	69	0.03724496	0.016314	0.02093096	56.20%
6478	TPCODL	CUTTACK	SED	N KOILI	NISCHINTAKOILI	14099	11 KV UMARA	14099201	DHALAPADA 1	3522DT181	100	MIXED	AMI	Yes	100%	65	0.03972496	0.01657	0.02315496	58.29%
6479	TPCODL	CUTTACK	SED	N KOILI	NISCHINTAKOILI	14099	11 KV UMARA	14099201	BADIKHIRI TEMPLE	3522DT183	100	MIXED	AMI	Yes	100%	44	0.02526186	0.015503	0.00975886	38.63%
6480	TPCODL	CUTTACK	SED	N KOILI	NISCHINTAKOILI	14099	11 KV UMARA	14099201	KANHAPUR VILLAGE 1	3522DT187	100	MIXED	AMI	Yes	100%	47	0.03498032	0.014333	0.02064732	59.03%
6481	TPCODL	CUTTACK	SED	N KOILI	NISCHINTAKOILI	14099	11 KV UMARA	14099201	GOTARA-2	3522DT191	100	MIXED	AMI	Yes	100%	125	0.06333892	0.037697	0.02564192	40.48%
6482	TPCODL	CUTTACK	SED	N KOILI	NISCHINTAKOILI	14099	11 KV UMARA	14099201	APILO VILLAGE 1	3522DT197	100	MIXED	AMI	Yes	100%	42	0.06769878	0.014126	0.05357278	79.13%
6483	TPCODL	CUTTACK	SED	N KOILI	NISCHINTAKOILI	14099	11 KV UMARA	14099201	OTHKA VILLAGE 1	3522DT220	100	MIXED	AMI	Yes	100%	100	0.04229332	0.031214	0.01107932	26.20%
6484	TPCODL	CUTTACK	SED	N KOILI	NISCHINTAKOILI	14099	11 KV BUHALA	14099202	NUASAHI	3522DT024	63	MIXED	AMI	Yes	67%	85	0.04427127	0.029941	0.01433027	32.37%
6485	TPCODL	CUTTACK	SED	N KOILI	NISCHINTAKOILI	14099	11 KV BUHALA	14099202	BHUHAL 1	3522DT028	100	MIXED	AMI	Yes	100%	47	0.03077388	0.018358	0.01241588	40.35%
6486	TPCODL	CUTTACK	SED	N KOILI	NISCHINTAKOILI	14099	11 KV BUHALA	14099202	SUNILO BARAL SAHI	3522DT030	250	MIXED	AMI	Yes	100%	118	0.05913938	0.043565	0.01557438	26.34%
6487	TPCODL	CUTTACK	SED	N KOILI	NISCHINTAKOILI	14099	11 KV BUHALA	14099202	BHUHAL 4	3522DT031	150	MIXED	AMI	Yes	33%	62	0.05907092	0.019607	0.03946392	66.81%
6488	TPCODL	CUTTACK	SED	N KOILI	NISCHINTAKOILI	14099	11 KV BUHALA	14099202	BARPADA SAMAL SAHI	3522DT036	63	MIXED	AMI	Yes	100%	29	0.00608158	0.004322	0.00175958	28.93%
6489	TPCODL	CUTTACK	SED	N KOILI	NISCHINTAKOILI	14099	11 KV BUHALA	14099202	BHUHAL PHAKIR PATNA	3522DT037	63	MIXED	AMI	Yes	100%	97	0.04049646	0.028483	0.01201346	29.67%
6490	TPCODL	CUTTACK	SED	N KOILI	NISCHINTAKOILI	14099	11 KV BUHALA	14099202	BARABADA BHUHAL 1	3522DT040	100	MIXED	AMI	Yes	100%	69	0.03824765	0.024017	0.01423065	37.21%
6491	TPCODL	CUTTACK	SED	N KOILI	NISCHINTAKOILI	14099	11 KV BUHALA	14099202	SADHOK NAGAR 63 KVA	3522DT301	63	MIXED	AMI	Yes	100%	61	0.03225152	0.019254	0.01299752	40.30%
6492	TPCODL	CUTTACK	SED	N KOILI	NISCHINTAKOILI	14099	11 KV BUHALA	14099202	TALASAHI	3522DT302	63	MIXED	AMI	Yes	100%	104	0.04301713	0.038094	0.00492313	11.44%
6493	TPCODL	CUTTACK	SED	N KOILI	NISCHINTAKOILI	14099	11 KV BUHALA	14099202	KELAPADIA-2	3522DT303	100	MIXED	AMI	Yes	0%	103	0.06753454	0.033665	0.03386954	50.15%
6494	TPCODL	CUTTACK	SED	N KOILI	NISCHINTAKOILI	14099	11 KV RAMAKRUSNAPUR	14099203	NISCHINTAKOILI BLOCK OFFICE ROAD	3522DT084	100	MIXED	AMI	Yes	100%	154	0.08840416	0.061859	0.02654516	30.03%
6495	TPCODL	CUTTACK	SED	N KOILI	NISCHINTAKOILI	14099	11 KV RAMAKRUSNAPUR	14099203	SWAKTISWARA 1	3522DT087	63	MIXED	AMI	Yes	100%	109	0.0422167	0.036094	0.0061227	14.50%
6496	TPCODL	CUTTACK	SED	N KOILI	NISCHINTAKOILI	14099	11 KV RAMAKRUSNAPUR	14099203	R.K PUR-1	3522DT090	500	MIXED	AMI	Yes	100%	282	0.2147192	0.122967	0.0917522	42.73%

Sl. No.	Zone Name	Circle name	Division name	Name of the Sub-division	Name of the Sub-station	Substation Code	Name of the 11 kV Feeder	Feeder Code	Name of the Location where DT situated	DT code	DT Capacity (kVA)	Predominant consumer type of DT (Domestic/Industrial/Agriculture/Mixed)	Type of metering AMR/AMI/ Communicable/Conventional metered/Unmetered	Status of Meter-whether Functional (Yes/No)	% of data received automatically (if AMR/AMI)	No. of Connected Consumers	Input Energy (MU) (A)	Billed Energy (MU) (B)	Loss (MU) (A-B)	% DT Loss (A-B)/A
6497	TPCODL	CUTTACK	SED	N KOILI	NISCHINTAKOILI	14099	11 KV RAMAKRUSNAPUR	14099203	LALBAG-1	3522DT093	100	MIXED	AMI	Yes	100%	80	0.03516848	0.025162	0.01000648	28.45%
6498	TPCODL	CUTTACK	SED	N KOILI	NISCHINTAKOILI	14099	11 KV RAMAKRUSNAPUR	14099203	EKARUKHI-3	3522DT095	100	MIXED	AMI	Yes	100%	64	0.05016418	0.022744	0.02742018	54.66%
6499	TPCODL	CUTTACK	SED	N KOILI	NISCHINTAKOILI	14099	11 KV RAMAKRUSNAPUR	14099203	MAHAJANPUR-2	3522DT102	100	MIXED	AMI	Yes	100%	121	0.06407176	0.05043	0.01364176	21.29%
6500	TPCODL	CUTTACK	SED	N KOILI	NISCHINTAKOILI	14099	11 KV RAMAKRUSNAPUR	14099203	CHHUALIA	3522DT103	100	MIXED	AMI	Yes	100%	158	0.06791752	0.04321	0.02470752	36.38%
6501	TPCODL	CUTTACK	SED	N KOILI	NISCHINTAKOILI	14099	11 KV RAMAKRUSNAPUR	14099203	MATKATPUR-1	3522DT111	100	MIXED	AMI	Yes	100%	41	0.06091064	0.060617	0.00029364	0.48%
6502	TPCODL	CUTTACK	SED	N KOILI	NISCHINTAKOILI	14099	11 KV RAMAKRUSNAPUR	14099203	JIGNIPUR-2	3522DT115	250	MIXED	AMI	Yes	100%	99	0.0500758	0.027055	0.0230208	45.97%
6503	TPCODL	CUTTACK	SED	N KOILI	NISCHINTAKOILI	14099	11 KV RAMAKRUSNAPUR	14099203	JHAPADA 1	3522DT118	100	MIXED	AMI	Yes	100%	93	0.06578318	0.028592	0.03719118	56.54%
6504	TPCODL	CUTTACK	SED	N KOILI	NISCHINTAKOILI	14099	11 KV RAMAKRUSNAPUR	14099203	FOGALA	3522DT123	100	MIXED	AMI	Yes	100%	79	0.04659372	0.026467	0.02012672	43.20%
6505	TPCODL	CUTTACK	SED	N KOILI	NISCHINTAKOILI	14099	11 KV RAMAKRUSNAPUR	14099203	JAGANNATHPUR-2	3522DT124	100	MIXED	AMI	Yes	100%	115	0.0618357	0.045305	0.0165307	26.73%
6506	TPCODL	CUTTACK	SED	N KOILI	NISCHINTAKOILI	14099	11 KV RAMAKRUSNAPUR	14099203	JAGANNATHPUR 1	3522DT126	100	MIXED	AMI	Yes	100%	98	0.03464456	0.034002	0.00064256	1.85%
6507	TPCODL	CUTTACK	SED	N KOILI	NISCHINTAKOILI	14099	11 KV RAMAKRUSNAPUR	14099203	ARJUN MARG 1	3522DT138	63	MIXED	AMI	Yes	100%	116	0.05438206	0.039662	0.01472006	27.07%
6508	TPCODL	CUTTACK	SED	N KOILI	NISCHINTAKOILI	14099	11 KV RAMAKRUSNAPUR	14099203	RAMAKRISHNA PURAM 2	3522DT143	63	MIXED	AMI	Yes	100%	50	0.02100834	0.015393	0.00561534	26.73%
6509	TPCODL	CUTTACK	SED	N KOILI	ORIKANTA	14212	11 KV GOPINATHPUR	14212201	MALIGA1	3523DT117	100	MIXED	AMI	Yes	67%	111	0.05766198	0.044649	0.01301298	22.57%
6510	TPCODL	CUTTACK	SED	N KOILI	ORIKANTA	14212	11 KV GOPINATHPUR	14212201	NEMALO2	3523DT119	250	MIXED	AMI	Yes	100%	279	0.12159348	0.106136	0.01545748	12.71%
6511	TPCODL	CUTTACK	SED	N KOILI	ORIKANTA	14212	11 KV GOPINATHPUR	14212201	NEMALO3	3523DT120	100	MIXED	AMI	Yes	100%	82	0.03965436	0.026055	0.01359936	34.29%
6512	TPCODL	CUTTACK	SED	N KOILI	ORIKANTA	14212	11 KV GOPINATHPUR	14212201	NEMALO9	3523DT126	500	MIXED	AMI	Yes	100%	175	0.07001664	0.063294	0.00672264	9.60%
6513	TPCODL	CUTTACK	SED	N KOILI	ORIKANTA	14212	11 KV GOPINATHPUR	14212201	MOHAMMED PUR	3523DT138	100	MIXED	AMI	Yes	100%	118	0.03831886	0.033349	0.00496986	12.97%
6514	TPCODL	CUTTACK	SED	N KOILI	ORIKANTA	14212	11 KV GOPINATHPUR	14212201	DIMANDO NO22	3523DT147	100	MIXED	AMI	Yes	100%	73	0.04181634	0.02447	0.01734634	41.48%
6515	TPCODL	CUTTACK	SED	N KOILI	ORIKANTA	14212	11 KV GOPINATHPUR	14212201	ODINGPUR	3523DT157	100	MIXED	AMI	Yes	67%	48	0.05209044	0.011158	0.04093244	78.58%
6516	TPCODL	CUTTACK	SED	N KOILI	ORIKANTA	14212	11 KV GOPINATHPUR	14212201	BALIYA PADA1	3523DT159	100	MIXED	AMI	Yes	100%	105	0.07927272	0.043283	0.03598972	45.40%
6517	TPCODL	CUTTACK	SED	N KOILI	ORIKANTA	14212	11 KV GOPINATHPUR	14212201	FATEHPUR1	3523DT165	100	MIXED	AMI	Yes	67%	76	0.04583246	0.018744	0.02708846	59.10%
6518	TPCODL	CUTTACK	SED	N KOILI	ORIKANTA	14212	11 KV GOPINATHPUR	14212201	BANDHKATIYA2	3523DT177	100	MIXED	AMI	Yes	67%	60	0.06886064	0.015348	0.05351264	77.71%
6519	TPCODL	CUTTACK	SED	N KOILI	ORIKANTA	14212	11 KV GOPINATHPUR	14212201	DAMODAR PUR NERA PANI KI.TANKI	3523DT215	250	MIXED	AMI	Yes	0%	111	0.127037	0.031602	0.095435	75.12%
6520	TPCODL	CUTTACK	SED	N KOILI	ORIKANTA	14212	11 KV GOPINATHPUR	14212201	GOPINATHPUR2	3523DT224	100	MIXED	AMI	Yes	100%	59	0.022402	0.012284	0.010118	45.17%
6521	TPCODL	CUTTACK	SED	N KOILI	ORIKANTA	14212	11 KV GOPINATHPUR	14212201	KORASAHI GOPI NATH PUR	3523DT232	100	MIXED	AMI	Yes	67%	76	0.05629074	0.028194	0.02809674	49.91%
6522	TPCODL	CUTTACK	SED	N KOILI	ORIKANTA	14212	11 KV GOPINATHPUR	14212201	BOILA1	3523DT237	100	MIXED	AMI	Yes	67%	81	0.05635942	0.026155	0.03020442	53.59%
6523	TPCODL	CUTTACK	SED	N KOILI	ORIKANTA	14212	11 KV GOPINATHPUR	14212201	RATILO1	3523DT255	250	MIXED	AMI	Yes	67%	161	0.07534668	0.047824	0.02752268	36.53%
6524	TPCODL	CUTTACK	SED	N KOILI	ORIKANTA	14212	11 KV GOPINATHPUR	14212201	SARODA SAHI	3523DT263	100	MIXED	AMI	Yes	67%	84	0.0579025	0.026067	0.0318355	54.98%
6525	TPCODL	CUTTACK	SED	N KOILI	ORIKANTA	14212	11 KV GOPINATHPUR	14212201	GUALI NO.1	3523DT278	100	MIXED	AMI	Yes	67%	55	0.04137694	0.01501438	0.02636256	63.71%
6526	TPCODL	CUTTACK	SED	N KOILI	ORIKANTA	14212	11 KV GOPINATHPUR	14212201	GUALI NO. 2	3523DT279	100	MIXED	AMI	Yes	67%	87	0.0719724	0.017034	0.0549384	76.33%
6527	TPCODL	CUTTACK	SED	N KOILI	ORIKANTA	14212	11 KV GOPINATHPUR	14212201	MURKUNDI1	3523DT288	100	MIXED	AMI	Yes	67%	42	0.02860206	0.00927383	0.01932823	67.58%
6528	TPCODL	CUTTACK	SED	N KOILI	ORIKANTA	14212	11 KV GOPINATHPUR	14212201	BALARAMPUR2	3523DT293	100	MIXED	AMI	Yes	100%	100	0.05723072	0.024268	0.03296272	57.60%
6529	TPCODL	CUTTACK	SED	N KOILI	ORIKANTA	14212	11 KV BILAHATA	14212202	BABUJANJ PANCHAYAT	3523DT038	100	MIXED	AMI	Yes	67%	106	0.05315298	0.048182	0.00497098	9.35%
6530	TPCODL	CUTTACK	SED	N KOILI	ORIKANTA	14212	11 KV BILAHATA	14212202	BABUJANJ 2	3523DT041	100	MIXED	AMI	Yes	67%	109	0.06605134	0.031303	0.03474834	52.61%
6531	TPCODL	CUTTACK	SED	N KOILI	ORIKANTA	14212	11 KV BILAHATA	14212202	UTTARKUL 2	3523DT052	500	MIXED	AMI	Yes	67%	154	0.05634656	0.046446	0.00990056	17.57%
6532	TPCODL	CUTTACK	SED	N KOILI	ORIKANTA	14212	11 KV BILAHATA	14212202	MUGURIA NILAKANTHA MANDIRA	3523DT057	100	MIXED	AMI	Yes	67%	88	0.06240568	0.03968	0.02272568	36.42%
6533	TPCODL	CUTTACK	SED	N KOILI	ORIKANTA	14212	11 KV BILAHATA	14212202	MUGURIA	3523DT059	100	MIXED	AMI	Yes	67%	100	0.0849131	0.031577	0.0533361	62.81%
6534	TPCODL	CUTTACK	SED	N KOILI	ORIKANTA	14212	11 KV BILAHATA	14212202	GAUDA SAHI	3523DT065	100	MIXED	AMI	Yes	67%	22	0.02213531	0.009115	0.01302031	58.82%
6535	TPCODL	CUTTACK	SED	N KOILI	ORIKANTA	14212	11 KV BILAHATA	14212202	PINPUR PARIDA SAHI	3523DT067	100	MIXED	AMI	Yes	33%	44	0.02407107	0.014216	0.00985507	40.94%
6536	TPCODL	CUTTACK	SED	N KOILI	ORIKANTA	14212	11 KV BILAHATA	14212202	SAFIPUR 1	3523DT068	100	MIXED	AMI	Yes	67%	65	0.02991412	0.016652	0.01326212	44.33%
6537	TPCODL	CUTTACK	SED	N KOILI	ORIKANTA	14212	11 KV BILAHATA	14212202	UTTARKUL SASAN	3523DT081	100	MIXED	AMI	Yes	67%	102	0.05498326	0.035935	0.01904826	34.64%
6538	TPCODL	CUTTACK	SED	N KOILI	ORIKANTA	14212	11 KV BILAHATA	14212202	MEHENDIPUR DARJI SAHI	3523DT082	100	MIXED	AMI	Yes	67%	96	0.04764882	0.043231	0.00441782	9.27%
6539	TPCODL	CUTTACK	SED	N KOILI	ORIKANTA	14212	11 KV BILAHATA	14212202	CHAMPA	3523DT087	100	MIXED	AMI	Yes	67%	113	0.04986608	0.039439	0.01042708	20.91%
6540	TPCODL	CUTTACK	SED	N KOILI	ORIKANTA	14212	11 KV BILAHATA	14212202	ODAKHANDA 1	3523DT089	100	MIXED	AMI	Yes	67%	56	0.01550418	0.010689	0.00481518	31.06%
6541	TPCODL	CUTTACK	SED	N KOILI	ORIKANTA	14212	11 KV BILAHATA	14212202	MANIJANGA 2	3523DT093	200	MIXED	AMI	Yes	67%	211	0.11965148	0.074052	0.04559948	38.11%
6542	TPCODL	CUTTACK	SED	N KOILI	ORIKANTA	14212	11 KV BILAHATA	14212202	BILASAHI	3523DT103	100	MIXED	AMI	Yes	67%	57	0.0633924	0.021518	0.0418744	66.06%
6543	TPCODL	CUTTACK	SED	N KOILI	ORIKANTA	14212	11 KV BILAHATA	14212202	CHARICHHAK	3523DT109	250	MIXED	AMI	Yes	67%	84	0.10628488	0.044572	0.06171288	58.06%
6544	TPCODL	CUTTACK	SED	N KOILI	ORIKANTA	14212	11 KV BILAHATA	14212202	MUSLIM SAHI	3523DT111	100	MIXED	AMI	Yes	67%	37	0.05423166	0.023922	0.03030966	55.89%
6545	TPCODL	CUTTACK	SED	N KOILI	ORIKANTA	14212	11 KV BILAHATA	14212202	BILAHAT 1	3523DT115	250	MIXED	AMI	Yes	67%	67	0.14715776	0.047011	0.10014676	68.05%
6546	TPCODL	CUTTACK	SED	N KOILI	ORIKANTA	14212	11 KV SOGAL	14212203	ORIKANTA SUBSTATION BACK SIDE 1	3523DT364	100	MIXED	AMI	Yes	100%	146	0.07946564	0.049458	0.03000764	37.76%
6547	TPCODL	CUTTACK	SED	N KOILI	ORIKANTA	14212	11 KV SOGAL	14212203	ORIKANTA	3523DT366	100	MIXED	AMI	Yes	100%	51	0.04998148	0.018992	0.03098948	62.00%
6548	TPCODL	CUTTACK	SED	N KOILI	ORIKANTA	14212	11 KV SOGAL	14212203	BHABARCHAND	3523DT372	100	MIXED	AMI	Yes	0%	98	0.09225474	0.026931	0.06532374	70.81%
6549	TPCODL	CUTTACK	SED	N KOILI	ORIKANTA	14212	11 KV SOGAL	14212203	PATENIGAON	3523DT375	100	MIXED	AMI	Yes	67%	34	0.045829	0.01089	0.034939	76.24%
6550	TPCODL	CUTTACK	SED	N KOILI	ORIKANTA	14212	11 KV SOGAL	14212203	TOTAPADA 3	3523DT378	100	MIXED	AMI	Yes	67%	150	0.08340198	0.037886	0.04551598	54.57%
6551	TPCODL	CUTTACK	SED	N KOILI	ORIKANTA	14212	11 KV SOGAL	14212203	SAHALAPUR 4	3523DT385	63	MIXED	AMI	Yes	100%	128	0.04716326	0.03813	0.00903326	19.15%
6552	TPCODL	CUTTACK	SED	N KOILI	ORIKANTA	14212	11 KV SOGAL	14212203	TOTAPADA 2	3523DT388	100	MIXED	AMI	Yes	67%	65	0.02596962	0.012805	0.01316462	50.69%
6553	TPCODL	CUTTACK	SED	N KOILI	ORIKANTA	14212	11 KV SOGAL	14212203	UDAYPUR 1	3523DT389	100	MIXED	AMI	Yes	67%	91	0.05254626	0.023341	0.02920526	55.58%
6554	TPCODL	CUTTACK	SED	N KOILI	ORIKANTA	14212	11 KV SOGAL	14212203	MANGADEIPUR 2	3523DT395	100	MIXED	AMI	Yes	67%	87	0.0380755	0.018356	0.0197195	51.79%
6555	TPCODL	CUTTACK	SED	N KOILI	ORIKANTA	14212	11 KV SOGAL	14212203	SAMITANGA 2	3523DT401	100	MIXED	AMI	Yes	100%	147	0.0532143	0.03652273	0.01669157	31.37%
6556	TPCODL	CUTTACK	SED	N KOILI	ORIKANTA	14212	11 KV SOGAL	14212203	SUGHAL 4	3523DT414	100	MIXED	AMI	Yes	100%	54	0.0294068	0.013716	0.0156908	53.36%
6557	TPCODL	CUTTACK	SED	N KOILI	ORIKANTA	14212	11 KV SOGAL	14212203	ODAKIMIRA MARKET COMPLEX	3523DT419	250	MIXED	AMI	Yes	100%	140	0.08160796	0.050212	0.03139596	38.47%
6558	TPCODL	CUTTACK	SED	N KOILI	ORIKANTA	14212	11 KV SOGAL	14212203	PURANHAT 4	3523DT427	63	MIXED	AMI	Yes	67%	159	0.07009578	0.041082	0.02901378	41.39%
6559	TPCODL	CUTTACK	SED	N KOILI	PALADHUAPADIA	14100	11 KV NISCHINTAKOILI B	14100201	NEW MAA AGENCY	3522DT007	500	MIXED	AMI	Yes	100%	153	0.20446568	0.129896	0.07456968	36.47%
6560	TPCODL	CUTTACK	SED	N KOILI	PALADHUAPADIA	14100	11 KV NISCHINTAKOILI B	14100201	DTR-2	3522DT008	100	MIXED	AMI	Yes	100%	53	0.0704733	0.027697	0.0427763	60.70%
6561	TPCODL	CUTTACK	SED	N KOILI	PALADHUAPADIA	14100	11 KV NISCHINTAKOILI B	14100201	OTHAKA-1	3522DT011	100	MIXED	AMI	Yes	100%	140	0.08790164	0.076988	0.01091364	12.42%
6562	TPCODL	CUTTACK	SED	N KOILI	PALADHUAPADIA	14100	11 KV KHANDASAHI	14100202	SARPADA HOTA SAHI	3522DT044	100	MIXED	AMI	Yes	100%	68	0.0232163	0.017935	0.0052813	22.75%
6563	TPCODL	CUTTACK	SED	N KOILI	PALADHUAPADIA	14100	11 KV KHANDASAHI	14100202	SARAPADA 5	3522DT048	100	MIXED	AMI	Yes	100%	39	0.02801508	0.012638	0.01537708	54.89%
6564	TPCODL	CUTTACK	SED	N KOILI	PALADHUAPADIA	14100	11 KV KHANDASAHI	14100202	BADATHAKAN-3	3522DT055	100	MIXED	AMI	Yes	100%	26	0.02346702	0.013359	0.01010802	43.07%
6565	TPCODL	CUTTACK	SED	N KOILI	PALADHUAPADIA	14100	11 KV KHANDASAHI	14100202	BODHANGA 2	3522DT057	100	MIXED	AMI	Yes	100%	141	0.09122832	0.054431	0.03679732	40.34%
6566	TPCODL	CUTTACK	SED	N KOILI	PALADHUAPADIA	14100	11 KV KHANDASAHI	14100202	BARIK SGAHI	3522DT059	100	MIXED	AMI	Yes	67%	90	0.04434402	0.032143	0.01220102	27.51%
6567	TPCODL	CUTTACK	SED	N KOILI	PALADHUAPADIA	14100	11 KV KHANDASAHI	14100202	BADATHAKAN-1	3522DT064	100	MIXED	AMI	Yes	100%	70	0.02673784	0.024545	0.00219284	8.20%
6568	TPCODL	CUTTACK	SED	N KOILI	RAISUNGUDA (MOD	14309	11 KV DHARMAGATAPUR	14309202	NEAR MISSION SHAKTI GRUH	3532DT271	100	MIXED	AMI	Yes	100%	64	0.06331482	0.019991	0.04332382	68.43%
6569	TPCODL	CUTTACK	SED	N KOILI	RAISUNGUDA (MOD	14309	11 KV MANOHARPUR	14309203	NEAR BARADA VILLAGE 1	3532DT197	100	MIXED	AMI	Yes	67%	68	0.0525669	0.01583	0.0367369	69.89%

Sl. No.	Zone Name	Circle name	Division name	Name of the Sub-division	Name of the Sub-station	Substation Code	Name of the 11 kV Feeder	Feeder Code	Name of the Location where DT situated	DT code	DT Capacity (kVA)	Predominant consumer type of DT (Domestic/Industrial/Agriculture/Mixed)	Type of metering AMR/AMI/ Communicable/Conventional metered/Unmetered	Status of Meter-whether Functional (Yes/No)	% of data received automatically (if AMR/AMI)	No. of Connected Consumers	Input Energy (MU) (A)	Billed Energy (MU) (B)	Loss (MU) (A-B)	% DT Loss (A-B)/A
6570	TPCODL	CUTTACK	SED	SALIPUR	SALIPUR	17021	33 kV SALIPUR	17021401	NANDISAHI	3533DT227	250	MIXED	AMI	Yes	100%	107	0.190488	0.067944	0.122544	64.33%
6571	TPCODL	CUTTACK	SED	SALIPUR	ASURESWAR ODSSP	14311	11 KV SUKARPADA	14311201	HALADHARPUR MUSLIM	3521DT096	63	MIXED	AMI	Yes	0%	43	0.0448837	0.018995	0.0258887	57.68%
6572	TPCODL	CUTTACK	SED	SALIPUR	ASURESWAR ODSSP	14311	11 KV LUNA	14311203	NARAJPUR	3521DT248	100	MIXED	AMI	Yes	67%	23	0.03275788	0.011983	0.02077488	63.42%
6573	TPCODL	CUTTACK	SED	SALIPUR	BAHUGRAM-1	14366	11 KV BAHUGRAM-1 GO	14366201	BAHADULAPATANA COLD STORAGE	3531DT123	100	MIXED	AMI	Yes	100%	80	0.08934273	0.046559	0.04278373	47.89%
6574	TPCODL	CUTTACK	SED	SALIPUR	BAHUGRAM-1	14366	11 KV BAHUGRAM-1 GO	14366201	ISLAMPUR 2	3531DT148	100	MIXED	AMI	Yes	100%	113	0.0841631	0.062095	0.0220681	26.22%
6575	TPCODL	CUTTACK	SED	SALIPUR	BAHUGRAM-1	14366	11 KV BAHUGRAM-1 GO	14366201	NRUSINGHA TEMPLE	3531DT149	100	MIXED	AMI	Yes	0%	92	0.10210228	0.045178	0.05692428	55.75%
6576	TPCODL	CUTTACK	SED	SALIPUR	BAHUGRAM-1	14366	11 KV BAHUGRAM-1 GO	14366201	MADHYAKACHHA NEAR RWSS	3531DT157	100	MIXED	AMI	Yes	100%	97	0.07864172	0.049473	0.02916872	37.09%
6577	TPCODL	CUTTACK	SED	SALIPUR	BAHUGRAM-1	14366	11 KV BAHUGRAM-1 GO	14366201	MADHYAKACHHA MISRA SAHI	3531DT158	100	MIXED	AMI	Yes	100%	45	0.04425072	0.030503	0.01374772	31.07%
6578	TPCODL	CUTTACK	SED	SALIPUR	BAHUGRAM-1	14366	11 KV BAHUGRAM-1 GO	14366201	KAZIBAZAR	3531DT159	500	MIXED	AMI	Yes	100%	267	0.2390644	0.145622	0.0934424	39.09%
6579	TPCODL	CUTTACK	SED	SALIPUR	BAHUGRAM-1	14366	11 KV BAHUGRAM-1 GO	14366201	PADMAPUR	3531DT168	100	MIXED	AMI	Yes	100%	92	0.07138588	0.049144	0.02224188	31.16%
6580	TPCODL	CUTTACK	SED	SALIPUR	BAHUGRAM-1	14366	11 KV BAHUGRAM-1 GO	14366201	UPPAR BAZAR	3531DT169	250	MIXED	AMI	Yes	100%	188	0.2196644	0.131828	0.0878364	39.99%
6581	TPCODL	CUTTACK	SED	SALIPUR	BAHUGRAM-1	14366	11 KV BAHUGRAM-1 GO	14366201	CHAMPTI VILLAGE	3531DT182	500	MIXED	AMI	Yes	0%	201	0.1529576	0.130215	0.0227426	14.87%
6582	TPCODL	CUTTACK	SED	SALIPUR	BAHUGRAM-1	14366	11 KV BAHUGRAM-1 GO	14366201	CROSS ARM PADIA-2	3531DT184	200	MIXED	AMI	Yes	100%	235	0.10373692	0.087928	0.01580892	15.24%
6583	TPCODL	CUTTACK	SED	SALIPUR	BAHUGRAM-1	14366	11 KV BAHUGRAM-1 GO	14366201	CHAMPTI ANDEI SAHI 1	3531DT187	500	MIXED	AMI	Yes	0%	212	0.1776904	0.136898	0.0407924	22.96%
6584	TPCODL	CUTTACK	SED	SALIPUR	BAHUGRAM-1	14366	11 KV BAHUGRAM-1 GO	14366201	BHAIRAPUR NUAPATANA	3531DT188	100	MIXED	AMI	Yes	100%	83	0.08130256	0.053199	0.02810356	34.57%
6585	TPCODL	CUTTACK	SED	SALIPUR	BAHUGRAM-1	14366	11 KV BAHUGRAM-1 GO	14366201	BHAIRAPUR VILL 1	3531DT202	100	MIXED	AMI	Yes	33%	110	0.14152078	0.066246	0.07527478	53.19%
6586	TPCODL	CUTTACK	SED	SALIPUR	BAHUGRAM-1	14366	11 KV BAHUGRAM-1 GO	14366201	KANIBATI BHAIRAPUR	3531DT206	100	MIXED	AMI	Yes	100%	30	0.03786894	0.016818	0.02105094	55.59%
6587	TPCODL	CUTTACK	SED	SALIPUR	BAHUGRAM-1	14366	11 KV BAHUGRAM-1 GO	14366201	GUNJARPUR ANDEI SAHI	3531DT210	100	MIXED	AMI	Yes	33%	120	0.12497244	0.065268	0.05970444	47.77%
6588	TPCODL	CUTTACK	SED	SALIPUR	BAHUGRAM-1	14366	11 KV BAHUGRAM-1 GO	14366201	GUNJARPUR MAHADEV SAHI	3531DT217	250	MIXED	AMI	Yes	33%	70	0.09099736	0.055783	0.03521436	38.70%
6589	TPCODL	CUTTACK	SED	SALIPUR	BAHUGRAM-1	14366	11 KV BAHUGRAM-1 GO	14366201	GUNJARPUR NEAR MAJSID	3531DT218	100	MIXED	AMI	Yes	100%	79	0.09909566	0.044123	0.05497266	55.47%
6590	TPCODL	CUTTACK	SED	SALIPUR	BAHUGRAM-1	14366	11 KV BAHUGRAM-1 GO	14366201	ANANTAPUR VILL	3531DT226	100	MIXED	AMI	Yes	100%	59	0.0565568	0.040131	0.0164258	29.04%
6591	TPCODL	CUTTACK	SED	SALIPUR	BAHUGRAM-1	14366	11 KV BAHUGRAM-1 GO	14366201	CHAMPATI 1	3531DT296	100	MIXED	AMI	Yes	100%	72	0.04362615	0.03648663	0.00713952	16.37%
6592	TPCODL	CUTTACK	SED	SALIPUR	BAHUGRAM-1	14366	11 KV BAHUGRAM-1 GO	14366201	CHAMPATI 6	3531DT301	100	MIXED	AMI	Yes	100%	71	0.09466628	0.037361	0.05730528	60.53%
6593	TPCODL	CUTTACK	SED	SALIPUR	BAHUGRAM-1	14366	11 KV BAHUGRAM-1 GO	14366201	SATNATIA 7	3531DT309	250	MIXED	AMI	Yes	100%	77	0.13423576	0.03767	0.09656576	71.94%
6594	TPCODL	CUTTACK	SED	SALIPUR	BAHUGRAM-1	14366	11 KV BAHUGRAM-1 GO	14366201	GODI SAHI	3531DT316	63	MIXED	AMI	Yes	100%	70	0.0716218	0.040972	0.0306498	42.79%
6595	TPCODL	CUTTACK	SED	SALIPUR	BAHUGRAM-1	14366	11 KV BAHUGRAM-1 ICH	14366202	HATIPADA	3531DT061	100	MIXED	AMI	Yes	100%	89	0.07087893	0.056343	0.01453593	20.51%
6596	TPCODL	CUTTACK	SED	SALIPUR	BAHUGRAM-1	14366	11 KV BAHUGRAM-1 ICH	14366202	TRILOCHANPUR GHADEISAHI	3531DT062	100	MIXED	AMI	Yes	0%	98	0.08805096	0.050462	0.03758896	42.69%
6597	TPCODL	CUTTACK	SED	SALIPUR	BAHUGRAM-1	14366	11 KV BAHUGRAM-1 ICH	14366202	KOTHABADA MUSLIM SAHI	3531DT073	100	MIXED	AMI	Yes	100%	99	0.18517448	0.059599	0.12557548	67.81%
6598	TPCODL	CUTTACK	SED	SALIPUR	BAHUGRAM-1	14366	11 KV BAHUGRAM-1 ICH	14366202	TRILOCHANPUR NEAR SWAPNESWAR	3531DT075	100	MIXED	AMI	Yes	100%	89	0.05890842	0.037918	0.02099042	35.63%
6599	TPCODL	CUTTACK	SED	SALIPUR	BAHUGRAM-1	14366	11 KV BAHUGRAM-1 ICH	14366202	TRILOCHANPUR VILL3	3531DT077	100	MIXED	AMI	Yes	100%	46	0.05658619	0.030149	0.02643719	46.72%
6600	TPCODL	CUTTACK	SED	SALIPUR	BAHUGRAM-2	14098	11 KV NANDOLA	14098201	SAMBHUPUR	3531DT087	100	MIXED	AMI	Yes	100%	152	0.065746	0.057791	0.007955	12.10%
6601	TPCODL	CUTTACK	SED	SALIPUR	BAHUGRAM-2	14098	11 KV NANDOLA	14098201	VATAPADA MANDAP	3531DT088	100	MIXED	AMI	Yes	100%	136	0.06849658	0.064	0.00449658	6.56%
6602	TPCODL	CUTTACK	SED	SALIPUR	BAHUGRAM-2	14098	11 KV NANDOLA	14098201	BISWANATHPUR(NIYAMATPUR)	3531DT320	100	MIXED	AMI	Yes	100%	112	0.06265314	0.043789	0.01886414	30.11%
6603	TPCODL	CUTTACK	SED	SALIPUR	BAHUGRAM-2	14098	11 KV NANDOLA	14098201	NIAMATPUR	3531DT322	250	MIXED	AMI	Yes	100%	176	0.17159744	0.125336	0.04626144	26.96%
6604	TPCODL	CUTTACK	SED	SALIPUR	BAHUGRAM-2	14098	11 KV NANDOLA	14098201	BISWANATHPUR (NUAMAL) 1	3534DT018	100	MIXED	AMI	Yes	100%	76	0.05638144	0.038893	0.01748844	31.02%
6605	TPCODL	CUTTACK	SED	SALIPUR	BAHUGRAM-2	14098	11 KV BAHUGRAM PADN	14098202	LAKSHINARAYAN PUR 2	3531DT011	100	MIXED	AMI	Yes	67%	192	0.10349288	0.073586	0.02990688	28.90%
6606	TPCODL	CUTTACK	SED	SALIPUR	BAHUGRAM-2	14098	11 KV BAHUGRAM PADN	14098202	SATYABHAMAPUR 4	3531DT028	100	MIXED	AMI	Yes	100%	89	0.10660316	0.047322	0.05928116	55.61%
6607	TPCODL	CUTTACK	SED	SALIPUR	BAHUGRAM-2	14098	11 KV BAHUGRAM PADN	14098202	GANESWAR PUR	3531DT031	100	MIXED	AMI	Yes	100%	70	0.03342154	0.024794	0.00862754	25.81%
6608	TPCODL	CUTTACK	SED	SALIPUR	BAHUGRAM-2	14098	11 KV BAHUGRAM PADN	14098202	GOPINATHPUR SASAN SAHI	3531DT034	100	MIXED	AMI	Yes	100%	88	0.0768843	0.039135	0.0377493	49.10%
6609	TPCODL	CUTTACK	SED	SALIPUR	BAHUGRAM-2	14098	11 KV BAHUGRAM PADN	14098202	PADHANPADA PARIDA SAHI	3531DT042	100	MIXED	AMI	Yes	100%	81	0.03024872	0.024192	0.00605672	20.02%
6610	TPCODL	CUTTACK	SED	SALIPUR	BAHUGRAM-2	14098	11 KV BAHUGRAM PADN	14098202	PADHANPADA VILLAGE	3531DT045	100	MIXED	AMI	Yes	100%	96	0.0428914	0.029545	0.0133464	31.12%
6611	TPCODL	CUTTACK	SED	SALIPUR	BAHUGRAM-2	14098	11 KV BAHUGRAM PADN	14098202	MALIHATA SCHOOL	3531DT054	63	MIXED	AMI	Yes	67%	118	0.05393025	0.053224	0.00070625	1.31%
6612	TPCODL	CUTTACK	SED	SALIPUR	BAHUGRAM-2	14098	11 KV BAHUGRAM PADN	14098202	CAHAPADA 2	3531DT055	100	MIXED	AMI	Yes	67%	169	0.0747303	0.052847	0.0218833	29.28%
6613	TPCODL	CUTTACK	SED	SALIPUR	BAHUGRAM-2	14098	11 KV PATAPUR	14098204	BAHUGRAM BAZAR	3531DT228	100	MIXED	AMI	Yes	100%	227	0.14048764	0.128977	0.01151064	8.19%
6614	TPCODL	CUTTACK	SED	SALIPUR	BAHUGRAM-2	14098	11 KV PATAPUR	14098204	KHARAKHIA 4 POLE	3531DT230	100	MIXED	AMI	Yes	33%	120	0.09306815	0.076192	0.01687615	18.13%
6615	TPCODL	CUTTACK	SED	SALIPUR	BAHUGRAM-2	14098	11 KV PATAPUR	14098204	TENTOLA WORD1	3531DT263	100	MIXED	AMI	Yes	33%	70	0.02621977	0.023984	0.00223577	8.53%
6616	TPCODL	CUTTACK	SED	SALIPUR	BAHUGRAM-2	14098	11 KV PATAPUR	14098204	LAXMI BIHAR	3531DT283	100	MIXED	AMI	Yes	100%	94	0.08583944	0.062541	0.02329844	27.14%
6617	TPCODL	CUTTACK	SED	SALIPUR	BAHUGRAM-2	14098	11 KV PATAPUR	14098204	BARABUDIA JENA SAHI	3531DT286	100	MIXED	AMI	Yes	100%	84	0.08061536	0.038656	0.04195936	52.05%
6618	TPCODL	CUTTACK	SED	SALIPUR	BAHUGRAM-2	14098	11 KV PATAPUR	14098204	JHADESWAR	3531DT290	100	MIXED	AMI	Yes	100%	58	0.05604994	0.026318	0.02973194	53.05%
6619	TPCODL	CUTTACK	SED	SALIPUR	DANPUR	14164	11 KV CHANDOLA	14164203	CHAKAR PUR 1	3511DT069	250	MIXED	AMI	Yes	100%	175	0.09668936	0.06366	0.03302936	34.16%
6620	TPCODL	CUTTACK	SED	SALIPUR	ERAKANA (GOKUNA	14310	11 KV LAXMINARAYANPU	14310201	SAIM VILLAGE	3511DT243	100	MIXED	AMI	Yes	100%	27	0.0364471	0.007564	0.0288831	79.25%
6621	TPCODL	CUTTACK	SED	SALIPUR	JAGATPUR (IPICOL)	14241	11 KV KHAIRA	14241203	SUNAKHALA CHAK 5	3531DT368	100	MIXED	AMI	Yes	67%	105	0.10598516	0.04157	0.06441516	60.78%
6622	TPCODL	CUTTACK	SED	SALIPUR	JAPAKUDA ODSSP	14312	11 KV JAPAKUDA	14312201	KATARAPARA 1	3534DT130	160	MIXED	AMI	Yes	100%	188	0.13303168	0.071182	0.06184968	46.49%
6623	TPCODL	CUTTACK	SED	SALIPUR	JAPAKUDA ODSSP	14312	11 KV JAPAKUDA	14312201	KATARAPA JAGANNATHA TEMPLE	3534DT131	100	MIXED	AMI	Yes	100%	125	0.05505216	0.036155	0.01889716	34.33%
6624	TPCODL	CUTTACK	SED	SALIPUR	JAPAKUDA ODSSP	14312	11 KV JAPAKUDA	14312201	MUTARUPA MAUSIMAA MANDIR	3534DT133	100	MIXED	AMI	Yes	100%	64	0.02858604	0.023413	0.00517304	18.10%
6625	TPCODL	CUTTACK	SED	SALIPUR	JAPAKUDA ODSSP	14312	11 KV JAPAKUDA	14312201	AURUDAPUR	3534DT142	100	MIXED	AMI	Yes	100%	77	0.05221738	0.028201	0.02401638	45.99%
6626	TPCODL	CUTTACK	SED	SALIPUR	JAPAKUDA ODSSP	14312	11 KV JAPAKUDA	14312201	MAHANA MUSLIM SAHI	3534DT148	100	MIXED	AMI	Yes	67%	86	0.07867998	0.050147	0.02853298	36.26%
6627	TPCODL	CUTTACK	SED	SALIPUR	JAPAKUDA ODSSP	14312	11 KV JAPAKUDA	14312201	BHATA 1	3534DT165	100	MIXED	AMI	Yes	100%	87	0.04006132	0.031366	0.00869532	21.71%
6628	TPCODL	CUTTACK	SED	SALIPUR	JAPAKUDA ODSSP	14312	11 KV JAPAKUDA	14312201	BODA MUNELDEI CHAKA	3534DT207	100	MIXED	AMI	Yes	100%	98	0.04282234	0.03587	0.00695234	16.24%
6629	TPCODL	CUTTACK	SED	SALIPUR	JAPAKUDA ODSSP	14312	11 KV BHIMDASPUR	14312202	SIDHO 100 KVA	3532DT036	100	MIXED	AMI	Yes	100%	130	0.07235746	0.032189	0.04016846	55.51%
6630	TPCODL	CUTTACK	SED	SALIPUR	JAPAKUDA ODSSP	14312	11 KV BHIMDASPUR	14312202	BHIMDAS PUR	3532DT055	100	MIXED	AMI	Yes	100%	104	0.05403032	0.033046	0.02098432	38.84%
6631	TPCODL	CUTTACK	SED	SALIPUR	JAPAKUDA ODSSP	14312	11 KV BHIMDASPUR	14312202	ODASING SANKHARI SAHI	3532DT061	100	MIXED	AMI	Yes	100%	60	0.0368657	0.019795	0.0170707	46.31%
6632	TPCODL	CUTTACK	SED	SALIPUR	JAPAKUDA ODSSP	14312	11 KV BHIMDASPUR	14312202	ODA SINGH ROAD2	3532DT064	100	MIXED	AMI	Yes	100%	51	0.03265542	0.022024	0.01063142	32.56%
6633	TPCODL	CUTTACK	SED	SALIPUR	JAPAKUDA ODSSP	14312	11 KV BHIMDASPUR	14312202	MALA ROAD3	3532DT074	100	MIXED	AMI	Yes	100%	58	0.03058852	0.02189	0.00869852	28.44%
6634	TPCODL	CUTTACK	SED	SALIPUR	JAPAKUDA ODSSP	14312	11 KV BHIMDASPUR	14312202	TILADA CLUB	3532DT075	100	MIXED	AMI	Yes	100%	140	0.08931902	0.067544	0.02177502	24.38%
6635	TPCODL	CUTTACK	SED	SALIPUR	JAPAKUDA ODSSP	14312	11 KV BHIMDASPUR	14312202	JAPAKUDA RODA4	3532DT080	100	MIXED	AMI	Yes	100%	59	0.0758338	0.027609	0.0482248	63.59%
6636	TPCODL	CUTTACK	SED	SALIPUR	JAPAKUDA ODSSP	14312	11 KV BHIMDASPUR	14312202	JIBASHAKTI CLUB	3532DT084	100	MIXED	AMI	Yes	100%	38	0.04995102	0.019119	0.03083202	61.72%
6637	TPCODL	CUTTACK	SED	SALIPUR	JAPAKUDA ODSSP	14312	11 KV BHIMDASPUR	14312202	TILDA PIRA BABA	3532DT090	100	MIXED	AMI	Yes	100%	54	0.07860902	0.0326	0.04600902	58.53%
6638	TPCODL	CUTTACK	SED	SALIPUR	JAPAKUDA ODSSP	14312	11 KV RAMESWAR SOUR	14312203	NEAR BY MAHASINGHPUR2 ROUL	3531DT344	100	MIXED	AMI	Yes	67%	117	0.13159561	0.053399	0.07819661	59.42%
6639	TPCODL	CUTTACK	SED	SALIPUR	JAPAKUDA ODSSP	14312	11 KV RAMESWAR SOUR	14312203	RAMESWAR	3534DT085	100	MIXED	AMI	Yes	100%	66	0.037407	0.02062	0.016787	44.88%
6640	TPCODL	CUTTACK	SED	SALIPUR	JAPAKUDA ODSSP	14312	11 KV RAMESWAR SOUR	14312203	NEAR BY BADA BHAIMRAJ PUR 2	3534DT095	100	MIXED	AMI	Yes	100%	95	0.09024232	0.036692	0.05355032	59.34%
6641	TPCODL	CUTTACK	SED	SALIPUR	JAPAKUDA ODSSP	14312	11 KV RAMESWAR SOUR	14312203	RAMESWARPUR	3534DT107	63	MIXED	AMI	Yes	100%	90	0.05514098	0.02888	0.02626098	47.63%
6642	TPCODL	CUTTACK	SED	SALIPUR	JAPAKUDA ODSSP	14312	11 KV RAMESWAR SOUR	14312203	SOURI CHANDI	3534DT109	100	MIXED	AMI	Yes	100%	39	0.02643502	0.009237	0.01719802	65.06%

Sl. No.	Zone Name	Circle name	Division name	Name of the Sub-division	Name of the Sub-station	Substation Code	Name of the 11 kV Feeder	Feeder Code	Name of the Location where DT situated	DT code	DT Capacity (kVA)	Predominant consumer type of DT (Domestic/Industrial/Agriculture/Mixed)	Type of metering AMR/AMI/ Communicable/Conventional metered/Unmetered	Status of Meter-whether Functional (Yes/No)	% of data received automatically (if AMR/AMI)	No. of Connected Consumers	Input Energy (MU) (A)	Billed Energy (MU) (B)	Loss (MU) (A-B)	% DT Loss (A-B)/A
6643	TPCODL	CUTTACK	SED	SALIPUR	JAPAKUDA ODSSP	14312	11 KV RAMESWAR SOUR	14312203	MALARIPUR	3534DT113	100	MIXED	AMI	Yes	100%	142	0.07332959	0.052989	0.02034059	27.74%
6644	TPCODL	CUTTACK	SED	SALIPUR	JAPAKUDA ODSSP	14312	11 KV RAMESWAR SOUR	14312203	TELI SAHI	3534DT116	100	MIXED	AMI	Yes	100%	120	0.06231028	0.047381	0.01492928	23.96%
6645	TPCODL	CUTTACK	SED	SALIPUR	JAPAKUDA ODSSP	14312	11 KV RAMESWAR SOUR	14312203	MARKET	3534DT117	100	MIXED	AMI	Yes	100%	115	0.05860708	0.056626	0.00198108	3.38%
6646	TPCODL	CUTTACK	SED	SALIPUR	JAPAKUDA ODSSP	14312	11 KV RAMESWAR SOUR	14312203	SURALA	3534DT124	63	MIXED	AMI	Yes	100%	125	0.06878056	0.049574	0.01920656	27.92%
6647	TPCODL	CUTTACK	SED	SALIPUR	JAPAKUDA ODSSP	14312	11 KV MALAMOUDA	14312204	MANGALA TEMPLE	3534DT027	100	MIXED	AMI	Yes	100%	95	0.07273546	0.031637	0.04109846	56.50%
6648	TPCODL	CUTTACK	SED	SALIPUR	JAPAKUDA ODSSP	14312	11 KV MALAMOUDA	14312204	NEAR MAABELSYARI TEMPLE	3534DT043	100	MIXED	AMI	Yes	100%	74	0.04434306	0.016923	0.02742006	61.84%
6649	TPCODL	CUTTACK	SED	SALIPUR	JAPAKUDA ODSSP	14312	11 KV MALAMOUDA	14312204	NEAR MALA BAJARA	3534DT050	100	MIXED	AMI	Yes	67%	68	0.02900592	0.022289	0.00671692	23.16%
6650	TPCODL	CUTTACK	SED	SALIPUR	JAPAKUDA ODSSP	14312	11 KV MALAMOUDA	14312204	HANUMAN MANDIR	3534DT052	100	MIXED	AMI	Yes	100%	125	0.05785714	0.038689	0.01916814	33.13%
6651	TPCODL	CUTTACK	SED	SALIPUR	JAPAKUDA ODSSP	14312	11 KV MALAMOUDA	14312204	MALA LENKA SAHI-3	3534DT054	100	MIXED	AMI	Yes	100%	111	0.12077612	0.030794	0.08998212	74.50%
6652	TPCODL	CUTTACK	SED	SALIPUR	MAHANGA	14097	11 KV KUANPALA	14097202	NURTANGA-3	3513DT101	100	MIXED	AMI	Yes	67%	159	0.04264866	0.03444	0.00820866	19.25%
6653	TPCODL	CUTTACK	SED	SALIPUR	MAHANGA	14097	11 KV CHAINPAL	14097203	MATIPARILO RWSS	3513DT052	100	MIXED	AMI	Yes	100%	97	0.02998318	0.019638	0.01034518	34.50%
6654	TPCODL	CUTTACK	SED	SALIPUR	NIALI	14106	11 KV TOLA	14106204	BAGALGAR BUS STAND	3341DT206	100	MIXED	AMI	Yes	67%	62	0.05656136	0.02574	0.03082136	54.49%
6655	TPCODL	CUTTACK	SED	SALIPUR	NISCHINTAKOILI	14099	11 KV RAMAKRUSNAPUR	14099203	DHEPADA 1	3513DT271	100	MIXED	AMI	Yes	100%	86	0.06948092	0.040014	0.02946692	42.41%
6656	TPCODL	CUTTACK	SED	SALIPUR	NISCHINTAKOILI	14099	11 KV RAMAKRUSNAPUR	14099203	JIGNIPUR-1	3522DT107	100	MIXED	AMI	Yes	100%	126	0.04812286	0.038816	0.00930686	19.34%
6657	TPCODL	CUTTACK	SED	SALIPUR	ORIKANTA	14212	11 KV GOPINATHPUR	14212201	DEMANDO 100 KVA	3523DT152	100	MIXED	AMI	Yes	100%	130	0.04817528	0.038651	0.00952428	19.77%
6658	TPCODL	CUTTACK	SED	SALIPUR	RAISUNGUDA (MOI	14309	11 KV RAISUNGUDA BAZ	14309201	RAISUNGUDA-2	3532DT092	250	MIXED	AMI	Yes	100%	117	0.10339916	0.049813	0.05358616	51.82%
6659	TPCODL	CUTTACK	SED	SALIPUR	RAISUNGUDA (MOI	14309	11 KV RAISUNGUDA BAZ	14309201	RAISUNGUDA-1	3532DT093	250	MIXED	AMI	Yes	100%	152	0.12315008	0.056654	0.06649608	54.00%
6660	TPCODL	CUTTACK	SED	SALIPUR	RAISUNGUDA (MOI	14309	11 KV DHARMAGATAPUR	14309202	MIRZAPUR 5	3532DT100	100	MIXED	AMI	Yes	100%	110	0.09034864	0.064097	0.02625164	29.06%
6661	TPCODL	CUTTACK	SED	SALIPUR	RAISUNGUDA (MOI	14309	11 KV DHARMAGATAPUR	14309202	GANGESWAR SCHOOL 1	3532DT101	100	MIXED	AMI	Yes	33%	78	0.0278076	0.021914	0.0058936	21.19%
6662	TPCODL	CUTTACK	SED	SALIPUR	RAISUNGUDA (MOI	14309	11 KV DHARMAGATAPUR	14309202	CHHOTINATARA 2	3532DT113	100	MIXED	AMI	Yes	100%	21	0.01612684	0.005855	0.01027184	63.69%
6663	TPCODL	CUTTACK	SED	SALIPUR	RAISUNGUDA (MOI	14309	11 KV DHARMAGATAPUR	14309202	BHUIYA SAHI 2	3532DT127	100	MIXED	AMI	Yes	100%	76	0.03972631	0.01825	0.02147631	54.06%
6664	TPCODL	CUTTACK	SED	SALIPUR	RAISUNGUDA (MOI	14309	11 KV DHARMAGATAPUR	14309202	NEAR LAXMI MEDICINE STORE	3532DT143	100	MIXED	AMI	Yes	100%	68	0.08631496	0.031194	0.05512096	63.86%
6665	TPCODL	CUTTACK	SED	SALIPUR	RAISUNGUDA (MOI	14309	11 KV DHARMAGATAPUR	14309202	PAIKAPUR 2	3532DT147	100	MIXED	AMI	Yes	100%	88	0.04604184	0.028587	0.01745484	37.91%
6666	TPCODL	CUTTACK	SED	SALIPUR	RAISUNGUDA (MOI	14309	11 KV MANOHARPUR	14309203	RAIGUAN	3522DT285	63	MIXED	AMI	Yes	100%	74	0.02591702	0.022112	0.00380502	14.68%
6667	TPCODL	CUTTACK	SED	SALIPUR	RAISUNGUDA (MOI	14309	11 KV MANOHARPUR	14309203	NEAR DHUNHA SAHI VILLAGE 3	3532DT184	100	MIXED	AMI	Yes	0%	85	0.06730566	0.035805	0.03150066	46.80%
6668	TPCODL	CUTTACK	SED	SALIPUR	RAISUNGUDA (MOI	14309	11 KV MANOHARPUR	14309203	NEAR DHUNHA SAHI VILLAGE 4	3532DT204	100	MIXED	AMI	Yes	100%	127	0.06619908	0.037609	0.02859008	43.19%
6669	TPCODL	CUTTACK	SED	SALIPUR	RAISUNGUDA (MOI	14309	11 KV MANOHARPUR	14309203	NEAR KUSHAMBI CHHAKA MAIDUNN	3532DT207	100	MIXED	AMI	Yes	0%	69	0.06958794	0.030505	0.03908294	56.16%
6670	TPCODL	CUTTACK	SED	SALIPUR	RAISUNGUDA (MOI	14309	11 KV MANOHARPUR	14309203	NEAR KARAMUNHA VILLAGE 1	3532DT235	100	MIXED	AMI	Yes	67%	113	0.06536602	0.025657	0.03970902	60.75%
6671	TPCODL	CUTTACK	SED	SALIPUR	RAISUNGUDA (MOI	14309	11 KV MANOHARPUR	14309203	SAIGODA 2	3532DT243	63	MIXED	AMI	Yes	100%	48	0.0566766	0.024804	0.0318726	56.24%
6672	TPCODL	CUTTACK	SED	SALIPUR	RAISUNGUDA (MOI	14309	11 KV MANOHARPUR	14309203	SAMAL SAHI GADA	3532DT280	100	MIXED	AMI	Yes	67%	86	0.09682972	0.029521	0.06730872	69.51%
6673	TPCODL	CUTTACK	SED	SALIPUR	SALIPUR	14095	11 KV NAIGUAN	14095201	TVS SHOWROOM	3533DT096	500	MIXED	AMI	Yes	100%	118	0.17918832	0.161114	0.01807432	10.09%
6674	TPCODL	CUTTACK	SED	SALIPUR	SALIPUR	14095	11 KV NAIGUAN	14095201	TOSHALI STACKCHER	3533DT104	500	MIXED	AMI	Yes	0%	78	0.11390564	0.047689	0.06621664	58.13%
6675	TPCODL	CUTTACK	SED	SALIPUR	SALIPUR	14095	11 KV NAIGUAN	14095201	KANTA SAHI	3533DT111	500	MIXED	AMI	Yes	100%	95	0.12961176	0.078099	0.05151276	39.74%
6676	TPCODL	CUTTACK	SED	SALIPUR	SALIPUR	14095	11 KV NAIGUAN	14095201	RAGHABPUR	3533DT116	100	MIXED	AMI	Yes	100%	58	0.05230272	0.028715	0.02358772	45.10%
6677	TPCODL	CUTTACK	SED	SALIPUR	SALIPUR	14095	11 KV NAIGUAN	14095201	NAIGUAN ROAD-1	3533DT119	100	MIXED	AMI	Yes	100%	167	0.11096298	0.089932	0.02103098	18.95%
6678	TPCODL	CUTTACK	SED	SALIPUR	SALIPUR	14095	11 KV NAIGUAN	14095201	NAIGUAN ROAD-2	3533DT122	100	MIXED	AMI	Yes	100%	86	0.07573686	0.04215	0.03358686	44.35%
6679	TPCODL	CUTTACK	SED	SALIPUR	SALIPUR	14095	11 KV NAIGUAN	14095201	BK TALKIES	3533DT125	500	MIXED	AMI	Yes	100%	379	0.23634176	0.199495	0.03684676	15.59%
6680	TPCODL	CUTTACK	SED	SALIPUR	SALIPUR	14095	11 KV NAIGUAN	14095201	BALISAHI	3533DT130	100	MIXED	AMI	Yes	33%	164	0.0880097	0.073329	0.0146807	16.68%
6681	TPCODL	CUTTACK	SED	SALIPUR	SALIPUR	14095	11 KV NAIGUAN	14095201	SISUA CENAL BRIDGE	3533DT131	100	MIXED	AMI	Yes	100%	83	0.03930962	0.037864	0.00144562	3.68%
6682	TPCODL	CUTTACK	SED	SALIPUR	SALIPUR	14095	11 KV NAIGUAN	14095201	PARTY OFFICE	3533DT132	250	MIXED	AMI	Yes	0%	27	0.04166732	0.012472	0.02919532	70.07%
6683	TPCODL	CUTTACK	SED	SALIPUR	SALIPUR	14095	11 KV NAIGUAN	14095201	RELIANCE TRENDS	3533DT140	100	MIXED	AMI	Yes	100%	61	0.0498176	0.025198	0.0246196	49.42%
6684	TPCODL	CUTTACK	SED	SALIPUR	SALIPUR	14095	11 KV NAIGUAN	14095201	MAHENDRA POLO	3533DT145	100	MIXED	AMI	Yes	100%	208	0.12808826	0.070819	0.05726926	44.71%
6685	TPCODL	CUTTACK	SED	SALIPUR	SALIPUR	14095	11 KV NAIGUAN	14095201	RAGHABPUR-3	3533DT148	75	MIXED	AMI	Yes	100%	125	0.07692452	0.046206	0.03071852	39.93%
6686	TPCODL	CUTTACK	SED	SALIPUR	SALIPUR	14095	11 KV KENDUPATNA	14095202	ICE FACTORY -1	3533DT158	250	MIXED	AMI	Yes	0%	72	0.1867064	0.049727	0.1369794	73.37%
6687	TPCODL	CUTTACK	SED	SALIPUR	SALIPUR	14095	11 KV KENDUPATNA	14095202	JAHAGIRABAD	3533DT161	250	MIXED	AMI	Yes	100%	41	0.15297348	0.037545	0.11542848	75.46%
6688	TPCODL	CUTTACK	SED	SALIPUR	SALIPUR	14095	11 KV KENDUPATNA	14095202	KHOLANPUR	3533DT163	100	MIXED	AMI	Yes	0%	100	0.0554404	0.052576	0.0028644	5.17%
6689	TPCODL	CUTTACK	SED	SALIPUR	SALIPUR	14095	11 KV KENDUPATNA	14095202	BETEI-2	3533DT168	100	MIXED	AMI	Yes	0%	74	0.12678958	0.047209	0.07958058	62.77%
6690	TPCODL	CUTTACK	SED	SALIPUR	SALIPUR	14095	11 KV KENDUPATNA	14095202	SUNA KHANDI	3533DT173	100	MIXED	AMI	Yes	100%	187	0.07152908	0.067612	0.00391708	5.48%
6691	TPCODL	CUTTACK	SED	SALIPUR	SALIPUR	14095	11 KV KENDUPATNA	14095202	KASHIPUR-1	3533DT174	200	MIXED	AMI	Yes	100%	89	0.07422892	0.043206	0.03102292	41.79%
6692	TPCODL	CUTTACK	SED	SALIPUR	SALIPUR	14095	11 KV KENDUPATNA	14095202	AIRTEL TOWER -2	3533DT181	100	MIXED	AMI	Yes	100%	45	0.09116496	0.020639	0.07052596	77.36%
6693	TPCODL	CUTTACK	SED	SALIPUR	SALIPUR	14095	11 KV KENDUPATNA	14095202	GUNEIPUR	3533DT186	100	MIXED	AMI	Yes	100%	8	0.06319976	0.015479	0.04772076	75.51%
6694	TPCODL	CUTTACK	SED	SALIPUR	SALIPUR	14095	11 KV KENDUPATNA	14095202	GUNEIPUR-2	3533DT202	100	MIXED	AMI	Yes	100%	108	0.05904066	0.037236	0.02180466	36.93%
6695	TPCODL	CUTTACK	SED	SALIPUR	SALIPUR	14095	11 KV KENDUPATNA	14095202	JIO TOWER	3533DT203	100	MIXED	AMI	Yes	0%	59	0.03361654	0.019754	0.01386254	41.24%
6696	TPCODL	CUTTACK	SED	SALIPUR	SALIPUR	14095	11 KV KENDUPATNA	14095202	GUNEIPUR-1	3533DT210	100	MIXED	AMI	Yes	100%	127	0.04380006	0.035491	0.00830906	18.97%
6697	TPCODL	CUTTACK	SED	SALIPUR	SALIPUR	14095	11 KV MEDICAL	14095203	RADHAPUR-1	3533DT003	500	MIXED	AMI	Yes	0%	172	0.22414992	0.137016	0.08713392	38.87%
6698	TPCODL	CUTTACK	SED	SALIPUR	SALIPUR	14095	11 KV MEDICAL	14095203	SALIPUR .RADHAPUR	3533DT011	250	MIXED	AMI	Yes	100%	92	0.15989324	0.050185	0.10970824	68.61%
6699	TPCODL	CUTTACK	SED	SALIPUR	SALIPUR	14095	11 KV MEDICAL	14095203	MARKET	3533DT039	63	MIXED	AMI	Yes	100%	104	0.05179216	0.036789	0.01500316	28.97%
6700	TPCODL	CUTTACK	SED	SALIPUR	SALIPUR	14095	11 KV MEDICAL	14095203	SALIPUR COLLEGE -2	3533DT240	500	MIXED	AMI	Yes	100%	61	0.19252	0.066701	0.125819	65.35%
6701	TPCODL	CUTTACK	SED	SALIPUR	SALIPUR	14095	11 KV CHHANIPUR	14095204	SATABATI 4	3532DT006	100	MIXED	AMI	Yes	100%	125	0.09509482	0.059195	0.03589982	37.75%
6702	TPCODL	CUTTACK	SED	SALIPUR	SALIPUR	14095	11 KV CHHANIPUR	14095204	JIO TOWAR	3533DT044	500	MIXED	AMI	Yes	0%	300	0.19565608	0.190372	0.00528408	2.70%
6703	TPCODL	CUTTACK	SED	SALIPUR	SALIPUR	14095	11 KV CHHANIPUR	14095204	JAHAGIRABAD	3533DT050	100	MIXED	AMI	Yes	100%	139	0.11416868	0.072848	0.04132068	36.19%
6704	TPCODL	CUTTACK	SED	SALIPUR	SALIPUR	14095	11 KV CHHANIPUR	14095204	BANAHARA-2	3533DT055	63	MIXED	AMI	Yes	100%	161	0.0626738	0.057255	0.0054188	8.65%
6705	TPCODL	CUTTACK	SED	SALIPUR	SALIPUR	14095	11 KV CHHANIPUR	14095204	TRINATH PADIA	3533DT067	100	MIXED	AMI	Yes	67%	102	0.0531926	0.043951	0.0092416	17.37%
6706	TPCODL	CUTTACK	SED	SALIPUR	SALIPUR	14095	11 KV CHHANIPUR	14095204	KAMALA SHAW MILL	3533DT073	150	MIXED	AMI	Yes	0%	188	0.13035632	0.10991	0.02044632	15.68%
6707	TPCODL	CUTTACK	SED	SALIPUR	SALIPUR	14095	11 KV CHHANIPUR	14095204	BODAMUNDEI BAZAR	3533DT075	100	MIXED	AMI	Yes	0%	65	0.03185154	0.024258	0.00759354	23.84%
6708	TPCODL	CUTTACK	SED	SALIPUR	SALIPUR	14095	11 KV CHHANIPUR	14095204	BARIGOLA-2	3533DT077	100	MIXED	AMI	Yes	100%	90	0.03760884	0.035402	0.00220684	5.87%
6709	TPCODL	CUTTACK	SED	SALIPUR	SALIPUR	14095	11 KV CHHANIPUR	14095204	ALI FURNITURE	3533DT091	100	MIXED	AMI	Yes	100%	61	0.0456822	0.033355	0.0123272	26.98%
6710	TPCODL	CUTTACK	SED	SALIPUR	TANGI	14107	11 KV MANGULI	14107203	KASERPUR	3323DT602	100	MIXED	AMI	Yes	100%	117	0.07007094	0.055265	0.01480594	21.13%
6711	TPCODL	DHENKAN	ANED	ANGUL	HEMSURPADA	14187	11 KV HEMSURPADA	14187201	OMM APARTMENT-1	4211DT069	500	MIXED	AMI	Yes	0%	80	0.08800848	0.086475	0.00153348	1.74%
6712	TPCODL	DHENKAN	ANED	ANGUL	HEMSURPADA	14187	11 KV HEMSURPADA	14187201	PRAFULLA MISHRA COMPLEX-1	4211DT099	500	MIXED	AMI	Yes	0%	87	0.13680176	0.106089	0.03071276	22.45%
6713	TPCODL	DHENKAN	ANED	ANGUL	HEMSURPADA	14187	11 KV HEMSURPADA	14187201	PRAFULLA MISHRA COMPLEX-2	4211DT100	500	MIXED	AMI	Yes	0%	54	0.19066872	0.058234	0.13243472	69.46%
6714	TPCODL	DHENKAN	ANED	ANGUL	PANCHAMAHAL	14383	11 kV POLYTECHNIC	14383201	URMILA DEVOLOPER	4211DT152	500	MIXED	AMI	Yes	100%	51	0.0845496	0.081869	0.0026806	3.17%
6715	TPCODL	DHENKAN	ANED	ANGUL	HEMSURPADA	14187	11 kV JARASINGHA	14187205	DERJANG PROPECT	4213DT089	100	MIXED	AMI	Yes	0%	40	0.02005781	0.019073	0.00098481	4.91%

Sl. No.	Zone Name	Circle name	Division name	Name of the Sub-division	Name of the Sub-station	Substation Code	Name of the 11 kV Feeder	Feeder Code	Name of the Location where DT situated	DT code	DT Capacity (kVA)	Predominant consumer type of DT (Domestic/Industrial/Agriculture/Mixed)	Type of metering AMR/AMI/ Communicable/Conventional metered/Unmetered	Status of Meter-whether Functional (Yes/No)	% of data received automatically (if AMR/AMI)	No. of Connected Consumers	Input Energy (MU) (A)	Billed Energy (MU) (B)	Loss (MU) (A-B)	% DT Loss (A-B)/A
6716	TPCODL	DHENKAN	ANED	ANGUL	INDUSTRIAL ESTATE	14133	11 kV KURDUL	14133202	FCI ROAD NEAR CALTAX P.T.C VATIKA	4213DT112	500	MIXED	AMI	Yes	0%	44	0.05780536	0.054743	0.00306236	5.30%
6717	TPCODL	DHENKAN	ANED	ANGUL	KULAD (KANDASAR)	14328	11 kV NALCO TOWNSHIP	14328201	KANHAEI NAGAR -1	4213DT267	500	MIXED	AMI	Yes	100%	217	0.20812304	0.1893	0.01882304	9.04%
6718	TPCODL	DHENKAN	ANED	ANGUL	BADAKERA	14227	11 kV DUDHIABEDA	14227202	TASHARA HARIJAN SAHI	4213DT341	63	MIXED	AMI	Yes	0%	20	0.00818504	0.005847	0.00233804	28.56%
6719	TPCODL	DHENKAN	ANED	ANGUL	BADAKERA	14227	11 kV DUDHIABEDA	14227202	DUDHIABEDA -1 NEAR LINE AB SW	4213DT515	63	MIXED	AMI	Yes	0%	45	0.01337426	0.009721	0.00365326	27.32%
6720	TPCODL	DHENKAN	ANED	ANGUL	BADAKERA	14227	11 kV DUDHIABEDA	14227202	SANAKERJANG GOCHHAYAT SAHI	4213DT527	63	MIXED	AMI	Yes	0%	49	0.02258906	0.005578	0.01701106	75.31%
6721	TPCODL	DHENKAN	ANED	ANGUL	RCMS	14132	11 kV RCMS RE-2	14132204	KHAMAR KHAMAR CHHACK 2	4214DT671	100	MIXED	AMI	Yes	0%	120	0.08424388	0.053362	0.03088188	36.66%
6722	TPCODL	DHENKAN	ANED	ANGUL	BADAKERA	14227	11 KV BADAKERA	14227201	MUSAPAPULI-LV DERJANG ROAD SID	4213DT216	100	MIXED	AMI	Yes	67%	61	0.04192314	0.022333	0.01959014	46.73%
6723	TPCODL	DHENKAN	ANED	ANGUL	BADAKERA	14227	11 KV BADAKERA	14227201	MUSAPAPULI-LLL SIDDHIVINAYAK CO	4213DT217	100	MIXED	AMI	Yes	67%	150	0.05613212	0.053238	0.00289412	5.16%
6724	TPCODL	DHENKAN	ANED	ANGUL	BADAKERA	14227	11 KV BADAKERA	14227201	BADAKERA CHHACK 1	4213DT410	250	MIXED	AMI	Yes	67%	195	0.26092264	0.169528	0.09139464	35.03%
6725	TPCODL	DHENKAN	ANED	ANGUL	BADAKERA	14227	11 KV BADAKERA	14227201	PANJIA SAHI	4213DT444	100	MIXED	AMI	Yes	67%	114	0.0816045	0.056528	0.0250765	30.73%
6726	TPCODL	DHENKAN	ANED	ANGUL	BADAKERA	14227	11 KV BADAKERA	14227201	SASAN BAZAR -L	4213DT461	100	MIXED	AMI	Yes	33%	70	0.09318138	0.040663	0.05251838	56.36%
6727	TPCODL	DHENKAN	ANED	ANGUL	BADAKERA	14227	11 KV BADAKERA	14227201	BADADANDSA SAHI NEAR MAUSI MA	4213DT465	100	MIXED	AMI	Yes	67%	83	0.05786486	0.02689	0.03097486	53.53%
6728	TPCODL	DHENKAN	ANED	ANGUL	BADAKERA	14227	11 KV BADAKERA	14227201	BADADANDSA SAHI	4213DT466	100	MIXED	AMI	Yes	67%	100	0.05494346	0.029947	0.02499646	45.49%
6729	TPCODL	DHENKAN	ANED	ANGUL	BADAKERA	14227	11 KV BADAKERA	14227201	KARAMANGA SAHI -LLL NEAR RWSS	4213DT471	100	MIXED	AMI	Yes	67%	84	0.0538043	0.026355	0.0274493	51.02%
6730	TPCODL	DHENKAN	ANED	ANGUL	BADAKERA	14227	11 KV BADAKERA	14227201	MATIA SAHI-L NEAR PANCHAYT OFF.	4213DT475	100	MIXED	AMI	Yes	67%	34	0.01268426	0.00612891	0.00655535	51.68%
6731	TPCODL	DHENKAN	ANED	ANGUL	BADAKERA	14227	11 KV BADAKERA	14227201	BANIA SAHI -L	4213DT482	100	MIXED	AMI	Yes	67%	99	0.04633074	0.025897	0.02043374	44.10%
6732	TPCODL	DHENKAN	ANED	ANGUL	BADAKERA	14227	11 KV BADAKERA	14227201	MADAN MOHAN PATNA-LL NEAR SCH	4213DT484	100	MIXED	AMI	Yes	67%	109	0.03918906	0.029035	0.01015406	25.91%
6733	TPCODL	DHENKAN	ANED	ANGUL	BADAKERA	14227	11 KV BADAKERA	14227201	MADAN MOHAN PATNA - L NR NEW	4213DT582	100	MIXED	AMI	Yes	67%	71	0.02381572	0.015302	0.00851372	35.75%
6734	TPCODL	DHENKAN	ANED	ANGUL	BADAKERA	14227	11 KV BADAKERA	14227201	HARIBERINI NH SIDE	4213DT591	100	MIXED	AMI	Yes	67%	129	0.0596231	0.0296413	0.0299818	50.29%
6735	TPCODL	DHENKAN	ANED	ANGUL	BADAKERA	14227	11 KV BADAKERA	14227201	MUSAPAPULI - I NEAR SCHOOL	4213DT592	100	MIXED	AMI	Yes	67%	62	0.04995348	0.028725	0.02122848	42.50%
6736	TPCODL	DHENKAN	ANED	ANGUL	BADAKERA	14227	11 KV BADAKERA	14227201	RANTALEI-I NH SIDE	4213DT597	100	MIXED	AMI	Yes	67%	118	0.0542231	0.047531	0.0066921	12.34%
6737	TPCODL	DHENKAN	ANED	ANGUL	BADAKERA	14227	11 KV BADAKERA	14227201	RANTALEI-III VILLAGE	4213DT601	100	MIXED	AMI	Yes	67%	178	0.0718378	0.04957415	0.02226365	30.99%
6738	TPCODL	DHENKAN	ANED	ANGUL	BADAKERA	14227	11 KV BADAKERA	14227201	CHANDRABAHAL VILLAGE	4213DT611	100	MIXED	AMI	Yes	67%	202	0.08015888	0.057918	0.02224088	27.75%
6739	TPCODL	DHENKAN	ANED	ANGUL	BADAKERA	14227	11 KV BADAKERA	14227201	KARAMANGA SAHI - L CHHACK	4213DT693	100	MIXED	AMI	Yes	67%	98	0.05135836	0.040779	0.01057936	20.60%
6740	TPCODL	DHENKAN	ANED	ANGUL	BADAKERA	14227	11 KV DUDHIABEDA	14227202	JUKUB VILLAGE	4213DT311	100	MIXED	AMI	Yes	67%	70	0.05184362	0.020123	0.03172062	61.19%
6741	TPCODL	DHENKAN	ANED	ANGUL	BADAKERA	14227	11 KV DUDHIABEDA	14227202	TUBEY NH SIDE MAIN VILLAGE NEAR	4213DT318	250	MIXED	AMI	Yes	67%	286	0.15822612	0.10576829	0.05245783	33.15%
6742	TPCODL	DHENKAN	ANED	ANGUL	BADAKERA	14227	11 KV DUDHIABEDA	14227202	TUBEY DHIPA SAHI 1	4213DT332	100	MIXED	AMI	Yes	67%	71	0.0393477	0.026319	0.0130287	33.11%
6743	TPCODL	DHENKAN	ANED	ANGUL	BADAKERA	14227	11 KV DUDHIABEDA	14227202	TUBEY DHIPA SAHI 2	4213DT334	100	MIXED	AMI	Yes	67%	57	0.02732746	0.019004	0.00832346	30.46%
6744	TPCODL	DHENKAN	ANED	ANGUL	BADAKERA	14227	11 KV DUDHIABEDA	14227202	TASHARA	4213DT339	100	MIXED	AMI	Yes	67%	114	0.06186298	0.029519	0.03234398	52.28%
6745	TPCODL	DHENKAN	ANED	ANGUL	BADAKERA	14227	11 KV DUDHIABEDA	14227202	SANTARAPUR VILLAGE NEAR U.P SCH	4213DT349	100	MIXED	AMI	Yes	67%	113	0.04866318	0.043816	0.00484718	9.96%
6746	TPCODL	DHENKAN	ANED	ANGUL	BADAKERA	14227	11 KV DUDHIABEDA	14227202	JARADA PRADHAN SAHI 1	4213DT366	100	MIXED	AMI	Yes	67%	120	0.03484278	0.024213	0.01062978	30.51%
6747	TPCODL	DHENKAN	ANED	ANGUL	BADAKERA	14227	11 KV DUDHIABEDA	14227202	JARADA SAMANTA SAHI NEAR KHEL F	4213DT374	100	MIXED	AMI	Yes	33%	75	0.058028	0.021632	0.036396	62.72%
6748	TPCODL	DHENKAN	ANED	ANGUL	BADAKERA	14227	11 KV DUDHIABEDA	14227202	BIMALABEDA - I	4213DT381	100	MIXED	AMI	Yes	67%	103	0.03500208	0.02972	0.00528208	15.09%
6749	TPCODL	DHENKAN	ANED	ANGUL	BADAKERA	14227	11 KV DUDHIABEDA	14227202	BADHINSHAR NUA SAHI	4213DT387	100	MIXED	AMI	Yes	67%	168	0.01603622	0.015865	0.00017122	1.07%
6750	TPCODL	DHENKAN	ANED	ANGUL	BADAKERA	14227	11 KV DUDHIABEDA	14227202	BADHINSHAR VILLAGE - I	4213DT390	100	MIXED	AMI	Yes	0%	95	0.029307	0.014579	0.014728	50.25%
6751	TPCODL	DHENKAN	ANED	ANGUL	BADAKERA	14227	11 KV DUDHIABEDA	14227202	BHERABHUIN BISWAL SAHI	4213DT530	100	MIXED	AMI	Yes	67%	30	0.0244796	0.01157	0.0129096	52.74%
6752	TPCODL	DHENKAN	ANED	ANGUL	BADAKERA	14227	11 KV DUDHIABEDA	14227202	BADKERJANG TRIBENI CHHAK	4213DT619	250	MIXED	AMI	Yes	67%	234	0.13646832	0.095216	0.04125232	30.23%
6753	TPCODL	DHENKAN	ANED	ANGUL	BADAKERA	14227	11 KV DUDHIABEDA	14227202	BADKERJANG JUNGLE KARATIA SAHI	4213DT623	100	MIXED	AMI	Yes	67%	22	0.01670368	0.006758	0.00994568	59.54%
6754	TPCODL	DHENKAN	ANED	ANGUL	BADAKERA	14227	11 KV DUDHIABEDA	14227202	BADKERJANG SUNDARSANPUR	4213DT624	100	MIXED	AMI	Yes	67%	91	0.02513102	0.017859	0.00727202	28.94%
6755	TPCODL	DHENKAN	ANED	ANGUL	BADAKERA	14227	11 KV DUDHIABEDA	14227202	BADKERJANG TENTULI SAHI UTARPAI	4213DT651	100	MIXED	AMI	Yes	67%	100	0.02507198	0.023647	0.00142498	5.68%
6756	TPCODL	DHENKAN	ANED	ANGUL	BADAKERA	14227	11 KV DUDHIABEDA	14227202	TUBEY NEAR SCHOOL	4213DT673	100	MIXED	AMI	Yes	67%	72	0.06299304	0.029697	0.03329604	52.86%
6757	TPCODL	DHENKAN	ANED	ANGUL	BANTALA	14134	11 KV BANTALA	14134201	BANTALA HATA PADIA 1	4214DT030	100	MIXED	AMI	Yes	0%	192	0.08916424	0.080181	0.00898324	10.07%
6758	TPCODL	DHENKAN	ANED	ANGUL	BANTALA	14134	11 KV BANTALA	14134201	BANTALA BAZAR	4214DT033	100	MIXED	AMI	Yes	100%	61	0.09069904	0.025065	0.06563404	72.36%
6759	TPCODL	DHENKAN	ANED	ANGUL	BANTALA	14134	11 KV BANTALA	14134201	BANTALA HOSPITAL	4214DT036	100	MIXED	AMI	Yes	100%	13	0.02194572	0.007328	0.01461772	66.61%
6760	TPCODL	DHENKAN	ANED	ANGUL	BANTALA	14134	11 KV BANTALA	14134201	BANTALA RAMA MANDIR	4214DT037	63	MIXED	AMI	Yes	100%	88	0.04483656	0.04358	0.00125656	2.80%
6761	TPCODL	DHENKAN	ANED	ANGUL	BANTALA	14134	11 KV BANTALA	14134201	POKATUNGA KALAPATA SAHI	4214DT060	100	MIXED	AMI	Yes	100%	84	0.05753112	0.02677	0.03076112	53.47%
6762	TPCODL	DHENKAN	ANED	ANGUL	BANTALA	14134	11 KV BANTALA	14134201	POKATUNGA VILLAGE	4214DT068	100	MIXED	AMI	Yes	100%	185	0.07900664	0.05484	0.02416664	30.59%
6763	TPCODL	DHENKAN	ANED	ANGUL	BANTALA	14134	11 KV BANTALA	14134201	POKATUNGA HAGURI GADIA	4214DT073	100	MIXED	AMI	Yes	100%	118	0.05265938	0.027201	0.02545838	48.35%
6764	TPCODL	DHENKAN	ANED	ANGUL	BANTALA	14134	11 KV BANTALA	14134201	POKATUNGA BEHERA SAHI	4214DT074	100	MIXED	AMI	Yes	100%	120	0.05536454	0.031587	0.02377754	42.95%
6765	TPCODL	DHENKAN	ANED	ANGUL	BANTALA	14134	11 KV BANTALA	14134201	POKATUNGA BANDHA CHHAKA	4214DT095	100	MIXED	AMI	Yes	100%	109	0.06309636	0.040918	0.02217836	35.15%
6766	TPCODL	DHENKAN	ANED	ANGUL	BANTALA	14134	11 KV BANTALA	14134201	MADHUPUR VILLAGE 1	4214DT098	100	MIXED	AMI	Yes	100%	186	0.04647738	0.035783	0.01069438	23.01%
6767	TPCODL	DHENKAN	ANED	ANGUL	BANTALA	14134	11 KV BANTALA	14134201	MADHUPUR VILLAGE -02	4214DT102	63	MIXED	AMI	Yes	67%	38	0.01396857	0.007106	0.00686257	49.13%
6768	TPCODL	DHENKAN	ANED	ANGUL	BANTALA	14134	11 KV BANTALA	14134201	NANDAPURA RAJIB GANADHI SEVA K	4214DT105	63	MIXED	AMI	Yes	100%	118	0.0373405	0.032843	0.0044975	12.04%
6769	TPCODL	DHENKAN	ANED	ANGUL	BANTALA	14134	11 KV BANTALA	14134201	KARATAPATA VILLAGE	4214DT157	63	MIXED	AMI	Yes	100%	85	0.04061441	0.019455	0.02115941	52.10%
6770	TPCODL	DHENKAN	ANED	ANGUL	BANTALA	14134	11 KV BANTALA	14134201	LACHHABANDHA VILLAGE	4214DT192	100	MIXED	AMI	Yes	33%	172	0.08253906	0.063338	0.01920106	23.26%
6771	TPCODL	DHENKAN	ANED	ANGUL	BANTALA	14134	11 KV BANTALA	14134201	KHALAGOAN VILLAGE -3	4214DT225	63	MIXED	AMI	Yes	67%	28	0.03032596	0.009112	0.02121396	69.95%
6772	TPCODL	DHENKAN	ANED	ANGUL	BANTALA	14134	11 KV BANTALA	14134201	BADAHINSO VILLAGE 1	4214DT253	100	MIXED	AMI	Yes	33%	85	0.04113462	0.017789	0.02334562	56.75%
6773	TPCODL	DHENKAN	ANED	ANGUL	BANTALA	14134	11 KV BANTALA	14134201	NEAR TALAGADA SARSWATI SISU VID	4214DT271	100	MIXED	AMI	Yes	0%	66	0.04825014	0.010464	0.03778614	78.31%
6774	TPCODL	DHENKAN	ANED	ANGUL	BANTALA	14134	11 KV BANTALA	14134201	TALAGADA VILLAGE-1	4214DT278	100	MIXED	AMI	Yes	67%	188	0.03318266	0.024767	0.00841566	25.36%
6775	TPCODL	DHENKAN	ANED	ANGUL	BANTALA	14134	11 KV BANTALA	14134201	BARAGOUNIA GOTHAMALA -5	4214DT315	63	MIXED	AMI	Yes	67%	14	0.00517237	0.001961	0.00321137	62.09%
6776	TPCODL	DHENKAN	ANED	ANGUL	BANTALA	14134	11 KV BANTALA	14134201	NANDAPURA HARIJANA SAHI	4214DT333	63	MIXED	AMI	Yes	0%	51	0.011505	0.00827	0.003235	28.12%
6777	TPCODL	DHENKAN	ANED	ANGUL	BANTALA	14134	11 KV SABALABHANGA	14134202	PANCHAGHARIA SAHI PANCHAGHARI	4214DT540	100	MIXED	AMI	Yes	67%	75	0.03865698	0.028429	0.01022798	26.46%
6778	TPCODL	DHENKAN	ANED	ANGUL	BANTALA	14134	11 KV SABALABHANGA	14134202	KUMURSINGHA MAJHI CHHAKA	4214DT573	100	MIXED	AMI	Yes	67%	239	0.05804677	0.057834	0.00021277	0.37%
6779	TPCODL	DHENKAN	ANED	ANGUL	BANTALA	14134	11 KV SABALABHANGA	14134202	SABALABHANGA PATHAN SAHI	4214DT586	100	MIXED	AMI	Yes	67%	134	0.09901708	0.066622	0.03239508	32.72%
6780	TPCODL	DHENKAN	ANED	ANGUL	BANTALA	14134	11 KV SABALABHANGA	14134202	SABALABHANGA MANDIRA SAHI	4214DT591	100	MIXED	AMI	Yes	67%	305	0.16746034	0.105482	0.06197834	37.01%
6781	TPCODL	DHENKAN	ANED	ANGUL	BANTALA	14134	11 KV SABALABHANGA	14134202	TALABAHAL VILLAGE SCHOOL	4214DT885	100	MIXED	AMI	Yes	67%	95	0.05816511	0.039203	0.01896211	32.60%
6782	TPCODL	DHENKAN	ANED	ANGUL	BANTALA	14134	11 KV KHINDA	14134203	HAMAMIRA 4	4214DT364	100	MIXED	AMI	Yes	67%	81	0.03368176	0.016762	0.01691976	50.23%
6783	TPCODL	DHENKAN	ANED	ANGUL	BANTALA	14134	11 KV KHINDA	14134203	BEDASASAN 1	4214DT372	100	MIXED	AMI	Yes	67%	120	0.04545604	0.037982	0.00747404	16.44%
6784	TPCODL	DHENKAN	ANED	ANGUL	BANTALA	14134	11 KV KHINDA	14134203	BASALA VILLAGE 2	4214DT404	100	MIXED	AMI	Yes	67%	209	0.06506598	0.043248	0.02181798	33.53%
6785	TPCODL	DHENKAN	ANED	ANGUL	BANTALA	14134	11 KV KHINDA	14134203	KHINDA 4	4214DT412	100	MIXED	AMI	Yes	100%	101	0.03880736	0.023894	0.01491336	38.43%
6786	TPCODL	DHENKAN	ANED	ANGUL	BANTALA	14134	11 KV KHINDA	14134203	KHINDA CHHAK	4214DT414	100	MIXED	AMI	Yes	100%	132	0.035966	0.027845	0.008121	22.58%
6787	TPCODL	DHENKAN	ANED	ANGUL	BANTALA	14134	11 KV KHINDA	14134203	MARANDA HALAR	4214DT422	100	MIXED	AMI	Yes	100%	115	0.03261298	0.0228	0.00981298	30.09%
6788	TPCODL	DHENKAN	ANED	ANGUL	BANTALA	14134	11 KV KHINDA	14134203	MARANDA	4214DT423	100	MIXED	AMI	Yes	100%	198	0.03810324	0.0326191	0.00548414	14.39%

Sl. No.	Zone Name	Circle name	Division name	Name of the Sub-division	Name of the Sub-station	Substation Code	Name of the 11 kV Feeder	Feeder Code	Name of the Location where DT situated	DT code	DT Capacity (kVA)	Predominant consumer type of DT (Domestic/Industrial/Agriculture/Mixed)	Type of metering AMR/AMI/ Communicable/Conventional metered/Unmetered	Status of Meter-whether Functional (Yes/No)	% of data received automatically (if AMR/AMI)	No. of Connected Consumers	Input Energy (MU) (A)	Billed Energy (MU) (B)	Loss (MU) (A-B)	% DT Loss (A-B)/A
6789	TPCODL	DHENKAN	ANED	ANGUL	BANTALA	14134	11 KV KHINDA	14134203	TALABERENA VILLAGE 1	4214DT434	100	MIXED	AMI	Yes	67%	84	0.03493412	0.010471	0.02446312	70.03%
6790	TPCODL	DHENKAN	ANED	ANGUL	BANTALA	14134	11 KV KHINDA	14134203	BADAKANTAKULVILLAGE 2	4214DT474	100	MIXED	AMI	Yes	100%	134	0.03324472	0.020939	0.01230572	37.02%
6791	TPCODL	DHENKAN	ANED	ANGUL	BANTALA	14134	11 KV KHINDA	14134203	JAMUNDA CHASA SAHI	4214DT479	100	MIXED	AMI	Yes	100%	130	0.03066336	0.02497	0.00569336	18.57%
6792	TPCODL	DHENKAN	ANED	ANGUL	BANTALA	14134	11 KV KHINDA	14134203	GADATARASH VILLAGE	4214DT487	100	MIXED	AMI	Yes	100%	31	0.0509445	0.010441	0.0405035	79.51%
6793	TPCODL	DHENKAN	ANED	ANGUL	BANTALA	14134	11 KV KHINDA	14134203	GADATARASH NUKHARIPADA	4214DT488	100	MIXED	AMI	Yes	67%	63	0.02634188	0.014182	0.01215988	46.16%
6794	TPCODL	DHENKAN	ANED	ANGUL	BANTALA	14134	11 KV SARANGAPUR	14134204	SARANGAPUR VILLAGE 1	4214DT012	100	MIXED	AMI	Yes	100%	91	0.03939	0.02707	0.01232	31.28%
6795	TPCODL	DHENKAN	ANED	ANGUL	BANTALA	14134	11 KV SARANGAPUR	14134204	BADAKANJANI NEAR SCHOOL 1	4214DT025	100	MIXED	AMI	Yes	100%	114	0.06435302	0.03065246	0.03370056	52.37%
6796	TPCODL	DHENKAN	ANED	ANGUL	BOINDA	14137	11 KV HANDPA	14137202	BHEJIGHOTH BOIDABASA	4221DT601	100	MIXED	AMI	Yes	33%	77	0.02013336	0.014124	0.00600936	29.85%
6797	TPCODL	DHENKAN	ANED	ANGUL	HEMSURPADA	14187	11 KV HEMSURPADA	14187201	PANCHAYAT INDUSTRI CHAKA-1	4211DT002	500	MIXED	AMI	Yes	0%	172	0.32644216	0.177237	0.14920516	45.71%
6798	TPCODL	DHENKAN	ANED	ANGUL	HEMSURPADA	14187	11 KV HEMSURPADA	14187201	BANU JENA S/STN-2	4211DT004	250	MIXED	AMI	Yes	100%	164	0.14148116	0.092739	0.04874216	34.45%
6799	TPCODL	DHENKAN	ANED	ANGUL	HEMSURPADA	14187	11 KV HEMSURPADA	14187201	BANU JENA S/STN-1	4211DT005	250	MIXED	AMI	Yes	0%	70	0.12247644	0.053161	0.06931544	56.59%
6800	TPCODL	DHENKAN	ANED	ANGUL	HEMSURPADA	14187	11 KV HEMSURPADA	14187201	SAW MILL CHAKA	4211DT008	500	MIXED	AMI	Yes	0%	244	0.3884856	0.217923	0.1705626	43.90%
6801	TPCODL	DHENKAN	ANED	ANGUL	HEMSURPADA	14187	11 KV HEMSURPADA	14187201	BHANDUBAR	4211DT011	250	MIXED	AMI	Yes	0%	187	0.28353792	0.168197	0.11534092	40.68%
6802	TPCODL	DHENKAN	ANED	ANGUL	HEMSURPADA	14187	11 KV HEMSURPADA	14187201	BHANDUBAR (RAPDRP)	4211DT012	100	MIXED	AMI	Yes	100%	30	0.05593342	0.025509	0.03042442	54.39%
6803	TPCODL	DHENKAN	ANED	ANGUL	HEMSURPADA	14187	11 KV HEMSURPADA	14187201	MEDICAL	4211DT016	250	MIXED	AMI	Yes	100%	77	0.0830996	0.066415	0.0166846	20.08%
6804	TPCODL	DHENKAN	ANED	ANGUL	HEMSURPADA	14187	11 KV HEMSURPADA	14187201	KABAR KHANA	4211DT021	250	MIXED	AMI	Yes	0%	234	0.2499216	0.222203	0.0277186	11.09%
6805	TPCODL	DHENKAN	ANED	ANGUL	HEMSURPADA	14187	11 KV HEMSURPADA	14187201	NAKHARA SAHI-1	4211DT024	250	MIXED	AMI	Yes	100%	75	0.10863836	0.087984	0.02065436	19.01%
6806	TPCODL	DHENKAN	ANED	ANGUL	HEMSURPADA	14187	11 KV HEMSURPADA	14187201	GHANA SAHU CHAKA-1	4211DT030	500	MIXED	AMI	Yes	0%	279	0.48131864	0.397764	0.08355464	17.36%
6807	TPCODL	DHENKAN	ANED	ANGUL	HEMSURPADA	14187	11 KV HEMSURPADA	14187201	GHANA SAHU CHAKA-2	4211DT031	100	MIXED	AMI	Yes	100%	35	0.06072506	0.045619	0.01510606	24.88%
6808	TPCODL	DHENKAN	ANED	ANGUL	HEMSURPADA	14187	11 KV HEMSURPADA	14187201	OMM APARTMENT-2	4211DT070	500	MIXED	AMI	Yes	100%	63	0.106712	0.078	0.028712	26.91%
6809	TPCODL	DHENKAN	ANED	ANGUL	HEMSURPADA	14187	11 KV HEMSURPADA	14187201	GUJURATI PADA-2	4211DT097	63	MIXED	AMI	Yes	0%	35	0.06660738	0.040947	0.02566038	38.52%
6810	TPCODL	DHENKAN	ANED	ANGUL	HEMSURPADA	14187	11 KV HEMSURPADA	14187201	GUJURATI PADA-1	4211DT098	100	MIXED	AMI	Yes	100%	71	0.11298854	0.104909	0.00807954	7.15%
6811	TPCODL	DHENKAN	ANED	ANGUL	HEMSURPADA	14187	11 KV MCL	14187202	BHANDUBAR	4211DT127	100	MIXED	AMI	Yes	100%	38	0.0925505	0.026432	0.0661185	71.44%
6812	TPCODL	DHENKAN	ANED	ANGUL	HEMSURPADA	14187	11 KV MCL	14187202	SAI VIHAR BHANDUBAR	4211DT128	250	MIXED	AMI	Yes	0%	132	0.16592192	0.132394	0.03352792	20.21%
6813	TPCODL	DHENKAN	ANED	ANGUL	HEMSURPADA	14187	11 KV MCL	14187202	SWEEPER COLONY BASTI	4211DT161	100	MIXED	AMI	Yes	100%	96	0.09485028	0.082692	0.01215828	12.82%
6814	TPCODL	DHENKAN	ANED	ANGUL	HEMSURPADA	14187	11 KV MCL	14187202	DERJANG SAHI KUMANDA	4213DT014	100	MIXED	AMI	Yes	100%	55	0.04673906	0.018537	0.02820206	60.34%
6815	TPCODL	DHENKAN	ANED	ANGUL	HEMSURPADA	14187	11 KV SIKHYAKAPADA	14187204	TOWN HIGH SCHOOL	4211DT071	250	MIXED	AMI	Yes	100%	156	0.14878552	0.123088	0.02569752	17.27%
6816	TPCODL	DHENKAN	ANED	ANGUL	HEMSURPADA	14187	11 KV SIKHYAKAPADA	14187204	RAJKISHORE PADA-1	4211DT073	250	MIXED	AMI	Yes	100%	233	0.26205404	0.18034	0.08171404	31.18%
6817	TPCODL	DHENKAN	ANED	ANGUL	HEMSURPADA	14187	11 KV SIKHYAKAPADA	14187204	RAJKISHORE PADA-3	4211DT075	100	MIXED	AMI	Yes	100%	84	0.1254624	0.074393	0.0510694	40.70%
6818	TPCODL	DHENKAN	ANED	ANGUL	HEMSURPADA	14187	11 KV SIKHYAKAPADA	14187204	SIKHYAKAPADA 2	4211DT078	500	MIXED	AMI	Yes	0%	373	0.4299264	0.345163	0.0847634	19.72%
6819	TPCODL	DHENKAN	ANED	ANGUL	HEMSURPADA	14187	11 KV SIKHYAKAPADA	14187204	SIKHYAKAPADA TALA SAHI	4211DT081	500	MIXED	AMI	Yes	0%	350	0.4029768	0.314637	0.0883398	21.92%
6820	TPCODL	DHENKAN	ANED	ANGUL	HEMSURPADA	14187	11 KV SIKHYAKAPADA	14187204	SAI MANDIR 1	4211DT082	250	MIXED	AMI	Yes	100%	179	0.17308684	0.103613	0.06947384	40.14%
6821	TPCODL	DHENKAN	ANED	ANGUL	HEMSURPADA	14187	11 KV SIKHYAKAPADA	14187204	SAI MANDIR 2	4211DT083	250	MIXED	AMI	Yes	100%	258	0.24437104	0.184736	0.05963504	24.40%
6822	TPCODL	DHENKAN	ANED	ANGUL	HEMSURPADA	14187	11 KV SIKHYAKAPADA	14187204	SHITAL VIHAR (STATION ROAD)	4211DT086	100	MIXED	AMI	Yes	100%	87	0.09236958	0.088462	0.00390758	4.23%
6823	TPCODL	DHENKAN	ANED	ANGUL	HEMSURPADA	14187	11 KV SIKHYAKAPADA	14187204	SHREE VIHAR	4211DT090	100	MIXED	AMI	Yes	100%	75	0.09958718	0.091212	0.00837518	8.41%
6824	TPCODL	DHENKAN	ANED	ANGUL	HEMSURPADA	14187	11 KV SIKHYAKAPADA	14187204	ANGUL GRID	4211DT092	100	MIXED	AMI	Yes	0%	62	0.06047444	0.054315	0.00615944	10.19%
6825	TPCODL	DHENKAN	ANED	ANGUL	HEMSURPADA	14187	11 KV SIKHYAKAPADA	14187204	PRAGATI NAGAR-1	4211DT093	250	MIXED	AMI	Yes	100%	257	0.27639392	0.189388	0.08700592	31.48%
6826	TPCODL	DHENKAN	ANED	ANGUL	HEMSURPADA	14187	11 KV SIKHYAKAPADA	14187204	PRAGATI NAGAR-3 (SANDHA GALI)	4211DT096	500	MIXED	AMI	Yes	100%	230	0.33251864	0.242457	0.09006164	27.08%
6827	TPCODL	DHENKAN	ANED	ANGUL	HEMSURPADA	14187	11 KV SIKHYAKAPADA	14187204	RANIGODA NEAR BELA GALI	4213DT003	100	MIXED	AMI	Yes	100%	90	0.10675914	0.053858	0.05290114	49.55%
6828	TPCODL	DHENKAN	ANED	ANGUL	HEMSURPADA	14187	11 KV JARASINGHA	14187205	KUMANDA NO 1 S/S	4213DT030	250	MIXED	AMI	Yes	100%	277	0.23890084	0.124676	0.11422484	47.81%
6829	TPCODL	DHENKAN	ANED	ANGUL	HEMSURPADA	14187	11 KV JARASINGHA	14187205	KUMANDA NO 2 S/S	4213DT031	250	MIXED	AMI	Yes	100%	134	0.22539248	0.092693	0.13269948	58.87%
6830	TPCODL	DHENKAN	ANED	ANGUL	HEMSURPADA	14187	11 KV JARASINGHA	14187205	KUMANDA JARASINGHA GIRLS HIGH S	4213DT035	100	MIXED	AMI	Yes	100%	86	0.09399224	0.071063	0.02292924	24.39%
6831	TPCODL	DHENKAN	ANED	ANGUL	HEMSURPADA	14187	11 KV JARASINGHA	14187205	KUSASINGHA NO1	4213DT042	100	MIXED	AMI	Yes	100%	110	0.06108593	0.032751	0.02833493	46.39%
6832	TPCODL	DHENKAN	ANED	ANGUL	HEMSURPADA	14187	11 KV JARASINGHA	14187205	JARASINGHA NO1 PURUNA JARASING	4213DT072	500	MIXED	AMI	Yes	100%	187	0.1702752	0.107728	0.0625472	36.73%
6833	TPCODL	DHENKAN	ANED	ANGUL	HEMSURPADA	14187	11 KV JARASINGHA	14187205	JARASINGHA PURUNA SAHI KARUNA	4213DT073	250	MIXED	AMI	Yes	0%	223	0.1829434	0.112144	0.0707994	38.70%
6834	TPCODL	DHENKAN	ANED	ANGUL	HEMSURPADA	14187	11 KV JARASINGHA	14187205	JARASINGHA NO4 TARINI PIDHA	4213DT079	100	MIXED	AMI	Yes	0%	204	0.27995764	0.114522	0.16543564	59.09%
6835	TPCODL	DHENKAN	ANED	ANGUL	HEMSURPADA	14187	11 KV JARASINGHA	14187205	JARASINGHA NO3 TARINI PIDHA	4213DT080	250	MIXED	AMI	Yes	0%	190	0.21195988	0.099013	0.11294688	53.29%
6836	TPCODL	DHENKAN	ANED	ANGUL	HEMSURPADA	14187	11 KV JARASINGHA	14187205	MAJHIKA VILLAGE NO1	4213DT083	100	MIXED	AMI	Yes	100%	154	0.0833433	0.066244	0.0170993	20.52%
6837	TPCODL	DHENKAN	ANED	ANGUL	HEMSURPADA	14187	11 KV JARASINGHA	14187205	BENAGADIA VILLAGE - I	4213DT093	100	MIXED	AMI	Yes	67%	121	0.06747696	0.060582	0.00689496	10.22%
6838	TPCODL	DHENKAN	ANED	ANGUL	INDUSTRIAL ESTATE	14133	11 KV INDUSTRIAL FEEDE	14133201	MALATI VIHAR KENAL ROAD	4211DT238	100	MIXED	AMI	Yes	0%	64	0.0738292	0.044417	0.0294122	39.84%
6839	TPCODL	DHENKAN	ANED	ANGUL	INDUSTRIAL ESTATE	14133	11 KV INDUSTRIAL FEEDE	14133201	Tamrit Colony near kenal(Ramesh Da	4211DT240	100	MIXED	AMI	Yes	100%	78	0.05754056	0.034501	0.02303956	40.04%
6840	TPCODL	DHENKAN	ANED	ANGUL	INDUSTRIAL ESTATE	14133	11 KV INDUSTRIAL FEEDE	14133201	Corporation Office	4211DT247	250	MIXED	AMI	Yes	100%	217	0.1593248	0.150088	0.0092368	5.80%
6841	TPCODL	DHENKAN	ANED	ANGUL	INDUSTRIAL ESTATE	14133	11 KV INDUSTRIAL FEEDE	14133201	FRC Chhak	4211DT256	500	MIXED	AMI	Yes	0%	308	0.36900624	0.32789	0.04111624	11.14%
6842	TPCODL	DHENKAN	ANED	ANGUL	INDUSTRIAL ESTATE	14133	11 KV INDUSTRIAL FEEDE	14133201	TAMRIT COLONY NEAR TIGER CLUB	4211DT258	100	MIXED	AMI	Yes	100%	32	0.1255895	0.037815	0.0877745	69.89%
6843	TPCODL	DHENKAN	ANED	ANGUL	INDUSTRIAL ESTATE	14133	11 KV INDUSTRIAL FEEDE	14133201	Soubhagya Nagar (Kesab Das)	4211DT264	100	MIXED	AMI	Yes	100%	48	0.0587738	0.044922	0.0138518	23.57%
6844	TPCODL	DHENKAN	ANED	ANGUL	INDUSTRIAL ESTATE	14133	11 KV INDUSTRIAL FEEDE	14133201	SOUBHAGYA NAGAR (ISWAR GADA N	4211DT265	100	MIXED	AMI	Yes	100%	73	0.09432755	0.067469	0.02685855	28.47%
6845	TPCODL	DHENKAN	ANED	ANGUL	INDUSTRIAL ESTATE	14133	11 KV INDUSTRIAL FEEDE	14133201	Station s/stn in side Structure	4211DT272	500	MIXED	AMI	Yes	0%	160	0.16717976	0.111817	0.05536276	33.12%
6846	TPCODL	DHENKAN	ANED	ANGUL	INDUSTRIAL ESTATE	14133	11 KV KURDUL	14133202	GITAGRAM(MIRROR)	4212DT118	500	MIXED	AMI	Yes	0%	246	0.32465296	0.261956	0.06269696	19.31%
6847	TPCODL	DHENKAN	ANED	ANGUL	INDUSTRIAL ESTATE	14133	11 KV KURDUL	14133202	GITARAM KALI MANDIR	4212DT119	250	MIXED	AMI	Yes	0%	112	0.1485866	0.126365	0.0222216	14.96%
6848	TPCODL	DHENKAN	ANED	ANGUL	INDUSTRIAL ESTATE	14133	11 KV KURDUL	14133202	FCI ROAD NEAR NARAYANI INDUSTRI	4213DT113	100	MIXED	AMI	Yes	100%	34	0.0751413	0.029346	0.0457953	60.95%
6849	TPCODL	DHENKAN	ANED	ANGUL	INDUSTRIAL ESTATE	14133	11 KV KURDUL	14133202	FCI ROAD NEAR AMARVANI SCHOOL	4213DT121	250	MIXED	AMI	Yes	100%	72	0.07098444	0.059554	0.01143044	16.10%
6850	TPCODL	DHENKAN	ANED	ANGUL	INDUSTRIAL ESTATE	14133	11 KV KURDUL	14133202	FCI ROAD NEAR AMARVANI SCHOOL	4213DT122	250	MIXED	AMI	Yes	100%	76	0.12935188	0.070221	0.05913088	45.71%
6851	TPCODL	DHENKAN	ANED	ANGUL	INDUSTRIAL ESTATE	14133	11 KV KURDUL	14133202	NUAPADA NEAR KOTHA GHARA	4213DT134	100	MIXED	AMI	Yes	67%	184	0.10967502	0.084286	0.02538902	23.15%
6852	TPCODL	DHENKAN	ANED	ANGUL	INDUSTRIAL ESTATE	14133	11 KV KURDUL	14133202	KURDUL NEAR KURDUL POND	4213DT136	100	MIXED	AMI	Yes	67%	152	0.08228442	0.06845	0.01383442	16.81%
6853	TPCODL	DHENKAN	ANED	ANGUL	INDUSTRIAL ESTATE	14133	11 KV KURDUL	14133202	TURANGA NEAR RAVI PRADHAN 3PH	4213DT164	100	MIXED	AMI	Yes	100%	126	0.1032531	0.069175	0.0340781	33.00%
6854	TPCODL	DHENKAN	ANED	ANGUL	INDUSTRIAL ESTATE	14133	11 KV KURDUL	14133202	TURANGA NEAR RAVI PRADHAN 3PH	4213DT165	100	MIXED	AMI	Yes	100%	83	0.09502758	0.02552	0.06950758	73.14%
6855	TPCODL	DHENKAN	ANED	ANGUL	INDUSTRIAL ESTATE	14133	11 KV KURDUL	14133202	SHREE LAXMI VILLA	4213DT177	500	MIXED	AMI	Yes	0%	146	0.22164688	0.153252	0.06839488	30.86%
6856	TPCODL	DHENKAN	ANED	ANGUL	INDUSTRIAL ESTATE	14133	11 KV KURDUL	14133202	DURGA VIHAR	4213DT178	250	MIXED	AMI	Yes	0%	114	0.16309248	0.129156	0.03393648	20.81%
6857	TPCODL	DHENKAN	ANED	ANGUL	INDUSTRIAL ESTATE	14133	11 KV KURDUL	14133202	TURANGA GAUDA SAHI - I	4213DT184	250	MIXED	AMI	Yes	0%	155	0.15426068	0.06750508	0.0867556	56.24%
6858	TPCODL	DHENKAN	ANED	ANGUL	INDUSTRIAL ESTATE	14133	11 KV KURDUL	14133202	TURANGA INDRAHARI NAGAR	4213DT190	100	MIXED	AMI	Yes	100%	80	0.0837217	0.073173	0.0105487	12.60%
6859	TPCODL	DHENKAN	ANED	ANGUL	INDUSTRIAL ESTATE	14133	11 KV KURDUL	14133202	RANIGODA SAMANTA SAHI	4213DT198	250	MIXED	AMI	Yes	100%	171	0.1332702	0.067176	0.0660942	49.59%
6860	TPCODL	DHENKAN	ANED	ANGUL	INDUSTRIAL ESTATE	14133	11 KV KURDUL	14133202	RANIGODA NEAR RLY TRACK	4213DT199	100	MIXED	AMI	Yes	100%	110	0.07014758	0.060883	0.00926458	13.21%
6861	TPCODL	DHENKAN	ANED	ANGUL	INDUSTRIAL ESTATE	14133	11 KV KURDUL	14133202	SAKOSINGHA NEAR SAKASINGHA UP	4213DT204	100	MIXED	AMI	Yes	67%	108	0.0704135	0.042643	0.0277705	39.44%

Sl. No.	Zone Name	Circle name	Division name	Name of the Sub-division	Name of the Sub-station	Substation Code	Name of the 11 kV Feeder	Feeder Code	Name of the Location where DT situated	DT code	DT Capacity (kVA)	Predominant consumer type of DT (Domestic/Industrial/Agriculture/Mixed)	Type of metering AMR/AMI/ Communicable/Conventional metered/Unmetered	Status of Meter-whether Functional (Yes/No)	% of data received automatically (if AMR/AMI)	No. of Connected Consumers	Input Energy (MU) (A)	Billed Energy (MU) (B)	Loss (MU) (A-B)	% DT Loss (A-B)/A
6862	TPCODL	DHENKAN	ANED	ANGUL	INDUSTRIAL ESTATE	14133	11 KV KURDUL	14133202	SAKOSINGHA YATRA PADIA	4213DT208	100	MIXED	AMI	Yes	67%	264	0.11693402	0.114278	0.00265602	2.27%
6863	TPCODL	DHENKAN	ANED	ANGUL	KULAD (KANDASAR)	14328	11 KV NALCO TOWNSHIP	14328201	LALA PLOTTING MAHULABURI	4213DT278	100	MIXED	AMI	Yes	100%	73	0.13067978	0.075844	0.05483578	41.96%
6864	TPCODL	DHENKAN	ANED	ANGUL	KULAD (KANDASAR)	14328	11 KV NALCO TOWNSHIP	14328201	RUGUDI SAHI-II(NEAR BHAJAN BAHAI	4213DT285	100	MIXED	AMI	Yes	67%	73	0.07501006	0.058358	0.01665206	22.20%
6865	TPCODL	DHENKAN	ANED	ANGUL	KULAD (KANDASAR)	14328	11 KV NALCO TOWNSHIP	14328201	RUGUDI SAHI-III(NEAR BHAJAN BAHA	4213DT286	100	MIXED	AMI	Yes	100%	111	0.1062006	0.07264433	0.03355627	31.60%
6866	TPCODL	DHENKAN	ANED	ANGUL	KULAD (KANDASAR)	14328	11 KV NALCO TOWNSHIP	14328201	PRATAP PLOTTING	4213DT301	100	MIXED	AMI	Yes	100%	20	0.03971926	0.023719	0.01600026	40.28%
6867	TPCODL	DHENKAN	ANED	ANGUL	KULAD (KANDASAR)	14328	11 KV NALCO TOWNSHIP	14328201	CHABBI PLOTTING	4213DT303	250	MIXED	AMI	Yes	100%	94	0.07187992	0.062745	0.00913492	12.71%
6868	TPCODL	DHENKAN	ANED	ANGUL	KULAD (KANDASAR)	14328	11 KV NALCO MAIN GAT	14328202	RUGUDI SAHI-II (NEAR KUMBHAR SAI	4213DT260	100	MIXED	AMI	Yes	100%	69	0.05986262	0.04622	0.01364262	22.79%
6869	TPCODL	DHENKAN	ANED	ANGUL	KULAD (KANDASAR)	14328	11 KV NALCO MAIN GAT	14328202	SAI NAGAR	4213DT261	500	MIXED	AMI	Yes	100%	125	0.11521828	0.101162	0.01405628	12.20%
6870	TPCODL	DHENKAN	ANED	ANGUL	KULAD (KANDASAR)	14328	11 KV NALCO MAIN GAT	14328202	KUMARSAHI	4213DT264	250	MIXED	AMI	Yes	100%	218	0.12671316	0.108561	0.01815216	14.33%
6871	TPCODL	DHENKAN	ANED	ANGUL	KULAD (KANDASAR)	14328	11 KV TURANGA	14328203	SCHOOL SAHI(MASTER SAHI)	4213DT227	100	MIXED	AMI	Yes	100%	72	0.12173664	0.042237	0.07949964	65.30%
6872	TPCODL	DHENKAN	ANED	ANGUL	KULAD (KANDASAR)	14328	11 KV TURANGA	14328203	SCHOOL SAHI-II	4213DT234	100	MIXED	AMI	Yes	100%	57	0.05911824	0.039693	0.01942524	32.86%
6873	TPCODL	DHENKAN	ANED	ANGUL	KULAD (KANDASAR)	14328	11 KV TURANGA	14328203	KANYABEDA SCHOOL SAHI	4213DT240	100	MIXED	AMI	Yes	100%	72	0.07010118	0.039407	0.03069418	43.79%
6874	TPCODL	DHENKAN	ANED	ANGUL	KULAD (KANDASAR)	14328	11 KV TURANGA	14328203	BALIA MARKET KANYABEDA	4213DT242	100	MIXED	AMI	Yes	100%	50	0.08966094	0.059145	0.03051594	34.03%
6875	TPCODL	DHENKAN	ANED	ANGUL	KULAD (KANDASAR)	14328	11 KV TURANGA	14328203	TAPASWANI COLONY (KANYABEDA)	4213DT243	100	MIXED	AMI	Yes	100%	22	0.10069436	0.021544	0.07915036	78.60%
6876	TPCODL	DHENKAN	ANED	ANGUL	KULAD (KANDASAR)	14328	11 KV TURANGA	14328203	TURUNGA INDRAHARI NAGAR	4213DT246	250	MIXED	AMI	Yes	0%	189	0.2067226	0.173396	0.0333266	16.12%
6877	TPCODL	DHENKAN	ANED	ANGUL	KULAD (KANDASAR)	14328	11 KV BENTPUR	14328204	MUNDA HUTTING	4213DT133	500	MIXED	AMI	Yes	0%	574	0.17832288	0.149295	0.02902788	16.28%
6878	TPCODL	DHENKAN	ANED	ANGUL	RCMS	14132	11 KV HARIMAHURI	14132201	MISHRAPADA 2	4211DT109	500	MIXED	AMI	Yes	0%	256	0.31949296	0.229925	0.08956796	28.03%
6879	TPCODL	DHENKAN	ANED	ANGUL	RCMS	14132	11 KV HARIMAHURI	14132201	MISHRAPADA 1	4211DT110	500	MIXED	AMI	Yes	0%	252	0.32183632	0.24464	0.07719632	23.99%
6880	TPCODL	DHENKAN	ANED	ANGUL	RCMS	14132	11 KV HARIMAHURI	14132201	HATISALA PADA,NEAR DHALA HOUSE	4211DT113	100	MIXED	AMI	Yes	100%	38	0.06383692	0.051655	0.01218192	19.08%
6881	TPCODL	DHENKAN	ANED	ANGUL	RCMS	14132	11 KV HARIMAHURI	14132201	HARIMAHURY CHHAK 1	4211DT115	500	MIXED	AMI	Yes	33%	151	0.18567096	0.182213	0.00345796	1.86%
6882	TPCODL	DHENKAN	ANED	ANGUL	RCMS	14132	11 KV HARIMAHURI	14132201	KALINGA MARKET COMPLEX	4211DT117	250	MIXED	AMI	Yes	100%	187	0.28287692	0.139109	0.14376792	50.82%
6883	TPCODL	DHENKAN	ANED	ANGUL	RCMS	14132	11 KV HARIMAHURI	14132201	HULURISINGHA NEAR HOTEL SANDHY	4211DT120	100	MIXED	AMI	Yes	100%	40	0.1419247	0.047447	0.0944777	66.57%
6884	TPCODL	DHENKAN	ANED	ANGUL	RCMS	14132	11 KV HARIMAHURI	14132201	HULURISINGHA CHAKA 1	4211DT123	500	MIXED	AMI	Yes	100%	553	0.69128864	0.661204	0.03008464	4.35%
6885	TPCODL	DHENKAN	ANED	ANGUL	RCMS	14132	11 KV HARIMAHURI	14132201	MUSHILIM PADA	4211DT125	100	MIXED	AMI	Yes	100%	67	0.1253446	0.075046	0.0502986	40.13%
6886	TPCODL	DHENKAN	ANED	ANGUL	RCMS	14132	11 KV AMALAPADA	14132202	BED CHHAK	4212DT192	100	MIXED	AMI	Yes	33%	34	0.04384318	0.032575	0.01126818	25.70%
6887	TPCODL	DHENKAN	ANED	ANGUL	RCMS	14132	11 KV AMALAPADA	14132202	THANA CHHACK-2(NEAR PHD OFFICE	4212DT202	250	MIXED	AMI	Yes	0%	104	0.09857172	0.070757	0.02781472	28.22%
6888	TPCODL	DHENKAN	ANED	ANGUL	RCMS	14132	11 KV AMALAPADA	14132202	MISSION BUNGLOW(NEAR SYNDICAT	4212DT212	250	MIXED	AMI	Yes	100%	160	0.1747894	0.105261	0.0695284	39.78%
6889	TPCODL	DHENKAN	ANED	ANGUL	RCMS	14132	11 KV AMALAPADA	14132202	TPCODL DIVISION OFFICE(BASANTI PI	4212DT214	250	MIXED	AMI	Yes	100%	94	0.08618272	0.081239	0.00494372	5.74%
6890	TPCODL	DHENKAN	ANED	ANGUL	RCMS	14132	11 KV AMALAPADA	14132202	GIRLS HIGH SCHOOL-AMALAPADA	4212DT215	500	MIXED	AMI	Yes	0%	234	0.2530536	0.200483	0.0525706	20.77%
6891	TPCODL	DHENKAN	ANED	ANGUL	RCMS	14132	11 KV AMALAPADA	14132202	AMALAPADA 4TH LANE NEAR POND	4212DT220	250	MIXED	AMI	Yes	100%	61	0.1580948	0.052426	0.1056688	66.84%
6892	TPCODL	DHENKAN	ANED	ANGUL	RCMS	14132	11 KV AMALAPADA	14132202	MASJID AMALAPADA	4212DT223	250	MIXED	AMI	Yes	0%	120	0.14469032	0.12022	0.02447032	16.91%
6893	TPCODL	DHENKAN	ANED	ANGUL	RCMS	14132	11 KV AMALAPADA	14132202	GURU GOVIND DHAM AMALAPADA D	4212DT225	500	MIXED	AMI	Yes	0%	194	0.24520336	0.192165	0.05303836	21.63%
6894	TPCODL	DHENKAN	ANED	ANGUL	RCMS	14132	11 KV AMALAPADA	14132202	AMALAPADA 6TH LANE NEAR PERFEC	4212DT230	100	MIXED	AMI	Yes	33%	22	0.06425606	0.062184	0.00207206	3.22%
6895	TPCODL	DHENKAN	ANED	ANGUL	RCMS	14132	11 KV AMALAPADA	14132202	NEAR GOVT BUS STAND	4212DT234	250	MIXED	AMI	Yes	100%	120	0.15785224	0.118046	0.03980624	25.22%
6896	TPCODL	DHENKAN	ANED	ANGUL	RCMS	14132	11 KV RCMS THANA	14132203	LIC COLONY	4212DT134	100	MIXED	AMI	Yes	67%	29	0.04025904	0.033718	0.00654104	16.25%
6897	TPCODL	DHENKAN	ANED	ANGUL	RCMS	14132	11 KV RCMS THANA	14132203	CESU SUB DIVISION	4212DT145	250	MIXED	AMI	Yes	100%	72	0.1780806	0.050924	0.1271566	71.40%
6898	TPCODL	DHENKAN	ANED	ANGUL	RCMS	14132	11 KV RCMS THANA	14132203	SP OFFICE	4212DT147	100	MIXED	AMI	Yes	100%	24	0.09481142	0.050681	0.04413042	46.55%
6899	TPCODL	DHENKAN	ANED	ANGUL	RCMS	14132	11 KV RCMS THANA	14132203	HANUMAN BAZAR-1	4212DT154	500	MIXED	AMI	Yes	0%	206	0.3182864	0.309038	0.0092484	2.91%
6900	TPCODL	DHENKAN	ANED	ANGUL	RCMS	14132	11 KV RCMS THANA	14132203	BHAKTI DAS GALI	4212DT156	250	MIXED	AMI	Yes	67%	94	0.15696156	0.073674	0.08328756	53.06%
6901	TPCODL	DHENKAN	ANED	ANGUL	RCMS	14132	11 KV RCMS THANA	14132203	HAKIMPADA(RABI PANDA CHAKA)	4212DT157	500	MIXED	AMI	Yes	100%	202	0.26026344	0.17477	0.08549344	32.85%
6902	TPCODL	DHENKAN	ANED	ANGUL	RCMS	14132	11 KV RCMS RE-2	14132204	KHALARI RANKEI	4214DT624	100	MIXED	AMI	Yes	67%	33	0.04428988	0.023299	0.02099088	47.39%
6903	TPCODL	DHENKAN	ANED	ANGUL	RCMS	14132	11 KV RCMS RE-2	14132204	CHHELIAPADA VILLAGE	4214DT642	100	MIXED	AMI	Yes	100%	177	0.0747271	0.049939	0.0247881	33.17%
6904	TPCODL	DHENKAN	ANED	ANGUL	RCMS	14132	11 KV RCMS RE-2	14132204	CHHELIAPADA BUDHAPADA SAHI 3	4214DT645	100	MIXED	AMI	Yes	67%	65	0.03299998	0.020145	0.01285498	38.95%
6905	TPCODL	DHENKAN	ANED	ANGUL	RCMS	14132	11 KV RCMS RE-2	14132204	CHHELIAPADA MATHA SAHI	4214DT649	100	MIXED	AMI	Yes	67%	68	0.0430144	0.02569	0.0173244	40.28%
6906	TPCODL	DHENKAN	ANED	ANGUL	RCMS	14132	11 KV RCMS RE-2	14132204	CHHELIAPADA CHHACK 2 (NEAR TOW	4214DT679	200	MIXED	AMI	Yes	0%	77	0.10637048	0.071538	0.03483248	32.75%
6907	TPCODL	DHENKAN	ANED	ANGUL	RCMS	14132	11 KV RCMS RE-2	14132204	KHAMAR VILLAGAE	4214DT681	100	MIXED	AMI	Yes	67%	95	0.08833068	0.044925	0.04340568	49.14%
6908	TPCODL	DHENKAN	ANED	ANGUL	RCMS	14132	11 KV RCMS RE-2	14132204	KANGULA TIARA SAHI 2	4214DT686	100	MIXED	AMI	Yes	67%	92	0.05213542	0.034755	0.01738042	33.34%
6909	TPCODL	DHENKAN	ANED	ANGUL	RCMS	14132	11 KV RCMS RE-2	14132204	KANGULA GODI SAHI 1	4214DT692	100	MIXED	AMI	Yes	0%	59	0.03605064	0.020946	0.01510464	41.90%
6910	TPCODL	DHENKAN	ANED	ANGUL	RCMS	14132	11 KV RCMS RE-2	14132204	KANGULA GODI SAHI 2	4214DT694	100	MIXED	AMI	Yes	67%	59	0.04328824	0.02022927	0.02305897	53.27%
6911	TPCODL	DHENKAN	ANED	ANGUL	RCMS	14132	11 KV RCMS RE-2	14132204	SAMAKOI VILLAGE 1	4214DT720	100	MIXED	AMI	Yes	67%	72	0.05914984	0.024986	0.03416384	57.76%
6912	TPCODL	DHENKAN	ANED	ANGUL	RCMS	14132	11 KV RCMS RE-2	14132204	BARASINGHA VILLAGE 2	4214DT734	100	MIXED	AMI	Yes	67%	91	0.03925192	0.025211	0.01404092	35.77%
6913	TPCODL	DHENKAN	ANED	ANGUL	RCMS	14132	11 KV RCMS RE-2	14132204	GADARAKHAI VILLAGE	4214DT746	100	MIXED	AMI	Yes	67%	97	0.0823548	0.045184	0.0371708	45.13%
6914	TPCODL	DHENKAN	ANED	ANGUL	RCMS	14132	11 KV RCMS RE-2	14132204	KHANDAHATA VILLAGE -1	4214DT755	100	MIXED	AMI	Yes	67%	90	0.04514928	0.024182	0.02096728	46.44%
6915	TPCODL	DHENKAN	ANED	ANGUL	RCMS	14132	11 KV RCMS RE-2	14132204	INKARABANADHA KENDUPULI SAHI	4214DT815	100	MIXED	AMI	Yes	67%	63	0.02843098	0.020899	0.00753198	26.49%
6916	TPCODL	DHENKAN	ANED	ANGUL	RCMS	14132	11 KV RCMS RE-2	14132204	BALASINGHA VILLAGE 2	4214DT828	100	MIXED	AMI	Yes	67%	224	0.07198488	0.055754	0.01623088	22.55%
6917	TPCODL	DHENKAN	ANED	ANGUL	RCMS	14132	11 KV RCMS RE-2	14132204	BENTPUR VILLAGE 1	4214DT849	100	MIXED	AMI	Yes	100%	33	0.01867066	0.01267	0.00600066	32.14%
6918	TPCODL	DHENKAN	ANED	ANGUL	RCMS	14132	11 KV RCMS RE-2	14132204	BENTPUR VILLAGE 2	4214DT851	250	MIXED	AMI	Yes	67%	156	0.10478608	0.076177	0.02860908	27.30%
6919	TPCODL	DHENKAN	ANED	ANGUL	RCMS	14132	11 KV RCMS RE-2	14132204	BENTPUR SCHOOL SAHI	4214DT853	100	MIXED	AMI	Yes	67%	77	0.0463096	0.031353	0.0149566	32.30%
6920	TPCODL	DHENKAN	ANED	ANGUL	RCMS	14132	11 KV RCMS RE-2	14132204	KANGULA MUNDIA SAHI	4214DT863	100	MIXED	AMI	Yes	67%	143	0.06055478	0.049691	0.01086378	17.94%
6921	TPCODL	DHENKAN	ANED	ANGUL	RCMS	14132	11 KV RCMS RE-2	14132204	NUA SAHI VILLAGE	4214DT866	250	MIXED	AMI	Yes	67%	80	0.11911232	0.028209	0.09090332	76.32%
6922	TPCODL	DHENKAN	ANED	ANGUL	RCMS	14132	11 KV RCMS RE-2	14132204	NUA SAHI CHHACK SAHI	4214DT868	100	MIXED	AMI	Yes	67%	129	0.0741765	0.047159	0.0270175	36.42%
6923	TPCODL	DHENKAN	ANED	ANGUL	RCMS	14132	11 KV RCMS RE-1	14132205	NIGAMANANDA LANE	4212DT159	100	MIXED	AMI	Yes	100%	62	0.0724042	0.068821	0.0035832	4.95%
6924	TPCODL	DHENKAN	ANED	ANGUL	RCMS	14132	11 KV RCMS BAZAR	14132206	HATISALAPADA	4211DT203	250	MIXED	AMI	Yes	100%	138	0.1820628	0.124335	0.0577278	31.71%
6925	TPCODL	DHENKAN	ANED	ANGUL	RCMS	14132	11 KV RCMS BAZAR	14132206	TOWN HALL	4212DT014	250	MIXED	AMI	Yes	0%	189	0.20661612	0.183201	0.02341512	11.33%
6926	TPCODL	DHENKAN	ANED	ANGUL	RCMS	14132	11 KV RCMS BAZAR	14132206	JAGANNATH MANDIR	4212DT016	250	MIXED	AMI	Yes	0%	65	0.13266052	0.052541	0.08011952	60.39%
6927	TPCODL	DHENKAN	ANED	ANGUL	RCMS	14132	11 KV RCMS BAZAR	14132206	MADANMOHAN PADA	4212DT017	100	MIXED	AMI	Yes	100%	67	0.08623696	0.058692	0.02754496	31.94%
6928	TPCODL	DHENKAN	ANED	ANGUL	RCMS	14132	11 KV RCMS BAZAR	14132206	MASJID	4212DT019	250	MIXED	AMI	Yes	0%	117	0.12581112	0.099773	0.02603812	20.70%
6929	TPCODL	DHENKAN	ANED	ANGUL	RCMS	14132	11 KV RCMS BAZAR	14132206	PATNAIK CAHAKA-I	4212DT020	500	MIXED	AMI	Yes	0%	153	0.15462184	0.148541	0.00608084	3.93%
6930	TPCODL	DHENKAN	ANED	ANGUL	RCMS	14132	11 KV RCMS BAZAR	14132206	BAZAR CHAKA-II	4212DT025	250	MIXED	AMI	Yes	0%	73	0.1399368	0.09253	0.0474068	33.88%
6931	TPCODL	DHENKAN	ANED	ANGUL	RCMS	14132	11 KV RCMS BAZAR	14132206	MATHA GALI	4212DT028	250	MIXED	AMI	Yes	0%	114	0.13725096	0.108962	0.02828896	20.61%
6932	TPCODL	DHENKAN	ANED	ANGUL	RCMS	14132	11 KV RCMS BAZAR	14132206	SASNKRIT COLLEGE-I	4212DT034	250	MIXED	AMI	Yes	100%	161	0.21584316	0.147997	0.06784616	31.43%
6933	TPCODL	DHENKAN	ANED	ANGUL	RCMS	14132	11 KV RCMS BAZAR	14132206	PWD OFFICE	4212DT036	250	MIXED	AMI	Yes	0%	18	0.02812144	0.026953	0.00116844	4.15%
6934	TPCODL	DHENKAN	ANED	ANGUL	RCMS	14132	11 KV RCMS BAZAR	14132206	DAILY MARKET 2	4212DT038	250	MIXED	AMI	Yes	0%	243	0.2083544	0.208152	0.0002024	0.10%

Sl. No.	Zone Name	Circle name	Division name	Name of the Sub-division	Name of the Sub-station	Substation Code	Name of the 11 kV Feeder	Feeder Code	Name of the Location where DT situated	DT code	DT Capacity (kVA)	Predominant consumer type of DT (Domestic/Industrial/Agriculture/Mixed)	Type of metering AMR/AMI/ Communicable/Conventional metered/Unmetered	Status of Meter-whether Functional (Yes/No)	% of data received automatically (if AMR/AMI)	No. of Connected Consumers	Input Energy (MU) (A)	Billed Energy (MU) (B)	Loss (MU) (A-B)	% DT Loss (A-B)/A
6935	TPCODL	DHENKAN	ANED	ANGUL	RCMS	14132	11 kV RCMS BAZAR	14132206	BRAHMANIDEI PADA	4212DT040	250	MIXED	AMI	Yes	0%	90	0.13523704	0.098149	0.03708804	27.42%
6936	TPCODL	DHENKAN	ANED	ANGUL	RCMS	14132	11 kV RCMS BAZAR	14132206	MEDICAL CHAKA	4212DT048	250	MIXED	AMI	Yes	0%	49	0.12517936	0.044133	0.08104636	64.74%
6937	TPCODL	DHENKAN	ANED	ANGUL	RCMS	14132	11 KV RCMS COLLEGE	14132207	RCMS STRUCTURE	4212DT165	250	MIXED	AMI	Yes	100%	51	0.06792888	0.042815	0.02511388	36.97%
6938	TPCODL	DHENKAN	ANED	ANGUL	RCMS	14132	11 KV RCMS COLLEGE	14132207	ASHRAM CHAKA-I (IRRIGATIONOFFIC	4212DT166	250	MIXED	AMI	Yes	0%	137	0.11229524	0.109838	0.00245724	2.19%
6939	TPCODL	DHENKAN	ANED	ANGUL	RCMS	14132	11 KV RCMS COLLEGE	14132207	HAPPY BANDHA	4212DT171	250	MIXED	AMI	Yes	33%	112	0.09352084	0.076548	0.01697284	18.15%
6940	TPCODL	DHENKAN	ANED	ANGUL	RCMS	14132	11 KV RCMS COLLEGE	14132207	DPR SUSUDA	4212DT178	250	MIXED	AMI	Yes	100%	81	0.17442	0.077869	0.096551	55.36%
6941	TPCODL	DHENKAN	ANED	ANGUL	RCMS	14132	11 KV RCMS COLLEGE	14132207	SAILABALA SUSUDA	4212DT179	500	MIXED	AMI	Yes	0%	174	0.25909312	0.147731	0.11136212	42.98%
6942	TPCODL	DHENKAN	ANED	ANGUL	RCMS	14132	11 KV RCMS COLLEGE	14132207	DURGADEVI-I SUSUDA	4212DT183	500	MIXED	AMI	Yes	0%	215	0.26080108	0.18148	0.07932108	30.41%
6943	TPCODL	DHENKAN	ANED	ANGUL	RCMS	14132	11 KV RCMS COLLEGE	14132207	DURGADEVI-II SUSUDA	4212DT184	100	MIXED	AMI	Yes	100%	108	0.06552808	0.043691	0.02183708	33.32%
6944	TPCODL	DHENKAN	ANED	ANGUL	RCMS	14132	11 kV KHALARI	14132208	KABAR KHANA	4212DT110	100	MIXED	AMI	Yes	100%	80	0.08020632	0.068519	0.01168732	14.57%
6945	TPCODL	DHENKAN	ANED	ANGUL	RCMS	14132	11 kV KHALARI	14132208	PHD COLONY	4212DT112	250	MIXED	AMI	Yes	100%	182	0.16047812	0.133684	0.02679412	16.70%
6946	TPCODL	DHENKAN	ANED	ANGUL	RCMS	14132	11 kV KHALARI	14132208	GURUHATA MATIA SAHI	4212DT116	500	MIXED	AMI	Yes	100%	171	0.18748896	0.11174	0.07574896	40.40%
6947	TPCODL	DHENKAN	ANED	ANGUL	RCMS	14132	11 kV KHALARI	14132208	KHALARI RAMESWAR MANDIR	4214DT546	500	MIXED	AMI	Yes	100%	358	0.38264104	0.304943	0.07769804	20.31%
6948	TPCODL	DHENKAN	ANED	ANGUL	RCMS	14132	11 kV KHALARI	14132208	KHALARI GADAPADA SAHI CHHACK	4214DT550	500	MIXED	AMI	Yes	100%	309	0.30231904	0.227856	0.07446304	24.63%
6949	TPCODL	DHENKAN	ANED	ANGUL	RCMS	14132	11 kV PTC	14132209	SIMILIPADA,MAHURI COLONY	4212DT062	250	MIXED	AMI	Yes	100%	146	0.17162388	0.169169	0.00245488	1.43%
6950	TPCODL	DHENKAN	ANED	ANGUL	RCMS	14132	11 kV PTC	14132209	BHARAT NAGAR,SIMILIPADA	4212DT072	100	MIXED	AMI	Yes	67%	81	0.06561614	0.062775	0.00284114	4.33%
6951	TPCODL	DHENKAN	ANED	ANGUL	RCMS	14132	11 kV PTC	14132209	MILAN VILLA-IPDS	4212DT074	250	MIXED	AMI	Yes	100%	97	0.1615492	0.117593	0.0439562	27.21%
6952	TPCODL	DHENKAN	ANED	ANGUL	RCMS	14132	11 kV PTC	14132209	SIMILIPADA,PANCHA CHAKIA NO-2,N	4212DT078	500	MIXED	AMI	Yes	100%	260	0.3335284	0.24078	0.0927484	27.81%
6953	TPCODL	DHENKAN	ANED	ANGUL	RCMS	14132	11 kV PTC	14132209	RAAZ CHAKA,SIMILIPADA	4212DT089	500	MIXED	AMI	Yes	100%	166	0.15619008	0.144424	0.01176608	7.53%
6954	TPCODL	DHENKAN	ANED	ANGUL	RCMS	14132	11 kV PTC	14132209	OMM APARTMENT,GITAGRAM	4212DT092	250	MIXED	AMI	Yes	100%	49	0.0423446	0.039175	0.0031696	7.49%
6955	TPCODL	DHENKAN	ANED	ANGUL	RCMS	14132	11 kV PTC	14132209	GITAGRAM PLOTTING	4212DT094	250	MIXED	AMI	Yes	100%	85	0.09052348	0.080572	0.00995148	10.99%
6956	TPCODL	DHENKAN	ANED	ANGUL	RCMS	14132	11 kV PTC	14132209	PTC MEDICAL	4212DT097	100	MIXED	AMI	Yes	100%	24	0.04164594	0.017143	0.02450294	58.84%
6957	TPCODL	DHENKAN	ANED	ANGUL	RCMS	14132	11 kV PTC	14132209	PTC,HARIJANA SAHI	4212DT098	100	MIXED	AMI	Yes	100%	89	0.0595935	0.032327	0.0272665	45.75%
6958	TPCODL	DHENKAN	ANED	ANGUL	RCMS	14132	11 kV PTC	14132209	VAISHNODEVI VIHAR,CALTAX	4212DT105	100	MIXED	AMI	Yes	100%	65	0.07497696	0.068737	0.00623996	8.32%
6959	TPCODL	DHENKAN	ANED	ANGUL	RCMS	14132	11 kV PTC	14132209	SANTOSHI MANDIR,GITAGRAM	4212DT108	100	MIXED	AMI	Yes	100%	67	0.10602708	0.07373	0.03229708	30.46%
6960	TPCODL	DHENKAN	ANED	ANGUL	RCMS	14132	11 kV PTC	14132209	CALTAX CHHAKA	4212DT120	500	MIXED	AMI	Yes	0%	251	0.25280448	0.225435	0.02736948	10.83%
6961	TPCODL	DHENKAN	ANED	ANGUL	RCMS	14132	11 kV PTC	14132209	NEAR PRASANTI HOTEL	4212DT126	500	MIXED	AMI	Yes	0%	117	0.21473272	0.11452	0.10021272	46.67%
6962	TPCODL	DHENKAN	ANED	ANGUL	RCMS	14132	11 kV PTC	14132209	NEAR PRASANTI HOTEL	4212DT129	100	MIXED	AMI	Yes	100%	47	0.06523736	0.053594	0.01164336	17.85%
6963	TPCODL	DHENKAN	ANED	ANGUL	RCMS	14132	11 kV BANIABAHAL	14132210	KANSA PLOTTING	4211DT173	250	MIXED	AMI	Yes	0%	89	0.12718552	0.084485	0.04270052	33.57%
6964	TPCODL	DHENKAN	ANED	ANGUL	RCMS	14132	11 kV BANIABAHAL	14132210	LINGARA JODI	4211DT174	250	MIXED	AMI	Yes	0%	208	0.31007848	0.086023	0.22405548	72.26%
6965	TPCODL	DHENKAN	ANED	ANGUL	RCMS	14132	11 kV BANIABAHAL	14132210	BANIABAHAL NEW CAPEX(ASHOK MI	4211DT181	250	MIXED	AMI	Yes	100%	120	0.14185192	0.077787	0.06406492	45.16%
6966	TPCODL	DHENKAN	ANED	ANGUL	RCMS	14132	11 kV BANIABAHAL	14132210	BANIABAHAL	4211DT183	250	MIXED	AMI	Yes	0%	268	0.36545796	0.131489	0.23396896	64.02%
6967	TPCODL	DHENKAN	ANED	ANGUL	RCMS	14132	11 kV BANIABAHAL	14132210	MATIASAHI NEAR BALABHADRA PATI	4212DT054	500	MIXED	AMI	Yes	0%	197	0.2177464	0.186544	0.0312024	14.33%
6968	TPCODL	DHENKAN	ANED	ANGUL	RCMS	14132	11 kV BANIABAHAL	14132210	MATIASAHI BEER BAR	4212DT056	100	MIXED	AMI	Yes	0%	58	0.09772298	0.072584	0.02513898	25.72%
6969	TPCODL	DHENKAN	ANED	ANGUL	RCMS	14132	11 KV PANCHAMAHALA	14132211	NEAR BINAYAKA CONSTRUCTION195	4211DT131	100	MIXED	AMI	Yes	100%	7	0.0075772	0.002955	0.0046222	61.00%
6970	TPCODL	DHENKAN	ANED	ANGUL	RCMS	14132	11 KV PANCHAMAHALA	14132211	PINTU NANAD	4211DT135	250	MIXED	AMI	Yes	100%	118	0.15096192	0.124386	0.02657592	17.60%
6971	TPCODL	DHENKAN	ANED	ANGUL	RCMS	14132	11 KV PANCHAMAHALA	14132211	TASTY FACTORY	4211DT136	100	MIXED	AMI	Yes	0%	43	0.10347544	0.051397	0.05207844	50.33%
6972	TPCODL	DHENKAN	ANED	ANGUL	RCMS	14132	11 KV PANCHAMAHALA	14132211	KARADAGADIA	4211DT139	250	MIXED	AMI	Yes	0%	111	0.13594352	0.077297	0.05864652	43.14%
6973	TPCODL	DHENKAN	ANED	ANGUL	RCMS	14132	11 KV PANCHAMAHALA	14132211	KARADA GADIA DESI	4211DT144	100	MIXED	AMI	Yes	33%	128	0.151679	0.077484	0.074195	48.92%
6974	TPCODL	DHENKAN	ANED	ANGUL	RCMS	14132	11 KV PANCHAMAHALA	14132211	ANADA BAZAR NEW CAPEX	4211DT150	250	MIXED	AMI	Yes	0%	73	0.2151726	0.075373	0.1397996	64.97%
6975	TPCODL	DHENKAN	ANED	ANGUL	RCMS	14132	11 KV PANCHAMAHALA	14132211	TOLL GATE	4211DT156	250	MIXED	AMI	Yes	67%	50	0.0730058	0.063818	0.0091878	12.59%
6976	TPCODL	DHENKAN	ANED	ANGUL	RCMS	14132	11 KV PANCHAMAHALA	14132211	BANTALA ROAD	4211DT160	250	MIXED	AMI	Yes	67%	265	0.2398412	0.226912	0.0129292	5.39%
6977	TPCODL	DHENKAN	ANED	ANGUL	RCMS	14132	11 KV PANCHAMAHALA	14132211	PANCHAMAHALA VILLAGE(KANDHA S	4211DT164	100	MIXED	AMI	Yes	33%	84	0.04529022	0.022926	0.02236422	49.38%
6978	TPCODL	DHENKAN	ANED	ANGUL	RCMS	14132	11 KV PANCHAMAHALA	14132211	PANCHAMAHALA GR	4211DT230	250	MIXED	AMI	Yes	100%	179	0.21929304	0.134129	0.08516404	38.84%
6979	TPCODL	DHENKAN	ANED	ANGUL	RCMS	14132	11 KV PANCHAMAHALA	14132211	GHASA FIRM	4211DT291	100	MIXED	AMI	Yes	100%	16	0.04389074	0.034599	0.00929174	21.17%
6980	TPCODL	DHENKAN	ANED	BOINDA	ANANDAPUR	14138	11 KV THAKURGARH	14138201	THAKURGARH MADABHATI	4221DT731	100	MIXED	AMI	Yes	67%	99	0.03841224	0.027487	0.01092524	28.44%
6981	TPCODL	DHENKAN	ANED	BOINDA	ANANDAPUR	14138	11 KV THAKURGARH	14138201	THAKURGARH P.S.-1	4221DT733	100	MIXED	AMI	Yes	67%	117	0.09274952	0.046856	0.04589352	49.48%
6982	TPCODL	DHENKAN	ANED	BOINDA	ANANDAPUR	14138	11 KV THAKURGARH	14138201	THAKURGARH P.S.-2	4221DT734	100	MIXED	AMI	Yes	100%	88	0.09592782	0.039423	0.05650482	58.90%
6983	TPCODL	DHENKAN	ANED	BOINDA	ANANDAPUR	14138	11 KV THAKURGARH	14138201	SHIBAMANDIR	4221DT759	100	MIXED	AMI	Yes	67%	95	0.06169914	0.040142	0.02155714	34.94%
6984	TPCODL	DHENKAN	ANED	BOINDA	ANANDAPUR	14138	11 KV THAKURGARH	14138201	TALAMALIA	4221DT872	100	MIXED	AMI	Yes	100%	79	0.0170058	0.014675	0.0023308	13.71%
6985	TPCODL	DHENKAN	ANED	BOINDA	ANANDAPUR	14138	11 KV KRUTIBASHPUR	14138202	BANAMALIPUR VILLAGE 1	4221DT942	100	MIXED	AMI	Yes	100%	120	0.0427741	0.031603	0.0111711	26.12%
6986	TPCODL	DHENKAN	ANED	BOINDA	ATHAMALIK	14139	11 KV ATHAMALLIK TOW	14139201	TANGIANISA VILLAGE	4223DT453	250	MIXED	AMI	Yes	67%	85	0.0323252	0.014995	0.0173302	53.61%
6987	TPCODL	DHENKAN	ANED	BOINDA	ATHAMALIK	14139	11 KV ATHAMALLIK TOW	14139201	HARIDANALI-1	4223DT467	100	MIXED	AMI	Yes	67%	78	0.0738714	0.064333	0.0095384	12.91%
6988	TPCODL	DHENKAN	ANED	BOINDA	ATHAMALIK	14139	11 KV ATHAMALLIK TOW	14139201	BETRA SAHI	4223DT472	100	MIXED	AMI	Yes	67%	67	0.1090121	0.031559	0.0774531	71.05%
6989	TPCODL	DHENKAN	ANED	BOINDA	ATHAMALIK	14139	11 KV ATHAMALLIK TOW	14139201	MANJOR CHHAK	4223DT473	100	MIXED	AMI	Yes	67%	46	0.04178144	0.030387	0.01139444	27.27%
6990	TPCODL	DHENKAN	ANED	BOINDA	ATHAMALIK	14139	11 KV ATHAMALLIK TOW	14139201	MI COLONY	4223DT475	100	MIXED	AMI	Yes	67%	23	0.02450162	0.015349	0.00915262	37.36%
6991	TPCODL	DHENKAN	ANED	BOINDA	ATHAMALIK	14139	11 KV ATHAMALLIK TOW	14139201	KATHABENTA SAHI-2	4223DT483	100	MIXED	AMI	Yes	67%	46	0.03910422	0.02466	0.01444422	36.94%
6992	TPCODL	DHENKAN	ANED	BOINDA	ATHAMALIK	14139	11 KV ATHAMALLIK TOW	14139201	MUSLIM BASTI	4223DT485	100	MIXED	AMI	Yes	67%	54	0.06305686	0.019321	0.04373586	69.36%
6993	TPCODL	DHENKAN	ANED	BOINDA	ATHAMALIK	14139	11 KV ATHAMALLIK TOW	14139201	BADAMPADIA	4223DT486	100	MIXED	AMI	Yes	67%	40	0.01994816	0.009806	0.01014216	50.84%
6994	TPCODL	DHENKAN	ANED	BOINDA	ATHAMALIK	14139	11 KV ATHAMALLIK TOW	14139201	RAJBATI	4223DT487	100	MIXED	AMI	Yes	67%	22	0.01689396	0.006644	0.01024996	60.67%
6995	TPCODL	DHENKAN	ANED	BOINDA	ATHAMALIK	14139	11 KV ATHAMALLIK TOW	14139201	BARAGAON-1	4223DT488	100	MIXED	AMI	Yes	67%	231	0.07741074	0.052969	0.02444174	31.57%
6996	TPCODL	DHENKAN	ANED	BOINDA	ATHAMALIK	14139	11 KV ATHAMALLIK TOW	14139201	BARAGAON-2	4223DT489	100	MIXED	AMI	Yes	67%	45	0.01919138	0.007069	0.01212238	63.17%
6997	TPCODL	DHENKAN	ANED	BOINDA	ATHAMALIK	14139	11 KV ATHAMALLIK TOW	14139201	GANDHI CHHAK-1	4223DT491	500	MIXED	AMI	Yes	67%	177	0.25610992	0.142474	0.11363592	44.37%
6998	TPCODL	DHENKAN	ANED	BOINDA	ATHAMALIK	14139	11 KV ATHAMALLIK TOW	14139201	MEDICAL CHHAK-2	4223DT500	500	MIXED	AMI	Yes	67%	149	0.15898064	0.096712	0.06226864	39.17%
6999	TPCODL	DHENKAN	ANED	BOINDA	ATHAMALIK	14139	11 KV ATHAMALLIK TOW	14139201	ATHAMALLIK MEDICAL COLONY	4223DT502	250	MIXED	AMI	Yes	0%	39	0.031819	0.025693	0.006126	19.25%
7000	TPCODL	DHENKAN	ANED	BOINDA	ATHAMALIK	14139	11 KV ATHAMALLIK TOW	14139201	ATHAMALLIK CIRCUIT HOUSE	4223DT503	250	MIXED	AMI	Yes	0%	130	0.12076012	0.06688	0.05388012	44.62%
7001	TPCODL	DHENKAN	ANED	BOINDA	ATHAMALIK	14139	11 KV ATHAMALLIK TOW	14139201	RAMESHWAR PATTNAIK	4223DT504	500	MIXED	AMI	Yes	67%	245	0.1110156	0.069202	0.0418136	37.66%
7002	TPCODL	DHENKAN	ANED	BOINDA	ATHAMALIK	14139	11 KV ATHAMALLIK TOW	14139201	GANGARAM CHHAK-2	4223DT508	250	MIXED	AMI	Yes	0%	99	0.13525824	0.090803	0.04445524	32.87%
7003	TPCODL	DHENKAN	ANED	BOINDA	ATHAMALIK	14139	11 KV ATHAMALLIK TOW	14139201	BANGALA SAHI JAGANNATH TEMPLE	4223DT511	500	MIXED	AMI	Yes	67%	155	0.15301728	0.108515	0.04450228	29.08%
7004	TPCODL	DHENKAN	ANED	BOINDA	ATHAMALIK	14139	11 KV ATHAMALLIK TOW	14139201	NUASAHI	4223DT513	250	MIXED	AMI	Yes	0%	154	0.15314948	0.089266	0.06388348	41.71%
7005	TPCODL	DHENKAN	ANED	BOINDA	ATHAMALIK	14139	11 KV ATHAMALLIK TOW	14139201	HUNUMAN BAZAR	4223DT518	250	MIXED	AMI	Yes	0%	94	0.07529812	0.073315	0.00198312	2.63%
7006	TPCODL	DHENKAN	ANED	BOINDA	ATHAMALIK	14139	11 KV ATHAMALLIK TOW	14139201	RANJIT BILDERS	4223DT645	100	MIXED	AMI	Yes	67%	3	0.0013112	0.001262	4.92E-05	3.75%
7007	TPCODL	DHENKAN	ANED	BOINDA	ATHAMALIK	14139	11 KV ATHAMALLIK TOW	14139201	LIPTINGA	4223DT646	250	MIXED	AMI	Yes	67%	255	0.16681812	0.080084	0.08673412	51.99%

Sl. No.	Zone Name	Circle name	Division name	Name of the Sub-division	Name of the Sub-station	Substation Code	Name of the 11 kV Feeder	Feeder Code	Name of the Location where DT situated	DT code	DT Capacity (kVA)	Predominant consumer type of DT (Domestic/Industrial/Agriculture/Mixed)	Type of metering AMR/AMI/ Communicable/Conventional metered/Unmetered	Status of Meter- whether Functional (Yes/No)	% of data received automatically (if AMR/AMI)	No. of Connected Consumers	Input Energy (MU) (A)	Billed Energy (MU) (B)	Loss (MU) (A-B)	% DT Loss (A-B)/A
7008	TPCODL	DHENKAN	ANED	BOINDA	ATHAMALIK	14139	11 KV ATHAMALLIK TOW	14139201	FOREST COLONY	4223DT650	250	MIXED	AMI	Yes	67%	73	0.08275048	0.054771	0.02797948	33.81%
7009	TPCODL	DHENKAN	ANED	BOINDA	ATHAMALIK	14139	11 KV MANTIRI	14139202	MALIPADAR VILLAGE-2	4223DT676	100	MIXED	AMI	Yes	67%	48	0.01030136	0.007189	0.00311236	30.21%
7010	TPCODL	DHENKAN	ANED	BOINDA	ATHAMALIK	14139	11 KV MANTIRI	14139202	ODASINGHA VILLAGE-1	4223DT696	100	MIXED	AMI	Yes	67%	90	0.02657042	0.019845	0.00672542	25.31%
7011	TPCODL	DHENKAN	ANED	BOINDA	ATHAMALIK	14139	11 KV MANTIRI	14139202	ODASINGHA VILLAGE-2	4223DT697	63	MIXED	AMI	Yes	0%	71	0.02864314	0.01171	0.01693314	59.12%
7012	TPCODL	DHENKAN	ANED	BOINDA	ATHAMALIK	14139	11 KV BINKEI	14139204	BAHALI VILLAGE	4223DT526	100	MIXED	AMI	Yes	67%	57	0.0083109	0.00814	0.0001709	2.06%
7013	TPCODL	DHENKAN	ANED	BOINDA	ATHAMALIK	14139	11 KV BINKEI	14139204	TENTULIPADAR	4223DT609	100	MIXED	AMI	Yes	67%	106	0.02282674	0.017447	0.00537974	23.57%
7014	TPCODL	DHENKAN	ANED	BOINDA	ATHAMALIK	14139	11 KV BAGHUAKATA	14139205	BADATIKIRA	4223DT402	100	MIXED	AMI	Yes	67%	51	0.01859386	0.010794	0.00779986	41.95%
7015	TPCODL	DHENKAN	ANED	BOINDA	BAMUR	14141	11 KV AMBAPAL	14141204	SCHOOL NEAR AMBAPAL	4222DT085	100	MIXED	AMI	Yes	100%	88	0.05506326	0.029257	0.02580626	46.87%
7016	TPCODL	DHENKAN	ANED	BOINDA	BOINDA	14137	11 KV BOINDA LOCAL	14137201	BOINDA SHIVA MANDIR 1(BOINDA-V	4221DT006	100	MIXED	AMI	Yes	100%	41	0.04328152	0.02678	0.01650152	38.13%
7017	TPCODL	DHENKAN	ANED	BOINDA	BOINDA	14137	11 KV BOINDA LOCAL	14137201	BOINDA MARKET 1(BOINDA NO-II)	4221DT011	100	MIXED	AMI	Yes	0%	31	0.03841278	0.020525	0.01788778	46.57%
7018	TPCODL	DHENKAN	ANED	BOINDA	BOINDA	14137	11 KV BOINDA LOCAL	14137201	BOINDA MARKET-3(BOINDA NO-III)	4221DT020	250	MIXED	AMI	Yes	0%	174	0.18432684	0.115624	0.06870284	37.27%
7019	TPCODL	DHENKAN	ANED	BOINDA	BOINDA	14137	11 KV BOINDA LOCAL	14137201	BOINDA ASHRAM-1(BOINDA NO-V)	4221DT023	100	MIXED	AMI	Yes	100%	108	0.06874116	0.047093	0.02164816	31.49%
7020	TPCODL	DHENKAN	ANED	BOINDA	BOINDA	14137	11 KV BOINDA LOCAL	14137201	BOINDA SIKHYAKAPADA(BOINDA NO	4221DT029	250	MIXED	AMI	Yes	100%	112	0.0936256	0.08289	0.0107356	11.47%
7021	TPCODL	DHENKAN	ANED	BOINDA	BOINDA	14137	11 KV HANDPA	14137202	HANDAPA BAZAR	4221DT505	250	MIXED	AMI	Yes	0%	159	0.10089412	0.06204	0.03885412	38.51%
7022	TPCODL	DHENKAN	ANED	BOINDA	BOINDA	14137	11 KV HANDPA	14137202	HANDAPA MAIN VILLAGE	4221DT511	250	MIXED	AMI	Yes	67%	206	0.07147836	0.039362	0.03211636	44.93%
7023	TPCODL	DHENKAN	ANED	BOINDA	BOINDA	14137	11 KV HANDPA	14137202	HANDAPA CHAKUNDAMUNDA	4221DT518	100	MIXED	AMI	Yes	67%	35	0.01858066	0.01677	0.00181066	9.74%
7024	TPCODL	DHENKAN	ANED	BOINDA	BOINDA	14137	11 KV HANDPA	14137202	PAPASARA MAINVILLAGE	4221DT552	250	MIXED	AMI	Yes	33%	265	0.08467032	0.06362	0.02105032	24.86%
7025	TPCODL	DHENKAN	ANED	BOINDA	BOINDA	14137	11 KV HANDPA	14137202	BELINALI VILLAGE	4221DT580	100	MIXED	AMI	Yes	33%	128	0.04386058	0.025444	0.01841658	41.99%
7026	TPCODL	DHENKAN	ANED	BOINDA	BOINDA	14137	11 KV HANDPA	14137202	GOBINDPUR MAIN VILLAGE	4221DT590	100	MIXED	AMI	Yes	0%	160	0.07701602	0.024192	0.05282402	68.59%
7027	TPCODL	DHENKAN	ANED	BOINDA	BOINDA	14137	11 KV HANDPA	14137202	SALANDA_02	4221DT627	250	MIXED	AMI	Yes	0%	147	0.04128732	0.028523	0.01276432	30.92%
7028	TPCODL	DHENKAN	ANED	BOINDA	BOINDA	14137	11 KV PAIKASAHI	14137204	TAPDHOL 2	4221DT050	100	MIXED	AMI	Yes	33%	250	0.05800592	0.039854	0.01815192	31.29%
7029	TPCODL	DHENKAN	ANED	BOINDA	BOINDA	14137	11 KV PAIKASAHI	14137204	PAIKA SAHI MAIN VILLAGE	4221DT333	100	MIXED	AMI	Yes	100%	171	0.07089814	0.060245	0.01065314	15.03%
7030	TPCODL	DHENKAN	ANED	BOINDA	BOINDA	14137	11 KV LUHAMUNDA	14137205	LUHA MUNDA-1	4221DT145	100	MIXED	AMI	Yes	100%	158	0.07642118	0.060042	0.01637918	21.43%
7031	TPCODL	DHENKAN	ANED	BOINDA	BOINDA	14137	11 KV LUHAMUNDA	14137205	LUHAMUNDA PRADHAN SAHI	4221DT153	100	MIXED	AMI	Yes	100%	71	0.0317844	0.019016	0.0127684	40.17%
7032	TPCODL	DHENKAN	ANED	BOINDA	BOINDA	14137	11 KV LUHAMUNDA	14137205	ICHAPUR 2	4221DT175	250	MIXED	AMI	Yes	0%	60	0.01802988	0.016117	0.00191288	10.61%
7033	TPCODL	DHENKAN	ANED	BOINDA	BOINDA	14137	11 KV SANAHULLA	14137206	BADAHULA MAIN VILLAGE	4221DT377	100	MIXED	AMI	Yes	100%	109	0.03012779	0.023073	0.00705479	23.42%
7034	TPCODL	DHENKAN	ANED	BOINDA	BOINDA	14137	11 KV SANAHULLA	14137206	PEDI PATHAR	4221DT405	100	MIXED	AMI	Yes	100%	124	0.03883454	0.020559	0.01827554	47.06%
7035	TPCODL	DHENKAN	ANED	BOINDA	BOINDA	14137	11 KV SANAHULLA	14137206	PEDI PATHAR SCHOOOL SAHI	4221DT406	100	MIXED	AMI	Yes	100%	61	0.03012232	0.015238	0.01488432	49.41%
7036	TPCODL	DHENKAN	ANED	BOINDA	DHAURAPALLI ODSS	14325	11 KV TALAPADAR	14325201	JAIRAT MAIN VILLAGE	4222DT313	100	MIXED	AMI	Yes	100%	132	0.04250594	0.038701	0.00380494	8.95%
7037	TPCODL	DHENKAN	ANED	BOINDA	DHAURAPALLI ODSS	14325	11 KV TALAPADAR	14325201	BRAMHANI PALI-2	4222DT318	100	MIXED	AMI	Yes	0%	85	0.01990422	0.018589	0.00131522	6.61%
7038	TPCODL	DHENKAN	ANED	BOINDA	DHAURAPALLI ODSS	14325	11 KV RANIAKATA	14325202	DOHILI 2	4222DT492	100	MIXED	AMI	Yes	67%	131	0.06559792	0.046806	0.01879192	28.65%
7039	TPCODL	DHENKAN	ANED	BOINDA	DHAURAPALLI ODSS	14325	11 KV RANIAKATA	14325202	SANDHAPAL	4222DT495	63	MIXED	AMI	Yes	0%	51	0.02049176	0.011021	0.00947076	46.22%
7040	TPCODL	DHENKAN	ANED	BOINDA	DHAURAPALLI ODSS	14325	11 KV RANIAKATA	14325202	HIMITIRA VILLAGE	4222DT504	100	MIXED	AMI	Yes	67%	197	0.05780212	0.042783	0.01501912	25.98%
7041	TPCODL	DHENKAN	ANED	BOINDA	DHAURAPALLI ODSS	14325	11 KV RANIAKATA	14325202	SANJAMURA BANDHASAHI	4222DT540	100	MIXED	AMI	Yes	0%	154	0.05397806	0.027252	0.02672606	49.51%
7042	TPCODL	DHENKAN	ANED	BOINDA	DHAURAPALLI ODSS	14325	11 KV RANIAKATA	14325202	SANJAMURA MAJHISAHI	4222DT541	100	MIXED	AMI	Yes	67%	125	0.02754074	0.025956	0.00158474	5.75%
7043	TPCODL	DHENKAN	ANED	BOINDA	DHAURAPALLI ODSS	14325	11 KV RANIAKATA	14325202	ANGAPADA VILLAGE	4222DT636	100	MIXED	AMI	Yes	67%	131	0.0521658	0.038584	0.0135818	26.04%
7044	TPCODL	DHENKAN	ANED	BOINDA	DHAURAPALLI ODSS	14325	11 KV KADALIMUNDA	14325203	KUSUNI	4222DT424	100	MIXED	AMI	Yes	100%	135	0.02899648	0.01979	0.00920648	31.75%
7045	TPCODL	DHENKAN	ANED	BOINDA	DHAURAPALLI ODSS	14325	11 KV KADALIMUNDA	14325203	KADALIMUNDA	4222DT437	100	MIXED	AMI	Yes	33%	114	0.03373974	0.030342	0.00339774	10.07%
7046	TPCODL	DHENKAN	ANED	BOINDA	DHAURAPALLI ODSS	14325	11 KV KISHORENAGAR	14325204	KHANDAHAT 2	4222DT364	100	MIXED	AMI	Yes	67%	122	0.07694034	0.042285	0.03465534	45.04%
7047	TPCODL	DHENKAN	ANED	BOINDA	DHAURAPALLI ODSS	14325	11 KV KISHORENAGAR	14325204	KISHORNAGAR	4222DT367	250	MIXED	AMI	Yes	0%	174	0.14371396	0.135397	0.00831696	5.79%
7048	TPCODL	DHENKAN	ANED	BOINDA	DHAURAPALLI ODSS	14325	11 KV KISHORENAGAR	14325204	DAHURAPALLI 1	4222DT377	250	MIXED	AMI	Yes	0%	240	0.11928832	0.08630085	0.03298747	27.65%
7049	TPCODL	DHENKAN	ANED	BOINDA	DHAURAPALLI ODSS	14325	11 KV KISHORENAGAR	14325204	GHASARA 1	4222DT395	250	MIXED	AMI	Yes	0%	270	0.12147188	0.098149	0.02332288	19.20%
7050	TPCODL	DHENKAN	ANED	BOINDA	DHAURAPALLI ODSS	14325	11 KV KISHORENAGAR	14325204	KADING BAHAL 2	4222DT404	100	MIXED	AMI	Yes	0%	72	0.03633802	0.021748	0.01459002	40.15%
7051	TPCODL	DHENKAN	ANED	BOINDA	MADHAPUR	14140	11 KV MADHAPUR	14140201	MADHAPUR HIGH SCHOOL	4223DT003	100	MIXED	AMI	Yes	67%	172	0.1572652	0.126984	0.0302812	19.25%
7052	TPCODL	DHENKAN	ANED	BOINDA	MADHAPUR	14140	11 KV MADHAPUR	14140201	TITIRKATA VILLAGE	4223DT046	100	MIXED	AMI	Yes	100%	56	0.01735112	0.009276	0.00807512	46.54%
7053	TPCODL	DHENKAN	ANED	BOINDA	MADHAPUR	14140	11 KV KIAKATA	14140202	KANDHAPADA VILLAGE-2	4223DT156	100	MIXED	AMI	Yes	67%	127	0.04180994	0.033533	0.00827694	19.80%
7054	TPCODL	DHENKAN	ANED	BOINDA	MADHAPUR	14140	11 KV KIAKATA	14140202	ORADA VILLAGE	4223DT337	100	MIXED	AMI	Yes	0%	103	0.0230093	0.013265	0.0097443	42.35%
7055	TPCODL	DHENKAN	ANED	BOINDA	MADHAPUR	14140	11 KV KIAKATA	14140202	BHANDARI MUNDA	4223DT341	100	MIXED	AMI	Yes	0%	82	0.01570806	0.012005	0.00370306	23.57%
7056	TPCODL	DHENKAN	ANED	BOINDA	NAKCHI ODSSP	14327	11 KV BUDULIMUNDA	14327201	THELAKNALI 2	4222DT126	100	MIXED	AMI	Yes	67%	30	0.02001985	0.01485	0.00516985	25.82%
7057	TPCODL	DHENKAN	ANED	BOINDA	NAKCHI ODSSP	14327	11 KV BUDULIMUNDA	14327201	BUDHULIMUNDA 1	4222DT164	100	MIXED	AMI	Yes	100%	97	0.0363213	0.026925	0.0093963	25.87%
7058	TPCODL	DHENKAN	ANED	BOINDA	NAKCHI ODSSP	14327	11 KV BUDULIMUNDA	14327201	JHARABENI	4222DT179	100	MIXED	AMI	Yes	100%	108	0.04927386	0.025024	0.02424986	49.21%
7059	TPCODL	DHENKAN	ANED	BOINDA	NAKCHI ODSSP	14327	11 KV NAKCHI	14327202	NAKCHI VILLAGE 1	4222DT200	100	MIXED	AMI	Yes	100%	146	0.08646964	0.053568	0.03290164	38.05%
7060	TPCODL	DHENKAN	ANED	BOINDA	RCMS	14132	11 kV KHALARI	14132208	KHALARI BISWAL SAHI	4214DT545	500	MIXED	AMI	Yes	100%	235	0.32104968	0.190009	0.13104068	40.82%
7061	TPCODL	DHENKAN	ANED	BOINDA	RCMS	14132	11 KV PANCHAMAHALA	14132211	SARADHAPUR VILLAGE	4214DT446	100	MIXED	AMI	Yes	100%	130	0.10331576	0.067065	0.03625076	35.09%
7062	TPCODL	DHENKAN	ANED	CHHENDIPADA	JARPADA	14135	11 kV KOSALA	14135203	DURGAPUR TANGIRISAHI SCHOOL	4232DT145	100	MIXED	AMI	Yes	0%	70	0.02172168	0.017102	0.00461968	21.27%
7063	TPCODL	DHENKAN	ANED	CHHENDIPADA	CHHENDIPADA	14136	11 kV DUBANALI	14136201	NAUPADA-II,OAIC,GOLEKH BISWAL	4232DT605	100	MIXED	AMI	Yes	0%	10	0.00192518	0.000911	0.00101418	52.68%
7064	TPCODL	DHENKAN	ANED	CHHENDIPADA	CHHENDIPADA	14136	11 KV DUBANALI	14136201	Handigoda	4231DT364	100	MIXED	AMI	Yes	67%	91	0.03833094	0.01863493	0.01969601	51.38%
7065	TPCODL	DHENKAN	ANED	CHHENDIPADA	CHHENDIPADA	14136	11 KV DUBANALI	14136201	Jamunali	4231DT369	100	MIXED	AMI	Yes	33%	152	0.04651082	0.030367	0.01614382	34.71%
7066	TPCODL	DHENKAN	ANED	CHHENDIPADA	CHHENDIPADA	14136	11 KV DUBANALI	14136201	KUKURPETA	4231DT408	100	MIXED	AMI	Yes	67%	279	0.06887376	0.06108052	0.00779324	11.32%
7067	TPCODL	DHENKAN	ANED	CHHENDIPADA	CHHENDIPADA	14136	11 KV DUBANALI	14136201	DUBANALI SCHOOL	4232DT039	100	MIXED	AMI	Yes	67%	127	0.02814284	0.01917	0.00897284	31.88%
7068	TPCODL	DHENKAN	ANED	CHHENDIPADA	CHHENDIPADA	14136	11 KV DUBANALI	14136201	BIJAMUNDA (KUSHKILA)	4232DT050	100	MIXED	AMI	Yes	33%	97	0.0335724	0.019506	0.0140664	41.90%
7069	TPCODL	DHENKAN	ANED	CHHENDIPADA	CHHENDIPADA	14136	11 KV DUBANALI	14136201	BALIPATA HATA	4232DT067	100	MIXED	AMI	Yes	67%	191	0.07987534	0.056801	0.02307434	28.89%
7070	TPCODL	DHENKAN	ANED	CHHENDIPADA	CHHENDIPADA	14136	11 KV DUBANALI	14136201	BALIPATA KUSUMA SAHI	4232DT068	100	MIXED	AMI	Yes	67%	84	0.04399028	0.022492	0.02149828	48.87%
7071	TPCODL	DHENKAN	ANED	CHHENDIPADA	CHHENDIPADA	14136	11 KV BRAHMANABIL	14136202	RR COLONY	4233DT358	250	MIXED	AMI	Yes	0%	1	0.01055736	0.010304	0.00025336	2.40%
7072	TPCODL	DHENKAN	ANED	CHHENDIPADA	CHHENDIPADA	14136	11 KV BRAHMANABIL	14136202	KARADABAHAL NEW OLIC 1	4233DT379	100	MIXED	AMI	Yes	67%	74	0.03377712	0.021578	0.01219912	36.12%
7073	TPCODL	DHENKAN	ANED	CHHENDIPADA	CHHENDIPADA	14136	11 KV BRAHMANABIL	14136202	BRAHMAN BILL CHHAWK	4233DT391	250	MIXED	AMI	Yes	67%	184	0.11713924	0.059844	0.05729524	48.91%
7074	TPCODL	DHENKAN	ANED	CHHENDIPADA	CHHENDIPADA	14136	11 KV BRAHMANABIL	14136202	CHHATASAHI BRAHMAN BILL	4233DT394	100	MIXED	AMI	Yes	67%	64	0.03351736	0.019275	0.01424236	42.49%
7075	TPCODL	DHENKAN	ANED	CHHENDIPADA	CHHENDIPADA	14136	11 KV BRAHMANABIL	14136202	SANTARABANDHA CHHAKA 2	4233DT414	100	MIXED	AMI	Yes	67%	147	0.04144244	0.027303	0.01413944	34.12%
7076	TPCODL	DHENKAN	ANED	CHHENDIPADA	CHHENDIPADA	14136	11 KV BRAHMANABIL	14136202	CHANGUDIA	4233DT421	100	MIXED	AMI	Yes	67%	66	0.0331239	0.014656	0.0184679	55.75%
7077	TPCODL	DHENKAN	ANED	CHHENDIPADA	CHHENDIPADA	14136	11 KV BRAHMANABIL	14136202	KAMPASALA BAZAR	4233DT456	100	MIXED	AMI	Yes	33%	46	0.02200974	0.014667	0.00734274	33.36%
7078	TPCODL	DHENKAN	ANED	CHHENDIPADA	CHHENDIPADA	14136	11 KV BRAHMANABIL	14136202	BEHERA SAHI BRAHMANIBILL 2	4233DT498	100	MIXED	AMI	Yes	67%	65	0.0438064	0.010706	0.0331004	75.56%
7079	TPCODL	DHENKAN	ANED	CHHENDIPADA	CHHENDIPADA	14136	11 KV BAHALSAHI	14136203	Bahalsahi	4231DT246	100	MIXED	AMI	Yes	67%	216	0.08203138	0.045156	0.03687538	44.95%
7080	TPCODL	DHENKAN	ANED	CHHENDIPADA	CHHENDIPADA	14136	11 KV BAHALSAHI	14136203	Nuapada	4231DT294	250	MIXED	AMI	Yes	33%	237	0.066593	0.047829	0.018764	28.18%

Sl. No.	Zone Name	Circle name	Division name	Name of the Sub-division	Name of the Sub-station	Substation Code	Name of the 11 kV Feeder	Feeder Code	Name of the Location where DT situated	DT code	DT Capacity (kVA)	Predominant consumer type of DT (Domestic/Industrial/Agriculture/Mixed)	Type of metering AMR/AMI/ Communicable/Conventional metered/Unmetered	Status of Meter-whether Functional (Yes/No)	% of data received automatically (if AMR/AMI)	No. of Connected Consumers	Input Energy (MU) (A)	Billed Energy (MU) (B)	Loss (MU) (A-B)	% DT Loss (A-B)/A
7081	TPCODL	DHENKAN	ANED	CHHENDIPADA	CHHENDIPADA	14136	11 KV BAHALSAHI	14136203	Ramchandrapur	4231DT304	100	MIXED	AMI	Yes	33%	136	0.06161404	0.024735	0.03687904	59.85%
7082	TPCODL	DHENKAN	ANED	CHHENDIPADA	CHHENDIPADA	14136	11 KV BAHALSAHI	14136203	Pattakumunda	4231DT327	100	MIXED	AMI	Yes	33%	174	0.0526982	0.030724	0.0219742	41.70%
7083	TPCODL	DHENKAN	ANED	CHHENDIPADA	CHHENDIPADA	14136	11 KV CHHENDIPADA	14136204	THANA CHHAKA	4231DT005	500	MIXED	AMI	Yes	0%	244	0.28537936	0.1902116	0.09516776	33.35%
7084	TPCODL	DHENKAN	ANED	CHHENDIPADA	CHHENDIPADA	14136	11 KV CHHENDIPADA	14136204	Mainsibandha-1	4231DT011	250	MIXED	AMI	Yes	0%	261	0.10012668	0.076028	0.02409868	24.07%
7085	TPCODL	DHENKAN	ANED	CHHENDIPADA	CHHENDIPADA	14136	11 KV CHHENDIPADA	14136204	CHHENDIPADA TAHASIL	4231DT022	250	MIXED	AMI	Yes	0%	154	0.10925136	0.095144	0.01410736	12.91%
7086	TPCODL	DHENKAN	ANED	CHHENDIPADA	CHHENDIPADA	14136	11 KV CHHENDIPADA	14136204	BANTABURI	4231DT024	100	MIXED	AMI	Yes	67%	154	0.10701994	0.082944	0.02407594	22.50%
7087	TPCODL	DHENKAN	ANED	CHHENDIPADA	CHHENDIPADA	14136	11 KV BAGEDIA	14136205	PODAPADA NAKI SAHI	4231DT058	100	MIXED	AMI	Yes	67%	82	0.03339198	0.023679	0.00971298	29.09%
7088	TPCODL	DHENKAN	ANED	CHHENDIPADA	CHHENDIPADA	14136	11 KV BAGEDIA	14136205	PODAPADA-1	4231DT059	100	MIXED	AMI	Yes	67%	244	0.09754944	0.072688	0.02486144	25.49%
7089	TPCODL	DHENKAN	ANED	CHHENDIPADA	CHHENDIPADA	14136	11 KV BAGEDIA	14136205	Purunagarh	4231DT083	100	MIXED	AMI	Yes	67%	144	0.05020086	0.027533	0.02266786	45.15%
7090	TPCODL	DHENKAN	ANED	CHHENDIPADA	CHHENDIPADA	14136	11 KV BAGEDIA	14136205	KHULIDHIPA(PURUNAGARH)	4231DT084	100	MIXED	AMI	Yes	67%	70	0.01865245	0.011735	0.00691745	37.09%
7091	TPCODL	DHENKAN	ANED	CHHENDIPADA	CHHENDIPADA	14136	11 KV BAGEDIA	14136205	Sarapal	4231DT102	100	MIXED	AMI	Yes	67%	124	0.04060392	0.024929	0.01567492	38.60%
7092	TPCODL	DHENKAN	ANED	CHHENDIPADA	CHHENDIPADA	14136	11 KV BAGEDIA	14136205	KHAJURIAMUNDA SAPOINALI	4231DT123	100	MIXED	AMI	Yes	67%	113	0.03445238	0.023032	0.01142038	33.15%
7093	TPCODL	DHENKAN	ANED	CHHENDIPADA	CHHENDIPADA	14136	11 KV BAGEDIA	14136205	Behera Sahi Sapoinali	4231DT129	100	MIXED	AMI	Yes	67%	108	0.03672348	0.0210681	0.01565538	42.63%
7094	TPCODL	DHENKAN	ANED	CHHENDIPADA	CHHENDIPADA	14136	11 KV BAGEDIA	14136205	Mausi Sahi Bagedia	4231DT141	100	MIXED	AMI	Yes	67%	189	0.07258232	0.053435	0.01914732	26.38%
7095	TPCODL	DHENKAN	ANED	CHHENDIPADA	CHHENDIPADA	14136	11 KV BAGEDIA	14136205	Bagedia Rajiv Bhavan	4231DT149	100	MIXED	AMI	Yes	67%	82	0.08345932	0.0306983	0.05276102	63.22%
7096	TPCODL	DHENKAN	ANED	CHHENDIPADA	CHHENDIPADA	14136	11 KV BAGEDIA	14136205	Khamar Gadavitarsahi	4231DT158	100	MIXED	AMI	Yes	67%	110	0.03552658	0.026549	0.00897758	25.27%
7097	TPCODL	DHENKAN	ANED	CHHENDIPADA	CHHENDIPADA	14136	11 KV BAGEDIA	14136205	KHAMAR-2	4231DT162	100	MIXED	AMI	Yes	33%	70	0.08397838	0.022008	0.06197038	73.79%
7098	TPCODL	DHENKAN	ANED	CHHENDIPADA	CHHENDIPADA	14136	11 KV BAGEDIA	14136205	Barasahi	4231DT171	100	MIXED	AMI	Yes	67%	178	0.06485252	0.04101449	0.02383803	36.76%
7099	TPCODL	DHENKAN	ANED	CHHENDIPADA	CHHENDIPADA	14136	11 KV PIPALA BAHALA	14136206	GHUNTULIPOSI	4231DT451	100	MIXED	AMI	Yes	67%	92	0.01752848	0.012922	0.00460648	26.28%
7100	TPCODL	DHENKAN	ANED	CHHENDIPADA	CHHENDIPADA	14136	11 KV PIPALA BAHALA	14136206	VEJIDIHA	4231DT503	100	MIXED	AMI	Yes	67%	117	0.050403	0.022712	0.027691	54.94%
7101	TPCODL	DHENKAN	ANED	CHHENDIPADA	CHHENDIPADA	14136	11 KV PIPALA BAHALA	14136206	BADA SAHI NUAGAON	4231DT560	100	MIXED	AMI	Yes	67%	78	0.02181774	0.010976	0.01084174	49.69%
7102	TPCODL	DHENKAN	ANED	CHHENDIPADA	CHHENDIPADA	14136	11 KV PIPALA BAHALA	14136206	Kanaloi	4231DT566	100	MIXED	AMI	Yes	67%	300	0.06490622	0.043629	0.02127722	32.78%
7103	TPCODL	DHENKAN	ANED	CHHENDIPADA	CHHENDIPADA	14136	11 KV PIPALA BAHALA	14136206	BHAGAMUNDA(AFTER MU)	4231DT575	16	MIXED	AMI	Yes	67%	8	0.00141152	0.000703	0.00070852	50.20%
7104	TPCODL	DHENKAN	ANED	CHHENDIPADA	CHHENDIPADA	14136	11 KV PIPALA BAHALA	14136206	NUATAILA(AFTER MU)	4231DT576	16	MIXED	AMI	Yes	100%	7	0.00091445	0.000605	0.00030945	33.84%
7105	TPCODL	DHENKAN	ANED	CHHENDIPADA	HEMSURPADA	14187	11 KV MCL	14187202	ALEKHAPATANA	4213DT004	250	MIXED	AMI	Yes	100%	121	0.20008992	0.092594	0.10749592	53.72%
7106	TPCODL	DHENKAN	ANED	CHHENDIPADA	HEMSURPADA	14187	11 KV MCL	14187202	SUBANPUR-1	4233DT043	100	MIXED	AMI	Yes	67%	120	0.06520246	0.038554	0.02664846	40.87%
7107	TPCODL	DHENKAN	ANED	CHHENDIPADA	HEMSURPADA	14187	11 KV MCL	14187202	KUIO-01	4233DT049	100	MIXED	AMI	Yes	100%	236	0.11768302	0.072576	0.04510702	38.33%
7108	TPCODL	DHENKAN	ANED	CHHENDIPADA	HEMSURPADA	14187	11 KV MCL	14187202	JAMUNALI, EKATALI SAHI	4233DT050	100	MIXED	AMI	Yes	100%	127	0.08003898	0.042909	0.03712998	46.39%
7109	TPCODL	DHENKAN	ANED	CHHENDIPADA	HEMSURPADA	14187	11 KV MCL	14187202	PRANA SAHU PLOTING	4233DT061	100	MIXED	AMI	Yes	100%	11	0.0113095	0.009278	0.0020315	17.96%
7110	TPCODL	DHENKAN	ANED	CHHENDIPADA	HEMSURPADA	14187	11 KV MCL	14187202	NATADA JATRAPADIA	4233DT079	100	MIXED	AMI	Yes	67%	159	0.1150385	0.088375	0.0266635	23.18%
7111	TPCODL	DHENKAN	ANED	CHHENDIPADA	HEMSURPADA	14187	11 KV MCL	14187202	NATADA VILLAGE	4233DT086	250	MIXED	AMI	Yes	67%	197	0.1172368	0.075014	0.0422228	36.01%
7112	TPCODL	DHENKAN	ANED	CHHENDIPADA	HEMSURPADA	14187	11 KV MCL	14187202	AMBAPAL-2	4233DT092	100	MIXED	AMI	Yes	67%	130	0.07268488	0.048687	0.02399788	33.02%
7113	TPCODL	DHENKAN	ANED	CHHENDIPADA	HEMSURPADA	14187	11 KV JARASINGHA	14187205	PARANGA BAZER SAHI	4233DT111	100	MIXED	AMI	Yes	100%	100	0.06114618	0.053814	0.00733218	11.99%
7114	TPCODL	DHENKAN	ANED	CHHENDIPADA	HEMSURPADA	14187	11 KV JARASINGHA	14187205	BASUDEV PUR RR COLONY	4233DT119	250	MIXED	AMI	Yes	0%	70	0.0751282	0.062849	0.0122792	16.34%
7115	TPCODL	DHENKAN	ANED	CHHENDIPADA	HEMSURPADA	14187	11 KV JARASINGHA	14187205	BASUDEV PUR RR COONY	4233DT133	250	MIXED	AMI	Yes	0%	238	0.14091272	0.095829	0.04508372	31.99%
7116	TPCODL	DHENKAN	ANED	CHHENDIPADA	HEMSURPADA	14187	11 KV JARASINGHA	14187205	NISHA RUGUDIA PADA SAHI	4233DT153	100	MIXED	AMI	Yes	67%	75	0.04476214	0.033407	0.01135514	25.37%
7117	TPCODL	DHENKAN	ANED	CHHENDIPADA	HEMSURPADA	14187	11 KV JARASINGHA	14187205	NISHA VILLAGE -1	4233DT156	63	MIXED	AMI	Yes	67%	129	0.07664484	0.048963	0.02768184	36.12%
7118	TPCODL	DHENKAN	ANED	CHHENDIPADA	HEMSURPADA	14187	11 KV JARASINGHA	14187205	KANKREI PRIMARY SCHOOL	4233DT174	100	MIXED	AMI	Yes	67%	53	0.03847802	0.014411	0.02406702	62.55%
7119	TPCODL	DHENKAN	ANED	CHHENDIPADA	HEMSURPADA	14187	11 KV JARASINGHA	14187205	BHUBANPUR VILLAGE-2	4233DT183	100	MIXED	AMI	Yes	67%	66	0.09657098	0.0504	0.04617098	47.81%
7120	TPCODL	DHENKAN	ANED	CHHENDIPADA	HEMSURPADA	14187	11 KV JARASINGHA	14187205	KALIAKATA VILLAGE -2	4233DT193	100	MIXED	AMI	Yes	33%	121	0.0243403	0.018349	0.0059913	24.61%
7121	TPCODL	DHENKAN	ANED	CHHENDIPADA	HEMSURPADA	14187	11 KV JARASINGHA	14187205	MALIBRHMANI RR COLONY	4233DT195	250	MIXED	AMI	Yes	0%	141	0.12094292	0.082269	0.03867392	31.98%
7122	TPCODL	DHENKAN	ANED	CHHENDIPADA	JARPADA	14135	11 KV KATADA	14135201	JARPADA LOCAL	4232DT361	250	MIXED	AMI	Yes	100%	201	0.14205588	0.107262	0.03479388	24.49%
7123	TPCODL	DHENKAN	ANED	CHHENDIPADA	JARPADA	14135	11 KV KATADA	14135201	KUMURSINGH	4232DT362	100	MIXED	AMI	Yes	67%	101	0.06166018	0.032152	0.02950818	47.86%
7124	TPCODL	DHENKAN	ANED	CHHENDIPADA	JARPADA	14135	11 KV KATADA	14135201	JERENGA MAIN VILLAGE	4232DT378	100	MIXED	AMI	Yes	67%	117	0.06382786	0.0370794	0.02674846	41.91%
7125	TPCODL	DHENKAN	ANED	CHHENDIPADA	JARPADA	14135	11 KV KATADA	14135201	LAXMIDHARPUR MAIN VILLAGE	4232DT381	100	MIXED	AMI	Yes	67%	204	0.05204274	0.046542	0.00550074	10.57%
7126	TPCODL	DHENKAN	ANED	CHHENDIPADA	JARPADA	14135	11 KV JAGANATHPUR(JA	14135202	PARA MANDIR SAHI	4232DT156	100	MIXED	AMI	Yes	0%	38	0.01492234	0.004649	0.01027334	68.85%
7127	TPCODL	DHENKAN	ANED	CHHENDIPADA	JARPADA	14135	11 KV JAGANATHPUR(JA	14135202	GANJADA	4232DT207	100	MIXED	AMI	Yes	0%	73	0.020359	0.010767	0.009592	47.11%
7128	TPCODL	DHENKAN	ANED	CHHENDIPADA	JARPADA	14135	11 KV KANJAR	14135204	TUKUDA UPER SAHI	4232DT010	100	MIXED	AMI	Yes	67%	146	0.08235828	0.045382	0.03697628	44.90%
7129	TPCODL	DHENKAN	ANED	CHHENDIPADA	JARPADA	14135	11 KV KANJAR	14135204	PARA KADAKHOLA	4232DT462	100	MIXED	AMI	Yes	67%	143	0.0185812	0.01775583	0.00082537	4.44%
7130	TPCODL	DHENKAN	ANED	CHHENDIPADA	JARPADA	14135	11 KV KANJAR	14135204	PARA VILLAGE	4232DT464	100	MIXED	AMI	Yes	100%	338	0.10078358	0.06185	0.03893358	38.63%
7131	TPCODL	DHENKAN	ANED	CHHENDIPADA	JARPADA	14135	11 KV KANJAR	14135204	PARA KADAMBA CHAOKA	4232DT472	100	MIXED	AMI	Yes	33%	104	0.02574758	0.016471	0.00927658	36.03%
7132	TPCODL	DHENKAN	ANED	CHHENDIPADA	JARPADA	14135	11 KV KANJAR	14135204	JAMUNDA JUNGLE-3	4232DT483	100	MIXED	AMI	Yes	67%	97	0.0430238	0.027615	0.0154088	35.81%
7133	TPCODL	DHENKAN	ANED	CHHENDIPADA	JARPADA	14135	11 KV KANJAR	14135204	JAMUNDA VILLAGE	4232DT501	100	MIXED	AMI	Yes	67%	176	0.05913166	0.043346	0.01578566	26.70%
7134	TPCODL	DHENKAN	ANED	CHHENDIPADA	JARPADA	14135	11 KV RAILWAY	14135205	JADAPADA 2	4232DT102	100	MIXED	AMI	Yes	100%	82	0.06084134	0.032666	0.02817534	46.31%
7135	TPCODL	DHENKAN	ANED	CHHENDIPADA	JARPADA	14135	11 KV RAILWAY	14135205	NEAR JARAPADA STATION	4232DT105	100	MIXED	AMI	Yes	100%	206	0.08301646	0.059883	0.02313346	27.87%
7136	TPCODL	DHENKAN	ANED	CHHENDIPADA	KOSALA ODSSP	14326	11 KV KOSALA	14326201	CHANDAN NAGAR 1	4233DT201	250	MIXED	AMI	Yes	67%	113	0.17412244	0.059291	0.11483144	65.95%
7137	TPCODL	DHENKAN	ANED	CHHENDIPADA	KOSALA ODSSP	14326	11 KV KOSALA	14326201	KAITHADHIPA	4233DT215	100	MIXED	AMI	Yes	67%	62	0.04573746	0.018239	0.02749846	60.12%
7138	TPCODL	DHENKAN	ANED	CHHENDIPADA	KOSALA ODSSP	14326	11 KV KOSALA	14326201	KANSANALI	4233DT219	100	MIXED	AMI	Yes	67%	135	0.0713165	0.039305	0.0320115	44.89%
7139	TPCODL	DHENKAN	ANED	CHHENDIPADA	KOSALA ODSSP	14326	11 KV KOSALA	14326201	NANDICHHOD VILLAGE	4233DT230	100	MIXED	AMI	Yes	67%	91	0.02423186	0.013193	0.01103886	45.56%
7140	TPCODL	DHENKAN	ANED	CHHENDIPADA	KOSALA ODSSP	14326	11 KV KOSALA	14326201	BARAPADA TALA SAHI	4233DT237	100	MIXED	AMI	Yes	67%	82	0.0307201	0.011827	0.0188931	61.50%
7141	TPCODL	DHENKAN	ANED	CHHENDIPADA	KOSALA ODSSP	14326	11 KV KOSALA	14326201	KORADA VILLAGE	4233DT263	100	MIXED	AMI	Yes	0%	134	0.06288118	0.026278	0.03660318	58.21%
7142	TPCODL	DHENKAN	ANED	CHHENDIPADA	KOSALA ODSSP	14326	11 KV KOSALA	14326201	BHAGILAKATA 2	4233DT275	100	MIXED	AMI	Yes	67%	70	0.0326613	0.023799	0.0088623	27.13%
7143	TPCODL	DHENKAN	ANED	CHHENDIPADA	KOSALA ODSSP	14326	11 KV CHANDAN NAGAR	14326204	KOSALA BAZAR 1	4233DT279	100	MIXED	AMI	Yes	67%	87	0.12904744	0.057198	0.07184944	55.68%
7144	TPCODL	DHENKAN	ANED	CHHENDIPADA	KOSALA ODSSP	14326	11 KV CHANDAN NAGAR	14326204	BAHAILI	4233DT281	100	MIXED	AMI	Yes	67%	56	0.04442808	0.026093	0.01833508	41.27%
7145	TPCODL	DHENKAN	ANED	CHHENDIPADA	KOSALA ODSSP	14326	11 KV CHANDAN NAGAR	14326204	HATAPADA	4233DT291	250	MIXED	AMI	Yes	67%	175	0.16354696	0.077378	0.08616896	52.69%
7146	TPCODL	DHENKAN	ANED	CHHENDIPADA	KOSALA ODSSP	14326	11 KV CHANDAN NAGAR	14326204	PIDHA SAHI	4233DT296	100	MIXED	AMI	Yes	67%	134	0.07185726	0.047278	0.02457926	34.21%
7147	TPCODL	DHENKAN	ANED	CHHENDIPADA	KOSALA ODSSP	14326	11 KV CHANDAN NAGAR	14326204	SIMILISAHI	4233DT297	250	MIXED	AMI	Yes	67%	143	0.09319332	0.057114	0.03607932	38.71%
7148	TPCODL	DHENKAN	ANED	CHHENDIPADA	KOSALA ODSSP	14326	11 KV CHANDAN NAGAR	14326204	RAIJHARAN-2	4233DT320	100	MIXED	AMI	Yes	0%	150	0.09065474	0.032834	0.05782074	63.78%
7149	TPCODL	DHENKAN	ANED	CHHENDIPADA	SANDA ODSSP	14329	11 kV KANKILI	14329204	KANKILI NIMADANDI	4331DT341	100	MIXED	AMI	Yes	33%	52	0.01342848	0.011541	0.00188748	14.06%
7150	TPCODL	DHENKAN	DED	DHENKANAL	GUNDICHAPADA	14131	11 kV Bhapur (G,Pada)	14131205	MANGALPUR RAGADISAHI	4111DT030	100	MIXED	AMI	Yes	67%	74	0.0705467	0.016346	0.0542007	76.83%
7151	TPCODL	DHENKAN	DED	DHENKANAL	DHENKANAL COLLE	14118	11 kV DKL TOWN-2	14118202	BUDHI THAKURANI	4112DT061	500	MIXED	AMI	Yes	100%	222	0.21480976	0.145553	0.06925676	32.24%
7152	TPCODL	DHENKAN	DED	DHENKANAL	GUNDICHAPADA	14131	11 kV CALTAX	14131203	GOPAL SAGAR JAYRAM SAHI	4113DT070	250	MIXED	AMI	Yes	0%	93	0.15216444	0.059934	0.09223044	60.61%
7153	TPCODL	DHENKAN	DED	DHENKANAL	DHENKANAL COLLE	14118	11 kV GOVINDPUR(DKL)	14118203	DALAK	4113DT288	100	MIXED	AMI	Yes	67%	104	0.05491376	0.028776	0.02613776	47.60%

Sl. No.	Zone Name	Circle name	Division name	Name of the Sub-division	Name of the Sub-station	Substation Code	Name of the 11 kV Feeder	Feeder Code	Name of the Location where DT situated	DT code	DT Capacity (kVA)	Predominant consumer type of DT (Domestic/Industrial/Agriculture/Mixed)	Type of metering AMR/AMI/ Communicable/Conventional metered/Unmetered	Status of Meter-whether Functional (Yes/No)	% of data received automatically (if AMR/AMI)	No. of Connected Consumers	Input Energy (MU) (A)	Billed Energy (MU) (B)	Loss (MU) (A-B)	% DT Loss (A-B)/A
7154	TPCODL	DHENKAN	DED	DHENKANAL	MUKTAPASI ODSSP	14316	11 kV Chaulia/Khamara	14316201	MANDAPAL HARIJAN SAHI	4113DT535	63	MIXED	AMI	Yes	0%	60	0.0083313	0.006899	0.0014323	17.19%
7155	TPCODL	DHENKAN	DED	DHENKANAL	MUKTAPASI ODSSP	14316	11 kV Chaulia/Khamara	14316201	SOGARAPASI	4113DT574	63	MIXED	AMI	Yes	0%	62	0.0176287	0.016082	0.0015467	8.77%
7156	TPCODL	DHENKAN	DED	DHENKANAL	MUKTAPASI ODSSP	14316	11 kV Similia	14316203	SANA SATHIA BATIA	4113DT604	100	MIXED	AMI	Yes	100%	48	0.06569164	0.030466	0.03522564	53.62%
7157	TPCODL	DHENKAN	DED	DHENKANAL	BHAPUR	14119	11 KV BHAPUR	14119201	KOILIPUNGI 1	4111DT331	100	MIXED	AMI	Yes	67%	135	0.0867516	0.052582	0.0341696	39.39%
7158	TPCODL	DHENKAN	DED	DHENKANAL	BHAPUR	14119	11 KV BHAPUR	14119201	RAGADA SAHI	4111DT339	100	MIXED	AMI	Yes	67%	61	0.03394144	0.023619	0.01032244	30.41%
7159	TPCODL	DHENKAN	DED	DHENKANAL	BHAPUR	14119	11 KV BHAPUR	14119201	RAJUA PATNA-1	4111DT340	100	MIXED	AMI	Yes	33%	102	0.0509904	0.030213	0.0207774	40.75%
7160	TPCODL	DHENKAN	DED	DHENKANAL	BHAPUR	14119	11 KV BHAPUR	14119201	BANIA SAHI	4111DT354	100	MIXED	AMI	Yes	67%	97	0.03566292	0.01694	0.01872292	52.50%
7161	TPCODL	DHENKAN	DED	DHENKANAL	BHAPUR	14119	11 KV BHAPUR	14119201	BHAPUR MAIN VILLAGE	4111DT356	500	MIXED	AMI	Yes	0%	543	0.19229	0.152081	0.040209	20.91%
7162	TPCODL	DHENKAN	DED	DHENKANAL	BHAPUR	14119	11 KV BHAPUR	14119201	DHALAPUR	4111DT376	100	MIXED	AMI	Yes	0%	84	0.03364252	0.017645	0.01599752	47.55%
7163	TPCODL	DHENKAN	DED	DHENKANAL	BHAPUR	14119	11 KV BHAPUR	14119201	GANJEIDIHI-1	4111DT385	100	MIXED	AMI	Yes	67%	110	0.0698185	0.031488	0.0383305	54.90%
7164	TPCODL	DHENKAN	DED	DHENKANAL	BHAPUR	14119	11 KV BHAPUR	14119201	JHUMPUDIA-1	4111DT389	100	MIXED	AMI	Yes	0%	34	0.03783434	0.010851	0.02698334	71.32%
7165	TPCODL	DHENKAN	DED	DHENKANAL	BHAPUR	14119	11 KV BHAPUR	14119201	SARAKA PATNA	4111DT511	250	MIXED	AMI	Yes	67%	139	0.096308	0.059795	0.036513	37.91%
7166	TPCODL	DHENKAN	DED	DHENKANAL	BHAPUR	14119	11 KV BHAPUR	14119201	KASHIPUR VILLAGE	4111DT513	100	MIXED	AMI	Yes	67%	33	0.01549404	0.011764	0.00373004	24.07%
7167	TPCODL	DHENKAN	DED	DHENKANAL	BHAPUR	14119	11 KV BHAPUR	14119201	BALYAMBA 2	4111DT530	100	MIXED	AMI	Yes	67%	157	0.0719748	0.03916435	0.03281045	45.59%
7168	TPCODL	DHENKAN	DED	DHENKANAL	BHAPUR	14119	11 KV BHAPUR	14119201	CHASAPADA 2	4111DT549	100	MIXED	AMI	Yes	33%	80	0.03851106	0.023686	0.01482506	38.50%
7169	TPCODL	DHENKAN	DED	DHENKANAL	BHAPUR	14119	11 KV BHAPUR	14119201	NUAGAON	4111DT554	100	MIXED	AMI	Yes	0%	85	0.0367166	0.020136	0.0165806	45.16%
7170	TPCODL	DHENKAN	DED	DHENKANAL	BHAPUR	14119	11 KV BHAPUR	14119201	TENTULIPATNA 1	4111DT572	250	MIXED	AMI	Yes	67%	114	0.07501204	0.031737	0.04327504	57.69%
7171	TPCODL	DHENKAN	DED	DHENKANAL	BHAPUR	14119	11 KV BHAPUR	14119201	TENTULIPATNA 2	4111DT578	100	MIXED	AMI	Yes	0%	87	0.0371751	0.025122	0.0120531	32.42%
7172	TPCODL	DHENKAN	DED	DHENKANAL	BHAPUR	14119	11 KV GHATIPIRI	14119202	KAKUDIBHAG -1	4111DT250	100	MIXED	AMI	Yes	0%	96	0.05381254	0.029416	0.02439654	45.34%
7173	TPCODL	DHENKAN	DED	DHENKANAL	BHAPUR	14119	11 KV GHATIPIRI	14119202	BHAPUR NEAR POST OFFICE	4111DT253	250	MIXED	AMI	Yes	67%	181	0.13155316	0.088916	0.04263716	32.41%
7174	TPCODL	DHENKAN	DED	DHENKANAL	BHAPUR	14119	11 KV GHATIPIRI	14119202	HARIDAPASI-1	4111DT260	100	MIXED	AMI	Yes	33%	109	0.04561568	0.032262	0.01335368	29.27%
7175	TPCODL	DHENKAN	DED	DHENKANAL	BHAPUR	14119	11 KV GHATIPIRI	14119202	GUHALADIHI	4111DT266	100	MIXED	AMI	Yes	67%	108	0.03222228	0.022511	0.00971128	30.14%
7176	TPCODL	DHENKAN	DED	DHENKANAL	BHAPUR	14119	11 KV GHATIPIRI	14119202	BHAPUR NUA SAHI	4111DT273	100	MIXED	AMI	Yes	67%	95	0.04765356	0.037333	0.01032056	21.66%
7177	TPCODL	DHENKAN	DED	DHENKANAL	BHUBAN	14129	11 KV BHUSAL	14129203	BHUSAL SHIVA TEMPLE	4141DT410	100	MIXED	AMI	Yes	100%	51	0.07102932	0.016773	0.05425632	76.39%
7178	TPCODL	DHENKAN	DED	DHENKANAL	DAKHINAKALI	14189	11 KV DEULASAHI	14189201	POLICE COLONY	4112DT004	100	MIXED	AMI	Yes	100%	125	0.1053543	0.071829	0.0335253	31.82%
7179	TPCODL	DHENKAN	DED	DHENKANAL	DAKHINAKALI	14189	11 KV DEULASAHI	14189201	KHAMAR SAHI 1	4112DT008	250	MIXED	AMI	Yes	0%	94	0.16562912	0.078139	0.08749012	52.82%
7180	TPCODL	DHENKAN	DED	DHENKANAL	DAKHINAKALI	14189	11 KV DEULASAHI	14189201	DANDA SAHI	4112DT012	100	MIXED	AMI	Yes	100%	76	0.06455312	0.021737	0.04281612	66.33%
7181	TPCODL	DHENKAN	DED	DHENKANAL	DAKHINAKALI	14189	11 KV DEULASAHI	14189201	KANAK DURGA BACK SIDE	4112DT019	100	MIXED	AMI	Yes	33%	30	0.03482998	0.020784	0.01404598	40.33%
7182	TPCODL	DHENKAN	DED	DHENKANAL	DAKHINAKALI	14189	11 KV DEULASAHI	14189201	KANAKA DURGA 1	4112DT020	500	MIXED	AMI	Yes	0%	114	0.27104672	0.088862	0.18218472	67.22%
7183	TPCODL	DHENKAN	DED	DHENKANAL	DAKHINAKALI	14189	11 KV DEULASAHI	14189201	LUCKY ATA KALA SIDE	4112DT023	250	MIXED	AMI	Yes	100%	202	0.23495052	0.123402	0.11154852	47.48%
7184	TPCODL	DHENKAN	DED	DHENKANAL	DAKHINAKALI	14189	11 KV DEULASAHI	14189201	DEULA SAHI UP SCHOOL	4112DT024	100	MIXED	AMI	Yes	100%	20	0.04524826	0.020128	0.02512026	55.52%
7185	TPCODL	DHENKAN	DED	DHENKANAL	DAKHINAKALI	14189	11 KV DEULASAHI	14189201	KALU BHANJA 1	4112DT026	500	MIXED	AMI	Yes	100%	123	0.11987832	0.076229	0.04364932	36.41%
7186	TPCODL	DHENKAN	DED	DHENKANAL	DAKHINAKALI	14189	11 KV DEULASAHI	14189201	KALU BHANJA 2	4112DT027	500	MIXED	AMI	Yes	0%	124	0.2031412	0.104953	0.0981882	48.33%
7187	TPCODL	DHENKAN	DED	DHENKANAL	DAKHINAKALI	14189	11 KV DEULASAHI	14189201	DURGA BAZAR-2	4112DT047	250	MIXED	AMI	Yes	67%	161	0.22975984	0.110422	0.11933784	51.94%
7188	TPCODL	DHENKAN	DED	DHENKANAL	DAKHINAKALI	14189	11 KV DEULASAHI	14189201	DURGA BAZAR-1	4112DT048	500	MIXED	AMI	Yes	100%	88	0.18276128	0.107367	0.07539428	41.25%
7189	TPCODL	DHENKAN	DED	DHENKANAL	DAKHINAKALI	14189	11 KV DEULASAHI	14189201	COURT CHHAK	4112DT051	500	MIXED	AMI	Yes	0%	129	0.29971104	0.106374	0.19333704	64.51%
7190	TPCODL	DHENKAN	DED	DHENKANAL	DAKHINAKALI	14189	11 KV DEULASAHI	14189201	EXCISE OFFICE	4112DT066	500	MIXED	AMI	Yes	0%	47	0.232972	0.068146	0.164826	70.75%
7191	TPCODL	DHENKAN	DED	DHENKANAL	DAKHINAKALI	14189	11 KV SASAN	14189202	CAPACITOR	4112DT081	500	MIXED	AMI	Yes	0%	207	0.23849208	0.151192	0.08730008	36.61%
7192	TPCODL	DHENKAN	DED	DHENKANAL	DAKHINAKALI	14189	11 KV SASAN	14189202	GOPINATH GARDEN	4112DT084	100	MIXED	AMI	Yes	100%	29	0.0396037	0.021519	0.0180847	45.66%
7193	TPCODL	DHENKAN	DED	DHENKANAL	DAKHINAKALI	14189	11 KV SASAN	14189202	TOWN HALL-1	4112DT100	500	MIXED	AMI	Yes	0%	66	0.099496	0.054684	0.044812	45.04%
7194	TPCODL	DHENKAN	DED	DHENKANAL	DAKHINAKALI	14189	11 KV SASAN	14189202	OLD SASAN	4112DT119	500	MIXED	AMI	Yes	0%	273	0.3687424	0.209558	0.1591844	43.17%
7195	TPCODL	DHENKAN	DED	DHENKANAL	DAKHINAKALI	14189	11 KV SASAN	14189202	GAYATREE NAGAR_1	4112DT126	500	MIXED	AMI	Yes	0%	233	0.29786824	0.206469	0.09139924	30.68%
7196	TPCODL	DHENKAN	DED	DHENKANAL	DAKHINAKALI	14189	11 KV SASAN	14189202	GAYATREE NAGAR_3	4112DT128	250	MIXED	AMI	Yes	0%	41	0.1597046	0.03284	0.1268646	79.44%
7197	TPCODL	DHENKAN	DED	DHENKANAL	DAKHINAKALI	14189	11 KV SASAN	14189202	GAYATREE NAGAR-2	4112DT129	250	MIXED	AMI	Yes	100%	56	0.08396032	0.044614	0.03934632	46.86%
7198	TPCODL	DHENKAN	DED	DHENKANAL	DAKHINAKALI	14189	11 KV KORIA(SPARE)	14189204	NEAR OMM INDUSTRIES	4113DT074	100	MIXED	AMI	Yes	100%	8	0.02684738	0.00873	0.01811738	67.48%
7199	TPCODL	DHENKAN	DED	DHENKANAL	DAKHINAKALI	14189	11 KV KORIA(SPARE)	14189204	NEAR SAI NIMEI APARTMENT _2	4113DT087	100	MIXED	AMI	Yes	100%	34	0.05911296	0.03346	0.02565296	43.40%
7200	TPCODL	DHENKAN	DED	DHENKANAL	DAKHINAKALI	14189	11 KV KORIA(SPARE)	14189204	SAI NIMEI APARTMENT _1	4113DT089	500	MIXED	AMI	Yes	100%	41	0.05469736	0.038989	0.01570836	28.72%
7201	TPCODL	DHENKAN	DED	DHENKANAL	DAKHINAKALI	14189	11 KV KORIA(SPARE)	14189204	KUTUNIA SAHI	4113DT108	100	MIXED	AMI	Yes	100%	74	0.04753412	0.026622	0.02091212	43.99%
7202	TPCODL	DHENKAN	DED	DHENKANAL	DHENKANAL COLLE	14118	11 KV DKL TOWN-1	14118201	NEAR COLLEGE BY PASS	4112DT133	250	MIXED	AMI	Yes	100%	30	0.07425704	0.02	0.05425704	73.07%
7203	TPCODL	DHENKAN	DED	DHENKANAL	DHENKANAL COLLE	14118	11 KV DKL TOWN-1	14118201	DHENKANAL COLLEGE_1	4112DT135	500	MIXED	AMI	Yes	67%	45	0.12311752	0.076709	0.04640852	37.69%
7204	TPCODL	DHENKAN	DED	DHENKANAL	DHENKANAL COLLE	14118	11 KV DKL TOWN-1	14118201	DHENKANAL COLLEGE_2	4112DT136	500	MIXED	AMI	Yes	0%	88	0.1724712	0.072864	0.0996072	57.75%
7205	TPCODL	DHENKAN	DED	DHENKANAL	DHENKANAL COLLE	14118	11 KV DKL TOWN-1	14118201	ANIMA COMPLEX	4112DT144	250	MIXED	AMI	Yes	100%	35	0.05655952	0.027132	0.02942752	52.03%
7206	TPCODL	DHENKAN	DED	DHENKANAL	DHENKANAL COLLE	14118	11 KV DKL TOWN-1	14118201	KUNJAKANTA POKHARI_1	4112DT148	500	MIXED	AMI	Yes	100%	149	0.18731672	0.10723	0.08008672	42.75%
7207	TPCODL	DHENKAN	DED	DHENKANAL	DHENKANAL COLLE	14118	11 KV DKL TOWN-1	14118201	KUNJAKANTA POKHARI_2	4112DT149	200	MIXED	AMI	Yes	0%	193	0.29886568	0.161837	0.13702868	45.85%
7208	TPCODL	DHENKAN	DED	DHENKANAL	DHENKANAL COLLE	14118	11 KV DKL TOWN-1	14118201	BLOCK OFFICE	4112DT156	500	MIXED	AMI	Yes	0%	390	0.39456608	0.357616	0.03695008	9.36%
7209	TPCODL	DHENKAN	DED	DHENKANAL	DHENKANAL COLLE	14118	11 KV DKL TOWN-1	14118201	MANGALA MANDIR	4112DT160	500	MIXED	AMI	Yes	100%	269	0.28059024	0.17663	0.10396024	37.05%
7210	TPCODL	DHENKAN	DED	DHENKANAL	DHENKANAL COLLE	14118	11 KV DKL TOWN-1	14118201	CHANDIA SAHI	4112DT162	250	MIXED	AMI	Yes	100%	218	0.16912652	0.152303	0.01682352	9.95%
7211	TPCODL	DHENKAN	DED	DHENKANAL	DHENKANAL COLLE	14118	11 KV DKL TOWN-1	14118201	GUDIANALI	4112DT167	500	MIXED	AMI	Yes	100%	241	0.30895536	0.166904	0.14205136	45.98%
7212	TPCODL	DHENKAN	DED	DHENKANAL	DHENKANAL COLLE	14118	11 KV DKL TOWN-1	14118201	B B HIGH SCHOOL OLD	4112DT172	500	MIXED	AMI	Yes	0%	190	0.34444576	0.126674	0.21777176	63.22%
7213	TPCODL	DHENKAN	DED	DHENKANAL	DHENKANAL COLLE	14118	11 KV DKL TOWN-1	14118201	B B JENA-1	4112DT183	500	MIXED	AMI	Yes	100%	71	0.09182784	0.050816	0.04101184	44.66%
7214	TPCODL	DHENKAN	DED	DHENKANAL	DHENKANAL COLLE	14118	11 KV DKL TOWN-1	14118201	B B JENA-2	4112DT184	250	MIXED	AMI	Yes	100%	129	0.1341674	0.100284	0.0338834	25.25%
7215	TPCODL	DHENKAN	DED	DHENKANAL	DHENKANAL COLLE	14118	11 KV DKL TOWN-1	14118201	TAHASIL-1	4112DT187	500	MIXED	AMI	Yes	67%	163	0.2171583	0.198609	0.0185493	8.54%
7216	TPCODL	DHENKAN	DED	DHENKANAL	DHENKANAL COLLE	14118	11 KV DKL TOWN-1	14118201	TALABANIA NEW	4112DT208	500	MIXED	AMI	Yes	100%	140	0.1417476	0.112152	0.0295956	20.88%
7217	TPCODL	DHENKAN	DED	DHENKANAL	DHENKANAL COLLE	14118	11 KV DKL TOWN-1	14118201	JABAHAR CHHAK-1	4112DT212	500	MIXED	AMI	Yes	0%	309	0.50521216	0.295964	0.20924816	41.42%
7218	TPCODL	DHENKAN	DED	DHENKANAL	DHENKANAL COLLE	14118	11 KV DKL TOWN-1	14118201	HIRA SAGAR (KUMBHAR SAHI)	4113DT291	250	MIXED	AMI	Yes	0%	67	0.209239	0.057874	0.151365	72.34%
7219	TPCODL	DHENKAN	DED	DHENKANAL	DHENKANAL COLLE	14118	11 KV DKL TOWN-1	14118201	HOUSING BOARD	4113DT292	250	MIXED	AMI	Yes	100%	74	0.11670692	0.046656	0.07005092	60.02%
7220	TPCODL	DHENKAN	DED	DHENKANAL	DHENKANAL COLLE	14118	11 KV DKL TOWN-1	14118201	HOUSING BOARD OLD	4113DT294	250	MIXED	AMI	Yes	100%	158	0.1327606	0.109937	0.0228236	17.19%
7221	TPCODL	DHENKAN	DED	DHENKANAL	DHENKANAL COLLE	14118	11 KV DKL TOWN-1	14118201	SWASAT NAGAR HOUSING BOARD	4113DT295	100	MIXED	AMI	Yes	0%	47	0.06002838	0.040227	0.01980138	32.99%
7222	TPCODL	DHENKAN	DED	DHENKANAL	DHENKANAL COLLE	14118	11 KV DKL TOWN-1	14118201	HOUSING BOARD NEW	4113DT296	250	MIXED	AMI	Yes	100%	172	0.16881522	0.106923	0.06189222	36.66%
7223	TPCODL	DHENKAN	DED	DHENKANAL	DHENKANAL COLLE	14118	11 KV DKL TOWN-2	14118202	BALARAM BIHAR	4112DT059	500	MIXED	AMI	Yes	100%	172	0.15904568	0.133199	0.02584668	16.25%
7224	TPCODL	DHENKAN	DED	DHENKANAL	DHENKANAL COLLE	14118	11 KV DKL TOWN-2	14118202	ALANA MOHARANA	4112DT065	250	MIXED	AMI	Yes	0%	176	0.22047528	0.128315	0.09216028	41.80%
7225	TPCODL	DHENKAN	DED	DHENKANAL	DHENKANAL COLLE	14118	11 KV DKL TOWN-2	14118202	RENGALI NEW SAHI	4113DT134	100	MIXED	AMI	Yes	100%	66	0.03757762	0.027033	0.01054462	28.06%
7226	TPCODL	DHENKAN	DED	DHENKANAL	DHENKANAL COLLE	14118	11 KV DKL TOWN-2	14118202	BANAMALI PRASAD	4113DT171	500	MIXED	AMI	Yes	67%	413	0.43094864	0.301535	0.12941364	30.03%

Sl. No.	Zone Name	Circle name	Division name	Name of the Sub-division	Name of the Sub-station	Substation Code	Name of the 11 kV Feeder	Feeder Code	Name of the Location where DT situated	DT code	DT Capacity (kVA)	Predominant consumer type of DT (Domestic/Industrial/Agriculture/Mixed)	Type of metering AMR/AMI/ Communicable/Conventional metered/Unmetered	Status of Meter-whether Functional (Yes/No)	% of data received automatically (if AMR/AMI)	No. of Connected Consumers	Input Energy (MU) (A)	Billed Energy (MU) (B)	Loss (MU) (A-B)	% DT Loss (A-B)/A
7227	TPCODL	DHENKAN	DED	DHENKANAL	DHENKANAL COLLE	14118	11 KV DKL TOWN-2	14118202	PHATA BANDHA	4113DT323	100	MIXED	AMI	Yes	100%	90	0.10576318	0.066802	0.03896118	36.84%
7228	TPCODL	DHENKAN	DED	DHENKANAL	DHENKANAL COLLE	14118	11 KV DKL TOWN-2	14118202	JUANGA SAHI	4113DT324	100	MIXED	AMI	Yes	0%	23	0.02523458	0.010315	0.01491958	59.12%
7229	TPCODL	DHENKAN	DED	DHENKANAL	DHENKANAL COLLE	14118	11 KV GOVINDPUR(DKL)	14118203	SHIBA MANDIRA	4113DT172	500	MIXED	AMI	Yes	0%	99	0.08264568	0.043626	0.03901968	47.21%
7230	TPCODL	DHENKAN	DED	DHENKANAL	DHENKANAL COLLE	14118	11 KV GOVINDPUR(DKL)	14118203	NH 55 ROAD SIDE	4113DT176	100	MIXED	AMI	Yes	100%	71	0.0745832	0.05628	0.0183032	24.54%
7231	TPCODL	DHENKAN	DED	DHENKANAL	DHENKANAL COLLE	14118	11 KV GOVINDPUR(DKL)	14118203	ANAND NAGAR_2	4113DT182	100	MIXED	AMI	Yes	0%	77	0.05154156	0.045833	0.00570856	11.08%
7232	TPCODL	DHENKAN	DED	DHENKANAL	DHENKANAL COLLE	14118	11 KV GOVINDPUR(DKL)	14118203	JUANGA SAHI_1	4113DT186	100	MIXED	AMI	Yes	0%	103	0.09230002	0.053033	0.03926702	42.54%
7233	TPCODL	DHENKAN	DED	DHENKANAL	DHENKANAL COLLE	14118	11 KV GOVINDPUR(DKL)	14118203	FRENCH COLONY	4113DT209	200	MIXED	AMI	Yes	100%	110	0.15768928	0.064544	0.09314528	59.07%
7234	TPCODL	DHENKAN	DED	DHENKANAL	DHENKANAL COLLE	14118	11 KV GOVINDPUR(DKL)	14118203	GOBINDPUR CHHAK	4113DT232	250	MIXED	AMI	Yes	100%	154	0.1818618	0.088836	0.0930258	51.15%
7235	TPCODL	DHENKAN	DED	DHENKANAL	DHENKANAL COLLE	14118	11 KV GOVINDPUR(DKL)	14118203	SIARIA _2	4113DT244	100	MIXED	AMI	Yes	67%	86	0.08493556	0.021849	0.06308656	74.28%
7236	TPCODL	DHENKAN	DED	DHENKANAL	DHENKANAL COLLE	14118	11 KV GOVINDPUR(DKL)	14118203	TALABARAKOT NEAR HIGH SCHOOL	4113DT257	100	MIXED	AMI	Yes	33%	110	0.04516688	0.024038	0.02112888	46.78%
7237	TPCODL	DHENKAN	DED	DHENKANAL	DHENKANAL COLLE	14118	11 KV GOVINDPUR(DKL)	14118203	TALABARAKOT CLUB CHHAK	4113DT258	100	MIXED	AMI	Yes	33%	61	0.04588442	0.020009	0.02587542	56.39%
7238	TPCODL	DHENKAN	DED	DHENKANAL	DHENKANAL COLLE	14118	11 KV GOVINDPUR(DKL)	14118203	REGEDA _1	4113DT345	100	MIXED	AMI	Yes	67%	80	0.05284946	0.02854	0.02430946	46.00%
7239	TPCODL	DHENKAN	DED	DHENKANAL	DHENKANAL COLLE	14118	11 KV JORANDA	14118204	SHYMACHARANPUR-1	4113DT140	100	MIXED	AMI	Yes	100%	75	0.07764964	0.054463	0.02318664	29.86%
7240	TPCODL	DHENKAN	DED	DHENKANAL	DHENKANAL COLLE	14118	11 KV JORANDA	14118204	SHYMACHARANPUR SAHAUNDI PAD	4113DT142	100	MIXED	AMI	Yes	100%	69	0.04323634	0.036554	0.00668234	15.46%
7241	TPCODL	DHENKAN	DED	DHENKANAL	DHENKANAL COLLE	14118	11 KV JORANDA	14118204	SHYMACHARANPUR SABAR SAHI	4113DT144	500	MIXED	AMI	Yes	100%	281	0.23566168	0.172101	0.06356068	26.97%
7242	TPCODL	DHENKAN	DED	DHENKANAL	DHENKANAL COLLE	14118	11 KV JORANDA	14118204	BORAPADA KHAMAR SAHI	4113DT161	100	MIXED	AMI	Yes	0%	47	0.02509298	0.013814	0.01127898	44.95%
7243	TPCODL	DHENKAN	DED	DHENKANAL	DHENKANAL COLLE	14118	11 KV SAPTASAJYA	14118205	MAHISAPATA HOUSING BOARD_6	4111DT135	250	MIXED	AMI	Yes	0%	24	0.0509154	0.011885	0.0390304	76.66%
7244	TPCODL	DHENKAN	DED	DHENKANAL	DHENKANAL COLLE	14118	11 KV SAPTASAJYA	14118205	MAHISAPATA _3	4111DT136	500	MIXED	AMI	Yes	100%	97	0.07306652	0.065401	0.00766552	10.49%
7245	TPCODL	DHENKAN	DED	DHENKANAL	DHENKANAL COLLE	14118	11 KV SAPTASAJYA	14118205	MAHISAPATA _5	4111DT139	250	MIXED	AMI	Yes	100%	51	0.07050508	0.017427	0.05307808	75.28%
7246	TPCODL	DHENKAN	DED	DHENKANAL	DHENKANAL COLLE	14118	11 KV SAPTASAJYA	14118205	MAHISAPATA HOUSING BOARD_2	4111DT142	250	MIXED	AMI	Yes	67%	21	0.00410708	0.00316	0.00094708	23.06%
7247	TPCODL	DHENKAN	DED	DHENKANAL	DHENKANAL COLLE	14118	11 KV SAPTASAJYA	14118205	MAHISAPATA HOUSING BOARD_3	4111DT143	500	MIXED	AMI	Yes	0%	14	0.01697624	0.009753	0.00722324	42.55%
7248	TPCODL	DHENKAN	DED	DHENKANAL	DHENKANAL COLLE	14118	11 KV SAPTASAJYA	14118205	MAHISAPATA HOUSING BOARD_4	4111DT144	500	MIXED	AMI	Yes	0%	21	0.0150048	0.005134	0.0098708	65.78%
7249	TPCODL	DHENKAN	DED	DHENKANAL	DHENKANAL COLLE	14118	11 KV SAPTASAJYA	14118205	GAJAMARA	4111DT168	250	MIXED	AMI	Yes	67%	104	0.13992396	0.073574	0.06634996	47.42%
7250	TPCODL	DHENKAN	DED	DHENKANAL	DHENKANAL COLLE	14118	11 KV SAPTASAJYA	14118205	PATRA BHAGA _2	4111DT197	25	MIXED	AMI	Yes	0%	57	0.03733144	0.021072	0.01625944	43.55%
7251	TPCODL	DHENKAN	DED	DHENKANAL	DHENKANAL COLLE	14118	11 KV SAPTASAJYA	14118205	PADMANAVPUR _1	4111DT213	250	MIXED	AMI	Yes	33%	115	0.08240028	0.047543	0.03485728	42.30%
7252	TPCODL	DHENKAN	DED	DHENKANAL	DHENKANAL COLLE	14118	11 KV SAPTASAJYA	14118205	BADAKILA	4111DT215	250	MIXED	AMI	Yes	67%	112	0.09578192	0.045363	0.05041892	52.64%
7253	TPCODL	DHENKAN	DED	DHENKANAL	DHENKANAL COLLE	14118	11 KV SAPTASAJYA	14118205	BAJIROUT ITI GALI	4113DT416	100	MIXED	AMI	Yes	100%	56	0.04417434	0.039683	0.00449134	10.17%
7254	TPCODL	DHENKAN	DED	DHENKANAL	GHATIPIRI ODSSP	14322	11 KV KALANGA	14322201	KALANGA VILLAGE	4111DT609	100	MIXED	AMI	Yes	67%	90	0.02696164	0.020377	0.00658464	24.42%
7255	TPCODL	DHENKAN	DED	DHENKANAL	GHATIPIRI ODSSP	14322	11 KV GHATIPIRI	14322202	GHATIPIRI NUA BANGALA	4111DT652	100	MIXED	AMI	Yes	67%	111	0.06908752	0.039729	0.02935852	42.49%
7256	TPCODL	DHENKAN	DED	DHENKANAL	GHATIPIRI ODSSP	14322	11 KV GHATIPIRI	14322202	OSTAPAL VILLAGE	4111DT657	100	MIXED	AMI	Yes	67%	67	0.07772854	0.021457	0.05627154	72.39%
7257	TPCODL	DHENKAN	DED	DHENKANAL	GHATIPIRI ODSSP	14322	11 KV GOBINDAPRASAD	14322203	BEGUNIAPAL VILLAGE	4111DT275	100	MIXED	AMI	Yes	0%	225	0.1402483	0.066772	0.0734763	52.39%
7258	TPCODL	DHENKAN	DED	DHENKANAL	GHATIPIRI ODSSP	14322	11 KV GOBINDAPRASAD	14322203	RATHAPADA	4111DT295	250	MIXED	AMI	Yes	67%	60	0.11108184	0.022715	0.08836684	79.55%
7259	TPCODL	DHENKAN	DED	DHENKANAL	GHATIPIRI ODSSP	14322	11 KV GOBINDAPRASAD	14322203	GOBINDPRASAD	4111DT407	250	MIXED	AMI	Yes	0%	138	0.13803024	0.044749	0.09328124	67.58%
7260	TPCODL	DHENKAN	DED	DHENKANAL	GHATIPIRI ODSSP	14322	11 KV GOBINDAPRASAD	14322203	GOBINDPRASAD	4111DT421	100	MIXED	AMI	Yes	0%	42	0.05324018	0.015337	0.03790318	71.19%
7261	TPCODL	DHENKAN	DED	DHENKANAL	GHATIPIRI ODSSP	14322	11 KV GOBINDAPRASAD	14322203	ICHHAPUR	4111DT427	100	MIXED	AMI	Yes	67%	98	0.04344082	0.031868	0.01157282	26.64%
7262	TPCODL	DHENKAN	DED	DHENKANAL	GHATIPIRI ODSSP	14322	11 KV GOBINDAPRASAD	14322203	SIMILIPATNA CHHAKILO	4111DT439	100	MIXED	AMI	Yes	67%	95	0.04697274	0.030841	0.01613174	34.34%
7263	TPCODL	DHENKAN	DED	DHENKANAL	GHATIPIRI ODSSP	14322	11 KV GOBINDAPRASAD	14322203	BRUNDABANPUR	4111DT443	100	MIXED	AMI	Yes	67%	56	0.03349612	0.020574	0.01292212	38.58%
7264	TPCODL	DHENKAN	DED	DHENKANAL	GHATIPIRI ODSSP	14322	11 KV GOBINDAPRASAD	14322203	GHATIPHIRI BAZAR	4111DT473	100	MIXED	AMI	Yes	67%	62	0.09590802	0.019509	0.07639902	79.66%
7265	TPCODL	DHENKAN	DED	DHENKANAL	GUNDICHAPADA	14131	11 KV SIMINAI	14131201	MULISINGH 2	4114DT009	100	MIXED	AMI	Yes	0%	52	0.05495054	0.023588	0.03136254	57.07%
7266	TPCODL	DHENKAN	DED	DHENKANAL	GUNDICHAPADA	14131	11 KV SIMINAI	14131201	ANKARANTIPUR UPER SAHI	4114DT010	100	MIXED	AMI	Yes	100%	85	0.04465178	0.04002	0.00463178	10.37%
7267	TPCODL	DHENKAN	DED	DHENKANAL	GUNDICHAPADA	14131	11 KV SIMINAI	14131201	ANKARANTIPUR TALASAHI	4114DT012	100	MIXED	AMI	Yes	0%	90	0.04624116	0.030671	0.01557016	33.67%
7268	TPCODL	DHENKAN	DED	DHENKANAL	GUNDICHAPADA	14131	11 KV SIMINAI	14131201	SIMINAI BUS STAND	4114DT018	250	MIXED	AMI	Yes	0%	97	0.06555764	0.050993	0.01456464	22.22%
7269	TPCODL	DHENKAN	DED	DHENKANAL	GUNDICHAPADA	14131	11 KV SIMINAI	14131201	NILAMBARPUR	4114DT019	100	MIXED	AMI	Yes	0%	82	0.0576485	0.050295	0.0073535	12.76%
7270	TPCODL	DHENKAN	DED	DHENKANAL	GUNDICHAPADA	14131	11 KV SIMINAI	14131201	SIMINAI NUA SAHI	4114DT028	100	MIXED	AMI	Yes	100%	102	0.07443212	0.051284	0.02314812	31.10%
7271	TPCODL	DHENKAN	DED	DHENKANAL	GUNDICHAPADA	14131	11 KV SIMINAI	14131201	SAINBIR MAIN VILLAGE 1	4114DT036	100	MIXED	AMI	Yes	0%	81	0.09155626	0.046261	0.04529526	49.47%
7272	TPCODL	DHENKAN	DED	DHENKANAL	GUNDICHAPADA	14131	11 KV SIMINAI	14131201	GADASILA 1	4114DT045	100	MIXED	AMI	Yes	100%	54	0.0326703	0.023252	0.0094183	28.83%
7273	TPCODL	DHENKAN	DED	DHENKANAL	GUNDICHAPADA	14131	11 KV SIMINAI	14131201	SAINBIR NEAR BADHI POKHARI	4114DT048	100	MIXED	AMI	Yes	100%	53	0.03654884	0.024785	0.01176384	32.19%
7274	TPCODL	DHENKAN	DED	DHENKANAL	GUNDICHAPADA	14131	11 KV SIMINAI	14131201	KASIADIHI MAIN VILLAGE 1 (NEAR M	4114DT051	100	MIXED	AMI	Yes	100%	78	0.0473662	0.036471	0.0108952	23.00%
7275	TPCODL	DHENKAN	DED	DHENKANAL	GUNDICHAPADA	14131	11 KV SIMINAI	14131201	SARIAPADA-2	4114DT054	100	MIXED	AMI	Yes	0%	74	0.04441078	0.016593	0.02781778	62.64%
7276	TPCODL	DHENKAN	DED	DHENKANAL	GUNDICHAPADA	14131	11 KV SIMINAI	14131201	BALARAMPUR MAIN VILLAGE 1	4114DT056	250	MIXED	AMI	Yes	100%	157	0.09517008	0.051347	0.04382308	46.05%
7277	TPCODL	DHENKAN	DED	DHENKANAL	GUNDICHAPADA	14131	11 KV SIMINAI	14131201	KASIADIHI SITHA SAHI	4114DT060	63	MIXED	AMI	Yes	0%	37	0.05474447	0.01489	0.03985447	72.80%
7278	TPCODL	DHENKAN	DED	DHENKANAL	GUNDICHAPADA	14131	11 KV SIMINAI	14131201	BALARAMPUR MAIN VILLAGE 2 (TEM	4114DT065	100	MIXED	AMI	Yes	100%	119	0.08183704	0.041966	0.03987104	48.72%
7279	TPCODL	DHENKAN	DED	DHENKANAL	GUNDICHAPADA	14131	11 KV SIMINAI	14131201	KANDABINDHA GUDIA TOTA	4114DT075	100	MIXED	AMI	Yes	100%	99	0.04669086	0.03135	0.01534086	32.86%
7280	TPCODL	DHENKAN	DED	DHENKANAL	GUNDICHAPADA	14131	11 KV SIMINAI	14131201	KANDABINDHA MAJHI SAHI 1	4114DT077	100	MIXED	AMI	Yes	100%	93	0.0534284	0.032611	0.0208174	38.96%
7281	TPCODL	DHENKAN	DED	DHENKANAL	GUNDICHAPADA	14131	11 KV SIMINAI	14131201	KANDABINDHA MAJHI SAHI 2	4114DT078	63	MIXED	AMI	Yes	100%	86	0.06034378	0.026052	0.03429178	56.83%
7282	TPCODL	DHENKAN	DED	DHENKANAL	GUNDICHAPADA	14131	11 KV SIMINAI	14131201	KANDABINDHA BANUA SAHI	4114DT085	100	MIXED	AMI	Yes	0%	41	0.05956402	0.013672	0.04589202	77.05%
7283	TPCODL	DHENKAN	DED	DHENKANAL	GUNDICHAPADA	14131	11 KV SIMINAI	14131201	BALISAHI 2	4114DT116	100	MIXED	AMI	Yes	100%	55	0.01147556	0.010094	0.00138156	12.04%
7284	TPCODL	DHENKAN	DED	DHENKANAL	GUNDICHAPADA	14131	11 KV SIMINAI	14131201	GODASILA BAZAR	4114DT121	250	MIXED	AMI	Yes	100%	146	0.08712032	0.061431	0.02568932	29.49%
7285	TPCODL	DHENKAN	DED	DHENKANAL	GUNDICHAPADA	14131	11 KV SIMINAI	14131201	CHAINPUR PATNA	4114DT124	250	MIXED	AMI	Yes	100%	217	0.13810352	0.111082	0.02702152	19.57%
7286	TPCODL	DHENKAN	DED	DHENKANAL	GUNDICHAPADA	14131	11 KV SIMINAI	14131201	SUDHADIHIKATENI UPPER SAHI 1	4114DT146	100	MIXED	AMI	Yes	0%	92	0.04583448	0.034886	0.01094848	23.89%
7287	TPCODL	DHENKAN	DED	DHENKANAL	GUNDICHAPADA	14131	11 KV SIMINAI	14131201	SUDHADIHIKATENI TALA SAHI 1	4114DT147	100	MIXED	AMI	Yes	100%	105	0.07460679	0.031189	0.04341779	58.20%
7288	TPCODL	DHENKAN	DED	DHENKANAL	GUNDICHAPADA	14131	11 KV SIMINAI	14131201	BAULPUR BINA SAHI	4114DT155	100	MIXED	AMI	Yes	100%	44	0.0392811	0.022128	0.0171531	43.67%
7289	TPCODL	DHENKAN	DED	DHENKANAL	GUNDICHAPADA	14131	11 KV SIMINAI	14131201	BAULPUR PATNA	4114DT158	500	MIXED	AMI	Yes	100%	202	0.07982776	0.058162	0.02166576	27.14%
7290	TPCODL	DHENKAN	DED	DHENKANAL	GUNDICHAPADA	14131	11 KV SIMINAI	14131201	BAULPUR MATHA GODI SAHI	4114DT167	100	MIXED	AMI	Yes	100%	63	0.01754608	0.011457	0.00608908	34.70%
7291	TPCODL	DHENKAN	DED	DHENKANAL	GUNDICHAPADA	14131	11 KV CALTAX	14131203	KORIN JUANGA SAHI OLD	4113DT014	100	MIXED	AMI	Yes	100%	107	0.12015648	0.070298	0.04985848	41.49%
7292	TPCODL	DHENKAN	DED	DHENKANAL	GUNDICHAPADA	14131	11 KV CALTAX	14131203	KORIAN OLD	4113DT020	500	MIXED	AMI	Yes	0%	89	0.12924632	0.058852	0.07039432	54.47%
7293	TPCODL	DHENKAN	DED	DHENKANAL	GUNDICHAPADA	14131	11 KV CALTAX	14131203	KOTIAN NEW	4113DT022	500	MIXED	AMI	Yes	0%	233	0.2464276	0.105753	0.1406746	57.09%
7294	TPCODL	DHENKAN	DED	DHENKANAL	GUNDICHAPADA	14131	11 KV CALTAX	14131203	TARINI NAGAR	4113DT028	100	MIXED	AMI	Yes	0%	57	0.08083218	0.04749	0.03334218	41.25%
7295	TPCODL	DHENKAN	DED	DHENKANAL	GUNDICHAPADA	14131	11 KV CALTAX	14131203	ALASUA HATA	4113DT030	100	MIXED	AMI	Yes	100%	99	0.07609632	0.04879	0.02730632	35.88%
7296	TPCODL	DHENKAN	DED	DHENKANAL	GUNDICHAPADA	14131	11 KV CALTAX	14131203	LAW COLLEGE	4113DT032	500	MIXED	AMI	Yes	0%	314	0.2710968	0.235363	0.0357338	13.18%
7297	TPCODL	DHENKAN	DED	DHENKANAL	GUNDICHAPADA	14131	11 KV CALTAX	14131203	RATNABAZAR RAGADA	4113DT049	100	MIXED	AMI	Yes	0%	45	0.07483284	0.04121	0.03362284	44.93%
7298	TPCODL	DHENKAN	DED	DHENKANAL	GUNDICHAPADA	14131	11 KV CALTAX	14131203	MANDABA SAHI	4113DT056	250	MIXED	AMI	Yes	100%	137	0.15930472	0.083128	0.07617672	47.82%
7299	TPCODL	DHENKAN	DED	DHENKANAL	GUNDICHAPADA	14131	11 KV CALTAX	14131203	TOWN PLANNING OLD	4113DT057	500	MIXED	AMI	Yes	0%	317	0.48781584	0.166963	0.32085284	65.77%

Sl. No.	Zone Name	Circle name	Division name	Name of the Sub-division	Name of the Sub-station	Substation Code	Name of the 11 kV Feeder	Feeder Code	Name of the Location where DT situated	DT code	DT Capacity (kVA)	Predominant consumer type of DT (Domestic/Industrial/Agriculture/Mixed)	Type of metering AMR/AMI/ Communicable/Conventional metered/Unmetered	Status of Meter-whether Functional (Yes/No)	% of data received automatically (if AMR/AMI)	No. of Connected Consumers	Input Energy (MU) (A)	Billed Energy (MU) (B)	Loss (MU) (A-B)	% DT Loss (A-B)/A
7300	TPCODL	DHENKAN	DED	DHENKANAL	GUNDICHAPADA	14131	11 KV CALTAX	14131203	TOWN PLANNING OLD	4113DT058	250	MIXED	AMI	Yes	100%	130	0.17999904	0.124232	0.05576704	30.98%
7301	TPCODL	DHENKAN	DED	DHENKANAL	GUNDICHAPADA	14131	11 KV CALTAX	14131203	TOWN PLANNING-3	4113DT060	500	MIXED	AMI	Yes	0%	155	0.25437552	0.139604	0.11477152	45.12%
7302	TPCODL	DHENKAN	DED	DHENKANAL	GUNDICHAPADA	14131	11 KV CALTAX	14131203	TOWN PLANNING-4	4113DT061	100	MIXED	AMI	Yes	0%	37	0.09986594	0.02946	0.07040594	70.50%
7303	TPCODL	DHENKAN	DED	DHENKANAL	GUNDICHAPADA	14131	11 KV CALTAX	14131203	KARIGAR SAHI	4113DT065	500	MIXED	AMI	Yes	0%	91	0.16633208	0.095793	0.07053908	42.41%
7304	TPCODL	DHENKAN	DED	DHENKANAL	GUNDICHAPADA	14131	11 KV CALTAX	14131203	CHEMR SAHI	4113DT068	500	MIXED	AMI	Yes	0%	217	0.35943312	0.132072	0.22736112	63.26%
7305	TPCODL	DHENKAN	DED	DHENKANAL	GUNDICHAPADA	14131	11 KV PHD (G.Pada)	14131204	RANAPASI (KASIPADA)	4114DT321	100	MIXED	AMI	Yes	100%	84	0.05151398	0.037512	0.01400198	27.18%
7306	TPCODL	DHENKAN	DED	DHENKANAL	GUNDICHAPADA	14131	11 KV PHD (G.Pada)	14131204	RANAPASI MAIN VILLAGE	4114DT322	100	MIXED	AMI	Yes	100%	92	0.05445076	0.043573	0.01087776	19.98%
7307	TPCODL	DHENKAN	DED	DHENKANAL	GUNDICHAPADA	14131	11 KV PHD (G.Pada)	14131204	GENGUTIA HARIJAN SAHI	4114DT326	100	MIXED	AMI	Yes	33%	101	0.02980688	0.026556	0.00325088	10.91%
7308	TPCODL	DHENKAN	DED	DHENKANAL	GUNDICHAPADA	14131	11 KV PHD (G.Pada)	14131204	GENGUTIA KENCHOUBERENI UPPER S	4114DT328	100	MIXED	AMI	Yes	0%	48	0.0283282	0.020445	0.0078832	27.83%
7309	TPCODL	DHENKAN	DED	DHENKANAL	GUNDICHAPADA	14131	11 KV PHD (G.Pada)	14131204	HALADI BARI	4114DT333	100	MIXED	AMI	Yes	100%	51	0.0312549	0.020449	0.0108059	34.57%
7310	TPCODL	DHENKAN	DED	DHENKANAL	GUNDICHAPADA	14131	11 KV PHD (G.Pada)	14131204	GURJUNG PURUNA SAHI	4114DT335	100	MIXED	AMI	Yes	100%	80	0.06045298	0.027219	0.03323398	54.97%
7311	TPCODL	DHENKAN	DED	DHENKANAL	GUNDICHAPADA	14131	11 KV PHD (G.Pada)	14131204	SANKULEI	4114DT346	100	MIXED	AMI	Yes	67%	149	0.08930316	0.042072	0.04723116	52.89%
7312	TPCODL	DHENKAN	DED	DHENKANAL	GUNDICHAPADA	14131	11 KV PHD (G.Pada)	14131204	SAKULEI MATHA SAHI	4114DT348	100	MIXED	AMI	Yes	67%	66	0.03026668	0.021532	0.00873468	28.86%
7313	TPCODL	DHENKAN	DED	DHENKANAL	GUNDICHAPADA	14131	11 KV PHD (G.Pada)	14131204	KUMARDEIPUR VILLAGE	4114DT352	100	MIXED	AMI	Yes	67%	23	0.01526348	0.006887	0.00837648	54.88%
7314	TPCODL	DHENKAN	DED	DHENKANAL	GUNDICHAPADA	14131	11 KV PHD (G.Pada)	14131204	KEUTABERENI	4114DT358	100	MIXED	AMI	Yes	0%	62	0.04912384	0.017106	0.03201784	65.18%
7315	TPCODL	DHENKAN	DED	DHENKANAL	GUNDICHAPADA	14131	11 KV PHD (G.Pada)	14131204	BALABHDRAPUR SASAN KESARIA	4114DT361	100	MIXED	AMI	Yes	100%	78	0.0482731	0.030178	0.0180951	37.48%
7316	TPCODL	DHENKAN	DED	DHENKANAL	GUNDICHAPADA	14131	11 KV PHD (G.Pada)	14131204	BALABHDRAPUR NUA SAHI	4114DT364	100	MIXED	AMI	Yes	100%	54	0.04160422	0.035966	0.00563822	13.55%
7317	TPCODL	DHENKAN	DED	DHENKANAL	GUNDICHAPADA	14131	11 KV PHD (G.Pada)	14131204	JANHI TAILA	4114DT397	100	MIXED	AMI	Yes	100%	60	0.03354422	0.028253	0.00529122	15.77%
7318	TPCODL	DHENKAN	DED	DHENKANAL	GUNDICHAPADA	14131	11 KV PHD (G.Pada)	14131204	BARADA MAJHI SAHI	4114DT401	100	MIXED	AMI	Yes	100%	84	0.06434756	0.029002	0.03534556	54.93%
7319	TPCODL	DHENKAN	DED	DHENKANAL	GUNDICHAPADA	14131	11 KV PHD (G.Pada)	14131204	BARADA NUA SAHI	4114DT404	100	MIXED	AMI	Yes	100%	68	0.02885836	0.016462	0.01239636	42.96%
7320	TPCODL	DHENKAN	DED	DHENKANAL	GUNDICHAPADA	14131	11 KV PHD (G.Pada)	14131204	BARADA UPER SAHI	4114DT408	100	MIXED	AMI	Yes	100%	68	0.04626634	0.029531	0.01673534	36.17%
7321	TPCODL	DHENKAN	DED	DHENKANAL	GUNDICHAPADA	14131	11 KV PHD (G.Pada)	14131204	BHOJDEIPUR (BALISINGA)	4114DT414	100	MIXED	AMI	Yes	100%	62	0.04724284	0.024706	0.02253684	47.70%
7322	TPCODL	DHENKAN	DED	DHENKANAL	GUNDICHAPADA	14131	11 KV PHD (G.Pada)	14131204	SADASIBAPUR NUA SAHI (RAILWAY S	4114DT425	100	MIXED	AMI	Yes	67%	80	0.05036392	0.031385	0.01897892	37.68%
7323	TPCODL	DHENKAN	DED	DHENKANAL	GUNDICHAPADA	14131	11 KV Bhapur (G,Pada)	14131205	NACHIPURA	4111DT006	100	MIXED	AMI	Yes	67%	62	0.03832778	0.019467	0.01886078	49.21%
7324	TPCODL	DHENKAN	DED	DHENKANAL	GUNDICHAPADA	14131	11 KV Bhapur (G,Pada)	14131205	BANAMALIPRASAD	4111DT015	250	MIXED	AMI	Yes	67%	112	0.12416144	0.0476	0.07656144	61.66%
7325	TPCODL	DHENKAN	DED	DHENKANAL	GUNDICHAPADA	14131	11 KV Bhapur (G,Pada)	14131205	MANGALPUR	4111DT023	250	MIXED	AMI	Yes	100%	161	0.15425756	0.050348	0.10390956	67.36%
7326	TPCODL	DHENKAN	DED	DHENKANAL	GUNDICHAPADA	14131	11 KV Bhapur (G,Pada)	14131205	MANJURI-2	4111DT031	100	MIXED	AMI	Yes	67%	64	0.0448748	0.029851	0.0150238	33.48%
7327	TPCODL	DHENKAN	DED	DHENKANAL	GUNDICHAPADA	14131	11 KV Bhapur (G,Pada)	14131205	KANKADAHAD-2	4111DT036	250	MIXED	AMI	Yes	33%	102	0.10090424	0.032688	0.06821624	67.60%
7328	TPCODL	DHENKAN	DED	DHENKANAL	GUNDICHAPADA	14131	11 KV Bhapur (G,Pada)	14131205	NAMICHIRA	4111DT084	100	MIXED	AMI	Yes	67%	67	0.03051262	0.014107	0.01640562	53.77%
7329	TPCODL	DHENKAN	DED	DHENKANAL	GUNDICHAPADA	14131	11 KV Bhapur (G,Pada)	14131205	B B KATENI	4111DT095	100	MIXED	AMI	Yes	67%	72	0.0431135	0.027962	0.0151515	35.14%
7330	TPCODL	DHENKAN	DED	DHENKANAL	GUNDICHAPADA	14131	11 KV Bhapur (G,Pada)	14131205	GUNDICHAPDA MARKET	4114DT501	250	MIXED	AMI	Yes	100%	74	0.124649	0.037269	0.08738	70.10%
7331	TPCODL	DHENKAN	DED	DHENKANAL	GUNDICHAPADA	14131	11 KV Bhapur (G,Pada)	14131205	GUNDICHAPDA SOLABAKHARA MUSL	4114DT505	100	MIXED	AMI	Yes	67%	59	0.05022147	0.026249	0.02397247	47.73%
7332	TPCODL	DHENKAN	DED	DHENKANAL	GUNDICHAPADA	14131	11 KV Bhapur (G,Pada)	14131205	GUNDICHAPDA MAIN VILLAGE	4114DT508	250	MIXED	AMI	Yes	0%	66	0.15191596	0.035634	0.11628196	76.54%
7333	TPCODL	DHENKAN	DED	DHENKANAL	GUNDICHAPADA	14131	11 KV Bhapur (G,Pada)	14131205	BESALIA SCHOOL	4114DT520	100	MIXED	AMI	Yes	0%	69	0.15907038	0.034327	0.12474338	78.42%
7334	TPCODL	DHENKAN	DED	DHENKANAL	GUNDICHAPADA	14131	11 KV Bhapur (G,Pada)	14131205	HARIPUR	4114DT524	100	MIXED	AMI	Yes	100%	103	0.05913118	0.047953	0.01117818	18.90%
7335	TPCODL	DHENKAN	DED	DHENKANAL	GUNDICHAPADA	14131	11 KV Bhapur (G,Pada)	14131205	INDUPUR CHANDAN MANDAP SAHI	4114DT538	250	MIXED	AMI	Yes	0%	179	0.09923012	0.063925	0.03530512	35.58%
7336	TPCODL	DHENKAN	DED	DHENKANAL	GUNDICHAPADA	14131	11 KV Bhapur (G,Pada)	14131205	CHATIA	4114DT540	100	MIXED	AMI	Yes	33%	94	0.04024746	0.036913	0.00333446	8.28%
7337	TPCODL	DHENKAN	DED	DHENKANAL	GUNDICHAPADA	14131	11 KV Bhapur (G,Pada)	14131205	LUNI	4114DT545	100	MIXED	AMI	Yes	100%	47	0.04047454	0.025876	0.01459854	36.07%
7338	TPCODL	DHENKAN	DED	DHENKANAL	GUNDICHAPADA	14131	11 KV Bhapur (G,Pada)	14131205	INDUPUR COLLEGE CHHAK	4114DT547	100	MIXED	AMI	Yes	100%	55	0.04333188	0.029834	0.01349788	31.15%
7339	TPCODL	DHENKAN	DED	DHENKANAL	GUNDICHAPADA	14131	11 KV Bhapur (G,Pada)	14131205	INDUPUR TANTI SAHI	4114DT569	100	MIXED	AMI	Yes	0%	111	0.08679028	0.048654	0.03813628	43.94%
7340	TPCODL	DHENKAN	DED	DHENKANAL	GUNDICHAPADA	14131	11 KV Bhapur (G,Pada)	14131205	INDIPUR TERAGHARIA	4114DT572	63	MIXED	AMI	Yes	0%	47	0.018275	0.012656	0.005619	30.75%
7341	TPCODL	DHENKAN	DED	DHENKANAL	GUNDICHAPADA	14131	11 KV Bhapur (G,Pada)	14131205	INDIPUR KHUNTUJHARI	4114DT577	100	MIXED	AMI	Yes	67%	80	0.03366406	0.027259	0.00640506	19.03%
7342	TPCODL	DHENKAN	DED	DHENKANAL	GUNDICHAPADA	14131	11 KV Bhapur (G,Pada)	14131205	KHUNTUJARI	4114DT587	100	MIXED	AMI	Yes	100%	33	0.01495038	0.007826	0.00712438	47.65%
7343	TPCODL	DHENKAN	DED	DHENKANAL	HINDOL ROAD	14121	11 KV 4 POLE	14121204	BUDHAPANKA-1	4132DT416	100	MIXED	AMI	Yes	67%	87	0.04979646	0.023684	0.02611246	52.44%
7344	TPCODL	DHENKAN	DED	DHENKANAL	JIRIDAMALI ODSSP	14318	11 KV JIRIDAMALI	14318202	NEAR JIRIDAMALI BAZAR	4142DT087	100	MIXED	AMI	Yes	33%	79	0.18699992	0.040897	0.14610292	78.13%
7345	TPCODL	DHENKAN	DED	DHENKANAL	KHAJURIAKATA	14122	11 KV Bedapada-1	14122202	RANJAGOLA 2	4133DT727	100	MIXED	AMI	Yes	100%	143	0.04769014	0.035861	0.01182914	24.80%
7346	TPCODL	DHENKAN	DED	DHENKANAL	KHAJURIAKATA	14122	11 KV KALINGA	14122203	PALA CHAKADA 3	4133DT409	100	MIXED	AMI	Yes	33%	38	0.02443456	0.016322	0.00811256	33.20%
7347	TPCODL	DHENKAN	DED	DHENKANAL	KHAJURIAKATA	14122	11 KV KALINGA	14122203	PALA CHAKADA 4	4133DT410	100	MIXED	AMI	Yes	100%	70	0.02340486	0.021204	0.00220086	9.40%
7348	TPCODL	DHENKAN	DED	DHENKANAL	MADHAPUR	14140	11 KV LUNAHANDI	14140204	MADHAPUR-1	4223DT101	100	MIXED	AMI	Yes	67%	94	0.05327696	0.039706	0.01357096	25.47%
7349	TPCODL	DHENKAN	DED	DHENKANAL	MUKTAPASI ODSSP	14316	11 KV Chaulia/Khamara	14316201	MANDAPAL 1	4113DT539	100	MIXED	AMI	Yes	100%	23	0.02754028	0.006593	0.02094728	76.06%
7350	TPCODL	DHENKAN	DED	DHENKANAL	MUKTAPASI ODSSP	14316	11 KV Chaulia/Khamara	14316201	NEAR CHAULIA GP OFFICE	4113DT556	63	MIXED	AMI	Yes	67%	88	0.04134238	0.022125	0.01921738	46.48%
7351	TPCODL	DHENKAN	DED	DHENKANAL	MUKTAPASI ODSSP	14316	11 KV Chaulia/Khamara	14316201	DUDHUKATENI GANDHI CHHAK 2	4113DT565	100	MIXED	AMI	Yes	67%	168	0.1021106	0.041867	0.0602436	59.00%
7352	TPCODL	DHENKAN	DED	DHENKANAL	MUKTAPASI ODSSP	14316	11 KV Chaulia/Khamara	14316201	CHAULIA KHAJURI SAHI	4113DT570	100	MIXED	AMI	Yes	0%	166	0.04733208	0.031322	0.01601008	33.83%
7353	TPCODL	DHENKAN	DED	DHENKANAL	MUKTAPASI ODSSP	14316	11 KV Tarva	14316202	TARAVA	4113DT640	250	MIXED	AMI	Yes	0%	132	0.19681194	0.050089	0.14672294	74.55%
7354	TPCODL	DHENKAN	DED	DHENKANAL	MUKTAPASI ODSSP	14316	11 KV Tarva	14316202	KHALIBANDHA 1	4113DT650	100	MIXED	AMI	Yes	100%	82	0.0421744	0.026485	0.0156894	37.20%
7355	TPCODL	DHENKAN	DED	DHENKANAL	MUKTAPASI ODSSP	14316	11 KV Similia	14316203	RANJA CHHAK-1	4113DT431	100	MIXED	AMI	Yes	100%	139	0.0909553	0.053712	0.0372433	40.95%
7356	TPCODL	DHENKAN	DED	DHENKANAL	MUKTAPASI ODSSP	14316	11 KV Similia	14316203	DERASINGH-2	4113DT439	100	MIXED	AMI	Yes	100%	67	0.0380482	0.016222	0.0218262	57.36%
7357	TPCODL	DHENKAN	DED	DHENKANAL	MUKTAPASI ODSSP	14316	11 KV Similia	14316203	ASANAPATIA	4113DT474	100	MIXED	AMI	Yes	100%	69	0.01838932	0.009813	0.00857632	46.64%
7358	TPCODL	DHENKAN	DED	DHENKANAL	MUKTAPASI ODSSP	14316	11 KV Similia	14316203	RANJA -2	4113DT476	100	MIXED	AMI	Yes	100%	111	0.03880676	0.028475	0.01033176	26.62%
7359	TPCODL	DHENKAN	DED	DHENKANAL	MUKTAPASI ODSSP	14316	11 KV Similia	14316203	KANKADAPAL NEAR BANK	4113DT490	100	MIXED	AMI	Yes	100%	83	0.07862726	0.034851	0.04377626	55.68%
7360	TPCODL	DHENKAN	DED	DHENKANAL	MUKTAPASI ODSSP	14316	11 KV Similia	14316203	SIMILIA DANDA SAHI	4113DT599	100	MIXED	AMI	Yes	67%	31	0.04227412	0.018068	0.02420612	57.26%
7361	TPCODL	DHENKAN	DED	DHENKANAL	MUKTAPASI ODSSP	14316	11 KV Similia	14316203	BHAGABANPUR CHHAK	4113DT606	250	MIXED	AMI	Yes	0%	236	0.21472176	0.133895	0.08082676	37.64%
7362	TPCODL	DHENKAN	DED	DHENKANAL	MUKTAPASI ODSSP	14316	11 KV Similia	14316203	OSF POLICE BATALION	4113DT616	250	MIXED	AMI	Yes	33%	8	0.02137404	0.018378	0.00299604	14.02%
7363	TPCODL	DHENKAN	DED	GONDIA	BANASINGH ODSSP	14314	11 KV BANASINGH	14314204	LATADEIPUR	4122DT360	100	MIXED	AMI	Yes	100%	91	0.05720516	0.040301	0.01690416	29.55%
7364	TPCODL	DHENKAN	DED	GONDIA	NIHALPRASAD	14190	11 kV Kasipur	14190202	PINGUA (JHARANA SAHI)	4123DT309	100	MIXED	AMI	Yes	33%	40	0.02159064	0.010499	0.01109164	51.37%
7365	TPCODL	DHENKAN	DED	GONDIA	BANARPAL	14142	11 KV KULAD	14142202	CHAURIDHIA BONDA	4311DT110	100	MIXED	AMI	Yes	100%	74	0.04304654	0.039481	0.00356554	8.28%
7366	TPCODL	DHENKAN	DED	GONDIA	BANASINGH ODSSP	14314	11 KV CHAULIA	14314201	TILAPADA-2	4122DT234	100	MIXED	AMI	Yes	100%	65	0.02215554	0.01665	0.00550554	24.85%
7367	TPCODL	DHENKAN	DED	GONDIA	BANASINGH ODSSP	14314	11 KV CHAULIA	14314201	KHANDIABANDHA	4122DT242	100	MIXED	AMI	Yes	100%	58	0.02318388	0.012426	0.01075788	46.40%
7368	TPCODL	DHENKAN	DED	GONDIA	BANASINGH ODSSP	14314	11 KV CHAULIA	14314201	NATHUA NUA SAHI	4122DT247	100	MIXED	AMI	Yes	33%	118	0.03471472	0.028646	0.00606872	17.48%
7369	TPCODL	DHENKAN	DED	GONDIA	BANASINGH ODSSP	14314	11 KV CHAULIA	14314201	NATHUA PURUNA SAHI	4122DT310	100	MIXED	AMI	Yes	100%	81	0.021283	0.016647	0.004636	21.78%
7370	TPCODL	DHENKAN	DED	GONDIA	BANASINGH ODSSP	14314	11 KV CHAULIA	14314201	PARIKHEDA-2	4122DT313	100	MIXED	AMI	Yes	0%	87	0.05793204	0.01771	0.04022204	69.43%
7371	TPCODL	DHENKAN	DED	GONDIA	BANASINGH ODSSP	14314	11 KV BANASINGH	14314204	NUAGADA	4122DT322	100	MIXED	AMI	Yes	100%	64	0.04360824	0.022316	0.02129224	48.83%
7372	TPCODL	DHENKAN	DED	GONDIA	BANASINGH ODSSP	14314	11 KV BANASINGH	14314204	BANASINGH 1	4122DT323	250	MIXED	AMI	Yes	100%	159	0.12020224	0.065745	0.05445724	45.30%

Sl. No.	Zone Name	Circle name	Division name	Name of the Sub-division	Name of the Sub-station	Substation Code	Name of the 11 kV Feeder	Feeder Code	Name of the Location where DT situated	DT code	DT Capacity (kVA)	Predominant consumer type of DT (Domestic/Industrial/Agriculture/Mixed)	Type of metering AMR/AMI/ Communicable/Conventional metered/Unmetered	Status of Meter-whether Functional (Yes/No)	% of data received automatically (if AMR/AMI)	No. of Connected Consumers	Input Energy (MU) (A)	Billed Energy (MU) (B)	Loss (MU) (A-B)	% DT Loss (A-B)/A
7373	TPCODL	DHENKAN	DED	GONDIA	BANASINGH ODSSP	14314	11 KV BANASINGH	14314204	BANASINGH 2	4122DT324	100	MIXED	AMI	Yes	100%	64	0.06077796	0.030538	0.03023996	49.75%
7374	TPCODL	DHENKAN	DED	GONDIA	BANASINGH ODSSP	14314	11 KV BANASINGH	14314204	BANASINGH KADHUA SAHI 2	4122DT329	100	MIXED	AMI	Yes	0%	99	0.05988522	0.02773	0.03215522	53.69%
7375	TPCODL	DHENKAN	DED	GONDIA	BANASINGH ODSSP	14314	11 KV BANASINGH	14314204	BANASING MAJHI SAHI 1	4122DT333	100	MIXED	AMI	Yes	0%	91	0.03853416	0.024605	0.01392916	36.15%
7376	TPCODL	DHENKAN	DED	GONDIA	BANASINGH ODSSP	14314	11 KV BANASINGH	14314204	BANASING TALA SAHI 2	4122DT334	100	MIXED	AMI	Yes	100%	63	0.03602572	0.020738	0.01528772	42.44%
7377	TPCODL	DHENKAN	DED	GONDIA	BANASINGH ODSSP	14314	11 KV BANASINGH	14314204	SANKARPUR 1	4122DT336	100	MIXED	AMI	Yes	67%	41	0.02251216	0.011337	0.01117516	49.64%
7378	TPCODL	DHENKAN	DED	GONDIA	BANASINGH ODSSP	14314	11 KV BANASINGH	14314204	SANKARPUR 3	4122DT341	100	MIXED	AMI	Yes	100%	67	0.02553704	0.015418	0.01011904	39.62%
7379	TPCODL	DHENKAN	DED	GONDIA	BANASINGH ODSSP	14314	11 KV BANASINGH	14314204	BHINPUR	4122DT342	100	MIXED	AMI	Yes	100%	61	0.03334016	0.01266319	0.02067697	62.02%
7380	TPCODL	DHENKAN	DED	GONDIA	BANASINGH ODSSP	14314	11 KV BANASINGH	14314204	RADHADEIPUR 2	4122DT351	100	MIXED	AMI	Yes	0%	109	0.04913912	0.030483	0.01865612	37.97%
7381	TPCODL	DHENKAN	DED	GONDIA	BANASINGH ODSSP	14314	11 KV BANASINGH	14314204	RADHADEIPUR 3	4122DT352	100	MIXED	AMI	Yes	67%	117	0.02911178	0.023588	0.00552378	18.97%
7382	TPCODL	DHENKAN	DED	GONDIA	BANASINGH ODSSP	14314	11 KV BANASINGH	14314204	KALURIA 2	4122DT367	100	MIXED	AMI	Yes	0%	117	0.03950842	0.02857	0.01093842	27.69%
7383	TPCODL	DHENKAN	DED	GONDIA	BANASINGH ODSSP	14314	11 KV BANASINGH	14314204	PATUSAHU KATENI	4122DT376	100	MIXED	AMI	Yes	0%	94	0.03308064	0.027089	0.00599164	18.11%
7384	TPCODL	DHENKAN	DED	GONDIA	BANASINGH ODSSP	14314	11 KV BANASINGH	14314204	GUNDULEI SCHOOL 2	4122DT384	100	MIXED	AMI	Yes	67%	62	0.04694	0.020552	0.026388	56.22%
7385	TPCODL	DHENKAN	DED	GONDIA	BANASINGH ODSSP	14314	11 KV BANASINGH	14314204	NUA THAKURAPAL	4122DT386	100	MIXED	AMI	Yes	100%	92	0.02738572	0.019324	0.00806172	29.44%
7386	TPCODL	DHENKAN	DED	GONDIA	BANASINGH ODSSP	14314	11 KV BANASINGH	14314204	THAKURAPAL 3	4122DT389	100	MIXED	AMI	Yes	0%	134	0.03225694	0.029133	0.00312394	9.68%
7387	TPCODL	DHENKAN	DED	GONDIA	BANASINGH ODSSP	14314	11 KV BANASINGH	14314204	BHATAKANTNI PURANASAHI	4122DT477	100	MIXED	AMI	Yes	33%	67	0.0453133	0.014579	0.0307343	67.83%
7388	TPCODL	DHENKAN	DED	GONDIA	BANASINGH ODSSP	14314	11 KV BANASINGH	14314204	SUDHARAPADA	4122DT480	100	MIXED	AMI	Yes	100%	60	0.03210442	0.015376	0.01672842	52.11%
7389	TPCODL	DHENKAN	DED	GONDIA	BANASINGH ODSSP	14314	11 KV BANASINGH	14314204	SANA NAGANA 1	4122DT489	100	MIXED	AMI	Yes	33%	67	0.03383574	0.011992	0.02184374	64.56%
7390	TPCODL	DHENKAN	DED	GONDIA	BANASINGH ODSSP	14314	11 KV BANASINGH	14314204	NAGANA 2	4122DT495	100	MIXED	AMI	Yes	100%	60	0.0211154	0.010107	0.0110084	52.13%
7391	TPCODL	DHENKAN	DED	GONDIA	BANASINGH ODSSP	14314	11 KV BANASINGH	14314204	NAGANA HARIJAN SAHI	4122DT497	100	MIXED	AMI	Yes	100%	70	0.01531922	0.00844	0.00687922	44.91%
7392	TPCODL	DHENKAN	DED	GONDIA	BANASINGH ODSSP	14314	11 KV BANASINGH	14314204	MAHAPADA 2	4122DT506	250	MIXED	AMI	Yes	100%	148	0.0548858	0.037654	0.0172318	31.40%
7393	TPCODL	DHENKAN	DED	GONDIA	DHENKANAL COLLE	14118	11 KV DKL TOWN-1	14118201	BAJICHOWK-3	4113DT299	500	MIXED	AMI	Yes	0%	306	0.23199416	0.182983	0.04901116	21.13%
7394	TPCODL	DHENKAN	DED	GONDIA	DHENKANAL COLLE	14118	11 KV JORANDA	14118204	JANKHIRA_3	4122DT255	100	MIXED	AMI	Yes	33%	117	0.02866016	0.021345	0.00731516	25.52%
7395	TPCODL	DHENKAN	DED	GONDIA	DHENKANAL COLLE	14118	11 KV JORANDA	14118204	DURGA PRASAD_1	4122DT298	250	MIXED	AMI	Yes	33%	94	0.0647922	0.027837	0.0369552	57.04%
7396	TPCODL	DHENKAN	DED	GONDIA	DHENKANAL COLLE	14118	11 KV JORANDA	14118204	DAHIMALA	4122DT408	100	MIXED	AMI	Yes	33%	33	0.01996886	0.010173	0.00979586	49.06%
7397	TPCODL	DHENKAN	DED	GONDIA	DHENKANAL COLLE	14118	11 KV JORANDA	14118204	CHANABOLUA FOREST BEAT ROAD	4122DT415	100	MIXED	AMI	Yes	0%	69	0.03529586	0.010883	0.02441286	69.17%
7398	TPCODL	DHENKAN	DED	GONDIA	DHENKANAL COLLE	14118	11 KV JORANDA	14118204	NAGIAPOSI_1	4122DT434	100	MIXED	AMI	Yes	100%	92	0.02597192	0.01435188	0.01162004	44.74%
7399	TPCODL	DHENKAN	DED	GONDIA	DHENKANAL COLLE	14118	11 KV JORANDA	14118204	BIRADIA_4	4122DT443	100	MIXED	AMI	Yes	33%	98	0.05355668	0.031639	0.02191768	40.92%
7400	TPCODL	DHENKAN	DED	GONDIA	GONDIA	14120	11 KV MANDAR	14120201	RAITALA 2	4121DT091	100	MIXED	AMI	Yes	67%	103	0.0465421	0.030108	0.0164341	35.31%
7401	TPCODL	DHENKAN	DED	GONDIA	GONDIA	14120	11 KV MANDAR	14120201	BARADA 4	4121DT131	250	MIXED	AMI	Yes	67%	137	0.078781	0.031574	0.047207	59.92%
7402	TPCODL	DHENKAN	DED	GONDIA	GONDIA	14120	11 KV MANDAR	14120201	KUSIDA 2	4121DT134	100	MIXED	AMI	Yes	67%	56	0.01892106	0.011576	0.00734506	38.82%
7403	TPCODL	DHENKAN	DED	GONDIA	GONDIA	14120	11 KV MANDAR	14120201	SPRK PUR 2	4121DT359	100	MIXED	AMI	Yes	67%	85	0.02631364	0.02442547	0.00188817	7.18%
7404	TPCODL	DHENKAN	DED	GONDIA	GONDIA	14120	11 KV KAPILASH	14120202	ARNAPUR PURUNA SAHI	4121DT244	63	MIXED	AMI	Yes	0%	54	0.06827232	0.019475	0.04879732	71.47%
7405	TPCODL	DHENKAN	DED	GONDIA	GONDIA	14120	11 KV KAPILASH	14120202	JHILLI	4121DT270	100	MIXED	AMI	Yes	0%	92	0.0702098	0.032605	0.0376048	53.56%
7406	TPCODL	DHENKAN	DED	GONDIA	GONDIA	14120	11 KV KAPILASH	14120202	DEOGAON 1	4121DT305	100	MIXED	AMI	Yes	67%	124	0.06004752	0.037248	0.02279952	37.97%
7407	TPCODL	DHENKAN	DED	GONDIA	GONDIA	14120	11 KV KAPILASH	14120202	CHANDRASEKHARPUR 4	4121DT332	100	MIXED	AMI	Yes	67%	59	0.03152894	0.017	0.01452894	46.08%
7408	TPCODL	DHENKAN	DED	GONDIA	GONDIA	14120	11 KV KAPILASH	14120202	GOPALPUR	4121DT337	100	MIXED	AMI	Yes	0%	60	0.03380214	0.01413982	0.01966232	58.17%
7409	TPCODL	DHENKAN	DED	GONDIA	GONDIA	14120	11 KV KAPILASH	14120202	DEOGAON 4	4121DT343	100	MIXED	AMI	Yes	100%	104	0.05948596	0.046486	0.01299996	21.85%
7410	TPCODL	DHENKAN	DED	GONDIA	GONDIA	14120	11 KV KAPILASH	14120202	NEAR DEAR PARK	4121DT345	100	MIXED	AMI	Yes	33%	32	0.01599936	0.008574	0.00742536	46.41%
7411	TPCODL	DHENKAN	DED	GONDIA	GONDIA	14120	11 KV GONDIA	14120203	GONDIA MARKET 1	4121DT003	250	MIXED	AMI	Yes	0%	242	0.18718208	0.11563161	0.07155047	38.23%
7412	TPCODL	DHENKAN	DED	GONDIA	GONDIA	14120	11 KV GONDIA	14120203	GONDIA MARKET 2	4121DT004	250	MIXED	AMI	Yes	100%	162	0.16465212	0.104677	0.05997512	36.43%
7413	TPCODL	DHENKAN	DED	GONDIA	GONDIA	14120	11 KV GONDIA	14120203	GONDIA SADAK SAHI 1	4121DT011	100	MIXED	AMI	Yes	100%	76	0.07780734	0.03413	0.04367734	56.14%
7414	TPCODL	DHENKAN	DED	GONDIA	GONDIA	14120	11 KV GONDIA	14120203	POROKHOJA 3	4121DT019	100	MIXED	AMI	Yes	100%	76	0.03644534	0.026564	0.00988134	27.11%
7415	TPCODL	DHENKAN	DED	GONDIA	GONDIA	14120	11 KV GONDIA	14120203	POROKHOJA 4	4121DT020	100	MIXED	AMI	Yes	100%	75	0.02803042	0.019126	0.00890442	31.77%
7416	TPCODL	DHENKAN	DED	GONDIA	GONDIA	14120	11 KV GONDIA	14120203	SIBA MANDIRA	4121DT024	100	MIXED	AMI	Yes	100%	109	0.06309578	0.042781	0.02031478	32.20%
7417	TPCODL	DHENKAN	DED	GONDIA	GONDIA	14120	11 KV GONDIA	14120203	GONDIA NUA SAHI	4121DT048	250	MIXED	AMI	Yes	100%	120	0.08285344	0.040683	0.04217044	50.90%
7418	TPCODL	DHENKAN	DED	GONDIA	GONDIA	14120	11 KV GONDIA	14120203	BARAPADA SASAN SAHI 1	4121DT052	100	MIXED	AMI	Yes	100%	35	0.05607676	0.028951	0.02712576	48.37%
7419	TPCODL	DHENKAN	DED	GONDIA	GONDIA	14120	11 KV GONDIA	14120203	BARAPADA SASAN SAHI 2	4121DT053	100	MIXED	AMI	Yes	100%	67	0.08249884	0.046474	0.03602484	43.67%
7420	TPCODL	DHENKAN	DED	GONDIA	GONDIA	14120	11 KV ANKURDA	14120204	ANKURDA	4121DT056	250	MIXED	AMI	Yes	0%	67	0.06854044	0.024363	0.04417744	64.45%
7421	TPCODL	DHENKAN	DED	GONDIA	GONDIA	14120	11 KV ANKURDA	14120204	SANTHAPUR 1	4121DT097	250	MIXED	AMI	Yes	100%	46	0.0596974	0.016943	0.0427544	71.62%
7422	TPCODL	DHENKAN	DED	GONDIA	GONDIA	14120	11 KV ANKURDA	14120204	SANTHAPUR (DEHURI SAHI)	4121DT100	100	MIXED	AMI	Yes	100%	47	0.02427076	0.009761	0.01450976	59.78%
7423	TPCODL	DHENKAN	DED	GONDIA	GONDIA	14120	11 KV ANKURDA	14120204	BAJURIA	4121DT103	100	MIXED	AMI	Yes	0%	65	0.04369218	0.027749	0.01594318	36.49%
7424	TPCODL	DHENKAN	DED	GONDIA	GONDIA	14120	11 KV PASUPATI	14120205	GUNDURAPASI	4121DT115	100	MIXED	AMI	Yes	100%	93	0.01969862	0.019115	0.00058362	2.96%
7425	TPCODL	DHENKAN	DED	GONDIA	GONDIA	14120	11 KV PASUPATI	14120205	BANIA	4121DT192	100	MIXED	AMI	Yes	67%	48	0.01255088	0.011442	0.00110888	8.84%
7426	TPCODL	DHENKAN	DED	GONDIA	GONDIA	14120	11 KV PASUPATI	14120205	SORSIAPADA 1	4121DT196	100	MIXED	AMI	Yes	0%	78	0.03842916	0.008959	0.02947016	76.69%
7427	TPCODL	DHENKAN	DED	GONDIA	JORANDA	14188	11 KV NATIMA	14188201	JORANDA S/S OFFICE TO TARINI CHA	4122DT121	100	MIXED	AMI	Yes	100%	82	0.06402692	0.045165	0.01886192	29.46%
7428	TPCODL	DHENKAN	DED	GONDIA	JORANDA	14188	11 KV NATIMA	14188201	JORANDA	4122DT123	100	MIXED	AMI	Yes	67%	62	0.06008884	0.037749	0.02233984	37.18%
7429	TPCODL	DHENKAN	DED	GONDIA	JORANDA	14188	11 KV NATIMA	14188201	JORANDA MARKET	4122DT124	500	MIXED	AMI	Yes	100%	221	0.16773952	0.069181	0.09855852	58.76%
7430	TPCODL	DHENKAN	DED	GONDIA	JORANDA	14188	11 KV NATIMA	14188201	JORANDA PRIMARY SCHOOL PATANA	4122DT125	250	MIXED	AMI	Yes	100%	136	0.03797734	0.035159	0.00281834	7.42%
7431	TPCODL	DHENKAN	DED	GONDIA	JORANDA	14188	11 KV NATIMA	14188201	JORANDA NUA SAHI	4122DT128	250	MIXED	AMI	Yes	100%	143	0.09764292	0.060703	0.03693992	37.83%
7432	TPCODL	DHENKAN	DED	GONDIA	JORANDA	14188	11 KV NATIMA	14188201	JORANDA JAMUSARA	4122DT129	100	MIXED	AMI	Yes	100%	61	0.0434667	0.030121	0.0133457	30.70%
7433	TPCODL	DHENKAN	DED	GONDIA	JORANDA	14188	11 KV NATIMA	14188201	NEULAPOI	4122DT142	100	MIXED	AMI	Yes	100%	126	0.0334768	0.024899	0.0085778	25.62%
7434	TPCODL	DHENKAN	DED	GONDIA	JORANDA	14188	11 KV NATIMA	14188201	KANKALUNDA-2	4122DT146	100	MIXED	AMI	Yes	0%	70	0.05065746	0.025772	0.02488546	49.12%
7435	TPCODL	DHENKAN	DED	GONDIA	JORANDA	14188	11 KV NATIMA	14188201	DADHISINGHA PRIMARY SCHOOL-1	4122DT153	100	MIXED	AMI	Yes	100%	123	0.1164241	0.039274	0.0771501	66.27%
7436	TPCODL	DHENKAN	DED	GONDIA	JORANDA	14188	11 KV NATIMA	14188201	DADHISINGHA PRIMARY SCHOOL-2	4122DT154	100	MIXED	AMI	Yes	100%	89	0.07671108	0.027845	0.04886608	63.70%
7437	TPCODL	DHENKAN	DED	GONDIA	JORANDA	14188	11 KV NATIMA	14188201	CHORULEI MARKET COMPLEX	4122DT162	100	MIXED	AMI	Yes	100%	71	0.04660796	0.034148	0.01245996	26.73%
7438	TPCODL	DHENKAN	DED	GONDIA	JORANDA	14188	11 KV NATIMA	14188201	HARADA BERANA NEAR PRIMARY SCH	4122DT171	100	MIXED	AMI	Yes	0%	70	0.01852932	0.014506	0.00402332	21.71%
7439	TPCODL	DHENKAN	DED	GONDIA	JORANDA	14188	11 KV NATIMA	14188201	NEULAPOI-1	4122DT177	100	MIXED	AMI	Yes	67%	98	0.03608784	0.030243	0.00584484	16.20%
7440	TPCODL	DHENKAN	DED	GONDIA	JORANDA	14188	11 KV NATIMA	14188201	CHHATIA NEAR SCHOOL	4122DT187	100	MIXED	AMI	Yes	67%	86	0.0556624	0.036199	0.0194634	34.97%
7441	TPCODL	DHENKAN	DED	GONDIA	JORANDA	14188	11 KV NATIMA	14188201	MAHIMA MANDIR BADA MATHA	4122DT190	250	MIXED	AMI	Yes	100%	29	0.0203752	0.005454	0.0149212	73.23%
7442	TPCODL	DHENKAN	DED	GONDIA	JORANDA	14188	11 KV KARAMUL	14188203	KABERA BEGUNIASAHI	4122DT013	100	MIXED	AMI	Yes	100%	63	0.0320468	0.023089	0.0089578	27.95%
7443	TPCODL	DHENKAN	DED	GONDIA	JORANDA	14188	11 KV KARAMUL	14188203	KHANKAR OLD	4122DT043	100	MIXED	AMI	Yes	100%	68	0.05791674	0.026478	0.03143874	54.28%
7444	TPCODL	DHENKAN	DED	GONDIA	JORANDA	14188	11 KV KARAMUL	14188203	BAISINGA KAMAR SALA	4122DT077	100	MIXED	AMI	Yes	100%	98	0.05413494	0.036535	0.01759994	32.51%
7445	TPCODL	DHENKAN	DED	GONDIA	JORANDA	14188	11 KV KARAMUL	14188203	BAISINGA TALASAHI	4122DT079	100	MIXED	AMI	Yes	100%	98	0.0442505	0.02557	0.0186805	42.22%

Sl. No.	Zone Name	Circle name	Division name	Name of the Sub-division	Name of the Sub-station	Substation Code	Name of the 11 kV Feeder	Feeder Code	Name of the Location where DT situated	DT code	DT Capacity (kVA)	Predominant consumer type of DT (Domestic/Industrial/Agriculture/Mixed)	Type of metering AMR/AMI/ Communicable/Conventional metered/Unmetered	Status of Meter-whether Functional (Yes/No)	% of data received automatically (if AMR/AMI)	No. of Connected Consumers	Input Energy (MU) (A)	Billed Energy (MU) (B)	Loss (MU) (A-B)	% DT Loss (A-B)/A
7446	TPCODL	DHENKAN	DED	GONDIA	JORANDA	14188	11 KV KARAMUL	14188203	AMBABAHALI-2	4122DT087	250	MIXED	AMI	Yes	100%	128	0.05918536	0.040104	0.01908136	32.24%
7447	TPCODL	DHENKAN	DED	GONDIA	JORANDA	14188	11 KV KARAMUL	14188203	BAINSIA BUS STAND	4122DT089	250	MIXED	AMI	Yes	100%	72	0.026833	0.020774	0.006059	22.58%
7448	TPCODL	DHENKAN	DED	GONDIA	JORANDA	14188	11 KV KARAMUL	14188203	BAINSIA HATA SAHI	4122DT091	100	MIXED	AMI	Yes	0%	73	0.03742178	0.023538	0.01388378	37.10%
7449	TPCODL	DHENKAN	DED	GONDIA	JORANDA	14188	11 KV KARAMUL	14188203	BALLAV NUA SAHI	4122DT092	100	MIXED	AMI	Yes	100%	125	0.05437668	0.041358	0.01301868	23.94%
7450	TPCODL	DHENKAN	DED	GONDIA	JORANDA	14188	11 KV KARAMUL	14188203	MAKUNDAPUR	4122DT106	100	MIXED	AMI	Yes	100%	92	0.05103126	0.024408	0.02662326	52.17%
7451	TPCODL	DHENKAN	DED	GONDIA	JORANDA	14188	11 KV KARAMUL	14188203	AMBAPADA STAND	4122DT112	100	MIXED	AMI	Yes	0%	41	0.01584128	0.011365	0.00447628	28.26%
7452	TPCODL	DHENKAN	DED	GONDIA	JORANDA	14188	11 KV KARAMUL	14188203	KARAMULA BUS STAND	4122DT119	100	MIXED	AMI	Yes	67%	54	0.02448814	0.015317	0.00917114	37.45%
7453	TPCODL	DHENKAN	DED	GONDIA	JORANDA	14188	11 KV KARAMUL	14188203	MAKUNDAPUR TALA SAHI	4122DT300	100	MIXED	AMI	Yes	100%	100	0.04208622	0.025334	0.01675222	39.80%
7454	TPCODL	DHENKAN	DED	GONDIA	KAIMATIA ODSSP	14301	11 KV SALAPADA	14301201	RIA	4123DT353	100	MIXED	AMI	Yes	67%	96	0.04770926	0.015762	0.03194726	66.96%
7455	TPCODL	DHENKAN	DED	GONDIA	KAIMATIA ODSSP	14301	11 KV SALAPADA	14301201	LETHAKA 3	4123DT360	100	MIXED	AMI	Yes	67%	120	0.05047048	0.03123	0.01924048	38.12%
7456	TPCODL	DHENKAN	DED	GONDIA	MANDAR (SADANGI	14320	11 KV PINGUA	14320201	CHITALPUR OLIC	4121DT442	100	MIXED	AMI	Yes	67%	115	0.0359434	0.02563424	0.01030916	28.68%
7457	TPCODL	DHENKAN	DED	GONDIA	MANDAR (SADANGI	14320	11 KV PINGUA	14320201	RAMSUDAPATNA 2	4123DT007	100	MIXED	AMI	Yes	33%	122	0.04775014	0.02797215	0.01977799	41.42%
7458	TPCODL	DHENKAN	DED	GONDIA	MANDAR (SADANGI	14320	11 KV PINGUA	14320201	GAHAMAKHALA	4123DT010	100	MIXED	AMI	Yes	0%	45	0.0331778	0.013284	0.0198938	59.96%
7459	TPCODL	DHENKAN	DED	GONDIA	MANDAR (SADANGI	14320	11 KV PINGUA	14320201	NUAGADA	4123DT018	100	MIXED	AMI	Yes	67%	93	0.064928	0.022347	0.042581	65.58%
7460	TPCODL	DHENKAN	DED	GONDIA	MANDAR (SADANGI	14320	11 KV SADANGI	14320202	JHANADA 3	4121DT139	100	MIXED	AMI	Yes	67%	91	0.0377842	0.03247	0.0053142	14.06%
7461	TPCODL	DHENKAN	DED	GONDIA	MANDAR (SADANGI	14320	11 KV SADANGI	14320202	JHANADA 4	4121DT140	100	MIXED	AMI	Yes	67%	78	0.0394192	0.028048	0.0113712	28.85%
7462	TPCODL	DHENKAN	DED	GONDIA	MANDAR (SADANGI	14320	11 KV SADANGI	14320202	SADANGI 2	4121DT446	100	MIXED	AMI	Yes	67%	144	0.03420226	0.02689476	0.0073075	21.37%
7463	TPCODL	DHENKAN	DED	GONDIA	MANDAR (SADANGI	14320	11 KV MANDAR	14320203	MANDAR 1	4121DT416	100	MIXED	AMI	Yes	67%	99	0.04426464	0.02560895	0.01865569	42.15%
7464	TPCODL	DHENKAN	DED	GONDIA	MANDAR (SADANGI	14320	11 KV MANDAR	14320203	DALLAR 2	4121DT431	100	MIXED	AMI	Yes	33%	68	0.02243092	0.01564431	0.00678661	30.26%
7465	TPCODL	DHENKAN	DED	GONDIA	MANDAR (SADANGI	14320	11 KV MANDAR	14320203	NABALINGA	4121DT434	100	MIXED	AMI	Yes	33%	67	0.01445096	0.01034815	0.00410281	28.39%
7466	TPCODL	DHENKAN	DED	GONDIA	NIHALPRASAD	14190	11 KV Nihalprasad	14190201	LAULAI	4123DT091	100	MIXED	AMI	Yes	33%	60	0.06416832	0.013356	0.05081232	79.19%
7467	TPCODL	DHENKAN	DED	GONDIA	NIHALPRASAD	14190	11 KV Nihalprasad	14190201	NABALAULAI	4123DT100	100	MIXED	AMI	Yes	0%	73	0.04199866	0.017598	0.02440066	58.10%
7468	TPCODL	DHENKAN	DED	GONDIA	NIHALPRASAD	14190	11 KV Nihalprasad	14190201	KHANKIRA 2	4123DT108	100	MIXED	AMI	Yes	67%	75	0.03229566	0.021954	0.01034166	32.02%
7469	TPCODL	DHENKAN	DED	GONDIA	NIHALPRASAD	14190	11 KV Nihalprasad	14190201	PANCHAKENDU	4123DT121	100	MIXED	AMI	Yes	33%	114	0.06895132	0.026093	0.04285832	62.16%
7470	TPCODL	DHENKAN	DED	GONDIA	NIHALPRASAD	14190	11 KV Nihalprasad	14190201	SOLAGADIA 2	4123DT133	100	MIXED	AMI	Yes	33%	81	0.03558734	0.024539	0.01104834	31.05%
7471	TPCODL	DHENKAN	DED	GONDIA	NIHALPRASAD	14190	11 KV Nihalprasad	14190201	RATANPUR 4	4123DT142	100	MIXED	AMI	Yes	33%	69	0.04262974	0.014921	0.02770874	65.00%
7472	TPCODL	DHENKAN	DED	GONDIA	NIHALPRASAD	14190	11 KV Kasipur	14190202	KASHIPUR 2	4123DT224	63	MIXED	AMI	Yes	67%	72	0.02066602	0.015794	0.00487202	23.58%
7473	TPCODL	DHENKAN	DED	GONDIA	NIHALPRASAD	14190	11 KV Kasipur	14190202	KASHIPUR 3	4123DT231	100	MIXED	AMI	Yes	0%	66	0.01447092	0.01311649	0.00135443	9.36%
7474	TPCODL	DHENKAN	DED	GONDIA	NIHALPRASAD	14190	11 KV Kasipur	14190202	BHALIAPAT 2	4123DT241	100	MIXED	AMI	Yes	100%	61	0.02051234	0.009825	0.01068734	52.10%
7475	TPCODL	DHENKAN	DED	GONDIA	NIHALPRASAD	14190	11 KV Kasipur	14190202	LAHADA 2	4123DT247	100	MIXED	AMI	Yes	67%	66	0.04358896	0.01777731	0.02581165	59.22%
7476	TPCODL	DHENKAN	DED	GONDIA	NIHALPRASAD	14190	11 KV Kasipur	14190202	DIGAMBERPUR 2	4123DT254	100	MIXED	AMI	Yes	67%	98	0.03659232	0.025385	0.01120732	30.63%
7477	TPCODL	DHENKAN	DED	GONDIA	NIHALPRASAD	14190	11 KV Kasipur	14190202	KALYAN MANDAP (PINGUA)	4123DT283	100	MIXED	AMI	Yes	33%	167	0.08317002	0.059648	0.02352202	28.28%
7478	TPCODL	DHENKAN	DED	GONDIA	NIHALPRASAD	14190	11 KV Kasipur	14190202	PINGUA (MAJHI SAHI)	4123DT288	100	MIXED	AMI	Yes	33%	34	0.04256924	0.009855	0.03271424	76.85%
7479	TPCODL	DHENKAN	DED	GONDIA	NIHALPRASAD	14190	11 KV Kasipur	14190202	MANJURIAPADA 2	4123DT298	100	MIXED	AMI	Yes	33%	95	0.06265388	0.027442	0.03521188	56.20%
7480	TPCODL	DHENKAN	DED	GONDIA	NIHALPRASAD	14190	11 KV Kasipur	14190202	PINGUA (BRAHMAN SAHI) 1	4123DT305	250	MIXED	AMI	Yes	33%	113	0.03549028	0.03374	0.00175028	4.93%
7481	TPCODL	DHENKAN	DED	GONDIA	NIHALPRASAD	14190	11 KV Kasipur	14190202	PINGUA (TALA SAHI) 1	4123DT313	100	MIXED	AMI	Yes	33%	47	0.02537002	0.014665	0.01070502	42.20%
7482	TPCODL	DHENKAN	DED	GONDIA	NIHALPRASAD	14190	11 KV Kasipur	14190202	PINGUA (TALA SAHI) 2	4123DT314	100	MIXED	AMI	Yes	0%	80	0.04500736	0.02345	0.02155736	47.90%
7483	TPCODL	DHENKAN	DED	GONDIA	NIHALPRASAD	14190	11 KV Kasipur	14190202	GOPALPUR	4123DT328	250	MIXED	AMI	Yes	0%	109	0.08570048	0.034085	0.05161548	60.23%
7484	TPCODL	DHENKAN	DED	GONDIA	NIHALPRASAD	14190	11 KV Kasipur	14190202	PURUNAAMANGA (NEAR MANGALA)	4123DT331	100	MIXED	AMI	Yes	0%	111	0.03591654	0.024211	0.01170554	32.59%
7485	TPCODL	DHENKAN	DED	GONDIA	NIHALPRASAD	14190	11 KV Kasipur	14190202	GOPALPUR 1	4123DT340	100	MIXED	AMI	Yes	0%	85	0.03127054	0.01812186	0.01314868	42.05%
7486	TPCODL	DHENKAN	DED	HINDOL ROAD	MERAMUNDALI OD	14330	11 KV KAMALANGA	14330202	UPERPAL	4132DT004	100	MIXED	AMI	Yes	100%	60	0.0311931	0.019517	0.0116761	37.43%
7487	TPCODL	DHENKAN	DED	HINDOL ROAD	HINDOL ROAD	14121	11 kV BADALO	14121203	GHODADINA VILLAGE_02	4132DT235	100	MIXED	AMI	Yes	100%	127	0.04160002	0.030198	0.01140202	27.41%
7488	TPCODL	DHENKAN	DED	HINDOL ROAD	KHAJURIAKATA	14122	11 kV Rasol	14122201	KUKUTA CHHAK	4133DT451	250	MIXED	AMI	Yes	0%	85	0.08950188	0.05285	0.03665188	40.95%
7489	TPCODL	DHENKAN	DED	HINDOL ROAD	BADALU (PADA) OD	14323	11 KV KURUMITHA	14323201	PADA VILLAGE	4131DT308	100	MIXED	AMI	Yes	100%	144	0.04494326	0.035202	0.00974126	21.67%
7490	TPCODL	DHENKAN	DED	HINDOL ROAD	BADALU (PADA) OD	14323	11 KV KURUMITHA	14323201	BALASAR	4131DT332	100	MIXED	AMI	Yes	0%	54	0.01221734	0.007056	0.00516134	42.25%
7491	TPCODL	DHENKAN	DED	HINDOL ROAD	BADALU (PADA) OD	14323	11 KV KURUMITHA	14323201	ISWARPUR 1	4131DT344	100	MIXED	AMI	Yes	0%	14	0.0100584	0.003217	0.0068414	68.02%
7492	TPCODL	DHENKAN	DED	HINDOL ROAD	BADALU (PADA) OD	14323	11 KV PATALA	14323203	DUDURKOTE NUA SAHI	4131DT396	100	MIXED	AMI	Yes	67%	87	0.0351908	0.023457	0.0117338	33.34%
7493	TPCODL	DHENKAN	DED	HINDOL ROAD	BADALU (PADA) OD	14323	11 KV PATALA	14323203	DUDURKOTE PATNA SAHI	4131DT407	100	MIXED	AMI	Yes	0%	138	0.07645934	0.050993	0.02546634	33.31%
7494	TPCODL	DHENKAN	DED	HINDOL ROAD	BADALU (PADA) OD	14323	11 KV PATALA	14323203	DUDURKOTE BARA SAHI 1	4131DT412	63	MIXED	AMI	Yes	67%	66	0.02128494	0.01778	0.00350494	16.47%
7495	TPCODL	DHENKAN	DED	HINDOL ROAD	BADALU (PADA) OD	14323	11 KV PATALA	14323203	MANPUR	4131DT433	100	MIXED	AMI	Yes	67%	96	0.03322707	0.02723	0.00599707	18.05%
7496	TPCODL	DHENKAN	DED	HINDOL ROAD	BADALU (PADA) OD	14323	11 KV PATALA	14323203	KUMURSINGA 2	4131DT441	100	MIXED	AMI	Yes	67%	114	0.03679178	0.01904794	0.01774384	48.23%
7497	TPCODL	DHENKAN	DED	HINDOL ROAD	BALIAPANDA	14066	11 KV 11kV Prachi OH	14066204	KRISHNA SEA SIGHT	2411DT104	500	MIXED	AMI	Yes	100%	289	0.19182576	0.116952	0.07487376	39.03%
7498	TPCODL	DHENKAN	DED	HINDOL ROAD	BHAPUR	14119	11 KV GHATIPIRI	14119202	KAKUDIBHAG -2	4111DT251	100	MIXED	AMI	Yes	67%	124	0.03493498	0.025185	0.00974998	27.91%
7499	TPCODL	DHENKAN	DED	HINDOL ROAD	BHUBAN	14129	11 KV Bhuban Town-1A	14129202	SASAN	4141DT281	250	MIXED	AMI	Yes	100%	118	0.1617184	0.042759	0.1189594	73.56%
7500	TPCODL	DHENKAN	DED	HINDOL ROAD	HINDOL	14123	11 KV Hindol	14123201	BANAMALIPUR 1	4131DT136	250	MIXED	AMI	Yes	67%	305	0.14299532	0.09321	0.04978532	34.82%
7501	TPCODL	DHENKAN	DED	HINDOL ROAD	HINDOL	14123	11 KV Hindol	14123201	GOBINDA BERENI	4131DT138	100	MIXED	AMI	Yes	67%	141	0.04016066	0.028954	0.01120666	27.90%
7502	TPCODL	DHENKAN	DED	HINDOL ROAD	HINDOL	14123	11 KV Hindol	14123201	SRADHAPUR	4131DT140	250	MIXED	AMI	Yes	67%	150	0.06016528	0.040814	0.01935128	32.16%
7503	TPCODL	DHENKAN	DED	HINDOL ROAD	HINDOL	14123	11 KV Hindol	14123201	HINDOL AMLAPADA-2	4131DT165	100	MIXED	AMI	Yes	0%	85	0.0970796	0.061425	0.0356546	36.73%
7504	TPCODL	DHENKAN	DED	HINDOL ROAD	HINDOL	14123	11 KV Hindol	14123201	HINDOL HARIHATA	4131DT171	100	MIXED	AMI	Yes	0%	23	0.0257887	0.013736	0.0120527	46.74%
7505	TPCODL	DHENKAN	DED	HINDOL ROAD	HINDOL	14123	11 KV Hindol	14123201	RADHANATHPUR	4131DT183	100	MIXED	AMI	Yes	67%	142	0.04884911	0.021284	0.02756511	56.43%
7506	TPCODL	DHENKAN	DED	HINDOL ROAD	HINDOL	14123	11 KV Hindol	14123201	BARDAPAL 2	4131DT223	100	MIXED	AMI	Yes	33%	112	0.02099824	0.013514	0.00748424	35.64%
7507	TPCODL	DHENKAN	DED	HINDOL ROAD	HINDOL	14123	11 KV Hindol	14123201	B GP HIGH SCHOOL SUNDARAPAL	4131DT225	100	MIXED	AMI	Yes	0%	19	0.00690894	0.00395	0.00295894	42.83%
7508	TPCODL	DHENKAN	DED	HINDOL ROAD	HINDOL	14123	11 KV Hindol	14123201	KANTAMILA UP SCHOOL	4131DT256	100	MIXED	AMI	Yes	0%	91	0.02947016	0.018222	0.01124816	38.17%
7509	TPCODL	DHENKAN	DED	HINDOL ROAD	HINDOL	14123	11 KV Hindol	14123201	MAHIDHARPUR BAZAR	4131DT275	100	MIXED	AMI	Yes	0%	83	0.1065331	0.042603	0.0639301	60.01%
7510	TPCODL	DHENKAN	DED	HINDOL ROAD	HINDOL	14123	11 KV Hindol	14123201	AMCTHI (NALA)	4131DT278	100	MIXED	AMI	Yes	67%	46	0.03095518	0.029653	0.00130218	4.21%
7511	TPCODL	DHENKAN	DED	HINDOL ROAD	HINDOL	14123	11 KV Hindol	14123201	KHANDANALI VILLAGE 2	4131DT282	100	MIXED	AMI	Yes	67%	65	0.06232634	0.027462	0.03486434	55.94%
7512	TPCODL	DHENKAN	DED	HINDOL ROAD	HINDOL	14123	11 KV Hindol	14123201	AMBITHI	4131DT284	100	MIXED	AMI	Yes	100%	38	0.03141563	0.010557	0.02085863	66.40%
7513	TPCODL	DHENKAN	DED	HINDOL ROAD	HINDOL	14123	11 KV Hindol	14123201	PATNA HATA CHHAK-2	4131DT504	100	MIXED	AMI	Yes	67%	104	0.05312366	0.040226	0.01289766	24.28%
7514	TPCODL	DHENKAN	DED	HINDOL ROAD	HINDOL	14123	11 KV Dudurkot	14123202	RAJMOHANPUR VILLAGE	4131DT041	100	MIXED	AMI	Yes	67%	100	0.02971956	0.022124	0.00759556	25.56%
7515	TPCODL	DHENKAN	DED	HINDOL ROAD	HINDOL ROAD	14121	11 KV TOWN (H.ROAD)	14121201	COLD STORE_01	4132DT021	250	MIXED	AMI	Yes	0%	163	0.1486016	0.132761	0.0158406	10.66%
7516	TPCODL	DHENKAN	DED	HINDOL ROAD	HINDOL ROAD	14121	11 KV TOWN (H.ROAD)	14121201	NUA BANGURSINGH	4132DT029	100	MIXED	AMI	Yes	0%	131	0.09817296	0.064357	0.03381596	34.45%
7517	TPCODL	DHENKAN	DED	HINDOL ROAD	HINDOL ROAD	14121	11 KV TOWN (H.ROAD)	14121201	ODAPADA TEACHERS COLONY	4132DT036	100	MIXED	AMI	Yes	0%	22	0.03946062	0.023124	0.01633662	41.40%
7518	TPCODL	DHENKAN	DED	HINDOL ROAD	HINDOL ROAD	14121	11 KV TOWN (H.ROAD)	14121201	ODAPADA PALA MANDAP	4132DT061	100	MIXED	AMI	Yes	0%	66	0.05060914	0.034537	0.01607214	31.76%

Sl. No.	Zone Name	Circle name	Division name	Name of the Sub-division	Name of the Sub-station	Substation Code	Name of the 11 kV Feeder	Feeder Code	Name of the Location where DT situated	DT code	DT Capacity (kVA)	Predominant consumer type of DT (Domestic/Industrial/Agriculture/Mixed)	Type of metering AMR/AMI/ Communicable/Conventional metered/Unmetered	Status of Meter- whether Functional (Yes/No)	% of data received automatically (if AMR/AMI)	No. of Connected Consumers	Input Energy (MU) (A)	Billed Energy (MU) (B)	Loss (MU) (A-B)	% DT Loss (A-B)/A
7519	TPCODL	DHENKAN	DED	HINDOL ROAD	HINDOL ROAD	14121	11 KV NIMIDHA	14121202	KHAMAN PADIA	4132DT106	250	MIXED	AMI	Yes	0%	155	0.19265408	0.104509	0.08814508	45.75%
7520	TPCODL	DHENKAN	DED	HINDOL ROAD	HINDOL ROAD	14121	11 KV NIMIDHA	14121202	UPER BAGHA LUNDA_02	4132DT133	100	MIXED	AMI	Yes	0%	157	0.05485766	0.040938	0.01391966	25.37%
7521	TPCODL	DHENKAN	DED	HINDOL ROAD	HINDOL ROAD	14121	11 KV NIMIDHA	14121202	DHALAPUR_02	4132DT137	100	MIXED	AMI	Yes	0%	66	0.05422594	0.043085	0.01114094	20.55%
7522	TPCODL	DHENKAN	DED	HINDOL ROAD	HINDOL ROAD	14121	11 KV NIMIDHA	14121202	JHARANA BAHALI_01	4132DT140	100	MIXED	AMI	Yes	100%	46	0.03145712	0.015417	0.01604012	50.99%
7523	TPCODL	DHENKAN	DED	HINDOL ROAD	HINDOL ROAD	14121	11 KV NIMIDHA	14121202	SSS MAHAVIDYALY	4132DT142	100	MIXED	AMI	Yes	0%	12	0.00564248	0.002305	0.00333748	59.15%
7524	TPCODL	DHENKAN	DED	HINDOL ROAD	HINDOL ROAD	14121	11 KV NIMIDHA	14121202	BADA RANI BANIA	4132DT153	100	MIXED	AMI	Yes	0%	115	0.05550218	0.032394	0.02310818	41.63%
7525	TPCODL	DHENKAN	DED	HINDOL ROAD	HINDOL ROAD	14121	11 KV NIMIDHA	14121202	GOPALPUR_01	4132DT155	100	MIXED	AMI	Yes	0%	91	0.0354091	0.0239	0.0115091	32.50%
7526	TPCODL	DHENKAN	DED	HINDOL ROAD	HINDOL ROAD	14121	11 KV NIMIDHA	14121202	GOPALPUR_02 (BISWANATHPUR)	4132DT157	100	MIXED	AMI	Yes	0%	70	0.03406984	0.017192	0.01687784	49.54%
7527	TPCODL	DHENKAN	DED	HINDOL ROAD	HINDOL ROAD	14121	11 KV NIMIDHA	14121202	BALIRATNAPUR_02	4132DT164	100	MIXED	AMI	Yes	0%	44	0.04689064	0.012672	0.03421864	72.98%
7528	TPCODL	DHENKAN	DED	HINDOL ROAD	HINDOL ROAD	14121	11 KV NIMIDHA	14121202	NIMIDHA	4132DT166	100	MIXED	AMI	Yes	67%	69	0.02809238	0.019822	0.00827038	29.44%
7529	TPCODL	DHENKAN	DED	HINDOL ROAD	HINDOL ROAD	14121	11 KV NIMIDHA	14121202	NIMIDHA VILLAGE_01	4132DT168	100	MIXED	AMI	Yes	67%	114	0.0287723	0.023753	0.0050193	17.44%
7530	TPCODL	DHENKAN	DED	HINDOL ROAD	HINDOL ROAD	14121	11 KV NIMIDHA	14121202	NIMIDHA VILLAGE_02	4132DT169	100	MIXED	AMI	Yes	67%	70	0.0229105	0.012109	0.0108015	47.15%
7531	TPCODL	DHENKAN	DED	HINDOL ROAD	HINDOL ROAD	14121	11 KV NIMIDHA	14121202	MATHA SAHI_01	4132DT175	100	MIXED	AMI	Yes	100%	50	0.01627464	0.01377134	0.0025033	15.38%
7532	TPCODL	DHENKAN	DED	HINDOL ROAD	HINDOL ROAD	14121	11 KV BADALO	14121203	SIRIDI VILLAGE_01	4132DT222	100	MIXED	AMI	Yes	0%	118	0.04018988	0.028144	0.01204588	29.97%
7533	TPCODL	DHENKAN	DED	HINDOL ROAD	HINDOL ROAD	14121	11 KV BADALO	14121203	BACHUR?BANKA_01	4132DT227	100	MIXED	AMI	Yes	100%	73	0.01805892	0.011111	0.00694792	38.47%
7534	TPCODL	DHENKAN	DED	HINDOL ROAD	HINDOL ROAD	14121	11 KV BADALO	14121203	BACHUR?BANKA_02	4132DT228	100	MIXED	AMI	Yes	0%	42	0.03991628	0.011716	0.02820028	70.65%
7535	TPCODL	DHENKAN	DED	HINDOL ROAD	HINDOL ROAD	14121	11 KV BADALO	14121203	GHODADINA VILLAGE_01	4132DT234	100	MIXED	AMI	Yes	0%	87	0.06344988	0.025654	0.03779588	59.57%
7536	TPCODL	DHENKAN	DED	HINDOL ROAD	HINDOL ROAD	14121	11 KV BADALO	14121203	GHODADINA VILLAGE_03	4132DT237	100	MIXED	AMI	Yes	100%	46	0.02556814	0.011547	0.01402114	54.84%
7537	TPCODL	DHENKAN	DED	HINDOL ROAD	HINDOL ROAD	14121	11 KV BADALO	14121203	BADALU_03	4132DT298	100	MIXED	AMI	Yes	100%	86	0.03248664	0.022295	0.01019164	31.37%
7538	TPCODL	DHENKAN	DED	HINDOL ROAD	HINDOL ROAD	14121	11 KV 4 POLE	14121204	GUNADEI-1	4132DT185	100	MIXED	AMI	Yes	0%	92	0.0499857	0.025119	0.0248667	49.75%
7539	TPCODL	DHENKAN	DED	HINDOL ROAD	HINDOL ROAD	14121	11 KV 4 POLE	14121204	MAHADIA UPER SAHI-2	4132DT189	100	MIXED	AMI	Yes	67%	80	0.06549304	0.028657	0.03683604	56.24%
7540	TPCODL	DHENKAN	DED	HINDOL ROAD	HINDOL ROAD	14121	11 KV 4 POLE	14121204	BANGURSINGH CHASA SAHI	4132DT353	100	MIXED	AMI	Yes	0%	79	0.02839362	0.027163	0.00123062	4.33%
7541	TPCODL	DHENKAN	DED	HINDOL ROAD	HINDOL ROAD	14121	11 KV 4 POLE	14121204	EKAGHARIA-1	4132DT370	100	MIXED	AMI	Yes	100%	102	0.0718018	0.024988	0.0468138	65.20%
7542	TPCODL	DHENKAN	DED	HINDOL ROAD	HINDOL ROAD	14121	11 KV 4 POLE	14121204	EKAGHARIA-2	4132DT376	100	MIXED	AMI	Yes	100%	100	0.05231562	0.024595	0.02772062	52.99%
7543	TPCODL	DHENKAN	DED	HINDOL ROAD	KALIAPANI	14130	11 KV CHINGUDIPALA	14130202	KAMPULAI(DEHURY SAHI)	4143DT178	100	MIXED	AMI	Yes	33%	59	0.00789296	0.005793	0.00209996	26.61%
7544	TPCODL	DHENKAN	DED	HINDOL ROAD	KHAJURIAKATA	14122	11 KV RASOLA	14122201	NEAR STATE BANK	4133DT453	100	MIXED	AMI	Yes	0%	62	0.09544396	0.059667	0.03577696	37.48%
7545	TPCODL	DHENKAN	DED	HINDOL ROAD	KHAJURIAKATA	14122	11 KV RASOLA	14122201	SISHUMANDIR-1	4133DT460	100	MIXED	AMI	Yes	100%	83	0.09407206	0.049239	0.04483306	47.66%
7546	TPCODL	DHENKAN	DED	HINDOL ROAD	KHAJURIAKATA	14122	11 KV RASOLA	14122201	SANA HINDOL 1	4133DT464	100	MIXED	AMI	Yes	100%	87	0.02429042	0.021017	0.00327342	13.48%
7547	TPCODL	DHENKAN	DED	HINDOL ROAD	KHAJURIAKATA	14122	11 KV RASOLA	14122201	NANDAPUR 1	4133DT469	100	MIXED	AMI	Yes	100%	69	0.03807806	0.015233	0.02284506	60.00%
7548	TPCODL	DHENKAN	DED	HINDOL ROAD	KHAJURIAKATA	14122	11 KV RASOLA	14122201	SATAMAILI IB	4133DT476	100	MIXED	AMI	Yes	100%	48	0.0391118	0.028876	0.0102358	26.17%
7549	TPCODL	DHENKAN	DED	HINDOL ROAD	KHAJURIAKATA	14122	11 KV RASOLA	14122201	PANCHUPADA UP SCHOOL	4133DT485	100	MIXED	AMI	Yes	100%	146	0.05472744	0.049996	0.00473144	8.65%
7550	TPCODL	DHENKAN	DED	HINDOL ROAD	KHAJURIAKATA	14122	11 KV Bedapada-1	14122202	BALIMI VILLAGE 1	4133DT523	100	MIXED	AMI	Yes	0%	101	0.05433846	0.032048	0.02229046	41.02%
7551	TPCODL	DHENKAN	DED	HINDOL ROAD	KHAJURIAKATA	14122	11 KV Bedapada-1	14122202	KARANDA SANA SAHI-2	4133DT558	100	MIXED	AMI	Yes	67%	42	0.026075	0.007076	0.018999	72.86%
7552	TPCODL	DHENKAN	DED	HINDOL ROAD	KHAJURIAKATA	14122	11 KV Bedapada-1	14122202	GIRIDHAR PRASAD 2	4133DT574	100	MIXED	AMI	Yes	0%	94	0.04689656	0.019898	0.02699856	57.57%
7553	TPCODL	DHENKAN	DED	HINDOL ROAD	KHAJURIAKATA	14122	11 KV Bedapada-1	14122202	BABANDHA RAM MONDIR 2	4133DT617	63	MIXED	AMI	Yes	33%	62	0.01812836	0.011627	0.00650136	35.86%
7554	TPCODL	DHENKAN	DED	HINDOL ROAD	KHAJURIAKATA	14122	11 KV Bedapada-1	14122202	BABANDHA PANCHAYAT OFFICE	4133DT628	100	MIXED	AMI	Yes	67%	142	0.0515803	0.04296684	0.00861346	16.70%
7555	TPCODL	DHENKAN	DED	HINDOL ROAD	KHAJURIAKATA	14122	11 KV Bedapada-1	14122202	KARANDA BADA SAHI 2	4133DT660	100	MIXED	AMI	Yes	100%	102	0.03472524	0.019187	0.01553824	44.75%
7556	TPCODL	DHENKAN	DED	HINDOL ROAD	KHAJURIAKATA	14122	11 KV Bedapada-1	14122202	KARANDA SIJUBANIA	4133DT666	100	MIXED	AMI	Yes	67%	123	0.0577556	0.043744	0.0140116	24.26%
7557	TPCODL	DHENKAN	DED	HINDOL ROAD	KHAJURIAKATA	14122	11 KV Bedapada-1	14122202	BEDAPADA KHATAKHURIA	4133DT702	100	MIXED	AMI	Yes	67%	171	0.0568745	0.035664	0.0212105	37.29%
7558	TPCODL	DHENKAN	DED	HINDOL ROAD	KHAJURIAKATA	14122	11 KV Bedapada-1	14122202	THAKOR USTA SAHI 1	4133DT711	100	MIXED	AMI	Yes	67%	90	0.03608816	0.018655	0.01743316	48.31%
7559	TPCODL	DHENKAN	DED	HINDOL ROAD	KHAJURIAKATA	14122	11 KV Bedapada-1	14122202	NUA 1	4133DT712	100	MIXED	AMI	Yes	67%	89	0.02126628	0.016506	0.00476028	22.38%
7560	TPCODL	DHENKAN	DED	HINDOL ROAD	KHAJURIAKATA	14122	11 KV Bedapada-1	14122202	NUA	4133DT718	100	MIXED	AMI	Yes	0%	27	0.0194622	0.003944	0.0155182	79.74%
7561	TPCODL	DHENKAN	DED	HINDOL ROAD	KHAJURIAKATA	14122	11 KV Bedapada-1	14122202	RANJAGOLA MAHULBURI	4133DT721	100	MIXED	AMI	Yes	100%	34	0.02855626	0.018408	0.01014826	35.54%
7562	TPCODL	DHENKAN	DED	HINDOL ROAD	KHAJURIAKATA	14122	11 KV KALINGA	14122203	THENGA 1	4133DT366	100	MIXED	AMI	Yes	100%	48	0.01551988	0.014826	0.00069388	4.47%
7563	TPCODL	DHENKAN	DED	HINDOL ROAD	KHAJURIAKATA	14122	11 KV KALINGA	14122203	BALI KIARI 2	4133DT372	100	MIXED	AMI	Yes	100%	36	0.02557964	0.010029	0.01555064	60.79%
7564	TPCODL	DHENKAN	DED	HINDOL ROAD	KHAJURIAKATA	14122	11 KV KALINGA	14122203	CHOTAPADA	4133DT380	100	MIXED	AMI	Yes	100%	66	0.02552442	0.01987	0.00565442	22.15%
7565	TPCODL	DHENKAN	DED	HINDOL ROAD	KHAJURIAKATA	14122	11 KV KALINGA	14122203	CHITTALPUR GAJA BARANA	4133DT389	100	MIXED	AMI	Yes	100%	106	0.04917914	0.037326	0.01185314	24.10%
7566	TPCODL	DHENKAN	DED	HINDOL ROAD	KHAJURIAKATA	14122	11 KV KALINGA	14122203	KALINGA PANCHAYAT	4133DT407	100	MIXED	AMI	Yes	100%	109	0.04847696	0.03945	0.00902696	18.62%
7567	TPCODL	DHENKAN	DED	HINDOL ROAD	KHAJURIAKATA	14122	11 KV KALINGA	14122203	ANLABEDA 1	4133DT419	100	MIXED	AMI	Yes	100%	162	0.04647124	0.039408	0.00706324	15.20%
7568	TPCODL	DHENKAN	DED	HINDOL ROAD	KHAJURIAKATA	14122	11 KV KALINGA	14122203	BANKATIA 2	4133DT430	100	MIXED	AMI	Yes	100%	58	0.03714986	0.022865	0.01428486	38.45%
7569	TPCODL	DHENKAN	DED	HINDOL ROAD	KHAJURIAKATA	14122	11 KV Bedapada-2(Rasol	14122204	KUKUTA UPER SAHI	4133DT496	100	MIXED	AMI	Yes	100%	141	0.0457865	0.044256	0.0015305	3.34%
7570	TPCODL	DHENKAN	DED	HINDOL ROAD	MERAMUNDALI OD	14330	11 KV KAMALANGA	14330202	CHINTAPOKHARI-2	4132DT001	100	MIXED	AMI	Yes	100%	93	0.04280248	0.03157524	0.01122724	26.23%
7571	TPCODL	DHENKAN	DED	HINDOL ROAD	MERAMUNDALI OD	14330	11 KV KAMALANGA	14330202	CHINTAPOKHARI-1	4132DT002	100	MIXED	AMI	Yes	0%	99	0.0509545	0.042235	0.0087195	17.11%
7572	TPCODL	DHENKAN	DED	HINDOL ROAD	MUKTAPASI ODSSP	14316	11 KV Similia	14316203	SIMILIA SABAR SAHI	4113DT598	500	MIXED	AMI	Yes	100%	205	0.2168208	0.077811	0.1390098	64.11%
7573	TPCODL	DHENKAN	DED	HINDOL ROAD	NUABAG (KODIBHA	14321	11 KV NUABAG	14321201	NUAPATNA VILLAGE	4133DT001	100	MIXED	AMI	Yes	100%	175	0.0814062	0.060839	0.0205672	25.26%
7574	TPCODL	DHENKAN	DED	HINDOL ROAD	NUABAG (KODIBHA	14321	11 KV Rasol (Nuabag)	14321202	PARSHURAMPUR 1	4133DT085	500	MIXED	AMI	Yes	100%	278	0.239602	0.191851	0.047751	19.93%
7575	TPCODL	DHENKAN	DED	HINDOL ROAD	NUABAG (KODIBHA	14321	11 KV Rasol (Nuabag)	14321202	COLONY SAHI OLD	4133DT089	100	MIXED	AMI	Yes	67%	38	0.0293428	0.022207	0.0071358	24.32%
7576	TPCODL	DHENKAN	DED	HINDOL ROAD	NUABAG (KODIBHA	14321	11 KV Rasol (Nuabag)	14321202	RASOLA BAZAR	4133DT129	500	MIXED	AMI	Yes	67%	330	0.2374712	0.181543	0.0559282	23.55%
7577	TPCODL	DHENKAN	DED	HINDOL ROAD	NUABAG (KODIBHA	14321	11 KV NAUKIARI	14321203	NAUKIARI-1	4133DT192	100	MIXED	AMI	Yes	0%	112	0.04578754	0.030827	0.01496054	32.67%
7578	TPCODL	DHENKAN	DED	HINDOL ROAD	NUABAG (KODIBHA	14321	11 KV NAUKIARI	14321203	NAUKIARI-2	4133DT194	100	MIXED	AMI	Yes	67%	162	0.04032227	0.034558	0.00576427	14.30%
7579	TPCODL	DHENKAN	DED	HINDOL ROAD	NUABAG (KODIBHA	14321	11 KV NAUKIARI	14321203	KUNUA 5	4133DT204	100	MIXED	AMI	Yes	0%	65	0.0453352	0.019787	0.0255482	56.35%
7580	TPCODL	DHENKAN	DED	HINDOL ROAD	NUABAG (KODIBHA	14321	11 KV NAUKIARI	14321203	KUNUA 6	4133DT207	100	MIXED	AMI	Yes	100%	112	0.03745608	0.032842	0.00461408	12.32%
7581	TPCODL	DHENKAN	DED	K.NAGAR	BHUBAN	14129	11 kV BHUBAN TOWN-2	14129206	LATABILA _01	4141DT107	250	MIXED	AMI	Yes	100%	78	0.06030568	0.035503	0.02480268	41.13%
7582	TPCODL	DHENKAN	DED	K.NAGAR	BHUBAN	14129	11 kV Bhuban Town-1A	14129202	GODIPAKHARI_03	4141DT274	100	MIXED	AMI	Yes	0%	12	0.02222074	0.00914	0.01308074	58.87%
7583	TPCODL	DHENKAN	DED	K.NAGAR	MAHULPAL(BHUBAI	14315	11 kV EKATALI	14315202	ASHWINI BARAL (BALIBO)	4141DT523	100	MIXED	AMI	Yes	67%	68	0.04321294	0.022967	0.02024594	46.85%
7584	TPCODL	DHENKAN	DED	K.NAGAR	JIRAL ODSSP	14319	11 kV GUNEIEIBIL	14319202	SANTRAPUR_02	4145DT089	100	MIXED	AMI	Yes	0%	46	0.02731348	0.007734	0.01957948	71.68%
7585	TPCODL	DHENKAN	DED	K.NAGAR	DAHANABIL	14127	11 KV KANHEIPAL	14127202	KANHEIPALA_02	4145DT547	100	MIXED	AMI	Yes	0%	44	0.01833594	0.010123	0.00821294	44.79%
7586	TPCODL	DHENKAN	DED	K.NAGAR	BADASUANLA	14125	11 KV BIRASAL	14125202	BADASUANLO	4145DT011	250	MIXED	AMI	Yes	100%	96	0.09340324	0.0401944	0.05320884	56.97%
7587	TPCODL	DHENKAN	DED	K.NAGAR	BADASUANLA	14125	11 KV BIRASAL	14125202	ARACHUA_01	4145DT019	100	MIXED	AMI	Yes	100%	93	0.02822424	0.018949	0.00927524	32.86%
7588	TPCODL	DHENKAN	DED	K.NAGAR	BALIAPANDA	14066	11 KV 11kV Lokanath	14066201	SIDHA BINAYAK EXECUTIVE APARTMI	2411DT184	500	MIXED	AMI	Yes	100%	100	0.01281024	0.00872	0.00409024	31.93%
7589	TPCODL	DHENKAN	DED	K.NAGAR	BHUBAN	14129	11 KV Bhuban Town-1A	14129202	KHOLASAHI	4141DT191	100	MIXED	AMI	Yes	67%	124	0.07100724	0.053715	0.01729224	24.35%
7590	TPCODL	DHENKAN	DED	K.NAGAR	BHUBAN	14129	11 KV Bhuban Town-1A	14129202	COLD STORE (NUABHABAN)	4141DT194	250	MIXED	AMI	Yes	100%	90	0.09591084	0.060669	0.03524184	36.74%
7591	TPCODL	DHENKAN	DED	K.NAGAR	BHUBAN	14129	11 KV Bhuban Town-1A	14129202	SISHU MANDIRA_01	4141DT196	250	MIXED	AMI	Yes	100%	81	0.0766592	0.051823	0.0248362	32.40%

Sl. No.	Zone Name	Circle name	Division name	Name of the Sub-division	Name of the Sub-station	Substation Code	Name of the 11 kV Feeder	Feeder Code	Name of the Location where DT situated	DT code	DT Capacity (kVA)	Predominant consumer type of DT (Domestic/Industrial/Agriculture/Mixed)	Type of metering AMR/AMI/ Communicable/Conventional metered/Unmetered	Status of Meter-whether Functional (Yes/No)	% of data received automatically (if AMR/AMI)	No. of Connected Consumers	Input Energy (MU) (A)	Billed Energy (MU) (B)	Loss (MU) (A-B)	% DT Loss (A-B)/A
7592	TPCODL	DHENKAN	DED	K.NAGAR	BHUBAN	14129	11 KV Bhuban Town-1A	14129202	SISHU MANDIRA_02	4141DT197	250	MIXED	AMI	Yes	100%	78	0.08571444	0.043664	0.04205044	49.06%
7593	TPCODL	DHENKAN	DED	K.NAGAR	BHUBAN	14129	11 KV Bhuban Town-1A	14129202	NEAR BASANTI LODGE	4141DT201	250	MIXED	AMI	Yes	100%	55	0.09414376	0.055423	0.03872076	41.13%
7594	TPCODL	DHENKAN	DED	K.NAGAR	BHUBAN	14129	11 KV Bhuban Town-1A	14129202	NEAR VETENARY OFFICE_02	4141DT206	250	MIXED	AMI	Yes	100%	139	0.12333132	0.114119	0.00921232	7.47%
7595	TPCODL	DHENKAN	DED	K.NAGAR	BHUBAN	14129	11 KV Bhuban Town-1A	14129202	NEAR PETROL PUMP (COLLEGE ROAD	4141DT207	100	MIXED	AMI	Yes	0%	76	0.11476978	0.045661	0.06910878	60.22%
7596	TPCODL	DHENKAN	DED	K.NAGAR	BHUBAN	14129	11 KV Bhuban Town-1A	14129202	GUJUNIHATA	4141DT262	500	MIXED	AMI	Yes	100%	448	0.29087752	0.221038	0.06983952	24.01%
7597	TPCODL	DHENKAN	DED	K.NAGAR	BHUBAN	14129	11 KV Bhuban Town-1A	14129202	BHUBAN BAZAR	4141DT263	500	MIXED	AMI	Yes	100%	288	0.28346016	0.106488	0.17697216	62.43%
7598	TPCODL	DHENKAN	DED	K.NAGAR	BHUBAN	14129	11 KV Bhuban Town-1A	14129202	HANSI SAHI	4141DT266	250	MIXED	AMI	Yes	0%	151	0.07835216	0.075563	0.00278916	3.56%
7599	TPCODL	DHENKAN	DED	K.NAGAR	BHUBAN	14129	11 KV Bhuban Town-1A	14129202	ARASAHI	4141DT270	250	MIXED	AMI	Yes	67%	198	0.18142384	0.0932	0.08822384	48.63%
7600	TPCODL	DHENKAN	DED	K.NAGAR	BHUBAN	14129	11 KV Bhuban Town-1A	14129202	NEAR CINEMA HALL	4141DT271	500	MIXED	AMI	Yes	0%	132	0.2050288	0.102156	0.1028728	50.17%
7601	TPCODL	DHENKAN	DED	K.NAGAR	BHUBAN	14129	11 KV Bhuban Town-1A	14129202	GODIPAKHARI_01	4141DT272	250	MIXED	AMI	Yes	0%	123	0.17981136	0.056889	0.12292236	68.36%
7602	TPCODL	DHENKAN	DED	K.NAGAR	BHUBAN	14129	11 KV Bhuban Town-1A	14129202	GODIPAKHARI_02	4141DT273	250	MIXED	AMI	Yes	100%	159	0.11239072	0.056328	0.05606272	49.88%
7603	TPCODL	DHENKAN	DED	K.NAGAR	BHUBAN	14129	11 KV Bhuban Town-1A	14129202	BHUBAN (SASAN)_02	4141DT276	250	MIXED	AMI	Yes	100%	78	0.13475036	0.033517	0.10123336	75.13%
7604	TPCODL	DHENKAN	DED	K.NAGAR	BHUBAN	14129	11 KV Bhuban Town-1A	14129202	CDR	4141DT280	500	MIXED	AMI	Yes	0%	217	0.15365824	0.076856	0.07680224	49.98%
7605	TPCODL	DHENKAN	DED	K.NAGAR	BHUBAN	14129	11 KV Bhuban Town-1A	14129202	PRUSTY POKHARI _03	4141DT366	250	MIXED	AMI	Yes	100%	99	0.11445476	0.048323	0.06613176	57.78%
7606	TPCODL	DHENKAN	DED	K.NAGAR	BHUBAN	14129	11 KV Bhuban Town-1A	14129202	NUABHABAN MATHA _01	4141DT369	250	MIXED	AMI	Yes	100%	89	0.04949456	0.033893	0.01560156	31.52%
7607	TPCODL	DHENKAN	DED	K.NAGAR	BHUBAN	14129	11 KV Bhuban Town-1A	14129202	NUABHABAN MATHA _02	4141DT370	250	MIXED	AMI	Yes	100%	149	0.12431296	0.065872	0.05844096	47.01%
7608	TPCODL	DHENKAN	DED	K.NAGAR	BHUBAN	14129	11 KV BHUSAL	14129203	KINGOL_02	4141DT219	250	MIXED	AMI	Yes	0%	139	0.0653762	0.03946	0.0259162	39.64%
7609	TPCODL	DHENKAN	DED	K.NAGAR	BHUBAN	14129	11 KV BHUSAL	14129203	GANGA DAS MILL	4141DT223	100	MIXED	AMI	Yes	33%	55	0.04094592	0.022486	0.01845992	45.08%
7610	TPCODL	DHENKAN	DED	K.NAGAR	BHUBAN	14129	11 KV BHUSAL	14129203	KIRTANPUR_02	4141DT409	100	MIXED	AMI	Yes	100%	51	0.04012414	0.01452	0.02560414	63.81%
7611	TPCODL	DHENKAN	DED	K.NAGAR	BHUBAN	14129	11 KV Anantpur	14129204	GADGANPUR_01	4141DT050	100	MIXED	AMI	Yes	33%	113	0.09869828	0.043666	0.05503228	55.76%
7612	TPCODL	DHENKAN	DED	K.NAGAR	BHUBAN	14129	11 KV Anantpur	14129204	BAUNSHAKAR_02	4141DT074	100	MIXED	AMI	Yes	100%	20	0.00565808	0.003299	0.00235908	41.69%
7613	TPCODL	DHENKAN	DED	K.NAGAR	BHUBAN	14129	11 KV Anantpur	14129204	KANAKHAI_02	4141DT087	100	MIXED	AMI	Yes	100%	36	0.01181608	0.006448	0.00536808	45.43%
7614	TPCODL	DHENKAN	DED	K.NAGAR	BHUBAN	14129	11 KV Bhuban Town-2	14129206	LATABILA _02	4141DT108	100	MIXED	AMI	Yes	100%	91	0.0829283	0.043156	0.0397723	47.96%
7615	TPCODL	DHENKAN	DED	K.NAGAR	BHUBAN	14129	11 KV Bhuban Town-2	14129206	KHANDIABANDHA	4141DT118	500	MIXED	AMI	Yes	0%	474	0.42028336	0.147268	0.27301536	64.96%
7616	TPCODL	DHENKAN	DED	K.NAGAR	BHUBAN	14129	11 KV Bhuban Town-2	14129206	CHINERAPOKHARI	4141DT119	250	MIXED	AMI	Yes	0%	166	0.22841332	0.047529	0.18088432	79.19%
7617	TPCODL	DHENKAN	DED	K.NAGAR	BHUBAN	14129	11 KV Bhuban Town-2	14129206	MANIPURM.V	4141DT135	250	MIXED	AMI	Yes	0%	148	0.10269152	0.067246	0.03544552	34.52%
7618	TPCODL	DHENKAN	DED	K.NAGAR	BIRASAL (RAHANI) (	14324	11 KV BIRASAL	14324201	P.H.C BIRASAL	4144DT361	250	MIXED	AMI	Yes	67%	68	0.10123856	0.044691	0.05654756	55.86%
7619	TPCODL	DHENKAN	DED	K.NAGAR	BIRASAL (RAHANI) (	14324	11KV KHAJURIA	14324203	KHAJURIA MAHANTA SAHI	4144DT389	100	MIXED	AMI	Yes	33%	75	0.02425524	0.017398	0.00685724	28.27%
7620	TPCODL	DHENKAN	DED	K.NAGAR	BIRASAL (RAHANI) (	14324	11KV KHAJURIA	14324203	PATHARAKATA_03	4144DT462	250	MIXED	AMI	Yes	33%	95	0.04211104	0.023805	0.01830604	43.47%
7621	TPCODL	DHENKAN	DED	K.NAGAR	BIRASAL (RAHANI) (	14324	11KV KHAJURIA	14324203	MAKUAKATENI MAIN VILLAGE	4144DT487	250	MIXED	AMI	Yes	67%	120	0.08009412	0.037864	0.04223012	52.73%
7622	TPCODL	DHENKAN	DED	K.NAGAR	DAHANABIL	14127	11 KV SURAPRATAP	14127201	KUNDIGODA_02	4145DT494	250	MIXED	AMI	Yes	0%	150	0.05288896	0.040738	0.01215096	22.97%
7623	TPCODL	DHENKAN	DED	K.NAGAR	DAHANABIL	14127	11 KV KANHEIPAL	14127202	MATHANUA GAON_06	4145DT558	100	MIXED	AMI	Yes	0%	95	0.05310332	0.025379	0.02772432	52.21%
7624	TPCODL	DHENKAN	DED	K.NAGAR	DAHANABIL	14127	11 KV KANHEIPAL	14127202	KANHEIPALA_03	4145DT560	100	MIXED	AMI	Yes	33%	175	0.0939098	0.03095173	0.06295807	67.04%
7625	TPCODL	DHENKAN	DED	K.NAGAR	DAHANABIL	14127	11 KV KANHEIPAL	14127202	BAMUAN_02	4145DT575	100	MIXED	AMI	Yes	0%	48	0.05318766	0.012163	0.04102466	77.13%
7626	TPCODL	DHENKAN	DED	K.NAGAR	GODA	14128	11 KV Goda	14128201	PALASAPITHIA_01	4141DT292	100	MIXED	AMI	Yes	100%	46	0.05434836	0.020329	0.03401936	62.60%
7627	TPCODL	DHENKAN	DED	K.NAGAR	GODA	14128	11 KV BARUAN	14128202	BARUAN MAIN VILLAGE	4141DT435	250	MIXED	AMI	Yes	100%	101	0.08843484	0.031422	0.05701284	64.47%
7628	TPCODL	DHENKAN	DED	K.NAGAR	GODA	14128	11 KV BARUAN	14128202	MATHAKHOKOSA 2	4141DT453	100	MIXED	AMI	Yes	0%	69	0.05725664	0.012758	0.04449864	77.72%
7629	TPCODL	DHENKAN	DED	K.NAGAR	GODA	14128	11 KV BARUAN	14128202	ODISHA	4141DT459	250	MIXED	AMI	Yes	100%	87	0.09026144	0.021044	0.06921744	76.69%
7630	TPCODL	DHENKAN	DED	K.NAGAR	GODA	14128	11 KV BARUAN	14128202	ODISHA PATRA SAHI	4141DT466	100	MIXED	AMI	Yes	100%	60	0.0232801	0.014539	0.0087411	37.55%
7631	TPCODL	DHENKAN	DED	K.NAGAR	GODA	14128	11 KV BARUAN	14128202	ANALA PURUNA SAHI	4141DT473	100	MIXED	AMI	Yes	100%	51	0.04284234	0.01671	0.02613234	61.00%
7632	TPCODL	DHENKAN	DED	K.NAGAR	GODA	14128	11 KV BARUAN	14128202	ANALA	4141DT475	100	MIXED	AMI	Yes	100%	85	0.06447314	0.029255	0.03521814	54.62%
7633	TPCODL	DHENKAN	DED	K.NAGAR	GODA	14128	11 KV BARUAN	14128202	ANALA JAGANNATH SAHI	4141DT476	250	MIXED	AMI	Yes	100%	60	0.08536224	0.022349	0.06301324	73.82%
7634	TPCODL	DHENKAN	DED	K.NAGAR	GODA	14128	11 KV BARUAN	14128202	ANALA PARIDA SHAI 2	4141DT481	100	MIXED	AMI	Yes	100%	61	0.07109706	0.019409	0.05168806	72.70%
7635	TPCODL	DHENKAN	DED	K.NAGAR	GODA	14128	11 KV BARUAN	14128202	ANALA JATRA PADIA	4141DT483	100	MIXED	AMI	Yes	100%	42	0.03488786	0.015358	0.01952986	55.98%
7636	TPCODL	DHENKAN	DED	K.NAGAR	GODA	14128	11 KV Dhalpada	14128203	DHALAPADA 2	4141DT318	100	MIXED	AMI	Yes	67%	35	0.03585484	0.014906	0.02094884	58.43%
7637	TPCODL	DHENKAN	DED	K.NAGAR	GODA	14128	11 KV Dhalpada	14128203	DHALAPADA 3	4141DT319	100	MIXED	AMI	Yes	67%	53	0.0450774	0.014986	0.0300914	66.75%
7638	TPCODL	DHENKAN	DED	K.NAGAR	GODA	14128	11 KV Dhalpada	14128203	KUNIDA 2	4141DT343	100	MIXED	AMI	Yes	67%	56	0.0555586	0.015025	0.0405336	72.96%
7639	TPCODL	DHENKAN	DED	K.NAGAR	GODA	14128	11 KV Dhalpada	14128203	R. PATNA 1	4141DT346	100	MIXED	AMI	Yes	33%	60	0.05207538	0.017785	0.03429038	65.85%
7640	TPCODL	DHENKAN	DED	K.NAGAR	GODA	14128	11 KV Dhalpada	14128203	R. PATNA 2	4141DT347	100	MIXED	AMI	Yes	67%	82	0.06376068	0.025224	0.03853668	60.44%
7641	TPCODL	DHENKAN	DED	K.NAGAR	GODA	14128	11 KV Dhalpada	14128203	DENGABAHALI 3	4141DT382	100	MIXED	AMI	Yes	67%	17	0.00507624	0.00408	0.00099624	19.63%
7642	TPCODL	DHENKAN	DED	K.NAGAR	GODA	14128	11 KV Dhalpada	14128203	SAMAL CHHAKA 1	4141DT392	100	MIXED	AMI	Yes	67%	11	0.02391298	0.008325	0.01558798	65.19%
7643	TPCODL	DHENKAN	DED	K.NAGAR	GUNDICHAPADA	14131	11 KV SIMINAI	14131201	BAULPUR 2	4114DT157	63	MIXED	AMI	Yes	100%	56	0.0571588	0.013974	0.0431848	75.55%
7644	TPCODL	DHENKAN	DED	K.NAGAR	HINDOL	14123	11 KV Hindol	14123201	RUPALI	4131DT100	100	MIXED	AMI	Yes	0%	41	0.0181345	0.005697	0.0124375	68.58%
7645	TPCODL	DHENKAN	DED	K.NAGAR	JIRAL ODSSP	14319	11 KV JIRAL	14319201	ARAKHAPALVILLAGE	4145DT303	100	MIXED	AMI	Yes	0%	102	0.0807294	0.026792	0.0539374	66.81%
7646	TPCODL	DHENKAN	DED	K.NAGAR	JIRAL ODSSP	14319	11 KV JIRAL	14319201	JIRALITI	4145DT318	100	MIXED	AMI	Yes	67%	74	0.03543782	0.023822	0.01161582	32.78%
7647	TPCODL	DHENKAN	DED	K.NAGAR	JIRAL ODSSP	14319	11 KV JIRAL	14319201	JIRALBADHEI SAHI	4145DT323	100	MIXED	AMI	Yes	100%	53	0.0478326	0.028617	0.0192156	40.17%
7648	TPCODL	DHENKAN	DED	K.NAGAR	JIRAL ODSSP	14319	11 KV JIRAL	14319201	DIGHITALASAHI	4145DT330	250	MIXED	AMI	Yes	100%	144	0.16857224	0.048812	0.11976024	71.04%
7649	TPCODL	DHENKAN	DED	K.NAGAR	JIRAL ODSSP	14319	11 KV JIRAL	14319201	JIRALMEDICAL SAHI	4145DT340	100	MIXED	AMI	Yes	67%	75	0.07287054	0.032753	0.04011754	55.05%
7650	TPCODL	DHENKAN	DED	K.NAGAR	JIRAL ODSSP	14319	11 KV JIRAL	14319201	JIRALBAZAR_02	4145DT343	250	MIXED	AMI	Yes	100%	68	0.08337272	0.034156	0.04921672	59.03%
7651	TPCODL	DHENKAN	DED	K.NAGAR	JIRAL ODSSP	14319	11 KV JIRAL	14319201	JIRALHIGH SCHOOL	4145DT350	100	MIXED	AMI	Yes	100%	82	0.07835952	0.036217	0.04214252	53.78%
7652	TPCODL	DHENKAN	DED	K.NAGAR	JIRAL ODSSP	14319	11 KV JIRAL	14319201	ASANAPATIA	4145DT351	100	MIXED	AMI	Yes	33%	62	0.02219844	0.020748	0.00145044	6.53%
7653	TPCODL	DHENKAN	DED	K.NAGAR	JIRAL ODSSP	14319	11 KV JIRAL	14319201	SARADEIPUR_01	4145DT383	100	MIXED	AMI	Yes	100%	22	0.0461036	0.012899	0.0332046	72.02%
7654	TPCODL	DHENKAN	DED	K.NAGAR	JIRAL ODSSP	14319	11 KV JIRAL	14319201	SASAPASIVILLAGE_03	4145DT392	100	MIXED	AMI	Yes	67%	51	0.03400956	0.017129	0.01688056	49.63%
7655	TPCODL	DHENKAN	DED	K.NAGAR	JIRAL ODSSP	14319	11 KV GUNEIEIBIL	14319202	SANABRAHMAPUR_01	4145DT075	100	MIXED	AMI	Yes	100%	66	0.0274285	0.019019	0.0084095	30.66%
7656	TPCODL	DHENKAN	DED	K.NAGAR	JIRAL ODSSP	14319	11 KV GUNEIEIBIL	14319202	BANKUAL_03	4145DT079	100	MIXED	AMI	Yes	100%	123	0.03874508	0.022527	0.01621808	41.86%
7657	TPCODL	DHENKAN	DED	K.NAGAR	JIRAL ODSSP	14319	11 KV GUNEIEIBIL	14319202	JALIA	4145DT080	100	MIXED	AMI	Yes	100%	74	0.03608464	0.017775	0.01830964	50.74%
7658	TPCODL	DHENKAN	DED	K.NAGAR	JIRAL ODSSP	14319	11 KV GUNEIEIBIL	14319202	BALIPADADIMIRIA_01	4145DT099	100	MIXED	AMI	Yes	100%	75	0.04174828	0.026323	0.01542528	36.95%
7659	TPCODL	DHENKAN	DED	K.NAGAR	JIRAL ODSSP	14319	11 KV GUNEIEIBIL	14319202	BUDHIBILITANGARA SAHI_02	4145DT130	100	MIXED	AMI	Yes	67%	77	0.02446852	0.023339	0.00112952	4.62%
7660	TPCODL	DHENKAN	DED	K.NAGAR	JIRAL ODSSP	14319	11 KV GUNEIEIBIL	14319202	GODA SAHI	4145DT149	250	MIXED	AMI	Yes	100%	126	0.04435744	0.032522	0.01183544	26.68%
7661	TPCODL	DHENKAN	DED	K.NAGAR	JIRIDAMALI ODSSP	14318	11 KV BAISINGA	14318201	KHATAKHURA JATRA PANDIA	4142DT332	100	MIXED	AMI	Yes	0%	81	0.05729058	0.025675	0.03161558	55.18%
7662	TPCODL	DHENKAN	DED	K.NAGAR	JIRIDAMALI ODSSP	14318	11 KV BAISINGA	14318201	KHATAKHURA TARINI MANDIR	4142DT340	100	MIXED	AMI	Yes	100%	112	0.07851324	0.037425	0.04108824	52.33%
7663	TPCODL	DHENKAN	DED	K.NAGAR	JIRIDAMALI ODSSP	14318	11 KV JIRIDAMALI	14318202	KANDARSINGHA 2	4142DT074	100	MIXED	AMI	Yes	0%	39	0.02859812	0.009775	0.01882312	65.82%
7664	TPCODL	DHENKAN	DED	K.NAGAR	JIRIDAMALI ODSSP	14318	11 KV JIRIDAMALI	14318202	BADAINDIPUR	4142DT076	100	MIXED	AMI	Yes	100%	66	0.05427478	0.023837	0.03043778	56.08%

Sl. No.	Zone Name	Circle name	Division name	Name of the Sub-division	Name of the Sub-station	Substation Code	Name of the 11 kV Feeder	Feeder Code	Name of the Location where DT situated	DT code	DT Capacity (kVA)	Predominant consumer type of DT (Domestic/Industrial/Agriculture/Mixed)	Type of metering AMR/AMI/ Communicable/Conventional metered/Unmetered	Status of Meter-whether Functional (Yes/No)	% of data received automatically (if AMR/AMI)	No. of Connected Consumers	Input Energy (MU) (A)	Billed Energy (MU) (B)	Loss (MU) (A-B)	% DT Loss (A-B)/A
7665	TPCODL	DHENKAN	DED	K.NAGAR	JIRIDAMALI ODSSP	14318	11 KV JIRIDAMALI	14318202	NILAMADHABPUR 1	4142DT079	100	MIXED	AMI	Yes	100%	112	0.10787134	0.075942	0.03192934	29.60%
7666	TPCODL	DHENKAN	DED	K.NAGAR	JIRIDAMALI ODSSP	14318	11 KV JIRIDAMALI	14318202	JIRIDAMALI	4142DT086	250	MIXED	AMI	Yes	100%	23	0.1497734	0.035646	0.1141274	76.20%
7667	TPCODL	DHENKAN	DED	K.NAGAR	JIRIDAMALI ODSSP	14318	11 KV JIRIDAMALI	14318202	KALINGA NAGAR	4142DT090	100	MIXED	AMI	Yes	33%	24	0.03091744	0.01462	0.01629744	52.71%
7668	TPCODL	DHENKAN	DED	K.NAGAR	JIRIDAMALI ODSSP	14318	11 KV JIRIDAMALI	14318202	RENGALI 1	4142DT092	250	MIXED	AMI	Yes	67%	128	0.0920732	0.067962	0.0241112	26.19%
7669	TPCODL	DHENKAN	DED	K.NAGAR	JIRIDAMALI ODSSP	14318	11 KV JIRIDAMALI	14318202	NILAMADHABPUR 5	4142DT360	100	MIXED	AMI	Yes	100%	84	0.12334596	0.025045	0.09830096	79.70%
7670	TPCODL	DHENKAN	DED	K.NAGAR	JIRIDAMALI ODSSP	14318	11 KV JIRIDAMALI	14318202	MALAPURA 2	4142DT362	100	MIXED	AMI	Yes	33%	34	0.03513548	0.016964	0.01817148	51.72%
7671	TPCODL	DHENKAN	DED	K.NAGAR	KALIAPANI	14130	11 KV BAZAR (TISCO)	14130201	ATWAL GATE	4143DT060	100	MIXED	AMI	Yes	100%	75	0.05500976	0.028732	0.02627776	47.77%
7672	TPCODL	DHENKAN	DED	K.NAGAR	KALIAPANI	14130	11 KV BAZAR (TISCO)	14130201	TARINI MARKET_02	4143DT113	100	MIXED	AMI	Yes	0%	182	0.14442144	0.097727	0.04669444	32.33%
7673	TPCODL	DHENKAN	DED	K.NAGAR	KALIAPANI	14130	11 KV BAZAR (TISCO)	14130201	TATA MAIN GATE	4143DT115	100	MIXED	AMI	Yes	100%	91	0.05999712	0.032709	0.02728812	45.48%
7674	TPCODL	DHENKAN	DED	K.NAGAR	KAMAKHYANAGAR	14124	11 KV TOWN-1 (K.Ngr)	14124201	JOGISAHI	4142DT002	100	MIXED	AMI	Yes	0%	58	0.09952144	0.031128	0.06839344	68.72%
7675	TPCODL	DHENKAN	DED	K.NAGAR	KAMAKHYANAGAR	14124	11 KV TOWN-1 (K.Ngr)	14124201	SRIRAM NAGAR 2	4142DT004	250	MIXED	AMI	Yes	100%	79	0.08658744	0.042015	0.04457244	51.48%
7676	TPCODL	DHENKAN	DED	K.NAGAR	KAMAKHYANAGAR	14124	11 KV TOWN-1 (K.Ngr)	14124201	SARDHAPUR	4142DT005	250	MIXED	AMI	Yes	100%	219	0.2278218	0.088897	0.1389248	60.98%
7677	TPCODL	DHENKAN	DED	K.NAGAR	KAMAKHYANAGAR	14124	11 KV TOWN-1 (K.Ngr)	14124201	SATYANAGAR	4142DT006	250	MIXED	AMI	Yes	100%	95	0.12400536	0.031826	0.09217936	74.33%
7678	TPCODL	DHENKAN	DED	K.NAGAR	KAMAKHYANAGAR	14124	11 KV TOWN-1 (K.Ngr)	14124201	SCIENCE COLLEGE	4142DT007	250	MIXED	AMI	Yes	100%	135	0.15230752	0.080657	0.07165052	47.04%
7679	TPCODL	DHENKAN	DED	K.NAGAR	KAMAKHYANAGAR	14124	11 KV TOWN-1 (K.Ngr)	14124201	RAM MANDIR 1	4142DT008	100	MIXED	AMI	Yes	100%	43	0.07108836	0.018693	0.05239536	73.70%
7680	TPCODL	DHENKAN	DED	K.NAGAR	KAMAKHYANAGAR	14124	11 KV TOWN-1 (K.Ngr)	14124201	CANAL HUDA ANANTAPUR 2	4142DT011	250	MIXED	AMI	Yes	33%	80	0.18612668	0.051888	0.13423868	72.12%
7681	TPCODL	DHENKAN	DED	K.NAGAR	KAMAKHYANAGAR	14124	11 KV TOWN-1 (K.Ngr)	14124201	ANANTAPUR	4142DT013	500	MIXED	AMI	Yes	0%	169	0.20347984	0.105363	0.09811684	48.22%
7682	TPCODL	DHENKAN	DED	K.NAGAR	KAMAKHYANAGAR	14124	11 KV TOWN-1 (K.Ngr)	14124201	MAIN ROAD CANAL HUDA	4142DT014	100	MIXED	AMI	Yes	100%	16	0.04957638	0.01585	0.03372638	68.03%
7683	TPCODL	DHENKAN	DED	K.NAGAR	KAMAKHYANAGAR	14124	11 KV TOWN-1 (K.Ngr)	14124201	JHUMPAN POKHARI	4142DT018	250	MIXED	AMI	Yes	100%	82	0.08820376	0.08523	0.00297376	3.37%
7684	TPCODL	DHENKAN	DED	K.NAGAR	KAMAKHYANAGAR	14124	11 KV TOWN-1 (K.Ngr)	14124201	PUMP HOUSE 2	4142DT030	100	MIXED	AMI	Yes	100%	73	0.10967546	0.032022	0.07765346	70.80%
7685	TPCODL	DHENKAN	DED	K.NAGAR	KAMAKHYANAGAR	14124	11 KV TOWN-1 (K.Ngr)	14124201	GOVT MEDICAL 1	4142DT033	100	MIXED	AMI	Yes	100%	51	0.04648382	0.024862	0.02162182	46.51%
7686	TPCODL	DHENKAN	DED	K.NAGAR	KAMAKHYANAGAR	14124	11 KV TOWN-1 (K.Ngr)	14124201	BALIKA SCHOOL 1	4142DT037	500	MIXED	AMI	Yes	100%	167	0.1605656	0.098847	0.0617186	38.44%
7687	TPCODL	DHENKAN	DED	K.NAGAR	KAMAKHYANAGAR	14124	11 KV TOWN-1 (K.Ngr)	14124201	BALIKA SCHOOL 2	4142DT038	250	MIXED	AMI	Yes	100%	78	0.12639908	0.051201	0.07519808	59.49%
7688	TPCODL	DHENKAN	DED	K.NAGAR	KAMAKHYANAGAR	14124	11 KV TOWN-1 (K.Ngr)	14124201	BALIKA SCHOOL 3	4142DT039	250	MIXED	AMI	Yes	100%	66	0.08992248	0.031756	0.05816648	64.69%
7689	TPCODL	DHENKAN	DED	K.NAGAR	KAMAKHYANAGAR	14124	11 KV TOWN-1 (K.Ngr)	14124201	NEAR POST OFFICE KAMAKHYA NAGA	4142DT041	500	MIXED	AMI	Yes	100%	41	0.06476792	0.040201	0.02456692	37.93%
7690	TPCODL	DHENKAN	DED	K.NAGAR	KAMAKHYANAGAR	14124	11 KV BAUNSAPALA	14124202	SHIVA MANDIRA	4142DT047	250	MIXED	AMI	Yes	100%	60	0.1394294	0.03596	0.1034694	74.21%
7691	TPCODL	DHENKAN	DED	K.NAGAR	KAMAKHYANAGAR	14124	11 KV BAUNSAPALA	14124202	NEAR HANUMAN BAZAR	4142DT049	250	MIXED	AMI	Yes	100%	57	0.08209316	0.035207	0.04688616	57.11%
7692	TPCODL	DHENKAN	DED	K.NAGAR	KAMAKHYANAGAR	14124	11 KV BAUNSAPALA	14124202	BADABANDHA SAHI_1	4142DT050	250	MIXED	AMI	Yes	100%	164	0.14214392	0.047778	0.09436592	66.39%
7693	TPCODL	DHENKAN	DED	K.NAGAR	KAMAKHYANAGAR	14124	11 KV BAUNSAPALA	14124202	SUBSTATION -1	4142DT101	500	MIXED	AMI	Yes	100%	132	0.08485688	0.074962	0.00989488	11.66%
7694	TPCODL	DHENKAN	DED	K.NAGAR	KAMAKHYANAGAR	14124	11 KV BAUNSAPALA	14124202	SUBSTATION-2	4142DT102	500	MIXED	AMI	Yes	100%	91	0.06252312	0.054398	0.00812512	13.00%
7695	TPCODL	DHENKAN	DED	K.NAGAR	KAMAKHYANAGAR	14124	11 KV BAUNSAPALA	14124202	ALATUMA HIGH SCHOOL	4142DT105	100	MIXED	AMI	Yes	100%	31	0.07157674	0.017173	0.05440374	76.01%
7696	TPCODL	DHENKAN	DED	K.NAGAR	KAMAKHYANAGAR	14124	11 KV BAUNSAPALA	14124202	CHATIA MOHANTY	4142DT110	100	MIXED	AMI	Yes	100%	53	0.04753072	0.011789	0.03574172	75.20%
7697	TPCODL	DHENKAN	DED	K.NAGAR	KAMAKHYANAGAR	14124	11 KV BAUNSAPALA	14124202	DHARMASALA	4142DT111	250	MIXED	AMI	Yes	100%	102	0.14703168	0.044596	0.10243568	69.67%
7698	TPCODL	DHENKAN	DED	K.NAGAR	KAMAKHYANAGAR	14124	11 KV BAUNSAPALA	14124202	DHAMANA BANDHA	4142DT115	100	MIXED	AMI	Yes	100%	79	0.0713531	0.03031468	0.04103842	57.51%
7699	TPCODL	DHENKAN	DED	K.NAGAR	KAMAKHYANAGAR	14124	11 KV BAUNSAPALA	14124202	PURUNA ALTUMA	4142DT117	250	MIXED	AMI	Yes	100%	97	0.15127096	0.047439	0.10383196	68.64%
7700	TPCODL	DHENKAN	DED	K.NAGAR	KAMAKHYANAGAR	14124	11 KV BAUNSAPALA	14124202	GUPTI NAGAR	4142DT125	100	MIXED	AMI	Yes	100%	27	0.04885294	0.018923	0.02992994	61.27%
7701	TPCODL	DHENKAN	DED	K.NAGAR	KAMAKHYANAGAR	14124	11 KV BAUNSAPALA	14124202	DASHI BANDHA_3	4142DT128	500	MIXED	AMI	Yes	0%	110	0.12561928	0.05311	0.07250928	57.72%
7702	TPCODL	DHENKAN	DED	K.NAGAR	KAMAKHYANAGAR	14124	11 KV BAUNSAPALA	14124202	SANA INDIPUR_1	4142DT132	100	MIXED	AMI	Yes	100%	60	0.05327852	0.023961	0.02931752	55.03%
7703	TPCODL	DHENKAN	DED	K.NAGAR	KAMAKHYANAGAR	14124	11 KV BAUNSAPALA	14124202	BADA INDIPUR	4142DT133	100	MIXED	AMI	Yes	33%	77	0.04034462	0.032407	0.00793762	19.67%
7704	TPCODL	DHENKAN	DED	K.NAGAR	KAMAKHYANAGAR	14124	11 KV BAUNSAPALA	14124202	SANA INDIPUR-2	4142DT134	100	MIXED	AMI	Yes	100%	58	0.03458288	0.011247	0.02333588	67.48%
7705	TPCODL	DHENKAN	DED	K.NAGAR	KAMAKHYANAGAR	14124	11 KV MAHULPAL	14124204	MAHULPAL TALASAHI	4142DT378	63	MIXED	AMI	Yes	0%	96	0.07425324	0.030952	0.04330124	58.32%
7706	TPCODL	DHENKAN	DED	K.NAGAR	KAMAKHYANAGAR	14124	11 KV MAHULPAL	14124204	SARUALI GOPAL SAHI	4142DT382	100	MIXED	AMI	Yes	67%	118	0.06632252	0.020957	0.04536552	68.40%
7707	TPCODL	DHENKAN	DED	K.NAGAR	KAMAKHYANAGAR	14124	11 KV MAHULPAL	14124204	MOTA_2	4142DT396	100	MIXED	AMI	Yes	100%	127	0.0613953	0.039696	0.0216993	35.34%
7708	TPCODL	DHENKAN	DED	K.NAGAR	KAMAKHYANAGAR	14124	11 KV MAHULPAL	14124204	KHOKSHA TALA SAHI	4142DT405	100	MIXED	AMI	Yes	0%	59	0.05190378	0.013832	0.03807178	73.35%
7709	TPCODL	DHENKAN	DED	K.NAGAR	KAMAKHYANAGAR	14124	11 KV MAHULPAL	14124204	KHUKASA UPARASAHI	4142DT408	100	MIXED	AMI	Yes	100%	71	0.03833856	0.019596	0.01874256	48.89%
7710	TPCODL	DHENKAN	DED	K.NAGAR	KAMAKHYANAGAR	14124	11 KV MAHULPAL	14124204	KANCHHIA_3	4142DT434	100	MIXED	AMI	Yes	33%	129	0.01856156	0.015591	0.00297056	16.00%
7711	TPCODL	DHENKAN	DED	K.NAGAR	KAMAKHYANAGAR	14124	11 KV MAHULPAL	14124204	JODAPAL CHOWK	4142DT449	100	MIXED	AMI	Yes	0%	12	0.0261849	0.006977	0.0192079	73.35%
7712	TPCODL	DHENKAN	DED	K.NAGAR	KAMAKHYANAGAR	14124	11 KV KADUA	14124205	BHAGIRATHIPUR BADADEHURI SAHI	4142DT202	100	MIXED	AMI	Yes	100%	98	0.0416034	0.029134	0.0124694	29.97%
7713	TPCODL	DHENKAN	DED	K.NAGAR	KAMAKHYANAGAR	14124	11 KV KADUA	14124205	BHAGIRATHIPUR SASAN	4142DT209	100	MIXED	AMI	Yes	100%	84	0.08601728	0.019649	0.06636828	77.16%
7714	TPCODL	DHENKAN	DED	K.NAGAR	KAMAKHYANAGAR	14124	11 KV KADUA	14124205	KADUA GP OFFICE	4142DT213	100	MIXED	AMI	Yes	0%	86	0.04764872	0.023535	0.02411372	50.61%
7715	TPCODL	DHENKAN	DED	K.NAGAR	KAMAKHYANAGAR	14124	11 KV KADUA	14124205	SAMATANGI	4142DT232	100	MIXED	AMI	Yes	100%	156	0.03383168	0.030998	0.00283368	8.38%
7716	TPCODL	DHENKAN	DED	K.NAGAR	KAMAKHYANAGAR	14124	11 KV KADUA	14124205	BANGURA GODI SAHI	4142DT268	100	MIXED	AMI	Yes	100%	80	0.04120754	0.015329	0.02587854	62.80%
7717	TPCODL	DHENKAN	DED	K.NAGAR	KAMAKHYANAGAR	14124	11 KV KADUA	14124205	SIBULAPASI	4142DT270	100	MIXED	AMI	Yes	100%	91	0.04287668	0.020844	0.02203268	51.39%
7718	TPCODL	DHENKAN	DED	K.NAGAR	KANKADAHADA	14191	11 KV DANDADHAR	14191201	BLOCK OFFICE	4144DT004	250	MIXED	AMI	Yes	67%	167	0.1056564	0.083252	0.0224044	21.20%
7719	TPCODL	DHENKAN	DED	K.NAGAR	KANKADAHADA	14191	11 KV DANDADHAR	14191201	KANKADAHAD_01	4144DT007	250	MIXED	AMI	Yes	67%	134	0.0506988	0.039206	0.0114928	22.67%
7720	TPCODL	DHENKAN	DED	K.NAGAR	KANKADAHADA	14191	11 KV DANDADHAR	14191201	KANKADAHAD_02	4144DT010	250	MIXED	AMI	Yes	67%	231	0.08594732	0.067757	0.01819032	21.16%
7721	TPCODL	DHENKAN	DED	K.NAGAR	KANKADAHADA	14191	11 KV URBENGI	14191203	DANGAPAL_02	4144DT172	100	MIXED	AMI	Yes	0%	60	0.02229908	0.016454	0.00584508	26.21%
7722	TPCODL	DHENKAN	DED	K.NAGAR	KANKADAHADA	14191	11 KV URBENGI	14191203	KANDHARA_02	4144DT327	100	MIXED	AMI	Yes	0%	182	0.04507	0.042536	0.002534	5.62%
7723	TPCODL	DHENKAN	DED	K.NAGAR	KHAJURIAKATA	14122	11 KV RASOLA	14122201	MEDICAL CHHAK	4133DT454	200	MIXED	AMI	Yes	0%	166	0.13393384	0.116973	0.01696084	12.66%
7724	TPCODL	DHENKAN	DED	K.NAGAR	MAHULPAL	14315	11 KV KUNDA	14315201	KUNDA (KHETRIYA SAHI)	4141DT175	100	MIXED	AMI	Yes	67%	60	0.05332268	0.014836	0.03848668	72.18%
7725	TPCODL	DHENKAN	DED	K.NAGAR	MAHULPAL	14315	11 KV EKATALI	14315202	EAKATALI NIMEINPUR	4141DT162	100	MIXED	AMI	Yes	100%	47	0.0398322	0.019917	0.0199152	50.00%
7726	TPCODL	DHENKAN	DED	K.NAGAR	MAHULPAL	14315	11 KV EKATALI	14315202	CHANDAN	4141DT168	250	MIXED	AMI	Yes	67%	31	0.05129076	0.012563	0.03872776	75.51%
7727	TPCODL	DHENKAN	DED	K.NAGAR	MAHULPAL	14315	11 KV EKATALI	14315202	EKATALI PATRA SAHI	4141DT489	100	MIXED	AMI	Yes	67%	97	0.03285086	0.021721	0.01112986	33.88%
7728	TPCODL	DHENKAN	DED	K.NAGAR	MAHULPAL	14315	11 KV EKATALI	14315202	NIMEINPUR MAIN VILLAGE	4141DT494	100	MIXED	AMI	Yes	100%	82	0.04793516	0.031881	0.01605416	33.49%
7729	TPCODL	DHENKAN	DED	K.NAGAR	MAHULPAL	14315	11 KV EKATALI	14315202	BALIBO TSRINI TEMPLE	4141DT498	250	MIXED	AMI	Yes	67%	142	0.08081996	0.04286	0.03795996	46.97%
7730	TPCODL	DHENKAN	DED	K.NAGAR	MAHULPAL	14315	11 KV EKATALI	14315202	NUAHATA BAZAR	4141DT532	250	MIXED	AMI	Yes	100%	162	0.13041952	0.079505	0.05091452	39.04%
7731	TPCODL	DHENKAN	DED	K.NAGAR	MAHULPAL	14315	11 KV Murdanga	14315203	MAHULPAL NEAR PANCHAYAT OFFIC	4141DT007	100	MIXED	AMI	Yes	67%	110	0.0619882	0.030825	0.0311632	50.27%
7732	TPCODL	DHENKAN	DED	K.NAGAR	MAHULPAL	14315	11 KV Murdanga	14315203	MAHULPAL (MANGALA SAHI)_01	4141DT010	250	MIXED	AMI	Yes	67%	112	0.02946808	0.026129	0.00333908	11.33%
7733	TPCODL	DHENKAN	DED	K.NAGAR	MAHULPAL	14315	11 KV Murdanga	14315203	MAHULPAL OLIC_05	4141DT016	63	MIXED	AMI	Yes	0%	9	0.00262727	0.001847	0.00078027	29.70%
7734	TPCODL	DHENKAN	DED	K.NAGAR	MAHULPAL	14315	11 KV Murdanga	14315203	MURDANGA	4141DT501	100	MIXED	AMI	Yes	67%	104	0.058668	0.046558	0.01211	20.64%
7735	TPCODL	DHENKAN	DED	K.NAGAR	MAHULPAL	14315	11 KV Murdanga	14315203	MURDANGA_01	4141DT509	100	MIXED	AMI	Yes	67%	76	0.0347726	0.020639	0.0141336	40.65%
7736	TPCODL	DHENKAN	DED	K.NAGAR	MAHULPAL	14315	11 KV Murdanga	14315203	MARUABIL MAHANTA SAHI	4144DT438	100	MIXED	AMI	Yes	33%	88	0.0379001	0.023553	0.0143471	37.86%
7737	TPCODL	DHENKAN	DED	K.NAGAR	MATHAKARAGOLA	14126	11 KV JIRAL	14126201	GORADIA_01	4145DT365	100	MIXED	AMI	Yes	100%	54	0.04185514	0.017852	0.02400314	57.35%

Sl. No.	Zone Name	Circle name	Division name	Name of the Sub-division	Name of the Sub-station	Substation Code	Name of the 11 kV Feeder	Feeder Code	Name of the Location where DT situated	DT code	DT Capacity (kVA)	Predominant consumer type of DT (Domestic/Industrial/Agriculture/Mixed)	Type of metering AMR/AMI/ Communicable/Conventional metered/Unmetered	Status of Meter-whether Functional (Yes/No)	% of data received automatically (if AMR/AMI)	No. of Connected Consumers	Input Energy (MU) (A)	Billed Energy (MU) (B)	Loss (MU) (A-B)	% DT Loss (A-B)/A
7738	TPCODL	DHENKAN	DED	K.NAGAR	MATHAKARAGOLA	14126	11 KV BELEISAHI	14126202	JAMUNAKOTANUASAHI_01	4145DT215	100	MIXED	AMI	Yes	33%	103	0.05072358	0.036281	0.01444258	28.47%
7739	TPCODL	DHENKAN	DED	K.NAGAR	MATHAKARAGOLA	14126	11 KV BELEISAHI	14126202	JAMUNAKOTA SUNDHIBOLA BAZAR	4145DT223	250	MIXED	AMI	Yes	100%	109	0.0965438	0.040361	0.0561828	58.19%
7740	TPCODL	DHENKAN	DED	K.NAGAR	MATHAKARAGOLA	14126	11 KV BALISAHI	14126203	GUMPHASAHI	4145DT243	100	MIXED	AMI	Yes	0%	75	0.08606698	0.021914	0.06415298	74.54%
7741	TPCODL	DHENKAN	DED	K.NAGAR	MATHAKARAGOLA	14126	11 KV BALISAHI	14126203	MATHAKARGOLABUS STAND	4145DT280	250	MIXED	AMI	Yes	100%	82	0.09256168	0.042373	0.05018868	54.22%
7742	TPCODL	DHENKAN	DED	K.NAGAR	MATHAKARAGOLA	14126	11 KV MARTHAPUR	14126204	JINEILOPURUNA SAHI	4145DT156	100	MIXED	AMI	Yes	0%	76	0.07701024	0.0245421	0.05246814	68.13%
7743	TPCODL	DHENKAN	DED	K.NAGAR	MATHAKARAGOLA	14126	11 KV MARTHAPUR	14126204	ANANDAPUR	4145DT165	100	MIXED	AMI	Yes	67%	52	0.03699564	0.026958	0.01003764	27.13%
7744	TPCODL	DHENKAN	DED	K.NAGAR	PANDUA ODSSP	14313	11 KV SOGAR	14313201	MACHHIA 1	4146DT016	100	MIXED	AMI	Yes	100%	86	0.04110296	0.02802	0.01308296	31.83%
7745	TPCODL	DHENKAN	DED	K.NAGAR	PANDUA ODSSP	14313	11 KV SOGAR	14313201	GOPALPUR SOGARA-2	4146DT037	100	MIXED	AMI	Yes	100%	102	0.05492378	0.052788	0.00213578	3.89%
7746	TPCODL	DHENKAN	DED	K.NAGAR	PANDUA ODSSP	14313	11 KV SOGAR	14313201	R N PUR SASAN	4146DT071	100	MIXED	AMI	Yes	67%	138	0.06143342	0.039273	0.02216042	36.07%
7747	TPCODL	DHENKAN	DED	K.NAGAR	PANDUA ODSSP	14313	11 KV ANLABERINI	14313202	KOTAGORA GRAMA PANCHAYAT OFF	4146DT136	100	MIXED	AMI	Yes	100%	62	0.0304083	0.024652	0.0057563	18.93%
7748	TPCODL	DHENKAN	DED	K.NAGAR	PANDUA ODSSP	14313	11 KV ANLABERINI	14313202	UPARAGODA SAHI_02	4146DT139	100	MIXED	AMI	Yes	100%	73	0.05078224	0.032593	0.01818924	35.82%
7749	TPCODL	DHENKAN	DED	K.NAGAR	PANDUA ODSSP	14313	11 KV ANLABERINI	14313202	KHATUAHATA	4146DT151	100	MIXED	AMI	Yes	100%	116	0.03860678	0.03248	0.00612678	15.87%
7750	TPCODL	DHENKAN	DED	K.NAGAR	PANDUA ODSSP	14313	11 KV ANLABERINI	14313202	KHUNTABADI	4146DT166	100	MIXED	AMI	Yes	100%	117	0.02723916	0.02204	0.00519916	19.09%
7751	TPCODL	DHENKAN	DED	K.NAGAR	PANDUA ODSSP	14313	11 KV ANLABERINI	14313202	ANLABERENI BAZAR	4146DT174	250	MIXED	AMI	Yes	0%	57	0.06764856	0.033955	0.03369356	49.81%
7752	TPCODL	DHENKAN	DED	K.NAGAR	PANDUA ODSSP	14313	11 KV ANLABERINI	14313202	ANLABERENI PURUNA	4146DT176	100	MIXED	AMI	Yes	0%	66	0.0289912	0.021066	0.0079252	27.34%
7753	TPCODL	DHENKAN	DED	K.NAGAR	PANDUA ODSSP	14313	11 KV ANLABERINI	14313202	MAHULI_01	4146DT208	100	MIXED	AMI	Yes	100%	195	0.07053792	0.049284	0.02125392	30.13%
7754	TPCODL	DHENKAN	DED	K.NAGAR	PANDUA ODSSP	14313	11 KV ANLABERINI	14313202	ANLABERENI MEDICAL_02	4146DT243	100	MIXED	AMI	Yes	100%	70	0.07735328	0.05608	0.02127328	27.50%
7755	TPCODL	DHENKAN	DED	K.NAGAR	PANDUA ODSSP	14313	11 KV KOTAGARA	14313203	JAKA NERA SCHOOL_02	4146DT258	100	MIXED	AMI	Yes	0%	75	0.02488288	0.020971	0.00391188	15.72%
7756	TPCODL	DHENKAN	DED	K.NAGAR	PANDUA ODSSP	14313	11 KV KOTAGARA	14313203	PUTA SAHI	4146DT261	100	MIXED	AMI	Yes	100%	83	0.0383789	0.02372	0.0146589	38.20%
7757	TPCODL	DHENKAN	DED	K.NAGAR	PANDUA ODSSP	14313	11 KV KOTAGARA	14313203	KANTIO VALIATAILA_02	4146DT266	100	MIXED	AMI	Yes	100%	60	0.02254458	0.012903	0.00964158	42.77%
7758	TPCODL	DHENKAN	DED	K.NAGAR	PANDUA ODSSP	14313	11 KV KOTAGARA	14313203	KANTIOPUTASAHI RADHA KRISHNA M	4146DT277	100	MIXED	AMI	Yes	100%	34	0.0256532	0.009097	0.0165562	64.54%
7759	TPCODL	DHENKAN	DED	K.NAGAR	PANDUA ODSSP	14313	11 KV KOTAGARA	14313203	KANTIOKATENI PRADHAN SAHI	4146DT281	100	MIXED	AMI	Yes	100%	128	0.02948774	0.026736	0.00275174	9.33%
7760	TPCODL	DHENKAN	DED	K.NAGAR	PANDUA ODSSP	14313	11 KV KOTAGARA	14313203	KANTIOKATENI SCHOOL SAHI	4146DT291	250	MIXED	AMI	Yes	100%	141	0.05209104	0.032796	0.01929504	37.04%
7761	TPCODL	DHENKAN	DED	K.NAGAR	PANDUA ODSSP	14313	11 KV KOTAGARA	14313203	KANTIOKATENI BHARATGAS	4146DT298	100	MIXED	AMI	Yes	100%	64	0.02953042	0.022404	0.00712642	24.13%
7762	TPCODL	DHENKAN	DED	K.NAGAR	PANDUA ODSSP	14313	11 KV KOTAGARA	14313203	TUMUSINGA_01	4146DT319	250	MIXED	AMI	Yes	0%	192	0.11423928	0.067739	0.04650028	40.70%
7763	TPCODL	DHENKAN	DED	K.NAGAR	PANDUA ODSSP	14313	11 KV KOTAGARA	14313203	KALIA HATA	4146DT346	100	MIXED	AMI	Yes	100%	119	0.04103616	0.027439	0.01359716	33.13%
7764	TPCODL	DHENKAN	DED	K.NAGAR	PANDUA ODSSP	14313	11 KV KOTAGARA	14313203	KANTAPALA	4146DT350	100	MIXED	AMI	Yes	100%	108	0.03497678	0.029455	0.00552178	15.79%
7765	TPCODL	DHENKAN	DED	K.NAGAR	PANDUA ODSSP	14313	11 KV KOTAGARA	14313203	GANGIJODI SABAR SAHI	4146DT363	100	MIXED	AMI	Yes	100%	141	0.02505128	0.019545	0.00550628	21.98%
7766	TPCODL	DHENKAN	DED	K.NAGAR	PANDUA ODSSP	14313	11 KV BARUAN (Pandua)	14313204	BARUAN K-1	4146DT092	100	MIXED	AMI	Yes	100%	53	0.02226346	0.012281	0.00998246	44.84%
7767	TPCODL	DHENKAN	DED	K.NAGAR	PANDUA ODSSP	14313	11 KV BARUAN (Pandua)	14313204	ICHHABATIPUR-2	4146DT246	100	MIXED	AMI	Yes	100%	65	0.03135208	0.02215	0.00920208	29.35%
7768	TPCODL	DHENKAN	DED	K.NAGAR	PANDUA ODSSP	14313	11 KV BARUAN (Pandua)	14313204	AMBABHOLA-1	4146DT248	100	MIXED	AMI	Yes	100%	103	0.01190224	0.0095841	0.00231814	19.48%
7769	TPCODL	DHENKAN	DED	K.NAGAR	PANDUA ODSSP	14313	11 KV BARUAN (Pandua)	14313204	AMBAKHOLA SABAR SAHI	4146DT249	100	MIXED	AMI	Yes	100%	78	0.02128528	0.01256701	0.00871827	40.96%
7770	TPCODL	DHENKAN	TED	CHAINPAL	BANARPAL	14142	11 kV BANARPAL MARKE	14142205	NEAR ASHA TALKIES_1	4311DT076	500	MIXED	AMI	Yes	100%	131	0.4523837	0.166604	0.2857797	63.17%
7771	TPCODL	DHENKAN	TED	CHAINPAL	BANARPAL	14142	11 kV BANARPAL MARKE	14142205	SANTRI CHOWK BANARPAL	4311DT080	100	MIXED	AMI	Yes	100%	11	0.01597468	0.009903	0.00607168	38.01%
7772	TPCODL	DHENKAN	TED	CHAINPAL	BANARPAL	14142	11 kV BANARPAL MARKE	14142205	SANTRI CHOWK BANARPAL-2	4311DT081	100	MIXED	AMI	Yes	0%	114	0.14753868	0.104571	0.04296768	29.12%
7773	TPCODL	DHENKAN	TED	CHAINPAL	BANARPAL	14142	11 KV CHAINPAL	14142201	APARTIPUR GAMBHARI SAHI	4311DT009	100	MIXED	AMI	Yes	67%	120	0.08261918	0.066229	0.01639018	19.84%
7774	TPCODL	DHENKAN	TED	CHAINPAL	BANARPAL	14142	11 KV CHAINPAL	14142201	GOTAMARA BALI SAHI	4311DT013	100	MIXED	AMI	Yes	100%	109	0.13559352	0.082533	0.05306052	39.13%
7775	TPCODL	DHENKAN	TED	CHAINPAL	BANARPAL	14142	11 KV CHAINPAL	14142201	GOTAMARA -2	4311DT018	100	MIXED	AMI	Yes	100%	91	0.13796466	0.077544	0.06042066	43.79%
7776	TPCODL	DHENKAN	TED	CHAINPAL	BANARPAL	14142	11 KV CHAINPAL	14142201	GOTAMARA -1	4311DT019	250	MIXED	AMI	Yes	100%	96	0.18470528	0.045593	0.13911228	75.32%
7777	TPCODL	DHENKAN	TED	CHAINPAL	BANARPAL	14142	11 KV CHAINPAL	14142201	GOTAMARA BRAHMAYANI SAHI GAD	4311DT022	100	MIXED	AMI	Yes	0%	154	0.14395604	0.08533516	0.05862088	40.72%
7778	TPCODL	DHENKAN	TED	CHAINPAL	BANARPAL	14142	11 KV CHAINPAL	14142201	GOTAMARA RADHA COMPLEX	4311DT026	100	MIXED	AMI	Yes	100%	27	0.051629	0.026763	0.024866	48.16%
7779	TPCODL	DHENKAN	TED	CHAINPAL	BANARPAL	14142	11 KV CHAINPAL	14142201	GOTAMARA KHARIA SAHI	4311DT034	250	MIXED	AMI	Yes	100%	289	0.2070829	0.178278	0.0288049	13.91%
7780	TPCODL	DHENKAN	TED	CHAINPAL	BANARPAL	14142	11 KV CHAINPAL	14142201	GOTAMARA PANCHAYAT OFFICE	4311DT037	100	MIXED	AMI	Yes	0%	77	0.07592892	0.036061	0.03986792	52.51%
7781	TPCODL	DHENKAN	TED	CHAINPAL	BANARPAL	14142	11 KV CHAINPAL	14142201	GOTAMARA NALCO SCHOOL	4311DT039	100	MIXED	AMI	Yes	0%	79	0.0840102	0.057918	0.0260922	31.06%
7782	TPCODL	DHENKAN	TED	CHAINPAL	BANARPAL	14142	11 KV KULAD	14142202	LAXMI NAGAR BADURI SAHI BANARP	4311DT087	100	MIXED	AMI	Yes	100%	77	0.09422781	0.072534	0.02169381	23.02%
7783	TPCODL	DHENKAN	TED	CHAINPAL	BANARPAL	14142	11 KV KULAD	14142202	BADURI SAHI LAXMI NAGAR BANARP	4311DT089	100	MIXED	AMI	Yes	100%	61	0.08068888	0.05174	0.02894888	35.88%
7784	TPCODL	DHENKAN	TED	CHAINPAL	BANARPAL	14142	11 KV KULAD	14142202	D.D.S.M.SCHOOL BANARPAL_1	4311DT093	100	MIXED	AMI	Yes	100%	60	0.08041002	0.051137	0.02927302	36.40%
7785	TPCODL	DHENKAN	TED	CHAINPAL	BANARPAL	14142	11 KV KULAD	14142202	BONDA PLOTTING_2	4311DT102	100	MIXED	AMI	Yes	33%	13	0.034976	0.010702	0.024274	69.40%
7786	TPCODL	DHENKAN	TED	CHAINPAL	BANARPAL	14142	11 KV KULAD	14142202	JHAJRI BALI SAHI	4311DT112	100	MIXED	AMI	Yes	100%	129	0.09681268	0.072622	0.02419068	24.99%
7787	TPCODL	DHENKAN	TED	CHAINPAL	BANARPAL	14142	11 KV KULAD	14142202	BONDA NEAR RWSS	4311DT113	100	MIXED	AMI	Yes	100%	151	0.15594208	0.113315	0.04262708	27.34%
7788	TPCODL	DHENKAN	TED	CHAINPAL	BANARPAL	14142	11 KV KULAD	14142202	BONDA NEAR MISTY HOTEL	4311DT122	250	MIXED	AMI	Yes	67%	69	0.16955992	0.066611	0.10294892	60.72%
7789	TPCODL	DHENKAN	TED	CHAINPAL	BANARPAL	14142	11 KV KULAD	14142202	KULAD ME SCHOOL	4311DT146	250	MIXED	AMI	Yes	67%	53	0.18471408	0.058975	0.12573908	68.07%
7790	TPCODL	DHENKAN	TED	CHAINPAL	BANARPAL	14142	11 KV KULAD	14142202	GIRANGI UPPER SAHI_1	4311DT149	100	MIXED	AMI	Yes	33%	74	0.10275856	0.063496	0.03926256	38.21%
7791	TPCODL	DHENKAN	TED	CHAINPAL	BANARPAL	14142	11 KV KULAD	14142202	GIRANGA CHOWK NEAR RAM MANDI	4311DT174	250	MIXED	AMI	Yes	0%	124	0.12775988	0.084149	0.04361088	34.14%
7792	TPCODL	DHENKAN	TED	CHAINPAL	BANARPAL	14142	11 KV KULAD	14142202	BASALA SAHI VILLAGE 2	4312DT231	100	MIXED	AMI	Yes	100%	65	0.05982892	0.046774	0.01305492	21.82%
7793	TPCODL	DHENKAN	TED	CHAINPAL	BANARPAL	14142	11 KV HINDOL	14142203	NUAHATA HADI SAHI	4311DT293	100	MIXED	AMI	Yes	67%	36	0.06202904	0.030429	0.03160004	50.94%
7794	TPCODL	DHENKAN	TED	CHAINPAL	BANARPAL	14142	11 KV HINDOL	14142203	SANTRI	4311DT310	250	MIXED	AMI	Yes	67%	53	0.09635992	0.020418	0.07594192	78.81%
7795	TPCODL	DHENKAN	TED	CHAINPAL	BANARPAL	14142	11 KV HINDOL	14142203	GADA SANTRI	4311DT317	100	MIXED	AMI	Yes	0%	18	0.0159083	0.008836	0.0070723	44.46%
7796	TPCODL	DHENKAN	TED	CHAINPAL	BANARPAL	14142	11 KV HINDOL	14142203	GADA SANTRI GP	4311DT321	200	MIXED	AMI	Yes	0%	103	0.109518	0.049943	0.059575	54.40%
7797	TPCODL	DHENKAN	TED	CHAINPAL	BANARPAL	14142	11 KV HINDOL	14142203	TULASIPALA RAJDHANI SAHI	4311DT327	100	MIXED	AMI	Yes	67%	128	0.07199344	0.034985	0.03700844	51.41%
7798	TPCODL	DHENKAN	TED	CHAINPAL	BANARPAL	14142	11 KV HINDOL	14142203	TULASIPALA RAJDHANI SAHI	4311DT335	100	MIXED	AMI	Yes	67%	134	0.0794175	0.049148	0.0302695	38.11%
7799	TPCODL	DHENKAN	TED	CHAINPAL	BANARPAL	14142	11 KV HINDOL	14142203	LANGULIABEDA	4311DT338	100	MIXED	AMI	Yes	0%	121	0.04041896	0.033605	0.00681396	16.86%
7800	TPCODL	DHENKAN	TED	CHAINPAL	BANARPAL	14142	11 KV HINDOL	14142203	LANGULIABEDA NEAR POND	4311DT339	100	MIXED	AMI	Yes	33%	88	0.04807174	0.033122	0.01494974	31.10%
7801	TPCODL	DHENKAN	TED	CHAINPAL	BANARPAL	14142	11 KV HINDOL	14142203	GANGIJODI	4311DT349	100	MIXED	AMI	Yes	33%	107	0.07819602	0.041201	0.03699502	47.31%
7802	TPCODL	DHENKAN	TED	CHAINPAL	BANARPAL	14142	11 KV HINDOL	14142203	BOULIGADA	4311DT373	100	MIXED	AMI	Yes	67%	143	0.09176046	0.042328	0.04943246	53.87%
7803	TPCODL	DHENKAN	TED	CHAINPAL	BANARPAL	14142	11 KV HINDOL	14142203	ARAHAT UP SCHOOL	4311DT389	100	MIXED	AMI	Yes	33%	57	0.03875608	0.018306	0.02045008	52.77%
7804	TPCODL	DHENKAN	TED	CHAINPAL	BANARPAL	14142	11 KV HINDOL	14142203	PURIKIA	4311DT395	100	MIXED	AMI	Yes	67%	101	0.04845222	0.030058	0.01839422	37.96%
7805	TPCODL	DHENKAN	TED	CHAINPAL	BANARPAL	14142	11 KV HINDOL	14142203	GADA SANTRI NALA CHANDRAPUR	4311DT433	100	MIXED	AMI	Yes	67%	36	0.0291188	0.007098	0.0220208	75.62%
7806	TPCODL	DHENKAN	TED	CHAINPAL	BANARPAL	14142	11 KV HINDOL	14142203	GADA SANTRI NALA CHANDRAPUR	4311DT434	100	MIXED	AMI	Yes	67%	52	0.0734222	0.023611	0.0498112	67.84%
7807	TPCODL	DHENKAN	TED	CHAINPAL	BANARPAL	14142	11 KV HINDOL	14142203	BADAKHALI	4311DT436	100	MIXED	AMI	Yes	0%	32	0.0064142	0.00625	0.0001642	2.56%
7808	TPCODL	DHENKAN	TED	CHAINPAL	BANARPAL	14142	11 KV MERAMUNDALI	14142204	BRUNDABANPUR MISTRI COMPANY	4311DT197	200	MIXED	AMI	Yes	0%	96	0.28272044	0.124794	0.15792644	55.86%
7809	TPCODL	DHENKAN	TED	CHAINPAL	BANARPAL	14142	11 KV MERAMUNDALI	14142204	GADA BUDHAPANKA GATE 1	4311DT201	250	MIXED	AMI	Yes	0%	107	0.15508114	0.103599	0.05148214	33.20%
7810	TPCODL	DHENKAN	TED	CHAINPAL	BANARPAL	14142	11 KV MERAMUNDALI	14142204	GADA BUDHAPANKA GATE 2	4311DT202	100	MIXED	AMI	Yes	100%	81	0.0955013	0.082504	0.0129973	13.61%

Sl. No.	Zone Name	Circle name	Division name	Name of the Sub-division	Name of the Sub-station	Substation Code	Name of the 11 kV Feeder	Feeder Code	Name of the Location where DT situated	DT code	DT Capacity (kVA)	Predominant consumer type of DT (Domestic/Industrial/Agriculture/Mixed)	Type of metering AMR/AMI/ Communicable/Conventional metered/Unmetered	Status of Meter-whether Functional (Yes/No)	% of data received automatically (if AMR/AMI)	No. of Connected Consumers	Input Energy (MU) (A)	Billed Energy (MU) (B)	Loss (MU) (A-B)	% DT Loss (A-B)/A
7811	TPCODL	DHENKAN	TED	CHAINPAL	BANARPAL	14142	11 KV MERAMUNDALI	14142204	NUAHATA BAIDYA SAHI	4311DT208	100	MIXED	AMI	Yes	100%	93	0.09216816	0.047052	0.04511616	48.95%
7812	TPCODL	DHENKAN	TED	CHAINPAL	BANARPAL	14142	11 KV MERAMUNDALI	14142204	NUAHATA BALI SAHI	4311DT209	100	MIXED	AMI	Yes	0%	70	0.0631575	0.055869	0.0072885	11.54%
7813	TPCODL	DHENKAN	TED	CHAINPAL	BANARPAL	14142	11 KV MERAMUNDALI	14142204	NUAHATA	4311DT218	100	MIXED	AMI	Yes	100%	90	0.08715804	0.054508	0.03265004	37.46%
7814	TPCODL	DHENKAN	TED	CHAINPAL	BANARPAL	14142	11 KV MERAMUNDALI	14142204	NUAHATA DIHA SAHI	4311DT219	250	MIXED	AMI	Yes	100%	59	0.09718244	0.027418	0.06976444	71.79%
7815	TPCODL	DHENKAN	TED	CHAINPAL	BANARPAL	14142	11 KV MERAMUNDALI	14142204	TALABAHAL -1	4311DT223	100	MIXED	AMI	Yes	100%	101	0.0625723	0.030784	0.0317883	50.80%
7816	TPCODL	DHENKAN	TED	CHAINPAL	BANARPAL	14142	11 KV MERAMUNDALI	14142204	JORAGADIA 2	4311DT228	100	MIXED	AMI	Yes	100%	95	0.10606538	0.075551	0.03051438	28.77%
7817	TPCODL	DHENKAN	TED	CHAINPAL	BANARPAL	14142	11 KV MERAMUNDALI	14142204	GADA BUDHAPANK SRI RAM NAGAR	4311DT233	100	MIXED	AMI	Yes	100%	60	0.06362006	0.048675	0.01494506	23.49%
7818	TPCODL	DHENKAN	TED	CHAINPAL	BANARPAL	14142	11 KV MERAMUNDALI	14142204	BUDHAPANK KADU SAHI	4311DT246	200	MIXED	AMI	Yes	33%	254	0.1684654	0.113304	0.0551614	32.74%
7819	TPCODL	DHENKAN	TED	CHAINPAL	CHAINPAL	14192	11 KV BALHAR	14192201	SANTHAPADA NUA SAHI	4312DT034	100	MIXED	AMI	Yes	33%	83	0.11597442	0.056103	0.05987142	51.62%
7820	TPCODL	DHENKAN	TED	CHAINPAL	CHAINPAL	14192	11 KV BALHAR	14192201	BANGU 2	4312DT037	100	MIXED	AMI	Yes	67%	26	0.03277064	0.01492	0.01785064	54.47%
7821	TPCODL	DHENKAN	TED	CHAINPAL	CHAINPAL	14192	11 KV BALHAR	14192201	BANGU 3	4312DT038	100	MIXED	AMI	Yes	67%	38	0.04738592	0.023901	0.02348492	49.56%
7822	TPCODL	DHENKAN	TED	CHAINPAL	CHAINPAL	14192	11 KV BALHAR	14192201	BIPIN PLOTTING	4312DT040	250	MIXED	AMI	Yes	0%	83	0.13677708	0.093653	0.04312408	31.53%
7823	TPCODL	DHENKAN	TED	CHAINPAL	CHAINPAL	14192	11 KV BALHAR	14192201	PADIABHANGI HIGH SCHOOL SAHI	4312DT129	100	MIXED	AMI	Yes	0%	61	0.06277722	0.041008	0.02176922	34.68%
7824	TPCODL	DHENKAN	TED	CHAINPAL	CHAINPAL	14192	11 KV BALHAR	14192201	KHOLUA-3	4312DT135	100	MIXED	AMI	Yes	0%	48	0.0680812	0.036436	0.0316452	46.48%
7825	TPCODL	DHENKAN	TED	CHAINPAL	CHAINPAL	14192	11 KV BALHAR	14192201	KHOLUA	4312DT138	100	MIXED	AMI	Yes	0%	112	0.08436952	0.052171	0.03219852	38.16%
7826	TPCODL	DHENKAN	TED	CHAINPAL	CHAINPAL	14192	11 KV BALHAR	14192201	KHOLUA-4	4312DT140	100	MIXED	AMI	Yes	67%	64	0.045333	0.031905	0.013428	29.62%
7827	TPCODL	DHENKAN	TED	CHAINPAL	CHAINPAL	14192	11 KV BALHAR	14192201	PANDARBHANIA 2	4312DT148	100	MIXED	AMI	Yes	67%	97	0.05223634	0.031969	0.02026734	38.80%
7828	TPCODL	DHENKAN	TED	CHAINPAL	CHAINPAL	14192	11 KV BALHAR	14192201	ANAND BAZAR 100	4312DT157	100	MIXED	AMI	Yes	67%	99	0.1152622	0.072186	0.0430762	37.37%
7829	TPCODL	DHENKAN	TED	CHAINPAL	CHAINPAL	14192	11 KV BALHAR	14192201	GANAPATI NAGAR	4312DT158	250	MIXED	AMI	Yes	0%	135	0.18187612	0.119758	0.06211812	34.15%
7830	TPCODL	DHENKAN	TED	CHAINPAL	CHAINPAL	14192	11 KV BALHAR	14192201	NUAPADA	4312DT163	100	MIXED	AMI	Yes	67%	61	0.0781832	0.033939	0.0442442	56.59%
7831	TPCODL	DHENKAN	TED	CHAINPAL	CHAINPAL	14192	11 KV BALHAR	14192201	NUAPADA BIRA PLOTING	4312DT164	100	MIXED	AMI	Yes	67%	41	0.06293088	0.035136	0.02779488	44.17%
7832	TPCODL	DHENKAN	TED	CHAINPAL	CHAINPAL	14192	11 KV BALHAR	14192201	BALHRA CHAK BABULI PLOTING	4312DT174	100	MIXED	AMI	Yes	0%	42	0.04117076	0.035367	0.00580376	14.10%
7833	TPCODL	DHENKAN	TED	CHAINPAL	CHAINPAL	14192	11 KV BALHAR	14192201	KRISHNA CLINIC BALHRA CHAK	4312DT176	100	MIXED	AMI	Yes	0%	47	0.06921856	0.066465	0.00275356	3.98%
7834	TPCODL	DHENKAN	TED	CHAINPAL	CHAINPAL	14192	11 KV BALHAR	14192201	SANTHAPADA-3	4312DT179	100	MIXED	AMI	Yes	67%	38	0.04908098	0.029333	0.01974798	40.24%
7835	TPCODL	DHENKAN	TED	CHAINPAL	CHAINPAL	14192	11 KV BALHAR	14192201	SANTHAPADA UP SCHOOL	4312DT181	100	MIXED	AMI	Yes	67%	131	0.05812321	0.047035	0.01108821	19.08%
7836	TPCODL	DHENKAN	TED	CHAINPAL	CHAINPAL	14192	11 KV BALHAR	14192201	SANTHAPADA SUNDARPASI	4312DT184	100	MIXED	AMI	Yes	67%	93	0.07938024	0.040989	0.03839124	48.36%
7837	TPCODL	DHENKAN	TED	CHAINPAL	CHAINPAL	14192	11 KV GOTAMARA	14192202	CHAINPAL-3 POND	4312DT003	250	MIXED	AMI	Yes	0%	135	0.15667776	0.077154	0.07952376	50.76%
7838	TPCODL	DHENKAN	TED	CHAINPAL	CHAINPAL	14192	11 KV GOTAMARA	14192202	GIRI COMPLEX GOTAMARA CANAL	4312DT010	100	MIXED	AMI	Yes	0%	10	0.00904814	0.008488	0.00056014	6.19%
7839	TPCODL	DHENKAN	TED	CHAINPAL	CHAINPAL	14192	11 KV GOTAMARA	14192202	LINGARAKATA SHIVA TEMPLE	4312DT015	100	MIXED	AMI	Yes	0%	95	0.05632052	0.024394	0.03192652	56.69%
7840	TPCODL	DHENKAN	TED	CHAINPAL	CHAINPAL	14192	11 KV GOTAMARA	14192202	TALA SAHI CHAINPA	4312DT017	100	MIXED	AMI	Yes	0%	12	0.0285961	0.009295	0.0193011	67.50%
7841	TPCODL	DHENKAN	TED	CHAINPAL	CHAINPAL	14192	11 KV GOTAMARA	14192202	LINGARAKATA NEAR RICE MILL	4312DT019	100	MIXED	AMI	Yes	0%	66	0.05810432	0.03486	0.02324432	40.00%
7842	TPCODL	DHENKAN	TED	CHAINPAL	CHAINPAL	14192	11 KV GOTAMARA	14192202	SALAGADIA-2 NEAR PLOTING	4312DT021	63	MIXED	AMI	Yes	67%	59	0.0381396	0.018632	0.0195076	51.15%
7843	TPCODL	DHENKAN	TED	CHAINPAL	CHAINPAL	14192	11 KV GOTAMARA	14192202	SALAGADIA-1 NEAR POND	4312DT022	100	MIXED	AMI	Yes	67%	90	0.0867607	0.033928	0.0528327	60.89%
7844	TPCODL	DHENKAN	TED	CHAINPAL	CHAINPAL	14192	11 KV BHOGABARINI	14192203	BALARAMPRASAD BAULA CHOWK	4312DT050	100	MIXED	AMI	Yes	67%	91	0.07769906	0.063712	0.01398706	18.00%
7845	TPCODL	DHENKAN	TED	CHAINPAL	CHAINPAL	14192	11 KV BHOGABARINI	14192203	BALARAMPRASAD PASCHIM PATNA-1	4312DT054	100	MIXED	AMI	Yes	67%	90	0.05802412	0.052326	0.00569812	9.82%
7846	TPCODL	DHENKAN	TED	CHAINPAL	CHAINPAL	14192	11 KV BHOGABARINI	14192203	BALARAMPRASAD PASCHIM PATNA-2	4312DT055	100	MIXED	AMI	Yes	67%	43	0.05517846	0.022856	0.03232246	58.58%
7847	TPCODL	DHENKAN	TED	CHAINPAL	CHAINPAL	14192	11 KV BHOGABARINI	14192203	BALARAMPRASAD PINGUA-1	4312DT056	100	MIXED	AMI	Yes	67%	69	0.06502614	0.054692	0.01033414	15.89%
7848	TPCODL	DHENKAN	TED	CHAINPAL	CHAINPAL	14192	11 KV BHOGABARINI	14192203	BALARAMPRASAD PINGUA-3	4312DT058	100	MIXED	AMI	Yes	67%	88	0.07307564	0.048883	0.02419264	33.11%
7849	TPCODL	DHENKAN	TED	CHAINPAL	CHAINPAL	14192	11 KV BHOGABARINI	14192203	BALARAMPRASAD GADA SAHI HANUI	4312DT060	100	MIXED	AMI	Yes	67%	67	0.0501766	0.040233	0.0099436	19.82%
7850	TPCODL	DHENKAN	TED	CHAINPAL	CHAINPAL	14192	11 KV BHOGABARINI	14192203	BHOGABERENI-2	4312DT064	100	MIXED	AMI	Yes	0%	15	0.03314126	0.008261	0.02488026	75.07%
7851	TPCODL	DHENKAN	TED	CHAINPAL	CHAINPAL	14192	11 KV BHOGABARINI	14192203	TENTOLOI ASHRAM SCHOOL-1	4312DT086	100	MIXED	AMI	Yes	67%	68	0.04972463	0.018872	0.03085263	62.05%
7852	TPCODL	DHENKAN	TED	CHAINPAL	CHAINPAL	14192	11 KV BHOGABARINI	14192203	BALARAMPRASAD ARA SAHI	4312DT105	100	MIXED	AMI	Yes	33%	53	0.05335858	0.049562	0.00379658	7.12%
7853	TPCODL	DHENKAN	TED	CHAINPAL	CHAINPAL	14192	11 KV BHOGABARINI	14192203	BALARAMPRASAD MADHYAGADA PA	4312DT119	100	MIXED	AMI	Yes	67%	56	0.0499352	0.038177	0.0117582	23.55%
7854	TPCODL	DHENKAN	TED	CHAINPAL	CHAINPAL	14192	11 KV BHOGABARINI	14192203	BALARAMPRASAD AMANTAPUR NEA	4312DT206	100	MIXED	AMI	Yes	67%	63	0.04694806	0.043126	0.00382206	8.14%
7855	TPCODL	DHENKAN	TED	CHAINPAL	CHAINPAL	14192	11 KV BHOGABARINI	14192203	BALARAMPRASAD AMANTAPUR AAD	4312DT209	100	MIXED	AMI	Yes	67%	36	0.05167424	0.021797	0.02987724	57.82%
7856	TPCODL	DHENKAN	TED	CHAINPAL	CHAINPAL	14192	11 KV BHOGABARINI	14192203	BALARAMPRASAD KENDUPATNA 2	4312DT221	100	MIXED	AMI	Yes	67%	84	0.0892445	0.075673	0.0135715	15.21%
7857	TPCODL	DHENKAN	TED	CHAINPAL	KHAMAR	14150	11 KV ODAUS	14150204	PADAPASI NUASAHI CLUB	4321DT033	100	MIXED	AMI	Yes	67%	76	0.02861454	0.016798	0.01181654	41.30%
7858	TPCODL	DHENKAN	TED	CHAINPAL	KUNJAM ODSSP	14332	11 KV NUAGAON	14332202	MUNDURIBEDA MAIN VILLAGE	4321DT562	100	MIXED	AMI	Yes	33%	105	0.03865012	0.023817	0.01483312	38.38%
7859	TPCODL	DHENKAN	TED	CHAINPAL	MERAMUNDALI OD	14330	11 KV KAMALANGA	14330202	MOTANGA 2	4313DT132	250	MIXED	AMI	Yes	100%	304	0.15202112	0.140212	0.01180912	7.77%
7860	TPCODL	DHENKAN	TED	CHAINPAL	MERAMUNDALI OD	14330	11 KV KAMALANGA	14330202	NAGARI CHASA SAHI 2	4313DT137	100	MIXED	AMI	Yes	100%	119	0.0368783	0.035626	0.0012523	3.40%
7861	TPCODL	DHENKAN	TED	CHAINPAL	MERAMUNDALI OD	14330	11 KV KAMALANGA	14330202	RANJASINGHA 1	4313DT139	250	MIXED	AMI	Yes	100%	235	0.1111126	0.072468	0.0386446	34.78%
7862	TPCODL	DHENKAN	TED	CHAINPAL	MERAMUNDALI OD	14330	11 KV KAMALANGA	14330202	SURAVI VILLAGE	4313DT146	100	MIXED	AMI	Yes	100%	92	0.0469475	0.027122	0.0198255	42.23%
7863	TPCODL	DHENKAN	TED	CHAINPAL	MERAMUNDALI OD	14330	11 KV KAMALANGA	14330202	TALADANGA UP SCHOOL	4313DT148	100	MIXED	AMI	Yes	100%	103	0.04147	0.030623	0.010847	26.16%
7864	TPCODL	DHENKAN	TED	CHAINPAL	MERAMUNDALI OD	14330	11 KV KAMALANGA	14330202	MERAMUNDULI GOVT HOSPITAL FRC	4313DT157	250	MIXED	AMI	Yes	100%	54	0.10252212	0.029953	0.07256912	70.78%
7865	TPCODL	DHENKAN	TED	CHAINPAL	MERAMUNDALI OD	14330	11 KV KAMALANGA	14330202	MERAMANDALI RAILWAY GATE BAZA	4313DT163	250	MIXED	AMI	Yes	0%	33	0.09766308	0.056702	0.04096108	41.94%
7866	TPCODL	DHENKAN	TED	CHAINPAL	MERAMUNDALI OD	14330	11 KV KAMALANGA	14330202	KHADAGPRASAD 7	4313DT174	500	MIXED	AMI	Yes	0%	291	0.2214664	0.109637	0.1118294	50.49%
7867	TPCODL	DHENKAN	TED	CHAINPAL	MERAMUNDALI OD	14330	11 KV KAMALANGA	14330202	KURUNTI PAIK SAHI	4313DT182	100	MIXED	AMI	Yes	100%	100	0.0728068	0.033443	0.0393638	54.07%
7868	TPCODL	DHENKAN	TED	CHAINPAL	MERAMUNDALI OD	14330	11 KV KAMALANGA	14330202	KUSUPANGA NO-1	4313DT189	100	MIXED	AMI	Yes	100%	187	0.1083649	0.077018	0.0313469	28.93%
7869	TPCODL	DHENKAN	TED	CHAINPAL	MERAMUNDALI OD	14330	11 KV KAMALANGA	14330202	KUSUPANGA NO-2	4313DT190	100	MIXED	AMI	Yes	100%	74	0.07735158	0.028235	0.04911658	63.50%
7870	TPCODL	DHENKAN	TED	CHAINPAL	MERAMUNDALI OD	14330	11 KV KAMALANGA	14330202	MANGALAPUR UP SCHOOL	4313DT200	100	MIXED	AMI	Yes	100%	68	0.08037794	0.029349	0.05102894	63.49%
7871	TPCODL	DHENKAN	TED	CHAINPAL	MERAMUNDALI OD	14330	11 KV KAMALANGA	14330202	MANGALAPUR H.SAHI 3	4313DT207	250	MIXED	AMI	Yes	100%	90	0.07746504	0.045612	0.03185304	41.12%
7872	TPCODL	DHENKAN	TED	CHAINPAL	MERAMUNDALI OD	14330	11 KV KAMALANGA	14330202	MANPUR 1	4313DT209	100	MIXED	AMI	Yes	100%	151	0.07558734	0.065169	0.01041834	13.78%
7873	TPCODL	DHENKAN	TED	CHAINPAL	MERAMUNDALI OD	14330	11 KV KAMALANGA	14330202	ITAP VILLAGE	4313DT233	100	MIXED	AMI	Yes	100%	85	0.07797972	0.070112	0.00786772	10.09%
7874	TPCODL	DHENKAN	TED	CHAINPAL	MERAMUNDALI OD	14330	11 KV KAMALANGA	14330202	KANTABANIA	4313DT248	250	MIXED	AMI	Yes	100%	169	0.20547676	0.193717	0.01175976	5.72%
7875	TPCODL	DHENKAN	TED	CHAINPAL	MERAMUNDALI OD	14330	11 KV KAMALANGA	14330202	KANTABANIA UP SCHOOL	4313DT249	100	MIXED	AMI	Yes	100%	79	0.14337882	0.085597	0.05778182	40.30%
7876	TPCODL	DHENKAN	TED	CHAINPAL	MERAMUNDALI OD	14330	11 KV KAMALANGA	14330202	MANAPUR HIGH SCHOOL	4313DT253	250	MIXED	AMI	Yes	100%	238	0.102369	0.072247	0.030122	29.42%
7877	TPCODL	DHENKAN	TED	CHAINPAL	MERAMUNDALI OD	14330	11 KV KAMALANGA	14330202	MANPUR 2	4313DT260	100	MIXED	AMI	Yes	100%	89	0.08109432	0.032482	0.04861232	59.95%
7878	TPCODL	DHENKAN	TED	CHAINPAL	MERAMUNDALI OD	14330	11 KV KAMALANGA	14330202	KAMALANGA NO-1	4313DT274	100	MIXED	AMI	Yes	67%	171	0.08264494	0.064385	0.01825994	22.09%
7879	TPCODL	DHENKAN	TED	CHAINPAL	MERAMUNDALI OD	14330	11 KV KAMALANGA	14330202	KALIA TAILA	4313DT280	100	MIXED	AMI	Yes	100%	81	0.04430106	0.026809	0.01749206	39.48%
7880	TPCODL	DHENKAN	TED	CHAINPAL	MERAMUNDALI OD	14330	11 KV KAMALANGA	14330202	KOCHILAMADA UP SCHOOL 1	4313DT317	250	MIXED	AMI	Yes	100%	219	0.1621322	0.073035	0.0890972	54.95%
7881	TPCODL	DHENKAN	TED	CHAINPAL	MERAMUNDALI OD	14330	11 KV KAMALANGA	14330202	KHADAGPRASAD ANGANWARI 2	4313DT326	100	MIXED	AMI	Yes	100%	65	0.07297617	0.031475	0.04150117	56.87%
7882	TPCODL	DHENKAN	TED	CHAINPAL	MERAMUNDALI OD	14330	11 KV KAMALANGA	14330202	KHADAGPRASAD 6	4313DT328	250	MIXED	AMI	Yes	0%	187	0.19305328	0.08044	0.11261328	58.33%
7883	TPCODL	DHENKAN	TED	CHAINPAL	MERAMUNDALI OD	14330	11 KV KAMALANGA	14330202	MERAMANDALI BY-PASS CHHAK NEA	4313DT338	100	MIXED	AMI	Yes	100%	10	0.02487012	0.01094	0.01393012	56.01%

Sl. No.	Zone Name	Circle name	Division name	Name of the Sub-division	Name of the Sub-station	Substation Code	Name of the 11 kV Feeder	Feeder Code	Name of the Location where DT situated	DT code	DT Capacity (kVA)	Predominant consumer type of DT (Domestic/Industrial/Agriculture/Mixed)	Type of metering AMR/AMI/ Communicable/Conventional metered/Unmetered	Status of Meter-whether Functional (Yes/No)	% of data received automatically (if AMR/AMI)	No. of Connected Consumers	Input Energy (MU) (A)	Billed Energy (MU) (B)	Loss (MU) (A-B)	% DT Loss (A-B)/A
7884	TPCODL	DHENKAN	TED	CHAINPAL	MERAMUNDALI OD	14330	11 KV KAMALANGA	14330202	KHADAGPRASAD PATNA UP SCHOOL	4313DT355	100	MIXED	AMI	Yes	100%	60	0.04504905	0.020042	0.02500705	55.51%
7885	TPCODL	DHENKAN	TED	CHAINPAL	MERAMUNDALI OD	14330	11 KV PURUNAKOT	14330203	GALAPADA	4313DT029	250	MIXED	AMI	Yes	100%	161	0.09142932	0.068025	0.02340432	25.60%
7886	TPCODL	DHENKAN	TED	CHAINPAL	MERAMUNDALI OD	14330	11 KV PURUNAKOT	14330203	BERUANPAL NO-1	4313DT034	100	MIXED	AMI	Yes	100%	48	0.02399284	0.01361	0.01038284	43.27%
7887	TPCODL	DHENKAN	TED	CHAINPAL	MERAMUNDALI OD	14330	11 KV PURUNAKOT	14330203	BERUANPAL NO-2	4313DT035	100	MIXED	AMI	Yes	100%	43	0.02878454	0.020196	0.00858854	29.84%
7888	TPCODL	DHENKAN	TED	CHAINPAL	MERAMUNDALI OD	14330	11 KV PURUNAKOT	14330203	KANKALU UP SCHOOL	4313DT072	250	MIXED	AMI	Yes	67%	259	0.10130204	0.082588	0.01871404	18.47%
7889	TPCODL	DHENKAN	TED	CHAINPAL	MERAMUNDALI OD	14330	11 KV PURUNAKOT	14330203	BRAHAMAN PURUNAKOTE 2	4313DT079	100	MIXED	AMI	Yes	67%	69	0.02748116	0.013802	0.01367916	49.78%
7890	TPCODL	DHENKAN	TED	CHAINPAL	MERAMUNDALI OD	14330	11 KV PURUNAKOT	14330203	NADEILO 2	4313DT082	100	MIXED	AMI	Yes	67%	35	0.01856894	0.007415	0.01115394	60.07%
7891	TPCODL	DHENKAN	TED	CHAINPAL	MERAMUNDALI OD	14330	11 KV PURUNAKOT	14330203	KHALIBELA 2	4313DT084	100	MIXED	AMI	Yes	67%	30	0.02222202	0.010153	0.01206902	54.31%
7892	TPCODL	DHENKAN	TED	CHAINPAL	MERAMUNDALI OD	14330	11 KV PURUNAKOT	14330203	BASUBAHALA 2	4313DT093	100	MIXED	AMI	Yes	67%	110	0.04088132	0.02507	0.01581132	38.68%
7893	TPCODL	DHENKAN	TED	CHAINPAL	MERAMUNDALI OD	14330	11 KV PURUNAKOT	14330203	BADIBAHALA	4313DT096	100	MIXED	AMI	Yes	67%	124	0.0543899	0.036699	0.0176909	32.53%
7894	TPCODL	DHENKAN	TED	CHAINPAL	MERAMUNDALI OD	14330	11 KV PURUNAKOT	14330203	PURUNAKOTE	4313DT101	100	MIXED	AMI	Yes	67%	60	0.03579334	0.01658328	0.01921006	53.67%
7895	TPCODL	DHENKAN	TED	CHAINPAL	MERAMUNDALI OD	14330	11 KV PURUNAKOT	14330203	PAIKPURUNAKOTE NARAHARIPUR	4313DT107	100	MIXED	AMI	Yes	67%	46	0.02517094	0.01579	0.00938094	37.27%
7896	TPCODL	DHENKAN	TED	CHAINPAL	MERAMUNDALI OD	14330	11 KV PURUNAKOT	14330203	RAGHUNATHPUR 1	4313DT116	100	MIXED	AMI	Yes	67%	67	0.07016166	0.025474	0.04468766	63.69%
7897	TPCODL	DHENKAN	TED	CHAINPAL	MERAMUNDALI OD	14330	11 KV PURUNAKOT	14330203	SARAPA	4313DT121	100	MIXED	AMI	Yes	67%	46	0.03422778	0.013345	0.02088278	61.01%
7898	TPCODL	DHENKAN	TED	CHAINPAL	MERAMUNDALI OD	14330	11 KV PURUNAKOT	14330203	JHADABANDHA FOUR SQUARE	4313DT129	100	MIXED	AMI	Yes	0%	90	0.08074383	0.042007	0.03873683	47.97%
7899	TPCODL	DHENKAN	TED	CHAINPAL	PHULAPADA ODSSP	14337	11 KV PHULPADA	14337201	PHULAPADA-1	4311DT454	100	MIXED	AMI	Yes	0%	45	0.0658378	0.015766	0.0500718	76.05%
7900	TPCODL	DHENKAN	TED	CHAINPAL	PHULAPADA ODSSP	14337	11 KV PHULPADA	14337201	SANTARAPUR	4311DT462	63	MIXED	AMI	Yes	67%	129	0.05148414	0.03131	0.02017414	39.19%
7901	TPCODL	DHENKAN	TED	CHAINPAL	PHULAPADA ODSSP	14337	11 KV PHULPADA	14337201	PHULPADA-3	4311DT480	100	MIXED	AMI	Yes	67%	81	0.07853232	0.042495	0.03603732	45.89%
7902	TPCODL	DHENKAN	TED	CHAINPAL	PHULAPADA ODSSP	14337	11 KV PHULPADA	14337201	TILAPANGA	4311DT487	100	MIXED	AMI	Yes	0%	51	0.03389234	0.010444	0.02344834	69.18%
7903	TPCODL	DHENKAN	TED	CHAINPAL	PHULAPADA ODSSP	14337	11 KV PHULPADA	14337201	TALAMULA SASAN KEUTA SAHI	4311DT512	100	MIXED	AMI	Yes	0%	23	0.0144292	0.004795	0.0096342	66.77%
7904	TPCODL	DHENKAN	TED	CHAINPAL	PHULAPADA ODSSP	14337	11 KV PHULPADA	14337201	GADA TALAMULA SAHI	4311DT522	100	MIXED	AMI	Yes	67%	156	0.06499134	0.061159	0.00383234	5.90%
7905	TPCODL	DHENKAN	TED	CHAINPAL	PHULAPADA ODSSP	14337	11 KV PHULPADA	14337201	GADATALAMULA-2	4311DT537	100	MIXED	AMI	Yes	67%	24	0.028299	0.009337	0.018962	67.01%
7906	TPCODL	DHENKAN	TED	CHAINPAL	PHULAPADA ODSSP	14337	11 KV PHULPADA	14337201	TALMULA HADI SAHI-1	4311DT542	100	MIXED	AMI	Yes	67%	60	0.0670396	0.023605	0.0434346	64.79%
7907	TPCODL	DHENKAN	TED	CHAINPAL	PHULAPADA ODSSP	14337	11 KV PHULPADA	14337201	TALMULA SASAN DHABALESWAR TEN	4311DT543	250	MIXED	AMI	Yes	0%	101	0.07854288	0.04297	0.03557288	45.29%
7908	TPCODL	DHENKAN	TED	CHAINPAL	PHULAPADA ODSSP	14337	11 KV PHULPADA	14337201	TALMULA SASAN DHABALESWAR TEN	4311DT544	250	MIXED	AMI	Yes	67%	172	0.10693376	0.051623	0.05531076	51.72%
7909	TPCODL	DHENKAN	TED	CHAINPAL	PHULAPADA ODSSP	14337	11 KV PHULPADA	14337201	TALMULA CHANDANPUR	4311DT551	250	MIXED	AMI	Yes	67%	144	0.15721212	0.076972	0.08024012	51.04%
7910	TPCODL	DHENKAN	TED	PALLAHARA	KHAMAR	14150	11 kV BARKOTIA	14150202	KHEMELA BUS STANDA	4321DT277	63	MIXED	AMI	Yes	0%	46	0.01263816	0.010086	0.00255216	20.19%
7911	TPCODL	DHENKAN	TED	PALLAHARA	PARABIL	14149	11 kV PARABIL	14149201	PARABIL PUJAGHARA	4323DT032	63	MIXED	AMI	Yes	100%	92	0.05584596	0.054936	0.00090996	1.63%
7912	TPCODL	DHENKAN	TED	PALLAHARA	BARUAN	14152	11 KV TUMUGAL	14152201	KADAPADA	4323DT386	100	MIXED	AMI	Yes	67%	109	0.02709428	0.023135	0.00395928	14.61%
7913	TPCODL	DHENKAN	TED	PALLAHARA	HANUMANPUR ODS	14334	11 KV BAJRAKOTE	14334201	BAJRAKOTE HATA CHHAKA	4324DT007	100	MIXED	AMI	Yes	0%	115	0.12818556	0.028584	0.09960156	77.70%
7914	TPCODL	DHENKAN	TED	PALLAHARA	HANUMANPUR ODS	14334	11 KV BAJRAKOTE	14334201	BAJRAKOTE MANDIR SAHI	4324DT010	100	MIXED	AMI	Yes	0%	145	0.10050414	0.03568	0.06482414	64.50%
7915	TPCODL	DHENKAN	TED	PALLAHARA	HANUMANPUR ODS	14334	11 KV BAJRAKOTE	14334201	BAJRAKOTE PAIK SAHI	4324DT022	100	MIXED	AMI	Yes	0%	105	0.0533822	0.024619	0.0287632	53.88%
7916	TPCODL	DHENKAN	TED	PALLAHARA	HANUMANPUR ODS	14334	11 KV BAJRAKOTE	14334201	KHALAPALA TALA SAHI	4324DT051	250	MIXED	AMI	Yes	33%	130	0.0494692	0.032974	0.0164952	33.34%
7917	TPCODL	DHENKAN	TED	PALLAHARA	HANUMANPUR ODS	14334	11 KV BAJRAKOTE	14334201	OLANDA TALA SAHI	4324DT062	100	MIXED	AMI	Yes	0%	202	0.06154724	0.036124	0.02542324	41.31%
7918	TPCODL	DHENKAN	TED	PALLAHARA	HANUMANPUR ODS	14334	11 KV BAJRAKOTE	14334201	SUAJHARI 1	4324DT065	100	MIXED	AMI	Yes	0%	111	0.04705524	0.025186	0.02186924	46.48%
7919	TPCODL	DHENKAN	TED	PALLAHARA	HANUMANPUR ODS	14334	11 KV BAJRAKOTE	14334201	BARAPADA PURUNA SAHI 1	4324DT072	100	MIXED	AMI	Yes	0%	95	0.0263875	0.020288	0.0060995	23.12%
7920	TPCODL	DHENKAN	TED	PALLAHARA	HANUMANPUR ODS	14334	11 KV BAJRAKOTE	14334201	BALIPASI GP OFFICE	4324DT191	100	MIXED	AMI	Yes	0%	65	0.0217843	0.013372	0.0084123	38.62%
7921	TPCODL	DHENKAN	TED	PALLAHARA	HANUMANPUR ODS	14334	11 KV GUNDURI	14334203	NALAM BARAPALA SAHI	4324DT110	100	MIXED	AMI	Yes	0%	26	0.03164334	0.007256	0.02438734	77.07%
7922	TPCODL	DHENKAN	TED	PALLAHARA	HANUMANPUR ODS	14334	11 KV GUNDURI	14334203	TITIRIMA 2	4324DT137	100	MIXED	AMI	Yes	100%	82	0.02350036	0.013159	0.01034136	44.01%
7923	TPCODL	DHENKAN	TED	PALLAHARA	HANUMANPUR ODS	14334	11 KV GUNDURI	14334203	KANTAPAL	4324DT142	100	MIXED	AMI	Yes	0%	119	0.06080076	0.026075	0.03472576	57.11%
7924	TPCODL	DHENKAN	TED	PALLAHARA	HANUMANPUR ODS	14334	11 KV GUNDURI	14334203	POIPAL 2	4324DT145	100	MIXED	AMI	Yes	0%	121	0.03410408	0.020129	0.01397508	40.98%
7925	TPCODL	DHENKAN	TED	PALLAHARA	HANUMANPUR ODS	14334	11 KV GUNDURI	14334203	TALAPADA 3	4324DT217	250	MIXED	AMI	Yes	33%	96	0.0526648	0.025264	0.0274008	52.03%
7926	TPCODL	DHENKAN	TED	PALLAHARA	HANUMANPUR ODS	14334	11 KV GUNDURI	14334203	SADANANDA HIGH SCHOOL TALAPAD	4324DT219	100	MIXED	AMI	Yes	0%	73	0.03526128	0.012918	0.02234328	63.36%
7927	TPCODL	DHENKAN	TED	PALLAHARA	HANUMANPUR ODS	14334	11 KV GUNDURI	14334203	DURGAPUR BISWAL SAHI	4324DT227	100	MIXED	AMI	Yes	0%	59	0.0336104	0.019541	0.0140694	41.86%
7928	TPCODL	DHENKAN	TED	PALLAHARA	HATATOTA	14145	11 KV Hatatota RE-2	14145202	BALUNGA OLD VILLAGE	4341DT295	100	MIXED	AMI	Yes	100%	66	0.07335866	0.042527	0.03083166	42.03%
7929	TPCODL	DHENKAN	TED	PALLAHARA	KANIHA	14148	11 KV DERANGA	14148206	SANAKAKUDIA	4342DT124	100	MIXED	AMI	Yes	33%	109	0.07711336	0.031812	0.04530136	58.75%
7930	TPCODL	DHENKAN	TED	PALLAHARA	KANIHA	14148	11 KV DERANGA	14148206	BADAKAKUDIA	4342DT162	250	MIXED	AMI	Yes	0%	161	0.08499916	0.038627	0.04637216	54.56%
7931	TPCODL	DHENKAN	TED	PALLAHARA	KANTALA ODSSP	14338	11 KV JHARBEDA	14338203	JHARALO 2	4322DT612	100	MIXED	AMI	Yes	0%	72	0.0196979	0.01209228	0.00760562	38.61%
7932	TPCODL	DHENKAN	TED	PALLAHARA	KHAMAR	14150	11 KV BARKOTIA	14150202	NEMIRIBEDA SANASADA	4321DT206	100	MIXED	AMI	Yes	0%	66	0.02482784	0.020106	0.00472184	19.02%
7933	TPCODL	DHENKAN	TED	PALLAHARA	KHAMAR	14150	11 KV BARKOTIA	14150202	NUAPADA	4321DT209	100	MIXED	AMI	Yes	0%	43	0.03606882	0.011508	0.02456082	68.09%
7934	TPCODL	DHENKAN	TED	PALLAHARA	KHAMAR	14150	11 KV BARKOTIA	14150202	NEMERIBEDA 3	4321DT236	250	MIXED	AMI	Yes	100%	98	0.05090988	0.033257	0.01765288	34.67%
7935	TPCODL	DHENKAN	TED	PALLAHARA	KHAMAR	14150	11 KV SANKHAMUR	14150203	KASTURBA GANDHI BALIKA VIDYALAY	4321DT071	250	MIXED	AMI	Yes	0%	121	0.1282566	0.088368	0.0398886	31.10%
7936	TPCODL	DHENKAN	TED	PALLAHARA	KHAMAR	14150	11 KV SANKHAMUR	14150203	KHAMAR RENGALI ROAD STAND	4321DT080	250	MIXED	AMI	Yes	0%	156	0.16032972	0.096285	0.06404472	39.95%
7937	TPCODL	DHENKAN	TED	PALLAHARA	KHAMAR	14150	11 KV SANKHAMUR	14150203	KHAMAR COLLAGE 1	4321DT081	100	MIXED	AMI	Yes	67%	30	0.03772356	0.029233	0.00849056	22.51%
7938	TPCODL	DHENKAN	TED	PALLAHARA	KHAMAR	14150	11 KV SANKHAMUR	14150203	KHAMAR HOSPITAL	4321DT083	250	MIXED	AMI	Yes	100%	81	0.08054088	0.07165	0.00889088	11.04%
7939	TPCODL	DHENKAN	TED	PALLAHARA	KHAMAR	14150	11 KV SANKHAMUR	14150203	JENAPADA MAIN VILLAGE	4321DT093	100	MIXED	AMI	Yes	100%	66	0.04163678	0.01884	0.02279678	54.75%
7940	TPCODL	DHENKAN	TED	PALLAHARA	KHAMAR	14150	11 KV SANKHAMUR	14150203	GARADAMUNDA -2	4321DT142	100	MIXED	AMI	Yes	100%	137	0.03291794	0.03129511	0.00162283	4.93%
7941	TPCODL	DHENKAN	TED	PALLAHARA	KHAMAR	14150	11 KV SANKHAMUR	14150203	PANIHARA MAIN VILLAGE	4321DT168	100	MIXED	AMI	Yes	0%	93	0.02416796	0.014861	0.00930696	38.51%
7942	TPCODL	DHENKAN	TED	PALLAHARA	KHAMAR	14150	11 KV SANKHAMUR	14150203	PARACHHAT2	4321DT197	100	MIXED	AMI	Yes	0%	59	0.02307342	0.007176	0.01589742	68.90%
7943	TPCODL	DHENKAN	TED	PALLAHARA	KHAMAR	14150	11 KV ODAUS	14150204	KHAMAR NUAPALI SAHI	4321DT004	100	MIXED	AMI	Yes	33%	42	0.01404542	0.00852	0.00552542	39.34%
7944	TPCODL	DHENKAN	TED	PALLAHARA	KHAMAR	14150	11 KV ODAUS	14150204	ODASA HADI SAHI	4321DT005	100	MIXED	AMI	Yes	33%	95	0.05763134	0.04703	0.01060134	18.40%
7945	TPCODL	DHENKAN	TED	PALLAHARA	KHAMAR	14150	11 KV ODAUS	14150204	PADAPASI TAILA SAHI	4321DT032	100	MIXED	AMI	Yes	67%	85	0.01877514	0.015358	0.00341714	18.20%
7946	TPCODL	DHENKAN	TED	PALLAHARA	KHAMAR	14150	11 KV ODAUS	14150204	ODASA UP SCHOOL-2	4321DT063	250	MIXED	AMI	Yes	100%	61	0.0420236	0.034775	0.0072486	17.25%
7947	TPCODL	DHENKAN	TED	PALLAHARA	KUNJAM ODSSP	14332	11 KV INJIDI	14332201	INJIDI 1	4321DT480	100	MIXED	AMI	Yes	33%	89	0.05152162	0.024869	0.02665262	51.73%
7948	TPCODL	DHENKAN	TED	PALLAHARA	KUNJAM ODSSP	14332	11 KV NUAGAON	14332202	SAREI MAIN VILLAGE	4321DT570	100	MIXED	AMI	Yes	0%	89	0.0449154	0.010051	0.0348644	77.62%
7949	TPCODL	DHENKAN	TED	PALLAHARA	KUNJAM ODSSP	14332	11 KV NUAGAON	14332202	KHALICHANDIA MAIN VILLAGE	4321DT670	100	MIXED	AMI	Yes	0%	66	0.02424092	0.009176	0.01506492	62.15%
7950	TPCODL	DHENKAN	TED	PALLAHARA	KUNJAM ODSSP	14332	11 KV NUAGAON	14332202	KOCHIABEDA MAIN VILLAGE	4321DT678	100	MIXED	AMI	Yes	33%	68	0.01902439	0.013738	0.00528639	27.79%
7951	TPCODL	DHENKAN	TED	PALLAHARA	OHPC	14186	11 KV RENGALI	14186201	DENALI NAIK SAHI 1	4324DT040	100	MIXED	AMI	Yes	0%	98	0.0509831	0.018193	0.0327901	64.32%
7952	TPCODL	DHENKAN	TED	PALLAHARA	OHPC	14186	11 KV RENGALI	14186201	RENGALI JHARA SAHI	4324DT045	100	MIXED	AMI	Yes	0%	86	0.05277206	0.021078	0.03169406	60.06%
7953	TPCODL	DHENKAN	TED	PALLAHARA	OHPC	14186	11 KV RENGALI	14186201	RENGALI MANDIRA CHHAK 2	4324DT047	250	MIXED	AMI	Yes	33%	99	0.03670648	0.017276	0.01943048	52.93%
7954	TPCODL	DHENKAN	TED	PALLAHARA	PALLAHARA	14151	11 KV TOWN (PALLAHAR	14151201	RAM MANDIR	4322DT401	100	MIXED	AMI	Yes	100%	25	0.01434364	0.007939	0.00640464	44.65%
7955	TPCODL	DHENKAN	TED	PALLAHARA	PALLAHARA	14151	11 KV TOWN (PALLAHAR	14151201	SAMART SAHI	4322DT405	100	MIXED	AMI	Yes	100%	108	0.09950032	0.064725	0.03477532	34.95%
7956	TPCODL	DHENKAN	TED	PALLAHARA	PALLAHARA	14151	11 KV TOWN (PALLAHAR	14151201	GUDIBANDHA-I	4322DT410	100	MIXED	AMI	Yes	0%	97	0.10177066	0.065738	0.03603266	35.41%

Sl. No.	Zone Name	Circle name	Division name	Name of the Sub-division	Name of the Sub-station	Substation Code	Name of the 11 kV Feeder	Feeder Code	Name of the Location where DT situated	DT code	DT Capacity (kVA)	Predominant consumer type of DT (Domestic/Industrial/Agriculture/Mixed)	Type of metering AMR/AMI/ Communicable/Conventional metered/Unmetered	Status of Meter- whether Functional (Yes/No)	% of data received automatically (if AMR/AMI)	No. of Connected Consumers	Input Energy (MU) (A)	Billed Energy (MU) (B)	Loss (MU) (A-B)	% DT Loss (A-B)/A
7957	TPCODL	DHENKAN	TED	PALLAHARA	PALLAHARA	14151	11 KV TOWN (PALLAHAR	14151201	BAPUJINAGAR	4322DT463	100	MIXED	AMI	Yes	100%	103	0.09850488	0.071229	0.02727588	27.69%
7958	TPCODL	DHENKAN	TED	PALLAHARA	PALLAHARA	14151	11 KV TOWN (PALLAHAR	14151201	PATBEDA 1	4322DT466	100	MIXED	AMI	Yes	0%	50	0.03337902	0.01907	0.01430902	42.87%
7959	TPCODL	DHENKAN	TED	PALLAHARA	PALLAHARA	14151	11 KV TOWN (PALLAHAR	14151201	NH -250KV	4322DT479	250	MIXED	AMI	Yes	67%	124	0.1864356	0.095563	0.0908726	48.74%
7960	TPCODL	DHENKAN	TED	PALLAHARA	PALLAHARA	14151	11 KV SEEGARH	14151203	SEA GARH MAIN VILLAGE	4322DT020	100	MIXED	AMI	Yes	100%	151	0.06044026	0.042538	0.01790226	29.62%
7961	TPCODL	DHENKAN	TED	PALLAHARA	PALLAHARA	14151	11 KV SEEGARH	14151203	NAIKANIPALI	4322DT026	100	MIXED	AMI	Yes	100%	17	0.02785374	0.008531	0.01932274	69.37%
7962	TPCODL	DHENKAN	TED	PALLAHARA	PALLAHARA	14151	11 KV PHAPAND	14151204	CHASAGURUJANGA-1	4322DT240	100	MIXED	AMI	Yes	67%	155	0.02576832	0.024535	0.00123332	4.79%
7963	TPCODL	DHENKAN	TED	PALLAHARA	PALLAHARA	14151	11 KV PHAPAND	14151204	SANBAGADARI MAIN VILLAGE	4322DT639	100	MIXED	AMI	Yes	33%	64	0.01135378	0.00793058	0.0034232	30.15%
7964	TPCODL	DHENKAN	TED	PALLAHARA	PALLAHARA	14151	11 KV BATISUAN	14151205	GURUNDIAMUNDA 2	4322DT161	100	MIXED	AMI	Yes	0%	80	0.0547848	0.01103127	0.04375353	79.86%
7965	TPCODL	DHENKAN	TED	PALLAHARA	PALLAHARA	14151	11 KV BATISUAN	14151205	JHIMIRIPALI 6	4322DT372	100	MIXED	AMI	Yes	0%	126	0.09838612	0.029687	0.06869912	69.83%
7966	TPCODL	DHENKAN	TED	PALLAHARA	PALLAHARA	14151	11 KV BATISUAN	14151205	PURUNA PANI	4322DT571	100	MIXED	AMI	Yes	0%	110	0.02204894	0.008441	0.01360794	61.72%
7967	TPCODL	DHENKAN	TED	PALLAHARA	PARABIL	14149	11 KV PARABIL	14149201	MAHIDHARPUR UP SCHOOL	4323DT023	100	MIXED	AMI	Yes	33%	142	0.0480684	0.030653	0.0174154	36.23%
7968	TPCODL	DHENKAN	TED	PALLAHARA	PARABIL	14149	11 KV PARABIL	14149201	PARABIL THAKURAGHARA 1	4323DT035	250	MIXED	AMI	Yes	67%	168	0.08972216	0.05742	0.03230216	36.00%
7969	TPCODL	DHENKAN	TED	PALLAHARA	PARABIL	14149	11 KV PARABIL	14149201	GAUNIGHASA UP SCHOOL	4323DT044	100	MIXED	AMI	Yes	0%	170	0.02930558	0.024469	0.00483658	16.50%
7970	TPCODL	DHENKAN	TED	PALLAHARA	PARABIL	14149	11 KV PARABIL	14149201	SARADHAPUR TELI SAHI 2	4323DT087	100	MIXED	AMI	Yes	67%	162	0.07294334	0.039831	0.03311234	45.39%
7971	TPCODL	DHENKAN	TED	PALLAHARA	PARABIL	14149	11 KV PARABIL	14149201	BURUKUNA	4323DT120	250	MIXED	AMI	Yes	33%	170	0.0466286	0.02508281	0.02154579	46.21%
7972	TPCODL	DHENKAN	TED	PALLAHARA	PARABIL	14149	11 KV ARKIL	14149202	SEEPUR	4323DT180	100	MIXED	AMI	Yes	67%	42	0.06816146	0.015166	0.05299546	77.75%
7973	TPCODL	DHENKAN	TED	PALLAHARA	PARABIL	14149	11 KV ARKIL	14149202	ARKIL JATRA PADIA	4323DT218	100	MIXED	AMI	Yes	33%	135	0.04822416	0.03100519	0.01721897	35.71%
7974	TPCODL	DHENKAN	TED	PALLAHARA	PARABIL	14149	11 KV ARKIL	14149202	ARKIL TALA SAHI	4323DT222	100	MIXED	AMI	Yes	0%	162	0.03964538	0.032501	0.00714438	18.02%
7975	TPCODL	DHENKAN	TED	PALLAHARA	PARABIL	14149	11 KV GAHAM	14149203	PRADHAN SAHI	4323DT007	100	MIXED	AMI	Yes	100%	95	0.0229439	0.015917	0.0070269	30.63%
7976	TPCODL	DHENKAN	TED	PALLAHARA	PARABIL	14149	11 KV GAHAM	14149203	GAHAM MAHULA MUNDA	4323DT009	100	MIXED	AMI	Yes	100%	80	0.04887582	0.02519	0.02368582	48.46%
7977	TPCODL	DHENKAN	TED	PALLAHARA	TALCHER-2 NTPC	14375	11 KV TALCHER PALACE	14375201	AMALAPADA	4345DT303	100	MIXED	AMI	Yes	100%	69	0.09080082	0.051732	0.03906882	43.03%
7978	TPCODL	DHENKAN	TED	PALLAHARA	TALCHER-2 NTPC	14375	11 KV TALCHER PALACE	14375201	BEBARTTAMUNDA	4345DT346	100	MIXED	AMI	Yes	100%	61	0.09193702	0.034119	0.05781802	62.89%
7979	TPCODL	DHENKAN	TED	PARJANG	GODIBANDHA (BAN	14339	11 kV BHEJIA	14339204	GURUJANGULI_01	4332DT214	100	MIXED	AMI	Yes	33%	133	0.02636647	0.01917797	0.0071885	27.26%
7980	TPCODL	DHENKAN	TED	PARJANG	MAHABIR ROAD OD	14336	11 kV MAHABIR ROAD	14336202	MAHABIROD DHABULI PATHAR SAHI	4332DT266	100	MIXED	AMI	Yes	67%	79	0.02346236	0.01816456	0.0052978	22.58%
7981	TPCODL	DHENKAN	TED	PARJANG	GODIBANDHA (BAN	14339	11 KV DADRAHATI	14339201	BHEJIA NO_04	4332DT154	100	MIXED	AMI	Yes	33%	43	0.01701032	0.011437	0.00557332	32.76%
7982	TPCODL	DHENKAN	TED	PARJANG	GODIBANDHA (BAN	14339	11 KV BHEJIA	14339204	GATAREI PLAY GROUND	4332DT197	25	MIXED	AMI	Yes	67%	33	0.01444826	0.007511	0.00693726	48.01%
7983	TPCODL	DHENKAN	TED	PARJANG	GODIBANDHA (BAN	14339	11 KV BHEJIA	14339204	BIRIBOLEI NEAR JANTA HIGH SCHOOL	4332DT203	100	MIXED	AMI	Yes	33%	91	0.02811938	0.020757	0.00736238	26.18%
7984	TPCODL	DHENKAN	TED	PARJANG	GODIBANDHA (BAN	14339	11 KV BHEJIA	14339204	BIRIBOLEI GP OFFICE	4332DT204	100	MIXED	AMI	Yes	33%	156	0.04098542	0.032093	0.00889242	21.70%
7985	TPCODL	DHENKAN	TED	PARJANG	GODIBANDHA (BAN	14339	11 KV BHEJIA	14339204	GURUJANGULI_02	4332DT215	100	MIXED	AMI	Yes	33%	78	0.02699788	0.013495	0.01350288	50.01%
7986	TPCODL	DHENKAN	TED	PARJANG	GODIBANDHA (BAN	14339	11 KV BHEJIA	14339204	CHANDAPUR_01	4332DT229	100	MIXED	AMI	Yes	33%	137	0.03235834	0.0256972	0.00666114	20.59%
7987	TPCODL	DHENKAN	TED	PARJANG	GODIBANDHA (BAN	14339	11 KV BHEJIA	14339204	CHANDAPUR_02	4332DT230	100	MIXED	AMI	Yes	33%	145	0.0355059	0.02475961	0.01074629	30.27%
7988	TPCODL	DHENKAN	TED	PARJANG	GODIBANDHA (BAN	14339	11 KV BHEJIA	14339204	JANGU_02	4332DT283	100	MIXED	AMI	Yes	33%	140	0.03677843	0.025921	0.01085743	29.52%
7989	TPCODL	DHENKAN	TED	PARJANG	GODIBANDHA (BAN	14339	11 KV BHEJIA	14339204	GHAGARAMUNDA	4332DT286	100	MIXED	AMI	Yes	33%	133	0.03467924	0.027918	0.00676124	19.50%
7990	TPCODL	DHENKAN	TED	PARJANG	GODIBANDHA (BAN	14339	11 KV BHEJIA	14339204	GHAGARAMUNDA TALA SAHI	4332DT290	100	MIXED	AMI	Yes	33%	102	0.0398302	0.01846	0.0213702	53.65%
7991	TPCODL	DHENKAN	TED	PARJANG	MAHABIR ROAD OD	14336	11 KV PANGATIRA	14336201	PANGATIRA NAIK SAHI	4332DT304	250	MIXED	AMI	Yes	67%	170	0.0489408	0.03724	0.0117008	23.91%
7992	TPCODL	DHENKAN	TED	PARJANG	MAHABIR ROAD OD	14336	11 kV PANGATIRA	14336201	DASIPUR BHALUMUNDA SAHI	4332DT404	100	MIXED	AMI	Yes	67%	57	0.0189128	0.011561	0.0073518	38.87%
7993	TPCODL	DHENKAN	TED	PARJANG	MAHABIR ROAD OD	14336	11 kV MAHABIR ROAD	14336202	MAHABIROD TALA SAHI (POND)	4332DT254	100	MIXED	AMI	Yes	67%	73	0.02079594	0.01842493	0.00237101	11.40%
7994	TPCODL	DHENKAN	TED	PARJANG	MAHABIR ROAD OD	14336	11 kV MAHABIR ROAD	14336202	MAHABIROD DHABULI PATHAR SAHI	4332DT267	100	MIXED	AMI	Yes	67%	58	0.01755468	0.013079	0.00447568	25.50%
7995	TPCODL	DHENKAN	TED	PARJANG	MAHABIR ROAD OD	14336	GADAPALASUNI KUTURI	14336203	MAHABIROD MEDICAL CHHAK	4332DT275	250	MIXED	AMI	Yes	67%	78	0.04967956	0.036358	0.01332156	26.81%
7996	TPCODL	DHENKAN	TED	PARJANG	MAHABIR ROAD OD	14336	GADAPALASUNI KUTURI	14336203	GADAPALASUNI MARKET	4332DT369	250	MIXED	AMI	Yes	67%	223	0.17875016	0.102789	0.07596116	42.50%
7997	TPCODL	DHENKAN	TED	PARJANG	MAHABIR ROAD OD	14336	GADAPALASUNI KUTURI	14336203	GADAPALASUNI	4332DT377	500	MIXED	AMI	Yes	0%	235	0.1013967	0.05682	0.0445767	43.96%
7998	TPCODL	DHENKAN	TED	PARJANG	MAHABIR ROAD OD	14336	GADAPALASUNI KUTURI	14336203	DEHURIHATA	4332DT392	100	MIXED	AMI	Yes	67%	94	0.02009178	0.014299	0.00579278	28.83%
7999	TPCODL	DHENKAN	TED	PARJANG	MAHABIR ROAD OD	14336	GADAPALASUNI KUTURI	14336203	DANGAPAL	4332DT399	100	MIXED	AMI	Yes	33%	17	0.0080782	0.00582213	0.00225607	27.93%
8000	TPCODL	DHENKAN	TED	PARJANG	MAHABIR ROAD OD	14336	GADAPALASUNI KUTURI	14336203	GADAPALASUNI BISWAL SAHI_02	4332DT407	100	MIXED	AMI	Yes	67%	70	0.05775392	0.022342	0.03541192	61.32%
8001	TPCODL	DHENKAN	TED	PARJANG	MAHABIR ROAD OD	14336	GADAPALASUNI KUTURI	14336203	KUTURIA NUA SAHI	4332DT424	100	MIXED	AMI	Yes	0%	75	0.0337444	0.025634	0.0081104	24.03%
8002	TPCODL	DHENKAN	TED	PARJANG	PARJANG	14143	11 KV OLD PARJANG	14143201	DIHADOL RAGADI SAHI	4331DT229	500	MIXED	AMI	Yes	0%	204	0.1935342	0.08893842	0.10459578	54.05%
8003	TPCODL	DHENKAN	TED	PARJANG	PARJANG	14143	11 KV OLD PARJANG	14143201	BARIHAPUR MANDAP SAHI	4331DT248	100	MIXED	AMI	Yes	67%	90	0.09672524	0.023118	0.07360724	76.10%
8004	TPCODL	DHENKAN	TED	PARJANG	PARJANG	14143	11 KV OLD PARJANG	14143201	CHANDPUR TELI SAHI 1	4331DT260	100	MIXED	AMI	Yes	0%	29	0.01100622	0.007257	0.00374922	34.06%
8005	TPCODL	DHENKAN	TED	PARJANG	PARJANG	14143	11 KV OLD PARJANG	14143201	CHANDPUR 3	4331DT270	100	MIXED	AMI	Yes	67%	113	0.03272254	0.014891	0.01783154	54.49%
8006	TPCODL	DHENKAN	TED	PARJANG	PARJANG	14143	11 KV OLD PARJANG	14143201	BADAJHARA NUA SAHI 3	4331DT295	100	MIXED	AMI	Yes	67%	40	0.04093594	0.008261	0.03267494	79.82%
8007	TPCODL	DHENKAN	TED	PARJANG	PARJANG	14143	11 KV OLD PARJANG	14143201	BADAJHARA 3	4331DT299	100	MIXED	AMI	Yes	67%	34	0.05409704	0.01376	0.04033704	74.56%
8008	TPCODL	DHENKAN	TED	PARJANG	PARJANG	14143	11 KV OLD PARJANG	14143201	MUKTAPASI NH	4331DT422	100	MIXED	AMI	Yes	0%	27	0.02052838	0.007057	0.01347138	65.62%
8009	TPCODL	DHENKAN	TED	PARJANG	PARJANG	14143	11 KV OLD PARJANG	14143201	MUKTAPASI 1	4331DT423	100	MIXED	AMI	Yes	67%	40	0.02776766	0.020451	0.00731666	26.35%
8010	TPCODL	DHENKAN	TED	PARJANG	PARJANG	14143	11 KV OLD PARJANG	14143201	BASOI CHHAK 1	4331DT474	100	MIXED	AMI	Yes	0%	67	0.0254839	0.011903	0.0135809	53.29%
8011	TPCODL	DHENKAN	TED	PARJANG	PARJANG	14143	11 KV OLD PARJANG	14143201	MUKTAPASI MEDICAL 2	4331DT498	250	MIXED	AMI	Yes	33%	47	0.06660092	0.018986	0.04761492	71.49%
8012	TPCODL	DHENKAN	TED	PARJANG	PARJANG	14143	11 KV OLD PARJANG	14143201	MUKTAPASI NH SIDE 2	4331DT501	100	MIXED	AMI	Yes	67%	72	0.0323633	0.026591	0.0057723	17.84%
8013	TPCODL	DHENKAN	TED	PARJANG	PARJANG	14143	11 KV OLD PARJANG	14143201	MUKTAPASI 3	4331DT502	100	MIXED	AMI	Yes	67%	152	0.05148984	0.033707	0.01778284	34.54%
8014	TPCODL	DHENKAN	TED	PARJANG	PARJANG	14143	11 KV OLD PARJANG	14143201	PATHARKHAMBA 3	4331DT510	100	MIXED	AMI	Yes	67%	83	0.02208788	0.016669	0.00541888	24.53%
8015	TPCODL	DHENKAN	TED	PARJANG	PARJANG	14143	11 KV OLD PARJANG	14143201	SIARIMALIA 1	4331DT520	100	MIXED	AMI	Yes	0%	12	0.01082388	0.002224	0.00859988	79.45%
8016	TPCODL	DHENKAN	TED	PARJANG	PARJANG	14143	11 KV Rengali (Parjang)	14143202	JANHAPADA 2	4331DT133	100	MIXED	AMI	Yes	0%	57	0.05751188	0.019189	0.03832288	66.63%
8017	TPCODL	DHENKAN	TED	PARJANG	PARJANG	14143	11 KV Rengali (Parjang)	14143202	DAMOL NAIK SAHI 1	4331DT150	100	MIXED	AMI	Yes	0%	25	0.01556504	0.007018	0.00854704	54.91%
8018	TPCODL	DHENKAN	TED	PARJANG	PARJANG	14143	11 KV Rengali (Parjang)	14143202	DAMOL NAIK SAHI 2	4331DT151	100	MIXED	AMI	Yes	0%	20	0.01438442	0.007075	0.00730942	50.81%
8019	TPCODL	DHENKAN	TED	PARJANG	PARJANG	14143	11 KV RN PUR	14143203	KANDARSINGHA H.SAHI	4331DT211	63	MIXED	AMI	Yes	0%	60	0.08312796	0.038732	0.04439596	53.41%
8020	TPCODL	DHENKAN	TED	PARJANG	PARJANG	14143	11 KV RN PUR	14143203	BHALUMUNDA KHALIBAHALA	4331DT214	100	MIXED	AMI	Yes	0%	91	0.067589	0.02856	0.039029	57.74%
8021	TPCODL	DHENKAN	TED	PARJANG	PARJANG	14143	11 KV Kualo (Parjang)	14143204	KUALO DALAK SAHI	4332DT523	100	MIXED	AMI	Yes	67%	44	0.04566294	0.021986	0.02367694	51.85%
8022	TPCODL	DHENKAN	TED	PARJANG	PARJANG	14143	11 KV Kualo (Parjang)	14143204	SINGADA BANGALI GADIA_01	4332DT524	100	MIXED	AMI	Yes	33%	28	0.01650548	0.010015	0.00649048	39.32%
8023	TPCODL	DHENKAN	TED	PARJANG	PARJANG	14143	11 KV Kualo (Parjang)	14143204	SINGADA BANGALI GADIA_02	4332DT525	100	MIXED	AMI	Yes	0%	31	0.04335988	0.013456	0.02990388	68.97%
8024	TPCODL	DHENKAN	TED	PARJANG	PARJANG	14143	11 KV Kualo (Parjang)	14143204	SINGADA_03	4332DT529	100	MIXED	AMI	Yes	67%	106	0.05277118	0.021361	0.03141018	59.52%
8025	TPCODL	DHENKAN	TED	PARJANG	PARJANG	14143	11 KV Kualo (Parjang)	14143204	KUALO HATA SAHI_01	4332DT530	100	MIXED	AMI	Yes	67%	90	0.06979802	0.031762	0.03803602	54.49%
8026	TPCODL	DHENKAN	TED	PARJANG	PARJANG	14143	11 KV Kualo (Parjang)	14143204	KALADA TANLAHATA	4332DT534	100	MIXED	AMI	Yes	67%	119	0.05392088	0.02902933	0.02489155	46.16%
8027	TPCODL	DHENKAN	TED	PARJANG	PARJANG	14143	11 KV Kualo (Parjang)	14143204	KUALO VILL-DTR	4332DT549	63	MIXED	AMI	Yes	67%	57	0.02856814	0.015175	0.01339314	46.88%
8028	TPCODL	DHENKAN	TED	PARJANG	PARJANG	14143	11 KV Mahaveer Road (P	14143205	KANTOR KHALAMALA SAHI	4332DT453	100	MIXED	AMI	Yes	67%	72	0.01906542	0.015595	0.00347042	18.20%
8029	TPCODL	DHENKAN	TED	PARJANG	PARJANG	14143	11 KV Mahaveer Road (P	14143205	KANTOR TALA SAHI	4332DT454	250	MIXED	AMI	Yes	67%	266	0.12479188	0.082255	0.04253688	34.09%

Sl. No.	Zone Name	Circle name	Division name	Name of the Sub-division	Name of the Sub-station	Substation Code	Name of the 11 kV Feeder	Feeder Code	Name of the Location where DT situated	DT code	DT Capacity (kVA)	Predominant consumer type of DT (Domestic/Industrial/Agriculture/Mixed)	Type of metering AMR/AMI/ Communicable/Conventional metered/Unmetered	Status of Meter-whether Functional (Yes/No)	% of data received automatically (if AMR/AMI)	No. of Connected Consumers	Input Energy (MU) (A)	Billed Energy (MU) (B)	Loss (MU) (A-B)	% DT Loss (A-B)/A
8030	TPCODL	DHENKAN	TED	PARJANG	PARJANG	14143	11 KV Mahaveer Road (P	14143205	KANTOR HIGH SCHOOL SAHI	4332DT459	63	MIXED	AMI	Yes	67%	89	0.04878498	0.035621	0.01316398	26.98%
8031	TPCODL	DHENKAN	TED	PARJANG	PARJANG	14143	11 KV Mahaveer Road (P	14143205	KANKADASODA DOLAMANDAP SAHI	4332DT466	100	MIXED	AMI	Yes	67%	83	0.03553154	0.0222883	0.01324324	37.27%
8032	TPCODL	DHENKAN	TED	PARJANG	PARJANG	14143	11 KV Mahaveer Road (P	14143205	AMBAPALASH_02	4332DT488	100	MIXED	AMI	Yes	0%	75	0.06477766	0.02414728	0.04063038	62.72%
8033	TPCODL	DHENKAN	TED	PARJANG	PARJANG	14143	11 KV Kandar Singha	14143206	KANDARSINGHA MAJHI SAHI 1	4331DT010	100	MIXED	AMI	Yes	67%	41	0.04500572	0.013216	0.03178972	70.63%
8034	TPCODL	DHENKAN	TED	PARJANG	PARJANG	14143	11 KV Kandar Singha	14143206	KANDARSINGHA PRADHAN SAHI 1	4331DT023	100	MIXED	AMI	Yes	67%	77	0.06548476	0.018066	0.04741876	72.41%
8035	TPCODL	DHENKAN	TED	PARJANG	PARJANG	14143	11 KV Kandar Singha	14143206	KANDARSINGHA PRADHAN SAHI 2	4331DT024	100	MIXED	AMI	Yes	67%	101	0.0591188	0.026481	0.0326378	55.21%
8036	TPCODL	DHENKAN	TED	PARJANG	PARJANG	14143	11 KV Kandar Singha	14143206	LODHANI PURUNA BANK 1	4331DT025	100	MIXED	AMI	Yes	67%	145	0.0977806	0.037799	0.0599816	61.34%
8037	TPCODL	DHENKAN	TED	PARJANG	PARJANG	14143	11 KV Kandar Singha	14143206	LODHANI PURUNA BANK 2	4331DT026	100	MIXED	AMI	Yes	0%	70	0.0374042	0.020324	0.0170802	45.66%
8038	TPCODL	DHENKAN	TED	PARJANG	PARJANG	14143	11 KV Kandar Singha	14143206	LODHANI TALA SAHI 1	4331DT032	100	MIXED	AMI	Yes	67%	88	0.03721587	0.023103	0.01411287	37.92%
8039	TPCODL	DHENKAN	TED	PARJANG	PARJANG	14143	11 KV Kandar Singha	14143206	LODHANI TALA SAHI 2	4331DT033	100	MIXED	AMI	Yes	67%	94	0.07869114	0.023178	0.05551314	70.55%
8040	TPCODL	DHENKAN	TED	PARJANG	PARJANG	14143	11 KV Kandar Singha	14143206	PATARPADA MAHAMAYE TEMPLE	4331DT040	100	MIXED	AMI	Yes	67%	120	0.0632425	0.028567	0.0346755	54.83%
8041	TPCODL	DHENKAN	TED	PARJANG	PARJANG	14143	11 KV Kandar Singha	14143206	MENDHAPADA	4331DT043	100	MIXED	AMI	Yes	0%	153	0.07457462	0.037605	0.03696962	49.57%
8042	TPCODL	DHENKAN	TED	PARJANG	PARJANG	14143	11 KV Kandar Singha	14143206	KATABAHAL KUMBHAR SAHI 2	4331DT053	100	MIXED	AMI	Yes	67%	130	0.06523468	0.031587	0.03364768	51.58%
8043	TPCODL	DHENKAN	TED	PARJANG	PARJANG	14143	11 KV Kandar Singha	14143206	PATARAPADA MAJHI SAHI	4331DT062	100	MIXED	AMI	Yes	67%	66	0.04462372	0.011594	0.03302972	74.02%
8044	TPCODL	DHENKAN	TED	PARJANG	PARJANG	14143	11 KV Kandar Singha	14143206	PALASAHI HIGH SCHOOL 2	4331DT069	100	MIXED	AMI	Yes	33%	84	0.05259862	0.023405	0.02919362	55.50%
8045	TPCODL	DHENKAN	TED	PARJANG	PARJANG	14143	11 KV Kandar Singha	14143206	GAILO_03	4331DT088	100	MIXED	AMI	Yes	0%	64	0.02125538	0.014332	0.00692338	32.57%
8046	TPCODL	DHENKAN	TED	PARJANG	PARJANG	14143	11 KV Kandar Singha	14143206	GAILO_02	4331DT089	100	MIXED	AMI	Yes	67%	16	0.0116521	0.002922	0.0087301	74.92%
8047	TPCODL	DHENKAN	TED	PARJANG	PARJANG	14143	11 KV Kandar Singha	14143206	KELARUDHA	4331DT098	100	MIXED	AMI	Yes	67%	79	0.08240708	0.019142	0.06326508	76.77%
8048	TPCODL	DHENKAN	TED	PARJANG	PARJANG	14143	11 KV Kandar Singha	14143206	NUA RODHA 1	4331DT108	200	MIXED	AMI	Yes	67%	51	0.04000296	0.010827	0.02917596	72.93%
8049	TPCODL	DHENKAN	TED	PARJANG	PARJANG	14143	11 KV Kandar Singha	14143206	RODA VILLAGE	4331DT560	100	MIXED	AMI	Yes	67%	54	0.03214908	0.014333	0.01781608	55.42%
8050	TPCODL	DHENKAN	TED	PARJANG	PARJANG	14143	11 KV Saranga	14143207	MUNDEILO	4332DT560	100	MIXED	AMI	Yes	0%	135	0.15616644	0.051443	0.10472344	67.06%
8051	TPCODL	DHENKAN	TED	PARJANG	PARJANG	14143	11 KV Saranga	14143207	MUNDEILO KHAIRIA SAHI_02	4332DT562	100	MIXED	AMI	Yes	67%	55	0.07573984	0.024597	0.05114284	67.52%
8052	TPCODL	DHENKAN	TED	PARJANG	PARJANG	14143	11 KV Saranga	14143207	GOUDA MUNDA	4332DT571	100	MIXED	AMI	Yes	67%	78	0.06677718	0.021092	0.04568518	68.41%
8053	TPCODL	DHENKAN	TED	PARJANG	PARJANG	14143	11 KV Saranga	14143207	PITIR PURUNA SAHI	4332DT597	100	MIXED	AMI	Yes	67%	33	0.0536329	0.012616	0.0410169	76.48%
8054	TPCODL	DHENKAN	TED	PARJANG	PARJANG	14143	11 KV Saranga	14143207	PITIR TALA SAHI	4332DT600	100	MIXED	AMI	Yes	67%	79	0.04250768	0.021027	0.02148068	50.53%
8055	TPCODL	DHENKAN	TED	PARJANG	PARJANG	14143	11 KV Saranga	14143207	KHALAPALA H.SAHI	4332DT612	100	MIXED	AMI	Yes	67%	64	0.0503668	0.021781	0.0285858	56.76%
8056	TPCODL	DHENKAN	TED	PARJANG	PARJANG	14143	11 KV Saranga	14143207	PARAMHANSPUR_02	4332DT631	100	MIXED	AMI	Yes	67%	36	0.03288458	0.014832	0.01805258	54.90%
8057	TPCODL	DHENKAN	TED	PARJANG	SANDA ODSSP	14329	11 KV SANDA	14329201	TALABERANA JANGYAMANDAP SAHI	4331DT303	100	MIXED	AMI	Yes	67%	99	0.05087468	0.032138	0.01873668	36.83%
8058	TPCODL	DHENKAN	TED	PARJANG	SANDA ODSSP	14329	11 KV SANDA	14329201	TALABERANA	4331DT304	100	MIXED	AMI	Yes	0%	26	0.01717072	0.00924	0.00793072	46.19%
8059	TPCODL	DHENKAN	TED	PARJANG	SANDA ODSSP	14329	11 KV SANDA	14329201	BUDHATOTA	4331DT366	100	MIXED	AMI	Yes	67%	49	0.02332702	0.016511	0.00681602	29.22%
8060	TPCODL	DHENKAN	TED	PARJANG	SANDA ODSSP	14329	11 KV SANDA	14329201	SIARIMALIA 2	4331DT369	100	MIXED	AMI	Yes	67%	95	0.0409863	0.022284	0.0187023	45.63%
8061	TPCODL	DHENKAN	TED	PARJANG	SANDA ODSSP	14329	11 KV SANDA	14329201	SANDA 1	4331DT374	100	MIXED	AMI	Yes	67%	231	0.08457094	0.064764	0.01980694	23.42%
8062	TPCODL	DHENKAN	TED	PARJANG	SANDA ODSSP	14329	11 KV SANDA	14329201	SARABERANI	4331DT377	250	MIXED	AMI	Yes	67%	63	0.05949384	0.020733	0.03876084	65.15%
8063	TPCODL	DHENKAN	TED	PARJANG	SANDA ODSSP	14329	11 KV SANDA	14329201	VERUNIA	4331DT382	100	MIXED	AMI	Yes	67%	67	0.03204644	0.026829	0.00521744	16.28%
8064	TPCODL	DHENKAN	TED	PARJANG	SANDA ODSSP	14329	11 KV PANI GENGUTIA	14329202	ANLAKATA	4331DT316	100	MIXED	AMI	Yes	33%	130	0.04091676	0.03280355	0.00811321	19.83%
8065	TPCODL	DHENKAN	TED	PARJANG	SANDA ODSSP	14329	11 kV KANKILI	14329204	KANKILI JARITAILA	4331DT344	100	MIXED	AMI	Yes	33%	60	0.03231234	0.014284	0.01802834	55.79%
8066	TPCODL	DHENKAN	TED	PARJANG	SANDA ODSSP	14329	11 kV KANKILI	14329204	KANKILI SANDA OFFICE 1	4331DT351	100	MIXED	AMI	Yes	67%	74	0.04309514	0.015057	0.02803814	65.06%
8067	TPCODL	DHENKAN	TED	PARJANG	SANDA ODSSP	14329	11 kV KANKILI	14329204	KANKILI SANDA OFFICE 2	4331DT352	100	MIXED	AMI	Yes	33%	82	0.03092686	0.013708	0.01721886	55.68%
8068	TPCODL	DHENKAN	TED	PARJANG	SARANGA ODSSP	14333	11 KV JATIA	14333201	SARANG CHEAK GATE	4332DT026	250	MIXED	AMI	Yes	67%	27	0.06448792	0.041476	0.02301192	35.68%
8069	TPCODL	DHENKAN	TED	PARJANG	SARANGA ODSSP	14333	11 KV JATIA	14333201	JATIA CHHAKA	4332DT030	100	MIXED	AMI	Yes	67%	12	0.02404378	0.013356	0.01068778	44.45%
8070	TPCODL	DHENKAN	TED	PARJANG	SARANGA ODSSP	14333	11 KV JATIA	14333201	JATIA PALA MANDAP SAHI_02	4332DT044	100	MIXED	AMI	Yes	100%	98	0.03891454	0.035833	0.00308154	7.92%
8071	TPCODL	DHENKAN	TED	PARJANG	SARANGA ODSSP	14333	11 KV SARANG	14333203	SARANG TELI SAHI_01	4332DT010	250	MIXED	AMI	Yes	67%	150	0.13572464	0.086697	0.04902764	36.12%
8072	TPCODL	DHENKAN	TED	PARJANG	SARANGA ODSSP	14333	11 KV SARANG	14333203	SARANG VILLAGE_02	4332DT013	250	MIXED	AMI	Yes	0%	137	0.15281324	0.05132	0.10149324	66.42%
8073	TPCODL	DHENKAN	TED	PARJANG	SARANGA ODSSP	14333	11 KV SARANG	14333203	SARANG MARKET	4332DT017	100	MIXED	AMI	Yes	67%	79	0.09639218	0.08754	0.00885218	9.18%
8074	TPCODL	DHENKAN	TED	PARJANG	SARANGA ODSSP	14333	11 KV SARANG	14333203	SARANG GAUDA SAHI	4332DT021	100	MIXED	AMI	Yes	67%	134	0.06575244	0.05049	0.01526244	23.21%
8075	TPCODL	DHENKAN	TED	PARJANG	SARANGA ODSSP	14333	11 KV SARANG	14333203	SARANG MOHANTY SAHI	4332DT022	100	MIXED	AMI	Yes	67%	106	0.08070934	0.078291	0.00241834	3.00%
8076	TPCODL	DHENKAN	TED	TALCHER	HATATOTA	14145	11 kV HATATOTA RE-2	14145202	DERA VILLAGE BALI SAHI	4341DT309	200	MIXED	AMI	Yes	67%	68	0.12615368	0.047996	0.07815768	61.95%
8077	TPCODL	DHENKAN	TED	TALCHER	KANIHA	14148	11 kV KARADI	14148205	BARADANGUA MANGALA SAHI	4343DT146	100	MIXED	AMI	Yes	67%	74	0.04283606	0.036835	0.00600106	14.01%
8078	TPCODL	DHENKAN	TED	TALCHER	HATATOTA	14145	11 kV Hatatota Town-2	14145204	TALCHER MADHURUM JEWELLERS	4345DT132	500	MIXED	AMI	Yes	0%	264	0.3707247	0.210039	0.1606857	43.34%
8079	TPCODL	DHENKAN	TED	TALCHER	TALCHER-2 NTPC	14375	11 kV HANDIDHUA	14375203	KAMALA VIHAR CHHAK PANI GALI	4345DT174	100	MIXED	AMI	Yes	67%	47	0.12186744	0.048668	0.07319944	60.06%
8080	TPCODL	DHENKAN	TED	TALCHER	TALCHER-2 NTPC	14375	11 kV TALCHER PALACE	14375201	CHAMPAPASI MINES	4345DT215	63	MIXED	AMI	Yes	0%	67	0.04399272	0.039171	0.00482172	10.96%
8081	TPCODL	DHENKAN	TED	TALCHER	TALCHER-2 NTPC	14375	11 kV TALCHER PALACE	14375201	ARJUNKATTA CHHAKA	4345DT319	63	MIXED	AMI	Yes	0%	46	0.02613246	0.015291	0.01084146	41.49%
8082	TPCODL	DHENKAN	TED	TALCHER	TALCHER-2 NTPC	14375	11 kV TALCHER PALACE	14375201	KASIPUR	4345DT337	63	MIXED	AMI	Yes	0%	29	0.024978	0.015284	0.009694	38.81%
8083	TPCODL	DHENKAN	TED	TALCHER	TALCHER-2 NTPC	14375	11 kV TALCHER PALACE	14375201	SANDHAGON 1	4345DT344	63	MIXED	AMI	Yes	0%	40	0.01975176	0.006996	0.01275576	64.58%
8084	TPCODL	DHENKAN	TED	TALCHER	BALANDA	14146	11 KV GOBARA	14146201	EKGHARIA_02	4344DT039	63	MIXED	AMI	Yes	0%	94	0.07270124	0.045131	0.02757024	37.92%
8085	TPCODL	DHENKAN	TED	TALCHER	BALANDA	14146	11 KV GOBARA	14146201	KARADAPALLI	4344DT040	100	MIXED	AMI	Yes	0%	131	0.13083168	0.105875	0.02495668	19.08%
8086	TPCODL	DHENKAN	TED	TALCHER	BALANDA	14146	11 KV GOBARA	14146201	GOBARA SIKOMUNDA SAHI	4344DT110	100	MIXED	AMI	Yes	0%	106	0.10123426	0.063819	0.03741526	36.96%
8087	TPCODL	DHENKAN	TED	TALCHER	BALANDA	14146	11 KV GOBARA	14146201	BADASINGHADA_04	4344DT120	100	MIXED	AMI	Yes	0%	22	0.0161648	0.013952	0.0022128	13.69%
8088	TPCODL	DHENKAN	TED	TALCHER	BALANDA	14146	11 KV GOBARA	14146201	KARNAPUR SWARGADWARA	4344DT245	100	MIXED	AMI	Yes	67%	36	0.04390446	0.019993	0.02391146	54.46%
8089	TPCODL	DHENKAN	TED	TALCHER	BALANDA	14146	11 KV GOBARA	14146201	KUKUDANGA BARA SAHI_01	4344DT260	100	MIXED	AMI	Yes	33%	78	0.07712362	0.03838	0.03874362	50.24%
8090	TPCODL	DHENKAN	TED	TALCHER	BALANDA	14146	11 KV GOBARA	14146201	KUKUDANGA BADABANDHA_01	4344DT263	100	MIXED	AMI	Yes	33%	86	0.10408298	0.028615	0.07546798	72.51%
8091	TPCODL	DHENKAN	TED	TALCHER	BALANDA	14146	11 KV GOBARA	14146201	KUKUDANGA KUIEPASI	4344DT269	100	MIXED	AMI	Yes	33%	128	0.0895518	0.055956	0.0335958	37.52%
8092	TPCODL	DHENKAN	TED	TALCHER	BALANDA	14146	11 KV JAGANNATHPUR (I	14146202	TENTOLEI HADI SAHI 2	4344DT065	100	MIXED	AMI	Yes	0%	107	0.137845	0.047453	0.090392	65.58%
8093	TPCODL	DHENKAN	TED	TALCHER	BALANDA	14146	11 KV JAGANNATHPUR (I	14146202	BAGHAMARA COLONY 2	4344DT067	100	MIXED	AMI	Yes	67%	35	0.09100216	0.052198	0.03880416	42.64%
8094	TPCODL	DHENKAN	TED	TALCHER	BALANDA	14146	11 KV JAGANNATHPUR (I	14146202	JAGANNATHPUR NUA BANDHA	4344DT129	100	MIXED	AMI	Yes	67%	50	0.07907134	0.022911	0.05616034	71.02%
8095	TPCODL	DHENKAN	TED	TALCHER	BALANDA	14146	11 KV JAGANNATHPUR (I	14146202	JAGANNATHPUR, DHIR TENT HOUSE	4344DT130	100	MIXED	AMI	Yes	33%	75	0.08694218	0.051496	0.03544618	40.77%
8096	TPCODL	DHENKAN	TED	TALCHER	BALANDA	14146	11 KV JAGANNATHPUR (I	14146202	JAGANNATHPUR , DHIR TENT HOUSE	4344DT131	100	MIXED	AMI	Yes	67%	67	0.1204977	0.056643	0.0638547	52.99%
8097	TPCODL	DHENKAN	TED	TALCHER	BALANDA	14146	11 KV JAGANNATHPUR (I	14146202	JAGANNATHPUR BAZAR G.P OFFICE	4344DT133	250	MIXED	AMI	Yes	0%	228	0.21063972	0.10255043	0.10808929	51.31%
8098	TPCODL	DHENKAN	TED	TALCHER	BALANDA	14146	11 KV JAGANNATHPUR (I	14146202	JAGANNATHPUR BAZAR	4344DT134	100	MIXED	AMI	Yes	67%	101	0.07667532	0.050323	0.02635232	34.37%
8099	TPCODL	DHENKAN	TED	TALCHER	BALANDA	14146	11 KV GURUDWARA	14146203	GURUDWAR-3	4344DT015	100	MIXED	AMI	Yes	0%	66	0.09979814	0.068372	0.03142614	31.49%
8100	TPCODL	DHENKAN	TED	TALCHER	BALANDA	14146	11 KV GURUDWARA	14146203	GURUDWAR-4	4344DT018	100	MIXED	AMI	Yes	0%	61	0.08569788	0.054387	0.03131088	36.54%
8101	TPCODL	DHENKAN	TED	TALCHER	BALANDA	14146	11 KV GURUDWARA	14146203	GURUDWAR-2	4344DT049	200	MIXED	AMI	Yes	0%	224	0.28268404	0.08523	0.19745404	69.85%
8102	TPCODL	DHENKAN	TED	TALCHER	BANARPAL	14142	11 KV KULAD	14142202	KULAD NEAR SADHANA FLY ASH BRIC	4311DT143	100	MIXED	AMI	Yes	100%	32	0.11375083	0.035582	0.07816883	68.72%

Sl. No.	Zone Name	Circle name	Division name	Name of the Sub-division	Name of the Sub-station	Substation Code	Name of the 11 kV Feeder	Feeder Code	Name of the Location where DT situated	DT code	DT Capacity (kVA)	Predominant consumer type of DT (Domestic/Industrial/Agriculture/Mixed)	Type of metering AMR/AMI/ Communicable/Conventional metered/Unmetered	Status of Meter-whether Functional (Yes/No)	% of data received automatically (if AMR/AMI)	No. of Connected Consumers	Input Energy (MU) (A)	Billed Energy (MU) (B)	Loss (MU) (A-B)	% DT Loss (A-B)/A
8103	TPCODL	DHENKAN	TED	TALCHER	BHUBAN	14129	11 KV BHUSAL	14129203	CHANDIPAL (NUA SAHI)	4141DT243	100	MIXED	AMI	Yes	33%	39	0.01401146	0.008827	0.00518446	37.00%
8104	TPCODL	DHENKAN	TED	TALCHER	HANUMANPUR ODS	14334	11 KV GUNDURI	14334203	NALAM PURUNA SAHI	4324DT125	100	MIXED	AMI	Yes	0%	126	0.05552902	0.020151	0.03537802	63.71%
8105	TPCODL	DHENKAN	TED	TALCHER	HATATOTA	14145	11 KV Hatatota RE-1	14145201	BHERUBANIA 4	4341DT338	100	MIXED	AMI	Yes	100%	38	0.06633176	0.014145	0.05218676	78.68%
8106	TPCODL	DHENKAN	TED	TALCHER	HATATOTA	14145	11 KV Hatatota RE-1	14145201	HARIHARPUR-3	4341DT342	100	MIXED	AMI	Yes	100%	57	0.0642365	0.033961	0.0302755	47.13%
8107	TPCODL	DHENKAN	TED	TALCHER	HATATOTA	14145	11 KV Hatatota RE-1	14145201	KANKILI UP SCHOOL 2	4341DT348	100	MIXED	AMI	Yes	100%	62	0.0569469	0.029592	0.0273549	48.04%
8108	TPCODL	DHENKAN	TED	TALCHER	HATATOTA	14145	11 KV Hatatota RE-1	14145201	KANKILI UP SCHOOL 3	4341DT349	100	MIXED	AMI	Yes	100%	48	0.0816115	0.018633	0.0629785	77.17%
8109	TPCODL	DHENKAN	TED	TALCHER	HATATOTA	14145	11 KV Hatatota RE-1	14145201	KANKILI NUA SAHI 1	4341DT355	100	MIXED	AMI	Yes	100%	42	0.06309498	0.016551	0.04654398	73.77%
8110	TPCODL	DHENKAN	TED	TALCHER	HATATOTA	14145	11 KV Hatatota RE-1	14145201	KANKILI NUA SAHI 2	4341DT356	250	MIXED	AMI	Yes	0%	163	0.23142352	0.085671	0.14575252	62.98%
8111	TPCODL	DHENKAN	TED	TALCHER	HATATOTA	14145	11 KV Hatatota RE-1	14145201	KANKILI POST OFFICE RANIA 1	4341DT357	100	MIXED	AMI	Yes	100%	110	0.10751236	0.041502	0.06601036	61.40%
8112	TPCODL	DHENKAN	TED	TALCHER	HATATOTA	14145	11 KV Hatatota RE-1	14145201	DHARAMPUR TELI SAHI 1	4341DT371	100	MIXED	AMI	Yes	67%	120	0.09666012	0.032985	0.06367512	65.88%
8113	TPCODL	DHENKAN	TED	TALCHER	HATATOTA	14145	11 KV Hatatota RE-1	14145201	SIRIGIDA 1	4341DT375	100	MIXED	AMI	Yes	100%	36	0.06426866	0.015855	0.04841366	75.33%
8114	TPCODL	DHENKAN	TED	TALCHER	HATATOTA	14145	11 KV Hatatota RE-1	14145201	SIRIGIDA 3	4341DT379	100	MIXED	AMI	Yes	100%	89	0.08015324	0.043189	0.03696424	46.12%
8115	TPCODL	DHENKAN	TED	TALCHER	HATATOTA	14145	11 KV Hatatota RE-1	14145201	KISHORIPAL 2	4345DT005	100	MIXED	AMI	Yes	100%	40	0.08196986	0.019585	0.06238486	76.11%
8116	TPCODL	DHENKAN	TED	TALCHER	HATATOTA	14145	11 KV Hatatota RE-2	14145202	NEW NARAHARIPUR 1	4341DT246	100	MIXED	AMI	Yes	0%	24	0.03467956	0.027018	0.00766156	22.09%
8117	TPCODL	DHENKAN	TED	TALCHER	HATATOTA	14145	11 KV Hatatota RE-2	14145202	BALUNGA NEAR SANI TEMPLE 1	4341DT259	100	MIXED	AMI	Yes	100%	69	0.08666208	0.05717	0.02949208	34.03%
8118	TPCODL	DHENKAN	TED	TALCHER	HATATOTA	14145	11 KV Hatatota RE-2	14145202	BALUNGA NEAR SANI TEMPLE 2	4341DT261	100	MIXED	AMI	Yes	100%	74	0.07994844	0.049239	0.03070944	38.41%
8119	TPCODL	DHENKAN	TED	TALCHER	HATATOTA	14145	11 KV Hatatota RE-2	14145202	KANDHAL UP SCHOOL 2	4341DT270	100	MIXED	AMI	Yes	0%	79	0.06609346	0.028194	0.03789946	57.34%
8120	TPCODL	DHENKAN	TED	TALCHER	HATATOTA	14145	11 KV Hatatota RE-2	14145202	JADUNATHPUR	4341DT287	100	MIXED	AMI	Yes	100%	30	0.04075518	0.024454	0.01630118	40.00%
8121	TPCODL	DHENKAN	TED	TALCHER	HATATOTA	14145	11 KV Hatatota RE-2	14145202	LANGIJODA CHHAK	4341DT292	100	MIXED	AMI	Yes	0%	34	0.0540126	0.013397	0.0406156	75.20%
8122	TPCODL	DHENKAN	TED	TALCHER	HATATOTA	14145	11 KV Hatatota RE-2	14145202	HENSAMUL	4341DT299	100	MIXED	AMI	Yes	67%	25	0.03662056	0.026696	0.00992456	27.10%
8123	TPCODL	DHENKAN	TED	TALCHER	HATATOTA	14145	11 KV Hatatota RE-2	14145202	BALUNGA ANANDPUR 1	4341DT416	250	MIXED	AMI	Yes	100%	92	0.12852664	0.066367	0.06215964	48.36%
8124	TPCODL	DHENKAN	TED	TALCHER	HATATOTA	14145	11 KV Hatatota Town-1	14145203	MOCHI SAHI	4345DT068	25	MIXED	AMI	Yes	67%	43	0.04805604	0.019262	0.02879404	59.92%
8125	TPCODL	DHENKAN	TED	TALCHER	HATATOTA	14145	11 KV Hatatota Town-1	14145203	BIRADARPADA 1	4345DT080	250	MIXED	AMI	Yes	100%	184	0.14949172	0.108669	0.04082272	27.31%
8126	TPCODL	DHENKAN	TED	TALCHER	HATATOTA	14145	11 KV Hatatota Town-1	14145203	SINGH SAHI	4345DT085	100	MIXED	AMI	Yes	33%	80	0.06794926	0.029398	0.03855126	56.74%
8127	TPCODL	DHENKAN	TED	TALCHER	HATATOTA	14145	11 KV Hatatota Town-1	14145203	BIRADARPADA 3	4345DT090	100	MIXED	AMI	Yes	100%	52	0.1281607	0.035389	0.0927717	72.39%
8128	TPCODL	DHENKAN	TED	TALCHER	HATATOTA	14145	11 KV Hatatota Town-1	14145203	THANASAHI TALCHER PATHAN GALI	4345DT094	100	MIXED	AMI	Yes	100%	145	0.14529658	0.08499	0.06030658	41.51%
8129	TPCODL	DHENKAN	TED	TALCHER	HATATOTA	14145	11 KV Hatatota Town-2	14145204	ARYA BIHAR 1	4345DT100	100	MIXED	AMI	Yes	100%	39	0.10195426	0.026132	0.07582226	74.37%
8130	TPCODL	DHENKAN	TED	TALCHER	HATATOTA	14145	11 KV Hatatota Town-2	14145204	TALCHER POST OFFICE	4345DT102	250	MIXED	AMI	Yes	100%	80	0.16392216	0.085939	0.07798316	47.57%
8131	TPCODL	DHENKAN	TED	TALCHER	HATATOTA	14145	11 KV Hatatota Town-2	14145204	BABULAL COLONY	4345DT113	250	MIXED	AMI	Yes	100%	111	0.191837	0.107568	0.084269	43.93%
8132	TPCODL	DHENKAN	TED	TALCHER	HATATOTA	14145	11 KV Hatatota Town-2	14145204	SURYA NAGAR	4345DT115	250	MIXED	AMI	Yes	100%	78	0.14278512	0.071579	0.07120612	49.87%
8133	TPCODL	DHENKAN	TED	TALCHER	HATATOTA	14145	11 KV Hatatota Town-2	14145204	SHARMA CHHAKA	4345DT128	500	MIXED	AMI	Yes	100%	448	0.6321308	0.356492	0.2756388	43.60%
8134	TPCODL	DHENKAN	TED	TALCHER	HATATOTA	14145	11 KV Hatatota Town-2	14145204	BATA GALI	4345DT129	250	MIXED	AMI	Yes	0%	132	0.19730448	0.063989	0.13331548	67.57%
8135	TPCODL	DHENKAN	TED	TALCHER	HATATOTA	14145	11 KV Hatatota Town-2	14145204	NABA MISHRA COLONY ROAD	4345DT138	250	MIXED	AMI	Yes	0%	130	0.15149748	0.108449	0.04304848	28.42%
8136	TPCODL	DHENKAN	TED	TALCHER	HATATOTA	14145	11 KV Hatatota Town-2	14145204	NABA MISHRA COLONY	4345DT140	250	MIXED	AMI	Yes	0%	51	0.18264456	0.045752	0.13689256	74.95%
8137	TPCODL	DHENKAN	TED	TALCHER	HATATOTA	14145	11 KV Hatatota Town-2	14145204	DEULABEDA IC FACTORY	4345DT144	250	MIXED	AMI	Yes	100%	174	0.16102208	0.157925	0.00309708	1.92%
8138	TPCODL	DHENKAN	TED	TALCHER	HATATOTA	14145	11 KV Hatatota LIC	14145205	DERA JAGANNATH COLONY 1	4341DT429	100	MIXED	AMI	Yes	0%	15	0.0299876	0.013806	0.0161816	53.96%
8139	TPCODL	DHENKAN	TED	TALCHER	HATATOTA	14145	11 KV Hatatota LIC	14145205	DERA JAGANNATH COLONY 2	4341DT430	100	MIXED	AMI	Yes	100%	49	0.04028784	0.03087	0.00941784	23.38%
8140	TPCODL	DHENKAN	TED	TALCHER	HATATOTA	14145	11 KV Hatatota LIC	14145205	NEW LANGIJODA 3	4341DT436	100	MIXED	AMI	Yes	67%	55	0.08381506	0.053873	0.02994206	35.72%
8141	TPCODL	DHENKAN	TED	TALCHER	HATATOTA	14145	11 KV Hatatota LIC	14145205	RODHASARA UP SCHOOL 2	4341DT438	100	MIXED	AMI	Yes	100%	36	0.07627918	0.023403	0.05287618	69.32%
8142	TPCODL	DHENKAN	TED	TALCHER	HATATOTA	14145	11 KV Hatatota LIC	14145205	GHANTAPADA BALI SAHI	4341DT442	100	MIXED	AMI	Yes	67%	90	0.11187264	0.029435	0.08243764	73.69%
8143	TPCODL	DHENKAN	TED	TALCHER	HATATOTA	14145	11 KV Hatatota LIC	14145205	GHANTAPADA BARA SAHI	4341DT444	250	MIXED	AMI	Yes	67%	95	0.20517796	0.044264	0.16091396	78.43%
8144	TPCODL	DHENKAN	TED	TALCHER	HATATOTA	14145	11 KV Hatatota LIC	14145205	ANANTABIHAR MARKET GATE	4341DT450	100	MIXED	AMI	Yes	0%	19	0.04407272	0.012168	0.03190472	72.39%
8145	TPCODL	DHENKAN	TED	TALCHER	HATATOTA	14145	11 KV Hatatota LIC	14145205	GHANTAPADA JAGANNATH VIHAR	4341DT451	100	MIXED	AMI	Yes	67%	21	0.03506827	0.019857	0.01521127	43.38%
8146	TPCODL	DHENKAN	TED	TALCHER	HATATOTA	14145	11 KV Hatatota LIC	14145205	CHALAGARH SAMA AND NUA SAHI	4341DT465	250	MIXED	AMI	Yes	67%	161	0.2308868	0.085137	0.1457498	63.13%
8147	TPCODL	DHENKAN	TED	TALCHER	HATATOTA	14145	11 KV Hatatota LIC	14145205	GHANTAPADA MALI SAHI	4341DT469	250	MIXED	AMI	Yes	67%	175	0.12407856	0.072889	0.05118956	41.26%
8148	TPCODL	DHENKAN	TED	TALCHER	HATATOTA	14145	11 KV Hatatota LIC	14145205	CHALA GARH MASANI KHANDI	4341DT476	100	MIXED	AMI	Yes	0%	29	0.03181544	0.03143	0.00038544	1.21%
8149	TPCODL	DHENKAN	TED	TALCHER	HATATOTA	14145	11 KV Hatatota LIC	14145205	DEULABEDA VILLAGE 1	4345DT014	100	MIXED	AMI	Yes	100%	112	0.0906616	0.081096	0.0095656	10.55%
8150	TPCODL	DHENKAN	TED	TALCHER	HATATOTA	14145	11 KV Hatatota LIC	14145205	SHARMA CHHAKA JAGANNATH VIHAI	4345DT031	100	MIXED	AMI	Yes	100%	36	0.0558541	0.042519	0.0133351	23.87%
8151	TPCODL	DHENKAN	TED	TALCHER	HATATOTA	14145	11 KV Hatatota LIC	14145205	HANDIDHUA BAZAR	4345DT034	250	MIXED	AMI	Yes	100%	93	0.26220372	0.141976	0.12022772	45.85%
8152	TPCODL	DHENKAN	TED	TALCHER	HATATOTA	14145	11 KV Hatatota LIC	14145205	DEULABEDA TELI SAHI	4345DT042	250	MIXED	AMI	Yes	100%	136	0.18159628	0.085467	0.09612928	52.94%
8153	TPCODL	DHENKAN	TED	TALCHER	HATATOTA	14145	11 KV Hatatota LIC	14145205	DEULADEDA TELI SAHI UP SCHOOL	4345DT048	100	MIXED	AMI	Yes	100%	101	0.08272668	0.066405	0.01632168	19.73%
8154	TPCODL	DHENKAN	TED	TALCHER	HATATOTA	14145	11 KV GODIBANDHA	14145206	JANDABAHAL PAIK SAHI	4341DT010	100	MIXED	AMI	Yes	67%	33	0.025778	0.015332	0.010446	40.52%
8155	TPCODL	DHENKAN	TED	TALCHER	HATATOTA	14145	11 KV GODIBANDHA	14145206	GURUJANG KUNDURA BHUIN 1	4341DT013	100	MIXED	AMI	Yes	33%	57	0.0375744	0.023167	0.0144074	38.34%
8156	TPCODL	DHENKAN	TED	TALCHER	HATATOTA	14145	11 KV GODIBANDHA	14145206	GURUJANGA BRAHMAN SAHI	4341DT021	100	MIXED	AMI	Yes	67%	33	0.02565122	0.019946	0.00570522	22.24%
8157	TPCODL	DHENKAN	TED	TALCHER	HATATOTA	14145	11 KV GODIBANDHA	14145206	GURUJANG NANDA SAHI	4341DT041	100	MIXED	AMI	Yes	67%	42	0.02307378	0.02215	0.00092378	4.00%
8158	TPCODL	DHENKAN	TED	TALCHER	HATATOTA	14145	11 KV GODIBANDHA	14145206	GURUJANG PURUNA SAHI 1	4341DT044	100	MIXED	AMI	Yes	67%	30	0.0505668	0.016049	0.0345178	68.26%
8159	TPCODL	DHENKAN	TED	TALCHER	HATATOTA	14145	11 KV GODIBANDHA	14145206	GURUJANG NUA SAHI	4341DT045	100	MIXED	AMI	Yes	67%	64	0.03973284	0.032111	0.00762184	19.18%
8160	TPCODL	DHENKAN	TED	TALCHER	HATATOTA	14145	11 KV GODIBANDHA	14145206	GODIBANDHA GP OFFICE	4341DT068	100	MIXED	AMI	Yes	67%	96	0.05546272	0.03403	0.02143272	38.64%
8161	TPCODL	DHENKAN	TED	TALCHER	HATATOTA	14145	11 KV GODIBANDHA	14145206	RADHARAMANPUR NEAR OMMKAR \	4341DT073	100	MIXED	AMI	Yes	67%	78	0.06477482	0.035959	0.02881582	44.49%
8162	TPCODL	DHENKAN	TED	TALCHER	HATATOTA	14145	11 KV GODIBANDHA	14145206	SUNAKHANI VILLAGE	4341DT113	100	MIXED	AMI	Yes	67%	120	0.08395268	0.060531	0.02342168	27.90%
8163	TPCODL	DHENKAN	TED	TALCHER	HATATOTA	14145	11 KV GODIBANDHA	14145206	BRAJANATHPUR NAIK SAHI 2	4341DT135	100	MIXED	AMI	Yes	67%	117	0.12899014	0.050943	0.07804714	60.51%
8164	TPCODL	DHENKAN	TED	TALCHER	HATATOTA	14145	11 KV GODIBANDHA	14145206	BRAJANATHPUR HIGH SCHOOL	4341DT136	100	MIXED	AMI	Yes	67%	72	0.05781616	0.033477	0.02433916	42.10%
8165	TPCODL	DHENKAN	TED	TALCHER	HATATOTA	14145	11 KV GODIBANDHA	14145206	EKADAL HILUI	4341DT166	100	MIXED	AMI	Yes	67%	37	0.0375636	0.016574	0.0209896	55.88%
8166	TPCODL	DHENKAN	TED	TALCHER	HATATOTA	14145	11 KV GODIBANDHA	14145206	EKADAL 5	4341DT172	100	MIXED	AMI	Yes	67%	37	0.03065372	0.015236	0.01541772	50.30%
8167	TPCODL	DHENKAN	TED	TALCHER	HATATOTA	14145	11 KV GODIBANDHA	14145206	RANGPUR	4341DT189	100	MIXED	AMI	Yes	67%	51	0.05415846	0.021528	0.03263046	60.25%
8168	TPCODL	DHENKAN	TED	TALCHER	KALAMCHHUIN (DA	14331	11 KV DANARA	14331201	NEAR DANARA SUBSTATION	4344DT201	100	MIXED	AMI	Yes	0%	99	0.13673762	0.065829	0.07090862	51.86%
8169	TPCODL	DHENKAN	TED	TALCHER	KALAMCHHUIN (DA	14331	11 KV DANARA	14331201	DANARA MOHANTY SAHI	4344DT204	100	MIXED	AMI	Yes	67%	141	0.0875345	0.076766	0.0107685	12.30%
8170	TPCODL	DHENKAN	TED	TALCHER	KALAMCHHUIN (DA	14331	11 KV DANARA	14331201	DANARA MAJHI SAHI	4344DT205	100	MIXED	AMI	Yes	100%	112	0.160455	0.056319	0.104136	64.90%
8171	TPCODL	DHENKAN	TED	TALCHER	KALAMCHHUIN (DA	14331	11 KV DANARA	14331201	DANARA HIGH SCHOOL-1	4344DT210	100	MIXED	AMI	Yes	67%	53	0.12202614	0.030603	0.09142314	74.92%
8172	TPCODL	DHENKAN	TED	TALCHER	KALAMCHHUIN (DA	14331	11 KV DANARA	14331201	DANARA V. S-2	4344DT212	100	MIXED	AMI	Yes	67%	86	0.09859329	0.042938	0.05565529	56.45%
8173	TPCODL	DHENKAN	TED	TALCHER	KALAMCHHUIN (DA	14331	11 KV DANARA	14331201	DANARA RAGUDI SAHI	4344DT214	100	MIXED	AMI	Yes	0%	64	0.11574388	0.041749	0.07399488	63.93%
8174	TPCODL	DHENKAN	TED	TALCHER	KALAMCHHUIN (DA	14331	11 KV KALAMCHHUIN	14331202	SOLADA NARAHARIPUR SAHI_01	4344DT302	100	MIXED	AMI	Yes	67%	65	0.08018564	0.056546	0.02363964	29.48%
8175	TPCODL	DHENKAN	TED	TALCHER	KALAMCHHUIN (DA	14331	11 KV KALAMCHHUIN	14331202	SOLADA NARAHARIPUR_02	4344DT303	100	MIXED	AMI	Yes	67%	68	0.09686216	0.043277	0.05358516	55.32%

Sl. No.	Zone Name	Circle name	Division name	Name of the Sub-division	Name of the Sub-station	Substation Code	Name of the 11 kV Feeder	Feeder Code	Name of the Location where DT situated	DT code	DT Capacity (kVA)	Predominant consumer type of DT (Domestic/Industrial/Agriculture/Mixed)	Type of metering AMR/AMI/ Communicable/Conventional metered/Unmetered	Status of Meter-whether Functional (Yes/No)	% of data received automatically (if AMR/AMI)	No. of Connected Consumers	Input Energy (MU) (A)	Billed Energy (MU) (B)	Loss (MU) (A-B)	% DT Loss (A-B)/A
8176	TPCODL	DHENKAN	TED	TALCHER	KALAMCHHUIN (DA	14331	11 KV KALAMCHHUIN	14331202	KANDHABERENI_01	4344DT308	100	MIXED	AMI	Yes	100%	41	0.05530705	0.02065	0.03465705	62.66%
8177	TPCODL	DHENKAN	TED	TALCHER	KALAMCHHUIN (DA	14331	11 KV KALAMCHHUIN	14331202	JORAGADIA UP SCHOOL	4344DT341	100	MIXED	AMI	Yes	33%	89	0.10330264	0.0332675	0.07003514	67.80%
8178	TPCODL	DHENKAN	TED	TALCHER	KALAMCHHUIN (DA	14331	11 KV KALAMCHHUIN	14331202	SOLADA THAKURANI SAHI	4344DT343	100	MIXED	AMI	Yes	67%	89	0.10181142	0.070627	0.03118442	30.63%
8179	TPCODL	DHENKAN	TED	TALCHER	KALAMCHHUIN (DA	14331	11 KV KALAMCHHUIN	14331202	BIRABARPUR MAJHI SAHI_01	4344DT353	100	MIXED	AMI	Yes	67%	80	0.09344286	0.038669	0.05477386	58.62%
8180	TPCODL	DHENKAN	TED	TALCHER	KALAMCHHUIN (DA	14331	11 KV KALAMCHHUIN	14331202	KALAMACHHUIN EKTALI_03	4344DT363	100	MIXED	AMI	Yes	33%	21	0.03834982	0.017251	0.02109882	55.02%
8181	TPCODL	DHENKAN	TED	TALCHER	KALAMCHHUIN (DA	14331	11 KV KALAMCHHUIN	14331202	KALAMACHHUIN PIDHA SAHI_01	4344DT369	100	MIXED	AMI	Yes	67%	97	0.1373236	0.073996	0.0633276	46.12%
8182	TPCODL	DHENKAN	TED	TALCHER	KALAMCHHUIN (DA	14331	11 KV GOPAL PRASAD	14331203	LAKEIPASI	4344DT223	100	MIXED	AMI	Yes	0%	85	0.11354698	0.044992	0.06855498	60.38%
8183	TPCODL	DHENKAN	TED	TALCHER	KALAMCHHUIN (DA	14331	11 KV GOPAL PRASAD	14331203	GOPALPRASAD NO-1	4344DT243	100	MIXED	AMI	Yes	67%	32	0.03102742	0.011499	0.01952842	62.94%
8184	TPCODL	DHENKAN	TED	TALCHER	KALAMCHHUIN (DA	14331	11 KV GOPAL PRASAD	14331203	GOPALPRASAD NO-2	4344DT398	100	MIXED	AMI	Yes	67%	60	0.06551316	0.025241	0.04027216	61.47%
8185	TPCODL	DHENKAN	TED	TALCHER	KALAMCHHUIN (DA	14331	11 KV GOPAL PRASAD	14331203	KUMUNDA NO-01	4344DT403	100	MIXED	AMI	Yes	67%	93	0.11043841	0.061638	0.04880041	44.19%
8186	TPCODL	DHENKAN	TED	TALCHER	KALAMCHHUIN (DA	14331	11 KV GOPAL PRASAD	14331203	KUMUNDA NO-02	4344DT408	100	MIXED	AMI	Yes	67%	127	0.10866076	0.066969	0.04169176	38.37%
8187	TPCODL	DHENKAN	TED	TALCHER	KANIHA	14148	11 KV KANIHA-1	14148201	TOLAKABEDA UP SCHOOL	4342DT389	100	MIXED	AMI	Yes	67%	70	0.03841738	0.024561	0.01385638	36.07%
8188	TPCODL	DHENKAN	TED	TALCHER	KANIHA	14148	11 KV KANIHA RE-1	14148202	TAKUA	4342DT306	100	MIXED	AMI	Yes	67%	44	0.06264674	0.022345	0.04030174	64.33%
8189	TPCODL	DHENKAN	TED	TALCHER	KANIHA	14148	11 KV KANIHA RE-2	14148203	SANATRIBIDA VILLAGE	4342DT194	100	MIXED	AMI	Yes	67%	129	0.06449306	0.041298	0.02319506	35.97%
8190	TPCODL	DHENKAN	TED	TALCHER	KANIHA	14148	11 KV KANIHA RE-2	14148203	SANAHAR	4342DT199	100	MIXED	AMI	Yes	0%	34	0.0390981	0.01421	0.0248881	63.66%
8191	TPCODL	DHENKAN	TED	TALCHER	KANIHA	14148	11 KV KANIHA RE-2	14148203	TELSINGHA	4342DT208	100	MIXED	AMI	Yes	33%	44	0.0448133	0.030821	0.0139923	31.22%
8192	TPCODL	DHENKAN	TED	TALCHER	KANIHA	14148	11 KV KANIHA RE-2	14148203	JARADA NEAR AIRTEL TOWER	4342DT213	100	MIXED	AMI	Yes	0%	68	0.07355148	0.027707	0.04584448	62.33%
8193	TPCODL	DHENKAN	TED	TALCHER	KANIHA	14148	11 KV KANIHA RE-2	14148203	CHHELIA TALA SAHI	4342DT220	100	MIXED	AMI	Yes	33%	47	0.02846942	0.009413	0.01905642	66.94%
8194	TPCODL	DHENKAN	TED	TALCHER	KANIHA	14148	11 KV KANIHA RE-2	14148203	KAMAREI VILLAGE	4342DT233	100	MIXED	AMI	Yes	33%	44	0.03396894	0.018404	0.01556494	45.82%
8195	TPCODL	DHENKAN	TED	TALCHER	KANIHA	14148	11 KV KANIHA RE-2	14148203	DANDASINGHA VILLAGE	4342DT239	100	MIXED	AMI	Yes	33%	99	0.08497789	0.037966	0.04701189	55.32%
8196	TPCODL	DHENKAN	TED	TALCHER	KANIHA	14148	11 KV KANIHA RE-2	14148203	BADATRIBIDA NEAR SBI	4342DT274	100	MIXED	AMI	Yes	0%	78	0.0784337	0.044925	0.0335087	42.72%
8197	TPCODL	DHENKAN	TED	TALCHER	KANIHA	14148	11 KV KANIHA RE-2	14148203	BADATRIBIDA HIGH SCHOOL	4342DT280	100	MIXED	AMI	Yes	0%	57	0.05223916	0.02947	0.02276916	43.59%
8198	TPCODL	DHENKAN	TED	TALCHER	KANIHA	14148	11 KV KANIHA RE-2	14148203	CHANDRABIL CAHNDRASEKHAR TEM	4342DT297	100	MIXED	AMI	Yes	0%	105	0.0670146	0.033396	0.0336186	50.17%
8199	TPCODL	DHENKAN	TED	TALCHER	KANIHA	14148	11 KV KANIHA RE-2	14148203	CHANDRABIL VILLAGE	4342DT298	100	MIXED	AMI	Yes	0%	71	0.063561	0.023727	0.039834	62.67%
8200	TPCODL	DHENKAN	TED	TALCHER	KANIHA	14148	11 KV KANIHA-2	14148204	KANIHA STRUCTURE DT	4342DT001	100	MIXED	AMI	Yes	0%	118	0.05376884	0.042711	0.01105784	20.57%
8201	TPCODL	DHENKAN	TED	TALCHER	KANIHA	14148	11 KV KANIHA-2	14148204	ANIMAL HEALTH CENTER QUARTER	4342DT003	100	MIXED	AMI	Yes	33%	45	0.07769512	0.049855	0.02784012	35.83%
8202	TPCODL	DHENKAN	TED	TALCHER	KANIHA	14148	11 KV KARADI	14148205	KARADEI	4343DT093	100	MIXED	AMI	Yes	67%	82	0.0760169	0.056357	0.0196599	25.86%
8203	TPCODL	DHENKAN	TED	TALCHER	KANIHA	14148	11 KV KARADI	14148205	GADASILA TENT HOUSE	4343DT102	100	MIXED	AMI	Yes	67%	73	0.05975582	0.039955	0.01980082	33.14%
8204	TPCODL	DHENKAN	TED	TALCHER	KANIHA	14148	11 KV KARADI	14148205	GADASILA TALA SAHI	4343DT105	100	MIXED	AMI	Yes	67%	63	0.06030235	0.033826	0.02647635	43.91%
8205	TPCODL	DHENKAN	TED	TALCHER	KANIHA	14148	11 KV KARADI	14148205	BIJIGOL PANCH CHHAK	4343DT126	100	MIXED	AMI	Yes	67%	67	0.06466828	0.043859	0.02080928	32.18%
8206	TPCODL	DHENKAN	TED	TALCHER	KANIHA	14148	11 KV KARADI	14148205	AMBAPAL ROAD 1	4343DT130	100	MIXED	AMI	Yes	0%	81	0.08812752	0.046897	0.04123052	46.79%
8207	TPCODL	DHENKAN	TED	TALCHER	KANIHA	14148	11 KV KARADI	14148205	NTPC BYPASS CHOWK BABA STEEL	4343DT166	250	MIXED	AMI	Yes	0%	93	0.15062424	0.069554	0.08107024	53.82%
8208	TPCODL	DHENKAN	TED	TALCHER	KANIHA	14148	11 KV KARADI	14148205	TELSINGHA CHHAK 1	4343DT168	250	MIXED	AMI	Yes	67%	67	0.14878356	0.058182	0.09060156	60.89%
8209	TPCODL	DHENKAN	TED	TALCHER	KANIHA	14148	11 KV KARADI	14148205	AMBAPAL CHHAK	4343DT173	63	MIXED	AMI	Yes	67%	22	0.01831255	0.016468	0.00184455	10.07%
8210	TPCODL	DHENKAN	TED	TALCHER	KANIHA	14148	11 KV KARADI	14148205	LODHABANDHA SUSANT ADVOCATE	4343DT177	100	MIXED	AMI	Yes	67%	98	0.13643962	0.094852	0.04158762	30.48%
8211	TPCODL	DHENKAN	TED	TALCHER	KANIHA	14148	11 KV KARADI	14148205	BHIMKANDA 2	4343DT180	25	MIXED	AMI	Yes	0%	18	0.03607	0.017696	0.018374	50.94%
8212	TPCODL	DHENKAN	TED	TALCHER	KANIHA	14148	11 KV KARADI	14148205	BIJUGULU TALESHINGA ROAD	4343DT186	63	MIXED	AMI	Yes	0%	81	0.09680099	0.076545	0.02025599	20.93%
8213	TPCODL	DHENKAN	TED	TALCHER	KANIHA	14148	11 KV KARADI	14148205	TELSINGA	4343DT188	100	MIXED	AMI	Yes	0%	65	0.08669114	0.056665	0.03002614	34.64%
8214	TPCODL	DHENKAN	TED	TALCHER	KANIHA	14148	11 KV DERANGA	14148206	KANSAMUNDA NEAR POND	4342DT009	100	MIXED	AMI	Yes	33%	96	0.05593118	0.052759	0.00317218	5.67%
8215	TPCODL	DHENKAN	TED	TALCHER	KANIHA	14148	11 KV DERANGA	14148206	KANSAMUNDA JATRA PADA SAHI	4342DT012	100	MIXED	AMI	Yes	0%	68	0.0647877	0.036928	0.0278597	43.00%
8216	TPCODL	DHENKAN	TED	TALCHER	KANIHA	14148	11 KV DERANGA	14148206	KANSAMUNDA PRADHAN SAHI	4342DT013	250	MIXED	AMI	Yes	33%	87	0.13380272	0.048044	0.08575872	64.09%
8217	TPCODL	DHENKAN	TED	TALCHER	KANIHA	14148	11 KV DERANGA	14148206	KANSAMUNDA SWAIN SAHI	4342DT038	100	MIXED	AMI	Yes	33%	47	0.04872544	0.026041	0.02268444	46.56%
8218	TPCODL	DHENKAN	TED	TALCHER	KANIHA	14148	11 KV DERANGA	14148206	JORADANGA_02	4342DT042	100	MIXED	AMI	Yes	33%	48	0.02931952	0.018605	0.01071452	36.54%
8219	TPCODL	DHENKAN	TED	TALCHER	KANIHA	14148	11 KV DERANGA	14148206	BADAGUNDURI UP SCHOOL_01	4342DT046	100	MIXED	AMI	Yes	67%	73	0.04093686	0.023003	0.01793386	43.81%
8220	TPCODL	DHENKAN	TED	TALCHER	KANIHA	14148	11 KV DERANGA	14148206	BADAGUNDURI UP SCHOOL_02	4342DT053	100	MIXED	AMI	Yes	0%	118	0.043995	0.02895	0.015045	34.20%
8221	TPCODL	DHENKAN	TED	TALCHER	KANIHA	14148	11 KV DERANGA	14148206	BADAGUNDURI BADBIL SAHI_02	4342DT069	100	MIXED	AMI	Yes	33%	79	0.0425011	0.019965	0.0225361	53.02%
8222	TPCODL	DHENKAN	TED	TALCHER	KANIHA	14148	11 KV DERANGA	14148206	BHUINPUR UP SCHOOL	4342DT073	100	MIXED	AMI	Yes	33%	88	0.07725604	0.028407	0.04884904	63.23%
8223	TPCODL	DHENKAN	TED	TALCHER	KANIHA	14148	11 KV DERANGA	14148206	KAKUDIA GP OFFICE	4342DT151	100	MIXED	AMI	Yes	0%	69	0.05311434	0.02081	0.03230434	60.82%
8224	TPCODL	DHENKAN	TED	TALCHER	KANIHA	14148	11 KV KIAJHAR	14148207	PATTAKHAMAN_01	4342DT367	100	MIXED	AMI	Yes	67%	43	0.02733842	0.018901	0.00843742	30.86%
8225	TPCODL	DHENKAN	TED	TALCHER	PARJANG	14143	11 KV Kandar Singha	14143206	KATABAHAL MAJHI SAHI	4331DT050	100	MIXED	AMI	Yes	33%	78	0.01891668	0.016799	0.00211768	11.19%
8226	TPCODL	DHENKAN	TED	TALCHER	SAMAL	14147	11 KV SAMAL VILLAGE	14147201	TIPPO VILLAGE	4343DT018	100	MIXED	AMI	Yes	67%	92	0.0655302	0.032751	0.0327792	50.02%
8227	TPCODL	DHENKAN	TED	TALCHER	SAMAL	14147	11 KV SAMAL VILLAGE	14147201	SAMAL VILLAGE PANCHAYAT OFFICE	4343DT024	100	MIXED	AMI	Yes	67%	89	0.05631914	0.025758	0.03056114	54.26%
8228	TPCODL	DHENKAN	TED	TALCHER	SAMAL	14147	11 KV SAMAL VILLAGE	14147201	BILINDA VILLAGE NEAR SCHOOL	4343DT063	100	MIXED	AMI	Yes	67%	122	0.0505257	0.046126	0.0043997	8.71%
8229	TPCODL	DHENKAN	TED	TALCHER	SAMAL	14147	11 KV BIJIGOL	14147202	RUTUBHUIN CRUSHER SIDE TELSING	4343DT031	100	MIXED	AMI	Yes	67%	16	0.0142088	0.01006	0.0041488	29.20%
8230	TPCODL	DHENKAN	TED	TALCHER	SAMAL	14147	11 KV BARRAGE COLONY	14147204	BARRAGE MEDICAL COLONY	4343DT004	100	MIXED	AMI	Yes	67%	45	0.01877704	0.007702	0.01107504	58.98%
8231	TPCODL	DHENKAN	TED	TALCHER	SAMAL	14147	11 KV BARRAGE COLONY	14147204	BARRAGE STORE NARAHATI	4343DT005	250	MIXED	AMI	Yes	33%	352	0.1783044	0.088545	0.0897594	50.34%
8232	TPCODL	DHENKAN	TED	TALCHER	TALCHER-2 NTPC	14375	11 KV TALCHER PALACE	14375201	PAIK SAHI 1	4345DT224	100	MIXED	AMI	Yes	0%	38	0.04609444	0.013596	0.03249844	70.50%
8233	TPCODL	DHENKAN	TED	TALCHER	TALCHER-2 NTPC	14375	11 KV TALCHER PALACE	14375201	GHODASALA NTPC	4345DT311	100	MIXED	AMI	Yes	100%	56	0.09634574	0.028228	0.06811774	70.70%
8234	TPCODL	DHENKAN	TED	TALCHER	TALCHER-2 NTPC	14375	11 KV TALCHER PALACE	14375201	TALCHER PALACE ROAD SAMANT QU	4345DT314	250	MIXED	AMI	Yes	100%	36	0.11693332	0.038151	0.07878232	67.37%
8235	TPCODL	DHENKAN	TED	TALCHER	TALCHER-2 NTPC	14375	11 KV TALCHER PALACE	14375201	SISHUMANDIR	4345DT318	100	MIXED	AMI	Yes	100%	14	0.0392416	0.013569	0.0256726	65.42%
8236	TPCODL	DHENKAN	TED	TALCHER	TALCHER-2 NTPC	14375	11 KV TALCHER PALACE	14375201	GOPINATHPUR VILLAGE	4345DT334	100	MIXED	AMI	Yes	0%	56	0.05930358	0.018056	0.04124758	69.55%
8237	TPCODL	DHENKAN	TED	TALCHER	TALCHER-2 NTPC	14375	11 KV BANTOL	14375202	BAGHUABOL VILLAGE	4345DT229	250	MIXED	AMI	Yes	0%	75	0.11357828	0.062097	0.05148128	45.33%
8238	TPCODL	DHENKAN	TED	TALCHER	TALCHER-2 NTPC	14375	11 KV BANTOL	14375202	SANTOSHIVIHAR CANAL SIDE	4345DT236	100	MIXED	AMI	Yes	100%	11	0.01323854	0.00719	0.00604854	45.69%
8239	TPCODL	DHENKAN	TED	TALCHER	TALCHER-2 NTPC	14375	11 KV BANTOL	14375202	BANATOL VILLAGE	4345DT240	100	MIXED	AMI	Yes	100%	37	0.05440328	0.015176	0.03922728	72.10%
8240	TPCODL	DHENKAN	TED	TALCHER	TALCHER-2 NTPC	14375	11 KV BANTOL	14375202	KUKUDULA VILLAGE 1	4345DT244	100	MIXED	AMI	Yes	100%	57	0.06520046	0.023987	0.04121346	63.21%
8241	TPCODL	DHENKAN	TED	TALCHER	TALCHER-2 NTPC	14375	11 KV BANTOL	14375202	KUKUDULA VILLAGE 2	4345DT245	100	MIXED	AMI	Yes	100%	46	0.07581242	0.018768	0.05704442	75.24%
8242	TPCODL	DHENKAN	TED	TALCHER	TALCHER-2 NTPC	14375	11 KV BANTOL	14375202	KUKUDULA RAIL GATE 1	4345DT247	100	MIXED	AMI	Yes	100%	50	0.10666446	0.030426	0.07623846	71.48%
8243	TPCODL	DHENKAN	TED	TALCHER	TALCHER-2 NTPC	14375	11 KV BANTOL	14375202	BALLAHAR VILLAGE TALA SAHI	4345DT257	100	MIXED	AMI	Yes	100%	54	0.15832958	0.060342	0.09798758	61.89%
8244	TPCODL	DHENKAN	TED	TALCHER	TALCHER-2 NTPC	14375	11 KV BANTOL	14375202	BALLAHAR VILLAGE 1	4345DT258	100	MIXED	AMI	Yes	100%	40	0.06538426	0.028839	0.03654526	55.89%
8245	TPCODL	DHENKAN	TED	TALCHER	TALCHER-2 NTPC	14375	11 KV BANTOL	14375202	SURYA VIHAR SURYA GARDEN BACK S	4345DT267	100	MIXED	AMI	Yes	100%	20	0.03567086	0.028425	0.00724586	20.31%
8246	TPCODL	DHENKAN	TED	TALCHER	TALCHER-2 NTPC	14375	11 KV BANTOL	14375202	AMRUTIDEIPUR	4345DT268	100	MIXED	AMI	Yes	100%	130	0.08645596	0.078187	0.00826896	9.56%
8247	TPCODL	DHENKAN	TED	TALCHER	TALCHER-2 NTPC	14375	11 KV BANTOL	14375202	BALLAHAR UP SCHOOL FRONT	4345DT274	100	MIXED	AMI	Yes	100%	64	0.0625528	0.045678	0.0168748	26.98%
8248	TPCODL	DHENKAN	TED	TALCHER	TALCHER-2 NTPC	14375	11 KV BANTOL	14375202	SANTOSHIVIHAR 2	4345DT280	250	MIXED	AMI	Yes	0%	82	0.21769408	0.089722	0.12797208	58.79%

Sl. No.	Zone Name	Circle name	Division name	Name of the Sub-division	Name of the Sub-station	Substation Code	Name of the 11 kV Feeder	Feeder Code	Name of the Location where DT situated	DT code	DT Capacity (kVA)	Predominant consumer type of DT (Domestic/Industrial/Agriculture/Mixed)	Type of metering AMR/AMI/ Communicable/Conventional metered/Unmetered	Status of Meter-whether Functional (Yes/No)	% of data received automatically (if AMR/AMI)	No. of Connected Consumers	Input Energy (MU) (A)	Billed Energy (MU) (B)	Loss (MU) (A-B)	% DT Loss (A-B)/A
8249	TPCODL	DHENKAN	TED	TALCHER	TALCHER-2 NTPC	14375	11 KV HANDIDHUA	14375203	BAGHUABOL PM PRADHAN	4345DT163	100	MIXED	AMI	Yes	100%	38	0.04311716	0.037085	0.00603216	13.99%
8250	TPCODL	DHENKAN	TED	TALCHER	TALCHER-2 NTPC	14375	11 KV HANDIDHUA	14375203	BAGHUABOL KAMANA MANDIR 1	4345DT168	100	MIXED	AMI	Yes	100%	86	0.0954642	0.041144	0.0543202	56.90%
8251	TPCODL	DHENKAN	TED	TALCHER	TALCHER-2 NTPC	14375	11 KV HANDIDHUA	14375203	BAGHUABOL KAMANA MANDIR 2	4345DT169	250	MIXED	AMI	Yes	100%	166	0.220315	0.078181	0.142134	64.51%
8252	TPCODL	DHENKAN	TED	TALCHER	TALCHER-2 NTPC	14375	11 KV HANDIDHUA	14375203	BAGHUABOL CHHAK MAHESH SAHO	4345DT171	100	MIXED	AMI	Yes	100%	49	0.11619174	0.054405	0.06178674	53.18%
8253	TPCODL	DHENKAN	TED	TALCHER	TALCHER-2 NTPC	14375	11 KV HANDIDHUA	14375203	GANDHI CHHAK CANAL SIDE	4345DT183	100	MIXED	AMI	Yes	67%	88	0.09747638	0.069059	0.02841738	29.15%
8254	TPCODL	DHENKAN	TED	TALCHER	TALCHER-2 NTPC	14375	11 KV HANDIDHUA	14375203	GANDHI CHHAK	4345DT184	250	MIXED	AMI	Yes	100%	141	0.18050132	0.124145	0.05635632	31.22%
8255	TPCODL	DHENKAN	TED	TALCHER	TALCHER-2 NTPC	14375	11 KV HANDIDHUA	14375203	GANESH VIHAR	4345DT193	250	MIXED	AMI	Yes	100%	85	0.18096392	0.087286	0.09367792	51.77%
8256	TPCODL	DHENKAN	TED	TALCHER	TALCHER-2 NTPC	14375	11 KV ITI	14375204	MADABHATI COLONY	4345DT157	100	MIXED	AMI	Yes	100%	132	0.0974926	0.093594	0.0038986	4.00%
8257	TPCODL	PARADEEP	JED	BALIKUDA	22MAUJA	14193	11 kV BAGALPUR	14193201	BHAGALPUR 200KV	5331DT235	200	MIXED	AMI	Yes	0%	166	0.13578728	0.075898	0.05988928	44.11%
8258	TPCODL	PARADEEP	JED	BALIKUDA	BALIKUDA	14174	11 KV DENGAPOLA	14174201	KRUSHNDASHPUR VILAGE (SCHOOL)	5311DT071	100	MIXED	AMI	Yes	67%	96	0.03111114	0.027596	0.00351514	11.30%
8259	TPCODL	PARADEEP	JED	BALIKUDA	BALIKUDA	14174	11 KV DENGAPOLA	14174201	DALANA VILLAGE	5311DT074	100	MIXED	AMI	Yes	67%	94	0.03227568	0.025364	0.00691168	21.41%
8260	TPCODL	PARADEEP	JED	BALIKUDA	BALIKUDA	14174	11 KV DENGAPOLA	14174201	SARANA VILLAGE 1	5311DT106	100	MIXED	AMI	Yes	67%	138	0.04760826	0.035419	0.01218926	25.60%
8261	TPCODL	PARADEEP	JED	BALIKUDA	BALIKUDA	14174	11 KV DENGAPOLA	14174201	SANAKARA VILAGE 2	5311DT112	100	MIXED	AMI	Yes	67%	80	0.04221091	0.028342	0.01386891	32.86%
8262	TPCODL	PARADEEP	JED	BALIKUDA	BALIKUDA	14174	11 KV DENGAPOLA	14174201	PAHARAHTA VILLAGE 2	5311DT121	500	MIXED	AMI	Yes	67%	229	0.09709664	0.09244607	0.00465057	4.79%
8263	TPCODL	PARADEEP	JED	BALIKUDA	BALIKUDA	14174	11 KV DENGAPOLA	14174201	KHANKARAPUR VILLAGE 2	5311DT122	100	MIXED	AMI	Yes	67%	102	0.04097352	0.0322	0.00877352	21.41%
8264	TPCODL	PARADEEP	JED	BALIKUDA	BALIKUDA	14174	11 KV DENGAPOLA	14174201	NETAPUR VILLAGE	5311DT138	100	MIXED	AMI	Yes	0%	109	0.05587598	0.03025	0.02562598	45.86%
8265	TPCODL	PARADEEP	JED	BALIKUDA	BALIKUDA	14174	11 KV SANGRAMPUR	14174202	REVERSITE 200 KVA	5311DT273	200	MIXED	AMI	Yes	100%	189	0.0713442	0.056515	0.0148292	20.79%
8266	TPCODL	PARADEEP	JED	BALIKUDA	BALIKUDA	14174	11 KV SANGRAMPUR	14174202	GOGALA	5313DT299	300	MIXED	AMI	Yes	67%	145	0.05026904	0.038313	0.01195604	23.78%
8267	TPCODL	PARADEEP	JED	BALIKUDA	BALIKUDA	14174	11 KV SANGRAMPUR	14174202	ACHHUTU PUR VILLAGE	5313DT301	100	MIXED	AMI	Yes	0%	90	0.04038721	0.021018	0.01936921	47.96%
8268	TPCODL	PARADEEP	JED	BALIKUDA	BALIKUDA	14174	11 KV SANGRAMPUR	14174202	BUDHISAHI VILLAGE2	5313DT303	250	MIXED	AMI	Yes	67%	42	0.031772	0.008234	0.023538	74.08%
8269	TPCODL	PARADEEP	JED	BALIKUDA	BALIKUDA	14174	11 KV SANGRAMPUR	14174202	GAGIRIPADA	5313DT304	250	MIXED	AMI	Yes	67%	100	0.02299198	0.022486	0.00050598	2.20%
8270	TPCODL	PARADEEP	JED	BALIKUDA	BALIKUDA	14174	11 KV SANGRAMPUR	14174202	DHAIPALA 1	5313DT327	250	MIXED	AMI	Yes	0%	85	0.05124348	0.027281	0.02396248	46.76%
8271	TPCODL	PARADEEP	JED	BALIKUDA	BALIKUDA	14174	11 KV BALIKUDA	14174203	AKHANDA MANI	5311DT029	100	MIXED	AMI	Yes	100%	171	0.07378591	0.058104	0.01568191	21.25%
8272	TPCODL	PARADEEP	JED	BALIKUDA	BALIKUDA	14174	11 KV BALIKUDA	14174203	BIRA BABA	5311DT034	100	MIXED	AMI	Yes	0%	135	0.09604644	0.058692	0.03735444	38.89%
8273	TPCODL	PARADEEP	JED	BALIKUDA	BALIKUDA	14174	11 KV BALIKUDA	14174203	UGRA TARA	5311DT038	100	MIXED	AMI	Yes	100%	103	0.03634276	0.032038	0.00430476	11.84%
8274	TPCODL	PARADEEP	JED	BALIKUDA	BALIKUDA	14174	11 KV BADAGAON	14174204	NEAR BY MAA BATAMANGALA TAMP	5311DT147	100	MIXED	AMI	Yes	67%	60	0.01684444	0.014028	0.00281644	16.72%
8275	TPCODL	PARADEEP	JED	BALIKUDA	BALIKUDA	14174	11 KV BADAGAON	14174204	NEAR BY NARSINGHPUR SCHOOL	5311DT150	100	MIXED	AMI	Yes	67%	79	0.02823142	0.021947	0.00628442	22.26%
8276	TPCODL	PARADEEP	JED	BALIKUDA	BALIKUDA	14174	11 KV BADAGAON	14174204	NEAR BY TANDAUNI VILLAGE	5311DT175	250	MIXED	AMI	Yes	67%	137	0.05109596	0.040295	0.01080096	21.14%
8277	TPCODL	PARADEEP	JED	BALIKUDA	BALIKUDA	14174	11 KV BADAGAON	14174204	KANPUR BAZAR	5311DT180	100	MIXED	AMI	Yes	67%	92	0.03453844	0.026789	0.00774944	22.44%
8278	TPCODL	PARADEEP	JED	BALIKUDA	BALIKUDA	14174	11 KV BADAGAON	14174204	CANAL ROAD BHUTAGHER	5311DT195	100	MIXED	AMI	Yes	67%	56	0.02377926	0.015797	0.00798226	33.57%
8279	TPCODL	PARADEEP	JED	BALIKUDA	BALIKUDA	14174	11 KV BADAGAON	14174204	OGOAPUR VILLAGE	5311DT207	100	MIXED	AMI	Yes	67%	96	0.03042014	0.026641	0.00377914	12.42%
8280	TPCODL	PARADEEP	JED	BALIKUDA	BALIKUDA	14174	11 KV BADAGAON	14174204	NEAR BY BADAGOAN HIGH SCHOOL	5311DT245	63	MIXED	AMI	Yes	67%	67	0.0303682	0.0234	0.0069682	22.95%
8281	TPCODL	PARADEEP	JED	BALIKUDA	BALIKUDA	14174	11 KV BADAGAON	14174204	NEAR BY SCHOOL, NORDIA	5311DT265	100	MIXED	AMI	Yes	67%	56	0.04079717	0.017813	0.02298417	56.34%
8282	TPCODL	PARADEEP	JED	BALIKUDA	BALIKUDA	14174	11 KV NAGAPUR	14174205	ALIKANTA POST OFFICE	5311DT298	100	MIXED	AMI	Yes	67%	75	0.01639822	0.014643	0.00175522	10.70%
8283	TPCODL	PARADEEP	JED	BALIKUDA	BALIKUDA	14174	11 KV NAGAPUR	14174205	THAILO250KV	5311DT310	250	MIXED	AMI	Yes	67%	150	0.06536044	0.047246	0.01811444	27.71%
8284	TPCODL	PARADEEP	JED	BALIKUDA	BALIKUDA	14174	11 KV NAGAPUR	14174205	MALIKAPUR RI OFFICE	5311DT315	100	MIXED	AMI	Yes	100%	88	0.0290391	0.021932	0.0071071	24.47%
8285	TPCODL	PARADEEP	JED	BALIKUDA	BALIKUDA	14174	11 KV NAGAPUR	14174205	DHANISO VILLAGE	5311DT327	100	MIXED	AMI	Yes	0%	98	0.0417283	0.029267	0.0124613	29.86%
8286	TPCODL	PARADEEP	JED	BALIKUDA	BALIKUDA	14174	11 KV NAGAPUR	14174205	TAINKULA	5311DT340	100	MIXED	AMI	Yes	0%	32	0.018479	0.008062	0.010417	56.37%
8287	TPCODL	PARADEEP	JED	BALIKUDA	BALIKUDA	14174	11 KV NAGAPUR	14174205	KHANDI ARILO 2	5311DT342	63	MIXED	AMI	Yes	100%	80	0.02432266	0.018456	0.00586666	24.12%
8288	TPCODL	PARADEEP	JED	BALIKUDA	BALIKUDA	14174	11 KV NAGAPUR	14174205	SIRAILO VILLAGE 2	5311DT348	63	MIXED	AMI	Yes	100%	70	0.02175486	0.019007	0.00274786	12.63%
8289	TPCODL	PARADEEP	JED	BALIKUDA	BALIKUDA	14174	11 KV NAGAPUR	14174205	BAHARANA DANDASAI	5311DT352	63	MIXED	AMI	Yes	100%	45	0.01549482	0.011353	0.00414182	26.73%
8290	TPCODL	PARADEEP	JED	BALIKUDA	BALIKUDA	14174	11 KV NAGAPUR	14174205	ALOBALA VILLAGE	5311DT383	63	MIXED	AMI	Yes	100%	110	0.04073306	0.036448	0.00428506	10.52%
8291	TPCODL	PARADEEP	JED	BALIKUDA	BALIKUDA	14174	11 KV RWSS /PHD	14174206	NARANPUR	5311DT006	100	MIXED	AMI	Yes	67%	100	0.02934301	0.023738	0.00560501	19.10%
8292	TPCODL	PARADEEP	JED	BALIKUDA	BARANGA (MARKAN	14362	11 KV FDR4	14362204	KODALA	5324DT221	100	MIXED	AMI	Yes	100%	96	0.0452451	0.030019	0.0152261	33.65%
8293	TPCODL	PARADEEP	JED	BALIKUDA	BHATAPADA ODSSP	14360	11 KV KHAIRA	14360202	BENAPADA	5313DT359	100	MIXED	AMI	Yes	67%	64	0.03659414	0.017515	0.01907914	52.14%
8294	TPCODL	PARADEEP	JED	BALIKUDA	BHATAPADA ODSSP	14360	11 KV KHAIRA	14360202	GREEN GOLA	5313DT364	100	MIXED	AMI	Yes	67%	117	0.08332652	0.052444	0.03088252	37.06%
8295	TPCODL	PARADEEP	JED	BALIKUDA	BHATAPADA ODSSP	14360	11 KV KHAIRA	14360202	NUAGAON	5313DT375	250	MIXED	AMI	Yes	0%	101	0.03999162	0.026535	0.01345662	33.65%
8296	TPCODL	PARADEEP	JED	BALIKUDA	BHATAPADA ODSSP	14360	11 KV KHAIRA	14360202	KUNDESHWARA 1	5313DT380	100	MIXED	AMI	Yes	67%	35	0.02690384	0.01467	0.01223384	45.47%
8297	TPCODL	PARADEEP	JED	BALIKUDA	BHATAPADA ODSSP	14360	11 KV KHAIRA	14360202	CHANARPUR MUSALMAN SAHI	5313DT391	100	MIXED	AMI	Yes	67%	112	0.19071928	0.052959	0.13776028	72.23%
8298	TPCODL	PARADEEP	JED	BALIKUDA	BHATAPADA ODSSP	14360	11 KV KHAIRA	14360202	GARAM	5313DT400	100	MIXED	AMI	Yes	100%	133	0.04225999	0.033811	0.00844899	19.99%
8299	TPCODL	PARADEEP	JED	BALIKUDA	DERIK-GANGADA OI	14357	11 KV DERIKI	14357201	DERIKI 1	5313DT112	100	MIXED	AMI	Yes	100%	91	0.05967906	0.039127	0.02055206	34.44%
8300	TPCODL	PARADEEP	JED	BALIKUDA	DERIK-GANGADA OI	14357	11 KV DERIKI	14357201	DERIKI 3	5313DT114	100	MIXED	AMI	Yes	100%	312	0.11497862	0.104985	0.00999362	8.69%
8301	TPCODL	PARADEEP	JED	BALIKUDA	DERIK-GANGADA OI	14357	11 KV SALAJANGA	14357202	SALIJANGA 1	5313DT220	100	MIXED	AMI	Yes	67%	164	0.05707464	0.043221	0.01385364	24.27%
8302	TPCODL	PARADEEP	JED	BALIKUDA	DERIK-GANGADA OI	14357	11 KV MUTUNIA	14357204	BALIKULA VILLAGE 1	5313DT166	100	MIXED	AMI	Yes	0%	35	0.01155143	0.008898	0.00265343	22.97%
8303	TPCODL	PARADEEP	JED	BALIKUDA	DERIK-GANGADA OI	14357	11 KV MUTUNIA	14357204	DHUANPADA 1	5313DT188	100	MIXED	AMI	Yes	67%	78	0.03052136	0.024161	0.00636036	20.84%
8304	TPCODL	PARADEEP	JED	BALIKUDA	DUSBATIA ODSSP	14361	11 KV NAHARANA	14361201	NEAR BARENDRA BARIKA NAHARANA	5312DT089	250	MIXED	AMI	Yes	100%	177	0.08477044	0.038114	0.04665644	55.04%
8305	TPCODL	PARADEEP	JED	BALIKUDA	DUSBATIA ODSSP	14361	11 KV NAHARANA	14361201	TASLA TRANSFORMERPVTNR NAHAR	5312DT093	100	MIXED	AMI	Yes	0%	145	0.0451456	0.024375	0.0207706	46.01%
8306	TPCODL	PARADEEP	JED	BALIKUDA	DUSBATIA ODSSP	14361	11 KV NAHARANA	14361201	NEAR BALIPATANA PW BANDHA ME	5312DT094	100	MIXED	AMI	Yes	33%	90	0.03413034	0.019775	0.01435534	42.06%
8307	TPCODL	PARADEEP	JED	BALIKUDA	DUSBATIA ODSSP	14361	11 KV NAHARANA	14361201	NEAR PANITANKI GANDAKULA	5312DT097	100	MIXED	AMI	Yes	67%	48	0.0142952	0.011457	0.0028382	19.85%
8308	TPCODL	PARADEEP	JED	BALIKUDA	DUSBATIA ODSSP	14361	11 KV NAHARANA	14361201	NEAR GANDAKULA TOWER 1	5312DT098	100	MIXED	AMI	Yes	100%	51	0.02060764	0.013966	0.00664164	32.23%
8309	TPCODL	PARADEEP	JED	BALIKUDA	DUSBATIA ODSSP	14361	11 KV BANDAR	14361202	BAGEIPUR VILLEGE 2	5312DT027	100	MIXED	AMI	Yes	67%	49	0.03031736	0.011157	0.01916036	63.20%
8310	TPCODL	PARADEEP	JED	BALIKUDA	DUSBATIA ODSSP	14361	11 KV BANDAR	14361202	MARICHPUR POND SIDE 1	5312DT030	100	MIXED	AMI	Yes	67%	139	0.04423368	0.032112	0.01212168	27.40%
8311	TPCODL	PARADEEP	JED	BALIKUDA	DUSBATIA ODSSP	14361	11 KV BANDAR	14361202	MAA BANDAREI TEMPLE SIDE 1	5312DT043	63	MIXED	AMI	Yes	33%	38	0.02944772	0.01054	0.01890772	64.21%
8312	TPCODL	PARADEEP	JED	BALIKUDA	DUSBATIA ODSSP	14361	11 KV BANDAR	14361202	DHANUHARBELARI 100	5312DT058	100	MIXED	AMI	Yes	33%	136	0.04230766	0.030682	0.01162566	27.48%
8313	TPCODL	PARADEEP	JED	BALIKUDA	DUSBATIA ODSSP	14361	11 KV Tentulibelari	14361203	MAALAXMI PUJA MANDAP KHADIKAI	5312DT133	250	MIXED	AMI	Yes	100%	197	0.07563868	0.034668	0.04097068	54.17%
8314	TPCODL	PARADEEP	JED	BALIKUDA	DUSBATIA ODSSP	14361	11 KV Tentulibelari	14361203	TENTULIBELARI DANDABEDI MARKET	5312DT162	100	MIXED	AMI	Yes	100%	111	0.04677134	0.017848	0.02892334	61.84%
8315	TPCODL	PARADEEP	JED	BALIKUDA	DUSBATIA ODSSP	14361	11 KV Tentulibelari	14361203	SITALA DEVI TEMPLE	5312DT164	100	MIXED	AMI	Yes	0%	75	0.06224554	0.018095	0.04415054	70.93%
8316	TPCODL	PARADEEP	JED	BALIKUDA	DUVALO (BORIKINA	14358	11 KV BORIKINA	14358201	TITRA ROAD	5312DT408	100	MIXED	AMI	Yes	67%	210	0.11111756	0.085079	0.02603856	23.43%
8317	TPCODL	PARADEEP	JED	BALIKUDA	DUVALO (BORIKINA	14358	11 KV BORIKINA	14358201	OLASA 1	5312DT419	100	MIXED	AMI	Yes	67%	135	0.03701428	0.03551	0.00150428	4.06%
8318	TPCODL	PARADEEP	JED	BALIKUDA	DUVALO (BORIKINA	14358	11 KV BORIKINA	14358201	ORANDA 2	5312DT434	100	MIXED	AMI	Yes	67%	153	0.05005934	0.037711	0.01234834	24.67%
8319	TPCODL	PARADEEP	JED	BALIKUDA	DUVALO (BORIKINA	14358	11 KV BORIKINA	14358201	MURUNIA	5312DT444	100	MIXED	AMI	Yes	67%	150	0.05070196	0.038981	0.01172096	23.12%
8320	TPCODL	PARADEEP	JED	BALIKUDA	DUVALO (BORIKINA	14358	11 KV BORIKINA	14358201	NARADIA	5312DT472	100	MIXED	AMI	Yes	67%	120	0.0441746	0.030831	0.0133436	30.21%
8321	TPCODL	PARADEEP	JED	BALIKUDA	DUVALO (BORIKINA	14358	11 KV TITIRA	14358203	BAHARAMPUR 1	5312DT366	100	MIXED	AMI	Yes	67%	57	0.01945932	0.009258	0.01020132	52.42%

Sl. No.	Zone Name	Circle name	Division name	Name of the Sub-division	Name of the Sub-station	Substation Code	Name of the 11 kV Feeder	Feeder Code	Name of the Location where DT situated	DT code	DT Capacity (kVA)	Predominant consumer type of DT (Domestic/Industrial/Agriculture/Mixed)	Type of metering AMR/AMI/ Communicable/Conventional metered/Unmetered	Status of Meter-whether Functional (Yes/No)	% of data received automatically (if AMR/AMI)	No. of Connected Consumers	Input Energy (MU) (A)	Billed Energy (MU) (B)	Loss (MU) (A-B)	% DT Loss (A-B)/A
8322	TPCODL	PARADEEP	JED	BALIKUDA	DUVALO (BORIKINA	14358	11 KV TITIRA	14358203	PALADHUABANDHA	5312DT370	100	MIXED	AMI	Yes	0%	100	0.06488576	0.023575	0.04131076	63.67%
8323	TPCODL	PARADEEP	JED	BALIKUDA	DUVALO (BORIKINA	14358	11 KV TITIRA	14358203	TITRA 3	5312DT394	100	MIXED	AMI	Yes	67%	111	0.04897732	0.032588	0.01638932	33.46%
8324	TPCODL	PARADEEP	JED	BALIKUDA	DUVALO (BORIKINA	14358	11 KV TITIRA	14358203	KEUTA PALA	5312DT399	100	MIXED	AMI	Yes	67%	27	0.01373952	0.007788	0.00595152	43.32%
8325	TPCODL	PARADEEP	JED	BALIKUDA	JAGANNATHPUR OD	14340	11 KV JAGANNATHPUR	14340201	BRAHMAPUR	5431DT740	100	MIXED	AMI	Yes	100%	127	0.0477137	0.036769	0.0109447	22.94%
8326	TPCODL	PARADEEP	JED	BALIKUDA	JOGESWARPUR (GA	14263	11 KV Nayhata	14263202	JAGANNATHPUR-1	1413DT576	100	MIXED	AMI	Yes	67%	190	0.0544947	0.047355	0.0071397	13.10%
8327	TPCODL	PARADEEP	JED	BALIKUDA	KANAKPUR ODSSP	14341	11 KV MULISINGH	14341203	GOPALPUR 4	5323DT242	100	MIXED	AMI	Yes	67%	81	0.06258232	0.047007	0.01557532	24.89%
8328	TPCODL	PARADEEP	JED	BALIKUDA	NAUGAON	14194	11 KV ROHIA	14194201	BACHHALO (JANGIAPADIA) 1	5313DT253	100	MIXED	AMI	Yes	100%	92	0.0692983	0.025104	0.0441943	63.77%
8329	TPCODL	PARADEEP	JED	BALIKUDA	NAUGAON	14194	11 KV CHANDPUR	14194202	NAUGAON HAT	5313DT062	100	MIXED	AMI	Yes	0%	129	0.1104947	0.05876	0.0517347	46.82%
8330	TPCODL	PARADEEP	JED	BALIKUDA	NAUGAON	14194	11 KV CHANDPUR	14194202	CHANDAPURA	5313DT068	100	MIXED	AMI	Yes	100%	100	0.04535626	0.038171	0.00718526	15.84%
8331	TPCODL	PARADEEP	JED	BALIKUDA	NAUGAON	14194	11 KV CHANDPUR	14194202	BANSHA	5313DT073	100	MIXED	AMI	Yes	100%	81	0.0352572	0.021495	0.0137622	39.03%
8332	TPCODL	PARADEEP	JED	BALIKUDA	NAUGAON	14194	11 KV SIKHARA	14194203	NAUGAON 2, TALASAHI	5313DT006	100	MIXED	AMI	Yes	100%	177	0.07260984	0.049897	0.02271284	31.28%
8333	TPCODL	PARADEEP	JED	BALIKUDA	NAUGAON	14194	11 KV SIKHARA	14194203	BILIPADA	5313DT017	100	MIXED	AMI	Yes	100%	132	0.0480026	0.037789	0.0102136	21.28%
8334	TPCODL	PARADEEP	JED	BALIKUDA	NAUGAON	14194	11 KV NAUGAON HQ	14194204	ODAPAINGA	5313DT024	100	MIXED	AMI	Yes	100%	69	0.02569324	0.020621	0.00507224	19.74%
8335	TPCODL	PARADEEP	JED	BALIKUDA	NAUGAON	14194	11 KV NAUGAON HQ	14194204	HARASHPUR	5313DT026	100	MIXED	AMI	Yes	100%	33	0.01469522	0.012122	0.00257322	17.51%
8336	TPCODL	PARADEEP	JED	BALIKUDA	NAUGAON	14194	11 KV NAUGAON HQ	14194204	BLOCK CHHAK	5313DT030	100	MIXED	AMI	Yes	0%	185	0.12613475	0.073655	0.05247975	41.61%
8337	TPCODL	PARADEEP	JED	BALIKUDA	NUAPOLA / NABAPA	14181	11 KV MANDASAHI	14181202	GHADIMULA 1	5324DT129	100	MIXED	AMI	Yes	33%	156	0.05152957	0.050362	0.00116757	2.27%
8338	TPCODL	PARADEEP	JED	BALIKUDA	SASANPADA	14218	11 KV ALIPINGAL	14218202	FULARA1	5322DT354	250	MIXED	AMI	Yes	67%	123	0.12451596	0.025883	0.09863296	79.21%
8339	TPCODL	PARADEEP	JED	BALIKUDA	SOVA	14173	11 KV AMBASALA	14173201	NADA 2	5312DT228	100	MIXED	AMI	Yes	67%	101	0.04468386	0.028565	0.01611886	36.07%
8340	TPCODL	PARADEEP	JED	BALIKUDA	SOVA	14173	11 KV AMBASALA	14173201	AMBASALA INDUSTRIES TRANSFORM	5312DT234	250	MIXED	AMI	Yes	67%	169	0.07984904	0.066902	0.01294704	16.21%
8341	TPCODL	PARADEEP	JED	BALIKUDA	SOVA	14173	11 KV MACHHAGAON	14173202	OCHINDA ROAD	5312DT253	250	MIXED	AMI	Yes	0%	81	0.13592016	0.032264	0.10365616	76.26%
8342	TPCODL	PARADEEP	JED	BALIKUDA	SOVA	14173	11 KV MACHHAGAON	14173202	DABER ROAD 2	5312DT256	100	MIXED	AMI	Yes	67%	26	0.01991746	0.007388	0.01252946	62.91%
8343	TPCODL	PARADEEP	JED	BALIKUDA	SOVA	14173	11 KV MACHHAGAON	14173202	DABER HIGH SCHOOL	5312DT257	100	MIXED	AMI	Yes	67%	117	0.03125652	0.018666	0.01259052	40.28%
8344	TPCODL	PARADEEP	JED	BALIKUDA	SOVA	14173	11 KV MACHHAGAON	14173202	SADHUBRAM TEMPLE 2	5312DT263	100	MIXED	AMI	Yes	67%	81	0.02923006	0.020338	0.00889206	30.42%
8345	TPCODL	PARADEEP	JED	BALIKUDA	SOVA	14173	11 KV MACHHAGAON	14173202	ANGARWA 2	5312DT265	100	MIXED	AMI	Yes	67%	68	0.01748038	0.012923	0.00455738	26.07%
8346	TPCODL	PARADEEP	JED	BALIKUDA	SOVA	14173	11 KV MACHHAGAON	14173202	KUTAMCHANDI TEMPLE	5313DT240	100	MIXED	AMI	Yes	67%	80	0.03702802	0.020007	0.01702102	45.97%
8347	TPCODL	PARADEEP	JED	BALIKUDA	SOVA	14173	11 KV MACHHAGAON	14173202	CANAL ROAD	5313DT241	100	MIXED	AMI	Yes	67%	129	0.04576038	0.029052	0.01670838	36.51%
8348	TPCODL	PARADEEP	JED	BALIKUDA	SOVA	14173	11 KV SOVA	14173204	PURUSOTAM	5312DT110	100	MIXED	AMI	Yes	100%	173	0.06356917	0.04342	0.02014917	31.70%
8349	TPCODL	PARADEEP	JED	BALIKUDA	SOVA	14173	11 KV SOVA	14173204	KHELWA 1	5312DT112	100	MIXED	AMI	Yes	0%	94	0.02342786	0.022072	0.00135586	5.79%
8350	TPCODL	PARADEEP	JED	BALIKUDA	SOVA	14173	11 kV OSKANA	14173205	NEAR BY TAMPLE	5312DT173	100	MIXED	AMI	Yes	100%	41	0.01989682	0.012028	0.00786882	39.55%
8351	TPCODL	PARADEEP	JED	BALIKUDA	SOVA	14173	11 kV OSKANA	14173205	SIMANTPUR VILLAGE	5312DT183	100	MIXED	AMI	Yes	67%	156	0.04822001	0.032323	0.01589701	32.97%
8352	TPCODL	PARADEEP	JED	JAGATSINGPUR	JAGATSINGHPUR	14169	11 kV TOWN	14169203	MUNICIPALITY	5322DT099	500	MIXED	AMI	Yes	100%	300	0.34662848	0.278824	0.06780448	19.56%
8353	TPCODL	PARADEEP	JED	JAGATSINGPUR	JAGATSINGHPUR	14169	11 kV CHHAPADA	14169201	DINGESWAR 3	5323DT031	100	MIXED	AMI	Yes	0%	96	0.06002253	0.044044	0.01597853	26.62%
8354	TPCODL	PARADEEP	JED	JAGATSINGPUR	JAGATSINGHPUR	14169	11 kV CHHAPADA	14169201	KULA SAHI	5323DT119	100	MIXED	AMI	Yes	0%	119	0.07098271	0.058509	0.01247371	17.57%
8355	TPCODL	PARADEEP	JED	JAGATSINGPUR	NUAPOLA / NABAPA	14181	11 kV MANDASAHI	14181202	KENDAL-1	5324DT008	100	MIXED	AMI	Yes	0%	124	0.08443231	0.04932	0.03511231	41.59%
8356	TPCODL	PARADEEP	JED	JAGATSINGPUR	NUAPOLA / NABAPA	14181	11 kV TARIKUNDA	14181201	NABAPATANA SOCIETY	5324DT205	100	MIXED	AMI	Yes	0%	93	0.04658615	0.035659	0.01092715	23.46%
8357	TPCODL	PARADEEP	JED	JAGATSINGPUR	BALIA (ADHANGA) (	14359	11 KV JAYSOL	14359203	JAYSOLE2	5324DT211	100	MIXED	AMI	Yes	100%	58	0.02976323	0.023274	0.00648923	21.80%
8358	TPCODL	PARADEEP	JED	JAGATSINGPUR	BARANGA (MARKAN	14362	11 KV Badabag-1	14362201	KANTABALARPUR	5322DT408	100	MIXED	AMI	Yes	100%	142	0.07847496	0.053865	0.02460996	31.36%
8359	TPCODL	PARADEEP	JED	JAGATSINGPUR	BARANGA (MARKAN	14362	11 KV Badabag-1	14362201	SUNAMUNHI(OLD)	5322DT411	100	MIXED	AMI	Yes	100%	97	0.06349874	0.044251	0.01924774	30.31%
8360	TPCODL	PARADEEP	JED	JAGATSINGPUR	BARANGA (MARKAN	14362	11 KV Badabag-1	14362201	TOLAPADA	5322DT413	100	MIXED	AMI	Yes	100%	58	0.03992218	0.033494	0.00642818	16.10%
8361	TPCODL	PARADEEP	JED	JAGATSINGPUR	BARANGA (MARKAN	14362	11 KV MANGALPUR	14362202	SUNDHI SAHI GADA	5322DT417	100	MIXED	AMI	Yes	100%	38	0.02493944	0.022538	0.00240144	9.63%
8362	TPCODL	PARADEEP	JED	JAGATSINGPUR	BARANGA (MARKAN	14362	11 KV MANGALPUR	14362202	DASARA PADIA	5322DT422	100	MIXED	AMI	Yes	100%	50	0.02316012	0.020337	0.00282312	12.19%
8363	TPCODL	PARADEEP	JED	JAGATSINGPUR	BARANGA (MARKAN	14362	11 KV MANGALPUR	14362202	PUNANAG	5322DT423	100	MIXED	AMI	Yes	100%	72	0.05244917	0.046526	0.00592317	11.29%
8364	TPCODL	PARADEEP	JED	JAGATSINGPUR	BARANGA (MARKAN	14362	11 KV MANGALPUR	14362202	KHUNTIA SAHI	5322DT426	100	MIXED	AMI	Yes	100%	36	0.02049536	0.014934	0.00556136	27.13%
8365	TPCODL	PARADEEP	JED	JAGATSINGPUR	BARANGA (MARKAN	14362	11 KV MANGALPUR	14362202	CHARI POLIA CHHAK 1	5322DT454	250	MIXED	AMI	Yes	0%	275	0.14651112	0.095835	0.05067612	34.59%
8366	TPCODL	PARADEEP	JED	JAGATSINGPUR	BARANGA (MARKAN	14362	11 KV MANGALPUR	14362202	CHAR PULIYA CHHAK 2	5322DT455	100	MIXED	AMI	Yes	100%	68	0.08083568	0.036673	0.04416268	54.63%
8367	TPCODL	PARADEEP	JED	JAGATSINGPUR	BARANGA (MARKAN	14362	11 KV MANGALPUR	14362202	MATHA KUMABIKAR SAHI	5324DT228	100	MIXED	AMI	Yes	100%	30	0.0089939	0.007728	0.0012659	14.08%
8368	TPCODL	PARADEEP	JED	JAGATSINGPUR	BARANGA (MARKAN	14362	11 KV JANKOTHI	14362203	SALIJANGA	5322DT289	100	MIXED	AMI	Yes	100%	69	0.0309544	0.01822	0.0127344	41.14%
8369	TPCODL	PARADEEP	JED	JAGATSINGPUR	BARANGA (MARKAN	14362	11 KV FDR4	14362204	ARANA 1	5322DT269	100	MIXED	AMI	Yes	100%	65	0.02783368	0.017262	0.01057168	37.98%
8370	TPCODL	PARADEEP	JED	JAGATSINGPUR	BARANGA (MARKAN	14362	11 KV FDR4	14362204	SOVAMULA 2	5322DT290	100	MIXED	AMI	Yes	100%	87	0.0315723	0.021975	0.0095973	30.40%
8371	TPCODL	PARADEEP	JED	JAGATSINGPUR	BARANGA (MARKAN	14362	11 KV FDR4	14362204	BERUHAN 3	5322DT295	100	MIXED	AMI	Yes	100%	107	0.04581372	0.032153	0.01366072	29.82%
8372	TPCODL	PARADEEP	JED	JAGATSINGPUR	BARANGA (MARKAN	14362	11 KV FDR4	14362204	BABA BASDEV	5324DT216	100	MIXED	AMI	Yes	100%	74	0.03908604	0.023408	0.01567804	40.11%
8373	TPCODL	PARADEEP	JED	JAGATSINGPUR	BARANGA (MARKAN	14362	11 KV FDR4	14362204	GOVT UGHS 2	5324DT218	100	MIXED	AMI	Yes	100%	43	0.04821355	0.013005	0.03520855	73.03%
8374	TPCODL	PARADEEP	JED	JAGATSINGPUR	BHATAPADA ODSSP	14360	11 KV DEVIDOLA	14360201	SALAJANGA 2	5321DT020	100	MIXED	AMI	Yes	100%	140	0.06095538	0.045892	0.01506338	24.71%
8375	TPCODL	PARADEEP	JED	JAGATSINGPUR	BHATAPADA ODSSP	14360	11 KV DEVIDOLA	14360201	SAINTO	5321DT021	100	MIXED	AMI	Yes	0%	93	0.02894228	0.024732	0.00421028	14.55%
8376	TPCODL	PARADEEP	JED	JAGATSINGPUR	BHATAPADA ODSSP	14360	11 KV DEVIDOLA	14360201	AGAR 2	5321DT028	100	MIXED	AMI	Yes	100%	92	0.03583744	0.026613	0.00922444	25.74%
8377	TPCODL	PARADEEP	JED	JAGATSINGPUR	BHATAPADA ODSSP	14360	11 KV DEVIDOLA	14360201	CHADHEIGAN HIGH SCHOOL	5321DT031	100	MIXED	AMI	Yes	100%	80	0.0300561	0.022592	0.0074641	24.83%
8378	TPCODL	PARADEEP	JED	JAGATSINGPUR	BHATAPADA ODSSP	14360	11 KV DEVIDOLA	14360201	KORATALA	5321DT037	100	MIXED	AMI	Yes	67%	28	0.01336502	0.006816	0.00654902	49.00%
8379	TPCODL	PARADEEP	JED	JAGATSINGPUR	BHATAPADA ODSSP	14360	11 KV KHAIRA	14360202	KHAIRAHOLI RAY SAHI	5313DT143	100	MIXED	AMI	Yes	0%	28	0.01658782	0.007267	0.00932082	56.19%
8380	TPCODL	PARADEEP	JED	JAGATSINGPUR	BIRIDI	14171	11 KV RANI PADA	14171203	HAJIPUR 16	5331DT069	100	MIXED	AMI	Yes	100%	86	0.04727438	0.03923	0.00804438	17.02%
8381	TPCODL	PARADEEP	JED	JAGATSINGPUR	CHIKINIA (ERANDAP	14363	11 KV REDHUA	14363202	SALIJANGA 10	5323DT349	100	MIXED	AMI	Yes	67%	42	0.01687523	0.010863	0.00601223	35.63%
8382	TPCODL	PARADEEP	JED	JAGATSINGPUR	CHIKINIA (ERANDAP	14363	11 KV REDHUA	14363202	HATAGRAM	5323DT365	100	MIXED	AMI	Yes	100%	40	0.0306571	0.011121	0.0195361	63.72%
8383	TPCODL	PARADEEP	JED	JAGATSINGPUR	CHIKINIA (ERANDAP	14363	11 KV REDHUA	14363202	BANWASAHI	5323DT370	100	MIXED	AMI	Yes	100%	76	0.03581419	0.028278	0.00753619	21.04%
8384	TPCODL	PARADEEP	JED	JAGATSINGPUR	DHIASAHI / JOGDHA	14172	11 KV ODISSO	14172201	KALIABORA	5321DT149	100	MIXED	AMI	Yes	67%	39	0.026835	0.014505	0.01233	45.95%
8385	TPCODL	PARADEEP	JED	JAGATSINGPUR	DHIASAHI / JOGDHA	14172	11 KV ODISSO	14172201	NEAR KALIABORA	5321DT151	250	MIXED	AMI	Yes	67%	174	0.0874754	0.055147	0.0323284	36.96%
8386	TPCODL	PARADEEP	JED	JAGATSINGPUR	DHIASAHI / JOGDHA	14172	11 KV ODISSO	14172201	RASALPUR 1	5321DT155	100	MIXED	AMI	Yes	67%	138	0.07176962	0.054766	0.01700362	23.69%
8387	TPCODL	PARADEEP	JED	JAGATSINGPUR	DHIASAHI / JOGDHA	14172	11 KV ODISSO	14172201	BANIASAHIDIHA	5321DT157	100	MIXED	AMI	Yes	0%	91	0.07045512	0.027798	0.04265712	60.55%
8388	TPCODL	PARADEEP	JED	JAGATSINGPUR	DHIASAHI / JOGDHA	14172	11 KV ODISSO	14172201	BANIASAHIDIHA BATIUPARA	5321DT163	100	MIXED	AMI	Yes	33%	88	0.05921246	0.022843	0.03636946	61.42%
8389	TPCODL	PARADEEP	JED	JAGATSINGPUR	DHIASAHI / JOGDHA	14172	11 KV ODISSO	14172201	KULAHALAR	5321DT171	100	MIXED	AMI	Yes	67%	1	0.00135998	0.001321	3.898E-05	2.87%
8390	TPCODL	PARADEEP	JED	JAGATSINGPUR	DHIASAHI / JOGDHA	14172	11 KV ODISSO	14172201	TOWER 3	5321DT185	100	MIXED	AMI	Yes	33%	119	0.08574832	0.061305	0.02444332	28.51%
8391	TPCODL	PARADEEP	JED	JAGATSINGPUR	DHIASAHI / JOGDHA	14172	11 KV ODISSO	14172201	ANAGARH 1	5321DT191	100	MIXED	AMI	Yes	67%	59	0.02316589	0.016287	0.00687889	29.69%
8392	TPCODL	PARADEEP	JED	JAGATSINGPUR	DHIASAHI / JOGDHA	14172	11 KV ODISSO	14172201	RASALPUR NATHASAHI	5321DT204	100	MIXED	AMI	Yes	67%	128	0.05666392	0.047155	0.00950892	16.78%
8393	TPCODL	PARADEEP	JED	JAGATSINGPUR	DHIASAHI / JOGDHA	14172	11 KV ODISSO	14172201	NUAPATANA 1	5321DT207	100	MIXED	AMI	Yes	33%	75	0.03592072	0.023291	0.01262972	35.16%
8394	TPCODL	PARADEEP	JED	JAGATSINGPUR	DHIASAHI / JOGDHA	14172	11 KV ODISSO	14172201	KAJIPATANA COLLEGE	5321DT215	100	MIXED	AMI	Yes	0%	128	0.06927336	0.044255	0.02501836	36.12%

Sl. No.	Zone Name	Circle name	Division name	Name of the Sub-division	Name of the Sub-station	Substation Code	Name of the 11 kV Feeder	Feeder Code	Name of the Location where DT situated	DT code	DT Capacity (kVA)	Predominant consumer type of DT (Domestic/Industrial/Agriculture/Mixed)	Type of metering AMR/AMI/ Communicable/Conventional metered/Unmetered	Status of Meter- whether Functional (Yes/No)	% of data received automatically (if AMR/AMI)	No. of Connected Consumers	Input Energy (MU) (A)	Billed Energy (MU) (B)	Loss (MU) (A-B)	% DT Loss (A-B)/A
8395	TPCODL	PARADEEP	JED	JAGATSINGPUR	DHIASAHI / JOGDHA	14172	11 KV ODISSO	14172201	RAHURA	5321DT218	100	MIXED	AMI	Yes	0%	115	0.0553924	0.042444	0.0129484	23.38%
8396	TPCODL	PARADEEP	JED	JAGATSINGPUR	DHIASAHI / JOGDHA	14172	11 KV ODISSO	14172201	JOTTA PRUSTY SAHI	5321DT224	100	MIXED	AMI	Yes	67%	126	0.06573948	0.0487	0.01703948	25.92%
8397	TPCODL	PARADEEP	JED	JAGATSINGPUR	DHIASAHI / JOGDHA	14172	11 KV ODISSO	14172201	JOTTA CHACHA	5321DT231	100	MIXED	AMI	Yes	0%	69	0.08247976	0.035198	0.04728176	57.33%
8398	TPCODL	PARADEEP	JED	JAGATSINGPUR	DHIASAHI / JOGDHA	14172	11 KV ODISSO	14172201	ANDHOTI	5321DT239	100	MIXED	AMI	Yes	67%	45	0.02331192	0.016047	0.00726492	31.16%
8399	TPCODL	PARADEEP	JED	JAGATSINGPUR	DHIASAHI / JOGDHA	14172	11 KV DHIASAHI	14172202	ETTAPADA VILLAGE	5321DT053	100	MIXED	AMI	Yes	0%	39	0.01714159	0.014209	0.00293259	17.11%
8400	TPCODL	PARADEEP	JED	JAGATSINGPUR	DHIASAHI / JOGDHA	14172	11 KV DHIASAHI	14172202	BALRAMPUR	5321DT056	100	MIXED	AMI	Yes	100%	170	0.05817946	0.04043707	0.01774239	30.50%
8401	TPCODL	PARADEEP	JED	JAGATSINGPUR	DHIASAHI / JOGDHA	14172	11 KV DHIASAHI	14172202	BALRAMPUR GRAMPANCHAYAT OFFI	5321DT061	100	MIXED	AMI	Yes	100%	122	0.05184098	0.040313	0.01152798	22.24%
8402	TPCODL	PARADEEP	JED	JAGATSINGPUR	DHIASAHI / JOGDHA	14172	11 KV DHIASAHI	14172202	VILLAGE SANTHOL	5321DT073	100	MIXED	AMI	Yes	100%	66	0.02809692	0.020369	0.00772792	27.50%
8403	TPCODL	PARADEEP	JED	JAGATSINGPUR	DHIASAHI / JOGDHA	14172	11 KV DHIASAHI	14172202	BENUPUR	5321DT097	100	MIXED	AMI	Yes	100%	75	0.02580174	0.025009	0.00079274	3.07%
8404	TPCODL	PARADEEP	JED	JAGATSINGPUR	DHIASAHI / JOGDHA	14172	11 KV DHIASAHI	14172202	KANTER 1	5321DT113	100	MIXED	AMI	Yes	0%	93	0.04890352	0.033886	0.01501752	30.71%
8405	TPCODL	PARADEEP	JED	JAGATSINGPUR	DHIASAHI / JOGDHA	14172	11 KV DHIASAHI	14172202	RAMA MANDIR	5321DT119	100	MIXED	AMI	Yes	100%	48	0.02583022	0.016334	0.00949622	36.76%
8406	TPCODL	PARADEEP	JED	JAGATSINGPUR	DHIASAHI / JOGDHA	14172	11 KV DHIASAHI	14172202	RAIBARI	5321DT133	100	MIXED	AMI	Yes	100%	125	0.05693468	0.046113	0.01082168	19.01%
8407	TPCODL	PARADEEP	JED	JAGATSINGPUR	DHIASAHI / JOGDHA	14172	11 KV DHIASAHI	14172202	PALLI PANCHAYAT OFFICE 1	5321DT139	100	MIXED	AMI	Yes	100%	24	0.0184543	0.005042	0.0134123	72.68%
8408	TPCODL	PARADEEP	JED	JAGATSINGPUR	GARDAPUR	14168	11 KV GARADAPUR-I	14168201	KESORADA 2	5432DT206	100	MIXED	AMI	Yes	67%	42	0.0234637	0.010863	0.0126007	53.70%
8409	TPCODL	PARADEEP	JED	JAGATSINGPUR	JAGATSINGHPUR	14169	11 KV CHHAPADA	14169201	HALDIPADIA	5322DT216	100	MIXED	AMI	Yes	100%	30	0.03948776	0.023147	0.01634076	41.38%
8410	TPCODL	PARADEEP	JED	JAGATSINGPUR	JAGATSINGHPUR	14169	11 KV CHHAPADA	14169201	PATENIGAON	5323DT011	100	MIXED	AMI	Yes	100%	96	0.05007898	0.037605	0.01247398	24.91%
8411	TPCODL	PARADEEP	JED	JAGATSINGPUR	JAGATSINGHPUR	14169	11 KV CHHAPADA	14169201	KOLARIA MAJURAI	5323DT024	100	MIXED	AMI	Yes	100%	72	0.0432868	0.025623	0.0176638	40.81%
8412	TPCODL	PARADEEP	JED	JAGATSINGPUR	JAGATSINGHPUR	14169	11 KV CHHAPADA	14169201	JIRA	5323DT034	100	MIXED	AMI	Yes	100%	92	0.03647924	0.027181	0.00929824	25.49%
8413	TPCODL	PARADEEP	JED	JAGATSINGPUR	JAGATSINGHPUR	14169	11 KV CHHAPADA	14169201	DINGESWAR 7	5323DT037	100	MIXED	AMI	Yes	100%	22	0.01523751	0.006555	0.00868251	56.98%
8414	TPCODL	PARADEEP	JED	JAGATSINGPUR	JAGATSINGHPUR	14169	11 KV CHHAPADA	14169201	PALASALA	5323DT043	100	MIXED	AMI	Yes	100%	101	0.04878318	0.031959	0.01682418	34.49%
8415	TPCODL	PARADEEP	JED	JAGATSINGPUR	JAGATSINGHPUR	14169	11 KV CHHAPADA	14169201	RATHANGE	5323DT062	100	MIXED	AMI	Yes	100%	96	0.03559176	0.024712	0.01087976	30.57%
8416	TPCODL	PARADEEP	JED	JAGATSINGPUR	JAGATSINGHPUR	14169	11 KV CHHAPADA	14169201	ICHHAPUR	5323DT063	100	MIXED	AMI	Yes	100%	71	0.0317661	0.023678	0.0080881	25.46%
8417	TPCODL	PARADEEP	JED	JAGATSINGPUR	JAGATSINGHPUR	14169	11 KV CHHAPADA	14169201	RADHANGA 6(ROUT SAHI)	5323DT071	100	MIXED	AMI	Yes	100%	114	0.04726534	0.034731	0.01253434	26.52%
8418	TPCODL	PARADEEP	JED	JAGATSINGPUR	JAGATSINGHPUR	14169	11 KV CHHAPADA	14169201	BRAHMANKHANDA	5323DT078	100	MIXED	AMI	Yes	100%	51	0.02350576	0.017181	0.00632476	26.91%
8419	TPCODL	PARADEEP	JED	JAGATSINGPUR	JAGATSINGHPUR	14169	11 KV CHHAPADA	14169201	KHAJURIA	5323DT085	100	MIXED	AMI	Yes	100%	89	0.05567602	0.043293	0.01238302	22.24%
8420	TPCODL	PARADEEP	JED	JAGATSINGPUR	JAGATSINGHPUR	14169	11 KV CHHAPADA	14169201	KUMBHARTOTA	5323DT086	100	MIXED	AMI	Yes	100%	99	0.02924866	0.023105	0.00614366	21.00%
8421	TPCODL	PARADEEP	JED	JAGATSINGPUR	JAGATSINGHPUR	14169	11 KV CHHAPADA	14169201	SAMANGA JENASAHI	5323DT089	100	MIXED	AMI	Yes	100%	37	0.02640874	0.015447	0.01096174	41.51%
8422	TPCODL	PARADEEP	JED	JAGATSINGPUR	JAGATSINGHPUR	14169	11 KV CHHAPADA	14169201	KHERASHPATNA 1	5323DT092	100	MIXED	AMI	Yes	0%	103	0.05259196	0.046727	0.00586496	11.15%
8423	TPCODL	PARADEEP	JED	JAGATSINGPUR	JAGATSINGHPUR	14169	11 KV CHHAPADA	14169201	CHANDURA 1	5323DT094	100	MIXED	AMI	Yes	100%	89	0.0569528	0.044146	0.0128068	22.49%
8424	TPCODL	PARADEEP	JED	JAGATSINGPUR	JAGATSINGHPUR	14169	11 KV CHHAPADA	14169201	TARADAPADA 4	5323DT102	100	MIXED	AMI	Yes	100%	126	0.08442572	0.075457	0.00896872	10.62%
8425	TPCODL	PARADEEP	JED	JAGATSINGPUR	JAGATSINGHPUR	14169	11 KV CHHAPADA	14169201	MAJURAI	5323DT107	100	MIXED	AMI	Yes	100%	145	0.06961108	0.052945	0.01666608	23.94%
8426	TPCODL	PARADEEP	JED	JAGATSINGPUR	JAGATSINGHPUR	14169	11 KV CHHAPADA	14169201	NIMAPUR	5323DT139	100	MIXED	AMI	Yes	100%	69	0.04026748	0.022995	0.01727248	42.89%
8427	TPCODL	PARADEEP	JED	JAGATSINGPUR	JAGATSINGHPUR	14169	11 KV ALIPINGALA	14169202	PATEL 4	5321DT004	100	MIXED	AMI	Yes	100%	26	0.0137608	0.007885	0.0058758	42.70%
8428	TPCODL	PARADEEP	JED	JAGATSINGPUR	JAGATSINGHPUR	14169	11 KV ALIPINGALA	14169202	HAWDIPAKA CHHAKA	5322DT224	100	MIXED	AMI	Yes	100%	112	0.0879525	0.055312	0.0326405	37.11%
8429	TPCODL	PARADEEP	JED	JAGATSINGPUR	JAGATSINGHPUR	14169	11 KV ALIPINGALA	14169202	JAYAGADA	5322DT225	250	MIXED	AMI	Yes	100%	259	0.155103	0.139302	0.015801	10.19%
8430	TPCODL	PARADEEP	JED	JAGATSINGPUR	JAGATSINGHPUR	14169	11 KV ALIPINGALA	14169202	PANISALIA-1	5322DT229	100	MIXED	AMI	Yes	100%	122	0.09690908	0.089866	0.00704308	7.27%
8431	TPCODL	PARADEEP	JED	JAGATSINGPUR	JAGATSINGHPUR	14169	11 KV ALIPINGALA	14169202	BANIATOTA	5322DT233	100	MIXED	AMI	Yes	100%	90	0.08664618	0.059398	0.02724818	31.45%
8432	TPCODL	PARADEEP	JED	JAGATSINGPUR	JAGATSINGHPUR	14169	11 KV ALIPINGALA	14169202	CHATRA-2	5322DT238	100	MIXED	AMI	Yes	100%	58	0.08196642	0.036154	0.04581242	55.89%
8433	TPCODL	PARADEEP	JED	JAGATSINGPUR	JAGATSINGHPUR	14169	11 KV ALIPINGALA	14169202	CHATTRA BHAI SAHI	5322DT241	100	MIXED	AMI	Yes	100%	63	0.04069434	0.023015	0.01767934	43.44%
8434	TPCODL	PARADEEP	JED	JAGATSINGPUR	JAGATSINGHPUR	14169	11 KV ALIPINGALA	14169202	SATSANGA VIHAR CHATTRA	5322DT243	100	MIXED	AMI	Yes	100%	14	0.01851932	0.010261	0.00825832	44.59%
8435	TPCODL	PARADEEP	JED	JAGATSINGPUR	JAGATSINGHPUR	14169	11 KV ALIPINGALA	14169202	MANDI 1	5322DT246	100	MIXED	AMI	Yes	100%	15	0.01625288	0.004453	0.01179988	72.60%
8436	TPCODL	PARADEEP	JED	JAGATSINGPUR	JAGATSINGHPUR	14169	11 KV ALIPINGALA	14169202	ALANGANATHA HATA	5322DT255	100	MIXED	AMI	Yes	100%	55	0.03265382	0.024895	0.00775882	23.76%
8437	TPCODL	PARADEEP	JED	JAGATSINGPUR	JAGATSINGHPUR	14169	11 KV ALIPINGALA	14169202	BISWALA SAHI-2	5322DT258	100	MIXED	AMI	Yes	100%	22	0.02653102	0.007004	0.01952702	73.60%
8438	TPCODL	PARADEEP	JED	JAGATSINGPUR	JAGATSINGHPUR	14169	11 KV ALIPINGALA	14169202	GALUPADA	5322DT300	100	MIXED	AMI	Yes	100%	157	0.08796642	0.072717	0.01524942	17.34%
8439	TPCODL	PARADEEP	JED	JAGATSINGPUR	JAGATSINGHPUR	14169	11 KV ALIPINGALA	14169202	JASWANTPUR BEJA	5322DT311	100	MIXED	AMI	Yes	100%	62	0.07964958	0.019267	0.06038258	75.81%
8440	TPCODL	PARADEEP	JED	JAGATSINGPUR	JAGATSINGHPUR	14169	11 KV ALIPINGALA	14169202	JHINKARA DIHA	5322DT312	100	MIXED	AMI	Yes	100%	87	0.05227472	0.031839	0.02043572	39.09%
8441	TPCODL	PARADEEP	JED	JAGATSINGPUR	JAGATSINGHPUR	14169	11 KV ALIPINGALA	14169202	AUGRATARA TEMPLE DEVOGA	5322DT324	100	MIXED	AMI	Yes	100%	96	0.05157008	0.03424	0.01733008	33.60%
8442	TPCODL	PARADEEP	JED	JAGATSINGPUR	JAGATSINGHPUR	14169	11 KV ALIPINGALA	14169202	ATAMALA	5322DT329	100	MIXED	AMI	Yes	100%	178	0.10882136	0.054075	0.05474636	50.31%
8443	TPCODL	PARADEEP	JED	JAGATSINGPUR	JAGATSINGHPUR	14169	11 KV TOWN	14169203	FISH MARKET-2	5322DT114	100	MIXED	AMI	Yes	100%	9	0.0769367	0.015889	0.0610477	79.35%
8444	TPCODL	PARADEEP	JED	JAGATSINGPUR	JAGATSINGHPUR	14169	11 KV TOWN	14169203	FCC HOSPITAL 1	5322DT115	250	MIXED	AMI	Yes	100%	83	0.16012936	0.06597	0.09415936	58.80%
8445	TPCODL	PARADEEP	JED	JAGATSINGPUR	JAGATSINGHPUR	14169	11 KV TOWN	14169203	FCC HOSPITAL 2	5322DT116	250	MIXED	AMI	Yes	0%	125	0.19747662	0.097994	0.09948262	50.38%
8446	TPCODL	PARADEEP	JED	JAGATSINGPUR	JAGATSINGHPUR	14169	11 KV TOWN	14169203	XAVIER	5322DT118	100	MIXED	AMI	Yes	100%	23	0.03871076	0.033992	0.00471876	12.19%
8447	TPCODL	PARADEEP	JED	JAGATSINGPUR	JAGATSINGHPUR	14169	11 KV TOWN	14169203	BARHA SAHI	5322DT119	250	MIXED	AMI	Yes	0%	253	0.18170608	0.130304	0.05140208	28.29%
8448	TPCODL	PARADEEP	JED	JAGATSINGPUR	JAGATSINGHPUR	14169	11 KV TOWN	14169203	SIPI BEHARA SAHI	5322DT122	100	MIXED	AMI	Yes	0%	49	0.09117098	0.018771	0.07239998	79.41%
8449	TPCODL	PARADEEP	JED	JAGATSINGPUR	JAGATSINGHPUR	14169	11 KV TOWN	14169203	CP CHHAK	5322DT133	500	MIXED	AMI	Yes	100%	281	0.29432976	0.153544	0.14078576	47.83%
8450	TPCODL	PARADEEP	JED	JAGATSINGPUR	JAGATSINGHPUR	14169	11 KV TOWN	14169203	JOGDHARI NEW BUS STAND-2	5322DT135	100	MIXED	AMI	Yes	100%	49	0.03120908	0.018605	0.01260408	40.39%
8451	TPCODL	PARADEEP	JED	JAGATSINGPUR	JAGATSINGHPUR	14169	11 KV TOWN	14169203	MADHARAHAT-1	5322DT161	100	MIXED	AMI	Yes	0%	84	0.06442056	0.027031	0.03738956	58.04%
8452	TPCODL	PARADEEP	JED	JAGATSINGPUR	JAGATSINGHPUR	14169	11 KV TOWN	14169203	CHAR CHIKA BAZAR	5322DT170	250	MIXED	AMI	Yes	100%	234	0.19956096	0.149497	0.05006396	25.09%
8453	TPCODL	PARADEEP	JED	JAGATSINGPUR	JAGATSINGHPUR	14169	11 KV TOWN	14169203	KHERASA	5322DT173	100	MIXED	AMI	Yes	100%	28	0.03494228	0.015083	0.01985928	56.83%
8454	TPCODL	PARADEEP	JED	JAGATSINGPUR	JAGATSINGHPUR	14169	11 KV TOWN	14169203	BELAPOKHARI NEAR KENAL-2	5322DT175	100	MIXED	AMI	Yes	0%	82	0.07059978	0.030527	0.04007278	56.76%
8455	TPCODL	PARADEEP	JED	JAGATSINGPUR	JAGATSINGHPUR	14169	11 KV TOWN	14169203	PURAHITAPUR-2	5322DT176	100	MIXED	AMI	Yes	100%	98	0.05318308	0.047128	0.00605508	11.39%
8456	TPCODL	PARADEEP	JED	JAGATSINGPUR	JAGATSINGHPUR	14169	11 KV TOWN	14169203	BELAPOKHARI	5322DT178	100	MIXED	AMI	Yes	100%	29	0.02920742	0.014789	0.01441842	49.37%
8457	TPCODL	PARADEEP	JED	JAGATSINGPUR	JAGATSINGHPUR	14169	11 KV TOWN	14169203	SCHOOL9	5322DT179	100	MIXED	AMI	Yes	0%	46	0.06949534	0.023274	0.04622134	66.51%
8458	TPCODL	PARADEEP	JED	JAGATSINGPUR	JAGATSINGHPUR	14169	11 KV TOWN	14169203	NANDAMANI	5322DT182	250	MIXED	AMI	Yes	100%	201	0.12093066	0.097772	0.02315866	19.15%
8459	TPCODL	PARADEEP	JED	JAGATSINGPUR	JAGATSINGHPUR	14169	11 KV PUNAGNA	14169204	OLD SBI	5322DT014	100	MIXED	AMI	Yes	67%	50	0.05631165	0.03032	0.02599165	46.16%
8460	TPCODL	PARADEEP	JED	JAGATSINGPUR	JAGATSINGHPUR	14169	11 KV PUNAGNA	14169204	RASMI DENGA-1	5322DT019	100	MIXED	AMI	Yes	67%	83	0.0756636	0.066095	0.0095686	12.65%
8461	TPCODL	PARADEEP	JED	JAGATSINGPUR	JAGATSINGHPUR	14169	11 KV PUNAGNA	14169204	BANIA SAHI	5322DT024	100	MIXED	AMI	Yes	100%	54	0.03541212	0.028242	0.00717012	20.25%
8462	TPCODL	PARADEEP	JED	JAGATSINGPUR	JAGATSINGHPUR	14169	11 KV PUNAGNA	14169204	JAYBADA NEW COLONY	5322DT026	100	MIXED	AMI	Yes	100%	173	0.0923919	0.086035	0.0063569	6.88%
8463	TPCODL	PARADEEP	JED	JAGATSINGPUR	JAGATSINGHPUR	14169	11 KV PUNAGNA	14169204	COURT CHACK	5322DT028	500	MIXED	AMI	Yes	100%	167	0.25819872	0.091231	0.16696772	64.67%
8464	TPCODL	PARADEEP	JED	JAGATSINGPUR	JAGATSINGHPUR	14169	11 KV PUNAGNA	14169204	OHAL NEW	5322DT030	100	MIXED	AMI	Yes	100%	72	0.06970898	0.047118	0.02259098	32.41%
8465	TPCODL	PARADEEP	JED	JAGATSINGPUR	JAGATSINGHPUR	14169	11 KV PUNAGNA	14169204	JENA CLINIC	5322DT035	250	MIXED	AMI	Yes	100%	104	0.10495288	0.068797	0.03615588	34.45%
8466	TPCODL	PARADEEP	JED	JAGATSINGPUR	JAGATSINGHPUR	14169	11 KV PUNAGNA	14169204	NEAR TOWER 3	5322DT042	100	MIXED	AMI	Yes	100%	126	0.09634392	0.067158	0.02918592	30.29%
8467	TPCODL	PARADEEP	JED	JAGATSINGPUR	JAGATSINGHPUR	14169	11 KV PUNAGNA	14169204	MALISAHI GADA-3	5322DT046	100	MIXED	AMI	Yes	100%	17	0.02807543	0.009511	0.01856443	66.12%

Sl. No.	Zone Name	Circle name	Division name	Name of the Sub-division	Name of the Sub-station	Substation Code	Name of the 11 kV Feeder	Feeder Code	Name of the Location where DT situated	DT code	DT Capacity (kVA)	Predominant consumer type of DT (Domestic/Industrial/Agriculture/Mixed)	Type of metering AMR/AMI/ Communicable/Conventional metered/Unmetered	Status of Meter- whether Functional (Yes/No)	% of data received automatically (if AMR/AMI)	No. of Connected Consumers	Input Energy (MU) (A)	Billed Energy (MU) (B)	Loss (MU) (A-B)	% DT Loss (A-B)/A
8468	TPCODL	PARADEEP	JED	JAGATSINGPUR	JAGATSINGHPUR	14169	11 KV PUNAGNA	14169204	MALISAHI GADA-1	5322DT048	100	MIXED	AMI	Yes	100%	27	0.06599168	0.013925	0.05206668	78.90%
8469	TPCODL	PARADEEP	JED	JAGATSINGPUR	JAGATSINGHPUR	14169	11 KV PUNAGNA	14169204	GANESH TEMPLE	5322DT051	100	MIXED	AMI	Yes	100%	55	0.0402892	0.037051	0.0032382	8.04%
8470	TPCODL	PARADEEP	JED	JAGATSINGPUR	JAGATSINGHPUR	14169	11 KV PUNAGNA	14169204	NEAR UPASASMAL HOUSE	5322DT052	100	MIXED	AMI	Yes	100%	136	0.0853133	0.083964	0.0013493	1.58%
8471	TPCODL	PARADEEP	JED	JAGATSINGPUR	JAGATSINGHPUR	14169	11 KV PUNAGNA	14169204	GIRLS HOSTAL 1	5322DT057	100	MIXED	AMI	Yes	0%	6	0.00680218	0.0065	0.00030218	4.44%
8472	TPCODL	PARADEEP	JED	JAGATSINGPUR	JAGATSINGHPUR	14169	11 KV PUNAGNA	14169204	FISHNY OFFICE	5322DT058	100	MIXED	AMI	Yes	100%	86	0.05492398	0.033647	0.02127698	38.74%
8473	TPCODL	PARADEEP	JED	JAGATSINGPUR	JAGATSINGHPUR	14169	11 KV PUNAGNA	14169204	KATAPADA BHOI SAHI	5322DT062	100	MIXED	AMI	Yes	0%	36	0.03766928	0.014784	0.02288528	60.75%
8474	TPCODL	PARADEEP	JED	JAGATSINGPUR	JAGATSINGHPUR	14169	11 KV PUNAGNA	14169204	DURGA ETA-1	5322DT063	100	MIXED	AMI	Yes	67%	39	0.01882856	0.01691	0.00191856	10.19%
8475	TPCODL	PARADEEP	JED	JAGATSINGPUR	JAGATSINGHPUR	14169	11 KV PUNAGNA	14169204	COLLAGE CHOUCK	5322DT069	250	MIXED	AMI	Yes	67%	135	0.15660915	0.122637	0.03397215	21.69%
8476	TPCODL	PARADEEP	JED	JAGATSINGPUR	JAGATSINGHPUR	14169	11 KV PUNAGNA	14169204	GOPADSAGAR	5322DT071	500	MIXED	AMI	Yes	100%	167	0.20718752	0.092095	0.11509252	55.55%
8477	TPCODL	PARADEEP	JED	JAGATSINGPUR	JAGATSINGHPUR	14169	11 KV PUNAGNA	14169204	MARICHAPADA	5323DT002	100	MIXED	AMI	Yes	0%	71	0.07320728	0.042472	0.03073528	41.98%
8478	TPCODL	PARADEEP	JED	JAGATSINGPUR	KANAKPUR ODSSP	14341	11 KV KANAKPUR-2(KAN	14341201	KATARA 1	5433DT267	100	MIXED	AMI	Yes	67%	76	0.0625584	0.047495	0.0150634	24.08%
8479	TPCODL	PARADEEP	JED	JAGATSINGPUR	NUAPADA	14195	11 KV PITEIPUR	14195201	GOBINDA POKHARI 2	5323DT149	100	MIXED	AMI	Yes	100%	48	0.02042234	0.014103	0.00631934	30.94%
8480	TPCODL	PARADEEP	JED	JAGATSINGPUR	NUAPADA	14195	11 KV PITEIPUR	14195201	MADHUA	5323DT162	100	MIXED	AMI	Yes	100%	99	0.05839361	0.036092	0.02230161	38.19%
8481	TPCODL	PARADEEP	JED	JAGATSINGPUR	NUAPADA	14195	11 KV PITEIPUR	14195201	BANAMALI PUR 1	5323DT166	100	MIXED	AMI	Yes	100%	103	0.07627575	0.049036	0.02723975	35.71%
8482	TPCODL	PARADEEP	JED	JAGATSINGPUR	NUAPADA	14195	11 KV PITEIPUR	14195201	BANAMALI PUR 2	5323DT169	250	MIXED	AMI	Yes	100%	147	0.0748061	0.053782	0.0210241	28.10%
8483	TPCODL	PARADEEP	JED	JAGATSINGPUR	NUAPADA	14195	11 KV PITEIPUR	14195201	MOHIUDDINPUR	5323DT171	250	MIXED	AMI	Yes	100%	151	0.12844424	0.101186	0.02725824	21.22%
8484	TPCODL	PARADEEP	JED	JAGATSINGPUR	NUAPADA	14195	11 KV PITEIPUR	14195201	PITEIPUR KOKILPUR 2	5323DT181	100	MIXED	AMI	Yes	100%	16	0.02384632	0.010637	0.01320932	55.39%
8485	TPCODL	PARADEEP	JED	JAGATSINGPUR	NUAPADA	14195	11 KV PITEIPUR	14195201	DENGA 1	5323DT189	100	MIXED	AMI	Yes	100%	156	0.07336614	0.062393	0.01097314	14.96%
8486	TPCODL	PARADEEP	JED	JAGATSINGPUR	NUAPADA	14195	11 KV NALIBAR	14195202	NALIBAR 3	5323DT247	100	MIXED	AMI	Yes	100%	132	0.0671794	0.050442	0.0167374	24.91%
8487	TPCODL	PARADEEP	JED	JAGATSINGPUR	NUAPADA	14195	11 KV NALIBAR	14195202	NUAPADA	5323DT257	100	MIXED	AMI	Yes	100%	68	0.03123976	0.02444	0.00679976	21.77%
8488	TPCODL	PARADEEP	JED	JAGATSINGPUR	NUAPADA	14195	11 KV NALIBAR	14195202	BRAHMAN BADI 6	5323DT393	100	MIXED	AMI	Yes	67%	55	0.04814229	0.019857	0.02828529	58.75%
8489	TPCODL	PARADEEP	JED	JAGATSINGPUR	NUAPADA	14195	11 KV NALIBAR	14195202	GAMHAPUR 4	5323DT427	100	MIXED	AMI	Yes	100%	104	0.03725806	0.036137	0.00112106	3.01%
8490	TPCODL	PARADEEP	JED	JAGATSINGPUR	NUAPADA	14195	11 KV ICHHAPUR	14195203	BARATIRA 2	5323DT268	100	MIXED	AMI	Yes	67%	118	0.04521006	0.038904	0.00630606	13.95%
8491	TPCODL	PARADEEP	JED	JAGATSINGPUR	NUAPADA	14195	11 KV ICHHAPUR	14195203	BADA KORKAR 8	5323DT295	100	MIXED	AMI	Yes	33%	92	0.03305312	0.026563	0.00649012	19.64%
8492	TPCODL	PARADEEP	JED	JAGATSINGPUR	NUAPADA	14195	11 KV ICHHAPUR	14195203	GUALIPUR 1	5323DT296	100	MIXED	AMI	Yes	33%	160	0.07626008	0.04256262	0.03369746	44.19%
8493	TPCODL	PARADEEP	JED	JAGATSINGPUR	NUAPADA	14195	11 KV ICHHAPUR	14195203	NUAPALAI 1	5323DT335	100	MIXED	AMI	Yes	67%	61	0.03160664	0.012385	0.01922164	60.82%
8494	TPCODL	PARADEEP	JED	JAGATSINGPUR	NUAPOLA / NABAPA	14181	11 KV TARIKUNDA	14181201	SEKHPATANA	5324DT151	100	MIXED	AMI	Yes	100%	85	0.05042709	0.036151	0.01427609	28.31%
8495	TPCODL	PARADEEP	JED	JAGATSINGPUR	NUAPOLA / NABAPA	14181	11 KV TARIKUNDA	14181201	JUALIA SCHOOL	5324DT154	100	MIXED	AMI	Yes	100%	149	0.08541868	0.058125	0.02729368	31.95%
8496	TPCODL	PARADEEP	JED	JAGATSINGPUR	NUAPOLA / NABAPA	14181	11 KV TARIKUNDA	14181201	NUADA	5324DT162	100	MIXED	AMI	Yes	100%	72	0.05304775	0.035483	0.01756475	33.11%
8497	TPCODL	PARADEEP	JED	JAGATSINGPUR	NUAPOLA / NABAPA	14181	11 KV TARIKUNDA	14181201	PANAPADIA	5324DT166	100	MIXED	AMI	Yes	67%	231	0.10294976	0.089675	0.01327476	12.89%
8498	TPCODL	PARADEEP	JED	JAGATSINGPUR	NUAPOLA / NABAPA	14181	11 KV TARIKUNDA	14181201	BARAGOLA	5324DT181	100	MIXED	AMI	Yes	0%	64	0.05050961	0.023784	0.02672561	52.91%
8499	TPCODL	PARADEEP	JED	JAGATSINGPUR	NUAPOLA / NABAPA	14181	11 KV TARIKUNDA	14181201	TARIKUND BAZAR 200	5324DT191	200	MIXED	AMI	Yes	100%	137	0.12132512	0.051814	0.06951112	57.29%
8500	TPCODL	PARADEEP	JED	JAGATSINGPUR	NUAPOLA / NABAPA	14181	11 KV TARIKUNDA	14181201	DHANIPUR 1	5324DT194	100	MIXED	AMI	Yes	0%	163	0.09829264	0.081935	0.01635764	16.64%
8501	TPCODL	PARADEEP	JED	JAGATSINGPUR	NUAPOLA / NABAPA	14181	11 KV TARIKUNDA	14181201	NABAPATANA 1	5324DT203	100	MIXED	AMI	Yes	100%	140	0.06706387	0.04895	0.01811387	27.01%
8502	TPCODL	PARADEEP	JED	JAGATSINGPUR	NUAPOLA / NABAPA	14181	11 KV TARIKUNDA	14181201	GOTHINA 1	5331DT366	63	MIXED	AMI	Yes	33%	98	0.06485466	0.028839	0.03601566	55.53%
8503	TPCODL	PARADEEP	JED	JAGATSINGPUR	NUAPOLA / NABAPA	14181	11 KV MANDASAHI	14181202	JARILOGADA	5324DT017	100	MIXED	AMI	Yes	100%	34	0.01163954	0.009719	0.00192054	16.50%
8504	TPCODL	PARADEEP	JED	JAGATSINGPUR	NUAPOLA / NABAPA	14181	11 KV MANDASAHI	14181202	MSPUR SASAN-1	5324DT019	100	MIXED	AMI	Yes	100%	95	0.06263876	0.040419	0.02221976	35.47%
8505	TPCODL	PARADEEP	JED	JAGATSINGPUR	NUAPOLA / NABAPA	14181	11 KV MANDASAHI	14181202	MAKUNDABARA	5324DT032	100	MIXED	AMI	Yes	100%	131	0.06326228	0.041358	0.02190428	34.62%
8506	TPCODL	PARADEEP	JED	JAGATSINGPUR	NUAPOLA / NABAPA	14181	11 KV MANDASAHI	14181202	TATALAPURGADA	5324DT036	100	MIXED	AMI	Yes	0%	66	0.03690076	0.029552	0.00734876	19.91%
8507	TPCODL	PARADEEP	JED	JAGATSINGPUR	NUAPOLA / NABAPA	14181	11 KV MANDASAHI	14181202	MADHUSUDANPUR 1	5324DT038	100	MIXED	AMI	Yes	100%	59	0.04518432	0.017562	0.02762232	61.13%
8508	TPCODL	PARADEEP	JED	JAGATSINGPUR	NUAPOLA / NABAPA	14181	11 KV MANDASAHI	14181202	MELAKSAHI	5324DT042	100	MIXED	AMI	Yes	67%	56	0.03965106	0.018272	0.02137906	53.92%
8509	TPCODL	PARADEEP	JED	JAGATSINGPUR	NUAPOLA / NABAPA	14181	11 KV MANDASAHI	14181202	JAHANPUR OLD 1	5324DT059	100	MIXED	AMI	Yes	100%	144	0.0583019	0.043266	0.0150359	25.79%
8510	TPCODL	PARADEEP	JED	JAGATSINGPUR	NUAPOLA / NABAPA	14181	11 KV MANDASAHI	14181202	UTARANDA OLD	5324DT063	100	MIXED	AMI	Yes	100%	76	0.03674729	0.023774	0.01297329	35.30%
8511	TPCODL	PARADEEP	JED	JAGATSINGPUR	NUAPOLA / NABAPA	14181	11 KV MANDASAHI	14181202	KULAMUNDILO 1	5324DT065	100	MIXED	AMI	Yes	100%	102	0.04455694	0.03439	0.01016694	22.82%
8512	TPCODL	PARADEEP	JED	JAGATSINGPUR	NUAPOLA / NABAPA	14181	11 KV MANDASAHI	14181202	MANDASAHI 1	5324DT079	100	MIXED	AMI	Yes	100%	69	0.06788986	0.026718	0.04117186	60.65%
8513	TPCODL	PARADEEP	JED	JAGATSINGPUR	NUAPOLA / NABAPA	14181	11 KV MANDASAHI	14181202	VOKANJI GUDIYA SAHI	5324DT091	100	MIXED	AMI	Yes	100%	15	0.02827222	0.005867	0.02240522	79.25%
8514	TPCODL	PARADEEP	JED	JAGATSINGPUR	NUAPOLA / NABAPA	14181	11 KV MANDASAHI	14181202	KANTILO SCHOOL	5324DT125	100	MIXED	AMI	Yes	67%	166	0.0649355	0.04531	0.0196255	30.22%
8515	TPCODL	PARADEEP	JED	JAGATSINGPUR	SASANPADA	14218	11 KV SITHAL	14218201	NILAMDHABA	5322DT186	250	MIXED	AMI	Yes	100%	87	0.04047368	0.02687	0.01360368	33.61%
8516	TPCODL	PARADEEP	JED	JAGATSINGPUR	SASANPADA	14218	11 KV SITHAL	14218201	RWSS AMARPADA	5322DT189	100	MIXED	AMI	Yes	0%	22	0.01952128	0.00546	0.01406128	72.03%
8517	TPCODL	PARADEEP	JED	JAGATSINGPUR	SASANPADA	14218	11 KV ALIPINGAL	14218202	KOLARA	5322DT356	100	MIXED	AMI	Yes	100%	100	0.03693916	0.023739	0.01320016	35.73%
8518	TPCODL	PARADEEP	JED	JAGATSINGPUR	SASANPADA	14218	11 KV ALIPINGAL	14218202	NAIK SAHI	5322DT362	63	MIXED	AMI	Yes	100%	16	0.01134138	0.007501	0.00384038	33.86%
8519	TPCODL	PARADEEP	JED	JAGATSINGPUR	SASANPADA	14218	11 KV ALIPINGAL	14218202	BHOI SAHI	5322DT363	63	MIXED	AMI	Yes	100%	58	0.01781902	0.017662	0.00015702	0.88%
8520	TPCODL	PARADEEP	JED	JAGATSINGPUR	SASANPADA	14218	11 KV ALIPINGAL	14218202	ADHANGA	5322DT365	63	MIXED	AMI	Yes	100%	65	0.0343662	0.015705	0.0186612	54.30%
8521	TPCODL	PARADEEP	JED	JAGATSINGPUR	SASANPADA	14218	11 KV ALIPINGAL	14218202	NEAR BY PATASARA 2	5322DT374	100	MIXED	AMI	Yes	33%	123	0.09545244	0.047286	0.04816644	50.46%
8522	TPCODL	PARADEEP	JED	JAGATSINGPUR	SASANPADA	14218	11 KV ALIPINGAL	14218202	NEAR BY PATASARA GRAM PANCHAY	5322DT380	100	MIXED	AMI	Yes	100%	9	0.00071076	0.00067	4.076E-05	5.73%
8523	TPCODL	PARADEEP	JED	JAGATSINGPUR	SASANPADA	14218	11 KV ALIPINGAL	14218202	AKASUDHA 1	5322DT382	250	MIXED	AMI	Yes	100%	171	0.12130244	0.049225	0.07207744	59.42%
8524	TPCODL	PARADEEP	JED	JAGATSINGPUR	SASANPADA	14218	11 KV ALIPINGAL	14218202	BAZAR	5322DT389	250	MIXED	AMI	Yes	100%	54	0.08885088	0.023355	0.06549588	73.71%
8525	TPCODL	PARADEEP	JED	JAGATSINGPUR	SASANPADA	14218	11 KV ALIPINGAL	14218202	JAHUSAHI	5322DT392	63	MIXED	AMI	Yes	100%	58	0.02910444	0.026104	0.00300044	10.31%
8526	TPCODL	PARADEEP	JED	JAGATSINGPUR	SASANPADA	14218	11 KV ALIPINGAL	14218202	RAYANK PATANA	5322DT397	100	MIXED	AMI	Yes	100%	106	0.03603212	0.028565	0.00746712	20.72%
8527	TPCODL	PARADEEP	JED	JAGATSINGPUR	SASANPADA	14218	11 KV ALIPINGAL	14218202	KHAMANGA 1	5322DT398	100	MIXED	AMI	Yes	100%	72	0.02363666	0.017907	0.00572966	24.24%
8528	TPCODL	PARADEEP	JED	RAGHUNATHPU	BALIA (ADHANGA) (	14359	11 kV ADHANGA (BALIA	14359202	NEAR BY PATRA HOUSE	5331DT320	250	MIXED	AMI	Yes	0%	224	0.08778566	0.075414	0.01237166	14.09%
8529	TPCODL	PARADEEP	JED	RAGHUNATHPU	RAGHUNATHPUR	14170	11 kV KUNTAHAR	14170202	PAIKARABATI4	5332DT232	100	MIXED	AMI	Yes	0%	120	0.0471168	0.038994	0.0081228	17.24%
8530	TPCODL	PARADEEP	JED	RAGHUNATHPU	RAGHUNATHPUR	14170	11KV PRAHARAJPUR FEE	14170205	JAGANNATHPUR-2	5332DT289	100	MIXED	AMI	Yes	100%	149	0.06962494	0.056659	0.01296594	18.62%
8531	TPCODL	PARADEEP	JED	RAGHUNATHPU	RAGHUNATHPUR	14170	11KV PRAHARAJPUR FEE	14170205	PATENA2	5332DT301	100	MIXED	AMI	Yes	100%	106	0.0299164	0.027202	0.0027144	9.07%
8532	TPCODL	PARADEEP	JED	RAGHUNATHPU	RAGHUNATHPUR	14170	11KV PRAHARAJPUR FEE	14170205	SADHU SAHI2	5332DT309	100	MIXED	AMI	Yes	100%	201	0.06372636	0.0556	0.00812636	12.75%
8533	TPCODL	PARADEEP	JED	RAGHUNATHPU	22MAUJA	14193	11 KV BAGALPUR	14193201	KULASAHI CHALIKHANDA	5331DT210	100	MIXED	AMI	Yes	0%	107	0.0503275	0.041812	0.0085155	16.92%
8534	TPCODL	PARADEEP	JED	RAGHUNATHPU	22MAUJA	14193	11 KV BAGALPUR	14193201	CHASUICHANDI	5331DT213	100	MIXED	AMI	Yes	100%	130	0.06934668	0.050004	0.01934268	27.89%
8535	TPCODL	PARADEEP	JED	RAGHUNATHPU	22MAUJA	14193	11 KV BAGALPUR	14193201	PRADHAN SAHI PURAN	5331DT218	100	MIXED	AMI	Yes	33%	101	0.03859916	0.035848	0.00275116	7.13%
8536	TPCODL	PARADEEP	JED	RAGHUNATHPU	22MAUJA	14193	11 KV BAGALPUR	14193201	NAHANBANI NO-1	5331DT243	100	MIXED	AMI	Yes	0%	81	0.05303144	0.026572	0.02645944	49.89%
8537	TPCODL	PARADEEP	JED	RAGHUNATHPU	22MAUJA	14193	11 KV BAGALPUR	14193201	OLIC DIHASAIBINI	5331DT280	100	MIXED	AMI	Yes	67%	49	0.03077598	0.014883	0.01589298	51.64%
8538	TPCODL	PARADEEP	JED	RAGHUNATHPU	22MAUJA	14193	11 KV BAGALPUR	14193201	GELAPUR	5331DT287	100	MIXED	AMI	Yes	67%	147	0.05136286	0.040901	0.01046186	20.37%
8539	TPCODL	PARADEEP	JED	RAGHUNATHPU	22MAUJA	14193	11 KV PARBATIPUR	14193202	SATHIBHAUNI BIDYA MANDIR, MANG	5331DT129	100	MIXED	AMI	Yes	67%	121	0.0567212	0.035375	0.0213462	37.63%
8540	TPCODL	PARADEEP	JED	RAGHUNATHPU	22MAUJA	14193	11 KV PARBATIPUR	14193202	BASANDARA VILLAGE 2	5331DT153	100	MIXED	AMI	Yes	67%	55	0.02864872	0.021579	0.00706972	24.68%

Sl. No.	Zone Name	Circle name	Division name	Name of the Sub-division	Name of the Sub-station	Substation Code	Name of the 11 kV Feeder	Feeder Code	Name of the Location where DT situated	DT code	DT Capacity (kVA)	Predominant consumer type of DT (Domestic/Industrial/Agriculture/Mixed)	Type of metering AMR/AMI/ Communicable/Conventional metered/Unmetered	Status of Meter- whether Functional (Yes/No)	% of data received automatically (if AMR/AMI)	No. of Connected Consumers	Input Energy (MU) (A)	Billed Energy (MU) (B)	Loss (MU) (A-B)	% DT Loss (A-B)/A
8541	TPCODL	PARADEEP	JED	RAGHUNATHPU	22MAUJA	14193	11 KV PARBATIPUR	14193202	BASANDARA VILLAGE 9	5331DT160	100	MIXED	AMI	Yes	67%	98	0.06148578	0.042071	0.01941478	31.58%
8542	TPCODL	PARADEEP	JED	RAGHUNATHPU	22MAUJA	14193	11 KV PARBATIPUR	14193202	PARBATIPUR VILLAGE NEAR SCHOOL	5331DT184	100	MIXED	AMI	Yes	67%	139	0.05238766	0.030401	0.02198666	41.97%
8543	TPCODL	PARADEEP	JED	RAGHUNATHPU	22MAUJA	14193	11 KV PARBATIPUR	14193202	SANKHARISAHI 6	5331DT197	100	MIXED	AMI	Yes	67%	88	0.02434574	0.021787	0.00255874	10.51%
8544	TPCODL	PARADEEP	JED	RAGHUNATHPU	BALIA (ADHANGA) (	14359	11 KV ADHANGA (BALIA	14359202	ADHANGA VILLAGE 1	5331DT324	100	MIXED	AMI	Yes	100%	138	0.10266778	0.056609	0.04605878	44.86%
8545	TPCODL	PARADEEP	JED	RAGHUNATHPU	BALIA (ADHANGA) (	14359	11 KV ADHANGA (BALIA	14359202	NUADHANA 1	5331DT326	100	MIXED	AMI	Yes	67%	160	0.07180264	0.068638	0.00316464	4.41%
8546	TPCODL	PARADEEP	JED	RAGHUNATHPU	BALIA (ADHANGA) (	14359	11 KV ADHANGA (BALIA	14359202	ADHANGA 4	5331DT339	100	MIXED	AMI	Yes	100%	82	0.04467276	0.035816	0.00885676	19.83%
8547	TPCODL	PARADEEP	JED	RAGHUNATHPU	BALIA (ADHANGA) (	14359	11 KV ADHANGA (BALIA	14359202	ADHANGAGARHA, ODISHA 2	5331DT347	100	MIXED	AMI	Yes	100%	55	0.02392236	0.022884	0.00103836	4.34%
8548	TPCODL	PARADEEP	JED	RAGHUNATHPU	BALIA (ADHANGA) (	14359	11 KV ADHANGA (BALIA	14359202	BARIK STORE	5331DT353	100	MIXED	AMI	Yes	100%	123	0.04519886	0.042072	0.00312686	6.92%
8549	TPCODL	PARADEEP	JED	RAGHUNATHPU	BALIA (ADHANGA) (	14359	11 KV JAYSOL	14359203	SUDAM GROCERY & RATION STORE -	5324DT210	100	MIXED	AMI	Yes	100%	54	0.01520062	0.013492	0.00170862	11.24%
8550	TPCODL	PARADEEP	JED	RAGHUNATHPU	BALIA (ADHANGA) (	14359	11 KV JAYSOL	14359203	BPD STUDY SPHERE - EDUCATION CEI	5331DT376	100	MIXED	AMI	Yes	100%	117	0.04876444	0.035128	0.01363644	27.96%
8551	TPCODL	PARADEEP	JED	RAGHUNATHPU	BALIA (ADHANGA) (	14359	11 KV JAYSOL	14359203	BASANTPUR 1	5331DT384	100	MIXED	AMI	Yes	100%	169	0.0753016	0.053033	0.0222686	29.57%
8552	TPCODL	PARADEEP	JED	RAGHUNATHPU	BALIA (ADHANGA) (	14359	11 KV JAYSOL	14359203	BASANTPUR 3	5331DT387	100	MIXED	AMI	Yes	100%	53	0.03904568	0.021639	0.01740668	44.58%
8553	TPCODL	PARADEEP	JED	RAGHUNATHPU	BALIA (ADHANGA) (	14359	11 KV BALIA	14359204	NEAR BHARATI SWAIN BHAVAN	5331DT426	100	MIXED	AMI	Yes	100%	61	0.0306181	0.023293	0.0073251	23.92%
8554	TPCODL	PARADEEP	JED	RAGHUNATHPU	BALIA (ADHANGA) (	14359	11 KV BALIA	14359204	NEAR CYCLONE BATYA RELIEF CENTE	5331DT428	100	MIXED	AMI	Yes	100%	109	0.06749076	0.054015	0.01347576	19.97%
8555	TPCODL	PARADEEP	JED	RAGHUNATHPU	BALIA (ADHANGA) (	14359	11 KV BALIA	14359204	NEAR BY MADINA MASJID	5331DT432	63	MIXED	AMI	Yes	100%	113	0.05738952	0.037825	0.01956452	34.09%
8556	TPCODL	PARADEEP	JED	RAGHUNATHPU	BALIA (ADHANGA) (	14359	11 KV BALIA	14359204	BADRINATH TEMPLE	5331DT433	63	MIXED	AMI	Yes	100%	87	0.03588904	0.033997	0.00189204	5.27%
8557	TPCODL	PARADEEP	JED	RAGHUNATHPU	BIRIDI	14171	11 KV DOGACHHIA	14171201	NUAPARI VILLAGE 4	5331DT098	63	MIXED	AMI	Yes	100%	49	0.02825634	0.013258	0.01499834	53.08%
8558	TPCODL	PARADEEP	JED	RAGHUNATHPU	BIRIDI	14171	11 KV DOGACHHIA	14171201	PANDIA 1	5331DT101	100	MIXED	AMI	Yes	0%	106	0.06927366	0.044253	0.02502066	36.12%
8559	TPCODL	PARADEEP	JED	RAGHUNATHPU	BIRIDI	14171	11 KV DOGACHHIA	14171201	BUDHAPADA VILLAGE 3	5331DT111	100	MIXED	AMI	Yes	100%	113	0.0905302	0.051329	0.0392012	43.30%
8560	TPCODL	PARADEEP	JED	RAGHUNATHPU	BIRIDI	14171	11 KV DHYANAKUD	14171202	BIRIDI 5	5331DT083	100	MIXED	AMI	Yes	67%	140	0.08051193	0.051061	0.02945093	36.58%
8561	TPCODL	PARADEEP	JED	RAGHUNATHPU	BIRIDI	14171	11 KV DHYANAKUD	14171202	BIRIDI CHANDAPUR 4	5331DT087	100	MIXED	AMI	Yes	100%	115	0.07862046	0.052902	0.02571846	32.71%
8562	TPCODL	PARADEEP	JED	RAGHUNATHPU	BIRIDI	14171	11 KV RANI PADA	14171203	RANIPADA 1	5331DT010	100	MIXED	AMI	Yes	100%	114	0.04650226	0.035719	0.01078326	23.19%
8563	TPCODL	PARADEEP	JED	RAGHUNATHPU	BIRIDI	14171	11 KV RANI PADA	14171203	HALADIAPADA 1	5331DT012	100	MIXED	AMI	Yes	100%	107	0.03062466	0.03005	0.00057466	1.88%
8564	TPCODL	PARADEEP	JED	RAGHUNATHPU	BIRIDI	14171	11 KV RANI PADA	14171203	HALADIAPADA 4	5331DT015	100	MIXED	AMI	Yes	100%	141	0.0802593	0.06206	0.0181993	22.68%
8565	TPCODL	PARADEEP	JED	RAGHUNATHPU	BIRIDI	14171	11 KV RANI PADA	14171203	BATIMARA 3	5331DT017	100	MIXED	AMI	Yes	100%	174	0.09188748	0.066553	0.02533448	27.57%
8566	TPCODL	PARADEEP	JED	RAGHUNATHPU	BIRIDI	14171	11 KV RANI PADA	14171203	ALANDO 3	5331DT019	100	MIXED	AMI	Yes	100%	101	0.06140092	0.030123	0.03127792	50.94%
8567	TPCODL	PARADEEP	JED	RAGHUNATHPU	BIRIDI	14171	11 KV RANI PADA	14171203	RANIPADA 2	5331DT023	100	MIXED	AMI	Yes	100%	125	0.0670951	0.055786	0.0113091	16.86%
8568	TPCODL	PARADEEP	JED	RAGHUNATHPU	BIRIDI	14171	11 KV RANI PADA	14171203	BADA KHANDAETTA 2	5331DT037	100	MIXED	AMI	Yes	100%	97	0.05732492	0.029695	0.02762992	48.20%
8569	TPCODL	PARADEEP	JED	RAGHUNATHPU	BIRIDI	14171	11 KV RANI PADA	14171203	ALANDA 7	5331DT043	100	MIXED	AMI	Yes	100%	50	0.03456072	0.018251	0.01630972	47.19%
8570	TPCODL	PARADEEP	JED	RAGHUNATHPU	BIRIDI	14171	11 KV RANI PADA	14171203	CHANDPUR 2	5331DT050	100	MIXED	AMI	Yes	0%	62	0.04441872	0.023047	0.02137172	48.11%
8571	TPCODL	PARADEEP	JED	RAGHUNATHPU	CHIKINIA (ERANDAP	14363	11 KV TARAPUR	14363201	ARANDA PALA	5332DT312	63	MIXED	AMI	Yes	100%	161	0.05727566	0.052286	0.00498966	8.71%
8572	TPCODL	PARADEEP	JED	RAGHUNATHPU	CHIKINIA (ERANDAP	14363	11 KV TARAPUR	14363201	KURTANGA 7	5332DT337	100	MIXED	AMI	Yes	100%	97	0.03767528	0.030671	0.00700428	18.59%
8573	TPCODL	PARADEEP	JED	RAGHUNATHPU	CHIKINIA (ERANDAP	14363	11 KV TARAPUR	14363201	BARTI 2	5332DT349	100	MIXED	AMI	Yes	67%	13	0.0177156	0.0169	0.0008156	4.60%
8574	TPCODL	PARADEEP	JED	RAGHUNATHPU	CHIKINIA (ERANDAP	14363	11 KV TARAPUR	14363201	GOKULPUR 17	5332DT358	100	MIXED	AMI	Yes	100%	73	0.0369948	0.023346	0.0136488	36.89%
8575	TPCODL	PARADEEP	JED	RAGHUNATHPU	CHIKINIA (ERANDAP	14363	11 KV TARAPUR	14363201	HARISHPUR	5332DT370	100	MIXED	AMI	Yes	100%	118	0.0489932	0.038116	0.0108772	22.20%
8576	TPCODL	PARADEEP	JED	RAGHUNATHPU	KAJALPUR ODSSP	14299	11 KV GOBINDPUR-II	14299202	GOVINDPUR 9	3333DT110	250	MIXED	AMI	Yes	0%	72	0.0862776	0.053424	0.0328536	38.08%
8577	TPCODL	PARADEEP	JED	RAGHUNATHPU	RAGHUNATHPUR	14170	11 KV RAGHUNATHPUR	14170201	RAGHUNATHAPUR MARKET 2	5332DT080	100	MIXED	AMI	Yes	100%	14	0.02915245	0.026859	0.00229345	7.87%
8578	TPCODL	PARADEEP	JED	RAGHUNATHPU	RAGHUNATHPUR	14170	11 KV RAGHUNATHPUR	14170201	JAGANNATHPUR 3	5332DT087	100	MIXED	AMI	Yes	100%	101	0.0523918	0.030304	0.0220878	42.16%
8579	TPCODL	PARADEEP	JED	RAGHUNATHPU	RAGHUNATHPUR	14170	11 KV RAGHUNATHPUR	14170201	SARAKARA SAHI 1	5332DT098	100	MIXED	AMI	Yes	100%	60	0.03126722	0.02321	0.00805722	25.77%
8580	TPCODL	PARADEEP	JED	RAGHUNATHPU	RAGHUNATHPUR	14170	11 KV RAGHUNATHPUR	14170201	PATENA 3	5332DT107	63	MIXED	AMI	Yes	100%	81	0.06788538	0.042013	0.02587238	38.11%
8581	TPCODL	PARADEEP	JED	RAGHUNATHPU	RAGHUNATHPUR	14170	11 KV KUNTAHAR	14170202	GADAMA BAZAR	5332DT225	100	MIXED	AMI	Yes	100%	183	0.08976306	0.077434	0.01232906	13.74%
8582	TPCODL	PARADEEP	JED	RAGHUNATHPU	RAGHUNATHPUR	14170	11 KV KUNTAHAR	14170202	GOTHAPADA	5332DT235	100	MIXED	AMI	Yes	100%	108	0.05591634	0.037663	0.01825334	32.64%
8583	TPCODL	PARADEEP	JED	RAGHUNATHPU	RAGHUNATHPUR	14170	11 KV KUNTAHAR	14170202	BODHAPUR CHAUDHURI SAHI	5332DT245	100	MIXED	AMI	Yes	100%	100	0.06207014	0.03487	0.02720014	43.82%
8584	TPCODL	PARADEEP	JED	RAGHUNATHPU	RAGHUNATHPUR	14170	11 KV KUNTAHAR	14170202	BODHAPUR FIELD	5332DT249	100	MIXED	AMI	Yes	100%	136	0.04804844	0.033337	0.01471144	30.62%
8585	TPCODL	PARADEEP	JED	RAGHUNATHPU	RAGHUNATHPUR	14170	11 KV KUNTAHAR	14170202	KOSOLA	5332DT406	100	MIXED	AMI	Yes	100%	92	0.05435154	0.045244	0.00910754	16.76%
8586	TPCODL	PARADEEP	JED	RAGHUNATHPU	RAGHUNATHPUR	14170	11 KV KUNTAHAR	14170202	BELESWARPUR	5332DT416	100	MIXED	AMI	Yes	100%	69	0.06026834	0.025244	0.03502434	58.11%
8587	TPCODL	PARADEEP	JED	RAGHUNATHPU	RAGHUNATHPUR	14170	11 KV KUNTAHAR	14170202	THORIAPADA MUSLIM SAHI	5332DT427	100	MIXED	AMI	Yes	100%	129	0.11026906	0.068233	0.04203606	38.12%
8588	TPCODL	PARADEEP	JED	RAGHUNATHPU	RAGHUNATHPUR	14170	11 KV TARAPUR	14170203	KORKARA 3	5332DT122	100	MIXED	AMI	Yes	100%	138	0.0702492	0.054277	0.0159722	22.74%
8589	TPCODL	PARADEEP	JED	RAGHUNATHPU	RAGHUNATHPUR	14170	11 KV TARAPUR	14170203	ROIPADA	5332DT127	100	MIXED	AMI	Yes	100%	105	0.03573708	0.032695	0.00304208	8.51%
8590	TPCODL	PARADEEP	JED	RAGHUNATHPU	RAGHUNATHPUR	14170	11 KV TARAPUR	14170203	SIRLO 2	5332DT139	100	MIXED	AMI	Yes	100%	193	0.05728768	0.052627	0.00466068	8.14%
8591	TPCODL	PARADEEP	JED	RAGHUNATHPU	RAGHUNATHPUR	14170	11 KV TARAPUR	14170203	SIRLO 6	5332DT143	100	MIXED	AMI	Yes	67%	78	0.06135842	0.029697	0.03166142	51.60%
8592	TPCODL	PARADEEP	JED	RAGHUNATHPU	RAGHUNATHPUR	14170	11 KV TARAPUR	14170203	SIRLO 7	5332DT144	100	MIXED	AMI	Yes	67%	122	0.06400306	0.048613	0.01539006	24.05%
8593	TPCODL	PARADEEP	JED	RAGHUNATHPU	RAGHUNATHPUR	14170	11 KV TARAPUR	14170203	SIRLO 8	5332DT145	100	MIXED	AMI	Yes	100%	166	0.06699754	0.045975	0.02102254	31.38%
8594	TPCODL	PARADEEP	JED	RAGHUNATHPU	RAGHUNATHPUR	14170	11 KV TARAPUR	14170203	SADHU SAHI	5332DT150	100	MIXED	AMI	Yes	67%	162	0.08561072	0.061417	0.02419372	28.26%
8595	TPCODL	PARADEEP	JED	RAGHUNATHPU	RAGHUNATHPUR	14170	11 KV TARAPUR	14170203	BASANTA 1	5332DT167	100	MIXED	AMI	Yes	100%	92	0.03888472	0.032706	0.00617872	15.89%
8596	TPCODL	PARADEEP	JED	RAGHUNATHPU	RAGHUNATHPUR	14170	11 KV TARAPUR	14170203	ODAPADA 5	5332DT188	100	MIXED	AMI	Yes	67%	150	0.05422788	0.047666	0.00656188	12.10%
8597	TPCODL	PARADEEP	JED	RAGHUNATHPU	RAGHUNATHPUR	14170	11 KV TARAPUR	14170203	KARAKARA 1	5332DT203	100	MIXED	AMI	Yes	100%	100	0.0379228	0.028251	0.0096718	25.50%
8598	TPCODL	PARADEEP	KED1	AUL	AUL	14154	11 kV CHHOTAKANIKA	14154203	NUAKULA 002	5111DT013	100	MIXED	AMI	Yes	0%	33	0.02966002	0.009433	0.02022702	68.20%
8599	TPCODL	PARADEEP	KED1	AUL	AUL	14154	11 kV CHHOTAKANIKA	14154203	ENDOL TRINATH MANDIR NEAR	5111DT015	100	MIXED	AMI	Yes	0%	58	0.0251172	0.022356	0.0027612	10.99%
8600	TPCODL	PARADEEP	KED1	AUL	PATTAMUNDAI	17033	AUL	17033402	SINGIRI	5111DT002	250	MIXED	AMI	Yes	67%	135	0.18513456	0.076818	0.10831656	58.51%
8601	TPCODL	PARADEEP	KED1	AUL	PATTAMUNDAI	17033	AUL	17033402	CHANDIAGARI	5111DT005	250	MIXED	AMI	Yes	67%	351	0.15619508	0.111028	0.04516708	28.92%
8602	TPCODL	PARADEEP	KED1	AUL	ADHAJORI	14159	11 KV DAMARPUR	14159203	DAMARPUR 13	5134DT277	100	MIXED	AMI	Yes	67%	134	0.0549399	0.038641	0.0162989	29.67%
8603	TPCODL	PARADEEP	KED1	AUL	AUL	14154	11 KV SASAN	14154201	NEAR SUBSTATION 1	5111DT270	100	MIXED	AMI	Yes	100%	102	0.0628716	0.04243	0.0204416	32.51%
8604	TPCODL	PARADEEP	KED1	AUL	AUL	14154	11 KV SASAN	14154201	SASAN 1	5111DT277	100	MIXED	AMI	Yes	100%	74	0.04609218	0.028321	0.01777118	38.56%
8605	TPCODL	PARADEEP	KED1	AUL	AUL	14154	11 KV SASAN	14154201	SASAN 2	5111DT278	100	MIXED	AMI	Yes	33%	83	0.04219772	0.031805	0.01039272	24.63%
8606	TPCODL	PARADEEP	KED1	AUL	AUL	14154	11 KV SASAN	14154201	PANI PUMP	5111DT280	100	MIXED	AMI	Yes	100%	62	0.02148964	0.020564	0.00092564	4.31%
8607	TPCODL	PARADEEP	KED1	AUL	AUL	14154	11 KV SASAN	14154201	PANI TANKI 4	5111DT285	100	MIXED	AMI	Yes	100%	87	0.04575714	0.03560367	0.01015347	22.19%
8608	TPCODL	PARADEEP	KED1	AUL	AUL	14154	11 KV SASAN	14154201	ROUTA 3	5111DT289	100	MIXED	AMI	Yes	67%	145	0.0661686	0.044104	0.0220646	33.35%
8609	TPCODL	PARADEEP	KED1	AUL	AUL	14154	11 KV SASAN	14154201	DHANMANDAL VILLAGE WATER PUM	5111DT297	100	MIXED	AMI	Yes	0%	172	0.09037488	0.061323	0.02905188	32.15%
8610	TPCODL	PARADEEP	KED1	AUL	AUL	14154	11 KV SASAN	14154201	NEAR SILASTAMBA GROUND 3	5111DT301	100	MIXED	AMI	Yes	100%	118	0.04465632	0.036655	0.00800132	17.92%
8611	TPCODL	PARADEEP	KED1	AUL	AUL	14154	11 KV SASAN	14154201	PAIKASAHI 1	5111DT320	100	MIXED	AMI	Yes	100%	70	0.03619392	0.02993	0.00626392	17.31%
8612	TPCODL	PARADEEP	KED1	AUL	AUL	14154	11 KV SASAN	14154201	SHALIYANPUR 2	5111DT328	100	MIXED	AMI	Yes	67%	64	0.0331594	0.024838	0.0083214	25.10%
8613	TPCODL	PARADEEP	KED1	AUL	AUL	14154	11 KV AUL	14154202	PANI TANKI 1	5111DT121	100	MIXED	AMI	Yes	100%	185	0.0851421	0.081494	0.0036481	4.28%

Sl. No.	Zone Name	Circle name	Division name	Name of the Sub-division	Name of the Sub-station	Substation Code	Name of the 11 kV Feeder	Feeder Code	Name of the Location where DT situated	DT code	DT Capacity (kVA)	Predominant consumer type of DT (Domestic/Industrial/Agriculture/Mixed)	Type of metering AMR/AMI/ Communicable/Conventional metered/Unmetered	Status of Meter-whether Functional (Yes/No)	% of data received automatically (if AMR/AMI)	No. of Connected Consumers	Input Energy (MU) (A)	Billed Energy (MU) (B)	Loss (MU) (A-B)	% DT Loss (A-B)/A
8614	TPCODL	PARADEEP	KED1	AUL	AUL	14154	11 KV AUL	14154202	MAHIMA SKILL PARK	5111DT125	100	MIXED	AMI	Yes	100%	60	0.10524736	0.041951	0.06329636	60.14%
8615	TPCODL	PARADEEP	KED1	AUL	AUL	14154	11 KV AUL	14154202	AUL BAZAR 2	5111DT130	250	MIXED	AMI	Yes	100%	178	0.17363196	0.091094	0.08253796	47.54%
8616	TPCODL	PARADEEP	KED1	AUL	AUL	14154	11 KV AUL	14154202	PANI TANKI KE PASS 1	5111DT139	100	MIXED	AMI	Yes	100%	115	0.10876845	0.062528	0.04624045	42.51%
8617	TPCODL	PARADEEP	KED1	AUL	AUL	14154	11 KV AUL	14154202	AUL 2	5111DT144	100	MIXED	AMI	Yes	33%	61	0.06425178	0.034639	0.02961278	46.09%
8618	TPCODL	PARADEEP	KED1	AUL	AUL	14154	11 KV AUL	14154202	HOSPITAL AUL 2	5111DT148	250	MIXED	AMI	Yes	67%	110	0.1505092	0.052234	0.0982752	65.30%
8619	TPCODL	PARADEEP	KED1	AUL	AUL	14154	11 KV AUL	14154202	LOKABADA 2	5111DT157	100	MIXED	AMI	Yes	100%	135	0.06851886	0.056259	0.01225986	17.89%
8620	TPCODL	PARADEEP	KED1	AUL	AUL	14154	11 KV AUL	14154202	LOKAPADA	5111DT173	63	MIXED	AMI	Yes	100%	51	0.06201382	0.017764	0.04424982	71.35%
8621	TPCODL	PARADEEP	KED1	AUL	AUL	14154	11 KV AUL	14154202	ADI 2	5111DT182	250	MIXED	AMI	Yes	100%	204	0.20895964	0.09614612	0.11281352	53.99%
8622	TPCODL	PARADEEP	KED1	AUL	AUL	14154	11 KV AUL	14154202	AADI 1	5111DT189	100	MIXED	AMI	Yes	100%	97	0.08432064	0.052519	0.03180164	37.72%
8623	TPCODL	PARADEEP	KED1	AUL	AUL	14154	11 KV AUL	14154202	NAGUPADA 1	5111DT190	100	MIXED	AMI	Yes	0%	68	0.0754033	0.02639	0.0490133	65.00%
8624	TPCODL	PARADEEP	KED1	AUL	AUL	14154	11 KV AUL	14154202	BALKATI 2	5111DT196	100	MIXED	AMI	Yes	0%	106	0.0521896	0.0374237	0.0147659	28.29%
8625	TPCODL	PARADEEP	KED1	AUL	AUL	14154	11 KV AUL	14154202	CHUNUBANDA 1	5111DT206	100	MIXED	AMI	Yes	67%	95	0.03428992	0.027181	0.00710892	20.73%
8626	TPCODL	PARADEEP	KED1	AUL	AUL	14154	11 KV AUL	14154202	BADANKO 1	5111DT211	100	MIXED	AMI	Yes	67%	79	0.02779978	0.02029	0.00750978	27.01%
8627	TPCODL	PARADEEP	KED1	AUL	AUL	14154	11 KV AUL	14154202	BADANKO 5	5111DT216	100	MIXED	AMI	Yes	0%	101	0.05264126	0.031863	0.02077826	39.47%
8628	TPCODL	PARADEEP	KED1	AUL	AUL	14154	11 KV AUL	14154202	BADANKO 7	5111DT219	100	MIXED	AMI	Yes	67%	69	0.04422006	0.016624	0.02759606	62.41%
8629	TPCODL	PARADEEP	KED1	AUL	AUL	14154	11 KV AUL	14154202	MAHU 8	5111DT234	100	MIXED	AMI	Yes	67%	79	0.0544524	0.029486	0.0249664	45.85%
8630	TPCODL	PARADEEP	KED1	AUL	AUL	14154	11 KV AUL	14154202	MAHU 9	5111DT235	100	MIXED	AMI	Yes	67%	145	0.06053894	0.045096	0.01544294	25.51%
8631	TPCODL	PARADEEP	KED1	AUL	AUL	14154	11 KV AUL	14154202	MAHU 14	5111DT240	100	MIXED	AMI	Yes	67%	110	0.04541148	0.039058	0.00635348	13.99%
8632	TPCODL	PARADEEP	KED1	AUL	AUL	14154	11 KV AUL	14154202	KOLIDIHA 2	5111DT245	100	MIXED	AMI	Yes	0%	24	0.02223488	0.009759	0.01247588	56.11%
8633	TPCODL	PARADEEP	KED1	AUL	AUL	14154	11 KV AUL	14154202	KOLIDIHA 3	5111DT246	100	MIXED	AMI	Yes	67%	59	0.02207868	0.016305	0.00577368	26.15%
8634	TPCODL	PARADEEP	KED1	AUL	AUL	14154	11 KV AUL	14154202	JAMUDANDA 1	5111DT253	100	MIXED	AMI	Yes	67%	64	0.02172944	0.01725	0.00447944	20.61%
8635	TPCODL	PARADEEP	KED1	AUL	AUL	14154	11 KV AUL	14154202	ECHHAPUR 3	5111DT257	100	MIXED	AMI	Yes	67%	38	0.01059832	0.009368	0.00123032	11.61%
8636	TPCODL	PARADEEP	KED1	AUL	AUL	14154	11 KV AUL	14154202	CHANDANGAR	5111DT258	100	MIXED	AMI	Yes	67%	58	0.03074708	0.01816	0.01258708	40.94%
8637	TPCODL	PARADEEP	KED1	AUL	AUL	14154	11 KV AUL	14154202	DINIARI 2	5111DT264	100	MIXED	AMI	Yes	0%	58	0.01802324	0.013567	0.00445624	24.72%
8638	TPCODL	PARADEEP	KED1	AUL	AUL	14154	11 KV CHHOTAKANIKA	14154203	TUNGA MANGALA TEMPALE	5111DT011	63	MIXED	AMI	Yes	0%	74	0.02897396	0.019683	0.00929096	32.07%
8639	TPCODL	PARADEEP	KED1	AUL	AUL	14154	11 KV CHHOTAKANIKA	14154203	NEW TUNGA ROAD SIDE	5111DT014	100	MIXED	AMI	Yes	33%	67	0.0410181	0.027296	0.0137221	33.45%
8640	TPCODL	PARADEEP	KED1	AUL	AUL	14154	11 KV CHHOTAKANIKA	14154203	RADHA KRISNA TEMPLE 2	5111DT017	100	MIXED	AMI	Yes	67%	55	0.04242268	0.018878	0.02354468	55.50%
8641	TPCODL	PARADEEP	KED1	AUL	AUL	14154	11 KV CHHOTAKANIKA	14154203	TUNGA KHARASRUTA RIVER ROAD SII	5111DT023	100	MIXED	AMI	Yes	67%	42	0.01971204	0.011441	0.00827104	41.96%
8642	TPCODL	PARADEEP	KED1	AUL	AUL	14154	11 KV CHHOTAKANIKA	14154203	GIRIBANDHA [LOKANATH TEMPLE 03	5111DT028	100	MIXED	AMI	Yes	67%	37	0.016888	0.012213	0.004675	27.68%
8643	TPCODL	PARADEEP	KED1	AUL	AUL	14154	11 KV CHHOTAKANIKA	14154203	GIRIBANDHA PRIMARY SCHOOL 2	5111DT035	100	MIXED	AMI	Yes	67%	62	0.05890888	0.021601	0.03730788	63.33%
8644	TPCODL	PARADEEP	KED1	AUL	AUL	14154	11 KV CHHOTAKANIKA	14154203	MULASAHI 1	5111DT037	100	MIXED	AMI	Yes	0%	114	0.06284792	0.022085	0.04076292	64.86%
8645	TPCODL	PARADEEP	KED1	AUL	AUL	14154	11 KV CHHOTAKANIKA	14154203	DAKA MANGALA	5111DT336	100	MIXED	AMI	Yes	0%	94	0.09705152	0.087945	0.00910652	9.38%
8646	TPCODL	PARADEEP	KED1	AUL	AUL	14154	11 KV CHHOTAKANIKA	14154203	CHHOTO BAULA JODI	5112DT001	100	MIXED	AMI	Yes	0%	44	0.0239129	0.010462	0.0134509	56.25%
8647	TPCODL	PARADEEP	KED1	AUL	AUL	14154	11 KV BHUINPUR	14154204	BALI SHAHI 3	5112DT076	100	MIXED	AMI	Yes	67%	61	0.02290208	0.02066	0.00224208	9.79%
8648	TPCODL	PARADEEP	KED1	AUL	AUL	14154	11 KV BHUINPUR	14154204	NEAR TEMPLE KHARAKHARA	5112DT080	100	MIXED	AMI	Yes	33%	53	0.02133	0.014413	0.006917	32.43%
8649	TPCODL	PARADEEP	KED1	AUL	AUL	14154	11 KV BHUINPUR	14154204	BRAHMANI RIVER KHARAKA BAZAR	5112DT081	250	MIXED	AMI	Yes	67%	162	0.10138784	0.048523	0.05286484	52.14%
8650	TPCODL	PARADEEP	KED1	AUL	AUL	14154	11 KV BHUINPUR	14154204	NEAR RIVER 12 AYATAPUR	5112DT091	100	MIXED	AMI	Yes	67%	118	0.06073446	0.041235	0.01949946	32.11%
8651	TPCODL	PARADEEP	KED1	AUL	AUL	14154	11 KV BHUINPUR	14154204	NEAR POND(JENAVALI)	5112DT094	100	MIXED	AMI	Yes	67%	68	0.0621939	0.01888	0.0433139	69.64%
8652	TPCODL	PARADEEP	KED1	AUL	AUL	14154	11 KV BHUINPUR	14154204	RAMA CHANDRA SAHOO	5112DT102	100	MIXED	AMI	Yes	67%	102	0.04164774	0.027501	0.01414674	33.97%
8653	TPCODL	PARADEEP	KED1	AUL	AUL	14154	11 KV BHUINPUR	14154204	NEAR RIVER 11(BADAMANGA MESHF	5112DT112	100	MIXED	AMI	Yes	67%	96	0.04453302	0.034763	0.00977002	21.94%
8654	TPCODL	PARADEEP	KED1	AUL	AUL	14154	11 KV BHUINPUR	14154204	NEAR RIVER 17(MANGARAJPUR MISH	5112DT117	100	MIXED	AMI	Yes	67%	26	0.00992868	0.008501	0.00142768	14.38%
8655	TPCODL	PARADEEP	KED1	AUL	AUL	14154	11 KV BHUINPUR	14154204	SANSHIDHA 1	5112DT120	100	MIXED	AMI	Yes	67%	55	0.02287894	0.011234	0.01164494	50.90%
8656	TPCODL	PARADEEP	KED1	AUL	AUL	14154	11 KV BHUINPUR	14154204	HANUMAN TEMPLE 3(THAKURPATAN	5112DT125	100	MIXED	AMI	Yes	67%	34	0.01165206	0.009392	0.00226006	19.40%
8657	TPCODL	PARADEEP	KED1	AUL	AUL	14154	11 KV BHUINPUR	14154204	PETEPADA 5	5112DT132	100	MIXED	AMI	Yes	67%	108	0.03768834	0.023181	0.01450734	38.49%
8658	TPCODL	PARADEEP	KED1	AUL	AUL	14154	11 KV BHUINPUR	14154204	NEAR WATER TANK 3	5112DT144	100	MIXED	AMI	Yes	0%	59	0.01829944	0.011647	0.00665244	36.35%
8659	TPCODL	PARADEEP	KED1	AUL	AUL	14154	11 KV BHUINPUR	14154204	NEAR RIVER 24(MANPUR PATANA)	5112DT153	100	MIXED	AMI	Yes	67%	94	0.03324512	0.026188	0.00705712	21.23%
8660	TPCODL	PARADEEP	KED1	AUL	AUL	14154	11 KV BHUINPUR	14154204	NEAR RIVER 26(MANPUR DAR SAHI)	5112DT155	100	MIXED	AMI	Yes	67%	98	0.0344501	0.031566	0.0028841	8.37%
8661	TPCODL	PARADEEP	KED1	AUL	AUL	14154	11 KV BHUINPUR	14154204	NEAR RIVER 27(MANPUR JENA SAHI)	5112DT156	100	MIXED	AMI	Yes	67%	83	0.0219892	0.018246	0.0037432	17.02%
8662	TPCODL	PARADEEP	KED1	AUL	AUL	14154	11 KV BHUINPUR	14154204	NEAR RIVER 30(SANSIDHA SETHY SAH	5112DT162	100	MIXED	AMI	Yes	67%	57	0.02814184	0.017853	0.01028884	36.56%
8663	TPCODL	PARADEEP	KED1	AUL	AUL	14154	11 KV BHUINPUR	14154204	KHARASROTA RIVER 2 KALAMADA SA	5112DT184	100	MIXED	AMI	Yes	33%	38	0.01507414	0.008062	0.00701214	46.52%
8664	TPCODL	PARADEEP	KED1	AUL	AUL	14154	11 KV BHUINPUR	14154204	NEAR RIVER 39(DAITARIPUR)	5112DT190	100	MIXED	AMI	Yes	33%	46	0.04471788	0.015575	0.02914288	65.17%
8665	TPCODL	PARADEEP	KED1	AUL	AUL	14154	11 KV BHUINPUR	14154204	NEAR AYATPUR JENASAHI	5112DT272	100	MIXED	AMI	Yes	67%	60	0.01481078	0.01289	0.00192078	12.97%
8666	TPCODL	PARADEEP	KED1	AUL	AUL	14154	11 KV BHUINPUR	14154204	JENAVALI ROAD(KALASPUR)	5112DT274	100	MIXED	AMI	Yes	0%	32	0.0230729	0.015215	0.0078579	34.06%
8667	TPCODL	PARADEEP	KED1	AUL	AUL	14154	11 KV BHUINPUR	14154204	JENAVALI ROAD(KALASPUR)	5112DT275	100	MIXED	AMI	Yes	67%	90	0.05144586	0.021187	0.03025886	58.82%
8668	TPCODL	PARADEEP	KED1	AUL	AUL	14154	11 KV MENDHAPUR	14154205	BHATAPADA	5111DT052	100	MIXED	AMI	Yes	67%	32	0.04435238	0.013128	0.03122438	70.40%
8669	TPCODL	PARADEEP	KED1	AUL	AUL	14154	11 KV MENDHAPUR	14154205	GOPALRAYPUR	5111DT060	100	MIXED	AMI	Yes	67%	47	0.02196144	0.016658	0.00530344	24.15%
8670	TPCODL	PARADEEP	KED1	AUL	AUL	14154	11 KV MENDHAPUR	14154205	PODAMARI	5111DT072	100	MIXED	AMI	Yes	67%	102	0.0388843	0.028909	0.0099753	25.65%
8671	TPCODL	PARADEEP	KED1	AUL	AUL	14154	11 KV MENDHAPUR	14154205	DHANESWARPUR	5111DT092	100	MIXED	AMI	Yes	67%	102	0.04566088	0.029275	0.01638588	35.89%
8672	TPCODL	PARADEEP	KED1	AUL	AUL	14154	11 KV MENDHAPUR	14154205	DHANESWARPUR	5111DT094	63	MIXED	AMI	Yes	67%	105	0.04978126	0.034039	0.01574226	31.62%
8673	TPCODL	PARADEEP	KED1	AUL	AUL	14154	11 KV MENDHAPUR	14154205	KANTIPUR	5111DT101	100	MIXED	AMI	Yes	67%	98	0.06108978	0.04427	0.01681978	27.53%
8674	TPCODL	PARADEEP	KED1	AUL	AUL	14154	11 KV MENDHAPUR	14154205	PATANA	5111DT113	100	MIXED	AMI	Yes	0%	113	0.03485176	0.02845	0.00640176	18.37%
8675	TPCODL	PARADEEP	KED1	AUL	AUL	14154	11 KV MENDHAPUR	14154205	MANGLA SAHUPADA	5111DT116	100	MIXED	AMI	Yes	0%	173	0.04049942	0.039535	0.00096442	2.38%
8676	TPCODL	PARADEEP	KED1	AUL	AUL	14154	11 KV MENDHAPUR	14154205	NEAR PANY TUNKY 1	5132DT005	100	MIXED	AMI	Yes	67%	92	0.03694108	0.026811	0.01013008	27.42%
8677	TPCODL	PARADEEP	KED1	AUL	AYATAN ODSSP	14352	11 KV AYATAN	14352201	MEGHAPUR	5114DT399	100	MIXED	AMI	Yes	67%	100	0.04799542	0.0334552	0.01454022	30.30%
8678	TPCODL	PARADEEP	KED1	AUL	AYATAN ODSSP	14352	11 KV AYATAN	14352201	AYATAN 3	5114DT408	100	MIXED	AMI	Yes	67%	110	0.04917252	0.044758	0.00441452	8.98%
8679	TPCODL	PARADEEP	KED1	AUL	AYATAN ODSSP	14352	11 KV AYATAN	14352201	SIKO 2	5114DT415	100	MIXED	AMI	Yes	67%	148	0.06136032	0.049536	0.01182432	19.27%
8680	TPCODL	PARADEEP	KED1	AUL	AYATAN ODSSP	14352	11 KV AYATAN	14352201	PANDUKOLI 4(KHANDITA)	5114DT480	100	MIXED	AMI	Yes	67%	150	0.05911818	0.035635	0.02348318	39.72%
8681	TPCODL	PARADEEP	KED1	AUL	AYATAN ODSSP	14352	11 KV AYATAN	14352201	KATANA MARKET 1	5114DT496	100	MIXED	AMI	Yes	67%	138	0.079686	0.070187	0.009499	11.92%
8682	TPCODL	PARADEEP	KED1	AUL	AYATAN ODSSP	14352	11 KV AYATAN	14352201	JHADAMALA 2,MADARANGAPATA	5114DT503	100	MIXED	AMI	Yes	67%	88	0.0321186	0.025313	0.0068056	21.19%
8683	TPCODL	PARADEEP	KED1	AUL	AYATAN ODSSP	14352	11 KV AYATAN	14352201	DHAMARA 5	5114DT521	100	MIXED	AMI	Yes	0%	66	0.03108058	0.01491729	0.01616329	52.00%
8684	TPCODL	PARADEEP	KED1	AUL	AYATAN ODSSP	14352	11 KV AYATAN	14352201	BIRADIA 1(PATRAPUR)	5114DT530	100	MIXED	AMI	Yes	67%	109	0.0356859	0.02646104	0.00922486	25.85%
8685	TPCODL	PARADEEP	KED1	AUL	AYATAN ODSSP	14352	11 KV JAYNAGAR	14352202	KHUNTA (BEHERASAHI)	5114DT162	100	MIXED	AMI	Yes	0%	69	0.0150053	0.013015	0.0019903	13.26%
8686	TPCODL	PARADEEP	KED1	AUL	AYATAN ODSSP	14352	11 KV JAYNAGAR	14352202	JAYANAGAR BAZAR	5114DT184	100	MIXED	AMI	Yes	33%	137	0.07306018	0.044924	0.02813618	38.51%

Sl. No.	Zone Name	Circle name	Division name	Name of the Sub-division	Name of the Sub-station	Substation Code	Name of the 11 kV Feeder	Feeder Code	Name of the Location where DT situated	DT code	DT Capacity (kVA)	Predominant consumer type of DT (Domestic/Industrial/Agriculture/Mixed)	Type of metering AMR/AMI/ Communicable/Conventional metered/Unmetered	Status of Meter-whether Functional (Yes/No)	% of data received automatically (if AMR/AMI)	No. of Connected Consumers	Input Energy (MU) (A)	Billed Energy (MU) (B)	Loss (MU) (A-B)	% DT Loss (A-B)/A
8687	TPCODL	PARADEEP	KED1	AUL	AYATAN ODSSP	14352	11 KV JAYNAGAR	14352202	BAZARPUR 1	5114DT191	100	MIXED	AMI	Yes	33%	185	0.05687638	0.049343	0.00753338	13.25%
8688	TPCODL	PARADEEP	KED1	AUL	AYATAN ODSSP	14352	11 KV NAHULIA	14352203	GIRIA 3	5114DT206	100	MIXED	AMI	Yes	67%	109	0.04742414	0.034579	0.01284514	27.09%
8689	TPCODL	PARADEEP	KED1	AUL	AYATAN ODSSP	14352	11 KV NAHULIA	14352203	KONARDA 1	5114DT238	100	MIXED	AMI	Yes	0%	143	0.08365534	0.05540827	0.02824707	33.77%
8690	TPCODL	PARADEEP	KED1	AUL	AYATAN ODSSP	14352	11 KV NAHULIA	14352203	DOSAUTUNI 2	5114DT246	100	MIXED	AMI	Yes	100%	125	0.06616778	0.045027	0.02114078	31.95%
8691	TPCODL	PARADEEP	KED1	AUL	AYATAN ODSSP	14352	11 KV NAHULIA	14352203	GOBANGA VILLAGE 1	5114DT251	100	MIXED	AMI	Yes	67%	105	0.0354094	0.02895	0.0064594	18.24%
8692	TPCODL	PARADEEP	KED1	AUL	AYATAN ODSSP	14352	11 KV NAHULIA	14352203	NAIKULA DANDI	5114DT265	100	MIXED	AMI	Yes	67%	108	0.02876818	0.024882	0.00388618	13.51%
8693	TPCODL	PARADEEP	KED1	AUL	BALARAMPUR	14200	11 KV OLAVAR	14200201	KENDU SHAHI 11	5113DT238	100	MIXED	AMI	Yes	67%	72	0.02460008	0.01851	0.00609008	24.76%
8694	TPCODL	PARADEEP	KED1	AUL	BALARAMPUR	14200	11 KV OLAVAR	14200201	KENDU SHAHI 7	5113DT246	100	MIXED	AMI	Yes	67%	98	0.03588892	0.027256	0.00863292	24.05%
8695	TPCODL	PARADEEP	KED1	AUL	BALARAMPUR	14200	11 KV OLAVAR	14200201	NAUNI 3	5113DT247	250	MIXED	AMI	Yes	67%	125	0.0498908	0.036538	0.0133528	26.76%
8696	TPCODL	PARADEEP	KED1	AUL	BALARAMPUR	14200	11 KV OLAVAR	14200201	BRUNA 2	5113DT274	100	MIXED	AMI	Yes	100%	53	0.06604652	0.018719	0.04732752	71.66%
8697	TPCODL	PARADEEP	KED1	AUL	BALARAMPUR	14200	11 KV HATASAHI	14200202	DOMANDA MAA MANGALA TEMPLE	5113DT074	100	MIXED	AMI	Yes	0%	15	0.0146023	0.006368	0.0082343	56.39%
8698	TPCODL	PARADEEP	KED1	AUL	BALARAMPUR	14200	11 KV HATASAHI	14200202	GUNTHALA RODE SIDE 1	5113DT090	100	MIXED	AMI	Yes	33%	73	0.02003378	0.017641	0.00239278	11.94%
8699	TPCODL	PARADEEP	KED1	AUL	BALARAMPUR	14200	11 KV HATASAHI	14200202	ABDULPUR RAJEEV GANDHI SEVA KEI	5113DT135	100	MIXED	AMI	Yes	100%	106	0.05547728	0.030581	0.02489628	44.88%
8700	TPCODL	PARADEEP	KED1	AUL	BALARAMPUR	14200	11 KV HATASAHI	14200202	HATISAHI ARPU PUJA MANDAP 2	5113DT189	100	MIXED	AMI	Yes	0%	153	0.07286296	0.039306	0.03355696	46.05%
8701	TPCODL	PARADEEP	KED1	AUL	BALARAMPUR	14200	11 KV HATASAHI	14200202	BHAMANDA BISWANATH HIGH SCHO	5113DT201	100	MIXED	AMI	Yes	67%	156	0.0602727	0.049667	0.0106057	17.60%
8702	TPCODL	PARADEEP	KED1	AUL	BALARAMPUR	14200	11 KV DASIPUR	14200203	TUNGA 1	5113DT005	100	MIXED	AMI	Yes	67%	72	0.03107594	0.021343	0.00973294	31.32%
8703	TPCODL	PARADEEP	KED1	AUL	BALARAMPUR	14200	11 KV DASIPUR	14200203	SHIV TEMPLE 2	5113DT011	100	MIXED	AMI	Yes	0%	104	0.03405472	0.031137	0.00291772	8.57%
8704	TPCODL	PARADEEP	KED1	AUL	BALARAMPUR	14200	11 KV DASIPUR	14200203	HABALGANDA 8	5113DT020	100	MIXED	AMI	Yes	67%	66	0.02060546	0.0174	0.00320546	15.56%
8705	TPCODL	PARADEEP	KED1	AUL	BALARAMPUR	14200	11 KV DASIPUR	14200203	UJANGA 4	5113DT029	100	MIXED	AMI	Yes	0%	59	0.02486154	0.020946	0.00391554	15.75%
8706	TPCODL	PARADEEP	KED1	AUL	BALARAMPUR	14200	11 KV DASIPUR	14200203	NEAR POUND 1	5113DT043	100	MIXED	AMI	Yes	0%	96	0.04764402	0.025756	0.02188802	45.94%
8707	TPCODL	PARADEEP	KED1	AUL	BALARAMPUR	14200	11 KV DASIPUR	14200203	BUDHI JAGULAI TEMPLE	5113DT057	100	MIXED	AMI	Yes	67%	84	0.03339558	0.026399	0.00699658	20.95%
8708	TPCODL	PARADEEP	KED1	AUL	BALARAMPUR	14200	11 KV DASIPUR	14200203	DEULATARA 6	5113DT313	100	MIXED	AMI	Yes	33%	141	0.05196558	0.038913	0.01305258	25.12%
8709	TPCODL	PARADEEP	KED1	AUL	BALARAMPUR	14200	11 KV DASIPUR	14200203	CHANDPADA 9	5113DT335	250	MIXED	AMI	Yes	67%	260	0.09036924	0.07052	0.01984924	21.96%
8710	TPCODL	PARADEEP	KED1	AUL	BARAMUNDA	14005	11 KV BARAMUNDA BDA	14005202	IDEAL PARKING TEMPORARY BUS STA	1221DT030	250	MIXED	AMI	Yes	0%	53	0.06548636	0.038682	0.02680436	40.93%
8711	TPCODL	PARADEEP	KED1	AUL	CHHATA	14199	11 KV PANCHUPANDAVA	14199202	BHUJUBALA	5121DT125	250	MIXED	AMI	Yes	0%	93	0.07945576	0.026277	0.05317876	66.93%
8712	TPCODL	PARADEEP	KED1	AUL	DANPUR	14164	11 KV DANPUR	14164201	NEAR PUJANJ TEMPLE	5122DT189	100	MIXED	AMI	Yes	100%	138	0.04462426	0.034243	0.01038126	23.26%
8713	TPCODL	PARADEEP	KED1	AUL	MADHUBANA ODSS	14349	11 KV GOVINDPUR (Mad	14349201	NEAR JUINA VILLAGE 2	5112DT006	63	MIXED	AMI	Yes	0%	52	0.02629848	0.015632	0.01066648	40.56%
8714	TPCODL	PARADEEP	KED1	AUL	MADHUBANA ODSS	14349	11 KV GOVINDPUR (Mad	14349201	NEAR JAGANATH TEMPLE 1 JUANIA	5112DT019	100	MIXED	AMI	Yes	100%	18	0.01989944	0.010188	0.00971144	48.80%
8715	TPCODL	PARADEEP	KED1	AUL	MADHUBANA ODSS	14349	11 KV GOVINDPUR (Mad	14349201	NEAR GOVINDPUR VILLAGE 2	5112DT025	100	MIXED	AMI	Yes	100%	110	0.05266494	0.03872	0.01394494	26.48%
8716	TPCODL	PARADEEP	KED1	AUL	MADHUBANA ODSS	14349	11 KV GOVINDPUR (Mad	14349201	PRAIMARY HEALTH CENTRE GOVINDI	5112DT027	100	MIXED	AMI	Yes	100%	51	0.01843564	0.016943	0.00149264	8.10%
8717	TPCODL	PARADEEP	KED1	AUL	MADHUBANA ODSS	14349	11 KV GOVINDPUR (Mad	14349201	PRAIMARY SCHOOL GOVINDPUR 1	5112DT029	100	MIXED	AMI	Yes	67%	119	0.06034034	0.04567473	0.01466561	24.30%
8718	TPCODL	PARADEEP	KED1	AUL	MADHUBANA ODSS	14349	11 KV GOVINDPUR (Mad	14349201	PRAIMARY SCHOOL GOVINDPUR 3 (S	5112DT031	100	MIXED	AMI	Yes	100%	64	0.02751418	0.017371	0.01014318	36.87%
8719	TPCODL	PARADEEP	KED1	AUL	MADHUBANA ODSS	14349	11 KV GOVINDPUR (Mad	14349201	BBA HINJAL SAHOO SAHI	5112DT038	100	MIXED	AMI	Yes	0%	28	0.0091749	0.007981	0.0011939	13.01%
8720	TPCODL	PARADEEP	KED1	AUL	MADHUBANA ODSS	14349	11 KV GOVINDPUR (Mad	14349201	DESAHI VILLAGE 1	5112DT048	100	MIXED	AMI	Yes	67%	107	0.04252276	0.028678	0.01384476	32.56%
8721	TPCODL	PARADEEP	KED1	AUL	MADHUBANA ODSS	14349	11 KV GOVINDPUR (Mad	14349201	DESAHI VILLAGE NEAR	5112DT052	100	MIXED	AMI	Yes	67%	60	0.02249474	0.015988	0.00650674	28.93%
8722	TPCODL	PARADEEP	KED1	AUL	MADHUBANA ODSS	14349	11 KV GOVINDPUR (Mad	14349201	HADUI VILLAGE NEAR SIV MANDIR 1	5112DT061	100	MIXED	AMI	Yes	67%	130	0.0576429	0.044264	0.0133789	23.21%
8723	TPCODL	PARADEEP	KED1	AUL	MADHUBANA ODSS	14349	11 KV GOVINDPUR (Mad	14349201	HADUI VILLAGE	5112DT064	100	MIXED	AMI	Yes	67%	76	0.03569202	0.03072	0.00497202	13.93%
8724	TPCODL	PARADEEP	KED1	AUL	MADHUBANA ODSS	14349	11 KV GOVINDPUR (Mad	14349201	SASAN HANUMAN MANDIR	5112DT267	100	MIXED	AMI	Yes	0%	19	0.01291516	0.007614	0.00530116	41.05%
8725	TPCODL	PARADEEP	KED1	AUL	MADHUBANA ODSS	14349	11 KV MAHARAKULA	14349202	MADHUBAN 7	5112DT207	100	MIXED	AMI	Yes	67%	64	0.01862604	0.012778	0.00584804	31.40%
8726	TPCODL	PARADEEP	KED1	AUL	MADHUBANA ODSS	14349	11 KV MAHARAKULA	14349202	MAHARKULA 11	5112DT215	100	MIXED	AMI	Yes	67%	114	0.04765298	0.03877	0.00888298	18.64%
8727	TPCODL	PARADEEP	KED1	AUL	MADHUBANA ODSS	14349	11 KV MAHARAKULA	14349202	ARGAL SASAN 1	5112DT219	100	MIXED	AMI	Yes	67%	133	0.03529602	0.029415	0.00588102	16.66%
8728	TPCODL	PARADEEP	KED1	AUL	MADHUBANA ODSS	14349	11 KV MAHARAKULA	14349202	SANAGIRI 1	5112DT221	100	MIXED	AMI	Yes	67%	37	0.01596916	0.011118	0.00485116	30.38%
8729	TPCODL	PARADEEP	KED1	AUL	MADHUBANA ODSS	14349	11 KV MAHARAKULA	14349202	ARGAL 5 D FALA SAHI	5112DT225	100	MIXED	AMI	Yes	67%	74	0.02515192	0.019788	0.00536392	21.33%
8730	TPCODL	PARADEEP	KED1	AUL	MADHUBANA ODSS	14349	11 KV MAHARAKULA	14349202	ARGAL 6	5112DT232	100	MIXED	AMI	Yes	67%	63	0.02215434	0.011905	0.01024934	46.26%
8731	TPCODL	PARADEEP	KED1	AUL	MADHUBANA ODSS	14349	11 KV MAHARAKULA	14349202	ARGAL 8 JENA SAHI	5112DT234	100	MIXED	AMI	Yes	0%	58	0.02395308	0.013866	0.01008708	42.11%
8732	TPCODL	PARADEEP	KED1	AUL	MADHUBANA ODSS	14349	11 KV MAHARAKULA	14349202	ARGAL SASAN 6	5112DT241	100	MIXED	AMI	Yes	67%	49	0.02197144	0.019137	0.00283444	12.90%
8733	TPCODL	PARADEEP	KED1	AUL	MADHUBANA ODSS	14349	11 KV MAHARAKULA	14349202	DIMIRIPAL 3 RGGVY-2	5112DT245	100	MIXED	AMI	Yes	0%	60	0.01728136	0.014178	0.00310336	17.96%
8734	TPCODL	PARADEEP	KED1	AUL	PATRAPUR	14156	11 KV BATIPADA	14156201	MAA BALAVI GOAN THAKURANI TEM	5112DT254	100	MIXED	AMI	Yes	33%	43	0.00814892	0.006664	0.00148492	18.22%
8735	TPCODL	PARADEEP	KED1	AUL	PATRAPUR	14156	11 KV BATIPADA	14156201	PANCHANPADA	5112DT257	100	MIXED	AMI	Yes	67%	136	0.03465656	0.03279	0.00186656	5.39%
8736	TPCODL	PARADEEP	KED1	AUL	PATRAPUR	14156	11 KV BATIPADA	14156201	MAA KANTIKAPALI TEMPLE NEAR DA	5112DT258	100	MIXED	AMI	Yes	0%	11	0.0075888	0.002401	0.0051878	68.36%
8737	TPCODL	PARADEEP	KED1	AUL	PATRAPUR	14156	11 KV BATIPADA	14156201	PANCHANPADA JENA SAHI	5112DT259	100	MIXED	AMI	Yes	67%	41	0.01430412	0.008037	0.00626712	43.81%
8738	TPCODL	PARADEEP	KED1	AUL	PATRAPUR	14156	11 KV BATIPADA	14156201	NEAR ARAJEE SHIVA TEMPLE DANDIS	5112DT261	100	MIXED	AMI	Yes	67%	27	0.00735546	0.005717	0.00163846	22.28%
8739	TPCODL	PARADEEP	KED1	AUL	PATRAPUR	14156	11 KV BATIPADA	14156201	SANAMANGA HIGH SCHOOL 2	5112DT265	100	MIXED	AMI	Yes	33%	26	0.02085978	0.019631	0.00122878	5.89%
8740	TPCODL	PARADEEP	KED1	AUL	PATRAPUR	14156	11 KV BATIPADA	14156201	NEAR THAKURSAHI BATIPADA	5132DT062	100	MIXED	AMI	Yes	67%	101	0.03729174	0.027889	0.00940274	25.21%
8741	TPCODL	PARADEEP	KED1	AUL	RAJAKANIKA	14155	11 KV OSTIA	14155201	KANTAPADA HATA	5114DT269	100	MIXED	AMI	Yes	0%	61	0.04583842	0.033824	0.01201442	26.21%
8742	TPCODL	PARADEEP	KED1	AUL	RAJAKANIKA	14155	11 KV OSTIA	14155201	BARADA VILLAGE	5114DT284	100	MIXED	AMI	Yes	33%	129	0.05202274	0.042728	0.00929474	17.87%
8743	TPCODL	PARADEEP	KED1	AUL	RAJAKANIKA	14155	11 KV OSTIA	14155201	KARANJA BANDHA VILLAGE PANI TAN	5114DT298	100	MIXED	AMI	Yes	33%	91	0.04982882	0.033196	0.01663282	33.38%
8744	TPCODL	PARADEEP	KED1	AUL	RAJAKANIKA	14155	11 KV OSTIA	14155201	BADAGARA VILLAGE NEAR PANI TANI	5114DT318	100	MIXED	AMI	Yes	67%	93	0.04949808	0.03925	0.01024808	20.70%
8745	TPCODL	PARADEEP	KED1	AUL	RAJAKANIKA	14155	11 KV OSTIA	14155201	TARAS VILLAGE	5114DT332	100	MIXED	AMI	Yes	33%	75	0.05900236	0.030202	0.02880036	48.81%
8746	TPCODL	PARADEEP	KED1	AUL	RAJAKANIKA	14155	11 KV OSTIA	14155201	DEULI	5114DT339	100	MIXED	AMI	Yes	33%	164	0.07657308	0.074141	0.00243208	3.18%
8747	TPCODL	PARADEEP	KED1	AUL	RAJAKANIKA	14155	11 KV OSTIA	14155201	SAHAJ JAN SEVA KENDR TARAS VILLA	5114DT347	100	MIXED	AMI	Yes	100%	75	0.04791202	0.038373	0.00953902	19.91%
8748	TPCODL	PARADEEP	KED1	AUL	RAJAKANIKA	14155	11 KV OSTIA	14155201	BANGARKUAN	5114DT354	100	MIXED	AMI	Yes	33%	144	0.05443758	0.040678	0.01375958	25.28%
8749	TPCODL	PARADEEP	KED1	AUL	RAJAKANIKA	14155	11 KV GIRIA	14155202	CHANDANPUR BAZAR	5114DT007	100	MIXED	AMI	Yes	100%	43	0.07267478	0.032015	0.04065978	55.95%
8750	TPCODL	PARADEEP	KED1	AUL	RAJAKANIKA	14155	11 KV GIRIA	14155202	KALIKAPUR	5114DT010	100	MIXED	AMI	Yes	100%	157	0.09553664	0.066833	0.02870364	30.04%
8751	TPCODL	PARADEEP	KED1	AUL	RAJAKANIKA	14155	11 KV BHARIGUDA	14155203	ASHOK BAZAR NEAR 1	5114DT041	100	MIXED	AMI	Yes	67%	16	0.03577434	0.015995	0.01977934	55.29%
8752	TPCODL	PARADEEP	KED1	AUL	RAJAKANIKA	14155	11 KV BHARIGUDA	14155203	ASHOK BAZAR NEAR 2	5114DT042	100	MIXED	AMI	Yes	67%	107	0.09415716	0.069876	0.02428116	25.79%
8753	TPCODL	PARADEEP	KED1	AUL	RAJAKANIKA	14155	11 KV BHARIGUDA	14155203	GANJA ORIMARI SCHOOL	5114DT046	100	MIXED	AMI	Yes	0%	81	0.03662472	0.02687943	0.00974529	26.61%
8754	TPCODL	PARADEEP	KED1	AUL	RAJAKANIKA	14155	11 KV BHARIGUDA	14155203	BALICHITRI GANJA	5114DT047	100	MIXED	AMI	Yes	0%	193	0.13867512	0.076236	0.06243912	45.03%
8755	TPCODL	PARADEEP	KED1	AUL	RAJAKANIKA	14155	11 KV BHARIGUDA	14155203	PANCHAYAT NODAL U.P SCHOOL 1	5114DT061	100	MIXED	AMI	Yes	67%	77	0.0498979	0.030673	0.0192249	38.53%
8756	TPCODL	PARADEEP	KED1	AUL	RAJAKANIKA	14155	11 KV BHARIGUDA	14155203	PANCHAYAT NODAL U.P SCHOOL 2	5114DT062	100	MIXED	AMI	Yes	67%	51	0.03726756	0.029995	0.00727256	19.51%
8757	TPCODL	PARADEEP	KED1	AUL	RAJAKANIKA	14155	11 KV BHARIGUDA	14155203	LAXMI BIRAH HIGH SCHOOL 2	5114DT097	100	MIXED	AMI	Yes	67%	220	0.07813042	0.060681	0.01744942	22.33%
8758	TPCODL	PARADEEP	KED1	AUL	RAJAKANIKA	14155	11 KV BHARIGUDA	14155203	PARIMAKUNDA U.P SCHOOL 2	5114DT103	100	MIXED	AMI	Yes	67%	106	0.0368157	0.030244	0.0065717	17.85%
8759	TPCODL	PARADEEP	KED1	AUL	RAJAKANIKA	14155	11 KV BHARIGUDA	14155203	BHAGABAT TEMPLE 2	5114DT557	100	MIXED	AMI	Yes	67%	52	0.01867916	0.011317	0.00736216	39.41%

Sl. No.	Zone Name	Circle name	Division name	Name of the Sub-division	Name of the Sub-station	Substation Code	Name of the 11 kV Feeder	Feeder Code	Name of the Location where DT situated	DT code	DT Capacity (kVA)	Predominant consumer type of DT (Domestic/Industrial/Agriculture/Mixed)	Type of metering AMR/AMI/ Communicable/Conventional metered/Unmetered	Status of Meter-whether Functional (Yes/No)	% of data received automatically (if AMR/AMI)	No. of Connected Consumers	Input Energy (MU) (A)	Billed Energy (MU) (B)	Loss (MU) (A-B)	% DT Loss (A-B)/A
8760	TPCODL	PARADEEP	KED1	AUL	RAJAKANIKA	14155	11 KV OLAVER	14155204	SN COLLEGE RAJKANIKA 3	5114DT021	100	MIXED	AMI	Yes	0%	63	0.08869446	0.026591	0.06210346	70.02%
8761	TPCODL	PARADEEP	KED1	AUL	RAJAKANIKA	14155	11 KV OLAVER	14155204	RAJKANIKA POLICE STATION	5114DT028	100	MIXED	AMI	Yes	100%	6	0.01999058	0.010053	0.00993758	49.71%
8762	TPCODL	PARADEEP	KED1	AUL	RAJAKANIKA	14155	11 KV RAJAKANIKA BAZA	14155205	RAJKANIKA BAZAR 1	5114DT196	250	MIXED	AMI	Yes	100%	168	0.1441949	0.128575	0.0156199	10.83%
8763	TPCODL	PARADEEP	KED1	KENDRAPARA	INDUPUR	14157	11 kV INDUPUR	14157201	HABILI PANCHAGOCHIA	5123DT053	100	MIXED	AMI	Yes	100%	54	0.0423071	0.022149	0.0201581	47.65%
8764	TPCODL	PARADEEP	KED1	KENDRAPARA	CHOKADA ODSSP	14351	11 kV BLOCK	14351203	HAZARI BAGICHA 2	5124DT216	63	MIXED	AMI	Yes	100%	117	0.14766192	0.088177	0.05948492	40.28%
8765	TPCODL	PARADEEP	KED1	KENDRAPARA	ADASPUR	14104	11 KV ADASPUR	14104201	URADHA BHOI SAHI	3343DT415	100	MIXED	AMI	Yes	67%	39	0.03727802	0.012836	0.02444202	65.57%
8766	TPCODL	PARADEEP	KED1	KENDRAPARA	ASURESWAR ODSSP	14311	11 KV LUNA	14311203	K.G. ISHALO PANDA SAHI	3521DT215	63	MIXED	AMI	Yes	67%	91	0.05455884	0.028825	0.02573384	47.17%
8767	TPCODL	PARADEEP	KED1	KENDRAPARA	AUL	14154	11 KV AUL	14154202	RANIPUR 3	5111DT185	100	MIXED	AMI	Yes	0%	94	0.08897924	0.027716	0.06126324	68.85%
8768	TPCODL	PARADEEP	KED1	KENDRAPARA	AUL	14154	11 KV BHUINPUR	14154204	KALASPUR 2 HARIJAN SAHI	5112DT104	100	MIXED	AMI	Yes	0%	32	0.0134259	0.007649	0.0057769	43.03%
8769	TPCODL	PARADEEP	KED1	KENDRAPARA	AUL	14154	11 KV BHUINPUR	14154204	NEAR RIVER 14(MANGARAJPUR)	5112DT115	100	MIXED	AMI	Yes	67%	55	0.02044454	0.014575	0.00586954	28.71%
8770	TPCODL	PARADEEP	KED1	KENDRAPARA	AYATAN ODSSP	14352	11 KV AYATAN	14352201	KATANA BANIA	5114DT493	100	MIXED	AMI	Yes	0%	66	0.03643582	0.019144	0.01729182	47.46%
8771	TPCODL	PARADEEP	KED1	KENDRAPARA	BALIKUDA	14174	11 KV DENGAPOLA	14174201	ICHAPUR VILLAGE 3	5311DT042	250	MIXED	AMI	Yes	33%	228	0.07394552	0.058691	0.01525452	20.63%
8772	TPCODL	PARADEEP	KED1	KENDRAPARA	CHAUDAKULATA OD	14347	11 KV GHAGARA	14347201	JARIA BADA	5123DT005	100	MIXED	AMI	Yes	100%	113	0.05775902	0.035261	0.02249802	38.95%
8773	TPCODL	PARADEEP	KED1	KENDRAPARA	CHAUDAKULATA OD	14347	11 KV GHAGARA	14347201	NEAR PANI TANKI	5123DT030	100	MIXED	AMI	Yes	100%	67	0.02191234	0.019921	0.00199134	9.09%
8774	TPCODL	PARADEEP	KED1	KENDRAPARA	CHAUDAKULATA OD	14347	11 KV CHOUDAKULAT	14347202	CHANDANPUR 3	5135DT077	250	MIXED	AMI	Yes	100%	281	0.15557708	0.109945	0.04563208	29.33%
8775	TPCODL	PARADEEP	KED1	KENDRAPARA	CHAUDAKULATA OD	14347	11 KV CHOUDAKULAT	14347202	DEBALA	5135DT107	100	MIXED	AMI	Yes	100%	69	0.06287768	0.024577	0.03830068	60.91%
8776	TPCODL	PARADEEP	KED1	KENDRAPARA	CHHAGHARIA	14198	11 KV BAGADA	14198201	CHHAGRIA 4	5125DT133	63	MIXED	AMI	Yes	100%	47	0.01955552	0.012071	0.00748452	38.27%
8777	TPCODL	PARADEEP	KED1	KENDRAPARA	CHHAGHARIA	14198	11 KV BAGADA	14198201	BAGADA 2	5125DT137	100	MIXED	AMI	Yes	33%	79	0.07131724	0.024109	0.04720824	66.19%
8778	TPCODL	PARADEEP	KED1	KENDRAPARA	CHHAGHARIA	14198	11 KV BAGADA	14198201	BAGADA 3	5125DT138	100	MIXED	AMI	Yes	33%	44	0.03804814	0.014531	0.02351714	61.81%
8779	TPCODL	PARADEEP	KED1	KENDRAPARA	CHHAGHARIA	14198	11 KV BAGADA	14198201	BAGADA 6	5125DT141	100	MIXED	AMI	Yes	100%	179	0.07736784	0.058699	0.01866884	24.13%
8780	TPCODL	PARADEEP	KED1	KENDRAPARA	CHHAGHARIA	14198	11 KV BAGADA	14198201	BAGADA 9	5125DT147	100	MIXED	AMI	Yes	67%	142	0.07011558	0.048137	0.02197858	31.35%
8781	TPCODL	PARADEEP	KED1	KENDRAPARA	CHHAGHARIA	14198	11 KV BAGADA	14198201	DUTIYALAY 1	5125DT156	100	MIXED	AMI	Yes	67%	113	0.05941956	0.039006	0.02041356	34.35%
8782	TPCODL	PARADEEP	KED1	KENDRAPARA	CHHAGHARIA	14198	11 KV BAGADA	14198201	KHASADI 2	5125DT180	100	MIXED	AMI	Yes	100%	171	0.07213466	0.053732	0.01840266	25.51%
8783	TPCODL	PARADEEP	KED1	KENDRAPARA	CHHAGHARIA	14198	11 KV BAGADA	14198201	KHASADI 3	5125DT181	100	MIXED	AMI	Yes	100%	135	0.05863668	0.036492	0.02214468	37.77%
8784	TPCODL	PARADEEP	KED1	KENDRAPARA	CHHAGHARIA	14198	11 KV GOPA CHHAKA	14198202	SANAIPUR	5125DT025	250	MIXED	AMI	Yes	100%	111	0.09510576	0.063439	0.03166676	33.30%
8785	TPCODL	PARADEEP	KED1	KENDRAPARA	CHHAGHARIA	14198	11 KV GOPA CHHAKA	14198202	NEAR HAVEY ROAD TIRAHA	5125DT032	250	MIXED	AMI	Yes	100%	17	0.0383964	0.015438	0.0229584	59.79%
8786	TPCODL	PARADEEP	KED1	KENDRAPARA	CHHATA	14199	11 KV CHHATA	14199201	GOBIND PUR 1	5121DT016	100	MIXED	AMI	Yes	100%	125	0.04393678	0.034301	0.00963578	21.93%
8787	TPCODL	PARADEEP	KED1	KENDRAPARA	CHHATA	14199	11 KV CHHATA	14199201	JAGULIPEDA	5121DT053	100	MIXED	AMI	Yes	67%	171	0.06573846	0.058642	0.00709646	10.79%
8788	TPCODL	PARADEEP	KED1	KENDRAPARA	CHHATA	14199	11 KV CHHATA	14199201	SHYAMSUNDARPUR 2	5121DT080	100	MIXED	AMI	Yes	100%	301	0.09718988	0.07423585	0.02295403	23.62%
8789	TPCODL	PARADEEP	KED1	KENDRAPARA	CHHATA	14199	11 KV CHHATA	14199201	BALIA 1	5121DT092	250	MIXED	AMI	Yes	67%	66	0.06488496	0.014195	0.05068996	78.12%
8790	TPCODL	PARADEEP	KED1	KENDRAPARA	CHHATA	14199	11 KV CHHATA	14199201	OLDHI -I	5121DT097	100	MIXED	AMI	Yes	0%	138	0.10996002	0.035966	0.07399402	67.29%
8791	TPCODL	PARADEEP	KED1	KENDRAPARA	CHHATA	14199	11 KV CHHATA	14199201	S.S CHHATA	5121DT220	500	MIXED	AMI	Yes	67%	128	0.08789832	0.075865	0.01203332	13.69%
8792	TPCODL	PARADEEP	KED1	KENDRAPARA	CHHATA	14199	11 KV CHHATA	14199201	MAHESHPUR 1	5125DT009	100	MIXED	AMI	Yes	67%	83	0.03846038	0.030039	0.00842138	21.90%
8793	TPCODL	PARADEEP	KED1	KENDRAPARA	CHHATA	14199	11 KV PANCHUPANDAVA	14199202	BAZAR	3312DT540	100	MIXED	AMI	Yes	0%	77	0.02225608	0.020662	0.00159408	7.16%
8794	TPCODL	PARADEEP	KED1	KENDRAPARA	CHHATA	14199	11 KV PANCHUPANDAVA	14199202	KANSANIPATNA1	5121DT126	100	MIXED	AMI	Yes	100%	177	0.08081444	0.065511	0.01530344	18.94%
8795	TPCODL	PARADEEP	KED1	KENDRAPARA	CHHATA	14199	11 KV PANCHUPANDAVA	14199202	BELARPUR	5121DT136	250	MIXED	AMI	Yes	0%	94	0.04003646	0.0199	0.02013646	50.30%
8796	TPCODL	PARADEEP	KED1	KENDRAPARA	CHHATA	14199	11 KV PANCHUPANDAVA	14199202	AMBURA	5121DT140	100	MIXED	AMI	Yes	67%	140	0.07692928	0.056995	0.01993428	25.91%
8797	TPCODL	PARADEEP	KED1	KENDRAPARA	CHHATA	14199	11 KV PANCHUPANDAVA	14199202	RAGHUDEIPURVILLAGE	5121DT142	250	MIXED	AMI	Yes	67%	87	0.0310682	0.024473	0.0065952	21.23%
8798	TPCODL	PARADEEP	KED1	KENDRAPARA	CHHATA	14199	11 KV PANCHUPANDAVA	14199202	RAJNAGAR	5121DT147	100	MIXED	AMI	Yes	67%	77	0.0220223	0.014551	0.0074713	33.93%
8799	TPCODL	PARADEEP	KED1	KENDRAPARA	CHHATA	14199	11 KV PANCHUPANDAVA	14199202	CHHACHINA 2	5121DT157	100	MIXED	AMI	Yes	67%	129	0.0508446	0.036545	0.0142996	28.12%
8800	TPCODL	PARADEEP	KED1	KENDRAPARA	CHHATA	14199	11 KV PANCHUPANDAVA	14199202	NUAHAT1	5121DT170	100	MIXED	AMI	Yes	67%	247	0.10146136	0.06947885	0.03198251	31.52%
8801	TPCODL	PARADEEP	KED1	KENDRAPARA	CHHATA	14199	11 KV PANCHUPANDAVA	14199202	DERADIHMARKIT PANCHU PANDAV	5121DT202	100	MIXED	AMI	Yes	100%	186	0.08597604	0.082924	0.00305204	3.55%
8802	TPCODL	PARADEEP	KED1	KENDRAPARA	CHOKADA ODSSP	14351	11 KV KANSAR	14351201	MALWA ISHWAPUR 3	5125DT442	100	MIXED	AMI	Yes	67%	33	0.02566264	0.006148	0.01951464	76.04%
8803	TPCODL	PARADEEP	KED1	KENDRAPARA	CHOKADA ODSSP	14351	11 KV KANSAR	14351201	CHAKARPUR 1	5126DT073	100	MIXED	AMI	Yes	0%	140	0.04992896	0.046204	0.00372496	7.46%
8804	TPCODL	PARADEEP	KED1	KENDRAPARA	CHOKADA ODSSP	14351	11 KV KANSAR	14351201	JAGADISHPUR 3	5126DT076	100	MIXED	AMI	Yes	0%	86	0.0727962	0.022931	0.0498652	68.50%
8805	TPCODL	PARADEEP	KED1	KENDRAPARA	CHOKADA ODSSP	14351	11 KV KANSAR	14351201	JAGADISHPUR 2	5126DT078	100	MIXED	AMI	Yes	33%	34	0.05816918	0.015124	0.04304518	74.00%
8806	TPCODL	PARADEEP	KED1	KENDRAPARA	CHOKADA ODSSP	14351	11 KV KANSAR	14351201	JAGADISHPUR 1	5126DT079	100	MIXED	AMI	Yes	100%	215	0.07659652	0.048105	0.02849152	37.20%
8807	TPCODL	PARADEEP	KED1	KENDRAPARA	CHOKADA ODSSP	14351	11 KV KANSAR	14351201	CHANDIYA PALI 2	5126DT091	100	MIXED	AMI	Yes	67%	61	0.03153952	0.014537	0.01700252	53.91%
8808	TPCODL	PARADEEP	KED1	KENDRAPARA	CHOKADA ODSSP	14351	11 KV KANSAR	14351201	KORUA 4	5126DT104	100	MIXED	AMI	Yes	67%	123	0.04664848	0.031297	0.01535148	32.91%
8809	TPCODL	PARADEEP	KED1	KENDRAPARA	CHOKADA ODSSP	14351	11 KV KANSAR	14351201	KORUA 2	5126DT106	100	MIXED	AMI	Yes	67%	122	0.03943392	0.034496	0.00493792	12.52%
8810	TPCODL	PARADEEP	KED1	KENDRAPARA	CHOKADA ODSSP	14351	11 KV KANSAR	14351201	LOKONATHPUR 8	5126DT123	100	MIXED	AMI	Yes	33%	28	0.01092078	0.006871	0.00404978	37.08%
8811	TPCODL	PARADEEP	KED1	KENDRAPARA	CHOKADA ODSSP	14351	11 KV KANSAR	14351201	BALIGOTHA 1	5126DT137	100	MIXED	AMI	Yes	0%	124	0.05049324	0.02471	0.02578324	51.06%
8812	TPCODL	PARADEEP	KED1	KENDRAPARA	CHOKADA ODSSP	14351	11 KV KANSAR	14351201	KEWATIPUR 3	5126DT143	100	MIXED	AMI	Yes	0%	89	0.06993244	0.016344	0.05358844	76.63%
8813	TPCODL	PARADEEP	KED1	KENDRAPARA	CHOKADA ODSSP	14351	11 KV KANSAR	14351201	CHANDANPUR 2	5126DT154	100	MIXED	AMI	Yes	67%	45	0.04876178	0.011781	0.03698078	75.84%
8814	TPCODL	PARADEEP	KED1	KENDRAPARA	CHOKADA ODSSP	14351	11 KV KANSAR	14351201	KANSAR 7	5126DT158	100	MIXED	AMI	Yes	67%	57	0.05417298	0.012814	0.04135898	76.35%
8815	TPCODL	PARADEEP	KED1	KENDRAPARA	CHOKADA ODSSP	14351	11 KV KANSAR	14351201	KANSAR 3	5126DT162	100	MIXED	AMI	Yes	67%	107	0.03701232	0.023143	0.01386932	37.47%
8816	TPCODL	PARADEEP	KED1	KENDRAPARA	CHOKADA ODSSP	14351	11 KV KANSAR	14351201	NARANPUR 6	5133DT352	100	MIXED	AMI	Yes	33%	114	0.03564784	0.027769	0.00787884	22.10%
8817	TPCODL	PARADEEP	KED1	KENDRAPARA	CHOKADA ODSSP	14351	11 KV KANSAR	14351201	POROMPUR 4	5223DT293	100	MIXED	AMI	Yes	33%	104	0.04346356	0.022148	0.02131556	49.04%
8818	TPCODL	PARADEEP	KED1	KENDRAPARA	CHOKADA ODSSP	14351	11 KV BALDEVJEW	14351202	NEAR FIRE OFFICE 1	5126DT005	250	MIXED	AMI	Yes	0%	178	0.11540156	0.100685	0.01471656	12.75%
8819	TPCODL	PARADEEP	KED1	KENDRAPARA	CHOKADA ODSSP	14351	11 KV BALDEVJEW	14351202	RELIANCE SMART POINT 2	5126DT012	500	MIXED	AMI	Yes	100%	351	0.30990416	0.215514	0.09439016	30.46%
8820	TPCODL	PARADEEP	KED1	KENDRAPARA	CHOKADA ODSSP	14351	11 KV BLOCK	14351203	TOWN BALRAMPUR 1	5124DT208	100	MIXED	AMI	Yes	0%	149	0.08686026	0.076829	0.01003126	11.55%
8821	TPCODL	PARADEEP	KED1	KENDRAPARA	CHOKADA ODSSP	14351	11 KV BLOCK	14351203	NEAR BLOCK 1	5124DT213	100	MIXED	AMI	Yes	33%	23	0.06563944	0.01322	0.05241944	79.86%
8822	TPCODL	PARADEEP	KED1	KENDRAPARA	CHOKADA ODSSP	14351	11 KV BLOCK	14351203	ALIJANGA 1	5124DT217	63	MIXED	AMI	Yes	33%	134	0.07726316	0.072629	0.00463416	6.00%
8823	TPCODL	PARADEEP	KED1	KENDRAPARA	CHOKADA ODSSP	14351	11 KV BLOCK	14351203	JANGIPUR 1	5124DT218	63	MIXED	AMI	Yes	67%	51	0.02609858	0.017369	0.00872958	33.45%
8824	TPCODL	PARADEEP	KED1	KENDRAPARA	CHOKADA ODSSP	14351	11 KV BLOCK	14351203	HAZARI BAGICHA 3	5124DT227	100	MIXED	AMI	Yes	100%	99	0.09465214	0.084133	0.01051914	11.11%
8825	TPCODL	PARADEEP	KED1	KENDRAPARA	CHOKADA ODSSP	14351	11 KV BLOCK	14351203	NEAR PETROL TANKI 1	5124DT232	250	MIXED	AMI	Yes	0%	306	0.32410496	0.241595	0.08250996	25.46%
8826	TPCODL	PARADEEP	KED1	KENDRAPARA	CHOKADA ODSSP	14351	11 KV BLOCK	14351203	GOPA 1	5124DT235	250	MIXED	AMI	Yes	100%	223	0.1669344	0.153552	0.0133824	8.02%
8827	TPCODL	PARADEEP	KED1	KENDRAPARA	CHOKADA ODSSP	14351	11 KV BLOCK	14351203	EKKADA KHANDI 1	5125DT436	100	MIXED	AMI	Yes	100%	124	0.12468482	0.074572	0.05011282	40.19%
8828	TPCODL	PARADEEP	KED1	KENDRAPARA	CHOKADA ODSSP	14351	11 KV BLOCK	14351203	TEMPAL 1	5126DT018	100	MIXED	AMI	Yes	100%	19	0.01268588	0.009089	0.00359688	28.35%
8829	TPCODL	PARADEEP	KED1	KENDRAPARA	CHOKADA ODSSP	14351	11 KV BLOCK	14351203	SARANG 4	5126DT022	100	MIXED	AMI	Yes	67%	40	0.03487716	0.015859	0.01901816	54.53%
8830	TPCODL	PARADEEP	KED1	KENDRAPARA	CHOKADA ODSSP	14351	11 KV BLOCK	14351203	BADA BARANG	5126DT026	250	MIXED	AMI	Yes	67%	161	0.08118928	0.051053	0.03013628	37.12%
8831	TPCODL	PARADEEP	KED1	KENDRAPARA	CHOKADA ODSSP	14351	11 KV BLOCK	14351203	GAPUR 1	5126DT029	100	MIXED	AMI	Yes	100%	99	0.05190048	0.017729	0.03417148	65.84%
8832	TPCODL	PARADEEP	KED1	KENDRAPARA	CHOKADA ODSSP	14351	11 KV BLOCK	14351203	SARANG 10	5126DT049	100	MIXED	AMI	Yes	67%	52	0.0271536	0.01648	0.0106736	39.31%

Sl. No.	Zone Name	Circle name	Division name	Name of the Sub-division	Name of the Sub-station	Substation Code	Name of the 11 kV Feeder	Feeder Code	Name of the Location where DT situated	DT code	DT Capacity (kVA)	Predominant consumer type of DT (Domestic/Industrial/Agriculture/Mixed)	Type of metering AMR/AMI/ Communicable/Conventional metered/Unmetered	Status of Meter- whether Functional (Yes/No)	% of data received automatically (if AMR/AMI)	No. of Connected Consumers	Input Energy (MU) (A)	Billed Energy (MU) (B)	Loss (MU) (A-B)	% DT Loss (A-B)/A
8833	TPCODL	PARADEEP	KED1	KENDRAPARA	DANPUR	14164	11 KV DANPUR	14164201	LAXMI BAZZR	5122DT177	100	MIXED	AMI	Yes	100%	91	0.04839796	0.029936	0.01846196	38.15%
8834	TPCODL	PARADEEP	KED1	KENDRAPARA	DANPUR	14164	11 KV DANPUR	14164201	BALIKUDA PLAYGROUND	5122DT204	100	MIXED	AMI	Yes	0%	125	0.06097014	0.039207	0.02176314	35.69%
8835	TPCODL	PARADEEP	KED1	KENDRAPARA	DANPUR	14164	11 KV DANPUR	14164201	ANNUPADA	5122DT215	100	MIXED	AMI	Yes	100%	162	0.06919606	0.057812	0.01138406	16.45%
8836	TPCODL	PARADEEP	KED1	KENDRAPARA	DANPUR	14164	11 KV DANPUR	14164201	FRONT FURNITURE MAKING SHOP	5122DT230	100	MIXED	AMI	Yes	100%	71	0.04797432	0.031078	0.01689632	35.22%
8837	TPCODL	PARADEEP	KED1	KENDRAPARA	DANPUR	14164	11 KV DANPUR	14164201	SUMALADA 3	5122DT336	100	MIXED	AMI	Yes	100%	195	0.0928198	0.070233	0.0225868	24.33%
8838	TPCODL	PARADEEP	KED1	KENDRAPARA	DANPUR	14164	11 KV DANPUR	14164201	SUMALADA 5	5122DT338	100	MIXED	AMI	Yes	100%	121	0.0524917	0.039463	0.0130287	24.82%
8839	TPCODL	PARADEEP	KED1	KENDRAPARA	DANPUR	14164	11 KV DANPUR	14164201	SAHPUR 3	5122DT346	100	MIXED	AMI	Yes	100%	202	0.0871673	0.074522	0.0126453	14.51%
8840	TPCODL	PARADEEP	KED1	KENDRAPARA	DANPUR	14164	11 KV DANPUR	14164201	SAMALADA 9	5125DT450	150	MIXED	AMI	Yes	100%	48	0.05145972	0.025903	0.02555672	49.66%
8841	TPCODL	PARADEEP	KED1	KENDRAPARA	DANPUR	14164	11 KV KHARIDASAHI	14164202	DANPUR 1	5122DT048	100	MIXED	AMI	Yes	100%	63	0.0417436	0.028591	0.0131526	31.51%
8842	TPCODL	PARADEEP	KED1	KENDRAPARA	DANPUR	14164	11 KV KHARIDASAHI	14164202	ANUAPADA	5122DT090	250	MIXED	AMI	Yes	100%	131	0.11657455	0.064906	0.05166855	44.32%
8843	TPCODL	PARADEEP	KED1	KENDRAPARA	DANPUR	14164	11 KV KHARIDASAHI	14164202	BISOKA 1	5122DT098	100	MIXED	AMI	Yes	100%	110	0.04284366	0.032487	0.01035666	24.17%
8844	TPCODL	PARADEEP	KED1	KENDRAPARA	DANPUR	14164	11 KV KHARIDASAHI	14164202	KHATUAPADA 1	5122DT104	100	MIXED	AMI	Yes	100%	65	0.02274436	0.020784	0.00196036	8.62%
8845	TPCODL	PARADEEP	KED1	KENDRAPARA	DANPUR	14164	11 KV CHANDOLA	14164203	NEAR MARKET	5122DT052	100	MIXED	AMI	Yes	0%	63	0.0336604	0.025919	0.0077414	23.00%
8846	TPCODL	PARADEEP	KED1	KENDRAPARA	DANPUR	14164	11 KV CHANDOLA	14164203	CHANDOLA 3	5122DT060	100	MIXED	AMI	Yes	100%	88	0.04554626	0.033586	0.01196026	26.26%
8847	TPCODL	PARADEEP	KED1	KENDRAPARA	DANPUR	14164	11 KV CHANDOLA	14164203	ORGALA 2	5122DT062	100	MIXED	AMI	Yes	100%	116	0.04898128	0.044823	0.00415828	8.49%
8848	TPCODL	PARADEEP	KED1	KENDRAPARA	DANPUR	14164	11 KV CHANDOLA	14164203	ORGALA 10	5122DT083	100	MIXED	AMI	Yes	0%	92	0.07456734	0.033394	0.04117334	55.22%
8849	TPCODL	PARADEEP	KED1	KENDRAPARA	DANPUR	14164	11 KV CHANDOLA	14164203	KANIPADA(MUSLIM SAHI)	5122DT088	200	MIXED	AMI	Yes	100%	215	0.14073916	0.112539	0.02820016	20.04%
8850	TPCODL	PARADEEP	KED1	KENDRAPARA	DANPUR	14164	11 KV ASURESWAR	14164204	BHARI GOL	5122DT245	100	MIXED	AMI	Yes	0%	37	0.0437989	0.016004	0.0277949	63.46%
8851	TPCODL	PARADEEP	KED1	KENDRAPARA	DANPUR	14164	11 KV ASURESWAR	14164204	DABOL	5122DT246	100	MIXED	AMI	Yes	100%	62	0.026602	0.021093	0.005509	20.71%
8852	TPCODL	PARADEEP	KED1	KENDRAPARA	DUHURIA	14197	11 KV DUHURIA	14197201	DUHURIA CHAKA	5122DT247	500	MIXED	AMI	Yes	100%	177	0.12364416	0.087951	0.03569316	28.87%
8853	TPCODL	PARADEEP	KED1	KENDRAPARA	DUHURIA	14197	11 KV LAW COLLEGE	14197202	LAW COLLEGE CHHAK 1	5122DT127	100	MIXED	AMI	Yes	67%	21	0.05243358	0.014693	0.03774058	71.98%
8854	TPCODL	PARADEEP	KED1	KENDRAPARA	ERAKANA (GOKUNA	14310	11 KV LAXMINARAYANPU	14310201	ETUKURA	3511DT263	100	MIXED	AMI	Yes	100%	99	0.0441623	0.025059	0.0191033	43.26%
8855	TPCODL	PARADEEP	KED1	KENDRAPARA	GOGUA	14161	11 KV DOBANDHA	14161205	SOBADA	5135DT059	100	MIXED	AMI	Yes	100%	113	0.04732006	0.041026	0.00629406	13.30%
8856	TPCODL	PARADEEP	KED1	KENDRAPARA	INDUPUR	14157	11 KV INDUPUR	14157201	INDUPUR TELI SAHI	5123DT045	63	MIXED	AMI	Yes	100%	75	0.03393652	0.031129	0.00280752	8.27%
8857	TPCODL	PARADEEP	KED1	KENDRAPARA	INDUPUR	14157	11 KV INDUPUR	14157201	BADHEI SAHI	5123DT046	100	MIXED	AMI	Yes	100%	114	0.05681958	0.039303	0.01751658	30.83%
8858	TPCODL	PARADEEP	KED1	KENDRAPARA	INDUPUR	14157	11 KV DHUMAT	14157202	RI OFFICE	5123DT067	100	MIXED	AMI	Yes	67%	133	0.03910308	0.03634945	0.00275363	7.04%
8859	TPCODL	PARADEEP	KED1	KENDRAPARA	INDUPUR	14157	11 KV DHUMAT	14157202	GALA GANDA	5123DT071	100	MIXED	AMI	Yes	0%	63	0.04010576	0.017933	0.02217276	55.29%
8860	TPCODL	PARADEEP	KED1	KENDRAPARA	INDUPUR	14157	11 KV DHUMAT	14157202	GANDA SAHI	5123DT091	100	MIXED	AMI	Yes	100%	84	0.04438758	0.024984	0.01940358	43.71%
8861	TPCODL	PARADEEP	KED1	KENDRAPARA	INDUPUR	14157	11 KV DHUMAT	14157202	MAHRANA SAHI	5123DT092	100	MIXED	AMI	Yes	0%	67	0.07504286	0.020105	0.05493786	73.21%
8862	TPCODL	PARADEEP	KED1	KENDRAPARA	INDUPUR	14157	11 KV DHUMAT	14157202	JAYAKRUSHNAPUR 1	5123DT098	100	MIXED	AMI	Yes	67%	90	0.03219926	0.023927	0.00827226	25.69%
8863	TPCODL	PARADEEP	KED1	KENDRAPARA	INDUPUR	14157	11 KV DHUMAT	14157202	CHARIGAN PUJA PAADIA	5123DT101	100	MIXED	AMI	Yes	100%	120	0.05500726	0.034893	0.02011426	36.57%
8864	TPCODL	PARADEEP	KED1	KENDRAPARA	INDUPUR	14157	11 KV NIKIREI	14157203	CHHARAPADA BAURI SAHI	5123DT109	63	MIXED	AMI	Yes	0%	45	0.0125828	0.011586	0.0009968	7.92%
8865	TPCODL	PARADEEP	KED1	KENDRAPARA	INDUPUR	14157	11 KV NIKIREI	14157203	NAYAK SAHI	5123DT152	100	MIXED	AMI	Yes	0%	40	0.02757962	0.0117058	0.01587382	57.56%
8866	TPCODL	PARADEEP	KED1	KENDRAPARA	INDUPUR	14157	11 KV NIKIREI	14157203	GHANTAPADA	5123DT154	100	MIXED	AMI	Yes	100%	173	0.06608058	0.039862	0.02621858	39.68%
8867	TPCODL	PARADEEP	KED1	KENDRAPARA	INDUPUR	14157	11 KV NIKIREI	14157203	NIKIREI BAZAR 1	5123DT167	100	MIXED	AMI	Yes	100%	102	0.05240502	0.033264	0.01914102	36.53%
8868	TPCODL	PARADEEP	KED1	KENDRAPARA	INDUPUR	14157	11 KV NIKIREI	14157203	KUTARANGA 2	5123DT184	100	MIXED	AMI	Yes	67%	31	0.02594898	0.010462	0.01548698	59.68%
8869	TPCODL	PARADEEP	KED1	KENDRAPARA	INDUPUR	14157	11 KV NIKIREI	14157203	KUTARANGA 3	5123DT185	100	MIXED	AMI	Yes	67%	129	0.0477515	0.03795	0.0098015	20.53%
8870	TPCODL	PARADEEP	KED1	KENDRAPARA	INDUPUR	14157	11 KV NIKIREI	14157203	JAMARA 2	5123DT191	250	MIXED	AMI	Yes	100%	216	0.0663013	0.055828	0.0104733	15.80%
8871	TPCODL	PARADEEP	KED1	KENDRAPARA	INDUPUR	14157	11 KV NIKIREI	14157203	KANTIA 1	5123DT198	100	MIXED	AMI	Yes	33%	99	0.03229216	0.027452	0.00484016	14.99%
8872	TPCODL	PARADEEP	KED1	KENDRAPARA	INDUPUR	14157	11 KV BAIRI	14157204	AHAMATHAPUR	5123DT252	100	MIXED	AMI	Yes	67%	67	0.04368958	0.019715	0.02397458	54.87%
8873	TPCODL	PARADEEP	KED1	KENDRAPARA	JAHARA BARIMUL (I	14350	11 KV Feeder-3 (Bholo)	14350201	KAU BAZAR 1	5122DT299	100	MIXED	AMI	Yes	100%	58	0.03290998	0.019657	0.01325298	40.27%
8874	TPCODL	PARADEEP	KED1	KENDRAPARA	JAHARA BARIMUL (I	14350	11 KV Feeder-3 (Bholo)	14350201	CHHAKANA 5	5122DT309	100	MIXED	AMI	Yes	100%	83	0.04643508	0.027617	0.01881808	40.53%
8875	TPCODL	PARADEEP	KED1	KENDRAPARA	JAHARA BARIMUL (I	14350	11 KV Feeder-3 (Bholo)	14350201	INDALO	5122DT313	100	MIXED	AMI	Yes	100%	43	0.02064764	0.010998	0.00964964	46.73%
8876	TPCODL	PARADEEP	KED1	KENDRAPARA	JAHARA BARIMUL (I	14350	11 KV Feeder-3 (Bholo)	14350201	CHHAKANA 7	5122DT318	100	MIXED	AMI	Yes	100%	201	0.07344328	0.05285401	0.02058927	28.03%
8877	TPCODL	PARADEEP	KED1	KENDRAPARA	JAHARA BARIMUL (I	14350	11 KV Feeder-1 (Jahara B	14350202	NEAR BY BABA AKHANDALAMANI VA	5122DT280	100	MIXED	AMI	Yes	100%	53	0.04058594	0.015532	0.02505394	61.73%
8878	TPCODL	PARADEEP	KED1	KENDRAPARA	KENDRAPARA	14158	11 KV KENDRAPADA TOV	14158201	HUDA HONDIYA 1	5124DT011	100	MIXED	AMI	Yes	67%	73	0.0888178	0.061482	0.0273358	30.78%
8879	TPCODL	PARADEEP	KED1	KENDRAPARA	KENDRAPARA	14158	11 KV KENDRAPADA TOV	14158201	HUDA HONDIYA 2	5124DT012	100	MIXED	AMI	Yes	100%	36	0.07485316	0.068408	0.00644516	8.61%
8880	TPCODL	PARADEEP	KED1	KENDRAPARA	KENDRAPARA	14158	11 KV KENDRAPADA TOV	14158201	GADA MAL CHHAK	5124DT024	500	MIXED	AMI	Yes	0%	237	0.34356952	0.197889	0.14568052	42.40%
8881	TPCODL	PARADEEP	KED1	KENDRAPARA	KENDRAPARA	14158	11 KV KENDRAPADA TOV	14158201	DILARPUR (AMBADI)	5124DT025	500	MIXED	AMI	Yes	0%	276	0.41695096	0.141998	0.27495296	65.94%
8882	TPCODL	PARADEEP	KED1	KENDRAPARA	KENDRAPARA	14158	11 KV KENDRAPADA TOV	14158201	SANJEET SCHOOL	5124DT041	250	MIXED	AMI	Yes	100%	126	0.13636516	0.091053	0.04531216	33.23%
8883	TPCODL	PARADEEP	KED1	KENDRAPARA	KENDRAPARA	14158	11 KV KENDRAPADA TOV	14158201	RANAPARA 1	5124DT049	250	MIXED	AMI	Yes	67%	141	0.12005668	0.080976	0.03908068	32.55%
8884	TPCODL	PARADEEP	KED1	KENDRAPARA	KENDRAPARA	14158	11 KV KENDRAPADA TOV	14158201	RANAPARA 2	5124DT050	100	MIXED	AMI	Yes	0%	75	0.09226572	0.040826	0.05143972	55.75%
8885	TPCODL	PARADEEP	KED1	KENDRAPARA	KENDRAPARA	14158	11 KV KENDRAPADA TOV	14158201	KENDRAPARA PURANA SCHOOL	5124DT056	500	MIXED	AMI	Yes	0%	353	0.35373816	0.216127	0.13761116	38.90%
8886	TPCODL	PARADEEP	KED1	KENDRAPARA	KENDRAPARA	14158	11 KV KENDRAPADA TOV	14158202	BADANAT 2	5124DT088	200	MIXED	AMI	Yes	0%	59	0.12431548	0.064151	0.06016448	48.40%
8887	TPCODL	PARADEEP	KED1	KENDRAPARA	KENDRAPARA	14158	11 KV KENDRAPADA TOV	14158202	BADANAT DHOBA SAHI	5124DT091	250	MIXED	AMI	Yes	100%	57	0.13812864	0.040954	0.09717464	70.35%
8888	TPCODL	PARADEEP	KED1	KENDRAPARA	KENDRAPARA	14158	11 KV KENDRAPADA TOV	14158202	MIRPATNA VOLLY GRAND	5124DT093	100	MIXED	AMI	Yes	0%	112	0.11762514	0.082835	0.03479014	29.58%
8889	TPCODL	PARADEEP	KED1	KENDRAPARA	KENDRAPARA	14158	11 KV KENDRAPADA TOV	14158202	MAHMUDABAD 1	5124DT094	100	MIXED	AMI	Yes	100%	60	0.10795896	0.052487	0.05547196	51.38%
8890	TPCODL	PARADEEP	KED1	KENDRAPARA	KENDRAPARA	14158	11 KV KENDRAPADA TOV	14158202	MADHAVPUR 2	5124DT098	250	MIXED	AMI	Yes	100%	43	0.17955884	0.039859	0.13969984	77.80%
8891	TPCODL	PARADEEP	KED1	KENDRAPARA	KENDRAPARA	14158	11 KV KENDRAPADA TOV	14158202	KENDRA PADA POLICE STATION	5124DT111	150	MIXED	AMI	Yes	100%	46	0.06591216	0.025888	0.04002416	60.72%
8892	TPCODL	PARADEEP	KED1	KENDRAPARA	KENDRAPARA	14158	11 KV THAKURPATANA	14158203	HORTICULTURE OFFICE	5125DT216	100	MIXED	AMI	Yes	0%	36	0.08626534	0.031902	0.05436334	63.02%
8893	TPCODL	PARADEEP	KED1	KENDRAPARA	KENDRAPARA	14158	11 KV THAKURPATANA	14158203	THAKUR PATA NA	5125DT241	100	MIXED	AMI	Yes	0%	164	0.08529224	0.05946	0.02583224	30.29%
8894	TPCODL	PARADEEP	KED1	KENDRAPARA	KENDRAPARA	14158	11 KV THAKURPATANA	14158203	BALIPATANA	5125DT244	100	MIXED	AMI	Yes	67%	137	0.0550237	0.048193	0.0068307	12.41%
8895	TPCODL	PARADEEP	KED1	KENDRAPARA	KENDRAPARA	14158	11 KV THAKURPATANA	14158203	KUSIAPAL 1	5125DT247	100	MIXED	AMI	Yes	100%	145	0.0766607	0.059007	0.0176537	23.03%
8896	TPCODL	PARADEEP	KED1	KENDRAPARA	KENDRAPARA	14158	11 KV THAKURPATANA	14158203	BADA MANGARAJ PUR VILLAGE	5125DT267	100	MIXED	AMI	Yes	0%	55	0.02439048	0.015215	0.00917548	37.62%
8897	TPCODL	PARADEEP	KED1	KENDRAPARA	KENDRAPARA	14158	11 KV THAKURPATANA	14158203	MANIPURA	5125DT273	100	MIXED	AMI	Yes	100%	94	0.0371507	0.031219	0.0059317	15.97%
8898	TPCODL	PARADEEP	KED1	KENDRAPARA	KENDRAPARA	14158	11 KV THAKURPATANA	14158203	BIRANKPUR	5125DT274	100	MIXED	AMI	Yes	0%	98	0.05303376	0.030835	0.02219876	41.86%
8899	TPCODL	PARADEEP	KED1	KENDRAPARA	KENDRAPARA	14158	11 KV THAKURPATANA	14158203	THAKUR PATANA	5125DT309	100	MIXED	AMI	Yes	100%	184	0.10144742	0.078395	0.02305242	22.72%
8900	TPCODL	PARADEEP	KED1	KENDRAPARA	KENDRAPARA	14158	11 KV BHARATPUR-1	14158204	NANKAR VILLAGE	5125DT062	100	MIXED	AMI	Yes	100%	115	0.07420132	0.048529	0.02567232	34.60%
8901	TPCODL	PARADEEP	KED1	KENDRAPARA	KENDRAPARA	14158	11 KV BHARATPUR-1	14158204	BR RESIDENCY	5125DT063	100	MIXED	AMI	Yes	100%	28	0.01865424	0.01387	0.00478424	25.65%
8902	TPCODL	PARADEEP	KED1	KENDRAPARA	KENDRAPARA	14158	11 KV BHARATPUR-1	14158204	SSPUR THAKURANI	5125DT064	100	MIXED	AMI	Yes	33%	105	0.13869508	0.045171	0.09352408	67.43%
8903	TPCODL	PARADEEP	KED1	KENDRAPARA	KENDRAPARA	14158	11 KV BHARATPUR-1	14158204	MAGURAGANDA PATNA	5125DT073	100	MIXED	AMI	Yes	67%	84	0.04058888	0.030658	0.00993088	24.47%
8904	TPCODL	PARADEEP	KED1	KENDRAPARA	KENDRAPARA	14158	11 KV BHARATPUR-1	14158204	KANTIA	5125DT101	100	MIXED	AMI	Yes	33%	43	0.0305258	0.01261	0.0179158	58.69%
8905	TPCODL	PARADEEP	KED1	KENDRAPARA	KENDRAPARA	14158	11 KV BHARATPUR-1	14158204	ARIPADA NEW	5125DT106	100	MIXED	AMI	Yes	100%	196	0.08750804	0.061252	0.02625604	30.00%

Sl. No.	Zone Name	Circle name	Division name	Name of the Sub-division	Name of the Sub-station	Substation Code	Name of the 11 kV Feeder	Feeder Code	Name of the Location where DT situated	DT code	DT Capacity (kVA)	Predominant consumer type of DT (Domestic/Industrial/Agriculture/Mixed)	Type of metering AMR/AMI/ Communicable/Conventional metered/Unmetered	Status of Meter-whether Functional (Yes/No)	% of data received automatically (if AMR/AMI)	No. of Connected Consumers	Input Energy (MU) (A)	Billed Energy (MU) (B)	Loss (MU) (A-B)	% DT Loss (A-B)/A
8906	TPCODL	PARADEEP	KED1	KENDRAPARA	KENDRAPARA	14158	11 KV BHARATPUR-1	14158204	NARILO HANUMAN TEMPLE	5223DT004	100	MIXED	AMI	Yes	100%	37	0.02199854	0.018816	0.00318254	14.47%
8907	TPCODL	PARADEEP	KED1	KENDRAPARA	KENDRAPARA	14158	11 KV TINIMUHANI	14158205	KAJALA MUNDASAHI	5124DT121	100	MIXED	AMI	Yes	0%	129	0.0667704	0.066485	0.0002854	0.43%
8908	TPCODL	PARADEEP	KED1	KENDRAPARA	KENDRAPARA	14158	11 KV TINIMUHANI	14158205	GOLDEN VILLA	5124DT123	250	MIXED	AMI	Yes	100%	104	0.12031208	0.059844	0.06046808	50.26%
8909	TPCODL	PARADEEP	KED1	KENDRAPARA	KENDRAPARA	14158	11 KV TINIMUHANI	14158205	KENDRAPARA AUTONOMOUS COLLE	5124DT124	250	MIXED	AMI	Yes	0%	33	0.0690732	0.038436	0.0306372	44.35%
8910	TPCODL	PARADEEP	KED1	KENDRAPARA	KENDRAPARA	14158	11 KV TINIMUHANI	14158205	COLLEGE CHHAKA	5124DT128	500	MIXED	AMI	Yes	0%	301	0.30259584	0.296403	0.00619284	2.05%
8911	TPCODL	PARADEEP	KED1	KENDRAPARA	KENDRAPARA	14158	11 KV TINIMUHANI	14158205	GULNAGAR 1	5124DT141	100	MIXED	AMI	Yes	100%	210	0.12398298	0.113999	0.00998398	8.05%
8912	TPCODL	PARADEEP	KED1	KENDRAPARA	KENDRAPARA	14158	11 KV TINIMUHANI	14158205	KANHA VILLA	5124DT149	100	MIXED	AMI	Yes	100%	32	0.04414078	0.025051	0.01908978	43.25%
8913	TPCODL	PARADEEP	KED1	KENDRAPARA	KENDRAPARA	14158	11 KV TINIMUHANI	14158205	BAULA BIHARA	5124DT150	250	MIXED	AMI	Yes	100%	161	0.1783638	0.128986	0.0493778	27.68%
8914	TPCODL	PARADEEP	KED1	KENDRAPARA	KENDRAPARA	14158	11 KV TINIMUHANI	14158205	KRISHNA VILLA	5124DT152	100	MIXED	AMI	Yes	100%	20	0.0315448	0.023253	0.0082918	26.29%
8915	TPCODL	PARADEEP	KED1	KENDRAPARA	KENDRAPARA	14158	11 KV TINIMUHANI	14158205	GARAPUR MUSLIM SAHI 1	5124DT177	250	MIXED	AMI	Yes	67%	195	0.19996836	0.103603	0.09636536	48.19%
8916	TPCODL	PARADEEP	KED1	KENDRAPARA	KENDRAPARA	14158	11 KV TINIMUHANI	14158205	DAKBANGALA	5124DT188	250	MIXED	AMI	Yes	0%	251	0.20622172	0.202901	0.00332072	1.61%
8917	TPCODL	PARADEEP	KED1	KENDRAPARA	KHAMAR KESHPUR	14353	11 KV KORO	14353201	TELIPATNA	5125DT353	100	MIXED	AMI	Yes	67%	54	0.11309862	0.027364	0.08573462	75.81%
8918	TPCODL	PARADEEP	KED1	KENDRAPARA	KHAMAR KESHPUR	14353	11 KV KORO	14353201	VERSHING	5125DT357	250	MIXED	AMI	Yes	67%	280	0.22723404	0.117427	0.10980704	48.32%
8919	TPCODL	PARADEEP	KED1	KENDRAPARA	KHAMAR KESHPUR	14353	11 KV BARO	14353202	TRILOCHANAPUR VILLAGE	5125DT369	100	MIXED	AMI	Yes	67%	130	0.06160104	0.043229	0.01837204	29.82%
8920	TPCODL	PARADEEP	KED1	KENDRAPARA	KHAMAR KESHPUR	14353	11 KV JAJANGA	14353203	TARANDA VILLAGE	5125DT188	100	MIXED	AMI	Yes	100%	162	0.06342104	0.057047	0.00637404	10.05%
8921	TPCODL	PARADEEP	KED1	KENDRAPARA	KHAMAR KESHPUR	14353	11 KV JAJANGA	14353203	SP OFFICE 1	5125DT200	100	MIXED	AMI	Yes	100%	8	0.02966204	0.009053	0.02060904	69.48%
8922	TPCODL	PARADEEP	KED1	KENDRAPARA	PATTAMUNDAI	14153	11 KV BALIPATANA & SA	14153204	NEAR GOJABAYANI MAA TEMPLE	5133DT025	100	MIXED	AMI	Yes	100%	175	0.10086406	0.075856	0.02500806	24.79%
8923	TPCODL	PARADEEP	KED1	KENDRAPARA	PATTAMUNDAI	14153	11 KV BELTAL	14153206	INDIAN OIL PETROL PUMP 2	5133DT055	100	MIXED	AMI	Yes	0%	75	0.0625881	0.045553	0.0170351	27.22%
8924	TPCODL	PARADEEP	KED1	KENDRAPARA	RAJANAGAR	14160	11 KV RAJANAGAR	14160201	BRAMAHNASAHI	5142DT250	100	MIXED	AMI	Yes	0%	128	0.04449166	0.021462	0.02302966	51.76%
8925	TPCODL	PARADEEP	KED1	KENDRAPARA	RAJANAGAR	14160	11 KV RAJANAGAR	14160201	GOVERDHANPUR	5142DT263	100	MIXED	AMI	Yes	33%	124	0.0334753	0.019858	0.0136173	40.68%
8926	TPCODL	PARADEEP	KED1	PATTAMUNDAI	PATTAMUNDAI	17033	GOGUA	17033404	GOGUA 1	5135DT174	100	MIXED	AMI	Yes	0%	104	0.06224426	0.042898	0.01934626	31.08%
8927	TPCODL	PARADEEP	KED1	PATTAMUNDAI	PATTAMUNDAI	17033	GOGUA	17033404	GOGUA 2	5135DT175	100	MIXED	AMI	Yes	100%	36	0.0692268	0.022887	0.0463398	66.94%
8928	TPCODL	PARADEEP	KED1	PATTAMUNDAI	ADHAJORI	14159	11 KV KORIAPALA	14159201	MALIPUR 1	5133DT341	100	MIXED	AMI	Yes	0%	142	0.07120202	0.044303	0.02689902	37.78%
8929	TPCODL	PARADEEP	KED1	PATTAMUNDAI	ADHAJORI	14159	11 KV KORIAPALA	14159201	ADHAJORI HOSPITAL1	5134DT078	100	MIXED	AMI	Yes	33%	133	0.03719758	0.030776	0.00642158	17.26%
8930	TPCODL	PARADEEP	KED1	PATTAMUNDAI	ADHAJORI	14159	11 KV KORIAPALA	14159201	KAJALABANDHA 1	5134DT092	100	MIXED	AMI	Yes	67%	184	0.06405214	0.04693	0.01712214	26.73%
8931	TPCODL	PARADEEP	KED1	PATTAMUNDAI	ADHAJORI	14159	11 KV KORIAPALA	14159201	BADAPAL	5134DT122	100	MIXED	AMI	Yes	67%	143	0.03773968	0.035014	0.00272568	7.22%
8932	TPCODL	PARADEEP	KED1	PATTAMUNDAI	ADHAJORI	14159	11 KV CHANDAN NAGAR	14159202	SANSARFAL SCHOOL	5134DT134	100	MIXED	AMI	Yes	67%	129	0.05772744	0.037144	0.02058344	35.66%
8933	TPCODL	PARADEEP	KED1	PATTAMUNDAI	ADHAJORI	14159	11 KV CHANDAN NAGAR	14159202	GOPTRIA	5134DT148	100	MIXED	AMI	Yes	67%	100	0.04253608	0.031132	0.01140408	26.81%
8934	TPCODL	PARADEEP	KED1	PATTAMUNDAI	ADHAJORI	14159	11 KV CHANDAN NAGAR	14159202	TELIPATANA	5134DT152	100	MIXED	AMI	Yes	33%	74	0.0311601	0.020034	0.0111261	35.71%
8935	TPCODL	PARADEEP	KED1	PATTAMUNDAI	ADHAJORI	14159	11 KV CHANDAN NAGAR	14159202	CHANDAN NAGAR 1	5134DT166	100	MIXED	AMI	Yes	0%	99	0.05084092	0.028775	0.02206592	43.40%
8936	TPCODL	PARADEEP	KED1	PATTAMUNDAI	ADHAJORI	14159	11 KV CHANDAN NAGAR	14159202	BHUNALO 1	5134DT168	100	MIXED	AMI	Yes	0%	122	0.04778196	0.02983	0.01795196	37.57%
8937	TPCODL	PARADEEP	KED1	PATTAMUNDAI	ADHAJORI	14159	11 KV CHANDAN NAGAR	14159202	MULAGAIN	5134DT178	100	MIXED	AMI	Yes	67%	108	0.06096666	0.02988	0.03108666	50.99%
8938	TPCODL	PARADEEP	KED1	PATTAMUNDAI	ADHAJORI	14159	11 KV CHANDAN NAGAR	14159202	BALIAN JODI	5134DT200	100	MIXED	AMI	Yes	67%	140	0.0526926	0.04044	0.0122526	23.25%
8939	TPCODL	PARADEEP	KED1	PATTAMUNDAI	ADHAJORI	14159	11 KV CHANDAN NAGAR	14159202	BALIA JODI 2	5134DT202	100	MIXED	AMI	Yes	0%	115	0.05459734	0.023487	0.03111034	56.98%
8940	TPCODL	PARADEEP	KED1	PATTAMUNDAI	ADHAJORI	14159	11 KV CHANDAN NAGAR	14159202	BAULANGA	5134DT206	100	MIXED	AMI	Yes	33%	194	0.06261042	0.042532	0.02007842	32.07%
8941	TPCODL	PARADEEP	KED1	PATTAMUNDAI	ADHAJORI	14159	11 KV DAMARPUR	14159203	SHRIRAMPUR 3	5134DT241	100	MIXED	AMI	Yes	67%	100	0.04488688	0.010719	0.03416788	76.12%
8942	TPCODL	PARADEEP	KED1	PATTAMUNDAI	ADHAJORI	14159	11 KV DAMARPUR	14159203	SHRIRAMPUR	5134DT245	100	MIXED	AMI	Yes	67%	101	0.04742338	0.022044	0.02537938	53.52%
8943	TPCODL	PARADEEP	KED1	PATTAMUNDAI	ADHAJORI	14159	11 KV DAMARPUR	14159203	DAMARPUR (SASAN)	5134DT255	100	MIXED	AMI	Yes	67%	112	0.05727328	0.037939	0.01933428	33.76%
8944	TPCODL	PARADEEP	KED1	PATTAMUNDAI	ADHAJORI	14159	11 KV DAMARPUR	14159203	PALAPATANA	5134DT263	100	MIXED	AMI	Yes	67%	175	0.05786338	0.045607	0.01225638	21.18%
8945	TPCODL	PARADEEP	KED1	PATTAMUNDAI	ADHAJORI	14159	11 KV DAMARPUR	14159203	JENA PATNA	5134DT267	100	MIXED	AMI	Yes	67%	114	0.0401974	0.02947367	0.01072373	26.68%
8946	TPCODL	PARADEEP	KED1	PATTAMUNDAI	ADHAJORI	14159	11 KV DAMARPUR	14159203	DAMARPUR 15	5134DT279	250	MIXED	AMI	Yes	67%	247	0.11373172	0.07172576	0.04200596	36.93%
8947	TPCODL	PARADEEP	KED1	PATTAMUNDAI	ADHAJORI	14159	11 KV DAMARPUR	14159203	SHRIRAMPUR 5	5134DT286	100	MIXED	AMI	Yes	0%	85	0.04362108	0.024968	0.01865308	42.76%
8948	TPCODL	PARADEEP	KED1	PATTAMUNDAI	AUL	14154	11 KV AUL	14154202	ECHHAPUR 2	5111DT256	100	MIXED	AMI	Yes	33%	54	0.03145022	0.017661	0.01378922	43.84%
8949	TPCODL	PARADEEP	KED1	PATTAMUNDAI	AUL	14154	11 KV BHUINPUR	14154204	NEAR POUND(BANDHASAHI)	5112DT271	100	MIXED	AMI	Yes	100%	85	0.02885722	0.025527	0.00333022	11.54%
8950	TPCODL	PARADEEP	KED1	PATTAMUNDAI	AUL	14154	11 KV MENDHAPUR	14154205	NUAGOAN	5111DT066	100	MIXED	AMI	Yes	67%	55	0.01915454	0.018615	0.00053954	2.82%
8951	TPCODL	PARADEEP	KED1	PATTAMUNDAI	AUL	14154	11 KV MENDHAPUR	14154205	KALADIA 2	5132DT008	100	MIXED	AMI	Yes	0%	124	0.06084706	0.038126	0.02272106	37.34%
8952	TPCODL	PARADEEP	KED1	PATTAMUNDAI	CHAUDAKULATA OD	14347	11 KV CHOUDAKULAT	14347202	DADHIBAMANAJEW TEMPLE 1	5135DT096	100	MIXED	AMI	Yes	0%	130	0.11781094	0.057875	0.05993594	50.87%
8953	TPCODL	PARADEEP	KED1	PATTAMUNDAI	CHAUDAKULATA OD	14347	11 KV CHOUDAKULAT	14347202	MUSADIHA 1	5135DT106	100	MIXED	AMI	Yes	100%	74	0.02875354	0.024772	0.00398154	13.85%
8954	TPCODL	PARADEEP	KED1	PATTAMUNDAI	CHOKADA ODSSP	14351	11 KV KANSAR	14351201	LOKONATHPUR 6	5126DT126	100	MIXED	AMI	Yes	33%	72	0.0294934	0.018653	0.0108404	36.76%
8955	TPCODL	PARADEEP	KED1	PATTAMUNDAI	DANDISAHI	14162	11 KV DANDISAHI	14162201	TARIDAPAL	5131DT071	100	MIXED	AMI	Yes	100%	99	0.02682446	0.026496	0.00032846	1.22%
8956	TPCODL	PARADEEP	KED1	PATTAMUNDAI	DANDISAHI	14162	11 KV DANDISAHI	14162201	ALAPUA DIHA	5131DT096	100	MIXED	AMI	Yes	67%	114	0.03265148	0.029138	0.00351348	10.76%
8957	TPCODL	PARADEEP	KED1	PATTAMUNDAI	DANDISAHI	14162	11 KV DANDISAHI	14162201	PENTHAPADA 3	5131DT098	100	MIXED	AMI	Yes	67%	110	0.0421089	0.034721	0.0073879	17.54%
8958	TPCODL	PARADEEP	KED1	PATTAMUNDAI	DANDISAHI	14162	11 KV DANDISAHI	14162201	TARADIPAL 24	5131DT114	100	MIXED	AMI	Yes	0%	138	0.07579994	0.042303	0.03349694	44.19%
8959	TPCODL	PARADEEP	KED1	PATTAMUNDAI	DANDISAHI	14162	11 KV DANDISAHI	14162201	GHAGARADIA 1	5131DT122	100	MIXED	AMI	Yes	67%	90	0.02680374	0.022117	0.00468674	17.49%
8960	TPCODL	PARADEEP	KED1	PATTAMUNDAI	DANDISAHI	14162	11 KV DANDISAHI	14162201	GOPALPUR	5131DT130	100	MIXED	AMI	Yes	67%	142	0.03564116	0.031339	0.00430216	12.07%
8961	TPCODL	PARADEEP	KED1	PATTAMUNDAI	DANDISAHI	14162	11 KV BERHAMPUR-1	14162202	ANDHARA DANDI UPARA	5131DT008	100	MIXED	AMI	Yes	67%	85	0.05154614	0.03148	0.02006614	38.93%
8962	TPCODL	PARADEEP	KED1	PATTAMUNDAI	DANDISAHI	14162	11 KV BERHAMPUR-1	14162202	ANDHARA PAJUMEDICAL HARIJAN SA	5131DT011	100	MIXED	AMI	Yes	0%	106	0.08466554	0.023147	0.06151854	72.66%
8963	TPCODL	PARADEEP	KED1	PATTAMUNDAI	DANDISAHI	14162	11 KV BERHAMPUR-1	14162202	ANDHARA MAJHI SAHI	5131DT014	100	MIXED	AMI	Yes	0%	148	0.06528552	0.042349	0.02293652	35.13%
8964	TPCODL	PARADEEP	KED1	PATTAMUNDAI	DANDISAHI	14162	11 KV BERHAMPUR-1	14162202	NUADIHA	5131DT043	100	MIXED	AMI	Yes	67%	133	0.05487074	0.039559	0.01531174	27.91%
8965	TPCODL	PARADEEP	KED1	PATTAMUNDAI	DANDISAHI	14162	11 KV BERHAMPUR-1	14162202	JAGANNATHPUR	5131DT048	100	MIXED	AMI	Yes	0%	72	0.03488202	0.017958	0.01692402	48.52%
8966	TPCODL	PARADEEP	KED1	PATTAMUNDAI	DANDISAHI	14162	11 KV PALIMI	14162203	KUSUMI GUNIDIHA	5131DT153	100	MIXED	AMI	Yes	0%	99	0.06485306	0.024382	0.04047106	62.40%
8967	TPCODL	PARADEEP	KED1	PATTAMUNDAI	DANDISAHI	14162	11 KV PALIMI	14162203	ERADANGA	5131DT165	100	MIXED	AMI	Yes	67%	45	0.01888718	0.012125	0.00676218	35.80%
8968	TPCODL	PARADEEP	KED1	PATTAMUNDAI	DANDISAHI	14162	11 KV PALIMI	14162203	PALIMI	5131DT175	250	MIXED	AMI	Yes	0%	176	0.08181312	0.074632	0.00718112	8.78%
8969	TPCODL	PARADEEP	KED1	PATTAMUNDAI	DANDISAHI	14162	11 KV PALIMI	14162203	MOHANPUR 3	5131DT186	100	MIXED	AMI	Yes	67%	135	0.03836638	0.03003	0.00833638	21.73%
8970	TPCODL	PARADEEP	KED1	PATTAMUNDAI	DANPUR	14164	11 KV CHANDOLA	14164203	KURUJANAGA	3511DT267	63	MIXED	AMI	Yes	100%	47	0.02632589	0.015806	0.01051989	39.96%
8971	TPCODL	PARADEEP	KED1	PATTAMUNDAI	DUHURIA	14197	11 KV LAW COLLEGE	14197202	JAMADHAR 4	5122DT144	250	MIXED	AMI	Yes	100%	118	0.10015145	0.066161	0.03399045	33.94%
8972	TPCODL	PARADEEP	KED1	PATTAMUNDAI	GOGUA	14161	11 KV NAPANGA	14161202	PANDU HOTA	5135DT124	100	MIXED	AMI	Yes	100%	58	0.01780816	0.014849	0.00295916	16.62%
8973	TPCODL	PARADEEP	KED1	PATTAMUNDAI	GOGUA	14161	11 KV NAPANGA	14161202	GANDUKULA 2	5135DT136	250	MIXED	AMI	Yes	100%	170	0.06200412	0.050291	0.01171312	18.89%
8974	TPCODL	PARADEEP	KED1	PATTAMUNDAI	GOGUA	14161	11 KV NAPANGA	14161202	MAJHI PANTURI	5135DT143	100	MIXED	AMI	Yes	100%	136	0.03347602	0.02964	0.00383602	11.46%
8975	TPCODL	PARADEEP	KED1	PATTAMUNDAI	INDUPUR	14157	11 KV BAIRI	14157204	KAMPAGARH 1	5123DT261	100	MIXED	AMI	Yes	33%	146	0.0853144	0.056517	0.0287974	33.75%
8976	TPCODL	PARADEEP	KED1	PATTAMUNDAI	KHAMAR KESHPUR	14353	11 KV KORO	14353201	PALAKANA	5125DT330	100	MIXED	AMI	Yes	67%	138	0.05522746	0.028608	0.02661946	48.20%
8977	TPCODL	PARADEEP	KED1	PATTAMUNDAI	KHAMAR KESHPUR	14353	11 KV KORO	14353201	AMBAPADA	5135DT161	100	MIXED	AMI	Yes	67%	79	0.06575914	0.021514	0.04424514	67.28%
8978	TPCODL	PARADEEP	KED1	PATTAMUNDAI	PATRAPUR	14156	11 KV BATIPADA	14156201	PATRAPUR-1	5132DT012	100	MIXED	AMI	Yes	67%	123	0.08817656	0.030516	0.05766056	65.39%

Sl. No.	Zone Name	Circle name	Division name	Name of the Sub-division	Name of the Sub-station	Substation Code	Name of the 11 kV Feeder	Feeder Code	Name of the Location where DT situated	DT code	DT Capacity (kVA)	Predominant consumer type of DT (Domestic/Industrial/Agriculture/Mixed)	Type of metering AMR/AMI/ Communicable/Conventional metered/Unmetered	Status of Meter- whether Functional (Yes/No)	% of data received automatically (if AMR/AMI)	No. of Connected Consumers	Input Energy (MU) (A)	Billed Energy (MU) (B)	Loss (MU) (A-B)	% DT Loss (A-B)/A
8979	TPCODL	PARADEEP	KED1	PATTAMUNDAI	PATRAPUR	14156	11 KV BATIPADA	14156201	PATRAPUR 15 LI DEAD	5132DT025	100	MIXED	AMI	Yes	67%	176	0.05493734	0.046511	0.00842634	15.34%
8980	TPCODL	PARADEEP	KED1	PATTAMUNDAI	PATRAPUR	14156	11 KV BATIPADA	14156201	SORI SADA	5132DT029	100	MIXED	AMI	Yes	67%	185	0.06128078	0.052488	0.00879278	14.35%
8981	TPCODL	PARADEEP	KED1	PATTAMUNDAI	PATRAPUR	14156	11 KV BATIPADA	14156201	ANGARAKHA 1	5132DT045	100	MIXED	AMI	Yes	67%	115	0.04320808	0.03353131	0.00967677	22.40%
8982	TPCODL	PARADEEP	KED1	PATTAMUNDAI	PATRAPUR	14156	11 KV BATIPADA	14156201	MOHANPUR	5132DT048	100	MIXED	AMI	Yes	67%	123	0.04148516	0.027184	0.01430116	34.47%
8983	TPCODL	PARADEEP	KED1	PATTAMUNDAI	PATRAPUR	14156	11 KV BATIPADA	14156201	BATIPADA 1	5132DT053	100	MIXED	AMI	Yes	67%	123	0.04618998	0.031715	0.01447498	31.34%
8984	TPCODL	PARADEEP	KED1	PATTAMUNDAI	PATRAPUR	14156	11 KV BATIPADA	14156201	BUDHA BABA MATHA, BATIPADA 3	5132DT060	100	MIXED	AMI	Yes	67%	69	0.02477978	0.017706	0.00707378	28.55%
8985	TPCODL	PARADEEP	KED1	PATTAMUNDAI	PATRAPUR	14156	11 KV BATIPADA	14156201	SIDHABALI 5	5132DT073	100	MIXED	AMI	Yes	67%	148	0.05327152	0.0348041	0.01846742	34.67%
8986	TPCODL	PARADEEP	KED1	PATTAMUNDAI	PATRAPUR	14156	11 KV BATIPADA	14156201	NEAR TARINI TEMPLE NUAPARA 1	5132DT074	250	MIXED	AMI	Yes	0%	137	0.0677818	0.035197	0.0325848	48.07%
8987	TPCODL	PARADEEP	KED1	PATTAMUNDAI	PATRAPUR	14156	11 KV PATRAPUR DASIPU	14156202	BELHANI VILLAGE	5132DT086	250	MIXED	AMI	Yes	0%	177	0.06703452	0.051313	0.01572152	23.45%
8988	TPCODL	PARADEEP	KED1	PATTAMUNDAI	PATRAPUR	14156	11 KV PATRAPUR DASIPU	14156202	DALARTI BAZAR GOPAL JEW PATANA	5132DT108	100	MIXED	AMI	Yes	0%	186	0.11829668	0.059387	0.05890968	49.80%
8989	TPCODL	PARADEEP	KED1	PATTAMUNDAI	PATRAPUR	14156	11 KV PATRAPUR DASIPU	14156202	RAMBHILA NEAR MANIKPATANA ROA	5132DT118	100	MIXED	AMI	Yes	67%	77	0.03906382	0.021017	0.01804682	46.20%
8990	TPCODL	PARADEEP	KED1	PATTAMUNDAI	PATRAPUR	14156	11 KV PATRAPUR DASIPU	14156202	DASIPUR 2	5132DT133	100	MIXED	AMI	Yes	0%	80	0.03138688	0.025948	0.00543888	17.33%
8991	TPCODL	PARADEEP	KED1	PATTAMUNDAI	PATRAPUR	14156	11 KV PATRAPUR DASIPU	14156202	KALADIA	5132DT134	100	MIXED	AMI	Yes	33%	90	0.0485119	0.028933	0.0195789	40.36%
8992	TPCODL	PARADEEP	KED1	PATTAMUNDAI	PATRAPUR	14156	11 KV PATRAPUR DASIPU	14156202	MANIKAPATANA 1	5132DT137	100	MIXED	AMI	Yes	67%	82	0.03623948	0.019334	0.01690548	46.65%
8993	TPCODL	PARADEEP	KED1	PATTAMUNDAI	PATRAPUR	14156	11 KV PATRAPUR DASIPU	14156202	NEAR HANUMAN TEMPLE TARIPATAI	5132DT150	100	MIXED	AMI	Yes	67%	199	0.07262894	0.070022	0.00260694	3.59%
8994	TPCODL	PARADEEP	KED1	PATTAMUNDAI	PATRAPUR	14156	11 KV PATRAPUR DASIPU	14156202	NARENDRAPUR PANDARE SILA	5132DT151	100	MIXED	AMI	Yes	67%	228	0.09051154	0.067469	0.02304254	25.46%
8995	TPCODL	PARADEEP	KED1	PATTAMUNDAI	PATRAPUR	14156	11 KV PATRAPUR DASIPU	14156202	NARENDRAPUR 2	5132DT155	100	MIXED	AMI	Yes	67%	99	0.05307848	0.020992	0.03208648	60.45%
8996	TPCODL	PARADEEP	KED1	PATTAMUNDAI	PATRAPUR	14156	11 KV PATRAPUR DASIPU	14156202	NARENDRAPUR 1	5132DT156	100	MIXED	AMI	Yes	67%	94	0.04012028	0.025404	0.01471628	36.68%
8997	TPCODL	PARADEEP	KED1	PATTAMUNDAI	PATTAMUNDAI	14153	11 KV JHARIA	14153201	DHAKINIDIA	5133DT098	250	MIXED	AMI	Yes	100%	341	0.1703742	0.16717	0.0032042	1.88%
8998	TPCODL	PARADEEP	KED1	PATTAMUNDAI	PATTAMUNDAI	14153	11 KV JHARIA	14153201	SHIV MANDIR	5133DT102	100	MIXED	AMI	Yes	100%	207	0.18818106	0.147154	0.04102706	21.80%
8999	TPCODL	PARADEEP	KED1	PATTAMUNDAI	PATTAMUNDAI	14153	11 KV JHARIA	14153201	POKHARIA CHHAK	5133DT110	250	MIXED	AMI	Yes	0%	97	0.14285392	0.07817	0.06468392	45.28%
9000	TPCODL	PARADEEP	KED1	PATTAMUNDAI	PATTAMUNDAI	14153	11 KV JHARIA	14153201	BAKTARPUR	5133DT117	100	MIXED	AMI	Yes	100%	9	0.03864642	0.014704	0.02394242	61.95%
9001	TPCODL	PARADEEP	KED1	PATTAMUNDAI	PATTAMUNDAI	14153	11 KV JHARIA	14153201	SHIV TEMPLE AGADA	5133DT120	100	MIXED	AMI	Yes	100%	183	0.09808522	0.076545	0.02154022	21.96%
9002	TPCODL	PARADEEP	KED1	PATTAMUNDAI	PATTAMUNDAI	14153	11 KV JHARIA	14153201	PACHHAPADA	5133DT136	100	MIXED	AMI	Yes	100%	156	0.06491672	0.045596	0.01932072	29.76%
9003	TPCODL	PARADEEP	KED1	PATTAMUNDAI	PATTAMUNDAI	14153	11 KV JHARIA	14153201	AMBER	5133DT138	100	MIXED	AMI	Yes	100%	74	0.03626104	0.025197	0.01106404	30.51%
9004	TPCODL	PARADEEP	KED1	PATTAMUNDAI	PATTAMUNDAI	14153	11 KV JHARIA	14153201	OSANGARA WATAER TANK	5133DT153	100	MIXED	AMI	Yes	0%	204	0.0646253	0.053844	0.0107813	16.68%
9005	TPCODL	PARADEEP	KED1	PATTAMUNDAI	PATTAMUNDAI	14153	11 KV JHARIA	14153201	PRAHARAJPUR	5133DT159	250	MIXED	AMI	Yes	100%	99	0.108639	0.106758	0.001881	1.73%
9006	TPCODL	PARADEEP	KED1	PATTAMUNDAI	PATTAMUNDAI	14153	11 KV JHARIA	14153201	DAKHINADIA SMART PARKN	5133DT172	100	MIXED	AMI	Yes	100%	49	0.03079786	0.020197	0.01060086	34.42%
9007	TPCODL	PARADEEP	KED1	PATTAMUNDAI	PATTAMUNDAI	14153	11 KV JHARIA	14153201	ADHAKHANDA MATHASAHI	5133DT177	100	MIXED	AMI	Yes	100%	143	0.05397358	0.034351	0.01962258	36.36%
9008	TPCODL	PARADEEP	KED1	PATTAMUNDAI	PATTAMUNDAI	14153	11 KV JHARIA	14153201	ALAVA 1(BADSAHI)	5133DT213	100	MIXED	AMI	Yes	100%	69	0.0428214	0.02824	0.0145814	34.05%
9009	TPCODL	PARADEEP	KED1	PATTAMUNDAI	PATTAMUNDAI	14153	11 KV JHARIA	14153201	ALAVA 3	5133DT215	100	MIXED	AMI	Yes	0%	137	0.05862012	0.039773	0.01884712	32.15%
9010	TPCODL	PARADEEP	KED1	PATTAMUNDAI	PATTAMUNDAI	14153	11 KV PATTAMUNDAI BA	14153202	RAM MANDIR	5133DT075	100	MIXED	AMI	Yes	100%	93	0.03979368	0.023054	0.01673968	42.07%
9011	TPCODL	PARADEEP	KED1	PATTAMUNDAI	PATTAMUNDAI	14153	11 KV PATTAMUNDAI BA	14153202	M. N. HIGH SCHOOL STADIUM 1	5133DT092	250	MIXED	AMI	Yes	0%	114	0.24817792	0.10664	0.14153792	57.03%
9012	TPCODL	PARADEEP	KED1	PATTAMUNDAI	PATTAMUNDAI	14153	11 KV BALIPATANA & SA	14153204	NEAR CANNEL BALIPATANA	5133DT021	100	MIXED	AMI	Yes	100%	40	0.05126684	0.015537	0.03572984	69.69%
9013	TPCODL	PARADEEP	KED1	PATTAMUNDAI	PATTAMUNDAI	14153	11 KV BALIPATANA & SA	14153204	NEAR RAM MANDIR	5133DT035	63	MIXED	AMI	Yes	67%	54	0.03916412	0.021018	0.01814612	46.33%
9014	TPCODL	PARADEEP	KED1	PATTAMUNDAI	PATTAMUNDAI	14153	11 KV BALIPATANA & SA	14153204	NEAR SAI TEMPLE BACHHARA	5133DT040	250	MIXED	AMI	Yes	67%	227	0.11098776	0.071421	0.03956676	35.65%
9015	TPCODL	PARADEEP	KED1	PATTAMUNDAI	PATTAMUNDAI	14153	11 KV BALIPATANA & SA	14153204	NEAR GOBINDAPUR NODAL UP SCHO	5135DT172	100	MIXED	AMI	Yes	67%	108	0.06159234	0.039528	0.02206434	35.82%
9016	TPCODL	PARADEEP	KED1	PATTAMUNDAI	PATTAMUNDAI	14153	11 KV BALDEV	14153205	AIRTEL SHOW ROOM	5133DT012	250	MIXED	AMI	Yes	100%	235	0.15221188	0.10717	0.04504188	29.59%
9017	TPCODL	PARADEEP	KED1	PATTAMUNDAI	PATTAMUNDAI	14153	11 KV BALDEV	14153205	NEAR GAYATRI TEMPLE	5133DT013	250	MIXED	AMI	Yes	0%	325	0.20100272	0.133208	0.06779472	33.73%
9018	TPCODL	PARADEEP	KED1	PATTAMUNDAI	PATTAMUNDAI	14153	11 KV BALDEV	14153205	BG TRADERS NEAR CANEL LAXMINAR	5133DT345	250	MIXED	AMI	Yes	100%	154	0.1051312	0.074028	0.0311032	29.59%
9019	TPCODL	PARADEEP	KED1	PATTAMUNDAI	PATTAMUNDAI	14153	11 KV BELTAL	14153206	N FRONT OF LIC LAXMI BAZAR MRF S	5133DT043	100	MIXED	AMI	Yes	100%	17	0.08102924	0.041718	0.03931124	48.51%
9020	TPCODL	PARADEEP	KED1	PATTAMUNDAI	PATTAMUNDAI	14153	11 KV BELTAL	14153206	NAHAR 1	5133DT047	100	MIXED	AMI	Yes	100%	83	0.05791514	0.041986	0.01592914	27.50%
9021	TPCODL	PARADEEP	KED1	PATTAMUNDAI	PATTAMUNDAI	14153	11 KV BELTAL	14153206	HEALTH & WELLNESS CENTRE 2	5133DT049	250	MIXED	AMI	Yes	67%	345	0.218039	0.198331	0.019708	9.04%
9022	TPCODL	PARADEEP	KED1	PATTAMUNDAI	SAHUPADA	14201	11 KV BADAPADA	14201201	BADA MOHANPUR	5133DT226	250	MIXED	AMI	Yes	0%	164	0.07998372	0.053567	0.02641672	33.03%
9023	TPCODL	PARADEEP	KED1	PATTAMUNDAI	SAHUPADA	14201	11 KV BADAPADA	14201201	MINJAUNI 1	5133DT243	100	MIXED	AMI	Yes	0%	91	0.04299918	0.016205	0.02679418	62.31%
9024	TPCODL	PARADEEP	KED1	PATTAMUNDAI	SAHUPADA	14201	11 KV BADAPADA	14201201	KATHIPARA 1	5133DT245	100	MIXED	AMI	Yes	33%	66	0.05973124	0.017647	0.04208424	70.46%
9025	TPCODL	PARADEEP	KED1	PATTAMUNDAI	SAHUPADA	14201	11 KV BADAPADA	14201201	MOHANPUR 2	5134DT028	100	MIXED	AMI	Yes	33%	120	0.0353558	0.026944	0.0084118	23.79%
9026	TPCODL	PARADEEP	KED1	PATTAMUNDAI	SAHUPADA	14201	11 KV BADAPADA	14201201	DIHUDPUR 2	5134DT040	100	MIXED	AMI	Yes	33%	117	0.04892504	0.042024	0.00690104	14.11%
9027	TPCODL	PARADEEP	KED1	PATTAMUNDAI	SAHUPADA	14201	11 KV GANGARANGPUR	14201202	LUNA NAI 11	5133DT272	100	MIXED	AMI	Yes	33%	68	0.03272174	0.021268	0.01145374	35.00%
9028	TPCODL	PARADEEP	KED1	PATTAMUNDAI	SAHUPADA	14201	11 KV GANGARANGPUR	14201202	LUNA NAI 17	5133DT278	100	MIXED	AMI	Yes	0%	184	0.05187732	0.04901	0.00286732	5.53%
9029	TPCODL	PARADEEP	KED1	PATTAMUNDAI	SAHUPADA	14201	11 KV GANGARANGPUR	14201202	KADALIPATANA 4	5133DT306	100	MIXED	AMI	Yes	33%	153	0.06745606	0.039788	0.02766806	41.02%
9030	TPCODL	PARADEEP	KED1	PATTAMUNDAI	SAHUPADA	14201	11 KV GANGARANGPUR	14201202	JIGARANA PATTAMUNDAI SUJAN PUI	5133DT336	250	MIXED	AMI	Yes	33%	166	0.0663886	0.035037	0.0313516	47.22%
9031	TPCODL	PARADEEP	KED1	PATTAMUNDAI	SAHUPADA	14201	11 KV GANGARANGPUR	14201202	PADMALAVAPUR 1	5134DT065	100	MIXED	AMI	Yes	33%	53	0.03258432	0.018665	0.01391932	42.72%
9032	TPCODL	PARADEEP	KED1	PATTAMUNDAI	SAHUPADA	14201	11 KV GANGARANGPUR	14201202	KUPUNI	5134DT072	100	MIXED	AMI	Yes	33%	43	0.03673634	0.01744	0.01929634	52.53%
9033	TPCODL	PARADEEP	KED1	RAJNAGAR	BADADIA ODSSP	14348	11 KV ISWARPUR(BADAD	14348201	GHADIAMAL 9	5142DT015	100	MIXED	AMI	Yes	67%	129	0.04252746	0.02828	0.01424746	33.50%
9034	TPCODL	PARADEEP	KED1	RAJNAGAR	BADADIA ODSSP	14348	11 KV ISWARPUR(BADAD	14348201	KHAMARSAHI VILLAGE 6	5143DT009	100	MIXED	AMI	Yes	100%	66	0.05522603	0.014961	0.04026503	72.91%
9035	TPCODL	PARADEEP	KED1	RAJNAGAR	BADADIA ODSSP	14348	11 KV ISWARPUR(BADAD	14348201	RIGAGARH 2	5143DT023	100	MIXED	AMI	Yes	0%	121	0.03884688	0.026381	0.01246588	32.09%
9036	TPCODL	PARADEEP	KED1	RAJNAGAR	BADADIA ODSSP	14348	11 KV ISWARPUR(BADAD	14348201	MADHUPUR 1	5143DT030	100	MIXED	AMI	Yes	67%	127	0.04393666	0.02184748	0.02208918	50.28%
9037	TPCODL	PARADEEP	KED1	RAJNAGAR	BADADIA ODSSP	14348	11 KV TALCHUA	14348202	BHAGUA 1	5143DT085	100	MIXED	AMI	Yes	67%	93	0.0276511	0.012714	0.0149371	54.02%
9038	TPCODL	PARADEEP	KED1	RAJNAGAR	BADADIA ODSSP	14348	11 KV TALCHUA	14348202	TELCHUA 2	5143DT109	100	MIXED	AMI	Yes	67%	120	0.04075798	0.031103	0.00965498	23.69%
9039	TPCODL	PARADEEP	KED1	RAJNAGAR	BADADIA ODSSP	14348	11 KV TALCHUA	14348202	RAJENDRA NAGAR 4	5143DT112	100	MIXED	AMI	Yes	0%	83	0.02598464	0.017403	0.00858164	33.03%
9040	TPCODL	PARADEEP	KED1	RAJNAGAR	BADADIA ODSSP	14348	11 KV TALCHUA	14348202	AHIRAJPUR 1	5143DT136	100	MIXED	AMI	Yes	33%	123	0.03648366	0.02213229	0.01435137	39.34%
9041	TPCODL	PARADEEP	KED1	RAJNAGAR	KANDIRA	14229	11 KV JARIMULA	14229202	JIRUMULA 5	5142DT112	100	MIXED	AMI	Yes	0%	81	0.04271168	0.029407	0.01330468	31.15%
9042	TPCODL	PARADEEP	KED1	RAJNAGAR	RAJANAGAR	14160	11 KV RAJANAGAR	14160201	STATE BANK CHHKA,RAJNAGAR	5142DT189	250	MIXED	AMI	Yes	67%	206	0.1656304	0.157892	0.0077384	4.67%
9043	TPCODL	PARADEEP	KED1	RAJNAGAR	RAJANAGAR	14160	11 KV RAJANAGAR	14160201	DHANESWARPUR VILLAGE	5142DT193	100	MIXED	AMI	Yes	0%	78	0.03042158	0.025204	0.00521758	17.15%
9044	TPCODL	PARADEEP	KED1	RAJNAGAR	RAJANAGAR	14160	11 KV RAJANAGAR	14160201	TARTC POKHARI VILLAGE	5142DT212	100	MIXED	AMI	Yes	0%	97	0.05783046	0.05344701	0.00438345	7.58%
9045	TPCODL	PARADEEP	KED1	RAJNAGAR	RAJANAGAR	14160	11 KV RAJANAGAR	14160201	MAHENSHASURA VILLAGE	5142DT221	100	MIXED	AMI	Yes	67%	106	0.05313292	0.038237	0.01489592	28.04%
9046	TPCODL	PARADEEP	KED1	RAJNAGAR	RAJANAGAR	14160	11 KV RAJANAGAR	14160201	MAHENSHASURA VILLAGE	5142DT223	100	MIXED	AMI	Yes	67%	36	0.02696234	0.012884	0.01407834	52.21%
9047	TPCODL	PARADEEP	KED1	RAJNAGAR	RAJANAGAR	14160	11 KV RAJANAGAR	14160201	BALARANPUR S/S	5142DT227	100	MIXED	AMI	Yes	0%	71	0.01928738	0.018706	0.00058138	3.01%
9048	TPCODL	PARADEEP	KED1	RAJNAGAR	RAJANAGAR	14160	11 KV RAJANAGAR	14160201	KANHUA VILLAGE S/S	5142DT228	100	MIXED	AMI	Yes	67%	65	0.03282196	0.017487	0.01533496	46.72%
9049	TPCODL	PARADEEP	KED1	RAJNAGAR	RAJANAGAR	14160	11 KV RAJANAGAR	14160201	CHAKRADHARAPUR VILLAGE S/S	5142DT230	100	MIXED	AMI	Yes	100%	77	0.02088722	0.017743	0.00314422	15.05%
9050	TPCODL	PARADEEP	KED1	RAJNAGAR	RAJANAGAR	14160	11 KV RAJANAGAR	14160201	BALARAMPUR VILLAGE S/S	5142DT233	100	MIXED	AMI	Yes	0%	164	0.05618464	0.046269	0.00991564	17.65%
9051	TPCODL	PARADEEP	KED1	RAJNAGAR	RAJANAGAR	14160	11 KV RAJANAGAR	14160201	TAIRA VILLAGE S/S	5142DT237	63	MIXED	AMI	Yes	67%	41	0.01560898	0.010305	0.00530398	33.98%

Sl. No.	Zone Name	Circle name	Division name	Name of the Sub-division	Name of the Sub-station	Substation Code	Name of the 11 kV Feeder	Feeder Code	Name of the Location where DT situated	DT code	DT Capacity (kVA)	Predominant consumer type of DT (Domestic/Industrial/Agriculture/Mixed)	Type of metering AMR/AMI/ Communicable/Conventional metered/Unmetered	Status of Meter- whether Functional (Yes/No)	% of data received automatically (if AMR/AMI)	No. of Connected Consumers	Input Energy (MU) (A)	Billed Energy (MU) (B)	Loss (MU) (A-B)	% DT Loss (A-B)/A
9052	TPCODL	PARADEEP	KED1	RAJNAGAR	RAJANAGAR	14160	11 KV RAJANAGAR	14160201	KURUNTI CHHAKA S/S	5142DT240	100	MIXED	AMI	Yes	0%	111	0.0380274	0.033915	0.0041124	10.81%
9053	TPCODL	PARADEEP	KED1	RAJNAGAR	RAJANAGAR	14160	11 KV RAJANAGAR	14160201	KURUNTI VILLAGE S/S	5142DT243	100	MIXED	AMI	Yes	0%	90	0.03469276	0.025546	0.00914676	26.37%
9054	TPCODL	PARADEEP	KED1	RAJNAGAR	RAJANAGAR	14160	11 KV RAJANAGAR	14160201	KURUNTI VILLAGE S/S	5142DT244	100	MIXED	AMI	Yes	67%	93	0.03113258	0.023663	0.00746958	23.99%
9055	TPCODL	PARADEEP	KED1	RAJNAGAR	RAJANAGAR	14160	11 KV RAJANAGAR	14160201	BADANAUKANA	5142DT256	63	MIXED	AMI	Yes	67%	79	0.03620452	0.020587	0.01561752	43.14%
9056	TPCODL	PARADEEP	KED1	RAJNAGAR	RAJANAGAR	14160	11 KV RAJANAGAR	14160201	BINDHA NAUKANA S/S	5142DT261	100	MIXED	AMI	Yes	67%	76	0.03155868	0.021395	0.01016368	32.21%
9057	TPCODL	PARADEEP	KED1	RAJNAGAR	RAJANAGAR	14160	11 KV RAJANAGAR	14160201	PRAHARAJPUR VILLAGE S/S	5142DT266	100	MIXED	AMI	Yes	33%	61	0.01915562	0.011292	0.00786362	41.05%
9058	TPCODL	PARADEEP	KED1	RAJNAGAR	RAJANAGAR	14160	11 KV RAJANAGAR	14160201	NEAR PENTHA BEACH S/S	5142DT276	100	MIXED	AMI	Yes	33%	66	0.02295256	0.01514	0.00781256	34.04%
9059	TPCODL	PARADEEP	KED1	RAJNAGAR	RAJANAGAR	14160	11 KV RAJANAGAR	14160201	JUNAPANGARA VILLAGE S/S	5142DT293	100	MIXED	AMI	Yes	67%	102	0.04027644	0.026137	0.01413944	35.11%
9060	TPCODL	PARADEEP	KED1	RAJNAGAR	RAJANAGAR	14160	11 KV RAJANAGAR	14160201	GOKHARI VILLAGE S/S	5142DT312	100	MIXED	AMI	Yes	67%	140	0.0322578	0.031727	0.0005308	1.65%
9061	TPCODL	PARADEEP	KED1	RAJNAGAR	RAJANAGAR	14160	11 KV RAJANAGAR	14160201	KARTHA VILLAGE S/S	5142DT318	100	MIXED	AMI	Yes	67%	96	0.03094212	0.017068	0.01387412	44.84%
9062	TPCODL	PARADEEP	KED1	RAJNAGAR	RAJANAGAR	14160	11 KV RAJANAGAR	14160201	KATHAPANGARA VILLAGE S/S	5142DT322	100	MIXED	AMI	Yes	67%	83	0.05043182	0.0268	0.02363182	46.86%
9063	TPCODL	PARADEEP	KED1	RAJNAGAR	RAJANAGAR	14160	11 KV RAJANAGAR	14160201	DHOBIEGARH	5142DT323	100	MIXED	AMI	Yes	67%	68	0.02121958	0.015366	0.00585358	27.59%
9064	TPCODL	PARADEEP	KED1	RAJNAGAR	RAJANAGAR	14160	11 KV RAJANAGAR	14160201	NUAGAN 1	5142DT324	100	MIXED	AMI	Yes	67%	39	0.0305927	0.008703	0.0218897	71.55%
9065	TPCODL	PARADEEP	KED1	RAJNAGAR	RAJANAGAR	14160	11 KV RAJANAGAR	14160201	KATHUAGANDA VILLAGE S/S	5142DT327	100	MIXED	AMI	Yes	67%	59	0.02019134	0.014045	0.00614634	30.44%
9066	TPCODL	PARADEEP	KED1	RAJNAGAR	RAJANAGAR	14160	11 KV RAJANAGAR	14160201	NARANGARH	5142DT329	100	MIXED	AMI	Yes	67%	67	0.01695474	0.011736	0.00521874	30.78%
9067	TPCODL	PARADEEP	KED1	RAJNAGAR	RAJANAGAR	14160	11 KV RAJANAGAR	14160201	GOPALPUR VILLAGE	5142DT331	100	MIXED	AMI	Yes	67%	80	0.03856278	0.020465	0.01809778	46.93%
9068	TPCODL	PARADEEP	KED1	RAJNAGAR	RAJANAGAR	14160	11 KV RAJANAGAR	14160201	NACHHIPADA VILLAGE S/S	5142DT337	100	MIXED	AMI	Yes	67%	94	0.03139332	0.02096	0.01043332	33.23%
9069	TPCODL	PARADEEP	KED1	RAJNAGAR	RAJANAGAR	14160	11 KV RAJANAGAR	14160201	HARINARAPUR VILLAGE S/S	5142DT341	100	MIXED	AMI	Yes	67%	68	0.01818116	0.014916	0.00326516	17.96%
9070	TPCODL	PARADEEP	KED1	RAJNAGAR	RAJANAGAR	14160	11 KV RAJANAGAR	14160201	KRUSHANPRIYAPUR	5142DT343	63	MIXED	AMI	Yes	67%	87	0.02080382	0.01399115	0.00681267	32.75%
9071	TPCODL	PARADEEP	KED1	RAJNAGAR	RAJANAGAR	14160	11 KV RAJANAGAR	14160201	RAJRAJESWARPUR	5142DT345	100	MIXED	AMI	Yes	67%	66	0.0163577	0.010144	0.0062137	37.99%
9072	TPCODL	PARADEEP	KED1	RAJNAGAR	RAJANAGAR	14160	11 KV RAJANAGAR	14160201	SINGADAPAL	5142DT349	63	MIXED	AMI	Yes	67%	102	0.0131678	0.011216	0.0019518	14.82%
9073	TPCODL	PARADEEP	KED1	RAJNAGAR	RAJANAGAR	14160	11 KV RAJANAGAR	14160201	D.N PUR	5142DT362	100	MIXED	AMI	Yes	67%	102	0.02771658	0.025262	0.00245458	8.86%
9074	TPCODL	PARADEEP	KED1	RAJNAGAR	RAJANAGAR	14160	11 KV RAJANAGAR	14160201	BANABIHARPUR	5142DT367	63	MIXED	AMI	Yes	0%	70	0.02762786	0.017501	0.01012686	36.65%
9075	TPCODL	PARADEEP	KED1	RAJNAGAR	RAJANAGAR	14160	11 KV RAJANAGAR	14160201	GUPTI	5142DT371	63	MIXED	AMI	Yes	0%	78	0.10702258	0.032193	0.07482958	69.92%
9076	TPCODL	PARADEEP	KED1	RAJNAGAR	RAJANAGAR	14160	11 KV KOILIPUR	14160202	RAJANAGAR MARKET 1(TILAKNAGAR	5141DT203	250	MIXED	AMI	Yes	67%	84	0.12112948	0.07222	0.04890948	40.38%
9077	TPCODL	PARADEEP	KED1	RAJNAGAR	RAJANAGAR	14160	11 KV KOILIPUR	14160202	KANKADIA	5141DT231	100	MIXED	AMI	Yes	0%	96	0.0351107	0.023464	0.0116467	33.17%
9078	TPCODL	PARADEEP	KED1	RAJNAGAR	RAJANAGAR	14160	11 KV KOILIPUR	14160202	BARHAPUR 1	5141DT237	100	MIXED	AMI	Yes	0%	60	0.04730292	0.022251	0.02505192	52.96%
9079	TPCODL	PARADEEP	KED1	RAJNAGAR	RAJANAGAR	14160	11 KV KOILIPUR	14160202	RAJNAGAR 1(S B GOPALPUR)	5141DT295	250	MIXED	AMI	Yes	100%	136	0.0988134	0.073999	0.0248144	25.11%
9080	TPCODL	PARADEEP	KED1	RAJNAGAR	RAJANAGAR	14160	11 KV KEREDAGADA	14160203	BHATAPARA 2	5141DT082	100	MIXED	AMI	Yes	67%	110	0.04891618	0.03617	0.01274618	26.06%
9081	TPCODL	PARADEEP	KED1	RAJNAGAR	RAJANAGAR	14160	11 KV KEREDAGADA	14160203	BADOLARA	5141DT095	100	MIXED	AMI	Yes	0%	55	0.04628224	0.015289	0.03099324	66.97%
9082	TPCODL	PARADEEP	KED1	RAJNAGAR	RAJANAGAR	14160	11 KV KEREDAGADA	14160203	BANDHAPATNA 2	5141DT122	100	MIXED	AMI	Yes	67%	73	0.02674274	0.014479	0.01226374	45.86%
9083	TPCODL	PARADEEP	KED1	RAJNAGAR	RAJANAGAR	14160	11 KV KEREDAGADA	14160203	OSTIA NAGAD 2	5141DT134	100	MIXED	AMI	Yes	67%	101	0.04241988	0.032636	0.00978388	23.06%
9084	TPCODL	PARADEEP	KED1	RAJNAGAR	RAJANAGAR	14160	11 KV KEREDAGADA	14160203	DHANDIA 3	5141DT146	100	MIXED	AMI	Yes	67%	64	0.0272225	0.022709	0.0045135	16.58%
9085	TPCODL	PARADEEP	KED1	RAJNAGAR	RAJANAGAR	14160	11 KV KEREDAGADA	14160203	BALISAHIPATANA	5141DT155	100	MIXED	AMI	Yes	67%	106	0.03954702	0.034718	0.00482902	12.21%
9086	TPCODL	PARADEEP	KED1	RAJNAGAR	RAJANAGAR	14160	11 KV KEREDAGADA	14160203	DAKHINADIHA 1	5141DT168	100	MIXED	AMI	Yes	67%	39	0.01354456	0.01082	0.00272456	20.12%
9087	TPCODL	PARADEEP	KED1	RAJNAGAR	RAJANAGAR	14160	11 KV KEREDAGADA	14160203	DAKHINADIHA 2	5141DT169	100	MIXED	AMI	Yes	67%	118	0.0318895	0.020141	0.0117485	36.84%
9088	TPCODL	PARADEEP	KED1	RAJNAGAR	RAJANAGAR	14160	11 KV KEREDAGADA	14160203	HANUMAN TEMPLE(DCIKHINDIA)	5141DT171	100	MIXED	AMI	Yes	67%	113	0.03587648	0.03134	0.00453648	12.64%
9089	TPCODL	PARADEEP	KED1	RAJNAGAR	RAJANAGAR	14160	11 KV KEREDAGADA	14160203	BALABHADARA RAJPUR 2	5141DT181	100	MIXED	AMI	Yes	0%	85	0.03739962	0.023954	0.01344562	35.95%
9090	TPCODL	PARADEEP	KED1	RAJNAGAR	RAJANAGAR	14160	11 KV MADANPUR-1	14160204	MADHYAPARA	5141DT038	100	MIXED	AMI	Yes	67%	120	0.05574102	0.03564836	0.02009266	36.05%
9091	TPCODL	PARADEEP	KED1	RAJNAGAR	RAJANAGAR	14160	11 KV MADANPUR-1	14160204	MADHAYPARA 2(NEW KANDIA)	5141DT041	100	MIXED	AMI	Yes	67%	47	0.0412404	0.011385	0.0298554	72.39%
9092	TPCODL	PARADEEP	KED1	RAJNAGAR	RAJANAGAR	14160	11 KV MADANPUR-1	14160204	FIRIKINDEY 1	5141DT061	100	MIXED	AMI	Yes	67%	95	0.08974164	0.029887	0.05985464	66.70%
9093	TPCODL	PARADEEP	KED2	MAHAKALAPAD	BADIHI	14228	11 kV JAMBOO	14228203	KHARIANTA	5211DT095	100	MIXED	AMI	Yes	0%	96	0.02897078	0.023901	0.00506978	17.50%
9094	TPCODL	PARADEEP	KED2	MAHAKALAPAD	BADIHI	14228	11 kV JAMBOO	14228203	JAGARIJOR KALI TEMPLE	5211DT102	100	MIXED	AMI	Yes	0%	81	0.03099274	0.020777	0.01021574	32.96%
9095	TPCODL	PARADEEP	KED2	MAHAKALAPAD	MARSHAGHAI	17035	33 kV LUNA	17035401	33/11 KV LUNA SS ST	5212DT001	100	MIXED	AMI	Yes	100%	1	0.0029702	0.00297	2E-07	0.01%
9096	TPCODL	PARADEEP	KED2	MAHAKALAPAD	LUNA	14166	11 kV NALADIA	14166205	NALADIA	5212DT021	63	MIXED	AMI	Yes	100%	104	0.03858596	0.024501	0.01408496	36.50%
9097	TPCODL	PARADEEP	KED2	MAHAKALAPAD	BADIHI	14228	11 KV BIJAYANAGAR-1	14228201	MANGARAJPUR 2	5133DT359	100	MIXED	AMI	Yes	67%	118	0.0484933	0.032454	0.0160393	33.08%
9098	TPCODL	PARADEEP	KED2	MAHAKALAPAD	BADIHI	14228	11 KV BIJAYANAGAR-1	14228201	NEAR MARKET (JASUAPALLY)	5211DT219	100	MIXED	AMI	Yes	0%	74	0.02891276	0.016701	0.01221176	42.24%
9099	TPCODL	PARADEEP	KED2	MAHAKALAPAD	BADIHI	14228	11 KV BIJAYANAGAR-1	14228201	NEAR PULL 9(ANDULI-2)	5211DT247	100	MIXED	AMI	Yes	67%	44	0.0167574	0.012043	0.0047144	28.13%
9100	TPCODL	PARADEEP	KED2	MAHAKALAPAD	BADIHI	14228	11 KV BIJAYANAGAR-1	14228201	NEAR PULL(RAMAKANI)	5211DT259	100	MIXED	AMI	Yes	67%	119	0.03085278	0.023345	0.00750778	24.33%
9101	TPCODL	PARADEEP	KED2	MAHAKALAPAD	BADIHI	14228	11 KV BIJAYANAGAR-1	14228201	NEAR PLAY GROUND 1(SANKHA PAD/	5211DT260	100	MIXED	AMI	Yes	33%	114	0.06738422	0.028101	0.03928322	58.30%
9102	TPCODL	PARADEEP	KED2	MAHAKALAPAD	BADIHI	14228	11 KV BIJAYANAGAR-1	14228201	NEAR PLAY GROUND 3(SAHABAJPUR-	5211DT266	100	MIXED	AMI	Yes	67%	207	0.06308734	0.05006226	0.01302508	20.65%
9103	TPCODL	PARADEEP	KED2	MAHAKALAPAD	BADIHI	14228	11 KV BIJAYANAGAR-1	14228201	NEAR PULL 12(BIJAYANAGAR BAHARI	5211DT270	100	MIXED	AMI	Yes	67%	155	0.06453442	0.043825	0.02070942	32.09%
9104	TPCODL	PARADEEP	KED2	MAHAKALAPAD	BADIHI	14228	11 KV BIJAYANAGAR-1	14228201	NEAR SCHOOL 11(BALIA-1)	5211DT271	100	MIXED	AMI	Yes	67%	76	0.02485554	0.01768	0.00717554	28.87%
9105	TPCODL	PARADEEP	KED2	MAHAKALAPAD	BADIHI	14228	11 KV BIJAYANAGAR-1	14228201	VILL. MULL BASANTA(MULABASANTA	5211DT273	100	MIXED	AMI	Yes	67%	47	0.04132162	0.011406	0.02991562	72.40%
9106	TPCODL	PARADEEP	KED2	MAHAKALAPAD	BADIHI	14228	11 KV BIJAYANAGAR-1	14228201	NEAR SCHOOL 6(KANPUR)	5211DT282	100	MIXED	AMI	Yes	67%	155	0.06832666	0.035217	0.03310966	48.46%
9107	TPCODL	PARADEEP	KED2	MAHAKALAPAD	BADIHI	14228	11 KV BABAR	14228202	BALIGANDA	5211DT026	100	MIXED	AMI	Yes	67%	91	0.02824258	0.023096	0.00514658	18.22%
9108	TPCODL	PARADEEP	KED2	MAHAKALAPAD	BADIHI	14228	11 KV JAMBOO	14228203	JAMBOO MARKET	5211DT170	150	MIXED	AMI	Yes	67%	167	0.05689936	0.037009	0.01989036	34.96%
9109	TPCODL	PARADEEP	KED2	MAHAKALAPAD	CHHAPALI	14382	11KV RAM NAGAR	14382202	BADATOTA 3	5213DT132	100	MIXED	AMI	Yes	67%	145	0.06706038	0.04274	0.02432038	36.27%
9110	TPCODL	PARADEEP	KED2	MAHAKALAPAD	CHHAPALI	14382	11KV RAM NAGAR	14382202	CHHAPALI 4	5213DT137	100	MIXED	AMI	Yes	67%	60	0.03601734	0.020374	0.01564334	43.43%
9111	TPCODL	PARADEEP	KED2	MAHAKALAPAD	CHHAPALI	14382	11KV RAM NAGAR	14382202	KHARNASI DASIT PADA	5213DT245	100	MIXED	AMI	Yes	67%	292	0.0766823	0.057046	0.0196363	25.61%
9112	TPCODL	PARADEEP	KED2	MAHAKALAPAD	CHHAPALI	14382	11KV RAM NAGAR	14382202	RAMNAGAR VILLAGE	5213DT304	100	MIXED	AMI	Yes	67%	178	0.05130092	0.049211	0.00208992	4.07%
9113	TPCODL	PARADEEP	KED2	MAHAKALAPAD	CHHAPALI	14382	11KV RAM NAGAR	14382202	PETCHHEA LINE AB SWITCH NEAR RU	5213DT311	100	MIXED	AMI	Yes	67%	134	0.04905398	0.036913	0.01214098	24.75%
9114	TPCODL	PARADEEP	KED2	MAHAKALAPAD	DHIASAHI / JOGDHA	14172	11 KV ODISSO	14172201	HODIPADWA MAHAKALESWAR	5321DT189	100	MIXED	AMI	Yes	0%	178	0.07909348	0.060368	0.01872548	23.68%
9115	TPCODL	PARADEEP	KED2	MAHAKALAPAD	LUNA	14166	11 KV ANKO	14166202	NEAR BADAPALA MARKET	5212DT256	63	MIXED	AMI	Yes	100%	113	0.05855216	0.056154	0.00239816	4.10%
9116	TPCODL	PARADEEP	KED2	MAHAKALAPAD	LUNA	14166	11 KV ANKO	14166202	NEAR KENAL 1	5212DT257	100	MIXED	AMI	Yes	100%	123	0.05572586	0.044465	0.01126086	20.21%
9117	TPCODL	PARADEEP	KED2	MAHAKALAPAD	LUNA	14166	11 KV ANKO	14166202	NEAR SCHOOL 16	5212DT262	100	MIXED	AMI	Yes	100%	75	0.06797592	0.029082	0.03889392	57.22%
9118	TPCODL	PARADEEP	KED2	MAHAKALAPAD	LUNA	14166	11 KV OSTARA	14166203	BADAGAON MATHASAHI 100KVA	5212DT117	100	MIXED	AMI	Yes	67%	70	0.05947016	0.017997	0.04147316	69.74%
9119	TPCODL	PARADEEP	KED2	MAHAKALAPAD	LUNA	14166	11 KV OSTARA	14166203	JAYACHANDRAPUR	5212DT123	100	MIXED	AMI	Yes	67%	143	0.0652912	0.042785	0.0225062	34.47%
9120	TPCODL	PARADEEP	KED2	MAHAKALAPAD	LUNA	14166	11 KV OSTARA	14166203	SANAGAN	5212DT128	100	MIXED	AMI	Yes	67%	254	0.08731244	0.062471	0.02484144	28.45%
9121	TPCODL	PARADEEP	KED2	MAHAKALAPAD	LUNA	14166	11 KV OSTARA	14166203	OSTER VILLAGE	5212DT131	100	MIXED	AMI	Yes	67%	170	0.06333594	0.04876	0.01457594	23.01%
9122	TPCODL	PARADEEP	KED2	MAHAKALAPAD	LUNA	14166	11 KV OSTARA	14166203	MANGALA MANDIR BELER NAUGAN	5212DT164	100	MIXED	AMI	Yes	67%	89	0.03202702	0.02559	0.00643702	20.10%
9123	TPCODL	PARADEEP	KED2	MAHAKALAPAD	LUNA	14166	11 KV OSTARA	14166203	KHASADI	5212DT171	100	MIXED	AMI	Yes	67%	113	0.04123512	0.028976	0.01225912	29.73%
9124	TPCODL	PARADEEP	KED2	MAHAKALAPAD	LUNA	14166	11 KV OSTARA	14166203	CHAMARSAHI	5212DT179	100	MIXED	AMI	Yes	33%	128	0.0794249	0.033361	0.0460639	58.00%

Sl. No.	Zone Name	Circle name	Division name	Name of the Sub-division	Name of the Sub-station	Substation Code	Name of the 11 kV Feeder	Feeder Code	Name of the Location where DT situated	DT code	DT Capacity (kVA)	Predominant consumer type of DT (Domestic/Industrial/Agriculture/Mixed)	Type of metering AMR/AMI/ Communicable/Conventional metered/Unmetered	Status of Meter-whether Functional (Yes/No)	% of data received automatically (if AMR/AMI)	No. of Connected Consumers	Input Energy (MU) (A)	Billed Energy (MU) (B)	Loss (MU) (A-B)	% DT Loss (A-B)/A
9125	TPCODL	PARADEEP	KED2	MAHAKALAPAD	LUNA	14166	11 KV OSTARA	14166203	MASAKANI	5212DT180	100	MIXED	AMI	Yes	67%	114	0.05783636	0.042242	0.01559436	26.96%
9126	TPCODL	PARADEEP	KED2	MAHAKALAPAD	LUNA	14166	11 KV OSTARA	14166203	MAKANI COMPLEX	5212DT182	100	MIXED	AMI	Yes	67%	85	0.05761152	0.034547	0.02306452	40.03%
9127	TPCODL	PARADEEP	KED2	MAHAKALAPAD	LUNA	14166	11 KV OSTARA	14166203	JADUPUR JADI	5212DT185	100	MIXED	AMI	Yes	67%	155	0.0580467	0.04665993	0.01138677	19.62%
9128	TPCODL	PARADEEP	KED2	MAHAKALAPAD	LUNA	14166	11 KV OSTARA	14166203	JADUPUR JADI	5212DT186	100	MIXED	AMI	Yes	67%	104	0.04309888	0.032617	0.01048188	24.32%
9129	TPCODL	PARADEEP	KED2	MAHAKALAPAD	LUNA	14166	11 KV OSTARA	14166203	KALAGARH	5212DT195	100	MIXED	AMI	Yes	67%	171	0.07095236	0.044514	0.02643836	37.26%
9130	TPCODL	PARADEEP	KED2	MAHAKALAPAD	LUNA	14166	11 KV KARANJA	14166204	KARAMKUL (ARTIPUR)	5212DT199	100	MIXED	AMI	Yes	100%	121	0.04427046	0.031968	0.01230246	27.79%
9131	TPCODL	PARADEEP	KED2	MAHAKALAPAD	LUNA	14166	11 KV KARANJA	14166204	KARAMKUL	5212DT200	100	MIXED	AMI	Yes	100%	101	0.05271968	0.036514	0.01620568	30.74%
9132	TPCODL	PARADEEP	KED2	MAHAKALAPAD	LUNA	14166	11 KV KARANJA	14166204	BADA POL 5 (KARAMKUL)	5212DT207	100	MIXED	AMI	Yes	100%	86	0.03634664	0.032577	0.00376964	10.37%
9133	TPCODL	PARADEEP	KED2	MAHAKALAPAD	LUNA	14166	11 KV KARANJA	14166204	BADA POL 8	5212DT210	100	MIXED	AMI	Yes	100%	78	0.0431943	0.025216	0.0179783	41.62%
9134	TPCODL	PARADEEP	KED2	MAHAKALAPAD	LUNA	14166	11 KV KARANJA	14166204	GOKHAPADA 2	5212DT216	100	MIXED	AMI	Yes	67%	102	0.0499233	0.029675	0.0202483	40.56%
9135	TPCODL	PARADEEP	KED2	MAHAKALAPAD	LUNA	14166	11 KV KARANJA	14166204	KARANJA 13	5212DT232	100	MIXED	AMI	Yes	0%	142	0.04417496	0.039418	0.00475696	10.77%
9136	TPCODL	PARADEEP	KED2	MAHAKALAPAD	LUNA	14166	11 KV KARANJA	14166204	GOKHAPADA 6 (BENUPAL)	5212DT239	100	MIXED	AMI	Yes	0%	84	0.02621036	0.015709	0.01050136	40.07%
9137	TPCODL	PARADEEP	KED2	MAHAKALAPAD	LUNA	14166	11 KV KARANJA	14166204	KARAMKUL 5(BALIKUDA)	5212DT252	100	MIXED	AMI	Yes	100%	129	0.05552296	0.039605	0.01591796	28.67%
9138	TPCODL	PARADEEP	KED2	MAHAKALAPAD	LUNA	14166	11 KV KARANJA	14166204	ASHRAM BALIKUDA	5212DT254	100	MIXED	AMI	Yes	100%	72	0.05181408	0.021595	0.03021908	58.32%
9139	TPCODL	PARADEEP	KED2	MAHAKALAPAD	LUNA	14166	11 KV NALADIA	14166205	GATONAI	5212DT029	100	MIXED	AMI	Yes	100%	131	0.047045	0.034551	0.012494	26.56%
9140	TPCODL	PARADEEP	KED2	MAHAKALAPAD	LUNA	14166	11 KV NALADIA	14166205	KORATPANGA	5212DT030	100	MIXED	AMI	Yes	67%	88	0.04756576	0.023045	0.02452076	51.55%
9141	TPCODL	PARADEEP	KED2	MAHAKALAPAD	LUNA	14166	11 KV NALADIA	14166205	KHURASIA	5212DT040	100	MIXED	AMI	Yes	67%	142	0.05444348	0.03547	0.01897348	34.85%
9142	TPCODL	PARADEEP	KED2	MAHAKALAPAD	LUNA	14166	11 KV NALADIA	14166205	KHURUSIAPUT	5212DT047	100	MIXED	AMI	Yes	33%	98	0.06001696	0.025522	0.03449496	57.48%
9143	TPCODL	PARADEEP	KED2	MAHAKALAPAD	LUNA	14166	11 KV NALADIA	14166205	PATALI PARK	5212DT052	100	MIXED	AMI	Yes	67%	144	0.05251154	0.033633	0.01887854	35.95%
9144	TPCODL	PARADEEP	KED2	MAHAKALAPAD	LUNA	14166	11 KV NALADIA	14166205	HANUMAN	5212DT054	100	MIXED	AMI	Yes	67%	53	0.01839486	0.017038	0.00135686	7.38%
9145	TPCODL	PARADEEP	KED2	MAHAKALAPAD	LUNA	14166	11 KV NALADIA	14166205	NEAR TEMPLE5	5212DT055	100	MIXED	AMI	Yes	0%	130	0.05080088	0.030781	0.02001988	39.41%
9146	TPCODL	PARADEEP	KED2	MAHAKALAPAD	LUNA	14166	11 KV NALADIA	14166205	P.PARK 3	5212DT061	100	MIXED	AMI	Yes	0%	143	0.04558832	0.040138	0.00545032	11.96%
9147	TPCODL	PARADEEP	KED2	MAHAKALAPAD	LUNA	14166	11 KV NALADIA	14166205	TIKARPANGA	5212DT072	100	MIXED	AMI	Yes	67%	44	0.02366212	0.0133	0.01036212	43.79%
9148	TPCODL	PARADEEP	KED2	MAHAKALAPAD	LUNA	14166	11 KV NALADIA	14166205	TARADEIPUR	5212DT074	100	MIXED	AMI	Yes	0%	100	0.0530881	0.025803	0.0272851	51.40%
9149	TPCODL	PARADEEP	KED2	MAHAKALAPAD	LUNA	14166	11 KV NALADIA	14166205	PURUSOTTAMPUR	5212DT081	100	MIXED	AMI	Yes	67%	80	0.04237872	0.024806	0.01757272	41.47%
9150	TPCODL	PARADEEP	KED2	MAHAKALAPAD	LUNA	14166	11 KV NALADIA	14166205	SUBALA	5212DT097	100	MIXED	AMI	Yes	67%	55	0.03017178	0.013791	0.01638078	54.29%
9151	TPCODL	PARADEEP	KED2	MAHAKALAPAD	LUNA	14166	11 KV NALADIA	14166205	SUBALA	5212DT099	100	MIXED	AMI	Yes	67%	79	0.04977138	0.020476	0.02929538	58.86%
9152	TPCODL	PARADEEP	KED2	MAHAKALAPAD	MAHAKALPADA	14167	11 KV CHHAPALI	14167202	JANHARA	5213DT088	100	MIXED	AMI	Yes	67%	76	0.03205014	0.020397	0.01165314	36.36%
9153	TPCODL	PARADEEP	KED2	MAHAKALAPAD	MAHAKALPADA	14167	11 KV CHHAPALI	14167202	NANTAR PASAWAR PUR 1	5213DT094	100	MIXED	AMI	Yes	33%	71	0.04775894	0.025364	0.02239494	46.89%
9154	TPCODL	PARADEEP	KED2	MAHAKALAPAD	MAHAKALPADA	14167	11 KV MAHAKALPADA	14167203	KEYAR BANK 3(CAPEX KEYAR BANK)	5213DT013	100	MIXED	AMI	Yes	67%	154	0.06307902	0.043281	0.01979802	31.39%
9155	TPCODL	PARADEEP	KED2	MAHAKALAPAD	MAHAKALPADA	14167	11 KV MAHAKALPADA	14167203	MAHAKALPADA BLOCK OFFICE	5213DT017	100	MIXED	AMI	Yes	67%	39	0.04300864	0.028113	0.01489564	34.63%
9156	TPCODL	PARADEEP	KED2	MAHAKALAPAD	MAHAKALPADA	14167	11 KV MAHAKALPADA	14167203	AMIRABAD 1	5213DT034	100	MIXED	AMI	Yes	67%	84	0.02339732	0.016721	0.00667632	28.53%
9157	TPCODL	PARADEEP	KED2	MAHAKALAPAD	MAHAKALPADA	14167	11 KV MAHAKALPADA	14167203	DEULAPADA 2	5213DT041	100	MIXED	AMI	Yes	67%	145	0.0478805	0.047684	0.0001965	0.41%
9158	TPCODL	PARADEEP	KED2	MAHAKALAPAD	MAHAKALPADA	14167	11 KV MAHAKALPADA	14167203	CHANDIYAPALI 1	5213DT050	100	MIXED	AMI	Yes	67%	150	0.05318952	0.039178	0.01401152	26.34%
9159	TPCODL	PARADEEP	KED2	MAHAKALAPAD	MAHAKALPADA	14167	11 KV MAHAKALPADA	14167203	GOUDBADPUR	5213DT058	100	MIXED	AMI	Yes	67%	83	0.0407911	0.024329	0.0164621	40.36%
9160	TPCODL	PARADEEP	KED2	MAHAKALAPAD	MAHAKALPADA	14167	11 KV MAHAKALPADA	14167203	CHANDEIGUAN 5(NEAR RANA HOUSE	5213DT059	100	MIXED	AMI	Yes	67%	44	0.02169298	0.017005	0.00468798	21.61%
9161	TPCODL	PARADEEP	KED2	MAHAKALAPAD	MAHAKALPADA	14167	11 KV MAHAKALPADA	14167203	KEYAR BANK 6	5213DT066	100	MIXED	AMI	Yes	67%	143	0.06524056	0.035181	0.03005956	46.07%
9162	TPCODL	PARADEEP	KED2	MAHAKALAPAD	MAHAKALPADA	14167	11 KV DASAMAUJI+BIJAY	14167205	MANGALAPUR 1	5213DT336	100	MIXED	AMI	Yes	67%	75	0.0369249	0.020925	0.0159999	43.33%
9163	TPCODL	PARADEEP	KED2	MAHAKALAPAD	MAHAKALPADA	14167	11 KV DASAMAUJI+BIJAY	14167205	DADHIPUR	5213DT351	100	MIXED	AMI	Yes	67%	140	0.0438688	0.039316	0.0045528	10.38%
9164	TPCODL	PARADEEP	KED2	MAHAKALAPAD	MAHAKALPADA	14167	11 KV DASAMAUJI+BIJAY	14167205	GOJABANDHA	5213DT364	100	MIXED	AMI	Yes	67%	100	0.03908602	0.025044	0.01404202	35.93%
9165	TPCODL	PARADEEP	KED2	MAHAKALAPAD	MAHAKALPADA	14167	11 KV DASAMAUJI+BIJAY	14167205	CHHEDAKANI	5213DT371	100	MIXED	AMI	Yes	67%	95	0.02941368	0.02198	0.00743368	25.27%
9166	TPCODL	PARADEEP	KED2	MARSHAGHAI	GAUDAGAON ODSS	14354	11KV KARANDIAPATANA	14354202	NEAR TEMPLE 9(PENTHA RAM MAND	5224DT240	100	MIXED	AMI	Yes	67%	142	0.04870918	0.031877	0.01683218	34.56%
9167	TPCODL	PARADEEP	KED2	MARSHAGHAI	GAUDAGAON ODSS	14354	11KV KARANDIAPATANA	14354202	NEAR TEMPLE 11(MEHENDINAGAR)	5224DT290	100	MIXED	AMI	Yes	0%	75	0.04100286	0.019548	0.02145486	52.33%
9168	TPCODL	PARADEEP	KED2	MARSHAGHAI	ASURESWAR ODSSP	14311	11 KV LUNA	14311203	DAMODARPUR 1	3523DT535	100	MIXED	AMI	Yes	100%	217	0.0671832	0.066457	0.0007262	1.08%
9169	TPCODL	PARADEEP	KED2	MARSHAGHAI	BEDARI ODSSP	14356	11 KV ANTAI	14356201	NEAR PULL 2(MANIKPUR) 2	5224DT071	100	MIXED	AMI	Yes	100%	45	0.04598708	0.014958	0.03102908	67.47%
9170	TPCODL	PARADEEP	KED2	MARSHAGHAI	BEDARI ODSSP	14356	11 KV ANTAI	14356201	NEAR TEMPLE 2(KINILO)	5224DT075	100	MIXED	AMI	Yes	100%	159	0.05140118	0.042071	0.00933018	18.15%
9171	TPCODL	PARADEEP	KED2	MARSHAGHAI	BEDARI ODSSP	14356	11 KV ANTAI	14356201	PADAMPUR	5224DT081	100	MIXED	AMI	Yes	100%	202	0.0696353	0.058701	0.0109343	15.70%
9172	TPCODL	PARADEEP	KED2	MARSHAGHAI	BEDARI ODSSP	14356	11 KV ANTAI	14356201	NEAR CANEL 1(BEDHI)	5224DT093	100	MIXED	AMI	Yes	67%	73	0.02632906	0.01998161	0.00634745	24.11%
9173	TPCODL	PARADEEP	KED2	MARSHAGHAI	BEDARI ODSSP	14356	11 KV ANTAI	14356201	NEAR BUILDING(MADHUSUDANPUR	5224DT101	100	MIXED	AMI	Yes	0%	48	0.0307432	0.022252	0.0084912	27.62%
9174	TPCODL	PARADEEP	KED2	MARSHAGHAI	BEDARI ODSSP	14356	11 KV ANTAI	14356201	NEAR MOHANADI RIVER 6(BATIRA)	5224DT107	25	MIXED	AMI	Yes	67%	56	0.02112886	0.016303	0.00482586	22.84%
9175	TPCODL	PARADEEP	KED2	MARSHAGHAI	BEDARI ODSSP	14356	11 KV ANTAI	14356201	NEAR SCHOOL 5(POTEIRI)	5224DT112	100	MIXED	AMI	Yes	0%	55	0.05116046	0.012907	0.03825346	74.77%
9176	TPCODL	PARADEEP	KED2	MARSHAGHAI	BEDARI ODSSP	14356	11 KV ANTAI	14356201	MADHUSUDANAPUR	5224DT116	100	MIXED	AMI	Yes	0%	139	0.0329008	0.032477	0.0004238	1.29%
9177	TPCODL	PARADEEP	KED2	MARSHAGHAI	BEDARI ODSSP	14356	11 KV ANTAI	14356201	NEAR TEMPLE 6(DHANUAPADA)	5224DT118	100	MIXED	AMI	Yes	67%	142	0.08235508	0.04387	0.03848508	46.73%
9178	TPCODL	PARADEEP	KED2	MARSHAGHAI	BEDARI ODSSP	14356	11 KV ANTAI	14356201	WATER PUMP 2	5224DT126	100	MIXED	AMI	Yes	67%	78	0.02143646	0.018304	0.00313246	14.61%
9179	TPCODL	PARADEEP	KED2	MARSHAGHAI	BEDARI ODSSP	14356	11 KV ANTAI	14356201	NEAR COLLEGE(ANTEI)	5224DT127	100	MIXED	AMI	Yes	33%	114	0.03566224	0.03423827	0.00142397	3.99%
9180	TPCODL	PARADEEP	KED2	MARSHAGHAI	BEDARI ODSSP	14356	11 KV ANTAI	14356201	NEAR TEMPLE 9(PAILO)	5224DT136	250	MIXED	AMI	Yes	67%	106	0.03539932	0.030618	0.00478132	13.51%
9181	TPCODL	PARADEEP	KED2	MARSHAGHAI	BEDARI ODSSP	14356	11 KV ANTAI	14356201	NEAR MARKET 2(SIRASTA MARKET)	5224DT141	100	MIXED	AMI	Yes	67%	202	0.08934138	0.057938	0.03140338	35.15%
9182	TPCODL	PARADEEP	KED2	MARSHAGHAI	BEDARI ODSSP	14356	11 KV PATKURA	14356202	NEAR TEMPLE 3(SRICHANDANPUR)	5224DT315	100	MIXED	AMI	Yes	0%	88	0.0472761	0.033343	0.0139331	29.47%
9183	TPCODL	PARADEEP	KED2	MARSHAGHAI	BEDARI ODSSP	14356	11 KV PATKURA	14356202	NEAR POLICE STATION	5224DT331	100	MIXED	AMI	Yes	100%	129	0.08473242	0.053979	0.03075342	36.29%
9184	TPCODL	PARADEEP	KED2	MARSHAGHAI	BEDARI ODSSP	14356	11 KV PATKURA	14356202	NEAR TEMPLE 6(LEKHANPADA)	5224DT339	100	MIXED	AMI	Yes	67%	73	0.03030796	0.023835	0.00647296	21.36%
9185	TPCODL	PARADEEP	KED2	MARSHAGHAI	BEDARI ODSSP	14356	11 KV PATKURA	14356202	NEAR TEMPLE 8(BUCHANA HARIDASI	5224DT348	100	MIXED	AMI	Yes	100%	96	0.05185306	0.028126	0.02372706	45.76%
9186	TPCODL	PARADEEP	KED2	MARSHAGHAI	GARDAPUR	14168	11 KV GARADAPUR-I	14168201	GARDPUR 6(NEAR BLOCK GARADPUR	5221DT112	250	MIXED	AMI	Yes	100%	98	0.07026428	0.050818	0.01944628	27.68%
9187	TPCODL	PARADEEP	KED2	MARSHAGHAI	GARDAPUR	14168	11 KV GARADAPUR-I	14168201	GOVINDPUR 1(SANI MANDIR)	5221DT143	100	MIXED	AMI	Yes	67%	141	0.0611179	0.045679	0.0154389	25.26%
9188	TPCODL	PARADEEP	KED2	MARSHAGHAI	GARDAPUR	14168	11 KV GARADAPUR-II	14168202	SARTOLA 1(BAMARA LINKA SAHI)	5221DT040	100	MIXED	AMI	Yes	100%	20	0.01947245	0.005504	0.01396845	71.73%
9189	TPCODL	PARADEEP	KED2	MARSHAGHAI	GARDAPUR	14168	11 KV GARADAPUR-II	14168202	TALAKUSMA 4(TALAKUSNAHALATHI	5221DT048	100	MIXED	AMI	Yes	100%	111	0.07352861	0.044479	0.02904961	39.51%
9190	TPCODL	PARADEEP	KED2	MARSHAGHAI	GARDAPUR	14168	11 KV GARADAPUR-II	14168202	BANTALA 2(TENTAL)	5221DT066	100	MIXED	AMI	Yes	100%	129	0.05428636	0.043296	0.01099036	20.25%
9191	TPCODL	PARADEEP	KED2	MARSHAGHAI	GARDAPUR	14168	11 KV GARADAPUR-II	14168202	RAISAR 4(MAHANGA)	5221DT073	100	MIXED	AMI	Yes	100%	38	0.02509396	0.019456	0.00563796	22.47%
9192	TPCODL	PARADEEP	KED2	MARSHAGHAI	GAUDAGAON ODSS	14354	11 KV KARILOPATANA	14354201	BALISAHI 4	5122DT330	250	MIXED	AMI	Yes	67%	134	0.06142108	0.038081	0.02334008	38.00%
9193	TPCODL	PARADEEP	KED2	MARSHAGHAI	GAUDAGAON ODSS	14354	11 KV KARILOPATANA	14354201	JAMAPADA 3	5222DT285	100	MIXED	AMI	Yes	67%	106	0.04400054	0.035777	0.00822354	18.69%
9194	TPCODL	PARADEEP	KED2	MARSHAGHAI	GAUDAGAON ODSS	14354	11 KV KARILOPATANA	14354201	HANTAPADA 5	5222DT312	100	MIXED	AMI	Yes	67%	116	0.03890628	0.031722	0.00718428	18.47%
9195	TPCODL	PARADEEP	KED2	MARSHAGHAI	GAUDAGAON ODSS	14354	11 KV KARILOPATANA	14354201	KARILO PATNA 2	5222DT314	100	MIXED	AMI	Yes	67%	89	0.04230551	0.036808	0.00549751	12.99%
9196	TPCODL	PARADEEP	KED2	MARSHAGHAI	GAUDAGAON ODSS	14354	11 KV KARILOPATANA	14354201	KARILO PATANA 2	5222DT322	100	MIXED	AMI	Yes	67%	73	0.09265448	0.032681	0.05997348	64.73%
9197	TPCODL	PARADEEP	KED2	MARSHAGHAI	GAUDAGAON ODSS	14354	11 KV KARILOPATANA	14354201	HURA SAHI 4	5222DT358	100	MIXED	AMI	Yes	67%	81	0.04723344	0.02395	0.02328344	49.29%

Sl. No.	Zone Name	Circle name	Division name	Name of the Sub-division	Name of the Sub-station	Substation Code	Name of the 11 kV Feeder	Feeder Code	Name of the Location where DT situated	DT code	DT Capacity (kVA)	Predominant consumer type of DT (Domestic/Industrial/Agriculture/Mixed)	Type of metering AMR/AMI/ Communicable/Conventional metered/Unmetered	Status of Meter-whether Functional (Yes/No)	% of data received automatically (if AMR/AMI)	No. of Connected Consumers	Input Energy (MU) (A)	Billed Energy (MU) (B)	Loss (MU) (A-B)	% DT Loss (A-B)/A
9198	TPCODL	PARADEEP	KED2	MARSHAGHAI	GAUDAGAON ODSS	14354	11 KV KARILOPATANA	14354201	NANKAR 1	5223DT328	100	MIXED	AMI	Yes	0%	70	0.07080266	0.021466	0.04933666	69.68%
9199	TPCODL	PARADEEP	KED2	MARSHAGHAI	GOGUA	14161	11 KV NAPANGA	14161202	BATIPADA-100KVA	5135DT120	100	MIXED	AMI	Yes	100%	114	0.02499782	0.024209	0.00078882	3.16%
9200	TPCODL	PARADEEP	KED2	MARSHAGHAI	KORUA	14163	11 KV KORUA	14163201	DHASANPARI	5222DT030	100	MIXED	AMI	Yes	67%	93	0.04964236	0.03972	0.00992236	19.99%
9201	TPCODL	PARADEEP	KED2	MARSHAGHAI	KORUA	14163	11 KV KORUA	14163201	ARILO VILLAGE	5222DT032	100	MIXED	AMI	Yes	67%	93	0.0379784	0.032713	0.0052654	13.86%
9202	TPCODL	PARADEEP	KED2	MARSHAGHAI	KORUA	14163	11 KV KORUA	14163201	ANGARKUR TEMPLE	5222DT036	100	MIXED	AMI	Yes	67%	115	0.05728	0.047175	0.010105	17.64%
9203	TPCODL	PARADEEP	KED2	MARSHAGHAI	KORUA	14163	11 KV KORUA	14163201	HATA SAHI	5222DT040	250	MIXED	AMI	Yes	67%	135	0.06820564	0.055024	0.01318164	19.33%
9204	TPCODL	PARADEEP	KED2	MARSHAGHAI	KORUA	14163	11 KV KORUA	14163201	NAGARIPADA (SCHOOL)	5222DT049	100	MIXED	AMI	Yes	67%	85	0.0373615	0.022116	0.0152455	40.81%
9205	TPCODL	PARADEEP	KED2	MARSHAGHAI	KORUA	14163	11 KV KORUA	14163201	KALABADA 2 DHIASAHI	5222DT061	100	MIXED	AMI	Yes	67%	76	0.02750604	0.02573	0.00177604	6.46%
9206	TPCODL	PARADEEP	KED2	MARSHAGHAI	KORUA	14163	11 KV KORUA	14163201	BEHULA	5222DT074	100	MIXED	AMI	Yes	67%	101	0.03931188	0.031308	0.00800388	20.36%
9207	TPCODL	PARADEEP	KED2	MARSHAGHAI	KORUA	14163	11 KV KORUA	14163201	OUPADA 1	5222DT081	100	MIXED	AMI	Yes	67%	64	0.02927224	0.018099	0.01117324	38.17%
9208	TPCODL	PARADEEP	KED2	MARSHAGHAI	KORUA	14163	11 KV KORUA	14163201	NADIBARIA MANGALA MANDIR	5222DT086	100	MIXED	AMI	Yes	33%	40	0.03127646	0.010928	0.02034846	65.06%
9209	TPCODL	PARADEEP	KED2	MARSHAGHAI	KORUA	14163	11 KV KORUA	14163201	NADIABARI	5222DT089	100	MIXED	AMI	Yes	67%	116	0.04985832	0.036892	0.01296632	26.01%
9210	TPCODL	PARADEEP	KED2	MARSHAGHAI	KORUA	14163	11 KV KORUA	14163201	OSTAPUR	5222DT091	100	MIXED	AMI	Yes	67%	98	0.03142866	0.025495	0.00593366	18.88%
9211	TPCODL	PARADEEP	KED2	MARSHAGHAI	KORUA	14163	11 KV KORUA	14163201	DHANIRAMPUR	5222DT141	100	MIXED	AMI	Yes	67%	105	0.05346836	0.038119	0.01534936	28.71%
9212	TPCODL	PARADEEP	KED2	MARSHAGHAI	KORUA	14163	11 KV NARENDRAPUR	14163202	MADHUSASHAN 1	5222DT005	100	MIXED	AMI	Yes	100%	38	0.02933538	0.015173	0.01416238	48.28%
9213	TPCODL	PARADEEP	KED2	MARSHAGHAI	KORUA	14163	11 KV NARENDRAPUR	14163202	MUSLIM SAI 1	5222DT011	100	MIXED	AMI	Yes	100%	123	0.07454812	0.06699	0.00755812	10.14%
9214	TPCODL	PARADEEP	KED2	MARSHAGHAI	KORUA	14163	11 KV NAGANPUR	14163203	MIRZAPUR	5222DT180	100	MIXED	AMI	Yes	67%	32	0.03444528	0.007583	0.02686228	77.99%
9215	TPCODL	PARADEEP	KED2	MARSHAGHAI	KORUA	14163	11 KV NAGANPUR	14163203	BHARIGOLA NEAR SCHOOL	5222DT206	100	MIXED	AMI	Yes	67%	100	0.030321	0.021337	0.008984	29.63%
9216	TPCODL	PARADEEP	KED2	MARSHAGHAI	KORUA	14163	11 KV NAGANPUR	14163203	PANASUAPADA SWAIN SAHI	5222DT247	100	MIXED	AMI	Yes	67%	114	0.05051188	0.028865	0.02164688	42.86%
9217	TPCODL	PARADEEP	KED2	MARSHAGHAI	KORUA	14163	11 KV NAGANPUR	14163203	SANABATERA NEAR TEMPLE	5222DT256	100	MIXED	AMI	Yes	67%	74	0.04472824	0.016405	0.02832324	63.32%
9218	TPCODL	PARADEEP	KED2	MARSHAGHAI	KORUA	14163	11 KV BANAKHUDA	14163204	NIRCHAINT 1(CHASHKUNDA)	5221DT207	100	MIXED	AMI	Yes	33%	85	0.03236856	0.026487	0.00588156	18.17%
9219	TPCODL	PARADEEP	KED2	MARSHAGHAI	KORUA	14163	11 KV BANAKHUDA	14163204	BANAKUND 1	5221DT213	100	MIXED	AMI	Yes	100%	74	0.02679371	0.02388945	0.00290426	10.84%
9220	TPCODL	PARADEEP	KED2	MARSHAGHAI	KORUA	14163	11 KV BANAKHUDA	14163204	TENDAKUDA 8(KATKIA MOHLA 2)	5221DT222	250	MIXED	AMI	Yes	67%	166	0.14796876	0.088642	0.05932676	40.09%
9221	TPCODL	PARADEEP	KED2	MARSHAGHAI	KORUA	14163	11 KV BANAKHUDA	14163204	TENDAKUDA 9(MIRZA MOHLA)	5221DT227	100	MIXED	AMI	Yes	67%	111	0.13887656	0.052476	0.08640056	62.21%
9222	TPCODL	PARADEEP	KED2	MARSHAGHAI	KORUA	14163	11 KV BANAKHUDA	14163204	ARABAL 1	5221DT240	100	MIXED	AMI	Yes	67%	87	0.03048026	0.021156	0.00932426	30.59%
9223	TPCODL	PARADEEP	KED2	MARSHAGHAI	LUNA	14166	11 KV PATAKURA-1(OLD)	14166201	NEAR TALASANGA 2	5224DT008	100	MIXED	AMI	Yes	100%	98	0.03890062	0.032981	0.00591962	15.22%
9224	TPCODL	PARADEEP	KED2	MARSHAGHAI	LUNA	14166	11 KV PATAKURA-1(OLD)	14166201	MANDIR K PASS 2 (SANTORI)	5224DT023	100	MIXED	AMI	Yes	67%	100	0.04201826	0.024352	0.01766626	42.04%
9225	TPCODL	PARADEEP	KED2	MARSHAGHAI	LUNA	14166	11 KV ANKO	14166202	ORISHA 1	5222DT155	100	MIXED	AMI	Yes	0%	52	0.02369604	0.016026	0.00767004	32.37%
9226	TPCODL	PARADEEP	KED2	MARSHAGHAI	LUNA	14166	11 KV ANKO	14166202	NEAR TEMPLE 4 (PARAKULA D.T.R)	5224DT168	100	MIXED	AMI	Yes	67%	170	0.05678648	0.049904	0.00688248	12.12%
9227	TPCODL	PARADEEP	KED2	MARSHAGHAI	LUNA	14166	11 KV ANKO	14166202	NEAR PULL 4(PIKAKALI)	5224DT172	100	MIXED	AMI	Yes	67%	76	0.02540666	0.020468	0.00493866	19.44%
9228	TPCODL	PARADEEP	KED2	MARSHAGHAI	LUNA	14166	11 KV ANKO	14166202	NEAR KAPILA MUNI TEMPLE(PIKAKAL	5224DT173	100	MIXED	AMI	Yes	67%	51	0.02179238	0.012258	0.00953438	43.75%
9229	TPCODL	PARADEEP	KED2	MARSHAGHAI	LUNA	14166	11 KV ANKO	14166202	NEAR PULL 6 (PODANA)	5224DT180	100	MIXED	AMI	Yes	67%	134	0.04775466	0.039861	0.00789366	16.53%
9230	TPCODL	PARADEEP	KED2	MARSHAGHAI	LUNA	14166	11 KV ANKO	14166202	NEWR SCHOOP 5 (MANDIA)	5224DT197	100	MIXED	AMI	Yes	67%	106	0.05559302	0.026445	0.02914802	52.43%
9231	TPCODL	PARADEEP	KED2	MARSHAGHAI	LUNA	14166	11 KV ANKO	14166202	NEAR ODANGA MARKET	5224DT200	100	MIXED	AMI	Yes	0%	233	0.07363398	0.0708254	0.00280858	3.81%
9232	TPCODL	PARADEEP	KED2	MARSHAGHAI	LUNA	14166	11 KV ANKO	14166202	NEAR TEMPLE 6(BINDOL)	5224DT207	100	MIXED	AMI	Yes	67%	48	0.04047722	0.008729	0.03174822	78.43%
9233	TPCODL	PARADEEP	KED2	MARSHAGHAI	LUNA	14166	11 KV ANKO	14166202	NARAYANPUR VILLAGE 4	5224DT269	100	MIXED	AMI	Yes	67%	75	0.01997938	0.017032	0.00294738	14.75%
9234	TPCODL	PARADEEP	KED2	MARSHAGHAI	LUNA	14166	11 KV NALADIA	14166205	CHHANDA	5212DT080	100	MIXED	AMI	Yes	67%	167	0.06158224	0.04289737	0.01868487	30.34%
9235	TPCODL	PARADEEP	KED2	MARSHAGHAI	MARSAGHAI	14165	11 KV MARSHAGHAI	14165202	KASOUTI	5223DT154	100	MIXED	AMI	Yes	67%	66	0.07805336	0.031359	0.04669436	59.82%
9236	TPCODL	PARADEEP	KED2	MARSHAGHAI	MARSAGHAI	14165	11 KV MARSHAGHAI	14165202	MANIKUNDA	5223DT160	100	MIXED	AMI	Yes	67%	156	0.05614392	0.0522	0.00394392	7.02%
9237	TPCODL	PARADEEP	KED2	MARSHAGHAI	MARSAGHAI	14165	11 KV MARSHAGHAI	14165202	MARSHAGHAI CHAURAHA	5223DT171	100	MIXED	AMI	Yes	0%	24	0.07187396	0.026752	0.04512196	62.78%
9238	TPCODL	PARADEEP	KED2	MARSHAGHAI	MARSAGHAI	14165	11 KV MARSHAGHAI	14165202	BALI KASOTI 100KVA	5223DT174	100	MIXED	AMI	Yes	0%	153	0.07228228	0.053849	0.01843328	25.50%
9239	TPCODL	PARADEEP	KED2	MARSHAGHAI	MARSAGHAI	14165	11 KV MARSHAGHAI	14165202	MARSA HIGH SUPPLY AGENCY K PASS	5223DT182	250	MIXED	AMI	Yes	0%	118	0.14100932	0.065928	0.07508132	53.25%
9240	TPCODL	PARADEEP	KED2	MARSHAGHAI	MARSAGHAI	14165	11 KV MARSHAGHAI	14165202	SCHOOL KE PICHE	5223DT184	100	MIXED	AMI	Yes	67%	159	0.06732572	0.057176	0.01014972	15.08%
9241	TPCODL	PARADEEP	KED2	MARSHAGHAI	MARSAGHAI	14165	11 KV SILIPUR	14165203	SECTION NAME SHOULD BE MARSHA	5213DT004	100	MIXED	AMI	Yes	67%	155	0.05910368	0.045819	0.01328468	22.48%
9242	TPCODL	PARADEEP	KED2	MARSHAGHAI	MARSAGHAI	14165	11 KV SILIPUR	14165203	SILIPUR 5	5223DT084	63	MIXED	AMI	Yes	0%	77	0.06529844	0.046358	0.01894044	29.01%
9243	TPCODL	PARADEEP	KED2	MARSHAGHAI	MARSAGHAI	14165	11 KV SILIPUR	14165203	KANPUR 2	5223DT089	100	MIXED	AMI	Yes	0%	177	0.0780439	0.064398	0.0136459	17.48%
9244	TPCODL	PARADEEP	KED2	MARSHAGHAI	NUAPOLA / NABAPA	14181	11 KV MANDASAHI	14181202	NACHIPUR OLD	5324DT118	100	MIXED	AMI	Yes	67%	77	0.03950307	0.02623	0.01327307	33.60%
9245	TPCODL	PARADEEP	KED2	MARSHAGHAI	ORIKANTA	14212	11 KV BILAHATA	14212202	AGRICULTURAL	3523DT548	100	MIXED	AMI	Yes	67%	54	0.02904994	0.019188	0.00986194	33.95%
9246	TPCODL	PARADEEP	KED2	MARSHAGHAI	THAURI ODSSP	14355	11 KV KURTANGA	14355201	THAURI 1	5223DT315	100	MIXED	AMI	Yes	67%	70	0.04261576	0.023065	0.01955076	45.88%
9247	TPCODL	PARADEEP	KED2	MARSHAGHAI	THAURI ODSSP	14355	11 KV KURTANGA	14355201	THAURI 7	5223DT321	100	MIXED	AMI	Yes	67%	88	0.05236184	0.021214	0.03114784	59.49%
9248	TPCODL	PARADEEP	KED2	MARSHAGHAI	THAURI ODSSP	14355	11 KV KURTANGA	14355201	THAURI 8	5223DT322	100	MIXED	AMI	Yes	67%	142	0.05516135	0.038454	0.01670735	30.29%
9249	TPCODL	PARADEEP	KED2	MARSHAGHAI	THAURI ODSSP	14355	11 KV ORATGHAT	14355202	NEAR COLLEGE	5223DT237	100	MIXED	AMI	Yes	67%	155	0.04700509	0.03493	0.01207509	25.69%
9250	TPCODL	PARADEEP	KED2	MARSHAGHAI	THAURI ODSSP	14355	11 KV ORATGHAT	14355202	VILLAGE GYASPUR 2	5223DT243	100	MIXED	AMI	Yes	0%	99	0.03318167	0.022638	0.01054367	31.78%
9251	TPCODL	PARADEEP	KED2	MARSHAGHAI	THAURI ODSSP	14355	11 KV ORATGHAT	14355202	NEAR PULL 2	5223DT247	100	MIXED	AMI	Yes	0%	136	0.04770891	0.028437	0.01927191	40.39%
9252	TPCODL	PARADEEP	KED2	MARSHAGHAI	THAURI ODSSP	14355	11 KV ORATGHAT	14355202	NEAR PULL 3	5223DT251	100	MIXED	AMI	Yes	67%	174	0.06189344	0.04625	0.01564344	25.27%
9253	TPCODL	PARADEEP	KED2	MARSHAGHAI	THAURI ODSSP	14355	11 KV ORATGHAT	14355202	NEAR WOOD MILL	5223DT254	100	MIXED	AMI	Yes	67%	59	0.01711206	0.011351	0.00576106	33.67%
9254	TPCODL	PARADEEP	KED2	MARSHAGHAI	THAURI ODSSP	14355	11 KV ORATGHAT	14355202	NEAR PULL 6	5223DT262	100	MIXED	AMI	Yes	33%	98	0.04302509	0.025725	0.01730009	40.21%
9255	TPCODL	PARADEEP	KED2	MARSHAGHAI	THAURI ODSSP	14355	11 KV ORATGHAT	14355202	NEAR SCHOOL 1	5223DT267	100	MIXED	AMI	Yes	67%	162	0.080149	0.051175	0.028974	36.15%
9256	TPCODL	PARADEEP	KED2	MARSHAGHAI	THAURI ODSSP	14355	11 KV ORATGHAT	14355202	NEAR BANK OF INDIA	5223DT269	100	MIXED	AMI	Yes	67%	140	0.04873254	0.041255	0.00747754	15.34%
9257	TPCODL	PARADEEP	KED2	MARSHAGHAI	THAURI ODSSP	14355	11 KV ORATGHAT	14355202	NEAR PULL 7	5223DT271	100	MIXED	AMI	Yes	33%	253	0.07363694	0.058581	0.01505594	20.45%
9258	TPCODL	PARADEEP	KED2	MARSHAGHAI	THAURI ODSSP	14355	11 KV ORATGHAT	14355202	NEAR SCHOOL 3	5223DT285	100	MIXED	AMI	Yes	67%	134	0.03978007	0.035168	0.00461207	11.59%
9259	TPCODL	PARADEEP	PDP	KUJANGA	KRISHNANDAPUR (S	14345	11 kV KRISHNANANDAPU	14345201	KRISNANDAPUR 35	5432DT168	100	MIXED	AMI	Yes	0%	148	0.13691062	0.100928	0.03598262	26.28%
9260	TPCODL	PARADEEP	PDP	KUJANGA	ERASAMA	14178	11 KV ERASAMA	14178203	NEAR ERSAMA TEHSIL 1	5431DT022	250	MIXED	AMI	Yes	100%	191	0.09348472	0.065646	0.02783872	29.78%
9261	TPCODL	PARADEEP	PDP	KUJANGA	GORADA ODSSP	14344	11 KV PANDUA	14344201	ODHANKRO 1	5413DT356	100	MIXED	AMI	Yes	100%	75	0.02197842	0.0188	0.00317842	14.46%
9262	TPCODL	PARADEEP	PDP	KUJANGA	GORADA ODSSP	14344	11 KV PANDUA	14344201	NEAR BISWAL HOUSE	5413DT418	100	MIXED	AMI	Yes	100%	63	0.0251526	0.021379	0.0037736	15.00%
9263	TPCODL	PARADEEP	PDP	KUJANGA	GORADA ODSSP	14344	11 KV BAILO	14344202	OKHLA	5413DT175	100	MIXED	AMI	Yes	100%	119	0.04728854	0.034467	0.01282154	27.11%
9264	TPCODL	PARADEEP	PDP	KUJANGA	GORADA ODSSP	14344	11 KV BAILO	14344202	CHANDAPATA 2	5413DT176	100	MIXED	AMI	Yes	100%	140	0.05358168	0.03776	0.01582168	29.53%
9265	TPCODL	PARADEEP	PDP	KUJANGA	GORADA ODSSP	14344	11 KV BAILO	14344202	DASIPURU 2	5413DT197	100	MIXED	AMI	Yes	100%	188	0.05924258	0.040268	0.01897458	32.03%
9266	TPCODL	PARADEEP	PDP	KUJANGA	GORADA ODSSP	14344	11 KV BAILO	14344202	NEAR MAHIMA ALEKHA ASHRAM 4	5413DT408	100	MIXED	AMI	Yes	100%	84	0.03813744	0.026652	0.01148544	30.12%
9267	TPCODL	PARADEEP	PDP	KUJANGA	GORADA ODSSP	14344	11 KV NUAPOKHARI	14344203	BATILO	5413DT290	100	MIXED	AMI	Yes	33%	122	0.07924124	0.04586	0.03338124	42.13%
9268	TPCODL	PARADEEP	PDP	KUJANGA	GORADA ODSSP	14344	11 KV NUAPOKHARI	14344203	OUPARA(GOBINDA MOHANTY)	5413DT291	100	MIXED	AMI	Yes	100%	91	0.04826638	0.033212	0.01505438	31.19%
9269	TPCODL	PARADEEP	PDP	KUJANGA	GORADA ODSSP	14344	11 KV NUAPOKHARI	14344203	IRI KUNDAL DAGARPADA	5413DT301	100	MIXED	AMI	Yes	0%	160	0.06599742	0.064109	0.00188842	2.86%
9270	TPCODL	PARADEEP	PDP	KUJANGA	GORADA ODSSP	14344	11 KV NUAPOKHARI	14344203	BODHEI(AKHANDALA MANI SAW MIL	5413DT308	250	MIXED	AMI	Yes	100%	7	0.0446298	0.034594	0.0100358	22.49%

Sl. No.	Zone Name	Circle name	Division name	Name of the Sub-division	Name of the Sub-station	Substation Code	Name of the 11 kV Feeder	Feeder Code	Name of the Location where DT situated	DT code	DT Capacity (kVA)	Predominant consumer type of DT (Domestic/Industrial/Agriculture/Mixed)	Type of metering AMR/AMI/ Communicable/Conventional metered/Unmetered	Status of Meter- whether Functional (Yes/No)	% of data received automatically (if AMR/AMI)	No. of Connected Consumers	Input Energy (MU) (A)	Billed Energy (MU) (B)	Loss (MU) (A-B)	% DT Loss (A-B)/A
9271	TPCODL	PARADEEP	PDP	KUJANGA	GORADA ODSSP	14344	11 KV NUAPOKHARI	14344203	BEMALEI	5413DT309	100	MIXED	AMI	Yes	0%	144	0.08252648	0.059821	0.02270548	27.51%
9272	TPCODL	PARADEEP	PDP	KUJANGA	GORADA ODSSP	14344	11 KV NUAPOKHARI	14344203	BODHEI(SAW MILL)	5413DT310	500	MIXED	AMI	Yes	100%	14	0.05800488	0.050007	0.00799788	13.79%
9273	TPCODL	PARADEEP	PDP	KUJANGA	GORADA ODSSP	14344	11 KV NUAPOKHARI	14344203	CHATOLA SCHOOL	5413DT319	100	MIXED	AMI	Yes	100%	96	0.03973968	0.031268	0.00847168	21.32%
9274	TPCODL	PARADEEP	PDP	KUJANGA	GORADA ODSSP	14344	11 KV NUAPOKHARI	14344203	BANDHABATI 4	5413DT401	100	MIXED	AMI	Yes	100%	37	0.0116622	0.009035	0.0026272	22.53%
9275	TPCODL	PARADEEP	PDP	KUJANGA	JAGANNATHPUR OD	14340	11 KV JAGANNATHPUR	14340201	BARABATI 5	5413DT165	250	MIXED	AMI	Yes	100%	93	0.09422698	0.051292	0.04293498	45.57%
9276	TPCODL	PARADEEP	PDP	KUJANGA	KANAKPUR ODSSP	14341	11 KV KANAKPUR-2(KAN	14341201	MARDAL 2	5433DT257	100	MIXED	AMI	Yes	67%	88	0.0256305	0.02027968	0.00535082	20.88%
9277	TPCODL	PARADEEP	PDP	KUJANGA	KANAKPUR ODSSP	14341	11 KV MULISINGH	14341203	HARISHINGHPUR	5433DT219	63	MIXED	AMI	Yes	67%	82	0.05919218	0.03672	0.02247218	37.96%
9278	TPCODL	PARADEEP	PDP	KUJANGA	KOTHI (JHIMANI) OD	14346	11 KV KOTHI	14346203	MANGARAJPUR-1	5421DT223	100	MIXED	AMI	Yes	67%	90	0.092109	0.028848	0.063261	68.68%
9279	TPCODL	PARADEEP	PDP	KUJANGA	KUJANGA	14179	11 KV TALADANDA	14179201	NEAR FURNITURE HOUSE	5412DT002	250	MIXED	AMI	Yes	67%	176	0.17055296	0.088591	0.08196196	48.06%
9280	TPCODL	PARADEEP	PDP	KUJANGA	KUJANGA	14179	11 KV TALADANDA	14179201	NEAR ROAD 1(SANOHAPUR-1)	5412DT022	100	MIXED	AMI	Yes	0%	43	0.09296662	0.022665	0.07030162	75.62%
9281	TPCODL	PARADEEP	PDP	KUJANGA	KUJANGA	14179	11 KV TALADANDA	14179201	CHARADIA	5412DT035	100	MIXED	AMI	Yes	100%	102	0.08630984	0.032661	0.05364884	62.16%
9282	TPCODL	PARADEEP	PDP	KUJANGA	KUJANGA	14179	11 KV TALADANDA	14179201	MALLASAHI 1	5412DT036	100	MIXED	AMI	Yes	67%	134	0.07231592	0.049257	0.02305892	31.89%
9283	TPCODL	PARADEEP	PDP	KUJANGA	KUJANGA	14179	11 KV TALADANDA	14179201	AIRTEL	5412DT044	100	MIXED	AMI	Yes	0%	63	0.04950078	0.036973	0.01252778	25.31%
9284	TPCODL	PARADEEP	PDP	KUJANGA	KUJANGA	14179	11 KV TALADANDA	14179201	ZILLAN SAHI NO-2	5412DT051	100	MIXED	AMI	Yes	67%	111	0.0626827	0.034464	0.0282187	45.02%
9285	TPCODL	PARADEEP	PDP	KUJANGA	KUJANGA	14179	11 KV TALADANDA	14179201	ZILLAN SAHI NO-1	5412DT052	100	MIXED	AMI	Yes	67%	103	0.05618096	0.026825	0.02935596	52.25%
9286	TPCODL	PARADEEP	PDP	KUJANGA	KUJANGA	14179	11 KV SANTARA	14179202	BIPIN CHAKA 1	5412DT113	100	MIXED	AMI	Yes	33%	101	0.08509756	0.054667	0.03043056	35.76%
9287	TPCODL	PARADEEP	PDP	KUJANGA	KUJANGA	14179	11 KV SANTARA	14179202	KUJANGA	5412DT119	100	MIXED	AMI	Yes	67%	54	0.08237656	0.03587	0.04650656	56.46%
9288	TPCODL	PARADEEP	PDP	KUJANGA	KUJANGA	14179	11 KV SANTARA	14179202	HANUMAN TEMPLE	5412DT123	100	MIXED	AMI	Yes	67%	80	0.04780976	0.024335	0.02347476	49.10%
9289	TPCODL	PARADEEP	PDP	KUJANGA	KUJANGA	14179	11 KV SANTARA	14179202	BIPIN CHAKA 2	5421DT093	100	MIXED	AMI	Yes	33%	101	0.08876784	0.084549	0.00421884	4.75%
9290	TPCODL	PARADEEP	PDP	KUJANGA	KUJANGA	14179	11 KV SANTARA	14179202	BALARAM PUR KARAN SAHI 2	5421DT097	100	MIXED	AMI	Yes	0%	89	0.07120974	0.047091	0.02411874	33.87%
9291	TPCODL	PARADEEP	PDP	KUJANGA	KUJANGA	14179	11 KV CHATUA	14179203	CHATUA 2	5411DT127	100	MIXED	AMI	Yes	67%	79	0.04336332	0.032547	0.01081632	24.94%
9292	TPCODL	PARADEEP	PDP	KUJANGA	KUJANGA	14179	11 KV CHATUA	14179203	SANAGABAPUR	5411DT225	100	MIXED	AMI	Yes	67%	57	0.02802924	0.015196	0.01283324	45.79%
9293	TPCODL	PARADEEP	PDP	KUJANGA	KUJANGA	14179	11 KV CHATUA	14179203	GUGANDA	5411DT240	100	MIXED	AMI	Yes	67%	65	0.0284203	0.021551	0.0068693	24.17%
9294	TPCODL	PARADEEP	PDP	KUJANGA	KUJANGA	14179	11 KV CHATUA	14179203	BARABATIA	5411DT272	100	MIXED	AMI	Yes	67%	99	0.03492848	0.025945	0.00898348	25.72%
9295	TPCODL	PARADEEP	PDP	KUJANGA	KUJANGA	14179	11 KV CHATUA	14179203	BAMADEIPUR	5411DT286	100	MIXED	AMI	Yes	67%	103	0.0578262	0.030116	0.0277102	47.92%
9296	TPCODL	PARADEEP	PDP	KUJANGA	KUJANGA	14179	11 KV CHATUA	14179203	NEAR HANUMAN TEMPLE 2	5412DT143	100	MIXED	AMI	Yes	67%	104	0.05424111	0.034245	0.01999611	36.87%
9297	TPCODL	PARADEEP	PDP	KUJANGA	KUJANGA	14179	11 KV CHATUA	14179203	KARATUTHA	5412DT162	100	MIXED	AMI	Yes	67%	80	0.0581488	0.02739	0.0307588	52.90%
9298	TPCODL	PARADEEP	PDP	KUJANGA	KUJANGA	14179	11 KV CHATUA	14179203	NEAR HANUMAN TEMPLE 8(AKAKHIA	5412DT164	100	MIXED	AMI	Yes	67%	79	0.03439008	0.020919	0.01347108	39.17%
9299	TPCODL	PARADEEP	PDP	KUJANGA	KUJANGA	14179	11 KV CHATUA	14179203	KUNJAKETHI 1 (HATAPADIA)	5431DT802	100	MIXED	AMI	Yes	33%	65	0.05081774	0.011295	0.03952274	77.77%
9300	TPCODL	PARADEEP	PDP	KUJANGA	KUJANGA	14179	11 KV KUJANGA BAZAR	14179204	SUBSTATION 1	5412DT108	250	MIXED	AMI	Yes	100%	150	0.139128	0.107946	0.031182	22.41%
9301	TPCODL	PARADEEP	PDP	KUJANGA	KUJANGA	14179	11 KV KUJANGA BAZAR	14179204	SUBSTATION 2	5412DT109	250	MIXED	AMI	Yes	100%	102	0.13450636	0.076899	0.05760736	42.83%
9302	TPCODL	PARADEEP	PDP	KUJANGA	RAHAMA	14177	11 KV RAHAMA	14177201	RAHAMA 9	5413DT042	100	MIXED	AMI	Yes	100%	39	0.0527911	0.030359	0.0224321	42.49%
9303	TPCODL	PARADEEP	PDP	KUJANGA	RAHAMA	14177	11 KV RAHAMA	14177201	JATIYA GADI 2	5413DT069	100	MIXED	AMI	Yes	100%	74	0.03833478	0.02523	0.01310478	34.19%
9304	TPCODL	PARADEEP	PDP	KUJANGA	RAHAMA	14177	11 KV RAHAMA	14177201	NIMCHANA 1	5413DT070	100	MIXED	AMI	Yes	100%	188	0.07270884	0.061892	0.01081684	14.88%
9305	TPCODL	PARADEEP	PDP	KUJANGA	RAHAMA	14177	11 KV RAHAMA	14177201	NIMCHANA 7	5413DT078	100	MIXED	AMI	Yes	100%	85	0.03991604	0.030473	0.00944304	23.66%
9306	TPCODL	PARADEEP	PDP	KUJANGA	RAHAMA	14177	11 KV RAHAMA	14177201	MANI JANGA 7	5413DT080	100	MIXED	AMI	Yes	0%	116	0.06077268	0.059266	0.00150668	2.48%
9307	TPCODL	PARADEEP	PDP	KUJANGA	RAHAMA	14177	11 KV RAHAMA	14177201	TRITAL PHONAGODA 4	5413DT090	100	MIXED	AMI	Yes	100%	144	0.06654092	0.054161	0.01237992	18.60%
9308	TPCODL	PARADEEP	PDP	KUJANGA	RAHAMA	14177	11 KV PANKAPAL	14177202	TARAMANPUR	5413DT216	100	MIXED	AMI	Yes	33%	102	0.06517384	0.044699	0.02047484	31.42%
9309	TPCODL	PARADEEP	PDP	KUJANGA	RAHAMA	14177	11 KV PANKAPAL	14177202	CHANDAPUR 2	5413DT220	100	MIXED	AMI	Yes	67%	61	0.03406694	0.029329	0.00473794	13.91%
9310	TPCODL	PARADEEP	PDP	KUJANGA	RAHAMA	14177	11 KV PANKAPAL	14177202	PANKPAL 5	5413DT232	100	MIXED	AMI	Yes	67%	106	0.04576154	0.03115	0.01461154	31.93%
9311	TPCODL	PARADEEP	PDP	KUJANGA	RAHAMA	14177	11 KV PANKAPAL	14177202	PANKAPAL 7	5413DT238	100	MIXED	AMI	Yes	67%	71	0.07228658	0.050318	0.02196858	30.39%
9312	TPCODL	PARADEEP	PDP	KUJANGA	RAHAMA	14177	11 KV PANKAPAL	14177202	PANKAPAL 13	5413DT247	100	MIXED	AMI	Yes	0%	59	0.06736444	0.017545	0.04981944	73.96%
9313	TPCODL	PARADEEP	PDP	KUJANGA	RAHAMA	14177	11 KV PANKAPAL	14177202	NEAR BABA BUDHA PIRA MAJHAR	5413DT250	100	MIXED	AMI	Yes	67%	30	0.01218256	0.008244	0.00393856	32.33%
9314	TPCODL	PARADEEP	PDP	KUJANGA	RAHAMA	14177	11 KV PANKAPAL	14177202	AGAPAL 2	5413DT254	63	MIXED	AMI	Yes	67%	54	0.02599848	0.016803	0.00919548	35.37%
9315	TPCODL	PARADEEP	PDP	KUJANGA	RAHAMA	14177	11 KV PANKAPAL	14177202	REPURPATANA	5413DT257	100	MIXED	AMI	Yes	67%	133	0.0696988	0.043197	0.0265018	38.02%
9316	TPCODL	PARADEEP	PDP	KUJANGA	RAHAMA	14177	11 KV PANKAPAL	14177202	PAIKASTA 2	5413DT263	100	MIXED	AMI	Yes	67%	122	0.05956326	0.039506	0.02005726	33.67%
9317	TPCODL	PARADEEP	PDP	KUJANGA	RAHAMA	14177	11 KV PANKAPAL	14177202	PAIKASTA 4	5413DT265	100	MIXED	AMI	Yes	0%	18	0.01475598	0.003608	0.01114798	75.55%
9318	TPCODL	PARADEEP	PDP	KUJANGA	RAHAMA	14177	11 KV PANKAPAL	14177202	AGAPAL 5	5413DT267	100	MIXED	AMI	Yes	0%	72	0.09534024	0.023219	0.07212124	75.65%
9319	TPCODL	PARADEEP	PDP	KUJANGA	RAHAMA	14177	11 KV PANKAPAL	14177202	AGAPAL 6	5413DT268	100	MIXED	AMI	Yes	67%	117	0.06423168	0.03649	0.02774168	43.19%
9320	TPCODL	PARADEEP	PDP	KUJANGA	RAHAMA	14177	11 KV PANKAPAL	14177202	AGAPAL 7	5413DT269	100	MIXED	AMI	Yes	67%	87	0.03965708	0.02742	0.01223708	30.86%
9321	TPCODL	PARADEEP	PDP	KUJANGA	RAHAMA	14177	11 KV BEHEDA	14177203	BAHARADA 1	5413DT118	100	MIXED	AMI	Yes	0%	74	0.04483902	0.026476	0.01836302	40.95%
9322	TPCODL	PARADEEP	PDP	KUJANGA	RAHAMA	14177	11 KV BEHEDA	14177203	BAHARADA 2	5413DT119	100	MIXED	AMI	Yes	67%	50	0.02335158	0.020215	0.00313658	13.43%
9323	TPCODL	PARADEEP	PDP	KUJANGA	RAHAMA	14177	11 KV BEHEDA	14177203	BAHARADA 5	5413DT124	100	MIXED	AMI	Yes	0%	39	0.03882238	0.024781	0.01404138	36.17%
9324	TPCODL	PARADEEP	PDP	KUJANGA	RAHAMA	14177	11 KV BEHEDA	14177203	LATHANGA	5413DT136	100	MIXED	AMI	Yes	67%	171	0.07939874	0.060243	0.01915574	24.13%
9325	TPCODL	PARADEEP	PDP	KUJANGA	RAHAMA	14177	11 KV BEHEDA	14177203	KHARDA	5413DT152	63	MIXED	AMI	Yes	100%	36	0.03904082	0.015601	0.02343982	60.04%
9326	TPCODL	PARADEEP	PDP	KUJANGA	RAHAMA	14177	11 KV MEDICAL(RAHAMA	14177204	NEAR RAILWAY LINE	5413DT005	100	MIXED	AMI	Yes	33%	55	0.06243366	0.03925	0.02318366	37.13%
9327	TPCODL	PARADEEP	PDP	KUJANGA	RAHAMA	14177	11 KV MEDICAL(RAHAMA	14177204	MEDICAL	5413DT019	250	MIXED	AMI	Yes	100%	48	0.08848924	0.036376	0.05211324	58.89%
9328	TPCODL	PARADEEP	PDP	KUJANGA	TRILOCHANPUR OD	14342	11 KV SANDHAKUDA	14342203	SANDHAKUDA BANGALI SAHI	5422DT356	100	MIXED	AMI	Yes	67%	147	0.06906866	0.034399	0.03466966	50.20%
9329	TPCODL	PARADEEP	PDP	KUJANGA	TRILOCHANPUR OD	14342	11 KV SANDHAKUDA	14342203	SANDHAKUDA 1	5422DT365	500	MIXED	AMI	Yes	0%	466	0.14125872	0.115938	0.02532072	17.93%
9330	TPCODL	PARADEEP	PDP	KUJANGA	TRILOCHANPUR OD	14342	11 KV BALITUTHA	14342204	MARKET 2	5411DT193	100	MIXED	AMI	Yes	67%	113	0.0403591	0.039116	0.0012431	3.08%
9331	TPCODL	PARADEEP	PDP	KUJANGA	TRILOCHANPUR OD	14342	11 KV BALITUTHA	14342204	BALITUTHA 2(BALISAHI)	5411DT196	100	MIXED	AMI	Yes	100%	86	0.0800068	0.031022	0.0489848	61.23%
9332	TPCODL	PARADEEP	PDP	KUJANGA	TRILOCHANPUR OD	14342	11 KV BALITUTHA	14342204	NEAR WATER TANK 3	5411DT209	100	MIXED	AMI	Yes	67%	88	0.03624132	0.025689	0.01055232	29.12%
9333	TPCODL	PARADEEP	PDP	PARADEEP	BIJAYCHANDRAPUR	14226	11 KV ATHARBANKI MED	14226201	TARINI MANDIR 2	5422DT180	250	MIXED	AMI	Yes	67%	11	0.13061522	0.033951	0.09666422	74.01%
9334	TPCODL	PARADEEP	PDP	PARADEEP	BIJAYCHANDRAPUR	14226	11 KV ATHARBANKI MED	14226201	JENAGADA 2	5422DT183	250	MIXED	AMI	Yes	100%	51	0.15972312	0.116951	0.04277212	26.78%
9335	TPCODL	PARADEEP	PDP	PARADEEP	BIJAYCHANDRAPUR	14226	11 KV ATHARBANKI MED	14226201	ITARANIGADA 3	5422DT195	250	MIXED	AMI	Yes	100%	133	0.47089512	0.272397	0.19849812	42.15%
9336	TPCODL	PARADEEP	PDP	PARADEEP	BIJAYCHANDRAPUR	14226	11 KV ATHARBANKI MED	14226201	NEAR ATHARABANKI, FISH MARKET	5422DT207	250	MIXED	AMI	Yes	33%	200	0.06990856	0.048167	0.02174156	31.10%
9337	TPCODL	PARADEEP	PDP	PARADEEP	BIJAYCHANDRAPUR	14226	11 KV ATHARBANKI MED	14226201	CENTRAL BANK	5422DT208	250	MIXED	AMI	Yes	100%	63	0.02990988	0.026293	0.00361688	12.09%
9338	TPCODL	PARADEEP	PDP	PARADEEP	BIJAYCHANDRAPUR	14226	11 KV ATHARBANKI MED	14226201	NEAR ATHARBANKI BUILDING MARKE	5422DT210	250	MIXED	AMI	Yes	100%	184	0.0517128	0.049453	0.0022598	4.37%
9339	TPCODL	PARADEEP	PDP	PARADEEP	BIJAYCHANDRAPUR	14226	11 KV ATHARBANKI MED	14226201	BAWARIYAPARIDA 1	5422DT212	100	MIXED	AMI	Yes	67%	227	0.05649424	0.03924	0.01725424	30.54%
9340	TPCODL	PARADEEP	PDP	PARADEEP	BIJAYCHANDRAPUR	14226	11 KV ATHARBANKI MED	14226201	BAWARIYAPARIDA 2	5422DT213	100	MIXED	AMI	Yes	67%	179	0.0510352	0.037043	0.0139922	27.42%
9341	TPCODL	PARADEEP	PDP	PARADEEP	BIJAYCHANDRAPUR	14226	11 KV ATHARBANKI MED	14226201	DAIDOCK	5422DT216	250	MIXED	AMI	Yes	0%	82	0.05805416	0.045149	0.01290516	22.23%
9342	TPCODL	PARADEEP	PDP	PARADEEP	BIJAYCHANDRAPUR	14226	11 KV ATHARBANKI MED	14226201	ATHARABANKI 2	5422DT220	100	MIXED	AMI	Yes	100%	65	0.09725822	0.044054	0.05320422	54.70%
9343	TPCODL	PARADEEP	PDP	PARADEEP	BIJAYCHANDRAPUR	14226	11 KV ATHARBANKI MED	14226201	BALI PLAT	5422DT227	250	MIXED	AMI	Yes	100%	67	0.03373222	0.025897	0.00783522	23.23%

Sl. No.	Zone Name	Circle name	Division name	Name of the Sub-division	Name of the Sub-station	Substation Code	Name of the 11 kV Feeder	Feeder Code	Name of the Location where DT situated	DT code	DT Capacity (kVA)	Predominant consumer type of DT (Domestic/Industrial/Agriculture/Mixed)	Type of metering AMR/AMI/ Communicable/Conventional metered/Unmetered	Status of Meter-whether Functional (Yes/No)	% of data received automatically (if AMR/AMI)	No. of Connected Consumers	Input Energy (MU) (A)	Billed Energy (MU) (B)	Loss (MU) (A-B)	% DT Loss (A-B)/A
9344	TPCODL	PARADEEP	PDP	PARADEEP	BIJAYCHANDRAPUR	14226	11 KV ATHARBANKI MED	14226201	ATHARABANKI 1	5422DT228	250	MIXED	AMI	Yes	100%	141	0.05530792	0.039372	0.01593592	28.81%
9345	TPCODL	PARADEEP	PDP	PARADEEP	BIJAYCHANDRAPUR	14226	11 KV ATHARBANKI MED	14226201	NEW JAGATNATH COLONY 3	5422DT231	250	MIXED	AMI	Yes	100%	375	0.19045234	0.179954	0.01049834	5.51%
9346	TPCODL	PARADEEP	PDP	PARADEEP	BIJAYCHANDRAPUR	14226	11 KV ATHARBANKI MED	14226201	SUKHUAKHUDA 1	5422DT233	250	MIXED	AMI	Yes	100%	104	0.04463648	0.035271	0.00936548	20.98%
9347	TPCODL	PARADEEP	PDP	PARADEEP	BIJAYCHANDRAPUR	14226	11 KV HANDIA	14226202	UDAY VIHAR 3	5422DT034	100	MIXED	AMI	Yes	67%	10	0.11213386	0.028823	0.08331086	74.30%
9348	TPCODL	PARADEEP	PDP	PARADEEP	BIJAYCHANDRAPUR	14226	11 KV HANDIA	14226202	UDAY VIHAR 2B	5422DT037	100	MIXED	AMI	Yes	67%	40	0.09289436	0.060588	0.03230636	34.78%
9349	TPCODL	PARADEEP	PDP	PARADEEP	BIJAYCHANDRAPUR	14226	11 KV HANDIA	14226202	UDAY VIHAR 2A	5422DT038	250	MIXED	AMI	Yes	67%	88	0.1126698	0.101674	0.0109958	9.76%
9350	TPCODL	PARADEEP	PDP	PARADEEP	BIJAYCHANDRAPUR	14226	11 KV HANDIA	14226202	BHIMO SAHI	5422DT056	100	MIXED	AMI	Yes	100%	73	0.03342124	0.026793	0.00662824	19.83%
9351	TPCODL	PARADEEP	PDP	PARADEEP	KOLAR(PARUNA)	14196	11 kV POSAL	14196203	BEHEDAPUR	5432DT275	100	MIXED	AMI	Yes	67%	79	0.02988748	0.022636	0.00725148	24.26%
9352	TPCODL	PARADEEP	PDP	PARADEEP	KOTHI (JHIMANI) OD	14346	11 KV JHIMANI	14346201	JIHMANI	5421DT248	100	MIXED	AMI	Yes	0%	160	0.05162319	0.043526	0.00809719	15.69%
9353	TPCODL	PARADEEP	PDP	PARADEEP	KOTHI (JHIMANI) OD	14346	11 KV BAGADIA	14346202	NUASALI	5421DT245	100	MIXED	AMI	Yes	100%	141	0.08086764	0.04859	0.03227764	39.91%
9354	TPCODL	PARADEEP	PDP	PARADEEP	KOTHI (JHIMANI) OD	14346	11 KV KOTHI	14346203	SIJU 7	5421DT211	100	MIXED	AMI	Yes	67%	136	0.10866022	0.044095	0.06456522	59.42%
9355	TPCODL	PARADEEP	PDP	PARADEEP	KOTHI (JHIMANI) OD	14346	11 KV KOTHI	14346203	MANGARAJPUR-2	5421DT224	100	MIXED	AMI	Yes	67%	111	0.06767388	0.030044	0.03762988	55.60%
9356	TPCODL	PARADEEP	PDP	PARADEEP	KOTHI (JHIMANI) OD	14346	11 KV KOTHI	14346203	KOTHIA SAHI	5421DT229	100	MIXED	AMI	Yes	67%	90	0.08300258	0.033185	0.04981758	60.02%
9357	TPCODL	PARADEEP	PDP	PARADEEP	KOTHI (JHIMANI) OD	14346	11 KV KOTHI	14346203	LUNUKUA	5421DT234	100	MIXED	AMI	Yes	0%	102	0.08610918	0.032785	0.05332418	61.93%
9358	TPCODL	PARADEEP	PDP	PARADEEP	KUJANGA	14179	11 KV SANTARA	14179202	SHIV TEMPLE	5421DT117	100	MIXED	AMI	Yes	67%	102	0.06212764	0.043561	0.01856664	29.88%
9359	TPCODL	PARADEEP	PDP	PARADEEP	KUJANGA	14179	11 KV SANTARA	14179202	SAMAGOL 2	5421DT119	63	MIXED	AMI	Yes	67%	38	0.04535596	0.01472	0.03063596	67.55%
9360	TPCODL	PARADEEP	PDP	PARADEEP	KUJANGA	14179	11 KV SANTARA	14179202	SANTARA 5	5421DT124	100	MIXED	AMI	Yes	67%	64	0.04270698	0.018221	0.02448598	57.33%
9361	TPCODL	PARADEEP	PDP	PARADEEP	KUJANGA	14179	11 KV SANTARA	14179202	KALIAPAT 2	5421DT130	100	MIXED	AMI	Yes	67%	92	0.04932952	0.021163	0.02816652	57.10%
9362	TPCODL	PARADEEP	PDP	PARADEEP	KUJANGA	14179	11 KV SANTARA	14179202	BALISAHI	5421DT139	100	MIXED	AMI	Yes	0%	211	0.06486348	0.041834	0.02302948	35.50%
9363	TPCODL	PARADEEP	PDP	PARADEEP	KUJANGA	14179	11 KV SANTARA	14179202	GOPIA KUDHA 3	5421DT151	100	MIXED	AMI	Yes	67%	139	0.11925628	0.035355	0.08390128	70.35%
9364	TPCODL	PARADEEP	PDP	PARADEEP	KUJANGA	14179	11 KV SANTARA	14179202	GOPIA KUDHA 5	5421DT155	100	MIXED	AMI	Yes	67%	107	0.1052122	0.032608	0.0726042	69.01%
9365	TPCODL	PARADEEP	PDP	PARADEEP	KUJANGA	14179	11 KV SANTARA	14179202	PALAHUNKA	5421DT186	100	MIXED	AMI	Yes	67%	106	0.13905624	0.048194	0.09086224	65.34%
9366	TPCODL	PARADEEP	PDP	PARADEEP	KUJANGA	14179	11 KV CHATUA	14179203	BIJUPUR SANI MANDIRA	5411DT223	100	MIXED	AMI	Yes	100%	67	0.03807149	0.029136	0.00893549	23.47%
9367	TPCODL	PARADEEP	PDP	PARADEEP	PARADEEP	14175	11 KV PARADEEPGARH	14175202	NEAR BY DBA PUBLIC SCHOOL	5422DT251	100	MIXED	AMI	Yes	0%	64	0.11942188	0.040773	0.07864888	65.86%
9368	TPCODL	PARADEEP	PDP	PARADEEP	PARADEEP	14175	11 KV PARADEEPGARH	14175202	NEAR BY PUBLIC SCHOOL 2	5422DT252	250	MIXED	AMI	Yes	67%	197	0.1730834	0.122593	0.0504904	29.17%
9369	TPCODL	PARADEEP	PDP	PARADEEP	PARADEEP	14175	11 KV PARADEEPGARH	14175202	NUAGARH 3	5422DT285	250	MIXED	AMI	Yes	0%	309	0.2368004	0.173276	0.0635244	26.83%
9370	TPCODL	PARADEEP	PDP	PARADEEP	PARADEEP	14175	11 KV PARADEEPGARH	14175202	SRIRAM NAGAR	5422DT294	250	MIXED	AMI	Yes	0%	33	0.12274164	0.071611	0.05113064	41.66%
9371	TPCODL	PARADEEP	PDP	PARADEEP	PARADEEP	14175	11 KV PLASTIC PARK DED	14175203	NARENDER PUR 1	5421DT016	100	MIXED	AMI	Yes	67%	72	0.05541272	0.034703	0.02070972	37.37%
9372	TPCODL	PARADEEP	PDP	PARADEEP	PARADEEP	14175	11 KV PLASTIC PARK DED	14175203	BISWALI 18	5421DT021	100	MIXED	AMI	Yes	33%	88	0.037423	0.028055	0.009368	25.03%
9373	TPCODL	PARADEEP	PDP	PARADEEP	PARADEEP	14175	11 KV PLASTIC PARK DED	14175203	MASIDIYA	5421DT026	100	MIXED	AMI	Yes	0%	28	0.046602	0.014132	0.03247	69.68%
9374	TPCODL	PARADEEP	PDP	PARADEEP	PARADEEP	14175	11 KV PLASTIC PARK DED	14175203	KUSHAWA NANDAPUR UCHHABAPUR	5421DT038	100	MIXED	AMI	Yes	67%	111	0.09344346	0.033268	0.06017546	64.40%
9375	TPCODL	PARADEEP	PDP	PARADEEP	PARADEEP	14175	11 KV PLASTIC PARK DED	14175203	MANGARAJ PUR 3	5421DT044	250	MIXED	AMI	Yes	0%	153	0.09199385	0.042363	0.04963085	53.95%
9376	TPCODL	PARADEEP	PDP	PARADEEP	PARADEEP	14175	11 KV PLASTIC PARK DED	14175203	MANGARAJPUR 11 HASINA	5421DT057	100	MIXED	AMI	Yes	67%	82	0.0469354	0.024254	0.0226814	48.32%
9377	TPCODL	PARADEEP	PDP	PARADEEP	PARADEEP	14175	11 KV PLASTIC PARK DED	14175203	HASINA	5421DT060	200	MIXED	AMI	Yes	33%	144	0.10364792	0.054431	0.04921692	47.48%
9378	TPCODL	PARADEEP	PDP	PARADEEP	PARADEEP	14175	11 KV PLASTIC PARK DED	14175203	HASINA 6 TALAPADA	5421DT064	100	MIXED	AMI	Yes	67%	90	0.03982826	0.026122	0.01370626	34.41%
9379	TPCODL	PARADEEP	PDP	PARADEEP	PARADEEP	14175	11 KV PLASTIC PARK DED	14175203	BHUTMUNDAI 2	5421DT072	100	MIXED	AMI	Yes	67%	98	0.0753633	0.031902	0.0434613	57.67%
9380	TPCODL	PARADEEP	PDP	PARADEEP	PARADEEP	14175	11 KV PLASTIC PARK DED	14175203	BHUTMUNDAI 1	5421DT073	100	MIXED	AMI	Yes	0%	71	0.02995606	0.02616	0.00379606	12.67%
9381	TPCODL	PARADEEP	PDP	PARADEEP	PARADEEP	14175	11 KV PLASTIC PARK DED	14175203	BHUTMUNDAI 5	5421DT075	250	MIXED	AMI	Yes	0%	139	0.17388748	0.069505	0.10438248	60.03%
9382	TPCODL	PARADEEP	PDP	PARADEEP	PARADEEP	14175	11 KV PLASTIC PARK DED	14175203	BHUTMUNDAI 11	5421DT081	100	MIXED	AMI	Yes	67%	72	0.09551546	0.033177	0.06233846	65.27%
9383	TPCODL	PARADEEP	PDP	PARADEEP	PARADEEP	14175	11 KV CHOUMUHANI + B	14175205	PIPAL	5422DT123	63	MIXED	AMI	Yes	33%	33	0.03777654	0.017673	0.02010354	53.22%
9384	TPCODL	PARADEEP	PDP	PARADEEP	PARADEEP	14175	11 KV CHOUMUHANI + B	14175205	BALDIA 6	5422DT138	100	MIXED	AMI	Yes	67%	44	0.03729162	0.016099	0.02119262	56.83%
9385	TPCODL	PARADEEP	PDP	TIRTOL	KRISHNANDAPUR (S	14345	11 kV DIGABARINI	14345203	DHOBHASIDE 1	5432DT051	100	MIXED	AMI	Yes	67%	104	0.05027804	0.037897	0.01238104	24.63%
9386	TPCODL	PARADEEP	PDP	TIRTOL	JAGANNATHPUR OD	14340	11 KV TULANGA FEEDER	14340203	NARUA	5431DT751	100	MIXED	AMI	Yes	100%	83	0.03249166	0.024264	0.00822766	25.32%
9387	TPCODL	PARADEEP	PDP	TIRTOL	JAGANNATHPUR OD	14340	11 KV TULANGA FEEDER	14340203	TULANGA-1	5431DT753	250	MIXED	AMI	Yes	100%	228	0.06916154	0.066172	0.00298954	4.32%
9388	TPCODL	PARADEEP	PDP	TIRTOL	JAGANNATHPUR OD	14340	11 KV TULANGA FEEDER	14340203	NAULO	5431DT767	100	MIXED	AMI	Yes	0%	111	0.04691274	0.025497	0.02141574	45.65%
9389	TPCODL	PARADEEP	PDP	TIRTOL	JAGANNATHPUR OD	14340	11 KV TULANGA FEEDER	14340203	TANDIKULA-1	5431DT774	100	MIXED	AMI	Yes	100%	144	0.0497196	0.040605	0.0091146	18.33%
9390	TPCODL	PARADEEP	PDP	TIRTOL	JAGANNATHPUR OD	14340	11 KV TULANGA FEEDER	14340203	PULASAHI	5431DT833	200	MIXED	AMI	Yes	100%	191	0.07978538	0.053444	0.02634138	33.02%
9391	TPCODL	PARADEEP	PDP	TIRTOL	BALIA (ADHANGA) (	14359	11 KV BALIA	14359204	NEAR MAA DURGA TEMPLE	5331DT429	250	MIXED	AMI	Yes	100%	206	0.09303956	0.066704	0.02633556	28.31%
9392	TPCODL	PARADEEP	PDP	TIRTOL	ERASAMA	14178	11 KV AMBIKI	14178201	JERILO 2	5431DT401	100	MIXED	AMI	Yes	100%	43	0.06117706	0.014804	0.04637306	75.80%
9393	TPCODL	PARADEEP	PDP	TIRTOL	ERASAMA	14178	11 KV ERASAMA	14178203	ARADA 1	5431DT003	100	MIXED	AMI	Yes	100%	39	0.05042074	0.020047	0.03037374	60.24%
9394	TPCODL	PARADEEP	PDP	TIRTOL	ERASAMA	14178	11 KV ERASAMA	14178203	NEAR SAHI 1	5431DT010	100	MIXED	AMI	Yes	100%	64	0.02631776	0.021936	0.00438176	16.65%
9395	TPCODL	PARADEEP	PDP	TIRTOL	ERASAMA	14178	11 KV ERASAMA	14178203	BLOCK DEVELOPMENT OFFICE	5431DT024	100	MIXED	AMI	Yes	100%	21	0.01449668	0.013224	0.00127268	8.78%
9396	TPCODL	PARADEEP	PDP	TIRTOL	ERASAMA	14178	11 KV ERASAMA	14178203	ERSAMA	5431DT043	100	MIXED	AMI	Yes	0%	103	0.08561448	0.044355	0.04125948	48.19%
9397	TPCODL	PARADEEP	PDP	TIRTOL	ERASAMA	14178	11 KV ERASAMA	14178203	DHAUNASAHI 4	5431DT054	100	MIXED	AMI	Yes	67%	54	0.0175985	0.014101	0.0034975	19.87%
9398	TPCODL	PARADEEP	PDP	TIRTOL	ERASAMA	14178	11 KV PANCHAPALLI	14178204	NADYA 4	5431DT119	250	MIXED	AMI	Yes	100%	100	0.06491516	0.038566	0.02634916	40.59%
9399	TPCODL	PARADEEP	PDP	TIRTOL	ERASAMA	14178	11 KV PANCHAPALLI	14178204	NARSINGHPUR 1	5431DT130	100	MIXED	AMI	Yes	100%	94	0.02771857	0.018502	0.00921657	33.25%
9400	TPCODL	PARADEEP	PDP	TIRTOL	ERASAMA	14178	11 KV JAPPA	14178205	RASAKDARPUR 3	5431DT530	100	MIXED	AMI	Yes	33%	18	0.02489762	0.007468	0.01742962	70.01%
9401	TPCODL	PARADEEP	PDP	TIRTOL	ERASAMA	14178	11 KV KOTHI	14178207	KHURUCHANRAPUR PLAY GROUND 1	5431DT067	100	MIXED	AMI	Yes	67%	72	0.02793056	0.022394	0.00553656	19.82%
9402	TPCODL	PARADEEP	PDP	TIRTOL	ERASAMA	14178	11 KV KOTHI	14178207	NAIGAUN 3	5431DT078	100	MIXED	AMI	Yes	67%	122	0.06760746	0.043816	0.02379146	35.19%
9403	TPCODL	PARADEEP	PDP	TIRTOL	ERASAMA	14178	11 KV KOTHI	14178207	NIMOLA	5431DT087	100	MIXED	AMI	Yes	67%	126	0.06518399	0.041926	0.02325799	35.68%
9404	TPCODL	PARADEEP	PDP	TIRTOL	ERASAMA	14178	11 KV KOTHI	14178207	IBRISINGH VILLAGE 2	5431DT090	100	MIXED	AMI	Yes	67%	120	0.05412364	0.032528	0.02159564	39.90%
9405	TPCODL	PARADEEP	PDP	TIRTOL	ERASAMA	14178	11 KV KOTHI	14178207	G.B PUR	5431DT097	100	MIXED	AMI	Yes	0%	94	0.04373602	0.028561	0.01517502	34.70%
9406	TPCODL	PARADEEP	PDP	TIRTOL	ERASAMA	14178	11 kV JAPA	14178208	JAPA VILLAGE 2	5431DT467	100	MIXED	AMI	Yes	0%	52	0.04213646	0.010403	0.03173346	75.31%
9407	TPCODL	PARADEEP	PDP	TIRTOL	ERASAMA	14178	11 kV JAPA	14178208	MACHIDEPUR 2	5431DT473	63	MIXED	AMI	Yes	0%	46	0.02070678	0.010052	0.01065478	51.46%
9408	TPCODL	PARADEEP	PDP	TIRTOL	ERASAMA	14178	11 KV JAPA	14178208	KURUNTUTTA 2	5431DT563	100	MIXED	AMI	Yes	67%	40	0.01730008	0.009057	0.00824308	47.65%
9409	TPCODL	PARADEEP	PDP	TIRTOL	GADA BISHNUPUR (	14343	11 KV PADMAPUR	14343201	HARISHPUR 5	5431DT416	250	MIXED	AMI	Yes	67%	62	0.03262022	0.015435	0.01718522	52.68%
9410	TPCODL	PARADEEP	PDP	TIRTOL	GADA BISHNUPUR (	14343	11 KV PADMAPUR	14343201	PADMAPUR	5431DT431	100	MIXED	AMI	Yes	67%	145	0.05736492	0.044487	0.01287792	22.45%
9411	TPCODL	PARADEEP	PDP	TIRTOL	GADA BISHNUPUR (	14343	11 KV GODA	14343202	GODA 2(RAJAPUR)	5431DT191	100	MIXED	AMI	Yes	67%	137	0.04014284	0.029126	0.01101684	27.44%
9412	TPCODL	PARADEEP	PDP	TIRTOL	GADA BISHNUPUR (	14343	11 KV GODA	14343202	DASAPUR	5431DT192	100	MIXED	AMI	Yes	67%	66	0.02994469	0.017659	0.01228569	41.03%
9413	TPCODL	PARADEEP	PDP	TIRTOL	GARDAPUR	14168	11 KV GARADAPUR-I	14168201	BILASPUR MARKET	5432DT187	100	MIXED	AMI	Yes	100%	26	0.03913083	0.01744	0.02169083	55.43%
9414	TPCODL	PARADEEP	PDP	TIRTOL	GARDAPUR	14168	11 KV GARADAPUR-I	14168201	BILASPUR	5432DT188	100	MIXED	AMI	Yes	67%	81	0.03755284	0.027204	0.01034884	27.56%
9415	TPCODL	PARADEEP	PDP	TIRTOL	GARDAPUR	14168	11 KV GARADAPUR-I	14168201	SAMANTARPARA 2	5432DT202	100	MIXED	AMI	Yes	67%	115	0.06273101	0.036814	0.02591701	41.31%
9416	TPCODL	PARADEEP	PDP	TIRTOL	GORADA ODSSP	14344	11 KV NUAPOKHARI	14344203	DHUNPUR	5413DT316	100	MIXED	AMI	Yes	0%	75	0.07332366	0.027337	0.04598666	62.72%

Sl. No.	Zone Name	Circle name	Division name	Name of the Sub-division	Name of the Sub-station	Substation Code	Name of the 11 kV Feeder	Feeder Code	Name of the Location where DT situated	DT code	DT Capacity (kVA)	Predominant consumer type of DT (Domestic/Industrial/Agriculture/Mixed)	Type of metering AMR/AMI/ Communicable/Conventional metered/Unmetered	Status of Meter-whether Functional (Yes/No)	% of data received automatically (if AMR/AMI)	No. of Connected Consumers	Input Energy (MU) (A)	Billed Energy (MU) (B)	Loss (MU) (A-B)	% DT Loss (A-B)/A
9417	TPCODL	PARADEEP	PDP	TIRTOL	JAGANNATHPUR OD	14340	11 KV JAGANNATHPUR	14340201	CHHATA MATHA	5431DT706	100	MIXED	AMI	Yes	100%	98	0.0410997	0.032111	0.0089887	21.87%
9418	TPCODL	PARADEEP	PDP	TIRTOL	JAGANNATHPUR OD	14340	11 KV JAGANNATHPUR	14340201	NARUA CHAKA	5431DT714	500	MIXED	AMI	Yes	100%	143	0.09815544	0.065885	0.03227044	32.88%
9419	TPCODL	PARADEEP	PDP	TIRTOL	JAGANNATHPUR OD	14340	11 KV JAGANNATHPUR	14340201	CHANDHA	5431DT746	100	MIXED	AMI	Yes	100%	155	0.0737943	0.055686	0.0181083	24.54%
9420	TPCODL	PARADEEP	PDP	TIRTOL	JAGANNATHPUR OD	14340	11 KV DIHASAHI	14340202	SANTOL 3	5431DT633	100	MIXED	AMI	Yes	67%	120	0.03865989	0.027106	0.01155389	29.89%
9421	TPCODL	PARADEEP	PDP	TIRTOL	JAGANNATHPUR OD	14340	11 KV DIHASAHI	14340202	SOMPUR	5431DT672	100	MIXED	AMI	Yes	67%	121	0.04308402	0.031555	0.01152902	26.76%
9422	TPCODL	PARADEEP	PDP	TIRTOL	JAGANNATHPUR OD	14340	11 KV DIHASAHI	14340202	SOMAPUR 2	5431DT675	100	MIXED	AMI	Yes	67%	88	0.04618944	0.035878	0.01031144	22.32%
9423	TPCODL	PARADEEP	PDP	TIRTOL	KANAKPUR ODSSP	14341	11 KV KANAKPUR-2(KAN	14341201	KANAKPUR 2	5433DT100	100	MIXED	AMI	Yes	67%	152	0.0810995	0.058251	0.0228485	28.17%
9424	TPCODL	PARADEEP	PDP	TIRTOL	KANAKPUR ODSSP	14341	11 KV KANAKPUR-2(KAN	14341201	KANAKPUR 6	5433DT105	100	MIXED	AMI	Yes	67%	67	0.06230814	0.037657	0.02465114	39.56%
9425	TPCODL	PARADEEP	PDP	TIRTOL	KANAKPUR ODSSP	14341	11 KV KANAKPUR-2(KAN	14341201	BADASAROL 1	5433DT121	100	MIXED	AMI	Yes	100%	95	0.04763382	0.036004	0.01162982	24.42%
9426	TPCODL	PARADEEP	PDP	TIRTOL	KANAKPUR ODSSP	14341	11 KV KANAKPUR-2(KAN	14341201	KANTAPADA 5	5433DT140	100	MIXED	AMI	Yes	67%	110	0.04674836	0.036805	0.00994336	21.27%
9427	TPCODL	PARADEEP	PDP	TIRTOL	KANAKPUR ODSSP	14341	11 KV GOVINDAPUR(Kan	14341202	CHHATRAMATHA	5433DT295	100	MIXED	AMI	Yes	100%	92	0.03227032	0.028245	0.00402532	12.47%
9428	TPCODL	PARADEEP	PDP	TIRTOL	KANAKPUR ODSSP	14341	11 KV GOVINDAPUR(Kan	14341202	KUTILO 1	5433DT307	100	MIXED	AMI	Yes	67%	63	0.0233725	0.01488	0.0084925	36.34%
9429	TPCODL	PARADEEP	PDP	TIRTOL	KANAKPUR ODSSP	14341	11 KV GOVINDAPUR(Kan	14341202	KURADHA	5433DT313	63	MIXED	AMI	Yes	67%	141	0.04795298	0.039065	0.00888798	18.53%
9430	TPCODL	PARADEEP	PDP	TIRTOL	KANAKPUR ODSSP	14341	11 KV GOVINDAPUR(Kan	14341202	KOSTI MALIKPUR 1	5433DT334	63	MIXED	AMI	Yes	67%	27	0.00974378	0.008013	0.00173078	17.76%
9431	TPCODL	PARADEEP	PDP	TIRTOL	KANAKPUR ODSSP	14341	11 KV GOVINDAPUR(Kan	14341202	BHATAGAN 2	5433DT341	100	MIXED	AMI	Yes	67%	61	0.02423872	0.022036	0.00220272	9.09%
9432	TPCODL	PARADEEP	PDP	TIRTOL	KANAKPUR ODSSP	14341	11 KV GOVINDAPUR(Kan	14341202	KIRANTI	5433DT347	100	MIXED	AMI	Yes	67%	72	0.03102842	0.021949	0.00907942	29.26%
9433	TPCODL	PARADEEP	PDP	TIRTOL	KANAKPUR ODSSP	14341	11 KV GOVINDAPUR(Kan	14341202	GOVINDPUR 4	5433DT353	100	MIXED	AMI	Yes	67%	80	0.04341096	0.03708	0.00633096	14.58%
9434	TPCODL	PARADEEP	PDP	TIRTOL	KANAKPUR ODSSP	14341	11 KV GOVINDAPUR(Kan	14341202	DANDAMIRA-1	5433DT362	100	MIXED	AMI	Yes	67%	165	0.05061036	0.04493	0.00568036	11.22%
9435	TPCODL	PARADEEP	PDP	TIRTOL	KANAKPUR ODSSP	14341	11 KV GOVINDAPUR(Kan	14341202	AHANA 2	5433DT365	100	MIXED	AMI	Yes	67%	48	0.02483918	0.012604	0.01223518	49.26%
9436	TPCODL	PARADEEP	PDP	TIRTOL	KANAKPUR ODSSP	14341	11 KV MULISINGH	14341203	PUTTING 1	5323DT231	63	MIXED	AMI	Yes	67%	54	0.03962068	0.022851	0.01676968	42.33%
9437	TPCODL	PARADEEP	PDP	TIRTOL	KANAKPUR ODSSP	14341	11 KV MULISINGH	14341203	BIRITOLA	5433DT199	100	MIXED	AMI	Yes	67%	53	0.04407848	0.02709	0.01698848	38.54%
9438	TPCODL	PARADEEP	PDP	TIRTOL	KANAKPUR ODSSP	14341	11 KV MULISINGH	14341203	RASALPUR 1	5433DT203	63	MIXED	AMI	Yes	67%	123	0.07746938	0.072234	0.00523538	6.76%
9439	TPCODL	PARADEEP	PDP	TIRTOL	KANAKPUR ODSSP	14341	11 KV MULISINGH	14341203	Rasulpur	5433DT210	63	MIXED	AMI	Yes	67%	69	0.06325448	0.046317	0.01693748	26.78%
9440	TPCODL	PARADEEP	PDP	TIRTOL	KANAKPUR ODSSP	14341	11 KV MULISINGH	14341203	SALANPUR 6	5433DT242	100	MIXED	AMI	Yes	67%	60	0.03544844	0.019446	0.01600244	45.14%
9441	TPCODL	PARADEEP	PDP	TIRTOL	KANAKPUR ODSSP	14341	11 KV MULISINGH	14341203	KIRTANPUR 1	5433DT453	100	MIXED	AMI	Yes	67%	38	0.0323562	0.016368	0.0159882	49.41%
9442	TPCODL	PARADEEP	PDP	TIRTOL	KOLAR(PARUNA)	14196	11KV PARUNA	14196202	DAMADAR PATENA	5432DT234	100	MIXED	AMI	Yes	0%	51	0.02237669	0.014287	0.00808969	36.15%
9443	TPCODL	PARADEEP	PDP	TIRTOL	KOLAR(PARUNA)	14196	11KV PARUNA	14196202	BIJIPUR	5432DT238	100	MIXED	AMI	Yes	67%	83	0.02548432	0.024036	0.00144832	5.68%
9444	TPCODL	PARADEEP	PDP	TIRTOL	KOLAR(PARUNA)	14196	11 kV POSAL	14196203	BALIKANI 4	5412DT186	100	MIXED	AMI	Yes	67%	159	0.0447988	0.03101	0.0137888	30.78%
9445	TPCODL	PARADEEP	PDP	TIRTOL	KOLAR(PARUNA)	14196	11 kV POSAL	14196203	DERAKANA	5432DT263	100	MIXED	AMI	Yes	67%	87	0.03881526	0.028988	0.00982726	25.32%
9446	TPCODL	PARADEEP	PDP	TIRTOL	KOLAR(PARUNA)	14196	11 kV POSAL	14196203	SANKHESWARA	5432DT268	100	MIXED	AMI	Yes	67%	20	0.01280736	0.008609	0.00419836	32.78%
9447	TPCODL	PARADEEP	PDP	TIRTOL	KOLAR(PARUNA)	14196	11 kV POSAL	14196203	TALA SAHI PAIKAKULA	5432DT279	100	MIXED	AMI	Yes	0%	24	0.03441636	0.00808	0.02633636	76.52%
9448	TPCODL	PARADEEP	PDP	TIRTOL	KOLAR(PARUNA)	14196	11 kV POSAL	14196203	KOLAR 4	5432DT310	100	MIXED	AMI	Yes	100%	135	0.0552799	0.041364	0.0139159	25.17%
9449	TPCODL	PARADEEP	PDP	TIRTOL	KOLAR(PARUNA)	14196	11 kV POSAL	14196203	DHANUA 4	5432DT318	100	MIXED	AMI	Yes	67%	170	0.05276646	0.046355	0.00641146	12.15%
9450	TPCODL	PARADEEP	PDP	TIRTOL	KOLAR(PARUNA)	14196	11 kV POSAL	14196203	MURARIPUR 1	5432DT337	100	MIXED	AMI	Yes	67%	52	0.0390679	0.028755	0.0103129	26.40%
9451	TPCODL	PARADEEP	PDP	TIRTOL	KOLAR(PARUNA)	14196	11 kV POSAL	14196203	MURARIPUR 4	5432DT340	100	MIXED	AMI	Yes	100%	45	0.02216378	0.015728	0.00643578	29.04%
9452	TPCODL	PARADEEP	PDP	TIRTOL	KOLAR(PARUNA)	14196	11 kV POSAL	14196203	NAGAPURA 2	5432DT345	100	MIXED	AMI	Yes	100%	76	0.03445972	0.028827	0.00563272	16.35%
9453	TPCODL	PARADEEP	PDP	TIRTOL	KOLAR(PARUNA)	14196	11 kV POSAL	14196203	POROGADEI 2	5432DT359	250	MIXED	AMI	Yes	67%	171	0.0597716	0.059347	0.0004246	0.71%
9454	TPCODL	PARADEEP	PDP	TIRTOL	KOLAR(PARUNA)	14196	11 kV POSAL	14196203	BANASARA 3	5432DT374	100	MIXED	AMI	Yes	67%	129	0.05798798	0.032331	0.02565698	44.25%
9455	TPCODL	PARADEEP	PDP	TIRTOL	KOLAR(PARUNA)	14196	11 kV POSAL	14196203	NEAR REVER 15	5432DT402	100	MIXED	AMI	Yes	67%	107	0.04438972	0.029347	0.01504272	33.89%
9456	TPCODL	PARADEEP	PDP	TIRTOL	KOLAR(PARUNA)	14196	11 kV POSAL	14196203	HABELI	5432DT417	100	MIXED	AMI	Yes	67%	144	0.07311986	0.044132	0.02898786	39.64%
9457	TPCODL	PARADEEP	PDP	TIRTOL	KRISHNANDAPUR (S	14345	11 KV KRISHNANANDAPU	14345201	KRISNANDAPUR 13	5432DT137	250	MIXED	AMI	Yes	33%	62	0.14799864	0.052078	0.09592064	64.81%
9458	TPCODL	PARADEEP	PDP	TIRTOL	KRISHNANDAPUR (S	14345	11 KV KRISHNANANDAPU	14345201	KRISNANDAPUR 14	5432DT138	250	MIXED	AMI	Yes	67%	95	0.11500656	0.048579	0.06642756	57.76%
9459	TPCODL	PARADEEP	PDP	TIRTOL	KRISHNANDAPUR (S	14345	11 KV KRISHNANANDAPU	14345201	BISANPUR	5432DT141	100	MIXED	AMI	Yes	67%	91	0.0836266	0.039292	0.0443346	53.01%
9460	TPCODL	PARADEEP	PDP	TIRTOL	KRISHNANDAPUR (S	14345	11 KV KRISHNANANDAPU	14345201	BISANPUR	5432DT143	100	MIXED	AMI	Yes	67%	53	0.08654636	0.032707	0.05383936	62.21%
9461	TPCODL	PARADEEP	PDP	TIRTOL	KRISHNANDAPUR (S	14345	11 KV KRISHNANANDAPU	14345201	KRISNANDAPUR 23	5432DT147	63	MIXED	AMI	Yes	67%	39	0.02694335	0.019573	0.00737035	27.35%
9462	TPCODL	PARADEEP	PDP	TIRTOL	KRISHNANDAPUR (S	14345	11 KV KRISHNANANDAPU	14345201	KRISNANDAPUR 28	5432DT152	63	MIXED	AMI	Yes	67%	21	0.01324314	0.009707	0.00353614	26.70%
9463	TPCODL	PARADEEP	PDP	TIRTOL	KRISHNANDAPUR (S	14345	11 KV KRISHNANANDAPU	14345201	KRISNANDAPUR 57	5432DT157	100	MIXED	AMI	Yes	67%	71	0.11587798	0.028419	0.08745898	75.48%
9464	TPCODL	PARADEEP	PDP	TIRTOL	KRISHNANDAPUR (S	14345	11 KV KRISHNANANDAPU	14345201	ROZUA MOLLA	5432DT164	63	MIXED	AMI	Yes	67%	40	0.05750746	0.02762	0.02988746	51.97%
9465	TPCODL	PARADEEP	PDP	TIRTOL	KRISHNANDAPUR (S	14345	11 KV KRISHNANANDAPU	14345201	KRISNANDAPUR 34	5432DT167	100	MIXED	AMI	Yes	67%	30	0.06055534	0.01603	0.04452534	73.53%
9466	TPCODL	PARADEEP	PDP	TIRTOL	KRISHNANDAPUR (S	14345	11 KV KRISHNANANDAPU	14345201	KRISNANDAPUR 36	5432DT170	100	MIXED	AMI	Yes	67%	136	0.09402724	0.061083	0.03294424	35.04%
9467	TPCODL	PARADEEP	PDP	TIRTOL	KRISHNANDAPUR (S	14345	11 KV KRISHNANANDAPU	14345201	KRISNANDAPUR 38	5432DT171	100	MIXED	AMI	Yes	67%	137	0.09327636	0.076734	0.01654236	17.73%
9468	TPCODL	PARADEEP	PDP	TIRTOL	KRISHNANDAPUR (S	14345	11 KV KRISHNANANDAPU	14345201	KRISNANDAPUR 48	5432DT181	100	MIXED	AMI	Yes	100%	27	0.0624103	0.019008	0.0434023	69.54%
9469	TPCODL	PARADEEP	PDP	TIRTOL	KRISHNANDAPUR (S	14345	11 KV KRISHNANANDAPU	14345201	KRISNANDAPUR 50	5432DT183	250	MIXED	AMI	Yes	0%	98	0.06019992	0.056602	0.00359792	5.98%
9470	TPCODL	PARADEEP	PDP	TIRTOL	KRISHNANDAPUR (S	14345	11 KV PAIKAKULA	14345202	PAIKA RD 1	5432DT023	250	MIXED	AMI	Yes	67%	89	0.07758724	0.039701	0.03788624	48.83%
9471	TPCODL	PARADEEP	PDP	TIRTOL	KRISHNANDAPUR (S	14345	11 KV PAIKAKULA	14345202	PAIKA RD 5	5432DT027	100	MIXED	AMI	Yes	33%	79	0.06129028	0.038309	0.02298128	37.50%
9472	TPCODL	PARADEEP	PDP	TIRTOL	KRISHNANDAPUR (S	14345	11 KV DIGABARINI	14345203	GAITHPUR 4	5432DT045	100	MIXED	AMI	Yes	67%	14	0.01626452	0.004823	0.01144152	70.35%
9473	TPCODL	PARADEEP	PDP	TIRTOL	KRISHNANDAPUR (S	14345	11 KV DIGABARINI	14345203	DIGABARINI 2	5432DT059	100	MIXED	AMI	Yes	0%	147	0.04080444	0.032053	0.00875144	21.45%
9474	TPCODL	PARADEEP	PDP	TIRTOL	KRISHNANDAPUR (S	14345	11 KV MANAPUR	14345204	BHANSAR 1	5432DT086	63	MIXED	AMI	Yes	33%	42	0.0309831	0.018077	0.0129061	41.66%
9475	TPCODL	PARADEEP	PDP	TIRTOL	KRISHNANDAPUR (S	14345	11 KV MANAPUR	14345204	BHANSAR UP SCHOOL	5432DT097	100	MIXED	AMI	Yes	0%	55	0.08494938	0.025692	0.05925738	69.76%
9476	TPCODL	PARADEEP	PDP	TIRTOL	KRISHNANDAPUR (S	14345	11 KV MANAPUR	14345204	MATTAGAJPUR 2	5432DT422	100	MIXED	AMI	Yes	67%	168	0.05657728	0.05534	0.00123728	2.19%
9477	TPCODL	PARADEEP	PDP	TIRTOL	KRISHNANDAPUR (S	14345	11 KV MANAPUR	14345204	MATTAGAJPUR 4	5432DT424	100	MIXED	AMI	Yes	67%	110	0.06130486	0.036335	0.02496986	40.73%
9478	TPCODL	PARADEEP	PDP	TIRTOL	LUNA	14166	11 KV PATAKURA-1(OLD)	14166201	TIKHRI 4(BEDHI TIKHIRI)	5224DT036	100	MIXED	AMI	Yes	100%	53	0.02688402	0.018331	0.00855302	31.81%
9479	TPCODL	PARADEEP	PDP	TIRTOL	TIRTOL	14176	11 KV KOTAKANA	14176201	JAI PUR 3	5332DT006	500	MIXED	AMI	Yes	0%	52	0.11974068	0.034937	0.08480368	70.82%
9480	TPCODL	PARADEEP	PDP	TIRTOL	TIRTOL	14176	11 KV KOTAKANA	14176201	JAI PUR 15	5332DT018	100	MIXED	AMI	Yes	67%	50	0.04581214	0.024894	0.02091814	45.66%
9481	TPCODL	PARADEEP	PDP	TIRTOL	TIRTOL	14176	11 KV KOTAKANA	14176201	GOREKHA NATH 1	5332DT031	100	MIXED	AMI	Yes	33%	86	0.04833082	0.044952	0.00337882	6.99%
9482	TPCODL	PARADEEP	PDP	TIRTOL	TIRTOL	14176	11 KV KOTAKANA	14176201	GOREKHA NATH 2	5332DT032	250	MIXED	AMI	Yes	67%	74	0.05003636	0.030786	0.01925036	38.47%
9483	TPCODL	PARADEEP	PDP	TIRTOL	TIRTOL	14176	11 KV KOTAKANA	14176201	GOREKHA NATH 5	5332DT035	100	MIXED	AMI	Yes	67%	81	0.05116406	0.040669	0.01049506	20.51%
9484	TPCODL	PARADEEP	PDP	TIRTOL	TIRTOL	14176	11 KV KOTAKANA	14176201	GOREKHA NATH 16	5332DT046	250	MIXED	AMI	Yes	67%	14	0.03435336	0.020539	0.01381436	40.21%
9485	TPCODL	PARADEEP	PDP	TIRTOL	TIRTOL	14176	11 KV KOTAKANA	14176201	NA	5433DT032	100	MIXED	AMI	Yes	67%	132	0.05868524	0.043987	0.01469824	25.05%
9486	TPCODL	PARADEEP	PDP	TIRTOL	TIRTOL	14176	11 KV KOTAKANA	14176201	KOTAKANA 4	5433DT035	100	MIXED	AMI	Yes	100%	73	0.02812706	0.023988	0.00413906	14.72%
9487	TPCODL	PARADEEP	PDP	TIRTOL	TIRTOL	14176	11 KV KOTAKANA	14176201	BIDYADHARA PUR2	5433DT061	100	MIXED	AMI	Yes	67%	112	0.05501556	0.04042	0.01459556	26.53%
9488	TPCODL	PARADEEP	PDP	TIRTOL	TIRTOL	14176	11 KV KANAKPUR	14176202	NAUSIRA	5433DT003	63	MIXED	AMI	Yes	100%	72	0.02801086	0.021281	0.00672986	24.03%
9489	TPCODL	PARADEEP	PDP	TIRTOL	TIRTOL	14176	11 KV KANAKPUR	14176202	MANITRI	5433DT010	100	MIXED	AMI	Yes	100%	42	0.03657482	0.027635	0.00893982	24.44%

Sl. No.	Zone Name	Circle name	Division name	Name of the Sub-division	Name of the Sub-station	Substation Code	Name of the 11 kV Feeder	Feeder Code	Name of the Location where DT situated	DT code	DT Capacity (kVA)	Predominant consumer type of DT (Domestic/Industrial/Agriculture/Mixed)	Type of metering AMR/AMI/ Communicable/Conventional metered/Unmetered	Status of Meter- whether Functional (Yes/No)	% of data received automatically (if AMR/AMI)	No. of Connected Consumers	Input Energy (MU) (A)	Billed Energy (MU) (B)	Loss (MU) (A-B)	% DT Loss (A-B)/A
9490	TPCODL	PARADEEP	PDP	TIRTOL	TIRTOL	14176	11 KV KANAKPUR	14176202	NEAR TENTULIPADA U.P SCHOOL OPI	5433DT376	100	MIXED	AMI	Yes	100%	184	0.08066286	0.068738	0.01192486	14.78%
9491	TPCODL	PARADEEP	PDP	TIRTOL	TIRTOL	14176	11 KV TIRTOL BAZAR	14176204	TRITOL 13	5413DT274	63	MIXED	AMI	Yes	100%	119	0.04549012	0.040238	0.00525212	11.55%
9492	TPCODL	PARADEEP	PDP	TIRTOL	TIRTOL	14176	11 KV TIRTOL BAZAR	14176204	TRITOL 18	5413DT279	63	MIXED	AMI	Yes	100%	61	0.02674538	0.020624	0.00612138	22.89%
9493	TPCODL	PARADEEP	PDP	TIRTOL	TIRTOL	14176	11 KV TIRTOL BAZAR	14176204	TRITOL 19	5413DT280	250	MIXED	AMI	Yes	100%	133	0.0597492	0.053812	0.0059372	9.94%
9494	TPCODL	PARADEEP	PDP	TIRTOL	TIRTOL	14176	11 KV TIRTOL BAZAR	14176204	TRITOL 9	5413DT336	63	MIXED	AMI	Yes	100%	58	0.06469612	0.040043	0.02465312	38.11%
9495	TPCODL	PARADEEP	PDP	TIRTOL	TIRTOL	14176	11 KV TIRTOL BAZAR	14176204	NEHRU ROAD 5	5433DT161	100	MIXED	AMI	Yes	100%	59	0.06147508	0.023865	0.03761008	61.18%
9496	TPCODL	PARADEEP	PDP	TIRTOL	TIRTOL	14176	11 KV TIRTOL BAZAR	14176204	TRITOL BAZAR 17	5433DT177	250	MIXED	AMI	Yes	100%	99	0.13320528	0.081611	0.05159428	38.73%
9497	TPCODL	PARADEEP	PDP	TIRTOL	TIRTOL	14176	11 KV TIRTOL BAZAR	14176204	TRITOL BAZAR 22	5433DT182	100	MIXED	AMI	Yes	0%	131	0.09510986	0.081394	0.01371586	14.42%
9498	TPCODL	PARADEEP	PDP	TIRTOL	TIRTOL	14176	11 KV TIRTOL BAZAR	14176204	TRITOL BAZAR 24	5433DT184	100	MIXED	AMI	Yes	100%	101	0.0567377	0.04577	0.0109677	19.33%