

TPCODL	TP CENTRAL ODISHA DISTRIBUTION LIMITED	
	TECHNICAL SPECIFICATION	
Document Title	SPECIFICATION FOR THREE PHASE 4 WIRE WHOLE CURRENT SMART METER WITH BOX	
Document No.	MMG-SMART-002	
		Page 1 of 39

CONTENTS

- 1.0 SCOPE**
- 2.0 APPLICABLE STANDARDS**
- 3.0 CLIMATIC CONDITIONS OF THE INSTALLATION**
- 4.0 GENERAL TECHNICAL REQUIREMENTS**
- 5.0 GENERAL CONSTRUCTIONS**
- 6.0 NAME PLATE AND MARKING**
- 7.0 TESTS**
- 8.0 TYPE TEST CERTIFICATES**
- 9.0 PRE-DESPATCH INSPECTION**
- 10.0 INSPECTION AFTER RECEIPT AT STORE**
- 11.0 GUARANTEE**
- 12.0 PACKING**
- 13.0 TENDER SAMPLE**
- 14.0 QUALITY CONTROL**
- 15.0 MINIMUM TESTING FACILITIES**
- 16.0 MANUFACTURING ACTIVITIES**
- 17.0 SPARES, ACCESSORIES AND TOOLS**
- 18.0 DRAWING AND DOCUMENTS**
- 19.0 GURANTEED TECHNICAL PARTICULARS**
- 20.0 SCHEDULE OF DEVIATIONS**

TPCODL

Document Title	SPECIFICATION FOR THREE PHASE 4 WIRE WHOLE CURRENT SMART METER WITH BOX	
Document No.	MMG-SMART-002	
		Page 2 of 39

1	SCOPE	<p>This specification covers the technical requirements of design, manufacturing, testing & integration with network integration card(NIC) of 4G communication being used at TATA POWER CENTRAL ODISHA DISTRIBUTION LIMITED at meter manufacturer's works,packing, forwarding, supply and unloading at store/site of three phase four wire,3x230 voltage,20-100A, whole current static smart energy meters of accuracy class 1.0 (here after referred as meters) complete with all accessories for efficient and trouble free operation with communication module (NIC) compatible with 4G and fall back to 2G technology..</p> <p>It is not the intent to specify completely herein all the details of tech design and construction of material. However, the material shall conform in all respects to high standards of engineering, design and workmanship and shall be capable of performing in continuous commercial operation in manner acceptable to the TPCODL, who will interpret the meanings of drawings and specification and shall have the power to reject any work or material which, in his judgment is not in accordance therewith. The offered material shall be complete with all components necessary for their effective and trouble free operation. Such components shall be deemed to be within the scope of Bidder's supply irrespective of whether those are specifically brought out in this specification and/or the commercial order or not.</p>																														
2	APPLICABLE STANDARDS	<p>The equipment covered by this specification shall conform to the requirements stated in latest editions & amendments of relevant Indian/ IEC Standards and shall conform to the regulations of local statutory authorities.</p> <table><tr><td>a</td><td>IS 16444 Part-1 : 2015</td><td>A.C. Static Direct connected Watt hour Smart meter class 1.0 and 2.0</td></tr><tr><td>b</td><td>IS 13779 : 1999</td><td>A.C. Static Watt hour meter class 1.0 and 2.0</td></tr><tr><td>c</td><td>IS 15884 : 2010</td><td>A.C. direct connected static prepayment meters for active energy (class 1 & 2)</td></tr><tr><td>d</td><td>IS 15959 Part 1 : 2011</td><td>Data exchange for electricity meter reading, tariff and load control</td></tr><tr><td>e</td><td>IS 15959 Part 2 : 2016</td><td>Data exchange for electricity meter reading , tariff and load control</td></tr><tr><td>f</td><td>IEEE 802.15.4 : 2003</td><td>Standard for local and metropolitan area networks</td></tr><tr><td>g</td><td>IS 9000</td><td>Basic Environmental testing procedure for electrical and electronic items.</td></tr><tr><td>h</td><td>IEC 62052-11 : 2003</td><td>Electricity Requirements (AC) General Requirements Tests and Test conditions for A.C.Static Watt hour meter for active energy Class 1.0 and 2.0.</td></tr><tr><td>i</td><td>IEC 62053-21 : 2003</td><td>A.C.Static Watt hour meter for active energy Class 1.0 and 2.0</td></tr><tr><td>j</td><td>IS 15707 : 2006</td><td>Testing Evaluation installation and maintenance of AC Electricity Meters- Code of practice.</td></tr></table>	a	IS 16444 Part-1 : 2015	A.C. Static Direct connected Watt hour Smart meter class 1.0 and 2.0	b	IS 13779 : 1999	A.C. Static Watt hour meter class 1.0 and 2.0	c	IS 15884 : 2010	A.C. direct connected static prepayment meters for active energy (class 1 & 2)	d	IS 15959 Part 1 : 2011	Data exchange for electricity meter reading, tariff and load control	e	IS 15959 Part 2 : 2016	Data exchange for electricity meter reading , tariff and load control	f	IEEE 802.15.4 : 2003	Standard for local and metropolitan area networks	g	IS 9000	Basic Environmental testing procedure for electrical and electronic items.	h	IEC 62052-11 : 2003	Electricity Requirements (AC) General Requirements Tests and Test conditions for A.C.Static Watt hour meter for active energy Class 1.0 and 2.0.	i	IEC 62053-21 : 2003	A.C.Static Watt hour meter for active energy Class 1.0 and 2.0	j	IS 15707 : 2006	Testing Evaluation installation and maintenance of AC Electricity Meters- Code of practice.
a	IS 16444 Part-1 : 2015	A.C. Static Direct connected Watt hour Smart meter class 1.0 and 2.0																														
b	IS 13779 : 1999	A.C. Static Watt hour meter class 1.0 and 2.0																														
c	IS 15884 : 2010	A.C. direct connected static prepayment meters for active energy (class 1 & 2)																														
d	IS 15959 Part 1 : 2011	Data exchange for electricity meter reading, tariff and load control																														
e	IS 15959 Part 2 : 2016	Data exchange for electricity meter reading , tariff and load control																														
f	IEEE 802.15.4 : 2003	Standard for local and metropolitan area networks																														
g	IS 9000	Basic Environmental testing procedure for electrical and electronic items.																														
h	IEC 62052-11 : 2003	Electricity Requirements (AC) General Requirements Tests and Test conditions for A.C.Static Watt hour meter for active energy Class 1.0 and 2.0.																														
i	IEC 62053-21 : 2003	A.C.Static Watt hour meter for active energy Class 1.0 and 2.0																														
j	IS 15707 : 2006	Testing Evaluation installation and maintenance of AC Electricity Meters- Code of practice.																														

TPCODL

Document Title	SPECIFICATION FOR THREE PHASE 4 WIRE WHOLE CURRENT SMART METER WITH BOX	
Document No.	MMG-SMART-002	
		Page 3 of 39

		<table><tr><td>k</td><td>IEC 60068</td><td>Environmental testing.</td></tr><tr><td>l</td><td>CBIP-TR No.325</td><td>Specification for A.C. Static Electrical Energy Meters (latest amendment)</td></tr><tr><td>m</td><td>CEA Regulation (2006)</td><td>Installation and operation of meters Dtd: 17/03/2006.</td></tr><tr><td>n</td><td>IS 12346:1999</td><td>Testing Equipment For Ac Electrical Energy Meters</td></tr><tr><td>o</td><td>IS 11000</td><td>Fire Hazard Testing</td></tr><tr><td>p</td><td>IS 60529</td><td>Degree of protection provided by enclosure</td></tr></table>	k	IEC 60068	Environmental testing.	l	CBIP-TR No.325	Specification for A.C. Static Electrical Energy Meters (latest amendment)	m	CEA Regulation (2006)	Installation and operation of meters Dtd: 17/03/2006.	n	IS 12346:1999	Testing Equipment For Ac Electrical Energy Meters	o	IS 11000	Fire Hazard Testing	p	IS 60529	Degree of protection provided by enclosure				
k	IEC 60068	Environmental testing.																						
l	CBIP-TR No.325	Specification for A.C. Static Electrical Energy Meters (latest amendment)																						
m	CEA Regulation (2006)	Installation and operation of meters Dtd: 17/03/2006.																						
n	IS 12346:1999	Testing Equipment For Ac Electrical Energy Meters																						
o	IS 11000	Fire Hazard Testing																						
p	IS 60529	Degree of protection provided by enclosure																						
3	CLIMATE CONDITIONS OF THE INSTALLATION	<table><tr><td>a) Max. Ambient Temperature</td><td>: 50 deg.C</td></tr><tr><td>b) Max. Daily average ambient temp.</td><td>: 40 deg.C</td></tr><tr><td>c) Min Ambient Temp</td><td>: 0 deg C</td></tr><tr><td>d) Maximum Humidity</td><td>: 95%</td></tr><tr><td>e) Minimum Humidity</td><td>: 10%</td></tr><tr><td>f) Average No. of thunderstorm days per annum</td><td>: 50</td></tr><tr><td>g) Maximum Annual Rainfall</td><td>: 750 mm</td></tr><tr><td>h) Average No. of rainy days per annum</td><td>: 60</td></tr><tr><td>i) Rainy months</td><td>: June to Oct.</td></tr><tr><td>j) Altitude above MSL not exceeding</td><td>: 300 meters</td></tr><tr><td>k) Wind Pressure elevation at 10 m.</td><td>: 126 kg/sq m up to an</td></tr></table> <p>The atmosphere is generally laden with mild acid and dust in suspension during the dry months and is subjected to fog in cold months. The design of equipment and accessories shall be suitable to withstand seismic forces corresponding to an acceleration of 0.3 g.</p>	a) Max. Ambient Temperature	: 50 deg.C	b) Max. Daily average ambient temp.	: 40 deg.C	c) Min Ambient Temp	: 0 deg C	d) Maximum Humidity	: 95%	e) Minimum Humidity	: 10%	f) Average No. of thunderstorm days per annum	: 50	g) Maximum Annual Rainfall	: 750 mm	h) Average No. of rainy days per annum	: 60	i) Rainy months	: June to Oct.	j) Altitude above MSL not exceeding	: 300 meters	k) Wind Pressure elevation at 10 m.	: 126 kg/sq m up to an
a) Max. Ambient Temperature	: 50 deg.C																							
b) Max. Daily average ambient temp.	: 40 deg.C																							
c) Min Ambient Temp	: 0 deg C																							
d) Maximum Humidity	: 95%																							
e) Minimum Humidity	: 10%																							
f) Average No. of thunderstorm days per annum	: 50																							
g) Maximum Annual Rainfall	: 750 mm																							
h) Average No. of rainy days per annum	: 60																							
i) Rainy months	: June to Oct.																							
j) Altitude above MSL not exceeding	: 300 meters																							
k) Wind Pressure elevation at 10 m.	: 126 kg/sq m up to an																							
4	GENERAL TECHNICAL REQUIREMENTS	<table><tr><th>S.No.</th><th>DESCRIPTION</th><th>REQUIREMENT</th></tr><tr><td>4.01</td><td>Type of the meter</td><td>Three phase four wire, static watt-hour direct connected type smart meter without application of any multiplication constant. It consisting of measuring elements(s),time of use of register(s),display, load switch and plug in type bi-directional communication module all integral within the meter housing. Meter should be compatible for integration with HES of TPCODL.</td></tr><tr><td>4.02</td><td>Accuracy Class of the meter</td><td>1.0</td></tr><tr><td>4.03</td><td>Basic Current (Ib) & rated Maximum current (Imax)</td><td>Ib= 20A; Imax= 100 Amps (Meter shall be able to continuously carry 120% of Imax Meeting the accuracy requirements)</td></tr><tr><td>4.04</td><td>Reference Conditions for testing the performance of the meter</td><td>Vref = 230V Frequency = 50Hz Temperature= 27 °C</td></tr><tr><td>4.05</td><td>Operating Voltage</td><td>Meter shall be operational with required accuracy from 0.6 Vref to 1.2 Vref. However meter shall withstand the maximum system Voltage of 440V</td></tr></table>	S.No.	DESCRIPTION	REQUIREMENT	4.01	Type of the meter	Three phase four wire, static watt-hour direct connected type smart meter without application of any multiplication constant. It consisting of measuring elements(s),time of use of register(s),display, load switch and plug in type bi-directional communication module all integral within the meter housing. Meter should be compatible for integration with HES of TPCODL.	4.02	Accuracy Class of the meter	1.0	4.03	Basic Current (Ib) & rated Maximum current (Imax)	Ib= 20A; Imax= 100 Amps (Meter shall be able to continuously carry 120% of Imax Meeting the accuracy requirements)	4.04	Reference Conditions for testing the performance of the meter	Vref = 230V Frequency = 50Hz Temperature= 27 °C	4.05	Operating Voltage	Meter shall be operational with required accuracy from 0.6 Vref to 1.2 Vref. However meter shall withstand the maximum system Voltage of 440V				
S.No.	DESCRIPTION	REQUIREMENT																						
4.01	Type of the meter	Three phase four wire, static watt-hour direct connected type smart meter without application of any multiplication constant. It consisting of measuring elements(s),time of use of register(s),display, load switch and plug in type bi-directional communication module all integral within the meter housing. Meter should be compatible for integration with HES of TPCODL.																						
4.02	Accuracy Class of the meter	1.0																						
4.03	Basic Current (Ib) & rated Maximum current (Imax)	Ib= 20A; Imax= 100 Amps (Meter shall be able to continuously carry 120% of Imax Meeting the accuracy requirements)																						
4.04	Reference Conditions for testing the performance of the meter	Vref = 230V Frequency = 50Hz Temperature= 27 °C																						
4.05	Operating Voltage	Meter shall be operational with required accuracy from 0.6 Vref to 1.2 Vref. However meter shall withstand the maximum system Voltage of 440V																						

TPCODL

Document Title	SPECIFICATION FOR THREE PHASE 4 WIRE WHOLE CURRENT SMART METER WITH BOX	
Document No.	MMG-SMART-002	
		Page 4 of 39

			(for minimum 5 min).
	4.06	Operating Frequency	50 Hz± 5%.
	4.07	Power Consumption	Voltage circuit: Maximum 5.0 W and 15 VA Current Circuit :Maximum 4VA (The additional power requirement during data transmission shall not exceed 7W/as mentioned in IS 16444 whichever is lower, per communication module)
	4.08	Starting Current	40mA (0.2% of Ib) (phase current)
	4.09	Short time over Current	3000 A for 0.01 sec (30Imax for one half cycle at Rated frequency)
	4.10	Influence of heating	Temperature rise at any point of the external surface of the meter shall not exceed by more than 20 ⁰ C with an ambient temperature at 50 ⁰ C.
	4.11	Rated Impulse withstand voltage	6KV (shall be applied ten times with one polarity and then repeated with the other polarity.)
	4.12	AC withstand Voltage for 1 min	4 KV
	4.13	Minimum Insulation resistance at test voltage 500+/- 50 V dc a)Between frame & current ,voltage circuits as well as auxiliary circuits connected together: b)Between each current (or voltage circuit) & each and every other circuit. :	a) 5 M ohm b) 50 M ohm.
	4.14	Mechanical requirements	Meter shall be in compliance with clause 12.3 of IS 13779
	4.15	Resistance to heat and fire	The terminal block and Meter case shall ensure safety against the spread of fire. They shall not be ignited by thermal overload of live parts in contact with them as per clause 6.8 of IS 13779. Fire retardant material shall be used.
	4.16	Protection against penetration of dust and water.	Degree of protection :IP 51 as per IS 12063/60529, but Without suction in the meter. Meter shall comply with clause 6.9 and 12.5 of IS 13779
	4.17	Resistance against Climatic influence.	Meter shall be in compliance with clause 12.6 of IS 13779.

TPCODL

Document Title	SPECIFICATION FOR THREE PHASE 4 WIRE WHOLE CURRENT SMART METER WITH BOX	
Document No.	MMG-SMART-002	
		Page 5 of 39

		4.18	Electromagnetic Compatibility (EMC)	Meter shall be in compliance with clause 4.5 & 5.5 of IS 15884.
		4.19	Accuracy requirements	Meter shall be in compliance with clause 11 of IS 13779.
		4.20	Power factor range	Zero lag to Zero lead. & meter shall be programed at default lag only configuration i.e. Lead to be treated as unity for kVA& kVAh calculations
		4.21	Energy measurement	Fundamental energy +Energy due to Harmonics
		4.22	Connection Diagram	The connection diagram for the system shall be provided on terminal cover.
		4.23	Self Diagnostic feature	The meter shall have indications for un satisfactory / non-functioning of (i) Real Time Clock (ii) RTC battery (iii) Non Volatile Memory (iv) NIC card
		4.24	Initial start up of meter	Meter shall be fully functional within 5 sec after reference voltage is applied to the meter terminals.
		4.25	Alternate mode of supply to the meters	In case of meter power failure , reading/data should be retrieved with the help of battery or other power source.
		4.26	Sleep Mode	Meter shall not go in sleep mode. Display should not be 'off' at any point of time when power up.
		4.27	Internal diameter of the terminal holes Depth of the terminal holes	9.5mm (minimum) 20 mm (minimum)
		4.28	Clearance between adjacent terminals	10 mm (minimum)
		4.29	Display	Backlit LCD, Scrolling, 10 seconds for each parameter. minimum 8 digits LCD display
		4.30	Security feature	Programmable facility to restrict the access to the information recorded at different security level such as read communication, write communication ,firmware selection from remote etc.
		4.31	Software and communication compatibility	The bidder shall supply software required for local (MRI – conventional/4G) & remote (AMI) connectivity including required training to use the software free of cost.
		4.32	Calibration	Meters shall be software calibrated at factory and modifications in calibration shall not be possible at site by any means. However parameters like RTC,TOD slots, DIP(billing & load survey), billing date, display

TPCODL

Document Title	SPECIFICATION FOR THREE PHASE 4 WIRE WHOLE CURRENT SMART METER WITH BOX	
Document No.	MMG-SMART-002	
		Page 6 of 39

				parameters etc. shall be reconfigure through MRI and remotely over the air (OTA)
		4.33	Communication module of meter for AMI	As per clause no 1.2 (b) of IS 16444. Meter should have provision of communication module compatible with both the variant mentioned in IS 16444. This module should be able to get connected to the NAN / WAN network of service provider (4G) of TPCODL. Meter should be able to provide required power supply to NIC card provided by communication provider recommended by TPCODL. Size /form factor of NIC card will be provided by TPCODL to the bidder and bidder should make necessary arrangement for the same.
		4.34	Communication Layer Protocol	Should be as per clause 9.3 of IS 16444
		4.35	Key Management and Security Feature	Should be as per IS 15959
		4.36	Harmonics recording	The meter should record the current and voltage THD. The meter should record harmonics up to 20th harmonic Average THD of all phase for voltage THD and current THD. THD values shall have 30 minutes integration period in load survey. Accuracy of harmonics recording shall be as per meter accuracy class. The meter shall generate a flag whenever the threshold (user configurable) of the 5% THD of the load current and voltage is breached.
		4.37	Usage Application	Indoor and Outdoor
		4.38	Ultrasonic welding / Chemical Bonding	Meter cover and body should be ultrasonically welded or should be seamlessly chemically bonded, so that meter should not open without leaving clear mark.

TPCODL

Document Title	SPECIFICATION FOR THREE PHASE 4 WIRE WHOLE CURRENT SMART METER WITH BOX	
Document No.	MMG-SMART-002	
		Page 7 of 39

4.1	DISCONNECTOR	<p>The meter shall have the facility of disconnecting and re-connecting the load of the meter from the remote and by authenticated command through Laptop/HHU at site by means of a built-in contactor. This operation shall be conducted with the help of a third party software which is owned by us and in addition to the manufacturer's own software,. Each operation of the switches shall be logged by the meter as an event with date and time stamp and reading parameters. This operation should be in line with clause 11 of IS 16444, however should be disabled by default. Meter should display reason for disconnection in meter display and IHD (if available). The cumulative number of ON/OFF operations shall also be made available.</p> <p>Switch shall be in compliance to IS 15884. The make of the load switch should be of reputed make like Grooner (German) or equivalent and same shall be confirmed by the bidder during tendering. The brief technical particulars of this Disconnecter/load switch are furnished below:-</p> <table border="1" data-bbox="475 969 1497 1395"> <thead> <tr> <th>S.No.</th><th>DESCRIPTION</th><th>REQUIREMENT</th></tr> </thead> <tbody> <tr> <td>1</td><td>Operating Voltage range</td><td>130 V to 470 V</td></tr> <tr> <td>2</td><td>Operating Current range</td><td>20 mA to 120 A</td></tr> <tr> <td>3</td><td>Maximum switching power</td><td>22 kVA per phase/ per IS 15884 Annex G</td></tr> <tr> <td>4</td><td>No. of poles</td><td>3 nos (one in each R,Y,B phases)</td></tr> <tr> <td>5</td><td>Operation of switches</td><td>Simultaneous</td></tr> <tr> <td>6</td><td>Utilization Categories</td><td>UC2 or better</td></tr> <tr> <td>7</td><td>Min. Number of operation</td><td>3000 (close, open each)</td></tr> </tbody> </table>	S.No.	DESCRIPTION	REQUIREMENT	1	Operating Voltage range	130 V to 470 V	2	Operating Current range	20 mA to 120 A	3	Maximum switching power	22 kVA per phase/ per IS 15884 Annex G	4	No. of poles	3 nos (one in each R,Y,B phases)	5	Operation of switches	Simultaneous	6	Utilization Categories	UC2 or better	7	Min. Number of operation	3000 (close, open each)
S.No.	DESCRIPTION	REQUIREMENT																								
1	Operating Voltage range	130 V to 470 V																								
2	Operating Current range	20 mA to 120 A																								
3	Maximum switching power	22 kVA per phase/ per IS 15884 Annex G																								
4	No. of poles	3 nos (one in each R,Y,B phases)																								
5	Operation of switches	Simultaneous																								
6	Utilization Categories	UC2 or better																								
7	Min. Number of operation	3000 (close, open each)																								
4.2	NIC MODULE DETAILS & INTEGRATION	<p>With the service providers offering 4G services, TPCODL intends to leverage 4G as the primary communication technology with hot swappable 2G Interface Card as a fall back for meter data acquisition.</p> <ol style="list-style-type: none"> The Network Interface Card for 4G shall be modular and pluggable. The NIC shall be interoperable for service provider and should be compatible with HES of TPCODL. NIC card shall support remote Device Management Capability such as Reset, Configuration, Log Check, Ping, and over the air Firmware upgrade NIC shall support two-way communications between smart meter & head-end system such as data exchange, configuration parameters exchange, alarms, operational commands, firmware upgrade of the meter as defined in IS16444 and IS15959. NIC shall support push services, alarms services of the smart meter as defined in IS16444 and IS15959. 4G NIC card shall support communication protocols as prescribed by 4G HES supplier. NIC shall also support on-demand / schedule reading, connect / disconnect, time sync, configuration and over the air firmware upgrade from the head-end system. NIC shall have persistent network connectivity throughout as defined by 4G standards. It shall support self-configuring and self-healing features. 																								

TPCODL

Document Title	SPECIFICATION FOR THREE PHASE 4 WIRE WHOLE CURRENT SMART METER WITH BOX	
Document No.	MMG-SMART-002	
		Page 8 of 39

		<ul style="list-style-type: none"> h) NIC shall operate 24*7 and shall recover from any deadlock situation immediately in the field. i) Support for possibility for provision of a unique certificate/key in each card for mutual authentication with the HES from security point of view. j) NIC shall support standard security protocols. k) NIC shall be compliant with cyber security norms. l) NIC shall register with network i.e. login and logout of each terminal to the HES. It shall be recognized in the HES as authorized node. m) Attributes such as Firmware version, Hardware version, Signal strength values, packet error rate, should be pushed periodically to HES for effective communication management. n) Data must be encrypted with AES-256 bit. o) LED indication for System, Power ON indicator. p) Colour coded LED (a) For latching on to the network (b) For latched on to the network (c) For data flow indication. q) Meter display should have provision for showing if NIC card if : 1. Installed, 2. Getting Network, 3. Latched with HES, 4. Communicating with HES
4.3	Communication capabilities and software feasibilities	<p>4.3.1 The meter shall have facilities for data transfer locally through Meter Reading Instrument (MRI) (Using optical port/NIC card) and remotely by 4G with proper security via Plug in type NIC. Data transfer locally through optical port via MRI is desired along with data transfer through NIC card. The data downloaded in MRI/hand held device shall be integrated to HES data base.</p> <p>4.3.2 It should be the responsibility of the bidder to ensure integration of meter into HES. For cellular fallback, the Module should have backward compatibility. The fall back provision shall be taken through optical port with external modem by TPCODL. Meter should be capable for sending all data from 4G NIC and optical port.</p> <p>4.3.3 It shall be possible to reconfigure the meters for RTC, TOD slots reprogramming, DIP (Demand Integration period), billing date , display parameters etc. through proper authentication process locally through MRI and remotely over the air (OTA). Meter data should remain intact with timings. And billing should be done whenever any above mentioned attribute is changed. The change should be recorded as upgrade event.</p> <p>4.3.4 Necessary keys if required for performing this reconfiguration operation should also be provided along with supply of meter lot & training to TPCODL staff on how to use it free of cost. Bidder to provide this support on a later stage also on the request of TPCODL without any cost implication.</p> <p>4.3.5 Optical Communication port shall be available for communication. Communication ports shall not be affected by any type of injection /unauthenticated signals and having proper sealing arrangement. The complete data shall be downloaded within 5 minutes OTA.</p> <p>4.3.6 Bidder to ensure integration of meter data with head end for data transfer as mentioned in specification.</p> <p>4.3.7 Meter should be supplied to TPCODL along with integrated NIC card. NIC card should be plug in type with proper sealing arrangement.</p>

TPCODL

Document Title	SPECIFICATION FOR THREE PHASE 4 WIRE WHOLE CURRENT SMART METER WITH BOX	
Document No.	MMG-SMART-002	
		Page 9 of 39

		<p>4.3.8 The bidder shall supply software required for local (MRI) & remote (AMI) connectivity including required training to use the software free of cost. Bidder shall provide the communication protocol / APIs for communication with meter through local (MRI) / remote (AMI) as and when required by TPCODL free of cost during life time of meter. The bidder should provide DLMS compliance for Communication with the meter at Optical port and at HES.</p> <p>4.3.9 Bidder should also provide software for changing/upgrading meter firmware in mass and should support integration of this software with HES. Bidder should also provide base computer software (BCS) for viewing the data downloaded through HES/MRI/laptop/HHU in separate PC/laptop. Android based or windows based HHU shall be preferred.</p> <p>4.3.10 For purpose of exercising control, like outage management, the meter should send abnormalities at the consumers' end like Power failure (Last Gasp) instantly, Power Restoration (First Breath) as event. Additional exceptional events should also be communicated to HES by meter immediately after the occurrence. It should also indicate the restoration of the same event.</p> <p>4.3.11 List of events to be reported should be configurable over the air(OTA).The meter should have "Last Gasp" and "First Breath" feature to facilitate sending alerts to the HES during fully powered off / On condition.</p> <p>4.3.12 If there are 2 requests given for communication one from HES and other from local device, request from local device should supersede.</p> <p>4.3.13 Last mile mesh network must support auto-registration and self-healing feature to continue operation using easiest possible available route in case of failure of any communication device in the mesh. Self-registrations in first communication.</p> <p>4.3.14 Meter Serial no will be used for tagging of all data of the meters in all database (at HES / MDM/ DCU level etc). However, it will be the responsibility of the Bidder to establish the complete communication solution involving all the meters in the system. Also, the Bidder must ensure that, the mode of communication used for 4G shall be consistent with the Government of India stipulations. Bidder should come out with it requirements for integration of meter with HES and MDMS clearly during tender submission.</p> <p>4.3.15 The Bidder's supplied meter with third party communication module should have suitable hand-shaking features to allow a third-party MDMS(procured by TPCODL) to configure, command, read and control smart meters installed at site. The Bidder shall extend all necessary assistance in developing the adaptor software through a third-party for facilitating the above.</p> <p>4.3.16 Integration of meter software's with HES / MDMS for seamless transfer of data will also be in scope of bidder till the expiry of warranty of the meters. It is desired meter firmware up gradation/selection should be available over the air. Meter should be able to change to prepaid mode if required with firmware upgrade. The required firmware and any required support for integration with HES shall be provided free of cost till the useful life of the meter.</p> <p>4.3.17 Communication of the meter at optical port /OTA (NAN/WAN) should be as per IS 15959 (Part-2):2016. The optical port should be with proper lockable mechanism</p>
--	--	--

TPCODL

Document Title	SPECIFICATION FOR THREE PHASE 4 WIRE WHOLE CURRENT SMART METER WITH BOX	
Document No.	MMG-SMART-002	
		Page 10 of 39

		<p>4.3.18 Communication NIC/network should be immune with any external Magnetic field/ESD/Jammer/HV voltage influence such that it shall not affect the normal overall functionality.</p> <p>4.3.19 Meter once powered up with NIC card should be self-detected by 4G network and its basic name plate details & current readings are transferred to HES.</p> <p>4.3.20 The required OBIS codes will be finalized with successful bidder. The bidder can offer desired codes from Blue Book ensuing the codes reserved or standardized by Bureau of Indian standards. The reserved codes in BIS are to be used/utilized as per guidelines of BIS and remaining codes from blue book can be used for communication of additional features mentioned in this specifications. This is to be done strictly with written approval from TPCODL after verification of proposed codes by manufacturer. In future if BIS adds any OBIS codes then the bidders to provide upgraded firmware with desired changes after in consultation and approval of TPCODL competent authority.</p> <p>4.3.21 Meter display should have provision for showing if NIC card if : 1. Installed, 2. Getting Network, 3. Latched with HES, 4. Communicating with HES</p> <p>4.3.22 If any tamper occurs in power off situation, it should be pushed as soon as the meter is powered on.</p> <p>4.3.23 Bidder to provide facility for Up-gradation / Modification of Firmware</p> <p>4.3.24 Following parameters may be updated multiple times during life cycle of meters over the air : Post Paid to Prepaid mode and vice versa Import mode to export Mode and vice versa. Accordingly Display parameters shall be updated remotely.</p>
4.4	Immunity against external influencing signals	<p>4.4.1 Magnetic Field: Meter shall record accurate energy in case of any external influencing signals in line with IS 13779:1999 Cl.11.2 and variation in limits of error (upto 100% I_{max}) shall be as per the table 17 of IS 13779. Meter shall be immune to magnetic field such that it shall not affect the normal overall functionality However, in case of abnormal magnetic field as defined below meter shall perform as per the following actions:</p> <p>a) Meter shall log the event in its memory as" Magnet" with date and time stamp, the event logging threshold values as per table no. 1 in 4.55</p> <p>b) The energy recording to shift on I_{max}, V_{ref}. with UPF.</p> <p>Abnormal Magnetic field is defined as below;</p> <p>a) Continuous DC magnetic induction: >0.20 Tesla ± 5% (Value of the magneto motive force to be applied shall be generally >10000 AT.</p> <p>b) AC magnetic induction: >10 milli Tesla (if produced with circular metal core with square cross section as specified in CBIP latest report with 2800 AT)</p> <p>c) Permanent Magnet: Immune up to 0.5T and Event logging >0.5T.</p>

TPCODL

Document Title	SPECIFICATION FOR THREE PHASE 4 WIRE WHOLE CURRENT SMART METER WITH BOX	
Document No.	MMG-SMART-002	
		Page 11 of 39

		<p>4.4.2 Electrostatic Discharge (ESD)</p> <p>Meter shall be immune up to 50 kV and shall record accurate energy as per IS-13779:1999/CBIP-325. Meter shall log the event into memory as ' ESD' with date & time stamp for any ESD greater than 50 kV with snap shot, the event logging threshold values as per table no. 1 in 4.6</p> <p>4.4.3 The shielding around the meter shall be such that it does not get affected by high Voltage and high energy or low energy impulse when comes in contact with meter from any side.</p> <p>4.4.4 Meter should immune to high/low frequency jammer devices. Meter shall log the event in its memory as" JAMMER" with date and time stamp, the threshold values as per table no. 1 in 4.6.</p> <p>4.4.5 The meter should be immune or log the tamper on application of any other higher magnetic field of any frequency waves, micro waves like magnetron etc. the threshold values as per table no. 1 in 4.6.</p>
4.5	Neutral Disturbance & other tampers	<p>4.5.1 The meter shall not saturate on passage of direct current, which can cause the meter either to stop recording/ record inaccurately. DC injection shall be tested both in phase and neutral. Measurement by meter shall not get influenced by injection of Chopped signal/ DC signal/ DC pulse upto 330V and for any value beyond this. Meter shall log the event into memory as 'Neutral Disturbance' with date & time stamp the thresholds are as per table no. 1 in 4.6</p> <p>4.5.2 The meter should log event as 'High Neutral current' with snapshot when all three phase currents are zero and neutral current is present.</p>
4.7	Event compartments	<p>4.7.1 The event compartments shall be IS 15959 Part-1 table 9.</p> <p>4.7.2 The size of the event compartments should be such that all above events (in table no.1 and other required events defined in various clauses of this documents) are accommodated in the assigned event category compartment. i.e. if in case of voltage compartment assigned to 4 number of events then the minimum size of this compartment should be such that it should accommodate sum of all maximum number of events as marked above table 1 .</p> <p>4.7.3 Transaction events compartment size shall be minimum 100 events.</p>
5	GENERALCONST RUCTIONS	<p>The Meter shall be designed and constructed in such a way as to avoid introducing any danger in normal use and under normal conditions, so as to ensure especially personal safety against electric shock, safety against effect of excessive temperature, protection against spread of fire, protection against penetration of solid objects, dust and water.</p> <p>All parts, which are subject to corrosion under normal working conditions, shall be protected effectively. Any protective coating shall not be liable to damage by ordinary handling or damage due to exposure to air, under normal working conditions.</p> <p>The meters shall be designed and manufactured using SMT (Surface Mount Technology) components</p>

TPCODL

Document Title	SPECIFICATION FOR THREE PHASE 4 WIRE WHOLE CURRENT SMART METER WITH BOX	
Document No.	MMG-SMART-002	
		Page 12 of 39

		<p>There should not be any connector or joint in the CT connection from PCB. All CT secondary shall be soldered on PCB. The battery cell shall be button/coin type leak proof.</p> <p>All the material and electronic power components used in the manufacture of the meter shall be of highest quality and reputed make to ensure higher reliability, longer life and sustained accuracy as given below or any other equivalent make with the strict approval of TPCODL:</p>																								
		<table><tr><th>S No</th><th>Component Function</th><th>Requirement</th><th>Makes and Origin</th></tr><tr><td>1.</td><td>Measurement/ computing chips</td><td>The Measurement/ computing chips used in the meter should be with the Surface mount type along with the ASICs</td><td><u>USA:</u> Anolog Devices, Cyrus Logic, Atmel, Phillips, Freescale semiconductor <u>South Africa:</u> SAMES <u>Japan:</u> NEC</td></tr><tr><td>2.</td><td>Memory chips/NVM</td><td>The memory chips should not be affected by the external parameters like sparking, high voltage spikes or electrostatic discharges. The life of NVM shall be 15 years.</td><td><u>USA:</u> Atmel, National Semiconductors, Texas Instruments, Phillips, Microchip <u>Japan:</u> Hitachi or Oki <u>Swiss:</u> ST Micro</td></tr><tr><td>3.</td><td>Display modules</td><td>The display modules should be well protected from the external UV radiations. The display visibility should be sufficient to read the meter mounted between height of 0.5m and 2m. The construction of the modules should be such that the displayed quantity should not disturbed with the life of display. Should be with Green LED background. It should be trans-reflective STN type industrial grade with extended temperature range.</td><td><u>Taiwan:</u> Holtek <u>Singapore:</u> Bonafied Technologies <u>Korea:</u> Advantek <u>China:</u> Xiamen, Truly semiconductor</td></tr><tr><td>4.</td><td>Optical port</td><td>Optical port should be used to transfer the meter data to meter reading instrument. The mechanical construction of the port should be such to facilitate the data transfer easily. It should be magnetic locking type</td><td><u>USA:</u> National Semiconductors <u>Holland / Korea:</u> Phillips <u>Taiwan:</u> MAXIM, Everlight <u>Japan:</u>Hitachi</td></tr><tr><td>5</td><td>P.C.B.</td><td>Glass Epoxy, fire resistance grade with minimum thickness 1.6 mm</td><td><u>A class consumer</u></td></tr></table>	S No	Component Function	Requirement	Makes and Origin	1.	Measurement/ computing chips	The Measurement/ computing chips used in the meter should be with the Surface mount type along with the ASICs	<u>USA:</u> Anolog Devices, Cyrus Logic, Atmel, Phillips, Freescale semiconductor <u>South Africa:</u> SAMES <u>Japan:</u> NEC	2.	Memory chips/NVM	The memory chips should not be affected by the external parameters like sparking, high voltage spikes or electrostatic discharges. The life of NVM shall be 15 years.	<u>USA:</u> Atmel, National Semiconductors, Texas Instruments, Phillips, Microchip <u>Japan:</u> Hitachi or Oki <u>Swiss:</u> ST Micro	3.	Display modules	The display modules should be well protected from the external UV radiations. The display visibility should be sufficient to read the meter mounted between height of 0.5m and 2m. The construction of the modules should be such that the displayed quantity should not disturbed with the life of display. Should be with Green LED background. It should be trans-reflective STN type industrial grade with extended temperature range.	<u>Taiwan:</u> Holtek <u>Singapore:</u> Bonafied Technologies <u>Korea:</u> Advantek <u>China:</u> Xiamen, Truly semiconductor	4.	Optical port	Optical port should be used to transfer the meter data to meter reading instrument. The mechanical construction of the port should be such to facilitate the data transfer easily. It should be magnetic locking type	<u>USA:</u> National Semiconductors <u>Holland / Korea:</u> Phillips <u>Taiwan:</u> MAXIM, Everlight <u>Japan:</u> Hitachi	5	P.C.B.	Glass Epoxy, fire resistance grade with minimum thickness 1.6 mm	<u>A class consumer</u>
S No	Component Function	Requirement	Makes and Origin																							
1.	Measurement/ computing chips	The Measurement/ computing chips used in the meter should be with the Surface mount type along with the ASICs	<u>USA:</u> Anolog Devices, Cyrus Logic, Atmel, Phillips, Freescale semiconductor <u>South Africa:</u> SAMES <u>Japan:</u> NEC																							
2.	Memory chips/NVM	The memory chips should not be affected by the external parameters like sparking, high voltage spikes or electrostatic discharges. The life of NVM shall be 15 years.	<u>USA:</u> Atmel, National Semiconductors, Texas Instruments, Phillips, Microchip <u>Japan:</u> Hitachi or Oki <u>Swiss:</u> ST Micro																							
3.	Display modules	The display modules should be well protected from the external UV radiations. The display visibility should be sufficient to read the meter mounted between height of 0.5m and 2m. The construction of the modules should be such that the displayed quantity should not disturbed with the life of display. Should be with Green LED background. It should be trans-reflective STN type industrial grade with extended temperature range.	<u>Taiwan:</u> Holtek <u>Singapore:</u> Bonafied Technologies <u>Korea:</u> Advantek <u>China:</u> Xiamen, Truly semiconductor																							
4.	Optical port	Optical port should be used to transfer the meter data to meter reading instrument. The mechanical construction of the port should be such to facilitate the data transfer easily. It should be magnetic locking type	<u>USA:</u> National Semiconductors <u>Holland / Korea:</u> Phillips <u>Taiwan:</u> MAXIM, Everlight <u>Japan:</u> Hitachi																							
5	P.C.B.	Glass Epoxy, fire resistance grade with minimum thickness 1.6 mm	<u>A class consumer</u>																							

TPCODL

Document Title	SPECIFICATION FOR THREE PHASE 4 WIRE WHOLE CURRENT SMART METER WITH BOX	
Document No.	MMG-SMART-002	
		Page 13 of 39

		<table><tr><td>6.</td><td>Electronic components</td><td>The active & passive components should be of the surface mount type & are to be handled & soldered by the state of art assembly processes.</td><td><u>USA:</u> National Semiconductors, Atmel,Phillips, Texas Instruments, Vishay <u>Japan:</u>Hitachi, Oki, AVX or Ricoh <u>Korea:</u> Samsung</td></tr><tr><td>7.</td><td>Battery</td><td>Lithium with guaranteed life of 15 years</td><td>Varta / Tedirun /Vitzrocell / Sanyo or equivalent.</td></tr><tr><td>8.</td><td>Micro controller and RTC having separate battery</td><td>The accuracy of RTC shall be as per relevant IEC / IS standards and RTC shall be provided with separate battery in its ckt.. The micro controller shall be of superior quality from reputed make with long life.</td><td>USA: Philips , Dallas, Atmel, Motorola <u>Japan:</u> NEC or Oki</td></tr><tr><td>9.</td><td>Temperature sensor</td><td>Temperature sensor shall be internal to the meter and its accuracy shall be as per relevant IEC / IS standards. The OEM test report to be furnished. With good performance till life of meter.</td><td>USA: Philips , Dallas, Atmel, Motorola <u>Japan:</u> NEC or Oki</td></tr></table>	6.	Electronic components	The active & passive components should be of the surface mount type & are to be handled & soldered by the state of art assembly processes.	<u>USA:</u> National Semiconductors, Atmel,Phillips, Texas Instruments, Vishay <u>Japan:</u> Hitachi, Oki, AVX or Ricoh <u>Korea:</u> Samsung	7.	Battery	Lithium with guaranteed life of 15 years	Varta / Tedirun /Vitzrocell / Sanyo or equivalent.	8.	Micro controller and RTC having separate battery	The accuracy of RTC shall be as per relevant IEC / IS standards and RTC shall be provided with separate battery in its ckt.. The micro controller shall be of superior quality from reputed make with long life.	USA: Philips , Dallas, Atmel, Motorola <u>Japan:</u> NEC or Oki	9.	Temperature sensor	Temperature sensor shall be internal to the meter and its accuracy shall be as per relevant IEC / IS standards. The OEM test report to be furnished. With good performance till life of meter.	USA: Philips , Dallas, Atmel, Motorola <u>Japan:</u> NEC or Oki
6.	Electronic components	The active & passive components should be of the surface mount type & are to be handled & soldered by the state of art assembly processes.	<u>USA:</u> National Semiconductors, Atmel,Phillips, Texas Instruments, Vishay <u>Japan:</u> Hitachi, Oki, AVX or Ricoh <u>Korea:</u> Samsung															
7.	Battery	Lithium with guaranteed life of 15 years	Varta / Tedirun /Vitzrocell / Sanyo or equivalent.															
8.	Micro controller and RTC having separate battery	The accuracy of RTC shall be as per relevant IEC / IS standards and RTC shall be provided with separate battery in its ckt.. The micro controller shall be of superior quality from reputed make with long life.	USA: Philips , Dallas, Atmel, Motorola <u>Japan:</u> NEC or Oki															
9.	Temperature sensor	Temperature sensor shall be internal to the meter and its accuracy shall be as per relevant IEC / IS standards. The OEM test report to be furnished. With good performance till life of meter.	USA: Philips , Dallas, Atmel, Motorola <u>Japan:</u> NEC or Oki															
5.1	Meter Body	<p>5.1.1 Meter body shall be made of unbreakable, high grade, fire retardant reinforced Insulating material (protective Class II) with FV0 Fire Retardant, self - extinguishing, UV stabilize, recyclable and Anti oxidation properties.</p> <p>5.1.2 The minimum thickness of the meter enclosure shall be 2mm.</p> <p>5.1.3 Meter base shall be opaque with polycarbonate LEXAN 500R or equivalent on prior approval from the TPCODL. (If different material offered the bidders should submit material data sheet in technical bid)</p> <p>5.1.4 Meter cover shall be transparent with polycarbonate LEXAN 143R/943A or equivalent on prior approval from the TPCODL. (If different material offered the bidders should submit material data sheet in technical bid)</p> <p>5.1.5 Meter cover & base shall be provided with continuous and seamless Ultrasonic welding such that it is not opened without breaking the enclosure. Front cover & base shall be such that it is not possible to cut & open the meter without certainly damaging the meter body and by no means shall an attempt to reassemble would not leave physical evidence. The damage evidences should be visible externally& should be traceable in such a way that attempts can be proved in court of law.</p> <p>5.1.6 The meter body shall be sealed in such a way that opening of meter base and cover is possible only after breaking the seal(s).</p> <p>5.1.7 Unidirectional screws to be used on meter covers where ever required.</p>																

TPCODL

Document Title	SPECIFICATION FOR THREE PHASE 4 WIRE WHOLE CURRENT SMART METER WITH BOX	
Document No.	MMG-SMART-002	
		Page 14 of 39

		<p>5.1.8 During meter manufacturing the meter seal fixing should be tightened such that the seal body should be close to meter body.</p> <p>5.1.9 The Meter body shall be such that the liquid or chemical shall not reach the electronic parts if liquid is injected from any side of meter body such as meter terminals, push button, display, NIC card casing etc. Necessary protection and water tight sealing to be provided at terminals and Push buttons etc.</p> <p>5.1.10 OEM should provide all required features as per OERC billing criteria in meter even if it is not mentioned in the specifications.</p>
5.2	Terminals, Terminal Block	<p>5.2.1 Terminal block should be in single mould with meter body base. (Not separate)</p> <p>5.2.1 After any attempts the terminal block should not be able to disengaged, opened or loosen from any side. Any attempt to disengage the terminal block should certainly damage the meter body with physical evidences. The damage evidences should be visible externally& should be traceable in such a way that attempts can be proved in court of law.</p> <p>5.2.2 Terminals may be grouped in terminal block having adequate insulating properties and mechanical strength. In order to satisfy such requirements when choosing insulating materials for the terminal block adequate testing of materials shall be taken into account.</p> <p>5.2.3 Terminal block and terminal cover shall be of a material which complies with the requirements of IS11731 (part 1) method FH1. The material of which the terminal block is made shall be capable of passing the Heat Deflection temperature test given in ISO 75 for temperature of 180°C and pressure of 1.8 M Pa. Tested as per ISO 75-2/A or ASTM D648.</p> <p>5.2.4 The terminal block shall be of opaque with polycarbonate LEXAN500R or equivalent on prior approval from the TPCODL. (If different material offered the bidders should submit material data sheet in technical bid)</p> <p>5.2.5 The terminals and connections shall be suitable to carry up to 120 % of I_{max} continuously (I_{max} 100 A). The size, design & material of Busbar /Shunt/Terminal shall be with suitable cross sectional area so that temperature rise will not be more than 20 °C above ambient temperature of 45°C at 120% of I_{max} loading for 06hrs continuous. This test of temp. rise shall be done on tender samples & will also be done on any samples from any supplied lot.</p> <p>5.2.6 To get the desired temp rise & avoid hot spots the design of the each terminal screw, terminal screw shall be of optimal design. Size of the screw is 8mm dia.</p> <p>5.2.7 The terminal block, the terminal cover and the meter case shall ensure reasonable safety against the spread of fire. They shall not be ignited by thermal overload of live parts in contact with them.</p> <p>5.2.8 Temperature sensor to be provided from inside near the terminal block of the energy meter for sensing the temperature and meter should be programmed</p>

TPCODL

Document Title	SPECIFICATION FOR THREE PHASE 4 WIRE WHOLE CURRENT SMART METER WITH BOX	
Document No.	MMG-SMART-002	
		Page 15 of 39

		<p>in such way that on reaching the threshold value set (as per tamper table no. 1) the event/alert should go the to HES/MDMS.</p> <p>5.2.9 The manner of fixing the conductors to the terminals shall ensure adequate and durable contact such that there is no risk of loosening or undue heating. Terminals shall be preferably with at least 8 mm dia for better contact area. Terminal & screw should not be damaged during regular opening and tightening. (MS terminals not accepted)</p> <p>5.2.10 Internal diameter of the terminal holes shall be minimum 9.5 mm; minimum clearance between adjacent terminals shall be 10 mm. Minimum Depth of the terminal holes shall be of 20 mm.</p> <p>5.2.11 Minimum two number of terminal screws to be provided per terminal wire.</p> <p>5.2.12 Terminal block shall be such that the risk of corrosion resulting from contact with any other metal part is minimized. Electrical connections shall be so designed that contact pressure is not transmitted through insulating material.</p> <p>5.2.13 The Aluminum cable of 4x50sq.mm shall be used as service line. Hence the terminals shall be provided with Zinc plating or tinning or suitable compatible coating to avoid the bimetallic effect at the joints with AL core of cable.</p> <p>5.2.14 The preferred arrangement of terminals shall be linear and if any change is offered then suitable arrangement for testing at our testing lab (MMG and MTL) to be provided by bidder free of cost as per requirement.</p>
5.3	Terminal Cover	<p>5.3.1 Terminal cover shall be transparent with polycarbonate LEXAN 143R/943A or equivalent on prior approval from the TPCODL.</p> <p>5.3.2 Appropriate space shall be available for incoming /outgoing cables without damaging/stressing terminal cover (terminal cover design shall be as per the TPCODL approval). After sealing the cover, terminals shall not be accessible without breaking the seals.</p> <p>5.3.3 The terminal cover design should be such that the sealing screw locking provision on cover should have min dimension of 3mmx3mm. (Excluding seal lock hole)</p>
5.4	Sealing of meter& terminal cover	<p>5.4.1 Reliable sealing arrangement shall be provided to make the meter tamper evident and to avoid fiddling or tampering by unauthorized persons.</p> <p>5.4.2 For this, one no. Polycarbonate seal and three no. Hologram seal (on Left, Right & Top side) shall be provided by the bidder.</p> <p>5.4.3. One no polycarbonate seal shall be provided by the TPCODL. This seal shall be fix on right hand side of meter.</p> <p>5.4.4. All the seals with unique serial numbers shall be fixed on meter body by the bidder at his works before calling for inspection.</p>

TPCODL

Document Title	SPECIFICATION FOR THREE PHASE 4 WIRE WHOLE CURRENT SMART METER WITH BOX	
Document No.	MMG-SMART-002	
		Page 16 of 39

		<p>5.4.5 Two sealing provision shall be provided at meter terminal cover, such that terminal shall not be accessible without breaking the seals. All the seals shall be provided on front side only and as per the TPCODL specification. Rear side sealing arrangement shall not be accepted. Bidder shall provide seals be as per CEA regulation (2006). Only patented seals to be used as per CEA requirements.</p> <p>5.4.6 Plug in type NIC card cover should have proper sealing arrangement and should be sealed with TPCODL polycarbonate seal.</p> <p>5.4.7 The bidder shall provide TPCODL(MMG store and MTL) the soft record of polycarbonate seal and hologram seal serial number and NIC card serial number used against each meter serial number along with its position (RHS/LHS/Top/ NIC Cover) in tabular form for every lot of meter.</p>									
5.5	TOD Feature	<p>The meter shall be capable of measuring Cumulative Energy (kWh & kVAh), and MD (kW & kVA) with time of day (TOD) registers having 8 zones & 02 seasons (no. of zones & time slot shall be programmable by MRI with adequate security level and in one to one /broadcast mode over the air). Current TOD (during tender) to be given is as below,</p> <table border="1"> <thead> <tr> <th>Slots</th><th>Time Slot</th><th>Jan-Dec</th></tr> </thead> <tbody> <tr> <td>Off-Peak</td><td>22:00-06:00</td><td>Register 1</td></tr> <tr> <td>Peak</td><td>06:00-22:00</td><td>Register 2</td></tr> </tbody> </table> <p>The bidder to ask TPCODL for latest TOD timing slots before manufacturing of every lot.</p>	Slots	Time Slot	Jan-Dec	Off-Peak	22:00-06:00	Register 1	Peak	06:00-22:00	Register 2
Slots	Time Slot	Jan-Dec									
Off-Peak	22:00-06:00	Register 1									
Peak	06:00-22:00	Register 2									
5.6	MD Integration	<p>The MD integration period shall be 30 minutes (integration period-programmable by MRI at site and also thru AMR with adequate security level). The MD resetting shall be automatic at the 1st of the month i.e. 0000 hours of 1st day of the month. Manual MD reset button shall not be available. Last six MD values shall be stored in the memory and one to be displayed in the Auto scroll mode. MD shall be recorded and displayed with minimum three digits before decimal and minimum two digits after decimal points. MD integration shall be of sliding Type at an interval of 10 min.</p>									
5.7	Parameters in BCS	<p>All these parameters shall be downloaded locally or remotely and interpreted in PC/Laptop. All the parameters shall be recorded and memorized in its Non volatile Memory (NVM). The corresponding non volatile memory shall have a minimum retention time of 10 years. Last six months history data (kWh & kVAh (lag only) current & TOD reading and MD(kW & kVA(lag only) current & TOD) with data and time) and at least last 25 tamper events for each tamper shall be available in the non volatile Memory.</p> <p>Fail to be log in memory in the following conditions only in BCS not in display</p> <ol style="list-style-type: none"> RTC fail NVM memory fail Battery fail NIC card fail <p>'High THD' to be log in memory in the following conditions only in BCS not in display</p> <ol style="list-style-type: none"> THDV any phase higher than threshold 									

TPCODL

Document Title	SPECIFICATION FOR THREE PHASE 4 WIRE WHOLE CURRENT SMART METER WITH BOX	
Document No.	MMG-SMART-002	
		Page 17 of 39

		<p>b) THDI any phase higher than threshold</p> <p>*Meter shall be programed at default 'lag only' configuration i.e. Leading power factor to be treated as unity for kVA & kVAh calculations.</p> <p>All the parameters shall be as per actual without multiplying factor.</p>																																				
5.7.1	Load survey(for pre-paid &post paid meter mode)	<p>The meter shall be capable of recording 30 minutes average of the following parameters for at least last 45 power ON days</p> <ul style="list-style-type: none">a) Voltage for each phaseb) Current of each phasec) Actual neutral currentd) Average PFe) Average kWhf) Average kVAh (lag only)g) kVArh(Lagging)h) kVArh(Leading)i) Temperature near terminal block (°C)j) THD Voltage phase wisek) THD Current phase wisel) Demand(KW)m) Demand(KVA) <p>Meter shall be capable of recording daily Energy and Demand 00:00 to 24:00 Hrs kWh, kVAh, kW, kVA in BCS for 45 days. Midnight energy value of cumulative kWh, kVAh and daily consumption kWh, kVAh should be available in meter memory for last 45 days.</p> <p>Load survey data should be at least with 5 decimal place</p>																																				
5.7.2	Instantaneous Parameters	<p>Meter shall be capable for following Instantaneous Parameters in Memory and should be available in BCS.</p> <table><tr><td>Meter Sr.No.</td><td></td></tr><tr><td>Meter Type</td><td></td></tr><tr><td>Meter date & Time</td><td>DD MM YYYY HH MM SS</td></tr><tr><td>Voltage –R</td><td>000.000V</td></tr><tr><td>Voltage –Y</td><td>000.000V</td></tr><tr><td>Voltage –B</td><td>000.000V</td></tr><tr><td>Line Current –R</td><td>00.000A</td></tr><tr><td>Line Current –Y</td><td>00.000A</td></tr><tr><td>Line Current –B</td><td>00.000A</td></tr><tr><td>Actual Neutral Current</td><td>00.00A</td></tr><tr><td>Active Current –R</td><td>00.000A</td></tr><tr><td>Active Current –Y</td><td>00.000A</td></tr><tr><td>Active Current –B</td><td>00.000A</td></tr><tr><td>Reactive Current-R</td><td>00.000A</td></tr><tr><td>Reactive Current-Y</td><td>00.000A</td></tr><tr><td>Reactive Current-B</td><td>00.000A</td></tr><tr><td>Power factor-R</td><td>0.000</td></tr><tr><td>Power factor-Y</td><td>0.000</td></tr></table>	Meter Sr.No.		Meter Type		Meter date & Time	DD MM YYYY HH MM SS	Voltage –R	000.000V	Voltage –Y	000.000V	Voltage –B	000.000V	Line Current –R	00.000A	Line Current –Y	00.000A	Line Current –B	00.000A	Actual Neutral Current	00.00A	Active Current –R	00.000A	Active Current –Y	00.000A	Active Current –B	00.000A	Reactive Current-R	00.000A	Reactive Current-Y	00.000A	Reactive Current-B	00.000A	Power factor-R	0.000	Power factor-Y	0.000
Meter Sr.No.																																						
Meter Type																																						
Meter date & Time	DD MM YYYY HH MM SS																																					
Voltage –R	000.000V																																					
Voltage –Y	000.000V																																					
Voltage –B	000.000V																																					
Line Current –R	00.000A																																					
Line Current –Y	00.000A																																					
Line Current –B	00.000A																																					
Actual Neutral Current	00.00A																																					
Active Current –R	00.000A																																					
Active Current –Y	00.000A																																					
Active Current –B	00.000A																																					
Reactive Current-R	00.000A																																					
Reactive Current-Y	00.000A																																					
Reactive Current-B	00.000A																																					
Power factor-R	0.000																																					
Power factor-Y	0.000																																					

TPCODL

Document Title	SPECIFICATION FOR THREE PHASE 4 WIRE WHOLE CURRENT SMART METER WITH BOX	
Document No.	MMG-SMART-002	
		Page 18 of 39

		<table><tr><td>Power factor-B</td><td>0.000</td></tr><tr><td>Average Power factor</td><td>0.000</td></tr><tr><td>Instantaneous Frequency</td><td>00.000Hz</td></tr><tr><td>Instantaneous Load</td><td>Active ,Reactive Lag/Lead, Apparent</td></tr><tr><td>Present Cumulative Energy</td><td>Active ,Reactive Lag/Lead, Apparent</td></tr><tr><td>Cumulative Power Off Duration</td><td>00000</td></tr><tr><td>Cumulative Power ON Duration</td><td>00000</td></tr><tr><td>Cumulative Tamper count</td><td>00000</td></tr><tr><td>Cumulative Tamper duration</td><td>00000</td></tr><tr><td>Last Billing date</td><td>dd:mm:yy</td></tr><tr><td>Terminal Block Temperature(°C)</td><td></td></tr><tr><td>Vector/phasor diagram (also showing neutral current)</td><td></td></tr><tr><td>No. of disconnector operation (Open)</td><td>00000</td></tr><tr><td>No. of disconnector operation (Close)</td><td>00000</td></tr></table>	Power factor-B	0.000	Average Power factor	0.000	Instantaneous Frequency	00.000Hz	Instantaneous Load	Active ,Reactive Lag/Lead, Apparent	Present Cumulative Energy	Active ,Reactive Lag/Lead, Apparent	Cumulative Power Off Duration	00000	Cumulative Power ON Duration	00000	Cumulative Tamper count	00000	Cumulative Tamper duration	00000	Last Billing date	dd:mm:yy	Terminal Block Temperature(°C)		Vector/phasor diagram (also showing neutral current)		No. of disconnector operation (Open)	00000	No. of disconnector operation (Close)	00000	
Power factor-B	0.000																														
Average Power factor	0.000																														
Instantaneous Frequency	00.000Hz																														
Instantaneous Load	Active ,Reactive Lag/Lead, Apparent																														
Present Cumulative Energy	Active ,Reactive Lag/Lead, Apparent																														
Cumulative Power Off Duration	00000																														
Cumulative Power ON Duration	00000																														
Cumulative Tamper count	00000																														
Cumulative Tamper duration	00000																														
Last Billing date	dd:mm:yy																														
Terminal Block Temperature(°C)																															
Vector/phasor diagram (also showing neutral current)																															
No. of disconnector operation (Open)	00000																														
No. of disconnector operation (Close)	00000																														
5.7.3	General Information	<p>Meter shall be capable for providing below mentioned general parameters in memory</p> <p>Meter Serial number Software Name Version Manufacture Name Manufacture Date (MM/YY) Meter Type Meter Class Meter Constant Meter Voltage Rating Meter Current Rating TOD profile</p> <p># if any additional key is required to see this value, it should be provided without any additional cost to TPCODL.</p>																													
5.7.4	Billing Parameters	<p>1) Cumulative kwh, kVAh (lag only), kVArh lead, KVArhlag (all import and export) and TOD1 kWh,TOD2 kWh,TOD1 kVAh (lag only),TOD2 kVAh (lag only), For present and last 06 Resets (reset date for all resets/history, time zone register wise)</p> <p>2) Maximum Demand Absolute Active Load and Absolute Apparent load and TOD1 kW,TOD2 kW, ,TOD1 kVA (lag only),TOD2 kVA (lag only),), for present and last 06</p>																													

TPCODL

Document Title	SPECIFICATION FOR THREE PHASE 4 WIRE WHOLE CURRENT SMART METER WITH BOX	
Document No.	MMG-SMART-002	
		Page 19 of 39

		<p>Resets (reset date for all resets/history, time zone register wise) along with date and time stamp. Monthly power on/off hrs.</p> <p>3) <u>Billing Dates (06 History)</u></p> <p>4) <u>Mode of operation of disconnect switch</u></p> <p>Last five modes with date & time of switching with cumulative energy parameters kWh, kVAh (lag only), kVAh lead, KVAh lag (all import and export) and TOD1 kWh,TOD2 kWh, ,TOD1 kVAh (lag only),TOD2 kVAh (lag only).</p>																					
5.7.5	Transactions	All the changes in software of meter to be logged along with date & time stamp and readings. Meter should do billing if any billing related transaction is done.																					
5.8	Display units	<p>The display unit shall be Pin type built-in liquid crystal display (Permanently backlit type LCD). The LCD shall be of STN (Super Twisted Nematic) construction suitable for maximum temperature withstands 65°C and minimum temperature withstands 0°C during normal operating condition. The LCD display shall have a wide viewing angle of 120 degree. When the meter is not energized the electronic display need not be visible. The display shall not be affected by electrical, magnetic disturbances and ESD.</p> <p>The display should be readable in direct sunlight. The back lit must be green in color for good visibility of digits in sunlight.</p> <p>The kWh &kVAh register shall have minimum 8 digits LCD display and size of the digits shall be minimum 10mmx5mm. Cumulative energy (kWh &kVAh) shall be displayed without decimal in auto scroll mode. (However decimal shall be available in push button mode for high resolution display for testing).</p>																					
5.8.1	Auto Scroll mode& push button mode in Post paid mode	<p>Persistence time for each parameter shall be 10 second. Values followed by header shall be avoided. (I.e. if MD1 is displayed in Auto scroll mode, Header (MD1) and value (say 5.23 kW) shall be shown simultaneously; it shall not be shown in successive displays. Off time shall not be available in auto scroll mode between each cycle. Auto scroll mode is restored after 10 sec, if push button is not operated. Display should not be stuck for any tamper events.</p> <p>All energy values should be without decimal.</p> <p>Following shall be continuously displayed in auto scroll and push button mode in the given order;</p> <table border="1"> <thead> <tr> <th>Display</th><th>Display 1</th><th>Display 2</th></tr> </thead> <tbody> <tr> <td>Scroll Process</td><td>Auto</td><td>Push</td></tr> <tr> <td>LCD Check</td><td>1</td><td>1</td></tr> <tr> <td>Meter Sr. No</td><td>2</td><td>2</td></tr> <tr> <td>Date</td><td>3</td><td>3</td></tr> <tr> <td>Time</td><td>4</td><td>4</td></tr> <tr> <td>Cum. kWh</td><td>5</td><td>5</td></tr> </tbody> </table>	Display	Display 1	Display 2	Scroll Process	Auto	Push	LCD Check	1	1	Meter Sr. No	2	2	Date	3	3	Time	4	4	Cum. kWh	5	5
Display	Display 1	Display 2																					
Scroll Process	Auto	Push																					
LCD Check	1	1																					
Meter Sr. No	2	2																					
Date	3	3																					
Time	4	4																					
Cum. kWh	5	5																					

TPCODL

Document Title	SPECIFICATION FOR THREE PHASE 4 WIRE WHOLE CURRENT SMART METER WITH BOX	
Document No.	MMG-SMART-002	
		Page 20 of 39

		Cum. kVAh	6	6	
		Cum. kVARh (Lag)	7	7	
		Cum. kVARh (Lead)	8	8	
		TOD Cum. kWh (T1,T2,)	9,10,	9,10,	
		TOD Cum. kVAh (T1,T2,)	12,13,	12,13,	
		Current Month MD kW	15	15	
		Current Month MD kVA	16	16	
		Last Month (history 1) kWh	17	17	
		Last Month (history 1) kVAh	18	18	
		Last Month (history 1) TOD Cum. kWh (T1,T2,)	19,20,	19,20,	
		Last Month (history 1) TOD Cum. kVAh (T1,T2,)	22,23,	22,23,	
		Last Month (history 1) MD kW	25	25	
		Last Month (history 1) MD kVA	26	26	
		Last Month (history 1) Power Factor	27	27	
		Phase Voltages (Vr, Vy, Vb)	28,29,30	28,29,30	
		Phase Currents (Ir, Iy, Ib)	31,32,33	31,32,33	
		Inst. Active Power (kW)	34	34	
		Inst. Apparent Power (kVA)	35	35	
		Inst.Power Factor	36	36	
		Voltage Sequence (R-Y-B)	37	37	
		Current Sequence (R-Y-B)	38	38	
		Status of Load Switch (connected or disconnected)	39	39	
		High Resolution kWh	-	40	
		High Resolution kVAh	-	41	
		High Resolution kVARh (Lag)	-	42	
		High Resolution kVARh (Lead)	-	43	
		Magnetic Tamper count	-	44	
		Latest Magnetic tamper occurrence date	-	45	
		Latest Magnetic tamper occurrence Time	-	46	
		ESD Tamper count	-	47	
		Latest ESD tamper occurrence date	-	48	
		Latest ESD tamper occurrence time	-	49	
		TC Open tamper count	-	50	
		TC Open occurrence date of very first event	-	51	
		TC open occurrence time of very first event	-	52	
		Count of Connect	-	53	
		Date & Time of Last Occurrence	-	54,55	

TPCODL

Document Title	SPECIFICATION FOR THREE PHASE 4 WIRE WHOLE CURRENT SMART METER WITH BOX	
Document No.	MMG-SMART-002	
		Page 21 of 39

		<table> <tr> <td>Count of disconnect</td><td>-</td><td>56</td></tr> <tr> <td>Date & Time of Last Occurrence</td><td>-</td><td>57,58</td></tr> </table>	Count of disconnect	-	56	Date & Time of Last Occurrence	-	57,58																																																																		
Count of disconnect	-	56																																																																								
Date & Time of Last Occurrence	-	57,58																																																																								
5.8.2	Auto Scroll mode & push button mode in Pre-paid mode	<p>Persistence time for each parameter shall be 10 second. Values followed by header shall be avoided. (I.e. if MD1 is displayed in Auto scroll mode, Header (MD1) and value (say 5.23 kW) shall be shown simultaneously; it shall not be shown in successive displays. Off time shall not be available in auto scroll mode between each cycle. Auto scroll mode is restored after 10 sec, if push button is not operated. Display should not be stuck for any tamper events.</p> <p>All energy values should be without decimal.</p> <p>Following shall be continuously displayed in auto scroll and push button mode in the given order;</p> <table> <tr> <th>Display</th><th>Display 1</th><th>Display 2</th></tr> <tr> <th>Scroll Process</th><th>Auto</th><th>Push</th></tr> <tr> <td>LCD Check</td><td>1</td><td>1</td></tr> <tr> <td>Meter Sr. No</td><td>2</td><td>2</td></tr> <tr> <td>Date</td><td>3</td><td>3</td></tr> <tr> <td>Time</td><td>4</td><td>4</td></tr> <tr> <td>Cum. kWh</td><td>5</td><td>5</td></tr> <tr> <td>Cum. kVAh</td><td>6</td><td>6</td></tr> <tr> <td>Cum. kVARh (Lag)</td><td>7</td><td>7</td></tr> <tr> <td>Cum. kVARh (Lead)</td><td>8</td><td>8</td></tr> <tr> <td>TOD Cum. kWh (T1,T2)</td><td>9,10,</td><td>9,10,</td></tr> <tr> <td>TOD Cum. kVAh (T1,T2)</td><td>11,12,</td><td>11,12</td></tr> <tr> <td>Current Month MD kW</td><td>13</td><td>13</td></tr> <tr> <td>Current Month MD kVA</td><td>14</td><td>14</td></tr> <tr> <td>Last Month (history 1) kWh</td><td>15</td><td>15</td></tr> <tr> <td>Last Month (history 1) kVAh</td><td>16</td><td>16</td></tr> <tr> <td>Last Month (history 1) TOD Cum. kWh (T1,T2,)</td><td>17,18,</td><td>17,18,</td></tr> <tr> <td>Last Month (history 1) TOD Cum. kVAh (T1,T2,)</td><td>19,20</td><td>19,20</td></tr> <tr> <td>Last Month (history 1) MD kW</td><td>21</td><td>21</td></tr> <tr> <td>Last Month (history 1) MD kVA</td><td>22</td><td>22</td></tr> <tr> <td>Last Month (history 1) Power Factor</td><td>23</td><td>23</td></tr> <tr> <td>Phase Voltages (Vr, Vy, Vb)</td><td>24,25,26</td><td>24,25,26</td></tr> <tr> <td>Phase Currents (Ir, Iy, Ib)</td><td>27,28,29</td><td>27,28,29</td></tr> <tr> <td>Inst. Active Power (kW)</td><td>30</td><td>30</td></tr> </table>	Display	Display 1	Display 2	Scroll Process	Auto	Push	LCD Check	1	1	Meter Sr. No	2	2	Date	3	3	Time	4	4	Cum. kWh	5	5	Cum. kVAh	6	6	Cum. kVARh (Lag)	7	7	Cum. kVARh (Lead)	8	8	TOD Cum. kWh (T1,T2)	9,10,	9,10,	TOD Cum. kVAh (T1,T2)	11,12,	11,12	Current Month MD kW	13	13	Current Month MD kVA	14	14	Last Month (history 1) kWh	15	15	Last Month (history 1) kVAh	16	16	Last Month (history 1) TOD Cum. kWh (T1,T2,)	17,18,	17,18,	Last Month (history 1) TOD Cum. kVAh (T1,T2,)	19,20	19,20	Last Month (history 1) MD kW	21	21	Last Month (history 1) MD kVA	22	22	Last Month (history 1) Power Factor	23	23	Phase Voltages (Vr, Vy, Vb)	24,25,26	24,25,26	Phase Currents (Ir, Iy, Ib)	27,28,29	27,28,29	Inst. Active Power (kW)	30	30
Display	Display 1	Display 2																																																																								
Scroll Process	Auto	Push																																																																								
LCD Check	1	1																																																																								
Meter Sr. No	2	2																																																																								
Date	3	3																																																																								
Time	4	4																																																																								
Cum. kWh	5	5																																																																								
Cum. kVAh	6	6																																																																								
Cum. kVARh (Lag)	7	7																																																																								
Cum. kVARh (Lead)	8	8																																																																								
TOD Cum. kWh (T1,T2)	9,10,	9,10,																																																																								
TOD Cum. kVAh (T1,T2)	11,12,	11,12																																																																								
Current Month MD kW	13	13																																																																								
Current Month MD kVA	14	14																																																																								
Last Month (history 1) kWh	15	15																																																																								
Last Month (history 1) kVAh	16	16																																																																								
Last Month (history 1) TOD Cum. kWh (T1,T2,)	17,18,	17,18,																																																																								
Last Month (history 1) TOD Cum. kVAh (T1,T2,)	19,20	19,20																																																																								
Last Month (history 1) MD kW	21	21																																																																								
Last Month (history 1) MD kVA	22	22																																																																								
Last Month (history 1) Power Factor	23	23																																																																								
Phase Voltages (Vr, Vy, Vb)	24,25,26	24,25,26																																																																								
Phase Currents (Ir, Iy, Ib)	27,28,29	27,28,29																																																																								
Inst. Active Power (kW)	30	30																																																																								

TPCODL

Document Title	SPECIFICATION FOR THREE PHASE 4 WIRE WHOLE CURRENT SMART METER WITH BOX	
Document No.	MMG-SMART-002	
		Page 22 of 39

		Inst. Apparent Power (kVA)	31	31
		Inst.Power Factor	32	32
		Voltage Sequence (R-Y-B)	33	33
		Current Sequence (R-Y-B)	34	34
		Status of Load Switch (connected or disconnected)	35	35
		Current Balance Amount (Current Balance)	36,37	36,37
		Current Balance Date & Time	38,39	38,39
		Total Balance at Last Recharge(Previous Balance)	40,41	40,41
		Last Recharge Amount	42,43	42,43
		Last Recharge Date & Time	44,45	44,45
		High Resolution kWh	-	46
		High Resolution kVAh	-	47
		High Resolution kVARh (Lag)	-	48
		High Resolution kVARh (Lead)	-	49
		Magnetic Tamper count	-	50
		Latest Magnetic tamper occurrence date	-	51
		Latest Magnetic tamper occurrence Time	-	52
		ESD Tamper count	-	53
		Latest ESD tamper occurrence date	-	54
		Latest ESD tamper occurrence time	-	55
		TC Open tamper count	-	56
		TC Open occurrence date of very first event	-	57
		TC open occurrence time of very first event	-	58
		Count of Connect		59
		Date & Time of Last Occurrence	-	60,61
		Count of disconnect	-	62
		Date & Time of Last Occurrence	-	63,64
		TOD Timing – T1(22:00hrs to 06:00hrs) T2(06:00hrs to 22:00hrs) programmable 8 zones		
		Following parameters may be updated multiple times during life cycle of meters over the air :		
		Enabling Post Paid to Prepaid mode and vice versa remotely		
		Import mode to export Mode and vice versa.		
		Accordingly Display parameters shall be updated remotely		

TPCODL

Document Title	SPECIFICATION FOR THREE PHASE 4 WIRE WHOLE CURRENT SMART METER WITH BOX	
Document No.	MMG-SMART-002	
		Page 23 of 39

5.9	Output Device	<ol style="list-style-type: none"> Pulse Rate: The meters shall have a suitable test output device. 2 nos of Red color blinking LED (marked as imp/kWh and imp/kVAh) shall be provided in the front. This device shall be suitable for using with sensing probe used with test benches or reference standard meters. The test output device shall have constant pulse rate of (preferred value- 400) pulse / kWh & pulse/kVAh. Meter constant shall be indelibly printed on the name plate as imp / kWh & imp/kVAh. Communication LCD indicator- The meter shall be provided with suitable LCD indication for communication in progress. Load Switch LCD indicator- The meter shall be provided with suitable LCD indication for condition of load switch (Close/open). LCD should show when load switch is open. Phase indication : Individual phases should be displayed on LCD display of meter and shall glow with minimum operating voltage (as defined in 4.05)
6.0	NAME PLATE AND MARKING	<p>Meters shall have a name plate clearly visible and effectively secured against removal. The name plate data should be laser printed. The base color of Name plate shall be blue(as of TPCODL logo)Indelibly and distinctly marked with all essential particulars as per relevant standards along with the following.</p> <ol style="list-style-type: none"> Manufacturer's name Type designation Number of phases and wires Serial number (Meter serial number shall be laser printed on name plate instead of sticker). Month and Year of manufacture Unit of measurement Reference voltage ,frequency Ref. temperature if different from 27 deg. C Rated basic and maximum Current Meter constant (imp/kWh & Imp/kVAh) 'BIS' Mark Class index of meter "Property of TPCODL" Purchase Order No. & date Guarantee period. Rated frequency Sign of double square Country of manufacture. Symbol of load switch. Communication Tech for WAN and NAN(with carrier frequency) Communication Technology is IHD supported (with carrier frequency). Firmware version for meter Category <p>However the following shall be printed in bar code on the meter nameplate.(shall be laser printed on name plate instead of sticker).</p>

TPCODL

Document Title	SPECIFICATION FOR THREE PHASE 4 WIRE WHOLE CURRENT SMART METER WITH BOX	
Document No.	MMG-SMART-002	
		Page 24 of 39

		<div>1) Manufacturer's code No.(given by TPCODL)</div> <div>2) Meter Sr. No</div> <div>3) TPCODL Property</div> <div>4) Month/Year of manufacture.</div> <div>The PCB Serial number should be printed on PCB instead of sticker.</div> <div>Bidder should ensure that NIC provided in meters are having laser printing of Sr. No., MFG date, 'Property of TPCODL' marked, PO date and no. (same as that of meter PO)</div>												
7.0	TESTS	All routine, acceptance & type tests shall be carried out on the meter and meter body separately in accordance with the relevant IS/IEC. All routine/acceptance tests shall be witnessed by the TPCODL/his authorized representative. All the components shall also be type tested as per the relevant standards. Following tests shall be necessarily conducted in addition to the tests specified in IS/IEC.												
7.1	TYPE TEST	<div>1) All tests as defined in IS 16444 Part-1: 2015 /IS 13779:1999 & IS15959 Part-2: 2016.</div> <div>2) Test against abnormal magnetic influence as per CBIP TR 325.</div> <div>3) Meter shall be type tested as per BIS16444 part-1</div>												
7.2	ROUTINE TEST	<div>1) AC High Voltage test</div> <div>2) Insulation test</div> <div>3) Test on limits of error</div> <div>4) Test of starting current</div> <div>5) Test of no load condition</div>												
7.3	ACCEPTANCE TEST	<div>1) AC High Voltage test</div> <div>2) Insulation test</div> <div>3) Test on limits of error with following loads</div> <table><tr><td>120% I max(120A)</td><td>I max (100A)</td><td>Ib(20A)</td><td>0.5 Ib (10A)</td><td>0.1Ib (2A)</td><td>0.05Ib (1A)</td></tr><tr><td>UPF, 0.8 lead and 0.5 lag</td><td>UPF, 0.8 lead and 0.5 lag</td><td>UPF, 0.8 lead and 0.5 lag</td><td>UPF, 0.8 lead and 0.5 lag</td><td>UPF, 0.8 Lead and 0.5 lag</td><td>UPF</td></tr></table> <div>4) Test of meter constant</div> <div>5) Test of starting current</div> <div>6) Test of no load condition</div> <div>7) Test of repeatability of error.</div> <div>8) Test of power consumption.</div> <div>9) Test for Immunity against external influencing signal as per the TPCODL specification</div> <div>10) Test for Immunity against DC Immunity as per the TPCODL specification</div> <div>11) Test for Immunity against Tamper conditions as per the TPCODL specification</div> <div>12) Error measurements with all abnormal condition along with ESD, magnet,</div> <div>13) Test to Influence of Harmonics</div> <div>14) Supply voltage and frequency variation test</div> <div>15) Testing of self diagnostic features</div> <div>16) Tamper count increment and logging with date and time in meter database</div>	120% I max(120A)	I max (100A)	Ib(20A)	0.5 Ib (10A)	0.1Ib (2A)	0.05Ib (1A)	UPF, 0.8 lead and 0.5 lag	UPF, 0.8 lead and 0.5 lag	UPF, 0.8 lead and 0.5 lag	UPF, 0.8 lead and 0.5 lag	UPF, 0.8 Lead and 0.5 lag	UPF
120% I max(120A)	I max (100A)	Ib(20A)	0.5 Ib (10A)	0.1Ib (2A)	0.05Ib (1A)									
UPF, 0.8 lead and 0.5 lag	UPF, 0.8 lead and 0.5 lag	UPF, 0.8 lead and 0.5 lag	UPF, 0.8 lead and 0.5 lag	UPF, 0.8 Lead and 0.5 lag	UPF									

TPCODL

Document Title	SPECIFICATION FOR THREE PHASE 4 WIRE WHOLE CURRENT SMART METER WITH BOX	
Document No.	MMG-SMART-002	
		Page 25 of 39

		<p>17) All tests as defined in IS 15959(Part-2):2016</p> <p>18) Functionality of communication module is 16444 part2</p> <p>19) smart meter communicability as per provision of 28 IS 15959 (part-3)</p> <p>20) Meter reading on HES demand, Scheduled meter reading from HES, remote firmware upgrade from HES and all programming request from HES to be simulated and checked during inspections.</p> <p>21) Physical check of NIC and replaceable ease of the NIC module in meter.</p> <p>22) Any other test required as per latest IS 16444, 15999 and relevant parts shall be tested during inspections.</p>
	METER BOX	<p>Acceptance Tests</p> <p>Physical verification of dimensions of the box.</p> <p>Compatibility of the box for housing the Meter, and ensuring ease of connecting and reading the meter.</p> <p>Test for mechanical strength.</p> <p>.</p> <p>Routine Tests :</p> <p>The routine test certificates for the following shall be furnished for approval of the purchaser.</p> <p>Physical verification of dimension of the box.</p> <p>Compatibility of the box for housing the meter ensuring ease of connecting and the reading the meter.</p> <p>Meter box shall be of polycarbonate transparent type(Degree of protection-IP55)</p>
7.4	Special Test	<p>1) The bidder shall demonstrate the communication capability of the meter through communication modes as defined in the specification before conducting acceptance tests.</p> <p>2) Temperature rise of terminal block with 120% I_{max} for 6 hours.</p>
8.0	TYPE TEST CERTIFICATE	<p>The bidder shall furnish the type test certificates of the meter for the tests as mentioned above as per the corresponding standards. All the tests shall be conducted at CPR/ ERDA/ UL laboratory as per BIS 16444 part-1. For communication testing any national approved laboratory or international acclaimed lab or equivalent will also suffice at the discretion of TPCODL.</p> <p>For technical evaluation of the tender, we may consider Type test report as per IS 13779. In such case the Bidder should provide IS16444 compliant test report before starting of supply of meters. Type test should have been conducted in certified Test Laboratories during the period not exceeding 5 years from the date of opening the bid. In the event of any discrepancy in the test reports i.e. any test report not acceptable or any/all type tests (including additional type tests, if any) not carried out, same shall be carried out without any cost implication to TPCODL.</p>
9.0	GUARANTEE	<p>Bidder shall stand guarantee towards design, materials, workmanship & quality of process / manufacturing of items under this contract for due and intended performance of the same, as an integrated product delivered under this contract. In the event any defect is found by the TPCODL up to a period of at least 60 months from the date of commissioning or 66 months from the date of last supplies made under the contract</p>

TPCODL

Document Title	SPECIFICATION FOR THREE PHASE 4 WIRE WHOLE CURRENT SMART METER WITH BOX	
Document No.	MMG-SMART-002	
		Page 26 of 39

		<p>whichever is earlier, Bidder shall be liable to undertake to replace/rectify such defects at its own costs, within mutually agreed time frame, and to the entire satisfaction of the Company, failing which the TPCODL will be at liberty to get it replaced/rectified at bidder's risks and costs and recover all such expenses plus the Company's own charges (@ 20% of expenses incurred), from the bidder or from the " Security cum Performance Deposit" as the case may be.</p> <p>Bidder shall own responsibility for all internal component with an end to end agreement with individual component manufacturer.</p>
10.0	PACKING	<ol style="list-style-type: none"> 1. Bidder shall ensure that all material covered under this specification shall be prepared for rail/road transport (local equipment) and be packed in such a manner as to protect it from damage in transit. The material used for packing shall be environmentally friendly. Packing and transportation shall be as per IS 15707:206 clauses 9.1 and 9.2. 2. Individual meter should be packed in separate box. Routine test report (with min. tests as defined in 7.2) of the individual meter shall be kept inside each card board carton of the meter. 3. On back side of RTC the bidder shall print a picture of the meter with its small details like for consumer to know about meter. 4. The softcopy of the routine test certificate of each meter to be provided with each lot to TPCODL, MMG stores at BHUBANESWAR. 5. The routine test certificate shall contain results & all tests of clause no. 7.2.
11.0	QUALITY CONTROL	<p>The bidder shall submit with the offer Quality assurance plan indicating the various stages of inspection, the tests and checks which will be carried out on the material of construction, components during manufacture and bought out items and fully assembled component and equipment after finishing. As part of the plan, a schedule for stage and final inspection within the parameters of the delivery schedule shall be furnished.</p> <p>Quality should be ensured at the following stages:</p> <ul style="list-style-type: none"> • At PCB manufacturing stage, each board shall be subjected to computerized bare board testing. • At insertion stage, all components should undergo computerized testing for conforming to design parameter and orientation. • Complete assembled and soldered PCB should undergo functional testing using Automatic Test Equipment (ATEs). • Prior to final testing and calibration, sample meters shall be subjected to aging test (i.e. meters will be kept in ovens for 24 hours at 55 DegC temperature and atmospheric humidity under real-life condition at its full load current. After 24 hours meter should work satisfactorily. <p>TPCODL's engineer or its nominated representative shall have free access to the bidder's/manufacturer's works to carry out inspections.</p>

TPCODL

Document Title	SPECIFICATION FOR THREE PHASE 4 WIRE WHOLE CURRENT SMART METER WITH BOX	
Document No.	MMG-SMART-002	
		Page 27 of 39

12.0	MINIMUM TESTING FACILITIES	Bidder shall have adequate in house testing facilities for carrying out all routine tests & acceptance tests as per relevant International / Indian standards. The bidder shall have duly calibrated Reference Standard meter of Class 0.1 accuracy or better.																																													
13.0	MANUFACTURING ACTIVITIES	The successful bidder will have to submit the bar chart for various manufacturing activities clearly elaborating each stage, with quantity. This bar chart shall be in line with the Quality assurance plan submitted with the offer. This bar chart will have to be submitted within 15 days from the release of the order.																																													
14.0	SPARES, ACCESSORIES AND TOOLS	NA																																													
15.0	DRAWINGS AND DOCUMENTS	<p>Following drawings & Documents shall be prepared based on TPCODL specifications and statutory requirements and shall be submitted with the bid:</p> <p>a) Completely filled-in Technical Parameters. b) General arrangement drawing of the meter c) Terminal Block dimensional drawing d) Mounting arrangement drawings. e) General description of the equipment and all components with makes and technical requirement f) Type Test Certificates g) Experience List</p> <p>After the award of the contract, soft copies of following drawings, drawn to scale, describing the equipment in detail shall be forwarded for approval:</p> <table><tr><th>S. No.</th><th>Description</th><th>For Approval</th><th>For Review Information</th><th>Final Submission</th></tr><tr><td>1</td><td>Technical Parameters</td><td>√</td><td></td><td>√</td></tr><tr><td>2</td><td>General Arrangement drawings</td><td>√</td><td></td><td>√</td></tr><tr><td>3</td><td>Terminal block Dimensional drawings</td><td>√</td><td></td><td>√</td></tr><tr><td>4</td><td>Mounting arrangement drawing.</td><td>√</td><td></td><td>√</td></tr><tr><td>5</td><td>Manual/Catalogues</td><td></td><td>√</td><td></td></tr><tr><td>6</td><td>Transport/ Shipping dimension drawing</td><td></td><td>√</td><td>√</td></tr><tr><td>7</td><td>QA & QC Plan</td><td>√</td><td>√</td><td>√</td></tr><tr><td>8</td><td>Routine, Acceptance and Type Test Certificates</td><td>√</td><td>√</td><td>√</td></tr></table> <p>Bidder shall subsequently provide Soft copy of all the drawing, GTP, Test certificates for the final approval of TPCODL.</p> <p>All the documents & drawings shall be in English language.</p>	S. No.	Description	For Approval	For Review Information	Final Submission	1	Technical Parameters	√		√	2	General Arrangement drawings	√		√	3	Terminal block Dimensional drawings	√		√	4	Mounting arrangement drawing.	√		√	5	Manual/Catalogues		√		6	Transport/ Shipping dimension drawing		√	√	7	QA & QC Plan	√	√	√	8	Routine, Acceptance and Type Test Certificates	√	√	√
S. No.	Description	For Approval	For Review Information	Final Submission																																											
1	Technical Parameters	√		√																																											
2	General Arrangement drawings	√		√																																											
3	Terminal block Dimensional drawings	√		√																																											
4	Mounting arrangement drawing.	√		√																																											
5	Manual/Catalogues		√																																												
6	Transport/ Shipping dimension drawing		√	√																																											
7	QA & QC Plan	√	√	√																																											
8	Routine, Acceptance and Type Test Certificates	√	√	√																																											

TPCODL

Document Title	SPECIFICATION FOR THREE PHASE 4 WIRE WHOLE CURRENT SMART METER WITH BOX	
Document No.	MMG-SMART-002	
		Page 28 of 39

16.0	GUARANTEED TECHNICAL PARTICULARS	A) Meter details-			
		Sr.No	Description	Units	As Furnished by Bidder
		1	Type of meter		
		2	Accuracy Class of the meter		
		3	Ib & Imax	A	
		4	a. Operating Voltage for meter b. Operating Voltage with communication unit functionality	V	
		5	Operating Frequency	Hz	
		6	Power Consumption and Burden		
		7	Starting Current	mA	
		8	Short time over current	A	
		9	Influence of heating		
		10	Rated impulse withstand voltage	KV	
		11	AC withstand Voltage for 1 min	KV	
		12	Insulation resistance a) Between frame &Current, voltage circuits connected together: b) Between each current(or voltage circuit) & each and every other circuit.	M ohm	
		13	Mechanical requirement as per IS 13779		
		14	Resistance to heat and fire (As per specification)		
		15	Degree of protection		
		16	Resistance against climatic influence (as per IS 13779)		
		17	Electromagnetic Compatibility (EMC)		
		18	Accuracy requirements (As per IS 13779		
		19	Power factor range		
		20	Energy measurement		
		21	Connection Diagram for system on terminal cover	Yes/No	
		22	Self diagnostic features		

TPCODL

Document Title	SPECIFICATION FOR THREE PHASE 4 WIRE WHOLE CURRENT SMART METER WITH BOX	
Document No.	MMG-SMART-002	
		Page 29 of 39

			23	Initial start up of meter (meter shall be fully functional within 5 sec after reference voltage is applied to the meter terminals)			
			24	Terminal block a)Depth of the Terminal holes b)Internal diameter of terminal holes c) Clearance between adjacent terminals	mm mm mm		
			25	Communication capabilities as per clause 4.3			
			26	Immunity & logging against abnormal Magnetic influence, as defined in Cl. 4.4			
			27	Immunity & logging against ESD/Jammer as defined in Cl. 4.4			
			28	DC & other tamper Immunity and logging as defined in Cl. 4.5			
			29	Abnormal tamper events and logging with snapshot in all Conditions as per table no-1	Yes/No		
			30	Grade/Name of material used for a) Meter base b) Meter cover c) Terminal block d) Terminal cover			
			31	Tamper counters	Yes/No		
			32	Recording forward energy in all tamper conditions	Yes/No		
			33	Display back lit color			
			34	Non Volatile memory (Retention period)			
			35	Measuring elements used in the meter			
			36	Power supply to circuit in case of supply failure			
			37	Display of measured values (As per specification –clause 5.8)	Yes/No		
			38	LCD display (Type and viewing angle)			

TPCODL

Document Title	SPECIFICATION FOR THREE PHASE 4 WIRE WHOLE CURRENT SMART METER WITH BOX	
Document No.	MMG-SMART-002	
		Page 30 of 39

			39	Pulse rate	Imp/kWh, Imp/kVArh		
			40	Name plate marking with laser printer	Yes/No		
			41	Routine test certificates	Yes/No		
			42	Acceptance test Certificates	Yes/No		
			43	Type test certificates	Yes/No		
			44	Guarantee certificates	Yes/No		
			45	Output Device(LEDs) As per Cl.5.9	Yes/No		
			46	Make of Disconnect Switch			
			47	Disconnect Technical particular as per Specification Cl no- 4.1	Yes/No		
			48	Terminal Screw dia.			
			49	Allen / Minus Screw head size & Screws per wire (Terminal Screw)			
			50	Fire retardant category of the material a. Meter body b. Terminal block			
			51	Meter sealing as per clause 5.4			
			52	Temperature Sensor near terminal block at incomer side			
			53	Ultrasonic welding of cover and base			
			54	Providing zig for NVM data retrieval after meter damaged at site as per clause no. 17			
			55	NIC module with cover & sealing arrangement			
			56	Meter shall be programmed at default 'lag only' configuration i.e. Leading power factor to be treated as unity for KVA & KVAh calculations, except for instantaneous parameters where values and Vector Diagram should show actual kVAh considering lead and Lag both.			

TPCODL

Document Title	SPECIFICATION FOR THREE PHASE 4 WIRE WHOLE CURRENT SMART METER WITH BOX	
Document No.	MMG-SMART-002	
		Page 31 of 39

57	Dimensions of the meter LxBxH		
	58	Terminal material	
	59	Terminal Screw material and plating details	
	60	Harmonics Recording- The recording of harmonics up to 20th harmonic Average THD of all phase for voltage THD and current THD.	
	61	Accuracy of harmonics recording	
B) Component data			
S No	Component Function	Requirement	Makes and Origin
1.	Measurement/ computing chips	The Measurement/ computing chips used in the meter should be with the Surface mount type along with the ASICs	
2.	Memory chips/NVM	The memory chips should not be affected by the external parameters like sparking, high voltage spikes or electrostatic discharges. The life of NVM shall be 15 years.	
3.	Display modules	The display modules should be well protected from the external UV radiations. The display visibility should be sufficient to read the meter mounted between height of 0.5m and 2m. The construction of the modules should be such that the displayed quantity should not be disturbed with the life of display. Should be with Green LED background. It should be trans-reflective STN type industrial grade with extended temperature range.	
4.	Optical port	Optical port should be used to transfer the meter data to meter reading instrument. The mechanical construction of the port should be such to facilitate the data transfer easily. It should be magnetic locking type	
5	P.C.B.	Glass Epoxy, fire resistance grade with minimum thickness 1.6 mm	

TPCODL

Document Title	SPECIFICATION FOR THREE PHASE 4 WIRE WHOLE CURRENT SMART METER WITH BOX	
Document No.	MMG-SMART-002	
		Page 32 of 39

		6.	Electronic components	The active & passive components should be of the surface mount type & are to be handled & soldered by the state of art assembly processes.	
		7.	Battery	Lithium with guaranteed life of 15 years	
		8.	Micro controller and RTC having separate battery	The accuracy of RTC shall be as per relevant IEC / IS standards and RTC shall be provided with separate battery in its ckt.. The micro controller shall be of superior quality from reputed make with long life.	
		9.	Temperature sensor	Temperature sensor shall be internal to the meter and its accuracy shall be as per relevant IEC / IS standards. The OEM test report to be furnished. With good performance till life of meter.	


TPCODL

Document Title	SPECIFICATION FOR THREE PHASE 4 WIRE WHOLE CURRENT SMART METER WITH BOX	
Document No.	MMG-SMART-002	
		Page 33 of 39

Three phase WC 20-100A Parameters list:**General Parameter's details: -**

1. TPCODL specific OBIS code for self-diagnostic- 1.0.96.5.1.255 IC-1
2. Default TOD timing three phase 20-100A is as per below
TOD-1 22:00 to 06:00
TOD-2 06:00 to 22:00

Note:- TOU (Time ZON) timing can programmed by using activity calendar for times zone (0.0.13.0.0.255) The same OBIS code shall be used for reading the configured TOU timings.

3. Three phase default display parameter shall be configured as Post-paid & shall be programmable through HES (OTA) for following combinations.
 - a. Pre-paid with TOD
 - b. Post-paid with TOD
 - c. Net mode (Import/export)
4. Meter serial number shall be alpha numeric and with 9 digits. Alphabetic part detail shall be shared by TPCODL
5. Communication LCD indicator-Meter display shall have  indication in context to NIC. The blinking should be slow when NIC is detected; blinking should be fast when NIC had searched the network and it should be stable when it is successfully latched to the HES.
6. Billing shall be done at following programming events and programing can be done OTA.
 - a. Metering mode change
 - b. Prepayment mode change
 - c. Communication driven MD reset
 - d. Time zone activation
 - e. Demand integration period change
 - f. Display parameter configuration
 - g. Firmware upgrade
 - h. Kvah configuration Lag or Lag+lead (OBIS code 1.0.128.5.131.255,event ID 192, value 0= Lag+Lead & value 1 = Lag only)
7. Following annexures are added in this document
 - a. Push data list – Annexure-A
 - b. Downloadable parameter list- Annexure-B
 - c. Display parameter list - Annexure-C

TPCODL

Document Title	SPECIFICATION FOR THREE PHASE 4 WIRE WHOLE CURRENT SMART METER WITH BOX	
Document No.	MMG-SMART-002	
		Page 34 of 39

8. Default MD integration period is 15 minute (sliding interval time 5 minute) & it can be configured to 30/15 minute
9. Default load survey integration period is 15 minute & can be configured to 30/15 minute. The load survey data shall be recorded for 45 days with 15 minute IP & 90 days with 30 minute IP
10. KVAH calculation shall be lag only by default it shall be configurable to lag + lead/lag only OBIS code 1.0.128.5.131.255, event ID 192, (value 0= Lag+Lead & value 1 = Lag only) shall be used for KVAH energy configuration.
11. All DATE should be in DDMMYYYY format.

TPCODL

Document Title	SPECIFICATION FOR THREE PHASE 4 WIRE WHOLE CURRENT SMART METER WITH BOX	
Document No.	MMG-SMART-002	
		Page 35 of 39

3 Phase WC 20-100A Push data list:**Annexure -A**

S. No.	Event Push data (This data shall be push when any event (Tamper, First breath, last gasp etc) is occurred)	OBIS Code	OBIS Source
1	Device ID	0.0.96.1.2.255	IS 15959 part-2
2	Event Push SM(Smart Meter) to HES	0.4.25.9.0.255	IS 15959 part-2
3	Real Time Clock – Date and Time	0.0.1.0.0.255	IS 15959 part-2
4	Event Status Word 1	0.0.94.91.18.255	IS 15959 part-2
5	Meter serial number	0.0.96.1.0.255	IS 15959 part-2
Note- This data shall be pushed to HES only			

S. No.	Periodic Schedule Push Instantaneous Profile (Meter shall push default at every 6 hours & push time is configurable by HES	OBIS Code	OBIS Source
1	Device ID	0.0.96.1.2.255	IS15959-Part2
2	Periodic Push SM (Smart Meter) to HES	0.0.25.9.0.255	IS15959-Part2
3	Periodic Time Clock – Date and Time	0.0.1.0.0.255	IS15959-Part2
4	Instantaneous profile (All daily survey profile parameters which are mentioned in daily profile – 1.0.94.91.0.255)	1.0.94.91.0.255	IS 15959 part-2
Note- This data shall be pushed to HES only			

S. No.	Daily survey profile (Mid night) push data (This data shall be pushed at every midnight)	OBIS Code	OBIS Source
1	Device ID	0.0.96.1.2.255	IS 15959 part-2
2	Mid Night (daily) push SM(Smart Meter) to HES	0.6.25.9.0.255	TPCODL Specific
3	Real Time Clock - Date and Time	0.0.1.0.0.255	IS15959-Part2
4	Daily survey profile (All daily survey profile parameters which are mentioned in daily profile – 1.0.99.2.0.255)	1.0.99.2.0.255	IS 15959 part-2
Note- This data shall be pushed to HES only			

S. No.	Billing Push Data (This data shall be pushed at every month end)	OBIS Code	OBIS Source
1	Device ID	0.0.96.1.2.255	IS 15959 part-2
2	Billing Push SM(Smart Meter) to HES	0.99.25.9.0.255	TPCODL Specific
3	Real Time Clock - Date and Time	0.0.1.0.0.255	IS15959-Part2
4	Daily survey profile (All daily survey profile parameters which are mentioned in daily profile – 1.0.98.1.0.255)	1.0.98.1.0.255	IS 15959 part-2
Note- This data shall be pushed to HES only			

TPCODL

Document Title	SPECIFICATION FOR THREE PHASE 4 WIRE WHOLE CURRENT SMART METER WITH BOX	
Document No.	MMG-SMART-002	
		Page 36 of 39

3 Phase WC 20-100A Downloadable Parameters List: -
Annexure-B

Three Phase WCM			
S.		OBIS Code	OBIS Source
	Instantaneous Profile	1.0.94.91.0.255	IS15959-Part2
1	Real Time Clock - Date and Time	0.0.1.0.0.255	IS15959-Part2
2	Current – IR	1.0.31.7.0.255	IS15959-Part2
3	Current – IY	1.0.51.7.0.255	IS15959-Part2
4	Current – IB	1.0.71.7.0.255	IS15959-Part2
5	Voltage – VRN	1.0.32.7.0.255	IS15959-Part2
6	Voltage – VYN	1.0.52.7.0.255	IS15959-Part2
7	Voltage - VBN	1.0.72.7.0.255	IS15959-Part2
8	Signed Power Factor - R phase	1.0.33.7.0.255	IS15959-Part2
9	Signed Power Factor - Y phase	1.0.53.7.0.255	IS15959-Part2
10	Signed Power Factor - B phase	1.0.73.7.0.255	IS15959-Part2
11	Signed three Phase Power Factor - PF	1.0.13.7.0.255	IS15959-Part2
12	Frequency	1.0.14.7.0.255	IS15959-Part2
13	Apparent Power - KVA	1.0.9.7.0.255	IS15959-Part2
14	Signed Active Power - kW (+ Forward; -Reverse)	1.0.1.7.0.255	IS15959-Part2
15	Signed Reactive Power - kVAR (+ Lag; - Lead)	1.0.3.7.0.255	IS15959-Part2
16	Number of power failures	0.0.96.7.0.255	IS15959-Part2
17	Cumulative power-failure duration in Min	0.0.94.91.8.255	IS15959-Part2
18	Cumulative Tamper count	0.0.94.91.0.255	IS15959-Part2
19	Cumulative Billing count	0.0.0.1.0.255	IS15959-Part2
20	Cumulative programming count	0.0.96.2.0.255	IS15959-Part2
21	Billing Date	0.0.0.1.2.255	IS15959-Part2
22	Cumulative Energy - kWh, Import/Forwarded	1.0.1.8.0.255	IS15959-Part2
23	Cumulative Energy - kWh, Export	1.0.2.8.0.255	IS15959-Part2
24	Cumulative Energy - kVAh, Import/Forwarded	1.0.9.8.0.255	IS15959-Part2
25	Cumulative Energy - kVAh, Export	1.0.10.8.0.255	IS15959-Part2
26	MD kW, Import/Forwarded with date & time	1.0.1.6.0.255	IS15959-Part2
27	MD kVA, Import/Forwarded with date & time	1.0.9.6.0.255	IS15959-Part2
28	Load Limit function status (Connect/disconnect - attribute 2: value)	0.0.96.3.10.255	IS15959-Part2
29	Load Limit Value in KW	0.0.17.0.0.255	IS15959-Part2
30	Cumulative energy, kVAh(QI)	1.0.5.8.0.255	IS15959-Part2
31	Cumulative energy, kVAh(QII)	1.0.6.8.0.255	IS15959-Part2
32	Cumulative energy, kVAh(QIII)	1.0.7.8.0.255	IS15959-Part2
33	Cumulative energy, kVAh(QIV)	1.0.8.8.0.255	IS15959-Part2
34	Cumulative power on duration (min)	0.0.94.91.14.255	IS15959-Part2
35	Temperature	0.0.96.9.128.255	TPCODL
36	Neutral current	1.0.91.7.0.255	TPCODL
37	Number of load switch (connect/disconnect) operations	0.0.96.50.1.255	TPCODL
38	R Phase active Current	1.0.31.7.128.255	TPCODL
39	Y Phase active Current	1.0.51.7.128.255	TPCODL
40	B Phase active Current	1.0.71.7.128.255	TPCODL
41	MD kW, Export with date & time	1.0.2.6.0.255	IS15959-Part2
42	MD kVA, Export with date & time	1.0.10.6.0.255	IS15959-Part2

TPCODL

Document Title	SPECIFICATION FOR THREE PHASE 4 WIRE WHOLE CURRENT SMART METER WITH BOX	
Document No.	MMG-SMART-002	
		Page 37 of 39

43	Angle between R-Y phase voltage	1.0.81.7.10.255	TPCODL
44	Angle between R-B phase voltage	1.0.81.7.20.255	TPCODL
45	Phase Sequence	1.0.128.7.0.255	TPCODL
46	Signal Strength (CSQ value)	0.1.96.12.5.255	TPCODL
47	Meter Serial number	0.0.96.1.0.255	IS 15959 Part-2
Note- This data shall be read through BCS & HES			

S.	Billing Profile	OBIS Code	OBIS Source
	Billing Profile	1.0.98.1.0.255	IS15959-Part2
1	Billing Date	0.0.0.1.2.255	IS15959-Part2
2	System Power Factor For Billing Period for Import	1.0.13.0.0.255	IS15959-Part2
3	Cumulative Energy - kWh, Import/Forwarded	1.0.1.8.0.255	IS15959-Part2
4	Cumulative Energy kWh TZ1, Import/Forwarded	1.0.1.8.1.255	IS15959-Part2
5	Cumulative Energy kWh TZ2, Import/Forwarded	1.0.1.8.2.255	IS15959-Part2
6	Cumulative Energy kWh TZ3, Import/Forwarded	1.0.1.8.3.255	IS15959-Part2
7	Cumulative Energy kWh TZ4, Import/Forwarded	1.0.1.8.4.255	IS15959-Part2
8	Cumulative Energy kWh TZ5, Import/Forwarded	1.0.1.8.5.255	IS15959-Part2
9	Cumulative Energy kWh TZ6, Import/Forwarded	1.0.1.8.6.255	IS15959-Part2
10	Cumulative Energy kWh TZ7, Import/Forwarded	1.0.1.8.7.255	IS15959-Part2
11	Cumulative Energy kWh TZ8, Import/Forwarded	1.0.1.8.8.255	IS15959-Part2
12	Cumulative Energy - kVAh, Import/Forwarded	1.0.9.8.0.255	IS15959-Part2
13	Cumulative Energy kVAH TZ1, Import/Forwarded	1.0.9.8.1.255	IS15959-Part2
14	Cumulative Energy kVAH TZ2, Import/Forwarded	1.0.9.8.2.255	IS15959-Part2
15	Cumulative Energy kVAH TZ3, Import/Forwarded	1.0.9.8.3.255	IS15959-Part2
16	Cumulative Energy kVAH TZ4, Import/Forwarded	1.0.9.8.4.255	IS15959-Part2
17	Cumulative Energy kVAH TZ5, Import/Forwarded	1.0.9.8.5.255	IS15959-Part2
18	Cumulative Energy kVAH TZ6, Import/Forwarded	1.0.9.8.6.255	IS15959-Part2
19	Cumulative Energy kVAH TZ7, Import/Forwarded	1.0.9.8.7.255	IS15959-Part2
20	Cumulative Energy kVAH TZ8, Import/Forwarded	1.0.9.8.8.255	IS15959-Part2
21	MD kW, Import/Forwarded with date & time	1.0.1.6.0.255	IS15959-Part2
22	MD kW TZ1, Import/Forwarded with date & time	1.0.1.6.1.255	IS15959-Part2
23	MD kW TZ2, Import/Forwarded with date & time	1.0.1.6.2.255	IS15959-Part2
24	MD kW TZ3, Import/Forwarded with date & time	1.0.1.6.3.255	IS15959-Part2
25	MD kW TZ4, Import/Forwarded with date & time	1.0.1.6.4.255	IS15959-Part2
26	MD kW TZ5, Import/Forwarded with date & time	1.0.1.6.5.255	IS15959-Part2
27	MD kW TZ6, Import/Forwarded with date & time	1.0.1.6.6.255	IS15959-Part2
28	MD kW TZ7, Import/Forwarded with date & time	1.0.1.6.7.255	IS15959-Part2
29	MD kW TZ8, Import/Forwarded with date & time	1.0.1.6.8.255	IS15959-Part2
30	MD kVA, Import/Forwarded with date & time	1.0.9.6.0.255	IS15959-Part2
31	MD kVA TZ1, Import/Forwarded with date & time	1.0.9.6.1.255	IS15959-Part2

TPCODL

Document Title	SPECIFICATION FOR THREE PHASE 4 WIRE WHOLE CURRENT SMART METER WITH BOX	
Document No.	MMG-SMART-002	
		Page 38 of 39

32	MD kVA TZ2, Import/Forwarded with date & time	1.0.9.6.2.255	IS15959-Part2
33	MD kVA TZ3, Import/Forwarded with date & time	1.0.9.6.3.255	IS15959-Part2
34	MD kVA TZ4, Import/Forwarded with date & time	1.0.9.6.4.255	IS15959-Part2
35	MD kVA TZ5, Import/Forwarded with date & time	1.0.9.6.5.255	IS15959-Part2
36	MD kVA TZ6, Import/Forwarded with date & time	1.0.9.6.6.255	IS15959-Part2
37	MD kVA TZ7, Import/Forwarded with date & time	1.0.9.6.7.255	IS15959-Part2
38	MD kVA TZ8, Import/Forwarded with date & time	1.0.9.6.8.255	IS15959-Part2
39	Billing Power ON Duration in Mins	0.0.94.91.13.25	IS15959-Part2
40	Cumulative Energy - kWh Export	1.0.2.8.0.255	IS15959-Part2
41	Cumulative Energy - kVAh Export	1.0.10.8.0.255	IS15959-Part2
42	Cumulative energy, kVAh(QI)	1.0.5.8.0.255	IS15959-Part2
43	Cumulative energy, kVAh(QII)	1.0.6.8.0.255	IS15959-Part2
44	Cumulative energy, kVAh(QIII)	1.0.7.8.0.255	IS15959-Part2
45	Cumulative energy, kVAh(QIV)	1.0.8.8.0.255	IS15959-Part2
46	Cumulative MD kW Import/Forwarded	1.0.1.2.0.255	TPCODL
47	Cumulative MD kVA Import/Forwarded	1.0.9.2.0.255	TPCODL
48	Billing Reset Type	1.0.96.50.2.255	TPCODL
49	MD kW, Export with date & time	1.0.2.6.0.255	IS15959-Part2
50	MD kVA, Export with date & time	1.0.10.6.0.255	IS15959-Part2
51	Meter serial number	0.0.96.1.0.255	IS 15959 Part-2
Note:- 1. Energy cconsumptions are derived parameters & same shall be available at HES & BCS end			

S.	Block Load Profile	OBIS Code	OBIS Source
	Block Load Profile	1.0.99.1.0.255	IS15959-Part2
1	RTC	0.0.1.0.0.255	IS15959-Part2
2	Average Current - IR	1.0.31.27.0.255	IS15959-Part2
3	Average Current - IY	1.0.51.27.0.255	IS15959-Part2
4	Average Current - IB	1.0.71.27.0.255	IS15959-Part2
5	Average Voltage - VRN	1.0.32.27.0.255	IS15959-Part2
6	Average Voltage - VYN	1.0.52.27.0.255	IS15959-Part2
7	Average Voltage - VBN	1.0.72.27.0.255	IS15959-Part2
8	Block Energy – kWh- Import/Forwarded	1.0.1.29.0.255	IS15959-Part2
9	Block Energy – kWh-Export	1.0.2.29.0.255	IS15959-Part2
10	Block energy. kvarh-Q1/Lag	1.0.5.29.0.255	IS15959-Part2
11	Block energy. kvarh-Q2/Lead	1.0.6.29.0.255	IS15959-Part2
12	Block energy. kvarh-Q3/Lag	1.0.7.29.0.255	IS15959-Part2
13	Block energy. kvarh-Q4/Lead	1.0.8.29.0.255	IS15959-Part2
14	Block Energy – kVAh- Import/Forwarded	1.0.9.29.0.255	IS15959-Part2
15	Block Energy – kVAh-Export	1.0.10.29.0.255	IS15959-Part2
16	Average Neutral current	1.0.91.29.0.255	TPCODL
17	%THDV R- Phase Average	1.0.32.128.124.255	TPCODL

TPCODL

Document Title	SPECIFICATION FOR THREE PHASE 4 WIRE WHOLE CURRENT SMART METER WITH BOX	
Document No.	MMG-SMART-002	
		Page 39 of 39

18	%THDV Y- Phase Average	1.0.52.128.124.255	TPCODL
19	%THDV B- Phase Average	1.0.72.128.124.255	TPCODL
20	%THDI R- Phase Average	1.0.31.128.124.255	TPCODL
21	%THDI Y- Phase Average	1.0.51.128.124.255	TPCODL
22	%THDI B- Phase Average	1.0.71.128.124.255	TPCODL
23	Average Temperature	0.0.96.9.129.255	TPCODL
24	Signal strength (CSQ value)	0.1.96.12.5.255	TPCODL
25	Meter Serial number	0.0.96.1.0.255	IS15959-Part2
<p>Note-1: Block energies data shall be with 3 decimal place</p> <p>Note-2: Demand KW ,KVA & Signed Power factor shall be derived at HES/MDMS & BCS end</p> <p>Note-3: Block load profile parameters shall be field programmable by TPCODL specific OBIS code. On changing capture object LS data will be reset</p> <p>Note-4: This data shall be read by through BCS & HES</p>			

S. No.	Daily Load Profile	OBIS Code	OBIS Source
	Daily Survey Profile	1.0.99.2.0.255	IS 15959 part-2
1	Real Time Clock – Date & Time	0.0.1.0.0.255	IS 15959 part-2
2	Cumulative Energy KWh Export	1.0.2.8.0.255	IS 15959 part-2
3	Cumulative Energy KVAh Export	1.0.10.8.0.255	IS 15959 part-2
4	Cumulative Energy – kWh Import/forwarded	1.0.1.8.0.255	IS 15959 part-2
5	Cumulative Energy kWh TZ1 Import/forwarded	1.0.1.8.1.255	IS 15959 part-2
6	Cumulative Energy kWh TZ2 Import/forwarded	1.0.1.8.2.255	IS 15959 part-2
7	Cumulative Energy kWh TZ3 Import/forwarded	1.0.1.8.3.255	IS 15959 part-2
8	Cumulative Energy kWh TZ4 Import/forwarded	1.0.1.8.4.255	IS 15959 part-2
9	Cumulative Energy kWh TZ5 Import/forwarded	1.0.1.8.5.255	IS 15959 part-2
10	Cumulative Energy kWh TZ6 Import/forwarded	1.0.1.8.6.255	IS 15959 part-2
11	Cumulative Energy kWh TZ7 Import/forwarded	1.0.1.8.7.255	IS 15959 part-2
12	Cumulative Energy kWh TZ8 Import/forwarded	1.0.1.8.8.255	IS 15959 part-2
13	Cumulative Energy – kVAh Import/forwarded	1.0.9.8.0.255	IS 15959 part-2
14	Cumulative Energy kVAh TZ1 Import/forwarded	1.0.9.8.1.255	IS 15959 part-2
15	Cumulative Energy kVAh TZ2 Import/forwarded	1.0.9.8.2.255	IS 15959 part-2
16	Cumulative Energy kVAh TZ3 Import/forwarded	1.0.9.8.3.255	IS 15959 part-2
17	Cumulative Energy kVAh TZ4 Import/forwarded	1.0.9.8.4.255	IS 15959 part-2
18	Cumulative Energy kVAh TZ5 Import/forwarded	1.0.9.8.5.255	IS 15959 part-2
19	Cumulative Energy kVAh TZ6 Import/forwarded	1.0.9.8.6.255	IS 15959 part-2
20	Cumulative Energy kVAh TZ7 Import/forwarded	1.0.9.8.7.255	IS 15959 part-2
21	Cumulative Energy kVAh TZ8 Import/forwarded	1.0.9.8.8.255	IS 15959 part-2
22	Maximum Demand KW Import/forwarded (With Date & Time)	1.0.1.6.0.255	IS 15959 part-2
23	Maximum Demand KW TZ1 Import/forwarded (With Date & Time)	1.0.1.6.1.255	IS 15959 part-2
24	Maximum Demand KW TZ2 Import/forwarded (With Date & Time)	1.0.1.6.2.255	IS 15959 part-2
25	Maximum Demand KW TZ3 Import/forwarded (With Date & Time)	1.0.1.6.3.255	IS 15959 part-2
26	Maximum Demand KW TZ4 Import/forwarded (With Date & Time)	1.0.1.6.4.255	IS 15959 part-2
27	Maximum Demand KW TZ5 Import/forwarded (With Date & Time)	1.0.1.6.5.255	IS 15959 part-2
28	Maximum Demand KW TZ6 Import/forwarded (With Date & Time)	1.0.1.6.6.255	IS 15959 part-2
29	Maximum Demand KW TZ7 Import/forwarded (With Date & Time)	1.0.1.6.7.255	IS 15959 part-2
30	Maximum Demand KW TZ8 Import/forwarded (With Date & Time)	1.0.1.6.8.255	IS 15959 part-2

TPCODL

Document Title	SPECIFICATION FOR THREE PHASE 4 WIRE WHOLE CURRENT SMART METER WITH BOX	
Document No.	MMG-SMART-002	
		Page 40 of 39

31	Maximum Demand KVA Import/forwarded (With Date & Time)	1.0.9.6.0.255	IS 15959 part-2
32	Maximum Demand KVA TZ1 Import/forwarded (With Date & Time)	1.0.9.6.1.255	IS 15959 part-2
33	Maximum Demand KVA TZ2 Import/forwarded (With Date & Time)	1.0.9.6.2.255	IS 15959 part-2
34	Maximum Demand KVA TZ3 Import/forwarded (With Date & Time)	1.0.9.6.3.255	IS 15959 part-2
35	Maximum Demand KVA TZ4 Import/forwarded (With Date & Time)	1.0.9.6.4.255	IS 15959 part-2
36	Maximum Demand KVA TZ5 Import/forwarded (With Date & Time)	1.0.9.6.5.255	IS 15959 part-2
37	Maximum Demand KVA TZ6 Import/forwarded (With Date & Time)	1.0.9.6.6.255	IS 15959 part-2
38	Maximum Demand KVA TZ7 Import/forwarded (With Date & Time)	1.0.9.6.7.255	IS 15959 part-2
39	Maximum Demand KVA TZ8 Import/forwarded (With Date & Time)	1.0.9.6.8.255	IS 15959 part-2
40	Cumulative Reactive Energy – Q1	1.0.5.8.0.255	IS 15959 part-2
41	Cumulative Reactive Energy – Q2	1.0.6.8.0.255	IS 15959 part-2
42	Cumulative Reactive Energy – Q3	1.0.7.8.0.255	IS 15959 part-2
43	Cumulative Reactive Energy – Q4	1.0.8.8.0.255	IS 15959 part-2
44	Maximum Demand KW Export (With Date & Time)	1.0.2.6.0.255	IS 15959 part-2
45	Maximum Demand KVA Export (With Date & Time)	1.0.10.6.0.255	IS 15959 part-2
44	Meter serial number	0.0.96.1.0.255	IS 15959 part-2
Note: 1-Daily consumption of energies shall be derived at HES & BCS end			
Note:-2-This data shall be read through BCS & HES			

S.	Name Plate Profile	OBIS Code	OBIS Source
	Name Plate Profile	0.0.94.91.10.255	IS15959-Part2
1	Meter Serial number	0.0.96.1.0.255	IS15959-Part2
2	Device ID	0.0.96.1.2.255	IS15959-Part2
3	Manufacturer Name	0.0.96.1.1.255	IS15959-Part2
4	Firmware Version for meter	1.0.0.2.0.255	IS15959-Part2
5	Meter Type (1Phase/3P-3W/3P-4W)	0.0.94.91.9.255	IS15959-Part2
6	Category	0.0.94.91.11.255	IS15959-Part2
7	Current rating	0.0.94.91.12.255	IS15959-Part2
8	Meter Year of TPCODL	0.0.96.1.4.255	IS15959-Part2
9	Internal CT Ratio	1.0.0.4.2.255	IS 15959 Part1
10	Internal PT Ratio	1.0.0.4.3.255	IS 15959 Part1
11	Meter Constant	1.0.0.3.0.255	TPCODL
12	Meter Voltage Rating	0.0.94.91.15.255	TPCODL
13	NIC Firmware version number	0.128.96.0.9.255	TPCODL
14	MD integration period	1.0.0.8.0.255	IS15959-Part2
15	Load survey integration period	1.0.0.8.4.255	IS15959-Part2
16	Kvah Energy definition (Lag only /Lag + Lead)	1.0.128.5.131.255	TPCODL
17	NIC IMEI number (Serial number)	0.0.96.1.5.255	TPCODL
18	Payment Mode	0.0.94.96.20.25	IS15959-Part2
19	Current Balance Amt.	0.0.94.96.24.25	IS15959-Part2
20	Current Balance Time	0.0.94.96.25.25	IS15959-Part2
21	Total Amt. At Last Recharge	0.0.94.96.23.25	IS15959-Part2
22	Last Token Recharge Amt.	0.0.94.96.21.25	IS15959-Part2
23	Last Token Recharge Time	0.0.94.96.22.25	IS15959-Part2
Note- This data shall be read by through BCS & HES			

S.	Profile for Voltage(e=0), Current(e=1) & Other events(e=4)	OBIS Code	OBIS Source
----	--	-----------	-------------

TPCODL

Document Title	SPECIFICATION FOR THREE PHASE 4 WIRE WHOLE CURRENT SMART METER WITH BOX		
Document No.	MMG-SMART-002		
		Page 41 of 39	

	Voltage related events Profile	0.0.99.98.e.255	IS15959-Part2
1	Real Time Clock – Date and Time	0.0.1.0.0.255	IS15959-Part2
2	Event Code (voltage events)	0.0.96.11.e.255	IS15959-Part2
3	Current - IR	1.0.31.7.0.255	IS15959-Part2
4	Current - IY	1.0.51.7.0.255	IS15959-Part2
5	Current - IB	1.0.71.7.0.255	IS15959-Part2
6	Voltage - VRN	1.0.32.7.0.255	IS15959-Part2
7	Voltage - VYN	1.0.52.7.0.255	IS15959-Part2
8	Voltage - VBN	1.0.72.7.0.255	IS15959-Part2
9	Signed R Phase Pf	1.0.33.7.0.255	IS15959-Part2
10	Signed Y Phase Pf	1.0.53.7.0.255	IS15959-Part2
11	Signed B Phase Pf	1.0.73.7.0.255	IS15959-Part2
12	KWH Import/Forwarded	1.0.1.8.0.255	IS15959-Part2
13	KWH Export	1.0.2.8.0.255	IS15959-Part2
14	Cumulative tamper count	0.0.94.91.0.255	IS15959-Part2
15	KVAH Import/Forwarded	1.0.9.8.0.255	IS15959-Part2
16	KVAH Export	1.0.10.8.0.255	IS15959-Part2
17	R Phase active Current	1.0.31.7.128.25	TPCODL
18	Y Phase active Current	1.0.51.7.128.25	TPCODL
19	B Phase active Current	1.0.71.7.128.25	TPCODL
20	Neutral current	1.0.91.7.0.255	IS15959-Part2
21	Total PF	1.0.13.7.0.255	IS15959-Part2
22	Meter Serial number	0.0.96.1.0.255	IS15959-Part2
Note- This data shall be read by BCS & HES			

S. No.	Profile for Power fail(e=2), Transaction(e=3), Non Rollover(e=5) & Control events (e=6) events	OBIS Code	OBIS Source
	Power Fail event profile	0.0.99.98.e.255	IS15959-Part2
1	Real Time Clock – Date and Time	0.0.1.0.0.255	IS15959-Part2
2	Event Code (power fail events)	0.0.96.11.e.255	IS15959-Part2
3	Meter Serial number	0.0.96.1.0.255	IS15959-Part2
Note- This data shall be read through BCS & HES			

S.	Profile for Temperature compartments	OBIS Code	OBIS Source
	TPCODL events compartments profile	0.0.99.98.128.255	TPCODL
1	Real Time Clock – Date and Time	0.0.1.0.0.255	IS15959-Part2
2	Event Code (Non Standard events)	0.0.96.11.128.255	TPCODL
3	Current – IR	1.0.31.7.0.255	IS15959-Part2
4	Current – IY	1.0.51.7.0.255	IS15959-Part2
5	Current – IB	1.0.71.7.0.255	IS15959-Part2
6	Voltage – VRN	1.0.32.7.0.255	IS15959-Part2
7	Voltage – VYN	1.0.52.7.0.255	IS15959-Part2
8	Voltage – VBN	1.0.72.7.0.255	IS15959-Part2
9	R Phase Pf	1.0.33.7.0.255	IS15959-Part2
10	Y Phase Pf	1.0.53.7.0.255	IS15959-Part2
11	B Phase Pf	1.0.73.7.0.255	IS15959-Part2

TPCODL

Document Title	SPECIFICATION FOR THREE PHASE 4 WIRE WHOLE CURRENT SMART METER WITH BOX		
Document No.	MMG-SMART-002		
		Page 42 of 39	

12	KWH Import/Forwarded	1.0.1.8.0.255	IS15959-Part2
13	KWH Export	1.0.2.8.0.255	IS15959-Part2
14	Cumulative tamper count	0.0.94.91.0.255	IS15959-Part2
15	KVAH Import/Forwarded	1.0.9.8.0.255	IS15959-Part2
16	KVAH Export/Forwarded	1.0.10.8.0.255	IS15959-Part2
17	R Phase active Current	1.0.31.7.128.255	TPCODL
18	Y Phase active Current	1.0.51.7.128.255	TPCODL
19	B Phase active Current	1.0.71.7.128.255	TPCODL
20	Neutral current	1.0.91.7.0.255	IS15959-Part2
21	Total PF	1.0.13.7.0.255	IS15959-Part2
22	Temperature	0.0.96.9.128.255	TPCODL
23	Meter Serial number	0.0.96.1.0.255	IS15959-Part2
Note- This data shall be read through BCS & HES			

S.	Mode of operation of load switch profile	OBIS Code	OBIS Source
	Mode of operation of load switch profile	0.0.99.98.129.2	TPCODL
1	Real Time Clock – Date and Time	0.0.1.0.0.255	IS15959-Part2
2	Event Code (control events)	0.0.96.11.6.255	IS15959-Part2
3	Reason for Switch operation	0.0.96.50.4.255	TPCODL
4	Cumulative Energy – kWh, Import/Forwarded	1.0.1.8.0.255	IS15959-Part2
5	Cumulative Energy – TOD 1 kWh, Import/Forwarded	1.0.1.8.1.255	IS15959-Part2
6	Cumulative Energy – TOD 2 kWh, Import/Forwarded	1.0.1.8.2.255	IS15959-Part2
7	Cumulative Energy – TOD 3 kWh, Import/Forwarded	1.0.1.8.3.255	IS15959-Part2
8	Cumulative Energy – TOD 4 kWh, Import/Forwarded	1.0.1.8.4.255	IS15959-Part2
9	Cumulative Energy – TOD 5 kWh, Import/Forwarded	1.0.1.8.5.255	IS15959-Part2
10	Cumulative Energy – TOD 6 kWh, Import/Forwarded	1.0.1.8.6.255	IS15959-Part2
11	Cumulative Energy – TOD 7 kWh, Import/Forwarded	1.0.1.8.7.255	IS15959-Part2
12	Cumulative Energy – TOD 8 kWh, Import/Forwarded	1.0.1.8.8.255	IS15959-Part2
13	Cumulative Energy – kVAh, Import/Forwarded	1.0.9.8.0.255	IS15959-Part2
14	Cumulative Energy – TOD1 KVAh, Import/Forwarded	1.0.9.8.1.255	IS15959-Part2
15	Cumulative Energy – TOD2 KVAh, Import/Forwarded	1.0.9.8.2.255	IS15959-Part2
16	Cumulative Energy – TOD3 KVAh, Import/Forwarded	1.0.9.8.3.255	IS15959-Part2
17	Cumulative Energy – TOD4 KVAh, Import/Forwarded	1.0.9.8.4.255	IS15959-Part2
18	Cumulative Energy – TOD5 KVAh, Import/Forwarded	1.0.9.8.5.255	IS15959-Part2
19	Cumulative Energy – TOD6 KVAh, Import/Forwarded	1.0.9.8.6.255	IS15959-Part2
20	Cumulative Energy – TOD7 KVAh, Import/Forwarded	1.0.9.8.7.255	IS15959-Part2
21	Cumulative Energy – TOD8 KVAh, Import/Forwarded	1.0.9.8.8.255	IS15959-Part2
22	kWh export	1.0.2.8.0.255	
23	kVAh export	1.0.10.8.0.255	
24	kVArh –Q1	1.0.5.8.0.255	
25	kVArh –Q2	1.0.6.8.0.255	
26	kVArh –Q3	1.0.7.8.0.255	
27	kVArh –Q4	1.0.8.8.0.255	
28	Meter Serial number	0.0.96.1.0.255	IS15959-Part2
Note- This data shall be read through BCS & HES			

TPCODL

Document Title	SPECIFICATION FOR THREE PHASE 4 WIRE WHOLE CURRENT SMART METER WITH BOX	
Document No.	MMG-SMART-002	
		Page 43 of 39

S.	Phasor profile	OBIS Code	OBIS Source
	Phasor Profile	1.0.99.128.128.255	TPCODL
1	Real Time Clock – Date and Time	0.0.1.0.0.255	IS15959-Part2
2	Current – IR	1.0.31.7.0.255	IS15959-Part2
3	Current – IY	1.0.51.7.0.255	IS15959-Part2
4	Current – IB	1.0.71.7.0.255	IS15959-Part2
5	Voltage – VRN	1.0.32.7.0.255	IS15959-Part2
6	Voltage – VYN	1.0.52.7.0.255	IS15959-Part2
7	Voltage – VBN	1.0.72.7.0.255	IS15959-Part2
8	Signed Power Factor –R phase	1.0.33.7.0.255	IS15959-Part2
9	Signed Power Factor –Y phase	1.0.53.7.0.255	IS15959-Part2
10	Signed Power Factor –B phase	1.0.73.7.0.255	IS15959-Part2
11	Signed Three Phase Power Factor – PF	1.0.13.7.0.255	IS15959-Part2
12	Frequency	1.0.14.7.0.255	IS15959-Part2
13	Apparent Power – KVA	1.0.9.7.0.255	IS15959-Part2
14	Signed Active Power – kW (+ Forward; -Reverse)	1.0.1.7.0.255	IS15959-Part2
15	Signed Reactive Power – kVAr (+ Lag; - Lead)	1.0.3.7.0.255	IS15959-Part2
16	Signed R Phase Active Power	1.0.21.7.0.255	TPCODL
17	Signed Y Phase Active Power	1.0.41.7.0.255	TPCODL
18	Signed B Phase Active Power	1.0.61.7.0.255	TPCODL
19	Angle Between Y- R Phase voltage	1.0.81.7.10.255	TPCODL
20	Angle Between B- R Phase voltage	1.0.81.7.20.255	TPCODL
21	Angle between two phase voltage	1.0.81.7.128.255	TPCODL
22	Phase Sequence	1.0.128.7.0.255	TPCODL
23	Neutral current	1.0.91.7.0.255	IS15959-Part2
24	Meter Serial number	0.0.96.1.0.255	IS15959-Part2
Note- This data shall be read through BCS only			

S. No.	Accuracy Check Data Profile (High Resolution Energy with 4 digit after decimal)	OBIS Code	OBIS Source
	Accuracy Check data Profile	1.0.99.128.129.255	TPCODL
1	Cumulative Energy - kWh, Import/Forwarded	1.0.1.8.0.255	IS15959-Part2
2	Cumulative Energy - kWh, Export	1.0.2.8.0.255	IS15959-Part2
3	Cumulative energy, kVArh(QI)	1.0.5.8.0.255	IS15959-Part2
4	Cumulative energy, kVArh (QII)	1.0.6.8.0.255	IS15959-Part2
5	Cumulative energy, kVArh (QIII)	1.0.7.8.0.255	IS15959-Part2
6	Cumulative energy, kVArh (QIV)	1.0.8.8.0.255	IS15959-Part2
7	Cumulative Energy - kVAh, Import/Forwarded	1.0.9.8.0.255	IS15959-Part2
8	Cumulative Energy - kVAh, Export	1.0.10.8.0.255	IS15959-Part2
9	Meter Serial number	0.0.96.1.0.255	IS15959-Part2
Note- This data shall be read through BCS only			

TPCODL

Document Title	SPECIFICATION FOR THREE PHASE 4 WIRE WHOLE CURRENT SMART METER WITH BOX		
Document No.	MMG-SMART-002		
		Page 44 of 39	

S. No.	Programmable Parameters	OBIS Code	Event IDs	OBIS Source
1	Real Time clock change	0.0.1.0.0.255	151	IS15959-Part2
2	Demand Integration Period change	1.0.0.8.0.255	152	IS15959-Part2
3	Profile captured period	1.0.0.8.4.255	153	IS15959-Part2
4	single-action schedule for billing dates	0.0.15.0.0.255	154	IS15959-Part2
5	Activity calendar for times zones	0.0.13.0.0.255	155	IS15959-Part2
6	new firmware (image) activated	0.0.44.0.0.255	157	IS15959-Part2
7	Load Limit KW Set	0.0.17.0.0.255	158	IS15959-Part2
8	Connect/Disconnect	0.0.96.3.10.255	159/160	IS15959-Part2
9	Metering Mode	0.0.94.96.19.255	167,(177=Forward,178=Import/Export)	IS15959-Part2
10	Payment mode	0.0.94.96.20.255	211=poastpaid,212 Pre-	IS15959-Part2
11	Last token recharge amount	0.0.94.96.21.255	N/A	IS15959-Part2
12	Last token recharge time	0.0.94.96.22.255	N/A	IS15959-Part2
13	Total Amount at last recharge	0.0.94.96.23.255	N/A	IS15959-Part2
14	Current balance amount	0.0.94.96.24.255	N/A	IS15959-Part2
15	Current balance time	0.0.94.96.25.255	N/A	IS15959-Part2
16	Current Association MR (LLS secret	0.0.40.0.2.255	161	IS15959-Part2
17	Current Association US (HLS Key change)	0.0.40.0.3.255	162	IS15959-Part2
18	Current Association FW (HLS Key change)	0.0.40.0.5.255	163	IS15959-Part2
19	Global key change	0.0.43.0.e.255	164	IS15959-Part2
20	ESWF	0.0.94.91.26.255	165	IS15959-Part2
21	MD Reset	0.0.10.0.1.255	166	IS15959-Part2
22	Image activation single action schedule	0.0.15.0.2.255	169	IS15959-Part2
23	Display Parameters Auto Scroll	0.0.96.128.0.255	760	TPCODL
24	Display Parameters Push Button	0.0.96.128.1.255	760	TPCODL
25	Display Parameters High Resolution Button	0.0.96.128.2.255	760	TPCODL
26	Missing potential Threshold Configuration	1.0.12.129.131.255	758	TPCODL
27	Over Voltage Threshold Configuration	1.0.12.129.129.255	758	TPCODL
28	Low Voltage Threshold Configuration	1.0.12.129.130.255	758	TPCODL
29	Voltage unbalance Threshold Configuration	1.0.12.129.128.255	758	TPCODL
30	Current Reversal Threshold Configuration	1.0.11.129.128.255	758	TPCODL
31	CT Open Threshold Configuration	1.0.11.129.129.255	758	TPCODL
32	Current unbalance Threshold Configuration	1.0.11.129.130.255	758	TPCODL
33	Over Current Threshold Configuration	1.0.11.129.132.255	758	TPCODL

TPCODL

Document Title	SPECIFICATION FOR THREE PHASE 4 WIRE WHOLE CURRENT SMART METER WITH BOX		
Document No.	MMG-SMART-002		
		Page 45 of 39	

34	CT Bypass Threshold Configuration	1.0.11.129.131.255	758	TPCODL
35	High Neutral current Threshold Configuration	1.0.91.129.128.255	758	TPCODL
36	Very Low PF Threshold Configuration	1.0.13.129.128.255	758	TPCODL
37	Temperature rise Threshold Configuration	0.0.96.128.3.255	758	TPCODL
38	Missing potential Persistence time Configuration	1.0.12.130.131.255	759	TPCODL
39	Over Voltage Persistence time Configuration	1.0.12.130.129.255	759	TPCODL
40	Low Voltage Persistence time Configuration	1.0.12.130.130.255	759	TPCODL
41	Voltage unbalance Persistence time Configuration	1.0.12.130.128.255	759	TPCODL
42	Current Reversal Persistence time Configuration	1.0.11.130.128.255	759	TPCODL
43	CT Open Persistence time Configuration	1.0.11.130.129.255	759	TPCODL
44	Current unbalance Persistence time Configuration	1.0.11.130.130.255	759	TPCODL
45	Over Current Persistence time Configuration	1.0.11.130.132.255	759	TPCODL
46	CT Bypass Persistence time Configuration	1.0.11.130.131.255	759	TPCODL
47	Power ON-OFF Persistence time Configuration	0.0.96.128.4.255	759	TPCODL
48	Magnetic influence Persistence time Configuration	0.0.96.128.5.255	759	TPCODL
49	Neutral Disturbance Persistence time Configuration	1.0.96.128.0.255	759	TPCODL
50	Very Low PF Persistence time Configuration	1.0.13.130.128.255	759	TPCODL
51	Over load Persistence time Configuration	1.0.1.130.128.255	759	TPCODL
52	Temperature rise Persistence time Configuration	0.0.96.128.6.255	759	TPCODL
53	Load Profile capture Objects	1.0.96.128.2.255	761	TPCODL
56	Load Control Parameters	0.0.96.3.128.255	768	TPCODL
57	Single Action Schedule for Daily (midnight) data push	0.6.15.0.4.255	798	TPCODL
58	Single Action Schedule Billing data push	0.6.15.0.4.255	799	TPCODL
Note:- This Data Can set through BCS & HES				

Three phase WC Common Display list for all combinations: Annexure-C

1. Forward mode
2. Net meter mode

TPCODL

Document Title	SPECIFICATION FOR THREE PHASE 4 WIRE WHOLE CURRENT SMART METER WITH BOX		
Document No.	MMG-SMART-002		
		Page 46 of 39	

3. Pre-Paid mode

S.No	Display list	Auto	Push	Mode of metering
1	LCD Check	YES	YES	
2	Meter Serial number	YES	YES	
3	Date(DD:MM:YY)	YES	YES	
4	Time (HH:MM:SS)	YES	YES	
5	Cumulative kWh(Import/Forwarded)	YES	YES	
6	Cumulative kVAh(Import/Forwarded)	YES	YES	
7	Cumulative kWh-Export	YES	YES	Applicable for “net meter” mode
8	Cumulative kVAh-Export	YES	YES	
9	Cumulative kVArh Lag (Q1)	YES	YES	
10	Cumulative kVArh Lead (Q4)	YES	YES	Applicable for “net meter” mode
11	Cumulative kVArh Lead (Q2)	YES	YES	
12	Cumulative kVArh Lag (Q3)	YES	YES	
13	Current Month MD – kW (Import/Forwarded) with	YES	YES	
14	Current Month MD - kVA(Import/Forwarded) with	YES	YES	
15	Current Month TOD - kW (Import/Forwarded)- TZ1	-	YES	
16	Current Month TOD - kW (Import/Forwarded)- TZ2	-	YES	
17	Current Month TOD - kVA (Import/Forwarded)- TZ1	-	YES	
18	Current Month TOD - kVA (Import/Forwarded)- TZ2	-	YES	
19	Current Month MD – kW(Export) with Date & Time	YES	YES	Applicable for “net meter” mode
20	Current Month MD – kVA(Export) with Date & Time	YES	YES	
21	Cumulative TOD KWH -TZ1	YES	YES	
22	Cumulative TOD KWH -TZ2	YES	YES	
23	Cumulative TOD KVAH -TZ1	YES	YES	
24	Cumulative TOD KVAH -TZ2	YES	YES	
25	Last Month (history 1) kWh (Import/Forwarded)	YES	YES	
26	Last Month (history 1) kVAh (Import/Forwarded)	YES	YES	
27	Last Month (history 1) kWh (Export)	YES	YES	Applicable for “net meter” mode
28	Last Month (history 1) kVAh (Export)	YES	YES	
29	Last Month (history 1) Cumulative TOD kWh TZ1	YES	YES	
30	Last Month (history 1) Cumulative TOD kWh TZ2	YES	YES	
31	Last Month (history 1) Cumulative TOD kVAh TZ1	YES	YES	
32	Last Month (history 1) Cumulative TOD kVAh TZ2	YES	YES	
33	Last Month (history 1) MD kW (Import/Forwarded)	YES	YES	
34	Last Month (history 1) MD kVA(Import/Forwarded)	YES	YES	
35	Last Month (history 1) MD kW (Export) with Date &	YES	YES	Applicable for “net meter” mode
36	Last Month (history 1) MD kVA(Export) with Date &	YES	YES	
37	Last Month (history 1) MD kW(Import/Forwarded) TZ1	-	YES	
38	Last Month (history 1) MD kW(Import/Forwarded) TZ2	-	YES	
39	Last Month (history 1) MD kVA(Import/Forwarded) TZ1	-	YES	
40	Last Month (history 1) MD kVA(Import/Forwarded) TZ2	-	YES	

TPCODL

Document Title	SPECIFICATION FOR THREE PHASE 4 WIRE WHOLE CURRENT SMART METER WITH BOX	
Document No.	MMG-SMART-002	
		Page 47 of 39

41	Last Month (history 1) Power Factor	YES	YES	
42	R Phase Voltages (Vr)	YES	YES	
43	Y Phase Voltages (Vy)	YES	YES	
44	B Phase Voltages (Vb)	YES	YES	
45	R Phase Current (Ir)	YES	YES	

TPCODL

Document Title	SPECIFICATION FOR THREE PHASE 4 WIRE WHOLE CURRENT SMART METER WITH BOX		
Document No.	MMG-SMART-002		
		Page 48 of 39	

46	Y Phase Current (Iy)	YES	YES	
47	B Phase Current (Ib)	YES	YES	
48	Signed R phase Power Factor	YES	YES	
49	Signed Y phase Power Factor	YES	YES	
50	Signed B phase Power Factor	YES	YES	
51	Instant Signed Three phase Power Factor	YES	YES	
52	Instant Signed Active Power (kW)	YES	YES	
53	Instant Apparent Power (kVA)	YES	YES	
54	Voltage Sequence (R-Y-B).	YES	YES	
55	Current Sequence (R-Y-B)	YES	YES	
56	Status of Load Switch (connected or	YES	YES	
57	Last token recharge amount	YES	YES	Applicable for "Prepayment meter" mode
58	Last token recharge Date & time	YES	YES	
59	Total amount at last recharge	YES	YES	
60	Current balance amount	YES	YES	
61	Current balance time	YES	YES	
62	High Resolution kWh (Import/Forwarded)	YES	YES	
63	High Resolution kVAh (Import/Forwarded)	YES	YES	
64	High Resolution kWh -Export	YES	YES	Applicable for "net meter" mode
65	High Resolution kVAh -Export	YES	YES	
66	High Resolution kVArh Lag \Q1	YES	YES	
67	High Resolution kVArh Lead\Q4	YES	YES	
68	High Resolution kVArh Lead \Q2	YES	YES	Applicable for "net meter" mode
69	High Resolution kVArh Lag \Q3	YES	YES	
70	Magnetic Tamper count	--	YES	
71	Latest Magnetic tamper occurrence date	--	YES	
72	Latest Magnetic tamper occurrence Time	--	YES	
73	ESD Tamper count	--	YES	
74	Latest ESD tamper occurrence date	--	YES	
75	Latest ESD tamper occurrence time	--	YES	
76	2 nd Last Month (history 2) kWh	--	YES	
77	2 nd Last Month (history 2) kVAh	--	YES	
78	2 nd Last Month (history 2) MD kW	--	YES	
79	2 nd Last Month (history 2) MD kVA	--	YES	
80	2 nd Last Month (history 2) Average PF	--	YES	
81	2 nd Last Month (history 2) kWh (Export)	--	YES	Applicable for "net meter" mode
82	2 nd Last Month (history 2) kVAh (Export)	--	YES	
83	2 nd Last Month (history 2) MD kW (Export) with	--	YES	
84	2 nd Last Month (history 2) MD kVA (Export)with	--	YES	
85	Cumulative MD-KW	--	YES	
86	Cumulative MD-KVA	--	YES	
87	Self-diagnostic check	--	YES	
88	Rising Demand in KW with elapsed time	--	YES	
89	Rising Demand in KVA with elapsed time	--	YES	
90	Cover Open tamper count	--	YES	
91	Cover Open occurrence date of very first event	--	YES	
92	Cover Open occurrence time of very first event	--	YES	
93	Relay Count of Connect	--	YES	

TPCODL

Document Title	SPECIFICATION FOR THREE PHASE 4 WIRE WHOLE CURRENT SMART METER WITH BOX	
Document No.	MMG-SMART-002	
		Page 49 of 39

94	Relay connect Date & Time of Last Occurrence	--	YES	
95	Relay Count of disconnect	--	YES	
96	Relay disconnect Date & Time of Last	--	YES	
97	Current month power On duration in min	--	YES	
98	RTC Status	--	YES	
99	RTC Battery Status	--	YES	
100	NVM (Memory) Status	--	YES	
101	NIC card status	--	YES	
102	Signal strength (CSQ value)	--	YES	
103	Meter display firmware version number	--	YES	