

Format for Pre-Bid Queries

Tender Reference No	TPCODL/P&S/1000000107/2020-21
Tender Name	Raise Contract for Supply of 11kV & 33kV CT
Bidder Name :	

Note :- Pre-Bid Query has to be sent in editable Excel file format only

Sl. No.	Detailed Reference to TPCODL Technical Document. Please specify Document No./ Clause No./ Para No.	Description as per Bid Document	Remarks - Query / Clarification	TPCODL Response
1				
1	Scope of Supply is as per Price Bid/ BOQ of TPCODL.		Please confirm the ratio and number of secondary core(s) as per Price Bid.	Pl refer Latest Tender Revision
2	If bidder want to submit bid for package 1 or package 2 then amount of EMD will be same or will be reduced.		Please confirm the amount of EMD if submitted only one package.	EMD amount shall be 50,000.00 in all the cases
3	If technical specification fault level shown as 25kA for 3 sec and short circuit ratio 25KA for 3 sec.		Please confirm the short circuit ratio, we assume i.e. 25 kA for 3 sec.	25KA for 3 sec
4	If technical specification No of phases written as 3 as well in CT type Single phase CT mentioned.		Please confirm the QTY shown in BOQ/ Price bid are of three or single phase per unit.	Single Phase
5	Annexure 1 page 15 of B0 Schedule of items.	Release order shall be issued as per requirement of TPCODL.	Kindly let us know minimum lot of quantity of CT whether it will be assorted units. How the inspection will be done?	Release order shall be issued as per requirement of TPCODL.
6	Clause No 1.18 terminals & connectors pg no 20 of B0	Dielectric solder less clamp type, rigid type terminal connectors, suitable for maximum conductor size shall be 20mm	Please provide specific drawing	Conductor Size upto 20mm. Detail drawing in Engineering Stage. Size of CT Sout is required from CT Manufacturer
7	Clause no 5 prices, rates, taxes pg no 13 of B0 line no 5	Transportation to TPCODL store/site and unloading and delivery at TPCODL store/site	We consider transportation to TPCODL, Shuntchewar/cuttak stores, unloading to your account.	Material unloading shall be in BA scope
8	Cl.No. 1.7(d), P.No 7	Bidder must have Type Test Reports containing drawings approved by concerned Type Testing Agency for offered materials, for Type Tests conducted at CPRI/ EMD or any other independent lab. Accredited Laboratory during last 5 Years. Copy of such Type Test Reports are to be furnished along with the Technical Bid of offered	We inform you that, type test reports undertaken letter to be submitted along with Bid. Type tests will be conducted the offered materials, at a desired laboratory as specified in the technical specification and shall furnish the type test reports to the TPCODL, authorities at the time of inspection of equipment/materials. Please review and accept the same.	Accepted
9	Cl.No.7.3 ,P.No: 13	Release Orders shall be placed against the awarded bid Contract by TPCODL as and when the requirements arise & Delivery within 30 days from RO	Please check/confirm delivery period required within 60 days from RO/Date of Drawings approval. Please review and amend the same.	Delivery time would be within 45 days from the date of drawing approval
	As per Technical Specification clause 1.10	The tank will be finished with min. 2 coats of zinc rich epoxy paint externally. The inner surface shall be painted with oil resistance white enamel paint. All frous terminals, exposed to atmosphere shall be hot dipped galvanized.	Please confirm whether your requirement is painted or Hot Dip Galvanized.	This shall be as per Tender Specification.
	As per Tender Documents special condition of contract clause 7.3	Delivery Period shall be 30 days from date of receipt of RO.	Delivery will be 60 days from receipt of RO. 1. Procurement of raw material - 15 days. 2. Manufacturing & Testing - 30 days. 3. LD from TPCODL - 5 days 4. Transit Time - 8 days. 5. POI - 3 days. Total - 60 days	Delivery time would be within 45 days from the date of drawing approval
	Technical Specification	GTP format not found in Technical Part of Tender documents.	Please provide GTP format so that GTP can be filled and uploaded with on line tender	Available in corrigendum
	Technical Specification	Mounting Details	Kindly intimate Mounting details	It shall be done During Detailed Engineering
	As per Annexure FVA ACCEPTANCE FORM FOR PARTICIPATION IN REVERSE AUCTION EVENT part no. 12	The original price bids of the bidders shall be reduced on pro-rata basis against each line item based on the final all-inclusive price offered during conclusion of the auction event for arriving at Contract amount.	Instead of allowing us to bid only the total package price, kindly allow us to submit bid against each line item.	Pls adhere the tender requirement
	As per Tender documents of clause no. 7.1. Special Conditions of Contract	Business Associate (BA) shall submit applicable Performance Bank Guarantee as per GCC within 30 days of issuance of order. PBG applicable shall be 10% of Order Value. PBG submitted, shall be released after completion of applicable guarantee period plus one month.	We have limited BCI limit, kindly allow submitting the PBG each RO.	Pls adhere the tender requirement
	As per tender documents of clause no. 7.3 delivery timelines	Release Orders shall be placed against the awarded bid Contract by TPCODL as and when the requirements arise & Delivery within 30 Days from RO.	Delivery will be 90 days from receipt of RO. Justification:- 1. procurement of raw material-15days 2. manufacturing & Testing-45 days 3. LD from TPCODL-12 days 4. POI- 8 days 5. transit time-10 days Total-90 days Substantially date of offer of material for inspection be taken as date of delivery for LD calculation purpose.	Delivery time would be within 45 days from the date of drawing approval
10				
Package 2	Detailed Reference to TPCODL Technical Document. Please specify Document No./ Clause No./ Para No.	Description as per Bid Document	Remarks - Query / Clarification	TPCODL Response
1	Clause No. 2.1	PI Clause	PI clause may kindly be made applicable as the tender is for a period of 1 Year.	Not applicable
2	Clause No. 7.3	Delivery Timelines	Supply of material shall be made as per monthly capacity	Full RO quantity has to be supplied
3	As per Technical Parameters of CT of clause no. 1.4	11kV CT Basis - 300-600/1	Pl refer to the core details of 11kV CT of ratio 300-600/1 as it is not mentioned in TS.	Pl refer Latest Tender Revision
4	As per Tender documents of clause no. 3.9 Type Tests (if applicable)	The type tests specified in TPCODL specifications should have been carried out either five years prior to the date of opening of technical bids and test reports are to be submitted along with the bids. If type tests carried out are not within the five years prior to the date of bidding, the bidder will arrange to carry out type tests specified, at his cost. The decision to accept/reject such bids rests with TPCODL.	Instead of 5 years, type tests up to 7 years may be accepted as per CEA guidelines may 2020 (CEA guidelines copy enclosed)	Accepted