

Pre-Bid Queries Response

| | |
|---------------------|--|
| Tender Reference No | TPCODL/P&S/1000000116/2020-21 |
| Tender Name | Rate Contract for Supply of 11kV & 33kV Isolator |
| Bidder Name : | |

| Sr. No. | Detailed Reference to TPCODL Technical Document. Please specify Document No / Clause No / Page No | Description as per Bid Document | Remarks - Query / Clarification | TPCODL Response |
|-----------|---|--|--|--|
| 1 | 2 | 3 | 4 | 5 |
| Package-1 | | | | |
| 1 | Tender_Doc, Page No-107, Clause No-6.4 | Arcing contacts/Horn: Arcing contacts are not required. Auxiliary switches : Auxiliary switches are not required | Whether Arcing Horn and Auxiliary contacts will be provided for 11KV & 33KV Isolators by us or not? Please Confirm. | Aux Contact : Required. Arcing Horns : Required |
| 2 | Tender_Doc, Page No-109, Clause No-6.10 | Each isolator shall be provided with a mechanically driven auxiliary switch with all necessary contacts for control, indication and interlocking purposes and with six normally open and six normally closed spare contacts. | Whether Arcing Horn and Auxiliary contacts will be provided for 11KV & 33KV Isolators by us or not? Please Confirm. | Aux Contact : Required. Arcing Horns : Required |
| 3 | Tender_Doc, Page No-88, Clause No-4.0, Sl. No. 17 | Operating Mechanism Isolator Type-Manual/ Motor Operated Earth Switch-Manual/Motor Operated | Please Clarify whether Isolator Main Switch will be Manual Operated or Motor Operated or Both. Also Please Clarify whether Isolator Earth Switch will be Manual Operated or Motor Operated or Both. As it is very crucial to finalize our product costing. | Non-Motorised |
| 4 | Tender_Doc, Page No-6, Clause No-1.4.4 | Drawing, Type Test details along with a sample of each item as specified at Annexure I (as applicable) | Whether we have to submit a sample of each item to the TPCODL's Office or not? If yes, then please mention the Due date and time of sample submission. | Required |
| 5 | Tender_Doc, Page No-9, Clause No-3.1 | EMD Original Hard Copy shall be delivered at the following address in Envelope clearly indicating Tender Reference/ Enquiry Number, Name of Tender and Bidder Name | Please mention the Due Date & Time of submitting Original Hard Copy of EMD to ther TPCODL's Office. | Latest by 06-11 2021 |
| 6 | | | | |
| 7 | | | | |
| 8 | | | | |
| 9 | | | | |
| 10 | | | | |
| Package-2 | Detailed Reference to TPCODL Technical Document. Please specify Document No / Clause No / Page No | Description as per Bid Document | Remarks - Query / Clarification | TPCODL Response |
| 1 | | | | |
| 2 | | | | |
| 3 | | | | |
| 4 | | | | |