

Tender No : TPCODL/P&S/100000136/2021-22	
Package Name : Rate Contract for Conductor	

Prebid Query				
Sr. No.	Detailed Reference to TPCODL Tender document. Please specify Document No / Clause No / Page No	Description as per Bid Document	Remarks - Query / Clarification	TPCODL RESPONSE
1	2	3	4	5
1	Document No- ENG-GEN-89 Clause No 04, Page No 25 of 135	It is mentioned GTP of Rabbit ACSR Insulated Conductor	Whether tendred item is "Rabbit ACSR Insulated Conductor" or "Rabbit AAAC Insulated Conductor", because as per Sl. No. 06 of Annexure I, Price Schedule it is mentioned as "Conductor 11KV 55 SQ. MM AAAC-Insulated" If it is Rabbit AAAC Insulated Conductor, please attach the detailed specification for the same	Requirement is: 11KV 55 SQ. MM is ACSR Insulated Conductor
2		11KV, 55 Sq.mm. AAAC Insulated Conductor	Technical Specification is not Provided with Tender Documents.	Refer Tender Document: Pg.No: 24/135, Doc.No.ENG-GEN-89, Doc. Title: STP for PVC Insulated Rabbit Conductor
3		AAAC 232 Sq.mm. Panther	Aluminum Strands diameter are wrong & other parameters missing in technical Specification.	Aluminum Strand Dia for 232Sq.mm Panther: 19/3.94MM Refer IS:398,Part-4:1994, Clause.7.1.1(Table-1) & Clause. 7.2.1(Table-2) (i).Cross Section Area of Nominal Dia Wire(Sq.mm): 12.19 SQ.MM (ii).Minimum Breaking Load of each strand after stranding(KN): 3.58KN (iii).Max. DC Resistance of 1Mtr. Length (Ohm) at 20 Deg.C: 0.002746 (iv). Approx total wt of each strand(Kg/Km): 32.92Kg/Km (v). Minimum Ultimate Breaking Load of Conductor(KN): 68.05KN



TP CENTRAL ODISHA DISTRIBUTION LIMITED
(A Tata Power & Odisha Govt. joint venture)
2nd Floor, IDCO Tower, Janpath Bhubaneswar, Odisha 751022

NIT No.: TPCODL/P&S/1000000136/2021-22

Annexure-I, Price Schedule

Sl No	Item Description	Qty	UOM	Rate (Rs)	Amount (Rs)	GST Amount(Rs)	Total with GST (Rs)
1	Conductor- 100 SQR MM AAAC	Km	5				
2	Conductor COYOTE AAAC 148 SQMM	Km	300				
3	Conductor- 232 SQR MM AAA	Km	250				
4	Conductor- 55 SQR MM AAAC	Km	5				
5	Conductor- 80 SQR MM AAA	Km	5				
6	Conductor 11KV 55 SQ. MM ACSR-Insulated	Km	20				

NOTE:

- i) All rates are to be quoted on delivered basis at TPCODL Store -Cuttack or Bhubaneswar, Odisha, and should be inclusive of freight, insurance, loading & unloading, handling charges and any other charges which may be applicable.
- ii) The overall period of the rate contract shall be for a period of 1 year. Release order shall be issued as per requirement of TPCODL. Rates will remain firm and fixed during the rate contract validity of 1 year.
- iii) The bids will be evaluated commercially on itemwise lowest cost.
- iv) The bidders are advised to quote prices strictly in the above format. Failing to do so, bids are liable for rejection.
- v) The bidder must fill each and every column of the above format. Mentioning "extra/inclusive" in any of the column may lead for rejection of the price bid.
- vi) No cutting/ overwriting in the prices is permissible.
- vii) Quantities mentioned above is for evaluation purpose only and not guaranteed. Quantities may change as per actual requirements.