

**Pre-Bid Queries: " Rate Contract for supply of Meter Box for SMART DT Meters) "
(Tender no. - TPCODL/ P&S/ 1000000142/ 2021-22)**

S No	Page No.	Tender Clause	Content of the Clause	Bidder Query	TPCODL Reply
1	30 of 140	4.0, B,22	Material of meter box:- Material a) Base : Virgin Polycarbonate equivalent to Lexan 943 A transparent b) Cover : Virgin Polycarbonate equivalent to Lexan 943 A transparent	All the connection and meter are mounted on a bakelite and nothin is visible from the back, we request you to kindly accept base in Grey colour instead of transparent and add PC grade Markolon 6557.	Specification to be complied.
2	30 of 140	5.0, 5.2	Overall size of meter box:- The required internal dimension of the meter box shall be: Length-670 mm, Breadth-335 mm and Height -250mm with + 10% tolerance.	To accommodate all the components, we will supply meter box of following outer size: Length- 700 mm +/- 5% Breadth- 370 mm +/- 5% Height- 270 mm +/- 5%	Noted
3	32 of 140	5.0, 5.2	Resin cast base unit:- 2 couplers (8 unit and 4 unit) The bottom side of resin cast base unit will have two couplers (8 way and 4 way).	For easy of assembly at installation sight we will provide 2 couplers (6 units and 6 units)	Noted
4	38 of 140	13	Tender sample:- Bidders are required to submit one no. of sample of complete kit along with box and one set of CTs (as applicable), at MMG Laboratory, TPCODL during tender submission, for technical evaluation	12 core cable is manufactured against order and the same is not available with us. Please allow us to submit the tender sample with 10 core cable, 3 nos. of CT and 1 box.	3nos. CTs & 1no. Neutral CT is required for DT Metering & accordingly 12core cable will be required in the event of order.